

Winston 12 Month Average and Total Run Times. (As of the end of Aug 2010)

	Sep 2009	Oct 2009	Nov 2009	Dec 2009	Jan 2010	Feb 2010	Mar 2010	Apr 2010	May 2010	Jun 2010	July 2010	Aug 2010	12 Month Total	12 Month Average	
1 Run	1.4	4.9	3.9	2.8	13.4	1.1	3.0	1.6	9.3	3.1	1.6	11.2	57.4	4.8	1 Run
1 Load	0.9	3.3	2.4	0.7	8.8	0.2	0.8	1.1	7.7	1.6	0.7	6.7	34.9	2.9	1 Load
2 Run	1.4	4.8	3.9	3.3	11.0	0.7	3.0	1.6	9.3	3.2	2.8	9.5	54.7	4.6	2 Run
2 Load	0.9	3.3	2.4	2.2	10.0	0.2	0.8	1.1	7.7	1.6	1.3	6.4	38.0	3.2	2 Load
3 Run	1.4	4.7	3.9	3.3	12.8	0.7	3.1	1.6	9.3	3.1	2.3	9.5	55.7	4.6	3 Run
3 Load	0.9	3.1	2.3	2.2	10.0	0.2	0.8	1.1	7.7	1.6	1.3	6.4	37.7	3.1	3 Load
4 Run	1.4	4.8	3.9	3.2	12.7	0.7	3.1	1.6	9.2	2.9	2.3	9.4	55.3	4.6	4 Run
4 Load	0.9	3.3	2.3	2.2	9.9	0.2	0.8	1.1	7.7	1.4	1.2	6.3	37.3	3.1	4 Load
5 Run	1.4	4.8	3.9	3.2	11.0	0.8	3.1	2.1	9.2	3.1	2.3	9.4	54.3	4.5	5 Run
5 Load	0.9	3.3	2.3	2.2	9.9	0.3	0.8	1.1	7.6	1.6	1.3	6.3	37.5	3.1	5 Load
6 Run	1.4	5.6	3.9	2.5	11.0	0.8	3.0	2.7	9.0	2.2	2.3	6.8	51.2	4.3	6 Run
6 Load	0.9	3.5	2.1	1.4	9.9	0.3	0.7	1.6	7.5	1.2	1.2	4.6	35.1	2.9	6 Load
7 Run	0.0	5.6	3.8	2.5	10.9	0.7	2.7	2.7	9.0	2.2	2.3	6.7	49.0	4.1	7 Run
7 Load	0.0	2.8	2.3	1.5	10.6	0.2	0.7	1.6	7.4	1.2	1.2	4.6	34.2	2.8	7 Load
8 Run	0.0	5.6	3.8	1.8	12.6	0.7	2.7	2.6	9.0	2.2	2.3	6.7	50.0	4.2	8 Run
8 Load	0.0	3.5	2.1	0.8	7.3	0.2	0.7	1.6	7.5	1.2	1.2	4.6	30.7	2.6	8 Load
9 Run	1.4	5.5	3.7	2.5	10.9	0.7	2.7	2.6	9.0	2.2	2.2	6.6	50.1	4.2	9 Run
9 Load	0.9	3.5	2.1	1.4	9.8	0.2	0.7	1.6	7.4	1.1	1.2	4.6	34.4	2.9	9 Load
10 Run	1.4	5.5	3.7	2.0	10.9	0.7	2.7	2.6	8.0	2.2	2.2	6.7	48.6	4.0	10 Run
10 Load	0.9	3.5	2.2	0.8	9.9	0.2	0.7	1.6	6.9	1.1	1.2	4.6	33.4	2.8	10 Load
11 Run	1.4	4.8	2.3	3.3	12.7	0.7	2.8	1.6	9.3	3.1	2.3	8.0	52.4	4.4	11 Run
11 Load	0.9	3.3	1.2	2.2	10.0	0.2	0.8	1.1	7.7	1.6	1.3	5.4	35.7	3.0	11 Load
12 Run	1.4	0.0	0.0	2.8	11.0	0.7	2.8	1.6	7.4	3.2	2.3	7.8	41.0	3.4	12 Run
12 Load	0.9	0.0	0.0	2.2	9.9	0.2	0.8	1.1	6.4	1.6	1.3	5.5	29.8	2.5	12 Load
13 Run	1.4	4.8	2.3	3.3	12.7	0.7	2.8	1.6	8.8	3.2	2.3	8.0	51.8	4.3	13 Run
13 Load	0.9	3.3	1.3	2.2	9.9	0.2	0.8	1.1	7.3	1.6	1.3	5.4	35.2	2.9	13 Load
14 Run	1.4	4.8	2.3	3.3	11.0	0.7	2.8	1.6	9.2	3.2	2.3	6.5	49.0	4.1	14 Run
14 Load	0.9	3.2	1.3	2.2	9.9	0.2	0.8	1.1	7.7	1.6	1.2	4.3	34.4	2.9	14 Load
15 Run	1.4	4.8	2.3	3.3	11.2	0.7	2.8	1.6	9.2	3.2	2.3	6.3	49.0	4.1	15 Run
15 Load	0.9	3.2	1.1	2.2	9.9	0.2	0.8	1.1	7.7	1.6	1.2	4.3	34.1	2.8	15 Load
16 Run	1.4	5.6	2.3	1.4	12.0	0.7	2.8	2.7	9.0	2.2	2.3	6.8	49.1	4.1	16 Run
16 Load	0.9	3.5	1.2	1.5	9.3	0.2	0.7	1.6	7.5	1.2	1.2	4.3	33.1	2.8	16 Load
17 Run	1.4	5.6	2.2	2.5	7.8	0.1	1.9	2.6	9.0	2.2	2.2	5.2	42.9	3.6	17 Run
17 Load	0.9	3.5	1.2	1.5	6.2	0.0	0.7	1.6	7.5	1.2	1.2	3.6	29.1	2.4	17 Load
18 Run	1.4	5.5	2.2	2.5	10.9	0.7	2.7	2.6	9.0	2.2	2.2	5.2	47.2	3.9	18 Run
18 Load	0.9	3.4	1.1	1.5	9.9	0.2	0.7	1.5	7.4	1.1	1.2	3.6	32.5	2.7	18 Load
19 Run	1.4	5.5	2.6	2.5	5.4	0.7	2.7	2.6	9.0	2.2	2.2	5.2	42.1	3.5	19 Run
19 Load	0.9	3.4	1.1	1.5	3.4	0.2	0.7	1.6	7.4	1.2	1.2	3.6	26.1	2.2	19 Load
20 Run	1.4	5.5	1.7	2.4	10.9	0.7	2.7	2.6	9.0	2.2	2.2	6.3	47.6	4.0	20 Run
20 Load	0.8	3.3	1.1	1.3	9.7	0.2	0.7	1.5	7.4	1.1	1.2	4.2	32.6	2.7	20 Load
Total Run	25.2	98.8	58.7	54.2	222.7	14.2	56.0	43.1	179.1	53.2	45.3	147.7	998.3	83.2	Total Run
Total Load	15.8	63.2	33.1	33.9	184.3	3.8	14.8	27.0	149.0	27.3	24.2	99.3	675.8	56.3	Total Load

OOS For Maintenance	998.3 Check
Not Called For	675.8 Sum

08 Current 12 Avg & Total Indv Eng Aug 2010

**Total Run Hours for All 20 Units**

**Compliance Assurance Demonstration Method**  
S.C. A.28.

Calculated tons of NOx
<b>5.790329</b> tons of NOx over past 12-month period

Past 12 Months	
Peak Load	100% Load Hours (Gas)
0	0

**NOTES:**

\*Did not operate any of the units in *Peak Mode* over the past 12-months

\*\*Did not operate any of the units on *Natural Gas* over the past 12-months

357

**TransMontaigne  
TAMPA, FL TERMINAL**

DESCRIPTION: Tampa Tank 1 ULSD  
SAMPLE DATE: 5-28-10  
REPORT DATE: 6-7-10  
SUBMITTED BY: Tampa Terminal

**CERTIFICATE OF ANALYSIS**

METHOD

COMP.  
RESULT

SULFUR PPM

D7039

Tank 1  
7.0 ppm



BY: Marie F. Calhoun, QC Manager


358 TO 370

**TransMontaigne  
TAMPA, FL TERMINAL**

DESCRIPTION: Tampa Tank 1 ULSD  
SAMPLE DATE: 6-4-10  
REPORT DATE: 6-9-10  
SUBMITTED BY: Tampa Terminal

**CERTIFICATE OF ANALYSIS**

	<u>METHOD</u>	<u>COMP. RESULT</u>
SULFUR PPM	D7039	Tank 1 6.0 ppm



BY: Marie F. Calhoon, QC Manager