

=====
Daily Calibration Summary
Florida Power
DeBary Unit P9
=====

DAHS Software Model: MODEL 20/20
DAHS Software Serial Number: 2020SPV75DB
Report Period
Day: 06/14/2005

ZERO CAL

SPAN CAL

=====
TIME ZERO %CE REF TIME SPAN %CE REF
NOX Hi 8:34 0.00 0.000P 0.00 8:43 176.10 0.100P 176.30
NOX 8:34 0.00 0.000P 0.00 8:39 27.30 0.010P 27.40
CO2 8:34 0.00 0.000P 0.00 8:43 7.00 0.200P 7.20
=====

Today's Date: 06/14/2005
Time: 10:03:33

%CE = Percent Calibration Error

P - Calibration Passed F - Calibration Failed

=====
 Daily Calibration Summary
 Florida Power
 DeBary Unit P8
 =====

DAHS Software Model: MODEL 20/20
 DAHS Software Serial Number: 2020SPV75DB
 Report Period
 Day: 06/14/2005

ZERO CAL

SPAN CAL

	TIME	ZERO	%CE	REF	TIME	SPAN	%CE	REF
NOX Hi	7:59	-0.20	0.100P	0.00	8:08	178.40	1.050P	176.30
	8:33	-0.20	0.100P	0.00	8:37	178.20	0.950P	176.30
	8:44	-0.10	0.050P	0.00	8:49	178.40	1.050P	176.30
NOX	7:59	0.00	0.000P	0.00	8:03	26.50	0.090P	27.40
	8:33	0.00	0.000P	0.00				
	8:44	0.10	0.010P	0.00				
CO2	7:59	0.40	0.400P	0.00	8:08	7.30	0.100P	7.20
	8:33	0.00	0.000P	0.00	8:37	7.10	0.100P	7.20
	8:44	0.10	0.100P	0.00	8:49	7.20	0.000P	7.20

Today's Date: 06/14/2005
 Time: 10:01:11

%CE = Percent Calibration Error

P - Calibration Passed F - Calibration Failed