



ENTERED FEB 04 2008

Wyp-6 2/4/08

RECEIVED

JAN 30 2008

DEP Central Dist.

January 29, 2008

Mr. James Bradner
Florida Department of Environmental Protection
Central District
3319 Maguire Boulevard, Suite 232
Orlando, FL 32803-3767

Re: Annual Statement of Compliance
Florida Power DeBary Peaker Facility
Facility ID No. 1270028

Dear Mr. Bradner

As required by Rule 62-213.440(3)(a)(2), Progress Energy Florida submits the attached 2007 Annual Statement of Compliance for the above-referenced facility.

Please contact Dave Meyer at (727) 820-5295 or Mark Tylec at (386) 668-5103 if you have any questions or would like additional information.

Sincerely,

A handwritten signature in black ink, appearing to read 'Reginald Anderson', written over a horizontal line.

Reginald Anderson
Plant Manager

cc: Ms. Roselyn Hughes, EPA Region IV

RECEIVED
JAN 30 2008
DEP Central Dist.

STATEMENT OF COMPLIANCE - TITLE V SOURCE

REASON FOR SUBMISSION (Check one to indicate why this statement of compliance is being submitted)

Annual Requirement Transfer of Permit Permanent Facility Shutdown

REPORTING PERIOD*	REPORT DEADLINE**
January 1 through December 31 of 2007 (year)	March 1, 2008

*The statement of compliance must cover all conditions that were in effect during the indicated reporting period, including any conditions that were added, deleted, or changed through permit revision.

**See Rule 62-213.440(3)(a)2., F.A.C.

Facility Owner/Company Name: Progress Energy Florida

Site Name: DeBary Facility ID No. 1270028 County: Volusia

COMPLIANCE STATEMENT (Check only one of the following three options)

A. This facility was in compliance with all terms and conditions of the Title V Air Operation Permit and, if applicable, the Acid Rain Part, and there were no reportable incidents of deviations from applicable requirements associated with any malfunction or breakdown of process, fuel burning or emission control equipment, or monitoring systems during the reporting period identified above.

B. This facility was in compliance with all terms and conditions of the Title V Air Operation Permit and, if applicable, the Acid Rain Part; however, there were one or more reportable incidents of deviations from applicable requirements associated with malfunctions or breakdowns of process, fuel burning or emission control equipment, or monitoring systems during the reporting period identified above, which were reported to the Department. For each incident of deviation, the following information is included:

1. Date of report previously submitted identifying the incident of deviation.
2. Description of the incident.

C. This facility was in compliance with all terms and conditions of the Title V Air Operation Permit and, if applicable, the Acid Rain Part, EXCEPT those identified in the pages attached to this report and any reportable incidents of deviations from applicable requirements associated with malfunctions or breakdowns of process, fuel burning or emission control equipment, or monitoring systems during the reporting period identified above, which were reported to the Department. For each item of noncompliance, the following information is included:

1. Emissions unit identification number.
2. Specific permit condition number (note whether the permit condition has been added, deleted, or changed during certification period).
3. Description of the requirement of the permit condition.
4. Basis for the determination of noncompliance (for monitored parameters, indicate whether monitoring was continuous, i.e., recorded at least every 15 minutes, or intermittent).
5. Beginning and ending dates of periods of noncompliance.
6. Identification of the probable cause of noncompliance and description of corrective action or preventative measures implemented.
7. Dates of any reports previously submitted identifying this incident of noncompliance.


For each incident of deviation, as described in paragraph B. above, the following information is included:

1. Date of report previously submitted identifying the incident of deviation.
2. Description of the incident.

STATEMENT OF COMPLIANCE - TITLE V SOURCE

RESPONSIBLE OFFICIAL CERTIFICATION

I, the undersigned, am a responsible official (Title V air permit application or responsible official notification form on file with the Department) of the Title V source for which this document is being submitted. With respect to all matters other than Acid Rain program requirements, I hereby certify, based on the information and belief formed after reasonable inquiry, that the statements made and data contained in this document are true, accurate, and complete.



(Signature of Title V Source Responsible Official)


1-29-08
(Date)

Name: Reginald Anderson

Title: Plant Manager

DESIGNATED REPRESENTATIVE CERTIFICATION (only applicable to Acid Rain source)

I, the undersigned, am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.



(Signature of Acid Rain Source Designated Representative)

1-24-08
(Date)

Name: J. Michael Kennedy

Title: Principal Environmental Specialist

{Note: Attachments, if required, are created by a responsible official or designated representative, as appropriate, and should consist of the information specified and any supporting records. Additional information may also be attached by a responsible official or designated representative when elaboration is required for clarity. This report is to be submitted to both the compliance authority (DEP district or local air program) and the U.S. Environmental Protection Agency(EPA) (U.S. EPA Region 4, Air and EPCRA Enforcement Branch, 61 Forsyth Street, Atlanta GA 30303).}

Progress Energy Florida Debarry Peakers

Deviations From Permit Conditions

During January 1st to December 31st 2007, the following deviations occurred. These were previously summarized in the quarterly excess emissions reports.

<u>Date</u>	<u>Time</u>	<u>Duration</u>	<u>Parameter</u>	<u>Description</u>
Unit P1	NONE			
Unit P2	NONE			
Unit P3	NONE			
Unit P4	NONE			
Unit P5	NONE			
Unit P6	NONE			
Unit P7				
03/02/07	15:00	1:00	NOx	Operator Maintenance
Unit P8				
10/16/07	11:00	1:00	NOx	Operator Maintenance
10/16/07	15:00	1:00	NOx	Operator Maintenance
Unit P9				
03/02/07	15:00	1:00	NOx	Operator Maintenance
Unit P10	NONE			

Additional events were reported to the Department at the time of occurrence and are documented in detail in the attached previously-submitted correspondence. These events occurred with respect to the following permit condition:

Permit Condition: **C.1.** Excess emissions resulting from startup, shutdown, or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]