

FUEL METER PROVING CERTIFICATION

STATION: 8950 SW 232 St DATE: 10/12/10
Black Point
Miami Dade Water + Sewer

UNIT NO. / LOCATION OF METER <u>Tank Farm/Loadrack</u>	REC. MAN. <u>VIR</u>	MODEL NO. <u>788700-030</u>	SERIAL NO. <u>9902037069</u>	PRINTER INSTALL — YES <input checked="" type="checkbox"/> NO
TOTALIZER-START: <u>666225</u>	TOTALIZER-FINISH: <u>666527</u>	TEMPERATURE °F <u>80</u>		
METER MANUFACTURER <u>L/C</u>	MODEL NO. <u>M-15-1</u>	SERIAL NO. <u>64858</u>	RATED FLOW - G.P.M. MIN. <u>20</u> MAX. <u>200</u>	TYPE OF FUEL JETA _____ GAS _____ AVGAS _____ DIESEL <input checked="" type="checkbox"/> OTHER _____
ALL SEALS INTACT BEFORE TEST <input checked="" type="checkbox"/> YES — NO	SEAL NUMBERS / LETTERS BEFORE TEST <u>STRC/ mps</u>	PROVER- <u>100</u>		

50 gal. SN #795
 100 gal. SN #4902
 525 gal. SN #130854
 1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	READINGS - UNITS / TENTHS			ADJUSTMENTS	REMARKS
		CU. IN PROVER	METER REGISTER	CU. IN DIFFERENCE		
1	70	-4	100.1			
2	120	+28	100.2	+5		
3		+68	100.3	0		
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						

ADJUSTMENT REQUIRED: — YES <input checked="" type="checkbox"/> NO	IF YES, POSITION OF ADJUSTER BEFORE TEST <u>SAME</u>	POSITION OF ADJUSTER AFTER TEST <u>N/A</u>
METER ADJUSTED & REGISTER SEALED AFTER TEST: <input checked="" type="checkbox"/> YES	SEAL NUMBER / LETTERS AFTER TEST <u>STRC/ mps</u>	STATE WEIGHTS & MEASURE REPRESENTATION PRESENT: — YES: <input checked="" type="checkbox"/> NO

ERROR TABLE ERROR % OF 1%	U.S. GALLON PROVER																
	1000		750		500		100		50		5						
	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.			
1/10	1	1.	231	3/4	.75	173	1/2	.5	115	1/10	.1	23	1/20	.05	11	1/200	.005

NOTES:

NAME OF MECHANIC/SEALER: <u>RS</u>	SOUTHERN TRUCK REPAIR & CALIBRATION LLC. 18310 SW 89th Court • Miami, Florida 33157 Ph: 305-302-8334 • Fax: 305-254-8017
---------------------------------------	---