

NS10-425

FUEL METER PROVING CERTIFICATION

UNIT NO. / LOCATION OF METER Pump Room			REC. MAN. V/R	MODEL NO. 788700-007	SERIAL NO. 101169285	STATION: MOWAS Black Point	DATE: 10/25/10
TOTALIZER-START: 375542.5		TOTALIZER-FINISH: 375702.9		TEMPERATURE °F 85			
METER MANUFACTURER WALC	MODEL NO. M-7-7	SERIAL NO. 410919	RATED FLOW - G.P.M. MIN. 10 MAX 10		TYPE OF FUEL JETA _____ GAS _____ AVGAS _____ DIESEL <input checked="" type="checkbox"/> _____ OTHER <input checked="" type="checkbox"/> _____		
ALL SEALS INTACT BEFORE TEST <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	SEAL NUMBERS / LETTERS BEFORE TEST RS/STEC		PROVER- 50				

50 gal. SN #795
 100 gal. SN #4902
 525 gal. SN #130854
 1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	READINGS - UNITS / TENTHS			ADJUSTMENTS	REMARKS
		CU. IN PROVER	METER REGISTER	CU. IN DIFFERENCE		
1	50	+30	50.22	-15		DRY
2		-5	50.08	-11		
3		-15	50.0	-15		
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						

ADJUSTMENT REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	IF YES, POSITION OF ADJUSTER BEFORE TEST _____	POSITION OF ADJUSTER AFTER TEST _____
---	---	--

METER ADJUSTED & REGISTER SEALED AFTER TEST: <input checked="" type="checkbox"/> YES	SEAL NUMBER / LETTERS AFTER TEST SAMP	STATE WEIGHTS & MEASURE REPRESENTATION PRESENT: <input type="checkbox"/> YES: <input checked="" type="checkbox"/> NO
--	---	--

ERROR TABLE ERROR % OF 1%	U.S. GALLON PROVER																
	1000		750		500		100		50		5						
	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.			
1/10	1	1.	231	3/4	.75	173	1/2	.5	115	1/10	.1	23	1/20	.05	11	1/200	.005

NOTES:

NAME OF MECHANIC/SEALER:
[Signature]

SOUTHERN TRUCK REPAIR & CALIBRATION LLC.
 18310 SW 89th Court • Miami, Florida 33157
 Ph: 305-302-8334 • Fax: 305-254-8017