

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 1 Hour

Type: Block

Report Period: 03/08/2011 00:00 Through 03/08/2011 13:04

Time Online Criteria: 1 minute(s)

Source Parameter)Unit(UNIT1			UNIT2		
	CO#/MM (LB/MMBTU)	NOX#/MM (LB/MMBTU)	SO2#/MM (LB/MMBTU)	CO#/MM (LB/MMBTU)	NOX#/MM (LB/MMBTU)	SO2#/MM (LB/MMBTU)
03/08/11 00:00	0.044	0.149	0.015	0.187	0.149	0.011
03/08/11 01:00	0.046	0.154	0.013	0.187	0.150	0.011
03/08/11 02:00	0.038	0.142	0.006	0.129	0.147	0.007
03/08/11 03:00	0.039	0.144	0.014	0.153	0.147	0.010
03/08/11 04:00	0.035	0.147	0.014	0.147	0.149	0.010
03/08/11 05:00	0.112C	0.149C	0.014C	0.257	0.147	0.015
03/08/11 06:00	0.134C	0.169C	0.018C	0.374C	0.164C	0.016C
03/08/11 07:00	0.152	0.170	0.020	0.606C	0.148C	0.014C
03/08/11 08:00	0.123	0.151	0.045	0.549	0.142	0.012
03/08/11 09:00	0.141	0.151	0.037	1.087	0.174	0.008
03/08/11 10:00	0.236	0.146	0.031	0.636	0.144	0.010
03/08/11 11:00	0.208	0.147	0.017	0.231	0.150	0.011
03/08/11 12:00	FI	FI	FI	FI	FI	FI
03/08/11 13:00	FI	FI	FI	FI	FI	FI
Average	0.109	0.152	0.020	0.379	0.151	0.011
Minimum	0.035	0.142	0.006	0.129	0.142	0.007
Maximum	0.236	0.170	0.045	1.087	0.174	0.016
Summation	1.308	1.819	0.244	4.543	1.811	0.135
Included Data Points	12	12	12	12	12	12
Total number of Data Points	14	14	14	14	14	14

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 1 Hour

Type: Block

Report Period: 03/08/2011 00:00 Through 03/08/2011 13:04

Time Online Criteria: 1 minute(s)

Source Parameter)Unit(UNIT3		
	CO#/MM (LB/MMBTU)	NOX#/MM (LB/MMBTU)	SO2#/MM (LB/MMBTU)
03/08/11 00:00	0.171	0.142	0.008
03/08/11 01:00	0.180	0.146	0.007
03/08/11 02:00	0.096	0.141	0.002
03/08/11 03:00	0.159	0.132	0.004
03/08/11 04:00	0.171	0.132	0.004
03/08/11 05:00	0.267	0.129	0.009
03/08/11 06:00	0.230	0.122	0.013
03/08/11 07:00	0.273C	0.119C	0.012C
03/08/11 08:00	0.210C	0.112C	0.011C
03/08/11 09:00	0.204	0.109	0.012
03/08/11 10:00	0.213	0.111	0.011
03/08/11 11:00	0.174	0.133	0.006
03/08/11 12:00	FI	FI	FI
03/08/11 13:00	FI	FI	FI
Average	0.196	0.127	0.008
Minimum	0.096	0.109	0.002
Maximum	0.273	0.146	0.013
Summation	2.348	1.528	0.099
Included Data Points	12	12	12
Total number of Data Points	14	14	14

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/08/2011 00:00 Through 03/08/2011 13:04

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/08/11 00:00	3.3	3.4	6.0
03/08/11 00:06	3.4	3.5	6.2
03/08/11 00:12	3.3	3.4	6.0
03/08/11 00:18	6.6	3.7	6.1
03/08/11 00:24	3.6	4.0	6.2
03/08/11 00:30	3.6	3.7	6.2
03/08/11 00:36	3.4	3.7	6.3
03/08/11 00:42	3.5	3.6	6.0
03/08/11 00:48	3.5	3.4	6.1
03/08/11 00:54	3.4	3.3	6.5
03/08/11 01:00	3.4	3.3	6.3
03/08/11 01:06	3.5	3.6	6.3
03/08/11 01:12	3.4	3.6	6.0
03/08/11 01:18	3.7	3.9	6.2
03/08/11 01:24	3.4	3.6	6.4
03/08/11 01:30	3.4	3.6	6.3
03/08/11 01:36	3.3	3.4	6.3
03/08/11 01:42	3.6	4.2	6.4
03/08/11 01:48	3.5	3.9	6.2
03/08/11 01:54	3.6	3.5	11.9
03/08/11 02:00	3.4	2.9	8.6
03/08/11 02:06	3.4	2.6	6.0
03/08/11 02:12	3.3	2.3	5.4
03/08/11 02:18	3.3	2.4	5.2
03/08/11 02:24	3.3	2.3	5.4
03/08/11 02:30	3.3	2.1	5.1
03/08/11 02:36	3.4	2.0	5.0
03/08/11 02:42	3.3	2.1	5.0
03/08/11 02:48	3.4	2.6	5.6
03/08/11 02:54	3.4	2.8	5.8
03/08/11 03:00	3.7	2.8	5.8
03/08/11 03:06	3.5	3.0	5.8
03/08/11 03:12	3.5	2.7	5.7
03/08/11 03:18	3.5	2.8	5.7
03/08/11 03:24	3.6	2.7	5.7
03/08/11 03:30	3.5	2.8	5.8
03/08/11 03:36	3.5	2.8	5.7
03/08/11 03:42	3.5	2.8	5.8
03/08/11 03:48	3.6	2.9	5.9
03/08/11 03:54	3.6	3.1	5.8
03/08/11 04:00	3.6	3.0	5.8
03/08/11 04:06	3.5	3.0	5.8
03/08/11 04:12	3.6	3.0	5.8
03/08/11 04:18	3.5	3.1	5.8
03/08/11 04:24	3.6	2.9	5.7
03/08/11 04:30	3.4	3.0	5.7
03/08/11 04:36	3.4	3.1	5.8
03/08/11 04:42	3.8	3.2	5.6
03/08/11 04:48	3.6	3.0	5.6
03/08/11 04:54	3.6	2.9	5.5
03/08/11 05:00	3.5	3.0	5.7

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/08/2011 00:00 Through 03/08/2011 13:04

Time Online Criteria: 1 minute(s)

Source		UNIT1	UNIT2	UNIT3
Parameter	Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/08/11	05:06	3.5	3.4	5.6
03/08/11	05:12	3.6	3.9	6.2
03/08/11	05:18	4.6	7.3	9.2
03/08/11	05:24	8.4	13.7	10.3
03/08/11	05:30	5.1	8.7	8.0
03/08/11	05:36	7.7	8.7	8.8
03/08/11	05:42	5.5	24.2E	9.5
03/08/11	05:48	5.9	8.4	7.8
03/08/11	05:54	17.2IC	6.2	8.3
03/08/11	06:00	5.0C	7.0	8.3
03/08/11	06:06	6.9	7.2	8.8
03/08/11	06:12	6.1	10.5	11.3
03/08/11	06:18	5.5	8.2	9.5
03/08/11	06:24	5.0	6.7	8.5
03/08/11	06:30	4.7	6.5	8.6
03/08/11	06:36	4.8	6.6	8.2
03/08/11	06:42	4.6	7.9	8.1
03/08/11	06:48	12.1	9.8	9.8
03/08/11	06:54	5.7	17.3IC	8.8
03/08/11	07:00	5.2	8.2C	9.3
03/08/11	07:06	5.0	8.8	9.3
03/08/11	07:12	5.5	8.8	12.2
03/08/11	07:18	5.2	10.1	9.4
03/08/11	07:24	5.5	9.5	9.2
03/08/11	07:30	5.0	8.8	8.8
03/08/11	07:36	4.9	8.2	8.2
03/08/11	07:42	4.8	10.3	8.9
03/08/11	07:48	6.6	8.7	8.1
03/08/11	07:54	6.8	7.0	17.1IC
03/08/11	08:00	4.6	7.5	7.7C
03/08/11	08:06	9.5	7.1	7.8
03/08/11	08:12	9.3	6.8	7.3
03/08/11	08:18	5.4	7.9	8.1
03/08/11	08:24	15.5	10.6	8.6
03/08/11	08:30	8.9	7.6	7.5
03/08/11	08:36	5.8	7.2	7.3
03/08/11	08:42	4.7	8.3	7.8
03/08/11	08:48	4.4	7.8	7.3
03/08/11	08:54	4.4	8.7	7.7
03/08/11	09:00	4.3	13.6	7.3
03/08/11	09:06	4.1	7.4	7.1
03/08/11	09:12	4.5	8.4	7.0
03/08/11	09:18	5.8	7.7	6.6
03/08/11	09:24	4.4	9.9	6.5
03/08/11	09:30	4.3	12.1	7.3
03/08/11	09:36	4.4	7.3	7.4
03/08/11	09:42	4.6	6.7	7.1
03/08/11	09:48	4.1	6.8	7.3
03/08/11	09:54	4.1	9.1	7.2
03/08/11	10:00	4.0	7.9	6.7
03/08/11	10:06	4.0	7.7	7.3

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/08/2011 00:00 Through 03/08/2011 13:04

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/08/11 10:12	4.1	8.7	7.6
03/08/11 10:18	4.2	9.8	9.4
03/08/11 10:24	4.0	8.7	8.0
03/08/11 10:30	4.3	7.8	9.1
03/08/11 10:36	4.2	7.9	7.1
03/08/11 10:42	6.5	7.7	6.9
03/08/11 10:48	6.5	11.5	6.6
03/08/11 10:54	6.3	10.9	7.3
03/08/11 11:00	5.8	7.2	6.5
03/08/11 11:06	5.0	7.9	6.7
03/08/11 11:12	4.8	6.4	8.1
03/08/11 11:18	4.4	10.1	6.7
03/08/11 11:24	4.2	9.6	6.2
03/08/11 11:30	8.6	6.2	5.9
03/08/11 11:36	6.7	13.0	4.9
03/08/11 11:42	4.6	6.2	5.5
03/08/11 11:48	4.4	5.0	4.9
03/08/11 11:54	5.0	4.6	5.0
03/08/11 12:00	8.4	5.1	5.2
03/08/11 12:06	4.0	7.2	4.9
03/08/11 12:12	4.0	4.5	4.7
03/08/11 12:18	4.0	5.2	4.4
03/08/11 12:24	3.7	6.9	4.3
03/08/11 12:30	3.3	4.7	4.5
03/08/11 12:36	3.3	4.2	4.4
03/08/11 12:42	3.3	5.1	4.8
03/08/11 12:48	3.4	4.1	4.7
03/08/11 12:54	F	F	F
03/08/11 13:00	F	F	F
Average	4.7	6.1	6.9
Minimum	3.3	2.0	4.3
Maximum	15.5	24.2	12.2
Summation	595.8	781.8	881.7
Included Data Points	128	128	128
Total number of Data Points	131	131	131

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 1 Hour

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source Parameter Unit(UNIT1			UNIT2		
	CO#/MM (LB/MMBTU)	NOX#/MM (LB/MMBTU)	SO2#/MM (LB/MMBTU)	CO#/MM (LB/MMBTU)	NOX#/MM (LB/MMBTU)	SO2#/MM (LB/MMBTU)
03/07/11 00:00	0.035	0.148	0.008	0.185	0.152	0.009
03/07/11 01:00	0.042	0.151	0.013	0.207	0.146	0.013
03/07/11 02:00	0.050	0.147	0.012	0.221	0.148	0.011
03/07/11 03:00	0.049	0.144	0.012	0.222	0.149	0.012
03/07/11 04:00	0.048	0.157	0.016	0.216	0.149	0.015
03/07/11 05:00	0.043C	0.149C	0.017C	0.201	0.149	0.016
03/07/11 06:00	0.047C	0.149C	0.015C	0.213C	0.148C	0.016C
03/07/11 07:00	0.166	0.177	0.019	0.340C	0.147C	0.010C
03/07/11 08:00	0.203	0.155	0.012	0.315	0.143	0.009
03/07/11 09:00	0.694	0.122	0.011	0.318	0.148	0.006
03/07/11 10:00	0.195	0.150	0.009	0.311	0.148	0.007
03/07/11 11:00	0.584	0.147	0.011	0.264	0.149	0.013
03/07/11 12:00	0.576	0.145	0.010	0.254	0.149	0.018
03/07/11 13:00	0.232	0.165	0.012	0.293	0.149	0.012
03/07/11 14:00	0.388	0.132	0.013	0.256	0.148	0.012
03/07/11 15:00	0.716	0.133	0.013	0.300	0.149	0.011
03/07/11 16:00	0.542	0.137	0.015	0.300	0.149	0.011
03/07/11 17:00	0.352	0.172	0.027	0.253	0.151	0.015
03/07/11 18:00	0.221	0.121	0.018	0.272	0.145	0.015
03/07/11 19:00	0.059	0.134	0.013	0.291	0.150	0.013
03/07/11 20:00	0.054	0.141	0.012	0.238	0.145	0.012
03/07/11 21:00	0.053	0.147	0.011	0.223	0.148	0.012
03/07/11 22:00	0.044	0.144	0.013	0.213	0.148	0.011
03/07/11 23:00	0.042	0.146	0.014	0.197	0.148	0.011
Average	0.226	0.146	0.014	0.254	0.148	0.012
Minimum	0.035	0.121	0.008	0.185	0.143	0.006
Maximum	0.716	0.177	0.027	0.340	0.152	0.018
Summation	5.435	3.513	0.326	6.103	3.555	0.290
Included Data Points	24	24	24	24	24	24
Total number of Data Points	24	24	24	24	24	24

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 1 Hour

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source Parameter Unit		UNIT3		
		CO#/MM (LB/MMBTU)	NOX#/MM (LB/MMBTU)	SO2#/MM (LB/MMBTU)
03/07/11	00:00	0.150	0.146	0.004
03/07/11	01:00	0.189	0.141	0.007
03/07/11	02:00	0.196	0.143	0.006
03/07/11	03:00	0.186	0.144	0.006
03/07/11	04:00	0.188	0.144	0.008
03/07/11	05:00	0.170	0.142	0.009
03/07/11	06:00	0.159	0.143	0.008
03/07/11	07:00	0.164C	0.144C	0.005C
03/07/11	08:00	0.155C	0.141C	0.004C
03/07/11	09:00	0.165	0.142	0.003
03/07/11	10:00	0.161	0.144	0.003
03/07/11	11:00	0.147	0.143	0.003
03/07/11	12:00	0.145	0.143	0.003
03/07/11	13:00	0.215	0.142	0.003
03/07/11	14:00	0.185	0.144	0.005
03/07/11	15:00	0.181	0.146	0.006
03/07/11	16:00	0.166	0.143	0.005
03/07/11	17:00	0.298	0.143	0.008
03/07/11	18:00	0.258	0.143	0.008
03/07/11	19:00	0.217	0.144	0.004
03/07/11	20:00	0.208	0.142	0.004
03/07/11	21:00	0.209	0.143	0.004
03/07/11	22:00	0.174	0.142	0.006
03/07/11	23:00	0.166	0.143	0.007

Average	0.185	0.143	0.005
Minimum	0.145	0.141	0.003
Maximum	0.298	0.146	0.009
Summation	4.452	3.435	0.129
Included Data Points	24	24	24
Total number of Data Points	24	24	24

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/07/11 00:00	3.5	2.9	5.2
03/07/11 00:06	3.5	3.0	5.2
03/07/11 00:12	3.4	2.7	5.1
03/07/11 00:18	3.5	2.9	5.0
03/07/11 00:24	3.3	2.8	5.1
03/07/11 00:30	3.5	2.8	5.1
03/07/11 00:36	3.6	2.8	5.0
03/07/11 00:42	3.6	3.7	5.7
03/07/11 00:48	4.0	5.0	6.5
03/07/11 00:54	3.7	5.6	6.2
03/07/11 01:00	3.5	4.8	6.2
03/07/11 01:06	3.4	5.1	6.2
03/07/11 01:12	3.4	5.0	6.2
03/07/11 01:18	3.3	5.0	6.1
03/07/11 01:24	3.3	4.7	6.2
03/07/11 01:30	3.6	4.8	6.0
03/07/11 01:36	3.3	4.8	6.1
03/07/11 01:42	3.4	4.4	6.2
03/07/11 01:48	3.3	4.5	6.1
03/07/11 01:54	3.2	4.7	6.0
03/07/11 02:00	3.2	4.4	5.9
03/07/11 02:06	3.2	4.8	6.1
03/07/11 02:12	3.2	5.2	6.3
03/07/11 02:18	3.3	4.4	6.2
03/07/11 02:24	3.3	5.4	6.4
03/07/11 02:30	3.3	4.7	6.1
03/07/11 02:36	3.3	4.7	6.3
03/07/11 02:42	F	F	F
03/07/11 02:48	3.3	4.5	6.2
03/07/11 02:54	3.3	4.6	6.5
03/07/11 03:00	3.4	5.5	6.2
03/07/11 03:06	3.3	4.6	6.3
03/07/11 03:12	3.4	4.5	6.4
03/07/11 03:18	3.3	4.4	6.3
03/07/11 03:24	3.3	4.7	6.4
03/07/11 03:30	3.4	4.8	6.3
03/07/11 03:36	3.3	5.0	6.2
03/07/11 03:42	3.4	4.5	6.5
03/07/11 03:48	3.4	5.3	6.2
03/07/11 03:54	3.3	5.2	6.7
03/07/11 04:00	3.6	5.3	6.3
03/07/11 04:06	3.4	5.5	6.1
03/07/11 04:12	3.4	4.9	6.7
03/07/11 04:18	3.4	5.0	6.2
03/07/11 04:24	3.3	5.1	6.5
03/07/11 04:30	3.3	7.0	6.3
03/07/11 04:36	3.4	5.1	6.2
03/07/11 04:42	3.3	5.1	6.3
03/07/11 04:48	3.3	4.6	6.7
03/07/11 04:54	3.3	4.9	6.2
03/07/11 05:00	3.3	4.8	6.0

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/07/11 05:06	3.2	4.6	6.0
03/07/11 05:12	3.4	5.6	6.0
03/07/11 05:18	3.3	4.8	6.0
03/07/11 05:24	3.3	5.1	5.9
03/07/11 05:30	3.3	5.3	6.0
03/07/11 05:36	3.3	4.5	6.0
03/07/11 05:42	3.3	4.8	6.0
03/07/11 05:48	3.2	6.7	5.9
03/07/11 05:54	3.4C	5.0	6.0
03/07/11 06:00	3.4C	5.2	6.0
03/07/11 06:06	3.4	4.9	6.2
03/07/11 06:12	3.4	5.7	6.5
03/07/11 06:18	3.4	5.4	6.6
03/07/11 06:24	3.4	5.5	6.2
03/07/11 06:30	3.6	5.7	6.3
03/07/11 06:36	3.4	5.5	6.3
03/07/11 06:42	3.4	5.7	6.5
03/07/11 06:48	3.7	6.7	6.6
03/07/11 06:54	3.5	5.8C	6.7
03/07/11 07:00	3.6	5.8C	6.0
03/07/11 07:06	3.7	4.8	6.0
03/07/11 07:12	4.3	4.8	6.5
03/07/11 07:18	5.3	4.1	6.0
03/07/11 07:24	3.7	4.1	5.7
03/07/11 07:30	3.6	3.7	5.4
03/07/11 07:36	3.6	3.4	5.1
03/07/11 07:42	3.4	3.1	5.7
03/07/11 07:48	3.2	2.6	5.3
03/07/11 07:54	3.1	2.6	16.5C
03/07/11 08:00	3.1	2.6	4.9C
03/07/11 08:06	3.1	2.6	4.8
03/07/11 08:12	3.1	3.0	5.0
03/07/11 08:18	3.1	2.6	4.7
03/07/11 08:24	3.1	2.7	4.8
03/07/11 08:30	3.1	2.5	4.8
03/07/11 08:36	3.0	2.7	5.3
03/07/11 08:42	3.1	2.8	4.8
03/07/11 08:48	3.2	2.7	5.0
03/07/11 08:54	3.1	2.9	4.9
03/07/11 09:00	3.2	2.6	4.8
03/07/11 09:06	3.3	2.6	4.8
03/07/11 09:12	3.4	2.6	4.9
03/07/11 09:18	10.7	2.5	4.9
03/07/11 09:24	5.3	2.6	4.9
03/07/11 09:30	3.8	2.5	4.7
03/07/11 09:36	3.6	2.6	4.8
03/07/11 09:42	4.0	2.8	4.9
03/07/11 09:48	3.9	2.7	4.9
03/07/11 09:54	3.5	2.9	4.9
03/07/11 10:00	3.7	2.9	5.0
03/07/11 10:06	3.4	2.8	5.0

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter)Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/07/11 10:12	3.5	2.9	5.2
03/07/11 10:18	3.5	3.2	5.1
03/07/11 10:24	3.4	3.2	5.2
03/07/11 10:30	3.2	2.7	4.8
03/07/11 10:36	3.2	2.6	4.9
03/07/11 10:42	3.1	2.5	4.7
03/07/11 10:48	3.1	2.8	5.0
03/07/11 10:54	3.1	4.9	5.0
03/07/11 11:00	3.1	2.9	4.9
03/07/11 11:06	3.3	8.0	5.1
03/07/11 11:12	3.3	6.0	5.0
03/07/11 11:18	3.2	3.4	5.1
03/07/11 11:24	3.3	7.2	5.0
03/07/11 11:30	3.2	4.5	4.9
03/07/11 11:36	3.1	3.4	4.8
03/07/11 11:42	3.9	10.7	4.9
03/07/11 11:48	4.5	5.3	4.8
03/07/11 11:54	3.5	3.5	4.8
03/07/11 12:00	3.7	8.2	4.7
03/07/11 12:06	3.6	6.8	4.9
03/07/11 12:12	3.4	3.7	4.7
03/07/11 12:18	3.3	7.7	4.7
03/07/11 12:24	3.3	4.4	4.7
03/07/11 12:30	3.8	4.0	5.2
03/07/11 12:36	3.3	6.9	5.3
03/07/11 12:42	3.5	4.5	4.8
03/07/11 12:48	3.2	4.0	4.8
03/07/11 12:54	3.1	3.0	4.8
03/07/11 13:00	3.1	3.0	4.7
03/07/11 13:06	3.1	3.0	5.1
03/07/11 13:12	3.4	3.0	4.8
03/07/11 13:18	3.2	2.8	4.7
03/07/11 13:24	3.2	3.0	4.7
03/07/11 13:30	3.3	2.7	4.7
03/07/11 13:36	3.3	2.6	4.6
03/07/11 13:42	3.1	2.5	4.4
03/07/11 13:48	3.2	2.5	4.5
03/07/11 13:54	3.3	2.5	5.9
03/07/11 14:00	3.1	2.6	4.4
03/07/11 14:06	3.2	2.3	8.1
03/07/11 14:12	3.3	2.4	6.3
03/07/11 14:18	3.7	2.2	4.5
03/07/11 14:24	4.4	2.5	4.7
03/07/11 14:30	5.0	2.3	5.3
03/07/11 14:36	3.7	2.3	4.3
03/07/11 14:42	3.6	2.5	8.0
03/07/11 14:48	3.4	2.4	5.9
03/07/11 14:54	3.4	2.4	4.5
03/07/11 15:00	3.4	2.4	7.6
03/07/11 15:06	3.4	2.4	5.5
03/07/11 15:12	3.4	2.4	4.4

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/07/11 15:18	3.1	2.1	10.4
03/07/11 15:24	3.1	2.2	5.7
03/07/11 15:30	3.2	2.3	4.4
03/07/11 15:36	3.3	2.3	7.1
03/07/11 15:42	3.5	2.4	6.4
03/07/11 15:48	4.2	2.3	4.9
03/07/11 15:54	4.6	2.3	4.1
03/07/11 16:00	5.4	2.6	4.0
03/07/11 16:06	16.8	2.3	4.1
03/07/11 16:12	7.9	2.5	4.4
03/07/11 16:18	5.1	2.3	4.3
03/07/11 16:24	9.5	2.4	4.3
03/07/11 16:30	4.2	2.5	4.2
03/07/11 16:36	3.5	2.6	4.4
03/07/11 16:42	3.4	3.0	4.3
03/07/11 16:48	3.3	2.6	4.4
03/07/11 16:54	3.4	2.5	4.3
03/07/11 17:00	3.2	2.7	4.4
03/07/11 17:06	3.1	2.4	4.4
03/07/11 17:12	3.0	2.3	4.3
03/07/11 17:18	2.9	2.3	4.4
03/07/11 17:24	2.9	2.2	4.5
03/07/11 17:30	3.1	2.5	5.7
03/07/11 17:36	4.2	3.3	5.0
03/07/11 17:42	3.5	4.2	5.4
03/07/11 17:48	3.7	6.4	6.4
03/07/11 17:54	4.2	4.3	6.6
03/07/11 18:00	6.6	4.2	6.6
03/07/11 18:06	7.8	4.4	6.2
03/07/11 18:12	4.0	6.5	5.9
03/07/11 18:18	3.7	6.7	6.0
03/07/11 18:24	3.5	5.6	7.2
03/07/11 18:30	3.3	4.3	6.2
03/07/11 18:36	3.4	4.7	6.3
03/07/11 18:42	3.3	4.3	6.9
03/07/11 18:48	3.3	4.7	6.7
03/07/11 18:54	3.8	5.2	7.0
03/07/11 19:00	3.7	6.1	6.6
03/07/11 19:06	4.5	6.7	6.4
03/07/11 19:12	3.7	9.5	6.4
03/07/11 19:18	3.6	6.9	6.5
03/07/11 19:24	3.7	6.8	6.1
03/07/11 19:30	3.5	7.9	6.8
03/07/11 19:36	4.2	6.5	6.7
03/07/11 19:42	3.7	5.9	6.2
03/07/11 19:48	3.7	6.7	6.3
03/07/11 19:54	3.7	7.7	5.9
03/07/11 20:00	3.5	14.0	7.2
03/07/11 20:06	3.5	6.7	6.4
03/07/11 20:12	3.5	6.4	6.6
03/07/11 20:18	3.8	6.1	6.2

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

Average Data

Plant: New Hope Power Company Okeelanta Cogen

Interval: 6 Minute

Type: Block

Report Period: 03/07/2011 00:00 Through 03/07/2011 23:59

Time Online Criteria: 1 minute(s)

Source	UNIT1	UNIT2	UNIT3
Parameter Unit(OPACITY (PERCENT)	OPACITY (PERCENT)	OPACITY (PERCENT)
03/07/11 20:24	3.6	5.6	6.1
03/07/11 20:30	3.6	5.5	6.0
03/07/11 20:36	4.4	5.5	6.4
03/07/11 20:42	3.6	6.0	6.2
03/07/11 20:48	3.7	5.3	6.1
03/07/11 20:54	3.6	5.1	6.2
03/07/11 21:00	3.5	5.2	6.1
03/07/11 21:06	3.6	5.6	6.4
03/07/11 21:12	3.7	5.2	6.2
03/07/11 21:18	3.6	5.7	6.2
03/07/11 21:24	3.6	5.4	6.3
03/07/11 21:30	3.6	5.5	6.3
03/07/11 21:36	3.7	4.6	6.7
03/07/11 21:42	3.5	7.5	6.4
03/07/11 21:48	3.6	7.4	6.3
03/07/11 21:54	3.5	4.5	6.3
03/07/11 22:00	3.6	4.6	6.4
03/07/11 22:06	3.5	4.7	6.6
03/07/11 22:12	3.5	4.8	6.5
03/07/11 22:18	3.6	4.9	6.4
03/07/11 22:24	3.5	4.6	6.5
03/07/11 22:30	3.4	4.4	6.4
03/07/11 22:36	3.5	4.3	6.3
03/07/11 22:42	3.4	4.2	6.4
03/07/11 22:48	3.5	4.4	6.4
03/07/11 22:54	3.4	3.9	6.4
03/07/11 23:00	3.5	3.9	6.3
03/07/11 23:06	3.4	3.8	6.1
03/07/11 23:12	3.4	3.8	6.3
03/07/11 23:18	3.3	4.0	6.3
03/07/11 23:24	3.4	4.5	6.2
03/07/11 23:30	3.3	4.5	6.2
03/07/11 23:36	3.4	3.8	6.2
03/07/11 23:42	3.3	4.3	6.2
03/07/11 23:48	3.4	3.9	6.3
03/07/11 23:54	3.4	3.4	6.0
Average	3.6	4.3	5.7
Minimum	2.9	2.1	4.0
Maximum	16.8	14.0	10.4
Summation	867.7	1,019.4	1,359.4
Included Data Points	238	238	238
Total number of Data Points	240	240	240

F = Unit Offline **E = Exceedance** **C = Calibration** **S = Substituted**
I = Invalid **M = Maintenance** **T = Out Of Control** *** = Suspect**

ABFT100
BLR A MAIN STM FLOW
KPPH
 03/07/2011 00:00:00 250.0
 03/07/2011 01:00:00 254.2
 03/07/2011 02:00:00 247.9
 03/07/2011 03:00:00 249.3
 03/07/2011 04:00:00 250.4
 03/07/2011 05:00:00 249.0
 03/07/2011 06:00:00 250.9
 03/07/2011 07:00:00 250.3
 03/07/2011 08:00:00 329.2
 03/07/2011 09:00:00 360.8
 03/07/2011 10:00:00 358.0
 03/07/2011 11:00:00 349.8
 03/07/2011 12:00:00 366.5
 03/07/2011 13:00:00 358.6
 03/07/2011 14:00:00 359.5
 03/07/2011 15:00:00 374.8
 03/07/2011 16:00:00 351.0
 03/07/2011 17:00:00 336.7
 03/07/2011 18:00:00 356.8
 03/07/2011 19:00:00 306.7
 03/07/2011 20:00:00 265.3
 03/07/2011 21:00:00 250.9
 03/07/2011 22:00:00 249.8
 03/07/2011 23:00:00 250.4
 03/08/2011 00:00:00 250.1
 03/08/2011 01:00:00 249.8
 03/08/2011 02:00:00 247.2
 03/08/2011 03:00:00 246.0
 03/08/2011 04:00:00 252.5
 03/08/2011 05:00:00 250.1
 03/08/2011 06:00:00 213.3
 03/08/2011 07:00:00 210.4
 03/08/2011 08:00:00 207.8
 03/08/2011 09:00:00 209.0
 03/08/2011 10:00:00 211.7
 03/08/2011 11:00:00 210.0
 03/08/2011 12:00:00 243.5

ABFT200
BLR B MAIN STM FLOW
KPPH
 03/07/2011 00:00:00 247.5
 03/07/2011 01:00:00 253.4
 03/07/2011 02:00:00 248.8
 03/07/2011 03:00:00 249.8
 03/07/2011 04:00:00 250.9
 03/07/2011 05:00:00 249.2
 03/07/2011 06:00:00 251.2
 03/07/2011 07:00:00 250.7
 03/07/2011 08:00:00 248.0
 03/07/2011 09:00:00 250.2
 03/07/2011 10:00:00 250.4
 03/07/2011 11:00:00 249.5
 03/07/2011 12:00:00 249.8
 03/07/2011 13:00:00 250.4
 03/07/2011 14:00:00 250.2
 03/07/2011 15:00:00 250.0
 03/07/2011 16:00:00 250.8
 03/07/2011 17:00:00 249.4
 03/07/2011 18:00:00 250.8
 03/07/2011 19:00:00 246.7
 03/07/2011 20:00:00 246.8
 03/07/2011 21:00:00 250.6
 03/07/2011 22:00:00 249.5
 03/07/2011 23:00:00 250.7
 03/08/2011 00:00:00 250.7
 03/08/2011 01:00:00 249.3
 03/08/2011 02:00:00 246.9
 03/08/2011 03:00:00 254.4
 03/08/2011 04:00:00 250.2
 03/08/2011 05:00:00 249.8
 03/08/2011 06:00:00 221.3
 03/08/2011 07:00:00 180.9
 03/08/2011 08:00:00 187.5
 03/08/2011 09:00:00 191.6
 03/08/2011 10:00:00 164.2
 03/08/2011 11:00:00 194.0
 03/08/2011 12:00:00 242.8

ABFT300
BLR C MAIN STM FLOW
KPPH
 03/07/2011 00:00:00 249.4
 03/07/2011 01:00:00 260.6
 03/07/2011 02:00:00 248.3
 03/07/2011 03:00:00 249.2
 03/07/2011 04:00:00 251.1
 03/07/2011 05:00:00 249.1
 03/07/2011 06:00:00 250.5
 03/07/2011 07:00:00 250.4
 03/07/2011 08:00:00 248.4
 03/07/2011 09:00:00 250.7
 03/07/2011 10:00:00 249.8
 03/07/2011 11:00:00 249.9
 03/07/2011 12:00:00 250.2
 03/07/2011 13:00:00 251.2
 03/07/2011 14:00:00 255.9
 03/07/2011 15:00:00 244.7
 03/07/2011 16:00:00 249.2
 03/07/2011 17:00:00 250.2
 03/07/2011 18:00:00 252.9
 03/07/2011 19:00:00 246.1
 03/07/2011 20:00:00 249.5
 03/07/2011 21:00:00 250.5
 03/07/2011 22:00:00 249.8
 03/07/2011 23:00:00 250.2
 03/08/2011 00:00:00 249.5
 03/08/2011 01:00:00 249.9
 03/08/2011 02:00:00 247.2
 03/08/2011 03:00:00 250.2
 03/08/2011 04:00:00 250.8
 03/08/2011 05:00:00 250.3
 03/08/2011 06:00:00 224.7
 03/08/2011 07:00:00 213.1
 03/08/2011 08:00:00 209.7
 03/08/2011 09:00:00 209.7
 03/08/2011 10:00:00 210.6
 03/08/2011 11:00:00 209.4
 03/08/2011 12:00:00 240.8