

DRAFT

**FLORIDA POWER AND LIGHT CO.
WEST COUNTY UNIT NO. CT-2B**

Test Date: 11/14/12

Run 1

ANALYZER CALIBRATION ERROR DATA

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	≤ 0.5 DIFF PPM	OR ± 2% SPAN	ANALYZER SERIAL #
10	ppm NOx	0.00	0.00	0.0	0.0	0600314588
	ppm NOx	5.00	4.98	0.0	-0.2	
	ppm NOx	9.78	9.90	0.1	1.2	
25	% O2	0.00	0.00	0.0	0.0	01420/B425
	% O2	13.80	13.80	0.0	0.0	
	% O2	24.70	24.82	0.1	0.5	
10	% CO2	0.00	0.00	0.0	0.0	01415C1245
	% CO2	5.06	5.08	0.0	0.2	
	% CO2	9.80	9.89	0.1	0.9	
10	ppm CO	0.00	0.00	0.0	0.0	00004484
	ppm CO	5.585	5.58	0.0	-0.1	
	ppm CO	9.785	9.70	-0.1	-0.9	

SYSTEM BIAS AND CALBRATION DRIFT DATA

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	OR		POSTTEST CHECK	OR		OR	
			≤ 0.5 DIFF PPM	± 5% SPAN		≤ 0.5 DIFF PPM	± 5% SPAN	≤ 0.5 DIFF PPM	≤ 3% DRIFT
ppm NOx	0.00	0.03	0.03	0.3	0.00	0.00	0.0	0.03	-0.3
ppm NOx	4.98	4.99	0.01	0.1	5.00	0.02	0.2	-0.01	0.1
% O2	0.00	0.00	0.00	0.0	0.00	0.00	0.0	0.00	0.0
## % O2	13.80	13.81	0.01	0.0	13.80	0.00	0.0	0.01	0.0
% CO2	0.00	0.01	0.01	0.1	0.02	0.02	0.2	-0.01	0.1
% CO2	5.08	5.08	0.00	0.0	5.09	0.01	0.1	-0.01	0.1
ppm CO	0.00	0.00	0.00	0.0	0.00	0.00	0.0	0.00	0.0
ppm CO	5.58	5.63	0.05	0.5	5.60	0.02	0.2	0.03	-0.3

UNCORRECTED REFERENCE DATA

Date / Time	NOx PPM	% O2	% CO2	CO PPM
11/14/2012 10:00	2.52	13.49	4.23	1.20
11/14/2012 10:02	2.48	13.53	4.25	1.17
11/14/2012 10:04	2.62	13.33	4.35	1.25
11/14/2012 10:06	2.60	13.36	4.33	1.22
11/14/2012 10:08	2.53	13.40	4.31	1.19
11/14/2012 10:10	2.61	13.43	4.29	1.11
11/14/2012 10:12	2.34	13.34	4.35	1.23
11/14/2012 10:14	2.36	13.31	4.37	1.18
11/14/2012 10:16	2.26	13.33	4.36	1.33
11/14/2012 10:18	2.42	13.33	4.36	1.53
11/14/2012 10:20	2.45	13.31	4.37	1.23
11/14/2012 10:22	2.36	13.31	4.37	1.31
AVERAGE	2.46	13.36	4.33	1.24

CORRECTED RESULTS	
NOx PPM	2.46
% O2	13.35
% CO2	4.30
CO PPM	1.24
CORRECTED NOx PPM	1.92
LB/MMBTU NOx	0.007

F Factor 8710

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:35

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stackla

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1A_NOXCORR ppm	Average 1A_NOXC_24 ppm	Average 1A_COCORR ppm	Average 1A_COC_24 ppm	Average 1A_HICOMB mmbtu
11/13/2012 00:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 01:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 02:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 03:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 04:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 05:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 06:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 07:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 08:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 09:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 10:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 11:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 12:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 13:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 14:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 15:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 16:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 17:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 18:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 19:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 20:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 21:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 22:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 23:00	N/A	N/A	N/A	N/A	N/A
11/14/2012 00:00	N/A	N/A	N/A	N/A	N/A
Final Average*	N/A	N/A	N/A	N/A	N/A
Maximum*	N/A	N/A	N/A	N/A	N/A
Minimum*	N/A	N/A	N/A	N/A	N/A

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:36

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stacklb

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1B_NOXCORR ppm	Average 1B_NOXC_24 ppm	Average 1B_COCORR ppm	Average 1B_COC_24 ppm	Average 1B_HICOMB mmbtu
11/13/2012 00:00	1.7	1.7	1.1	1.3	2285.1
11/13/2012 01:00	1.7	1.7	1.6	1.1	2193.0
11/13/2012 02:00	1.7	1.7	2.6	1.4	2121.1
11/13/2012 03:00	1.7	1.7	2.4	1.8	2120.4
11/13/2012 04:00	1.7	1.7	2.4	1.9	2118.7
11/13/2012 05:00	1.7	1.7	1.4	2.0	2303.0
11/13/2012 06:00	1.7	1.7	0.7	1.9	2464.2
11/13/2012 07:00	1.6	1.7	1.8	1.7	2221.8
11/13/2012 08:00	1.7	1.7	2.0	1.7	2141.9
11/13/2012 09:00	1.7	1.7	0.8	1.8	2364.0
11/13/2012 10:00	1.7	1.7	0.4	1.7	2390.1
11/13/2012 11:00	1.7	1.7	0.4	1.6	2384.7
11/13/2012 12:00	1.7	1.7	0.4	1.5	2385.6
11/13/2012 13:00	1.7	1.7	0.4	1.4	2385.1
11/13/2012 14:00	1.6	1.7	0.7	1.3	2411.6
11/13/2012 15:00	1.7	1.7	0.8	1.3	2573.0
11/13/2012 16:00	1.7	1.7	0.8	1.2	2587.7
11/13/2012 17:00	1.7	1.7	0.8	1.2	2596.0
11/13/2012 18:00	1.7	1.7	0.8	1.2	2597.8
11/13/2012 19:00	1.7	1.7	0.8	1.2	2600.6
11/13/2012 20:00	1.7	1.7	0.8	1.2	2588.5
11/13/2012 21:00	1.7	1.7	0.8	1.1	2562.4
11/13/2012 22:00	1.7	1.7	0.8	1.1	2556.5
11/13/2012 23:00	1.7	1.7	1.0	1.1	2357.7
11/14/2012 00:00	1.7	1.7	1.4	1.1	2208.6
Final Average*	1.7	1.7	1.1	1.4	2380.8
Maximum*	1.7	1.7	2.6	2.0	2600.6
Minimum*	1.6	1.7	0.4	1.1	2118.7

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:36

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stacklc

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1C_NOXCORR ppm	Average 1C_NOXC_24 ppm	Average 1C_COCORR ppm	Average 1C_COC_24 ppm	Average 1C_HICOMB mmbtu
11/13/2012 00:00	1.7	1.7	0.5	0.6	2463.7
11/13/2012 01:00	1.6	1.7	0.5	0.5	2360.5
11/13/2012 02:00	1.6	1.7	0.7	0.5	2280.6
11/13/2012 03:00	1.7	1.6	0.8	0.6	2279.6
11/13/2012 04:00	1.7	1.7	0.8	0.6	2276.5
11/13/2012 05:00	1.8	1.7	0.5	0.7	2473.5
11/13/2012 06:00	1.7	1.7	0.4	0.6	2616.4
11/13/2012 07:00	1.6	1.7	0.7	0.6	2393.7
11/13/2012 08:00	1.8	1.7	0.7	0.6	2304.1
11/13/2012 09:00	1.8	1.7	0.4	0.6	2520.2
11/13/2012 10:00	1.7	1.7	0.3	0.6	2540.8
11/13/2012 11:00	1.7	1.7	0.3	0.6	2533.7
11/13/2012 12:00	1.7	1.7	0.3	0.5	2530.4
11/13/2012 13:00	1.7	1.7	0.4	0.5	2532.5
11/13/2012 14:00	1.7	1.7	0.4	0.5	2558.4
11/13/2012 15:00	1.7	1.7	0.5	0.5	2735.6
11/13/2012 16:00	1.7	1.7	0.5	0.5	2750.6
11/13/2012 17:00	1.7	1.7	0.5	0.5	2757.2
11/13/2012 18:00	1.7	1.7	0.5	0.5	2759.3
11/13/2012 19:00	1.7	1.7	0.5	0.5	2762.0
11/13/2012 20:00	1.7	1.7	0.5	0.5	2749.4
11/13/2012 21:00	1.7	1.7	0.6	0.5	2725.8
11/13/2012 22:00	1.7	1.7	0.6	0.5	2715.4
11/13/2012 23:00	1.6	1.7	0.4	0.5	2524.6
11/14/2012 00:00	1.7	1.7	0.5	0.5	2380.4
Final Average*	1.7	1.7	0.5	0.5	2541.0
Maximum*	1.8	1.7	0.8	0.7	2762.0
Minimum*	1.6	1.6	0.3	0.5	2276.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:34

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2a

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2A_NOXCORR ppm	Average 2A_NOXC_24 ppm	Average 2A_COCORR ppm	Average 2A_COC_24 ppm	Average 2A_HICOMB mmbtu
11/13/2012 00:00	1.7	1.7	1.3	1.6	2324.2
11/13/2012 01:00	1.7	1.7	2.0	1.3	2214.3
11/13/2012 02:00	1.7	1.7	3.7	1.7	2062.4
11/13/2012 03:00	1.7	1.7	3.6	2.3	2016.6
11/13/2012 04:00	1.7	1.7	3.3	2.7	2057.7
11/13/2012 05:00	1.8	1.7	1.5	2.8	2392.0
11/13/2012 06:00	1.7	1.7	1.2	2.6	2528.3
11/13/2012 07:00	1.7	1.7	1.5	2.4	2431.6
11/13/2012 08:00	1.7	1.7	1.9	2.3	2260.3
11/13/2012 09:00	1.7	1.7	1.2	2.2	2504.5
11/13/2012 10:00	1.7	1.7	1.0	2.1	2482.3
11/13/2012 11:00	1.7	1.7	1.0	2.0	2479.0
11/13/2012 12:00	1.7	1.7	1.0	1.9	2483.0
11/13/2012 13:00	1.7	1.7	1.0	1.9	2482.7
11/13/2012 14:00	1.7	1.7	1.0	1.8	2485.3
11/13/2012 15:00	1.7	1.7	1.0	1.8	2529.0
11/13/2012 16:00	1.8	1.7	1.4	1.7	2555.5
11/13/2012 17:00	1.7	1.7	1.4	1.7	2680.2
11/13/2012 18:00	1.7	1.7	1.3	1.7	2692.9
11/13/2012 19:00	1.7	1.7	1.3	1.7	2697.9
11/13/2012 20:00	1.7	1.7	1.4	1.6	2591.5
11/13/2012 21:00	10.4	1.7	692.7	1.6	1493.0
11/13/2012 22:00	N/A	1.7	N/A	1.6	N/A
11/13/2012 23:00	N/A	1.7	N/A	1.6	N/A
11/14/2012 00:00	N/A	1.7	N/A	1.6	N/A
Final Average*	2.1	1.7	33.0	1.9	2383.8
Maximum*	10.4	1.7	692.7	2.8	2697.9
Minimum*	1.7	1.7	1.0	1.3	1493.0

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:34

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2b

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2B_NOXCORR ppm	Average 2B_NOXC_24 ppm	Average 2B_COCORR ppm	Average 2B_COC_24 ppm	Average 2B_HICOMB mmbtu
11/13/2012 00:00	1.7	1.7	2.8	1.9	2302.7
11/13/2012 01:00	1.7	1.7	3.8	2.8	2193.7
11/13/2012 02:00	1.7	1.7	3.9	3.3	2044.6
11/13/2012 03:00	1.7	1.7	3.3	3.5	2000.5
11/13/2012 04:00	1.7	1.7	2.8	3.5	2042.1
11/13/2012 05:00	1.7	1.7	2.6	3.3	2388.0
11/13/2012 06:00	1.7	1.7	1.0	3.2	2560.5
11/13/2012 07:00	1.6	1.7	2.8	2.9	2425.5
11/13/2012 08:00	1.7	1.7	3.9	2.9	2169.7
11/13/2012 09:00	1.7	1.7	1.7	3.0	2487.9
11/13/2012 10:00	1.7	1.7	1.8	2.9	2505.8
11/13/2012 11:00	1.7	1.7	1.5	2.8	2505.2
11/13/2012 12:00	1.7	1.7	1.3	2.7	2508.6
11/13/2012 13:00	1.7	1.7	1.2	2.5	2508.6
11/13/2012 14:00	1.8	1.7	1.2	2.5	2603.6
11/13/2012 15:00	1.7	1.7	1.1	2.4	2684.4
11/13/2012 16:00	1.7	1.7	1.1	2.3	2705.5
11/13/2012 17:00	1.7	1.7	0.9	2.2	2728.2
11/13/2012 18:00	1.7	1.7	1.0	2.1	2708.9
11/13/2012 19:00	1.7	1.7	1.0	2.1	2711.9
11/13/2012 20:00	1.7	1.7	1.1	2.0	2605.7
11/13/2012 21:00	1.7	1.7	0.9	2.0	2546.6
11/13/2012 22:00	1.7	1.7	1.0	1.9	2570.0
11/13/2012 23:00	1.7	1.7	2.7	1.9	2386.6
11/14/2012 00:00	1.7	1.7	3.2	1.9	2238.0
Final Average*	1.7	1.7	2.0	2.6	2445.3
Maximum*	1.8	1.7	3.9	3.5	2728.2
Minimum*	1.6	1.7	0.9	1.9	2000.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:35

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2c

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2C_NOXCORR ppm	Average 2C_NOXC_24 ppm	Average 2C_COCORR ppm	Average 2C_COC_24 ppm	Average 2C_HICOMB mmbtu
11/13/2012 00:00	N/A	1.7	N/A	1.6	N/A
11/13/2012 01:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 02:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 03:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 04:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 05:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 06:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 07:00	29.1	N/A	1631.9	N/A	1004.4
11/13/2012 08:00	4.8	N/A	67.9	N/A	1999.4
11/13/2012 09:00	1.7	N/A	5.1	N/A	2136.8
11/13/2012 10:00	1.7	1.7	1.3	5.1	2504.5
11/13/2012 11:00	1.7	1.7	1.5	3.2	2505.6
11/13/2012 12:00	1.7	1.7	1.7	2.6	2534.6
11/13/2012 13:00	1.7	1.7	1.5	2.4	2535.5
11/13/2012 14:00	1.8	1.7	1.5	2.2	2607.4
11/13/2012 15:00	1.7	1.7	1.5	2.1	2674.0
11/13/2012 16:00	1.7	1.7	1.5	2.0	2686.9
11/13/2012 17:00	1.7	1.7	1.5	1.9	2705.1
11/13/2012 18:00	1.7	1.7	1.5	1.9	2696.8
11/13/2012 19:00	1.7	1.7	1.5	1.8	2696.6
11/13/2012 20:00	1.7	1.7	1.5	1.8	2608.9
11/13/2012 21:00	1.7	1.7	1.3	1.8	2559.7
11/13/2012 22:00	1.7	1.7	1.3	1.7	2575.0
11/13/2012 23:00	1.7	1.7	2.3	1.7	2397.4
11/14/2012 00:00	1.7	1.7	3.0	1.8	2251.0
Final Average*	3.4	1.7	96.1	2.2	2426.6
Maximum*	29.1	1.7	1631.9	5.1	2705.1
Minimum*	1.7	1.7	1.3	1.6	1004.4

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:38

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3a

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3A_NOXCORR ppm	Average 3A_NOXC_24 ppm	Average 3A_COCORR ppm	Average 3A_COC_24 ppm	Average 3A_HICOMB mmbtu
11/13/2012 00:00	1.7	1.7	1.6	1.3	2351.9
11/13/2012 01:00	1.7	1.7	1.7	1.6	2253.7
11/13/2012 02:00	1.6	1.7	2.4	1.6	2110.7
11/13/2012 03:00	1.7	1.7	2.1	1.9	2077.0
11/13/2012 04:00	1.7	1.7	2.0	1.9	2132.8
11/13/2012 05:00	1.7	1.7	1.1	2.0	2455.7
11/13/2012 06:00	1.7	1.7	0.8	1.8	2530.0
11/13/2012 07:00	1.6	1.7	1.1	1.7	2502.8
11/13/2012 08:00	1.7	1.7	0.9	1.6	2510.9
11/13/2012 09:00	1.7	1.7	0.8	1.5	2492.6
11/13/2012 10:00	1.7	1.7	0.8	1.4	2470.7
11/13/2012 11:00	1.7	1.7	1.2	1.4	2512.1
11/13/2012 12:00	1.7	1.7	1.0	1.4	2538.9
11/13/2012 13:00	1.6	1.7	1.1	1.3	2533.0
11/13/2012 14:00	1.6	1.7	0.9	1.3	2587.3
11/13/2012 15:00	1.7	1.7	0.7	1.3	2715.5
11/13/2012 16:00	1.7	1.7	0.8	1.3	2706.3
11/13/2012 17:00	1.6	1.7	0.8	1.2	2749.2
11/13/2012 18:00	1.6	1.7	0.8	1.2	2757.7
11/13/2012 19:00	1.6	1.7	0.8	1.2	2763.4
11/13/2012 20:00	1.6	1.7	0.8	1.2	2764.1
11/13/2012 21:00	1.6	1.7	0.8	1.1	2769.2
11/13/2012 22:00	1.7	1.7	0.7	1.1	2711.7
11/13/2012 23:00	1.6	1.7	1.5	1.1	2441.9
11/14/2012 00:00	1.6	1.7	1.8	1.1	2207.2
Final Average*	1.7	1.7	1.2	1.4	2505.9
Maximum*	1.7	1.7	2.4	2.0	2769.2
Minimum*	1.6	1.7	0.7	1.1	2077.0

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:39

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3b

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3B_NOXCORR ppm	Average 3B_NOXC_24 ppm	Average 3B_COCORR ppm	Average 3B_COC_24 ppm	Average 3B_HICOMB mmbtu
11/13/2012 00:00	1.7	1.7	1.8	1.7	2381.0
11/13/2012 01:00	1.7	1.7	2.1	1.8	2281.1
11/13/2012 02:00	1.7	1.7	3.2	1.9	2135.8
11/13/2012 03:00	1.7	1.7	3.2	2.3	2097.5
11/13/2012 04:00	1.7	1.7	2.9	2.5	2154.8
11/13/2012 05:00	1.7	1.7	1.4	2.6	2505.6
11/13/2012 06:00	1.7	1.7	0.8	2.4	2587.7
11/13/2012 07:00	1.7	1.7	1.0	2.2	2547.6
11/13/2012 08:00	1.7	1.7	0.9	2.0	2529.5
11/13/2012 09:00	1.7	1.7	0.9	1.9	2509.0
11/13/2012 10:00	1.7	1.7	0.8	1.8	2487.9
11/13/2012 11:00	1.7	1.7	1.1	1.7	2523.9
11/13/2012 12:00	1.7	1.7	1.1	1.7	2526.5
11/13/2012 13:00	1.7	1.7	1.1	1.6	2524.7
11/13/2012 14:00	1.7	1.7	0.9	1.6	2582.5
11/13/2012 15:00	1.7	1.7	0.8	1.6	2692.9
11/13/2012 16:00	1.7	1.7	0.8	1.5	2701.7
11/13/2012 17:00	1.7	1.7	0.7	1.5	2769.9
11/13/2012 18:00	1.7	1.7	0.8	1.4	2757.7
11/13/2012 19:00	1.7	1.7	0.7	1.4	2766.5
11/13/2012 20:00	1.7	1.7	0.8	1.4	2755.9
11/13/2012 21:00	1.7	1.7	0.7	1.3	2775.4
11/13/2012 22:00	1.7	1.7	0.7	1.3	2736.0
11/13/2012 23:00	1.7	1.7	1.7	1.3	2471.9
11/14/2012 00:00	1.7	1.7	2.8	1.3	2230.9
Final Average*	1.7	1.7	1.3	1.7	2521.4
Maximum*	1.7	1.7	3.2	2.6	2775.4
Minimum*	1.7	1.7	0.7	1.3	2097.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 11/14/2012 11:39

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3c

Period Start: 11/13/2012 00:00
 Period End: 11/14/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3C_NOXCORR ppm	Average 3C_NOXC_24 ppm	Average 3C_COCORR ppm	Average 3C_COC_24 ppm	Average 3C_HICOMB mmbtu
11/13/2012 00:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 01:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 02:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 03:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 04:00	N/A	N/A	N/A	N/A	N/A
11/13/2012 05:00	35.3	N/A	1981.5	N/A	882.8
11/13/2012 06:00	21.1	N/A	891.9	N/A	1409.8
11/13/2012 07:00	2.0	N/A	3.4	N/A	2329.2
11/13/2012 08:00	1.7	1.6	0.9	3.4	2523.5
11/13/2012 09:00	1.7	1.6	0.8	2.1	2504.5
11/13/2012 10:00	1.7	1.6	0.8	1.7	2485.2
11/13/2012 11:00	1.7	1.7	1.2	1.4	2526.7
11/13/2012 12:00	1.7	1.7	0.9	1.4	2540.0
11/13/2012 13:00	1.7	1.7	0.9	1.3	2532.9
11/13/2012 14:00	1.7	1.7	1.1	1.3	2564.9
11/13/2012 15:00	1.7	1.7	0.9	1.2	2681.7
11/13/2012 16:00	1.7	1.7	0.9	1.2	2685.6
11/13/2012 17:00	1.7	1.7	0.8	1.2	2752.5
11/13/2012 18:00	1.7	1.7	0.9	1.1	2751.8
11/13/2012 19:00	1.7	1.7	0.9	1.1	2750.6
11/13/2012 20:00	1.7	1.7	0.9	1.1	2749.3
11/13/2012 21:00	1.7	1.7	0.8	1.1	2767.9
11/13/2012 22:00	1.7	1.7	0.8	1.1	2726.9
11/13/2012 23:00	1.7	1.7	2.5	1.1	2441.4
11/14/2012 00:00	1.7	1.7	3.5	1.1	2198.8
Final Average*	4.4	1.7	144.8	1.4	2440.3
Maximum*	35.3	1.7	1981.5	3.4	2767.9
Minimum*	1.7	1.6	0.8	1.1	882.8

*Does not include Invalid Averaging Periods ("N/A")