

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 4/26/2011 11:14

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3a

Period Start: 4/26/2011 00:00
 Period End: 4/26/2011 11:14
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3A_NOXCORR ppm	Average 3A_NOXC_24 ppm	Average 3A_COCORR ppm	Average 3A_COC_24 ppm	Average 3A_HICOMB mmbtu
04/26/2011 00:00	7.5	3.0	5.6	N/A	2197.0
04/26/2011 01:00	7.5	7.5	5.5	5.6	2198.9
04/26/2011 02:00	7.5	7.5	5.4	5.5	2198.3
04/26/2011 03:00	7.5	7.5	5.5	5.5	2200.4
04/26/2011 04:00	7.5	7.5	5.5	5.5	2196.9
04/26/2011 05:00	7.5	7.5	5.6	5.5	2188.1
04/26/2011 06:00	7.5	7.5	5.7	5.5	2191.2
04/26/2011 07:00	7.0	7.5	5.9	5.5	2181.7
04/26/2011 08:00	7.0	7.4	5.6	5.6	2184.5
04/26/2011 09:00	6.4	7.4	5.6	5.6	2166.2
04/26/2011 10:00	6.4	7.3	5.5	5.6	2155.8
04/26/2011 11:00	N/A	7.2	N/A	5.6	N/A
Final Average*	7.2	7.1	5.6	5.5	2187.2
Maximum*	7.5	7.5	5.9	5.6	2200.4
Minimum*	6.4	3.0	5.4	5.5	2155.8

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 4/26/2011 11:20

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3b

Period Start: 4/26/2011 00:00
 Period End: 4/26/2011 11:14
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3B_NOXCORR ppm	Average 3B_NOXC_24 ppm	Average 3B_COCORR ppm	Average 3B_COC_24 ppm	Average 3B_HICOMB mmbtu
04/26/2011 00:00	1.5	1.6	6.6	2.3	2015.7
04/26/2011 01:00	1.5	1.5	7.0	6.6	2014.8
04/26/2011 02:00	1.5	1.5	6.8	6.8	2016.3
04/26/2011 03:00	1.5	1.5	6.4	6.8	2024.3
04/26/2011 04:00	1.5	1.5	6.1	6.7	2055.2
04/26/2011 05:00	1.5	1.5	5.9	6.6	2055.9
04/26/2011 06:00	1.5	1.5	6.1	6.5	2058.7
04/26/2011 07:00	1.5	1.5	5.8	6.4	2056.7
04/26/2011 08:00	1.5	1.5	3.3	6.3	2237.1
04/26/2011 09:00	1.5	1.5	0.3	6.0	2482.3
04/26/2011 10:00	1.5	1.5	0.2	5.4	2470.8
04/26/2011 11:00	N/A	1.5	N/A	5.0	N/A
Final Average*	1.5	1.5	5.0	6.0	2135.3
Maximum*	1.5	1.6	7.0	6.8	2482.3
Minimum*	1.5	1.5	0.2	2.3	2014.8

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 4/26/2011 11:20

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3c

Period Start: 4/26/2011 00:00
 Period End: 4/26/2011 11:14
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3C_NOXCORR ppm	Average 3C_NOXC_24 ppm	Average 3C_COCORR ppm	Average 3C_COC_24 ppm	Average 3C_HICOMB mmbtu
04/26/2011 00:00	1.4	1.5	6.0	2.3	2162.9
04/26/2011 01:00	1.4	1.4	6.0	6.0	2159.3
04/26/2011 02:00	1.4	1.4	5.8	6.0	2161.3
04/26/2011 03:00	1.4	1.4	6.1	5.9	2159.4
04/26/2011 04:00	1.4	1.4	5.8	6.0	2159.5
04/26/2011 05:00	1.4	1.4	5.8	5.9	2158.5
04/26/2011 06:00	1.5	1.4	6.1	5.9	2159.0
04/26/2011 07:00	1.5	1.4	6.0	5.9	2159.0
04/26/2011 08:00	1.4	1.4	3.6	5.9	2291.5
04/26/2011 09:00	1.4	1.4	0.5	5.7	2478.3
04/26/2011 10:00	1.5	1.4	0.5	5.2	2468.1
04/26/2011 11:00	N/A	1.4	N/A	4.7	N/A
Final Average*	1.4	1.4	4.7	5.5	2228.8
Maximum*	1.5	1.5	6.1	6.0	2478.3
Minimum*	1.4	1.4	0.5	2.3	2158.5

*Does not include Invalid Averaging Periods ("N/A")