

## HEATING UNITS AND GENERAL PURPOSE INTERNAL COMBUSTION ENGINES



## COMPLIANCE INSPECTION CHECKLIST

	ANNUAL (INS1, INS2) RE-INSPECTION (FUI)	COMPLAINT/DISCOVE			
AIRS ID#: 0250683 DATE: <u>7/28/2011</u> ARRIVE: <u>1;15PM</u> DEPART: <u>1:45PM</u>					
FACILITY NAME: PUMP STATION S-331					
FACILITY LOCATION	N: 19755 SW 168TH ST				
	MIAMI 33187				
OWNER/AUTHORIZE Email: CONTACT NAME: J Email: ENTITLEMENT PERI		Mobile	E: (561)682-2516		
PART I: INSPECTION COMPLIANCE STATUS (check ✓ only one box)  ☐ IN COMPLIANCE ☐ MINOR Non-COMPLIANCE ☐ SIGNIFICANT Non-COMPLIANCE					
(check <b>☑</b> appropria	operate any emissions units other	PING REQUIREMENTS –	Rule 62-210.300, F.A.C.		

PART II: CONTROL TECHNOLOGY/RECORDKEEPING REQUIREMENTS – Rule 62-210.300, F.A.C. (continued (check ☑ appropriate box(es))	d)			
7. Does the owner/operator of the facility maintain records to document the fuel consumption, by type, for each emissions unit? (Rule 62-210.300(3)(c)3.e., F.A.C.)	] No			
PART III: GENERAL CONDITIONS/MAINTENANCE REQUIREMENTS – Rule 62-210.300(4)(e)6., 8., & 12., F.A.C. (check ☑ appropriate box(es))				
<ol> <li>Does the owner or operator make every reasonable effort to conduct the specific activity authorized by the general permit in a manner that minimizes adverse effects on adjacent property or on public use of the adjacent property, where applicable, and on the environment, including fish, wildlife, natural resources, water quality, or air quality?</li></ol>				

PART IV: SPECIAL CONDITIONS AND PROCEDUR (check ☑ appropriate box(es))	RES – Rule 62-210.300(4)(d)4., F.A.C.	
A. New or Modified Process Equipment		
<ul> <li>b) alterations to existing process equipment with</li> <li>c) replacement of existing equipment substantial recent notification form?</li> <li>d) If you answered <u>YES</u> to any of the above, did notification form and appropriate fee (Rule 62)</li> </ul>	the owner submit a new and complete	☐Yes ⊠No ☐Yes ⊠No
MARUFUL MALIK	7/28/2011	
Inspector's Name (Please Print)	Date of Inspection	_
	7/28/2012	
Inspector's Signature	Approximate Date of Next Inspection	_

**COMMENTS:** On July 28, 2011 I visited this facility to conduct the annual compliance inspection. On site I met Larry Schiefer, the Pump Station Oparator. This facility has three small diesel engines to pump water and two back up generators. A test ran was performed to all the generators for 15 minutes and vibration analysis was conducted today. Two 10.000 gallons above ground tanks were on site. The diesel pumps are used for emergency flood control.