

$\frac{\textbf{RECIPROCATING INTERNAL}}{\underline{\textbf{ENGINES}}} \, \frac{\textbf{COMBUSTION}}{}$



COMPLIANCE INSPECTION CHECKLIST

INSPECTION TYPE: ANNUAL (INS1, INS2) COMPLAINT/DISCOVERY (CI) RE-INSPECTION (FUI) ARMS COMPLAINT NO:				
AIRS ID#: 0930103 DATE: 11/13/2012 ARRIVE: 11:15 DEPART: 11:45				
FACILITY NAME: PUMP STATION S-133				
FACILITY LOCATION: 2780 SE HWY 441				
OKEECHOBEE 34974				
OWNER/AUTHORIZED REPRESENTATIVE: KAREN ESTOCK Email: CONTACT NAME: JEFFREY SMITH Email: JESMITH@SFWMD.GOV ENTITLEMENT PERIOD: 5/16/2011 / 5/16/2016 (effective date) (end date) PHONE: (561)682-6282 Mobile: PHONE: (561)682-6282 Mobile:				
PART I: <u>INSPECTION COMPLIANCE STATUS</u> (check ✓ only one box) ☐ IN COMPLIANCE ☐ MINOR Non-COMPLIANCE ☐ SIGNIFICANT Non-COMPLIANCE				
b) gasoline – 22,000 gallons/year (if gasoline is the sole source of energy at this facility)?	10 10			

PART II: CONTROL TECHNOLOGY/RECORDKEEPING REQUIREMENTS – Rule 62-210.300, F.A.C. (continued) (check ☑ appropriate box(es))
7. Does the owner/operator of the facility maintain records to document the fuel consumption, by type, for each emissions unit? (Rule 62-210.300(3)(c)3.e., F.A.C.)
PART III: GENERAL CONDITIONS/MAINTENANCE REQUIREMENTS – Rule 62-210.300(4)(e)6., 8., & 12., F.A.C. (check ☐ appropriate box(es)) 1. Does the owner or operator make every reasonable effort to conduct the specific activity authorized by the general permit in a manner that minimizes adverse effects on adjacent property or on public use of the adjacent property, where applicable, and on the environment, including fish, wildlife, natural resources, water quality, or air quality?
 Does the owner or operator maintain the permitted facility, emission unit, or activity in good condition?

PART IV: <u>SPECIAL CONDITIONS</u> <u>AND</u> <u>PROCEDU</u> (check ☑ appropriate box(es))	<u>RES</u> – Rule 62-210.300(4)(d)4., F.A.C.			
A. New or Modified Process Equipment				
1. Since the last inspection has there been a) installation of any new process equipment?				
Patricia Tampas	11/13/2012			
Inspector's Name (Please Print)	Date of Inspection	_		
	11/13/2017			
Inspector's Signature	Approximate Date of Next Inspection	_		

COMMENTS: Walk through and record review found no violations. Facility keeps fuel records of the total site used. Each engine has a digital display showing total hours run. The station operated 5 Caterpiller, model 3406, 261 HP engines that drive five pumps that move water from the rim canal into the lake for flood control. There is a small generator that is decomissioned and soon to be removed because a larger generator in it's own building replaceed it.