

$\frac{\textbf{RECIPROCATING INTERNAL}}{\underline{\textbf{ENGINES}}} \, \frac{\textbf{COMBUSTION}}{}$



COMPLIANCE INSPECTION CHECKLIST

	ANNUAL (INS1, INS2) RE-INSPECTION (FUI)	COMPLAINT/DIS	· / <u> </u>		
AIRS ID#: 0250768 DA	TE: <u>7/17/2012</u>	ARRIVE: <u>11:09 A</u>	<u>M</u> DEPART: <u>11:22 AM</u>		
FACILITY NAME: PUMP STATION #2 (9TH ST PUMP STATION)					
FACILITY LOCATION: 1075 BISCAYNE BLVD					
	MIAMI 33132-1701				
OWNER/AUTHORIZE Email: CONTACT NAME: F Email: rorou01@mi ENTITLEMENT PERI	amidade.gov		PHONE: (786)552-8116 Mobile: PHONE: (786)552-8123 Mobile:		
PART I: <u>INSPECTION COMPLIANCE STATUS</u> (check ✓ only one box) ☐ IN COMPLIANCE ☐ MINOR Non-COMPLIANCE ☐ SIGNIFICANT Non-COMPLIANCE					

PART II: CONTROL TECHNOLOGY/RECORDKEEPING REQUIREMENTS – Rule 62-210.300, F.A.C. (continued)					
(check ☑ appropriate box(es))					
 Does the owner/operator of the facility maintain records to document the fuel consumption, by type, for each emissions unit? (Rule 62-210.300(3)(c)3.e., F.A.C.)					
(Rule 62-210.300(4)(b)2.b., F.A.C.) a) employing energy conservation measures to reduce the demand for heat from any heating units? b) performing regular maintenance of heating units to ensure efficient heat recovery? c) Yes No c) the use of, or considering the use of economizers to recycle waste heat back into the combustion air stream?					
d) improved operating procedures to reduce the load on any internal combustion engines?					
PART III: GENERAL CONDITIONS/MAINTENANCE REQUIREMENTS – Rule 62-210.300(4)(e)6., 8., & 12., F.A.C. (check ☑ appropriate box(es))					
1. Does the owner or operator make every reasonable effort to conduct the specific activity authorized by the general permit in a manner that minimizes adverse effects on adjacent property or on public use of the adjacent property, where applicable, and on the environment, including fish, wildlife, natural resources, water quality, or air quality?					
water quality, or air quality?					
inoperable condition of applicable air pollution control devices?					

PART IV: <u>SPECIAL CONDITIONS</u> <u>AND PROCEDURE</u> (check ☑ appropriate box(es))	<u>S</u> – Rule 62-210.300(4)(d)4., F.A.C.	
 b) alterations to existing process equipment without c) replacement of existing equipment substantially recent notification form? d) If you answered <u>YES</u> to any of the above, did the notification form and appropriate fee (Rule 62-4) 	he owner submit a new and complete	☐Yes ⊠No ☐Yes ⊠No
FRANK DELGADO	7/17/2012	
Inspector's Name (Please Print)	Date of Inspection	_
	7/2013	
Inspector's Signature	Approximate Date of Next Inspection	_

COMMENTS: THERE ARE TWO (2) DIESEL-FUELED ENGINES USED TO DRIVE TWO (2) EMERGENCY POWER GENERATORS. THE ENGINES ARE TESTED ONCE PER WEEK FOR ABOUT AN HOUR. THE HIGHEST 12-MONTH TOTAL FUEL CONSUMPTION OCCURRED BETWEEN SEPTEMBER 2005 AND AUGUST 2006 WITH 3,080 GALLONS OF DIESEL FUEL CONSUMED.

REVIEWED

By Ray Gordon at 10:03 am, Aug 14, 2012