

HEATING UNITS AND GENERAL PURPOSE INTERNAL COMBUSTION ENGINES



COMPLIANCE INSPECTION CHECKLIST

	ANNUAL (INS1, INS2) RE-INSPECTION (FUI)	COMPLAINT/D	DISCOVERY (CI) AINT NO:
AIRS ID#: 0990650 DA	TE: <u>10/27/2010</u>	ARRIVE: <u>1245</u>	DEPART: <u>1310</u>
FACILITY NAME: WA	ATER TREATMENT PLANT 9		
FACILITY LOCATION	N: 22438 SW 7TH AVE		
	BOCA RATON 33433		
OWNER/AUTHORIZE Email: CONTACT NAME: V Email: ENTITLEMENT PERIO			PHONE: (561)493-6000 Mobile: PHONE: (561)381-5354 Mobile:
PART I: INSPECTION IN COMPLIANCE	CE MINOR Non-COMP		GNIFICANT Non-COMPLIANCE
 (check ☑ appropriat Does the facility of combustion engine paragraph 62-210 F.A.C.? (Rule 62- 	te box(es)) operate any emissions units other es and emissions units which are	than the heating units exempt from permitti be been exempted from	ring pursuant to the criteria of n permitting under Rule 62-4.040,

PART II: CONTROL TECHNOLOGY/RECORDKEEPING REQUIREMENTS – Rule 62-210.300, F.A.C. (continued)				
(check ☑ appropriate box(es))				
8. Does the owner/operator retain, and make available for Department inspection, these records for a period of at least five years? (Rule 62-210.300(3)(c)3.e., F.A.C.)——————————————————————————————————	Yes ⊠ No Yes □ No			
PART III: GENERAL CONDITIONS/MAINTENANCE REQUIREMENTS – Rule 62-210.300(4)(e)6., 8., & 12 (check ☑ appropriate box(es))	2., F.A.C.			
 Does the owner or operator maintain the permitted facility, emission unit, or activity in good condition? Has the owner or operator allowed the circumvention of any applicable air pollution control devices? Has the owner or operator allowed the emission of air pollutants as the result of the malfunction of, or 	Yes ⊠ No Yes □ No Yes ⊠ No Yes ⊠ No			

PART IV: SPECIAL CONDITIONS AND PROCEDUR (check ☐ appropriate box(es))	RES – Rule 62-210.300(4)(d)4., F.A.C.			
A. New or Modified Process Equipment				
1. Since the last inspection has there been a) installation of any new process equipment?				
Patricia Tampas	10/27/2010			
Inspector's Name (Please Print)	Date of Inspection	_		
	10/27/2010			
Inspector's Signature	Approximate Date of Next Inspection	_		

COMMENTS: There are two emergency generators at this facility for water treatment back up. The permit was expired at the time of the inspection, but the paperwork was already submitted. The facility was without an active permit for a total of two months. The facility runs these generators normally approx 4 to 8 hours monthly to keep them operating.