| WHERTUL PROTECTION |
|--------------------|
| Same Variation |
| FLORIDA |
| |

<u>RECIPROCATING INTERNAL COMBUSTION</u> <u>ENGINES</u>



COMPLIANCE INSPECTION CHECKLIST

| INSPECTION TYPE: ANNUAL (INS1, INS2) COMPLAINT/I RE-INSPECTION (FUI) ARMS COMPL | DISCOVERY (CI) | | | | | |
|--|--|--|--|--|--|--|
| AIRS ID#: 0251286 DATE: 12/27/2013ARRIVE: 11:15FACILITY NAME: QUALITY TECHNOLOGY SERVICES-MIAMIFACILITY LOCATION:11234 NW 20th StMIAMI33172-1824 | AM DEPART: <u>12:00PM</u> | | | | | |
| OWNER/AUTHORIZED REPRESENTATIVE: CHAD WILIAMS PHONE: (786)515-2114 Email: david.murray@qualitytech.com Mobile: CONTACT NAME: DOUGLAS MAYTAN PHONE: (786)413-9752 Email: douglas.maytan@qualitytech.com Mobile: ENTITLEMENT PERIOD: 6/14/2013 / 6/14/2018 6/14/2018 (effective date) (end date) | | | | | | |
| PART I: INSPECTION COMPLIANCE STATUS (check I only one box) IN COMPLIANCE MINOR Non-COMPLIANCE SIGNIFICANT Non-COMPLIANCE | | | | | | |
| PART II: <u>CONTROL TECHNOLOGY/RECORDKEEPING REQUIREN</u> (check appropriate box(es)) 1. Does the facility operate any emissions units other than the heating uni combustion engines and emissions units which are exempt from permitt paragraph 62-210.300(3)(a), or (b), F.A.C., or have been exempted from F.A.C.? (Rule 62-210.300(3)(c)3.a., F.A.C.) | its and general purpose internal tting pursuant to the criteria of m permitting under Rule 62-4.040, | | | | | |

PART II: <u>CONTROL TECHNOLOGY/RECORDKEEPING REQUIREMENTS</u> – Rule 62-210.300, F.A.C. (*continued*)

(check ☑ appropriate box(es))

| | Does the owner/operator of the facility maintain records to document the fuel consumption, by type, for each emissions unit? (Rule 62-210.300(3)(c)3.e., F.A.C.) | ⊠Yes □ No ⊠Yes □ No |
|----|---|------------------------|
| 9. | Does the owner or operator voluntarily encourage pollution prevention through such measures as: (Rule 62-210.300(4)(b)2.b., F.A.C.) | |
| | a) employing energy conservation measures to reduce the demand for heat from any heating units?b) performing regular maintenance of heating units to ensure efficient heat recovery?c) the use of, or considering the use of economizers to recycle waste heat back into the combustion air | ⊠Yes □ No ⊠Yes □ No |
| | stream?d) improved operating procedures to reduce the load on any internal combustion engines? | ⊠Yes □ No ⊠Yes □ No |
| | e) the use of, or considering the use of alternative fuels? | ⊠Yes 🗌 No |

PART III: <u>GENERAL CONDITIONS/MAINTENANCE REQUIREMENTS</u> – Rule 62-210.300(4)(e)6., 8., & 12., F.A.C. (check ☑ appropriate box(es))

| 1. | Does the owner or operator make every reasonable effort to conduct the specific activity authorized by the general permit in a manner that minimizes adverse effects on adjacent property or on public use of the | 2 |
|----|---|------------|
| | adjacent property, where applicable, and on the environment, including fish, wildlife, natural resources, | |
| | water quality, or air quality? | ⊠Yes 📙 No |
| 2. | Does the owner or operator maintain the permitted facility, emission unit, or activity in good condition? | 🛛 Yes 🗌 No |
| 3. | Has the owner or operator allowed the circumvention of any applicable air pollution control devices? | 🛛 Yes 🗌 No |
| 4. | Has the owner or operator allowed the emission of air pollutants as the result of the malfunction of, or | |
| | inoperable condition of applicable air pollution control devices? | 🗌 Yes 🗌 No |

| PART IV: <u>SPECIAL CONDITIONS AND PROCEDU</u> (check ☑ appropriate box(es)) A. <u>New or Modified Process Equipment</u> | <u>RES</u> – Rule 62-210.300(4)(d)4., F.A.C. | | | |
|---|--|--|--|--|
| Since the last inspection has there been a) installation of any new process equipment? | | | | |
| MARUFUL MALIK | 12/27/2013 | | | |
| Inspector's Name (Please Print) | Date of Inspection | | | |
| | 12/2014 | | | |

Inspector's Signature

Approximate Date of Next Inspection

COMMENTS: On December 27, 2013 I visited this facility to conduct the annual compliance inspection. On site I met Daniel Fabiana, the Lead Technician of the facility. This facility is a Data Center with three emergency diesel-powered generators and three 20,000 gallons diesel fuel storage tanks, and two 400 gallons Day tanks on site. The test run is conducted on two generators for fifteen (15) minutes once a week. The test run is conducted on the third generator for five(5) minutes twice a month. The total site run hours for all three generators in 2013 were 52.9 hours. The total diesel consumption for 2013 was 1,923 gallons. No objectionable odor was detected inside or outside the facility.

REVIEWED By Ray Gordon at 10:42 am, Jan 28, 2014