

## HEATING UNITS AND GENERAL PURPOSE INTERNAL COMBUSTION ENGINES



## COMPLIANCE INSPECTION CHECKLIST

INSPECTION TYPE: ANNUAL (INS1, INS2) COMPLAINT, RE-INSPECTION (FUI) ARMS COMP	/DISCOVERY (CI)
AIRS ID#: 0251323 DATE: 10/21/2010 ARRIVE: 10:20  FACILITY NAME: NORWOOD-OEFFLER WATER TREATMENT PLA	
FACILITY LOCATION: 19150 NW 8TH AVE  MIAMI GARDENS 33169-3100  OWNER/AUTHORIZED REPRESENTATIVE: KARL THOMPSON Email:	PHONE: (305)948-2983 Mobile:
CONTACT NAME: GODFREY SOOKLAL Email: ENTITLEMENT PERIOD: 4/30/2010 / 4/30/2015 (effective date) (end date)	PHONE: (305)650-0000 Mobile:
PART I: INSPECTION COMPLIANCE STATUS (check ✓ only one be IN COMPLIANCE ☐ MINOR Non-COMPLIANCE ☐ STATUS	ox) IGNIFICANT Non-COMPLIANCE
PART II: CONTROL TECHNOLOGY/RECORDKEEPING REQUIRE (check ☑ appropriate box(es))  1. Does the facility operate any emissions units other than the heating un combustion engines and emissions units which are exempt from perm paragraph 62-210.300(3)(a), or (b), F.A.C., or have been exempted from F.A.C.? (Rule 62-210.300(3)(c)3.a., F.A.C.)  2. Are these heating units or general purpose internal combustion engine Program as defined at Rule 62-210.200, F.A.C.? (Rule 62-210.300(3)(a))  3. Were visible stack emissions tests conducted during this site visit according (40 CFR 60, Appendix A)?	nits and general purpose internal itting pursuant to the criteria of om permitting under Rule 62-4.040,

PART II: CONTROL TECHNOLOGY/RECORDKEEPING REQUIREMENTS – Rule 62-210.300, F.A.C. (con	tinued)
(check ☑ appropriate box(es))	
7. Does the owner/operator of the facility maintain records to document the fuel consumption, by type, for each emissions unit? (Rule 62-210.300(3)(c)3.e., F.A.C.)——————————————————————————————————	es No es No es No es No es No
PART III: GENERAL CONDITIONS/MAINTENANCE REQUIREMENTS – Rule 62-210.300(4)(e)6., 8., & 12. (check ☑ appropriate box(es))	., F.A.C.
4. Has the owner or operator allowed the emission of air pollutants as the result of the malfunction of, or	

That noted on the most  that noted on the most  t a new and complete of the appropriate DEP or  Yes No  Yes No  Yes No  Yes No
Hat noted on the most  That no
t a new and complete of the appropriate DEP or
10/21/2010
ate of Inspection
)11
oproximate Date of Next Inspection
20

COMMENTS: PAT MITCHELL, THE FACILITY'S OPERATIONS MANAGER ATTENDED ME. THERE IS ONE CATERPILLAR DIESEL GENERATOR ON SITE. THE OTHER THREE (3) MENTIONED IN THE GENERAL PERMIT NOTIFICATION HAVE NOT BEEN INSTALLED. THE DIESEL GENERATOR IS USED FOR EMERGENCY POWER. IT IS TESTED FOR FOUR (4) HOURS ONCE PER MONTH. THE AMOUNT OF DIESEL FUEL BURNED FOR THE LAST 12 MONTHS IS 10416 GALLONS. THE HOUSEKEEPING IS GOOD.