Jacksonville
Where Florida Begins.

NOTICE OF PERMIT ISSUANCE

CERTIFIED – RETURN RECEIPT

Mr. Christopher Pelligreen
Omega Partners III, LLC
711 Old Ballas Rd, Suite 216
St Louis, MO 63141

Re: Duval County - Air Pollution
Omega Partners III, LLC
Jacksonville Terminal
Bulk Gasoline Fuel Terminal
FINAL Permit No.: 0310556-001-AC

Dear Mr. Pelligreen:

Enclosed is Permit Number 0310556-001-AC for the subject air pollution source, issued pursuant to Section 403.087, Florida Statutes (FS).

Any party to this Order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, FS, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, City of Jacksonville, 117 West Duval Street, Suite 480, Jacksonville, FL 32202, and with the Clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, FL, 32399-3000, and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date this Notice is filed with the Clerk of the Department.

Executed in Jacksonville, Florida.

City of Jacksonville
Environmental and Compliance Department
Environmental Quality Division

Richard L. Robinson FOR

Robert Steven Pace, P.E., Manager
Air Quality Branch

RSP/RLR/jw

CERTIFICATE OF SERVICE

The undersigned duly designated Department Clerk hereby certifies that this **Final Permit** was mailed before the close of business on March 21, 2008 to the listed person:

Mr. Christopher Pelligreen, President, Omega Partners III, LLC

The undersigned duly designated Department Clerk hereby certifies that this **Final Permit** was e-mailed to the listed person(s):

Ms. Rita Felton-Smith, FDEP, Northeast District
Ms. Aimee Andrews, P.E., Trinity Consultants
Mr. Brad James, Trinity Consultants

FILING AND ACKNOWLEDGMENT

FILED, on this date, pursuant to S.120.52(7), FS, with the designated Department Clerk, receipt of which is hereby acknowledged.

Elaine Tebles
Clerk

March 21, 2008
Date

s:\air quality\permitn\CP\final\0310556-001fm -AC

Jacksonville
Where Florida Begins.

Permittee:
Omega Partners III, LLC
711 Old Ballas Rd, Suite 216
St. Louis, MO 63141

Final Permit No.: 0310556-001-AC
Facility ID No.: 0310556
SIC Nos.: 51
Project: Fuel Terminal Modification

This permit is for the construction/modification of a bulk fuels terminal. An existing storage tank will be retrofitted with an internal floating roof and a new tank will be constructed with an internal floating roof. A two bay loading rack will be constructed with two loading arms per bay. Fuel products will be unloaded from barges and/or rail car tankers. Various fuels will include gasolines, gasoline blends, aviation fuels, distillate fuel oils and ethanol. This facility is located at 3721 Talleyrand Ave, Jacksonville, Duval County, FL; UTM Coordinates: Zone 17, 444 km East and 3359 km North; Latitude: 30° 21' 48" North and Longitude: 81° 34' 57" West.

This permit is issued under the provisions of Chapter 403, Florida Statutes (FS) and Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296, and 62-297, Florida Administrative Code, (FAC). The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the Environmental and Compliance Department, Environmental Quality Division (Department) in accordance with the terms and conditions of this permit.

Operation Permit Application Due Date: **March 1, 2009**
Expiration Date: **May 31, 2009**

Environmental and Compliance Department
Environmental Quality Division

FOR

Robert Steven Pace, P.E., Manager
Air Quality Branch

RSP/JW

20. The owner or operator of the loading rack shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of this emission unit.
[40 CFR 60.7(b), Rule 62-204.800, FAC, and Rule 2.201, JEPB]

21. The owner or operator shall provide the vapor combustor manufacturer, model number and specifications with the air operation permit application if any changes have been made from the air construction permit application.
[Rule 62-4.070, FAC, and Rule 2.1301, JEPB]

FILING AND ACKNOWLEDGMENT

FILED, on this date, pursuant to S.120.52(7), FS, with the designated Department Clerk, receipt of which is hereby acknowledged.

Elaine Fobles — Clerk

March 21, 2008 — Date

s:\air quality\permitn\CP\final\0310556-001k-AC