FINAL DETERMINATION

I. GENERAL INFORMATION

A. APPLICANT

Omega Partners III, LLC
3721 Talleyrand Avenue
Jacksonville, FL 32206

Final Permit No: 0310556-001-AC
County: Duval

B. PROJECT

The applicant, Omega Partners III, LLC, applied on November 29, 2007 to the Department for a permit for the construction/modification of a bulk fuels terminal. An existing storage tank will be retrofitted with an internal floating roof and a new tank will be constructed with an internal floating roof. A two bay loading rack will be constructed with two loading arms per bay. Fuel products will be unloaded from barges and/or rail car tankers. Various fuels will include gasolines, gasoline blends, aviation fuels, distillate fuel oils and ethanol. Omega Partners III, LLC, Jacksonville Terminal, is located at 3721 Talleyrand Avenue, Jacksonville, FL 32206.

II. FINAL DETERMINATION

The Technical Evaluation and Preliminary Determination for the project described above was distributed on February 21, 2008. The Public Notice of Intent to Issue Permit was published in the Jacksonville Business Journal on February 29, 2008. The Proof of Publication of Public Notice of Intent to Issue Permit was received on March 13, 2008. Copies of the evaluation were available for public inspection at the Environmental and Compliance Department, Environmental Quality Division (Department).

One comment was submitted (received March 11, 2008 by e-mail) on the Public Notice of Intent to Issue Permit by Mr. Brad James, Trinity Consultants, Inc., consultant for Omega partners III, LLC. The comment noted that the incorrect control device was listed for the Tank Truck Loading System (Emission Unit No. 2). As a result of the comment the control device description will be changed as follows:

From: Tornado Flare Systems, Inc. Vapor Combustor

To: MRW Technologies, Inc. Enclosed Loadout Flare

It is noted that the facility shall be subject to the following subpart: 40 CFR 63, Subpart BBBBBB, National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities and applicable provisions of 40 CFR 63, Subpart A, General Provisions. Note: The above referenced Subpart BBBBBB was proposed on November 9, 2006 and was promulgated on January 10, 2008. All required reports, notifications, and correspondence should be sent to the Environmental Protection Agency **and** the Department (Environmental Quality Division) at the following addresses:

Environmental and Compliance Department
Environmental Quality Division
117 West Duval Street, Suite 225
Jacksonville, FL 32202
Telephone: (904) 630-4900
Fax: (904) 630-3638

United States Environmental Protection Agency
Region 4
Air, Pesticides & Toxics Management Division
Air and EPCRA Enforcement Branch
61 Forsyth Street
Atlanta, GA 30303
Telephone: 404/562-9155
Fax: 404/562-9163

All required reports, notifications, and correspondence should be mailed in accordance with the timelines and requirements specified in 40 CFR, Part 63, Subpart A and 40 CFR, Part 63, Subpart BBBBBB.

The final action of the Department will be to issue Construction Permit 0310556-001-AC as proposed in the Technical Evaluation and Preliminary Determination with the change noted above.