


3. New 100,000 barrel crude oil storage tank: The permittee is authorized to install a new 100,000 barrel crude oil storage tank (TK-002) with associated pumps and piping. The tank shall be constructed with an external floating roof painted white with a mechanical shoe to meet the applicable requirements of 40 CFR 60 subpart Kb. [40 CFR 60.112b(2)(i and ii), Rules 62-4.070(3) and 62-210.300(1), F.A.C., and Application No. 0330289-002-AC]
4. Appendices: The following Appendices are attached as part of this permit:
  - a. Appendix A. Citation Formats and Glossary of Common Terms;
  - b. Appendix B. General Conditions;
  - c. Appendix C. Common Conditions
  - d. Appendix D. 40 CFR 60 Subpart Kb - Standards of Performance for VOL Storage Vessels

#### STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-210, and 62-212 of the Florida Administrative Code (F.A.C.).

Executed in Pensacola, Florida.



J. Charles Harp  
Program Administrator  
Waste Management/Air Resources

May 30, 2013

Date

Copies furnished to:

Kristi Unzicker, Energy, LLC, [Kristi.Unzicker@genlp.com](mailto:Kristi.Unzicker@genlp.com)  
Lee Rogers, P.E.; PPM Consulting, [lee.rodgers@ppmco.com](mailto:lee.rodgers@ppmco.com)