

- A.21.** Compliance with the additional heat input weighted 30-day rolling average NO_x emission limit of 0.10 lb NO_x/mmBtu shall be demonstrated using CEMS data beginning July 1, 2007, (or 30 boiler operating days after June 1, 2007), and every 30 ~~calendar~~ or boiler operating days thereafter.

[Rule 62-4.070(3), F.A.C.]

A copy of this letter shall be filed with the referenced permit and shall become part of the permit. Any party to this permitting decision (order) has the right to seek judicial review of it under Section 120.68 of the Florida Statutes, by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.



Joseph Kahn, Director
Division of Air Resource Management


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this PERMIT MODIFICATION was sent electronically (with Received Receipt) before the close of business on 12/29/06 to the person(s) listed below:

Karen Sheffield, General Manager, TEC: kashffield@tecoenergy.com
Byron Burrows, TEC: btburrows@tecoenergy.com
Tom Davis, ECT: tdavis@ectinc.com
Mara Nasca, FDEP-SWD: mara.nasca@dep.state.fl.us
Diana Lee, HCEPC: Lee@epchc.org
James Little, EPA Region 4: little.james@epa.gov

Clerk Stamp

FILING AND ACKNOWLEDGMENT
FILED, on this date, pursuant to §120.52,
Florida Statutes, with the designated
Department Clerk, receipt of which is hereby
acknowledged.


(Clerk)

12/29/06
(Date)