

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
NOTICE OF FINAL PERMIT

In the Matter of an
Application for Permit by:


Robert McGarrah, Manager of Power Production
City of Tallahassee
1125 Geddie Road
Tallahassee, Florida 32304

DEP File No. 0730003-006-AC
Arvah B. Hopkins Generating Station
Leon County

Enclosed is Final Permit Number 0730003-006AC. This permit authorizes the City of Tallahassee to establish an allowable emissions limitation for excess visible emissions resulting from fuel switching, startup or shutdown of an individual burner, or minor load change. The current permit allows emissions in excess of the permitted limit for up to 2 hours in any 24 hour period for occurrences of a unit start up, shut down or malfunction. However, due to the operational nature of this specific dual fuel-fired boiler, fuel switching and minor load changes can sometimes result in visible emissions slightly above the current permitted levels with no detectable increase in particulate matter emissions. In accordance with rule 62-210.700(5), Florida Administrative Code (F.A.C.), considering operational variations in types of industrial equipment operations affected by this rule, the Department may adjust maximum and minimum factors to provide reasonable and practical regulatory controls consistent with the public interest. This permit is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order has the right to seek judicial review of it under section 120.68 of the Florida Statutes, by filing a notice of appeal under rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief
Bureau of Air Regulation


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Final Permit (including the Final permit) was sent by certified mail (*) and copies were electronically mailed by Internet e-mail before the close of business on 12/7/04 to the person(s) listed:

Mr. Robert McGarrah, Manager of Power Production, COT*
Mr. John Powell, P.E. (powellJ@talgov.com)
Mr. Kevin White, DEP-SWD
Mr. Gerry Neubauer, DEP-NWDT
Mr. Hamilton Oven, P.E., DEP-SCO

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.


(Clerk) 12/7/04
(Date)



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

PERMITTEE:

City of Tallahassee
Arvah B. Hopkins Generating Station
1125 Geddie Road
Tallahassee, Florida 32304

ARMS Permit No.	0730003-006-AC
Facility ID No.	0730003
SIC No.	4911
Expires:	May 31, 2005

Authorized Representative:

Robert McGarrah, Manager of Power Production

PROJECT AND LOCATION

This permitting action is being issued at the applicant's request to allow for excess visible emissions resulting from fuel switching, startup or shutdown of an individual burner, or minor load change. The current permit allows emissions in excess of the permitted limit for up to 2 hours in any 24 hour period for occurrences of a unit start up, shut down or malfunction. However, due to the operational nature of this specific dual fuel-fired boiler, fuel switching and minor load changes can sometimes result in visible emissions slightly above the current permitted levels with no detectable increase in particulate matter emissions. In accordance with rule 62-210.700(5), Florida Administrative Code (F.A.C.), considering operational variations in types of industrial equipment operations affected by this rule, the Department may adjust maximum and minimum factors to provide reasonable and practical regulatory controls consistent with the public interest.

The facility is located at 1125 Geddie Road, Tallahassee, Leon County.

STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to make changes in accordance with the conditions of this permit.

APPENDICES

The following attached document is incorporated as part of this permit:

Appendix CG

General Conditions

Michael G. Cooke, Director
Division of Air Resource Management

MGC/jkp/jh

Enclosure

cc: Kevin White, DEP - NWD
Jennette Curtis, City of Tallahassee
Buck Oven, DEP - PPSCO

Andy Allen, DEP - NWD
John Powell, City of Tallahassee
Gerry Neubauer, DEP - NWDT