

SECTION IV. APPENDICES

CONTENTS

Appendix ASTM	ASTM Standard D6751-09 for Biodiesel;
Appendix BMP	Best Management Practices Plan;
Appendix CC	Common Conditions;
Appendix CEMS	Continuous Emissions Monitoring System (CEMS) Requirements;
Appendix CF	Citation Formats and Glossary of Common Terms;
Appendix CTR	Common Testing Requirements;
Appendix Db	NSPS, 40 CFR 60, Subpart Db - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units;
Appendix F	40 CFR 75, Appendix F, Section 5 – Measurement of Boiler Heat Input Rates;
Appendix GC	General Conditions;
Appendix GP	Identification of General Provisions - NSPS 40 CFR 60, Subpart A and NESHAP 40 CFR 63, Subpart A;
Appendix IIII	NSPS, Subpart IIII - Stationary Compression Ignition Internal Combustion Engines; and,
Appendix ZZZZ	NESHAP, Subpart ZZZZ - Stationary Reciprocating Internal Combustion Engines (RICE).

SECTION IV. APPENDIX ASTM
ASTM STANDARD D6751-09 FOR BIODIESEL

ASTM standard for biodiesel is defined as the mono alkyl esters of long chain fatty acids derived from vegetable oils or animal fats, for use in compression-ignition (diesel) engines. This specification is for pure (100%) biodiesel prior to use or blending with diesel fuel.

Standards for Biodiesel	ASTM D-6751	IS 15607 : 2005
Density	Not Mentioned	860 - 900 Kg / m ³
Ester Content	Not Mentioned	96.5 %
Flash point (closed cup)	130°C min. (150°C average)	120°C
Water and sediment	0.050% by vol., max.	500 mg / Kg, max.
Kinematic viscosity at 40°C	1.9-6.0 mm ² /s	2.5-6.0 mm ² /s
Oxidation Stability	Not Mentioned	6 hours min, at 110°C
Ramsbottom carbon residue, % mass	0.10	
Sulfated ash	0.020% by mass, max.	
Sulfur	0.0015% by mass, max*.	50 mg / Kg max
Copper strip corrosion 3 hrs. 50°C	No. 3 max	Class 1
Cetane	47 min.	51 min.
Carbon residue	0.050% by mass, max.	
Acid number, mg KOH/g	0.80 max.	0.50 max.
Methanol or Ethanol	Not Mentioned	0.2 % m/m, max
Free glycerin	0.020 % mass	0.020 % mass
Total glycerine (free glycerine and unconverted glycerides combined)	0.24% by mass, max.	0.25% by mass, max.
Group I Metal (Na+K)	5 mg/Kg, max	5 mg/Kg, max
Group II Metal (Ca+Mg)	Not Mentioned	5 mg/Kg, max
Phosphorus content	0.001 max. % mass	10 mg/Kg, max
Distillation	90% @ 360°C	Not Mentioned

* **S 15 Grade Biodiesel** is required for the FBE Project to meet the fuel sulfur requirements of 40 CFR 60, NSPS Subparts IIII and Db.

SECTION IV. APPENDIX BMP

BEST MANAGEMENT PRACTICES (BMP) PLAN

PRELIMINARY BEST MANAGEMENT PRACTICES (BMP) PLAN FOR MINIMIZATION OF FUGITIVE DUST, STORAGE PILE MANAGEMENT, FIRE PREVENTION AND BIOMASS QUALITY ASSURANCE

The permittee shall comply with this BMP plan and any update hereto.

[Rule 62-4.070, F.A.C. Reasonable Assurance and Rule 62-296.320(4)(c), F.A.C.]

{Permitting Note: The preliminary BMP plan will be updated by FBE as the engineering of the Biomass Feedstock delivery, handling and preparation emission unit (EU-001) is finalized. The final BMP plan must be submitted to the Compliance Authority no later than 180 days before the FBE facility becomes operational}

Practice	Description
Minimization of Fugitive Dust	<ol style="list-style-type: none">1) Conveyor systems and associated drop points shall be enclosed to the extent practicable to minimize exposure to air currents. Enclosed conveyors means that the conveyance belt for the biomass is totally enclosed from above thus preventing wind from causing fugitive dust emissions. However, the bottom of the conveyance belt shall be accessible for maintenance and repairs.2) Drop points to woody biomass storage areas shall be designed to minimize the overall drop height exposed to air current.3) Periodic equipment inspection and maintenance shall be performed to maintain the integrity of conveyor systems and associated drop point enclosures. Appropriate plant records shall be maintained on equipment maintenance performed.4) Fuel silos shall be equipped with vent filters.5) Plant personnel shall conduct daily inspections of the conveyor systems and associated drop point integrity to identify any equipment abnormalities.6) Signs shall be posted identifying warning signs of potential equipment malfunction.7) Plant personnel shall be trained on identification of warning signs for potential equipment malfunction.8) Procedures shall be established for defining excessive fugitive dust from woody biomass truck unloading operations. Plant personnel shall monitor truck unloading operations and if excessive fugitive dust is detected plant personnel shall implement appropriate fugitive dust minimization techniques. Plant personnel shall be trained on procedures for defining and minimizing excessive dust from the truck unloading operations.9) All major roadways at the plant shall be paved.10) Plant personnel shall be trained on what constitutes excessive dust on paved roads.11) Transfer points and fuel bins are equipped with vent filters.12) Fuel handling equipment shall be inspected for proper operation and for maintenance requirements.13) Plant fuel handling personnel shall implement procedures for monitoring and controlling unplanned fugitive dust emissions, including truck handling and unloading.14) Plant personnel shall will spray, wash, scrape, or otherwise remove dirt or spilled biomass fuel on plant roads as necessary to reduce fugitive emissions.
Storage Pile Management	<ol style="list-style-type: none">1) A woody biomass storage pile fugitive dust management plan shall be developed and maintained onsite. The plan shall identify warning signs and identify corrective actions for conditions that could result in excessive wind erosion and fugitive dust formation. Plant personnel shall be trained to recognize such warning signs.2) Operational plans will recognize conditions such as high winds likely to result in wind erosion and excessive fugitive dust and will instruct plant personnel to

SECTION IV. APPENDIX BMP

BEST MANAGEMENT PRACTICES (BMP) PLAN

	<p>curtail movement of fuel by mobile equipment under such conditions.</p> <ol style="list-style-type: none"> 3) Mechanical moving of woody biomass by front end loaders and other supporting equipment shall be minimized on high wind event days. 4) First in first out biomass utilization shall be implemented to minimize objectionable odors. 5) The woody biomass storage areas shall be monitored and if conditions are conducive to wind erosion and fugitive dust formation, procedures from the fugitive dust plan shall be implemented. 6) Mobile equipment will be used to maintain the pile's design shape and to ensure adherence to FIFO in reclaim operations
Fire Prevention /Spontaneous Combustion Minimization	<ol style="list-style-type: none"> 1) A fire management plan (FMP) shall be developed to identify and list the causes and conditions giving rise to spontaneous combustion. 2) Contact local fire marshal to develop fire management plan. The FMP shall be maintained on site. 3) The FMP shall include: a) requirement to train onsite personnel to handle incipient fires and training on the identification of potential fire hazards; and, b) install and maintain equipment for plant personnel to handle incipient fires. The local fire department shall be invited to participate in onsite training. 4) Sufficient inspections of the woody biomass storage areas shall be performed by plant personnel to identify potential fire hazards. Plant personnel shall be trained on identification of potential fire hazards. 5) Signs which identify potential fire hazards shall be posted at the plant. 6) Incoming unprocessed materials shall be stored in areas in accordance with clearance ranges between each storage area as described in the FMP. 7) The stacker reclaimer shall maximize the removal of older material in order to minimize the stacking of newer material on top of older material. 8) Compaction of woody biomass materials in the storage areas shall be minimized. 9) Fuel pile fire protection equipment may be used for minimization of fugitive dust emissions and dust suppression as required. 10) Plant personnel shall conduct daily inspection for fire hazards and monitor the hazards using video surveillance. 11) The FMP shall describe the use of fire-water cannons, mounted on elevated structures, together with mobile equipment to uncover and rapidly extinguish any smoldering materials. 12) The size of the fuel storage pile will not exceed the design value – this is a primary control measure, based upon the limited on-site fuel storage of about 2 weeks' worth of fuel. Specifically, the stacker will build a pile in zones up to a maximum of 60 feet high (an average of 40 feet high) and the reclaimer will start with the first zone built and reclaim the pile down to within two inches of grade.
Quality Assurance of Clean Woody Biomass	<p>Clean woody biomass shall mean: the feedstock will consist of woody biomass that will be processed at a remote fuel preparation area (or areas) where it will be sorted, screened and chipped to size. Woody biomass is characterized by cellulose, hemicellulose, lignin and mineral content. The biomass for this project is limited to <u>clean woody</u> biomass meaning trees and woody plants, including limbs, tops, trunks, needles, leaves, stalks and other woody parts, grown in a forest, urban and suburban environments, utility rights-of-way, woodland, rangeland environment, tree farm or agricultural crop farm. The term also includes the residues and rejects from the physical (non-chemical) processing of such woody biomass. The woody biomass feedstock will be delivered via truck to</p>

SECTION IV. APPENDIX BMP

BEST MANAGEMENT PRACTICES (BMP) PLAN

	<p>the site at a rate of approximately 65 trucks per day.</p> <p>Clean Woody Biomass can include: saw dust; hogged fuel; processed butt cuts, and fuel crop.</p> <ul style="list-style-type: none">• <i>Saw Dust</i> is defined as a by-product of forest and forest product operations.• Hogged Fuel is material that comprises land clearing debris that has either been pre-processed, run through a tub grinder, or a horizontal mill at a specific private forest clearing site.• Butt Cuts are untreated round residues that are either of oversized or undersized non processible materials from post or pole manufacturers.• Fuel Crop is a vegetative product specifically grown for energy use or a waste product of agricultural operations (e.g., corn stover, peanut hulls, etc.). <p>The following is required from the permittee:</p> <ol style="list-style-type: none">1) Woody biomass feedstocks shall be obtained from vendors that certify that the woody biomass feed stocks they supply to FBE meet the definition of woody biomass specified above. In addition, the vendor must certify that the woody biomass does not contain any of the prohibited items listed in Item 10, below.2) Any such vendor certification shall include, in legible fashion, the name of the vendor's representative making the certification as well as the representative's signature. The permittee shall retain records of the certifications for 5 years.3) The woody biomass feedstock will be delivered to the FBE facility in vehicles designed to prevent release. Woody biomass feedstock shall be delivered to FBE primarily by trucks.4) The permittee shall inspect each shipment of woody biomass upon receipt for any material not specifically identified in this plan. If the permittee identifies any such material, the material shall be rejected and/or marshaled in specified areas until proper disposal can be arranged. Rejected materials shall be moved off site in a logistically reasonable time period.5) For each original source of woody biomass feedstock, the permittee shall retain documentation of the original source's procedures to prevent the contamination of the woody biomass with any materials not specifically authorized by this permit. Such documentation shall explicitly identify the procedures used to prevent the introduction of any treated wood or any other prohibited materials into the woody biomass.6) The permittee shall retain documentation of the off-site material handling facility's procedures for receiving, segregating and loading the woody biomass from the original sources. In addition, the permittee shall retain documentation of the quality assurance procedures in place at the off-site handling facility to ensure the woody biomass is not contaminated with any materials not specifically authorized by this permit. Such documentation shall explicitly identify the procedures used to prevent the introduction of any treated wood or any other prohibited materials into the woody biomass.7) For each shipment of woody biomass, the permittee shall record the date received, the original source and the material description of the woody biomass and the quantity received, and the name, in a legible fashion, and signature of the individual(s) responsible for performing the visible inspection in Item 8, below.8) The permittee shall inspect each shipment of woody biomass upon receipt and during unloading for any material not specifically authorized by this permit. If the permittee identifies any such material, the material must be removed from the shipment and the material vendor notified. The rejected material must be disposed of following all applicable Department regulations. The permittee
--	--

SECTION IV. APPENDIX BMP

BEST MANAGEMENT PRACTICES (BMP) PLAN

	<p>shall maintain a record of rejected materials, the amount of material rejected and the reason(s) for rejection.</p> <p>9) The permittee shall maintain records of rejected shipments and disposition thereof. Such records shall be made available to the Department upon request.</p> <p>10) The following items <u>are not</u> considered woody biomass and are expressly prohibited:</p> <ul style="list-style-type: none">a) those materials that are prohibited by state or federal law;b) plastics;c) woody biomass that has been chemically treated or processed;d) yard trash;e) municipal solid waste;f) paper;g) treated wood such as CCA or creosote;h) painted wood; andi) wood wastes from landfills.
--	---

SECTION IV. APPENDIX CC

COMMON CONDITIONS

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at the FBE facility.

EMISSIONS AND CONTROLS

1. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
2. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]
3. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed 2 hours in any 24-hour period unless specifically authorized by the Department for longer duration. Pursuant to Rule 62-210.700(5), F.A.C., the permit subsection may specify more or less stringent requirements for periods of excess emissions. Rule 62-210.700(Excess Emissions), F.A.C., cannot vary or supersede any federal NSPS or NESHAP provision. [Rule 62-210.700(1), F.A.C.]
4. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]
5. Excess Emissions - Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Compliance Authority in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]
6. VOC or OS Emissions: No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]
7. Objectionable Odor Prohibited: No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and 62-210.200(Definitions), F.A.C.]
8. General Visible Emissions: No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b)1, F.A.C.]
9. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

SECTION IV. APPENDIX CC

COMMON CONDITIONS

RECORDS AND REPORTS

10. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least 5 years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rule 62-213.440(1)(b)2, F.A.C.]
11. Emissions Computation and Reporting
 - a. *Applicability*. This rule sets forth required methodologies to be used by the owner or operator of a facility for computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for computing emissions for purposes of the reporting requirements of subsection 62-210.370(3) and paragraph 62-212.300(1)(e), F.A.C., or of any permit condition that requires emissions be computed in accordance with this rule. This rule is not intended to establish methodologies for determining compliance with the emission limitations of any air permit.
 - b. *Computation of Emissions*. For any of the purposes set forth in subsection 62-210.370(1), F.A.C., the owner or operator of a facility shall compute emissions in accordance with the requirements set forth in this subsection.
 - (1) *Basic Approach*. The owner or operator shall employ, on a pollutant-specific basis, the most accurate of the approaches set forth below to compute the emissions of a pollutant from an emissions unit; provided, however, that nothing in this rule shall be construed to require installation and operation of any continuous emissions monitoring system (CEMS), continuous parameter monitoring system (CPMS), or predictive emissions monitoring system (PEMS) not otherwise required by rule or permit, nor shall anything in this rule be construed to require performance of any stack testing not otherwise required by rule or permit.
 - (a) If the emissions unit is equipped with a CEMS meeting the requirements of paragraph 62-210.370(2)(b), F.A.C., the owner or operator shall use such CEMS to compute the emissions of the pollutant, unless the owner or operator demonstrates to the department that an alternative approach is more accurate because the CEMS represents still-emerging technology.
 - (b) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., but emissions of the pollutant can be computed pursuant to the mass balance methodology of paragraph 62-210.370(2)(c), F.A.C., the owner or operator shall use such methodology, unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
 - (c) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., and emissions cannot be computed pursuant to the mass balance methodology, the owner or operator shall use an emission factor meeting the requirements of paragraph 62-210.370(2)(d), F.A.C., unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
 - (2) *Continuous Emissions Monitoring System (CEMS)*.
 - (a) An owner or operator may use a CEMS to compute emissions of a pollutant for purposes of this rule provided:
 - 1) The CEMS complies with the applicable certification and quality assurance requirements of 40 CFR Part 60, Appendices B and F, or, for an acid rain unit, the certification and quality assurance requirements of 40 CFR Part 75, all adopted by reference at Rule 62-204.800, F.A.C.; or

SECTION IV. APPENDIX CC

COMMON CONDITIONS

- 2) The owner or operator demonstrates that the CEMS otherwise represents the most accurate means of computing emissions for purposes of this rule.
 - (b) Stack gas volumetric flow rates used with the CEMS to compute emissions shall be obtained by the most accurate of the following methods as demonstrated by the owner or operator:
 - 1) A calibrated flowmeter that records data on a continuous basis, if available; or
 - 2) The average flow rate of all valid stack tests conducted during a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
 - (c) The owner or operator may use CEMS data in combination with an appropriate f-factor, heat input data, and any other necessary parameters to compute emissions if such method is demonstrated by the owner or operator to be more accurate than using a stack gas volumetric flow rate as set forth at subparagraph 62-210.370(2)(b)2., F.A.C., above.
- (3) Mass Balance Calculations.
- (a) An owner or operator may use mass balance calculations to compute emissions of a pollutant for purposes of this rule provided the owner or operator:
 - 1) Demonstrates a means of validating the content of the pollutant that is contained in or created by all materials or fuels used in or at the emissions unit; and
 - 2) Assumes that the emissions unit emits all of the pollutant that is contained in or created by any material or fuel used in or at the emissions unit if it cannot otherwise be accounted for in the process or in the capture and destruction of the pollutant by the unit's air pollution control equipment.
 - (b) Where the vendor of a raw material or fuel which is used in or at the emissions unit publishes a range of pollutant content from such material or fuel, the owner or operator shall use the highest value of the range to compute the emissions, unless the owner or operator demonstrates using site-specific data that another content within the range is more accurate.
 - (c) In the case of an emissions unit using coatings or solvents, the owner or operator shall document, through purchase receipts, records and sales receipts, the beginning and ending VOC inventories, the amount of VOC purchased during the computational period, and the amount of VOC disposed of in the liquid phase during such period.
- (4) Emission Factors.
- (a) An owner or operator may use an emission factor to compute emissions of a pollutant for purposes of this rule provided the emission factor is based on site-specific data such as stack test data, where available, unless the owner or operator demonstrates to the department that an alternative emission factor is more accurate. An owner or operator using site-specific data to derive an emission factor, or set of factors, shall meet the following requirements.
 - 1) If stack test data are used, the emission factor shall be based on the average emissions per unit of input, output, or gas volume, whichever is appropriate, of all valid stack tests conducted during at least a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
 - 2) Multiple emission factors shall be used as necessary to account for variations in emission rate associated with variations in the emissions unit's operating rate or operating conditions during the period over which emissions are computed.

SECTION IV. APPENDIX CC

COMMON CONDITIONS

- 3) The owner or operator shall compute emissions by multiplying the appropriate emission factor by the appropriate input, output or gas volume value for the period over which the emissions are computed. The owner or operator shall not compute emissions by converting an emission factor to pounds per hour and then multiplying by hours of operation, unless the owner or operator demonstrates that such computation is the most accurate method available.
 - (b) If site-specific data are not available to derive an emission factor, the owner or operator may use a published emission factor directly applicable to the process for which emissions are computed. If no directly-applicable emission factor is available, the owner or operator may use a factor based on a similar, but different, process.
 - (5) Accounting for Emissions during Periods of Missing Data from CEMS, PEMS, or CPMS. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of missing data from CEMS, PEMS, or CPMS using other site-specific data to generate a reasonable estimate of such emissions.
 - (6) Accounting for Emissions during Periods of Startup and Shutdown. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.
 - (7) Fugitive Emissions. In computing the emissions of a pollutant from a facility or emissions unit, the owner or operator shall account for the fugitive emissions of the pollutant, to the extent quantifiable, associated with such facility or emissions unit.
 - (8) Recordkeeping. The owner or operator shall retain a copy of all records used to compute emissions pursuant to this rule for a period of five years from the date on which such emissions information is submitted to the department for any regulatory purpose.
- c. *Annual Operating Report for Air Pollutant Emitting Facility*
- (1) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year for the following facilities:
 - (a) All Title V sources.
 - (b) All synthetic non-Title V sources.
 - (c) All facilities with the potential to emit ten (10) tons per year or more of volatile organic compounds or twenty-five (25) tons per year or more of nitrogen oxides and located in an ozone nonattainment area or ozone air quality maintenance area.
 - (d) All facilities for which an annual operating report is required by rule or permit.
 - (2) Notwithstanding paragraph 62-210.370(3)(a), F.A.C., no annual operating report shall be required for any facility operating under an air general permit.
 - (3) The annual operating report shall be submitted to the appropriate Department of Environmental Protection (DEP) division, district or DEP-approved local air pollution control program office by April 1 of the following year.
 - (4) Beginning with 2007 annual emissions, emissions shall be computed in accordance with the provisions of subsection 62-210.370(2), F.A.C., for purposes of the annual operating report.

[Rule 62-210.370, F.A.C.]

SECTION IV. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) REQUIREMENTS

CEMS OPERATION PLAN

1. CEMS Operation Plan: The owner or operator shall create and implement a facility-wide plan for the proper installation, calibration, maintenance and operation of each CEMS required by this permit. The owner or operator shall submit the CEMS Operation Plan to the Bureau of Air Monitoring and Mobile Sources for approval at least 60 days prior to CEMS installation. The CEMS Operation Plan shall become effective 60 days after submittal or upon its approval. If the CEMS Operation Plan is not approved, the owner or operator shall submit a new or revised plan for approval.

{Permitting Note: The Department maintains both guidelines for developing a CEMS Operation Plan and example language that can be used as the basis for the facility-wide plan required by this permit. Contact the Emissions Monitoring Section of the Bureau of Air Monitoring and Mobile Sources at (850)488-0114.}

INSTALLATION, PERFORMANCE SPECIFICATIONS AND QUALITY ASSURANCE

2. Timelines:
 - a. New and Existing Emission Units. For new emission units, the owner or operator shall install each CEMS required by this permit prior to initial startup of the unit. The owner or operator shall conduct the appropriate performance specification for each CEMS within 90 operating days of achieving permitted capacity as defined in Rule 62-297.310(2), F.A.C., but no later than 180 calendar days after initial startup.
3. Installation: All CEMS shall be installed such that representative measurements of emissions or process parameters from the facility are obtained. The owner or operator shall locate the CEMS by following the procedures contained in the applicable performance specification of 40 CFR part 60, Appendix B.
4. Span Values and Dual Range Monitors: The owner or operator shall set appropriate span values for the CEMS. The owner or operator shall install dual range monitors if required by and in accordance with the CEMS Operation Plan.
5. Continuous Flow Monitor: For compliance with mass emission rate standards, the owner or operator shall install a continuous flow monitor to determine the stack exhaust flow rate. The flow monitor shall be certified pursuant to 40 CFR part 60, Appendix B, Performance Specification 6.
6. Diluent Monitor: If it is necessary to correct the CEMS output to the oxygen concentrations specified in this permit's emission standards, the owner or operator shall either install an oxygen monitor or install a CO₂ monitor and use an appropriate F-Factor computational approach.
7. Moisture Correction: If necessary, the owner or operator shall determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture).

{Permitting Note: The CEMS Operation Plan will contain additional CEMS-specific details and procedures for installation.}
8. Performance Specifications: The owner or operator shall evaluate the acceptability of each CEMS by conducting the appropriate performance specification, as follows. CEMS determined to be unacceptable shall not be considered installed for purposes of meeting the timelines of this permit.
 - a. CO Monitors: For CO monitors, the owner or operator shall conduct Performance Specification 4 or 4A of 40 CFR part 60, Appendix B
 - b. NO_x and SO₂ Monitors: For NO_x and SO₂ monitors, the owner or operator shall conduct Performance Specification 2 of 40 CFR part 60, Appendix B.
 - c. HCl CEMS: The HCl CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 15, EPA Method OTM 22 or alternative specifications approved by the Department.

SECTION IV. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) REQUIREMENTS

Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority.

- d. HF CEMS: The HF CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 15, EPA Method OTM 22 or alternative specifications approved by the Department. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority.
 - e. COMS: In accordance with 40 CFR 60.48b(a) the permittee shall install, calibrate, operate and maintain a continuous opacity monitor (COM) to continuously monitor and record opacity from the steam generating unit. The COMS shall be certified pursuant to 40 CFR 60 Appendix B, Performance Specification 1.
9. Quality Assurance: The owner or operator shall follow the quality assurance procedures of 40 CFR part 60, Appendix F.
- a. CO Monitors: The required relative accuracy test audit (RATA) tests shall be performed using EPA Method 10 in Appendix A of 40 CFR part 60 and shall be based on a continuous sampling train.
 - b. NO_x Monitors: The required RATA tests shall be performed using EPA Method 7E in Appendix A of 40 CFR part 60. NO_x shall be expressed “as NO₂.”
 - c. SO₂ Monitors: The required RATA tests shall be performed using EPA Method 6C in Appendix A of 40 CFR part 60.
 - d. HCl CEMS: The HCl CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 15, EPA Method OTM 22 or alternative specifications approved by the Department. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, EPA Method OTM 23 or alternative procedures approved by the Department. A Data Assessment Report shall be made each calendar quarter and reported semiannually to the Compliance Authority. The RATA tests required for the HCl monitor shall be performed using EPA Method 26 or 26A as detailed in Appendix A of 40 CFR 60 or by Method 320 as detailed in Appendix A of 40 CFR 63. The HCl monitor span values shall be set appropriately, considering the allowable methods of operation and corresponding emission standards. Approval of specific initial performance specifications and quality assurance and control (Q&A) procedures must be provided by the Department prior to installation and operation of the CEM system.
 - e. HF CEMS: The HF CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 15, EPA Method OTM 22 or alternative specifications approved by the Department. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, EPA Method OTM 23 or alternative procedures approved by the Department. A Data Assessment Report shall be made each calendar quarter and reported semiannually to the Compliance Authority. The RATA tests required for the HF monitor shall be performed using EPA Method 26 or 26A as detailed in Appendix A of 40 CFR 60 or by Method 320 as detailed in Appendix A of 40 CFR 63. The HF monitor span values shall be set appropriately, considering the allowable methods of operation and corresponding emission standards. Approval of specific initial performance specifications and quality assurance and control (Q&A) procedures must be provided by the Department prior to installation and operation of the CEM system.
10. Substituting RATA Tests for Compliance Tests: Data collected during CEMS quality assurance RATA tests can substitute for annual stack tests, and vice versa, at the option of the owner or operator, provided

SECTION IV. APPENDIX CEMS
CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) REQUIREMENTS

the owner or operator indicates this intent in the submitted test protocol and follows the procedures outlined in the CEMS Operation Plan.

CALCULATION APPROACH

11. CEMS Used for Compliance: Once adherence to the applicable performance specification for each CEMS is demonstrated, the owner or operator shall use the CEMS to demonstrate compliance with the applicable emission standards as specified by this permit.
12. CEMS Data: Each CEMS shall monitor and record emissions during all periods of operation and whenever emissions are being generated, including during episodes of startups, shutdowns, and malfunctions. All data shall be used, except for invalid measurements taken during monitor system breakdowns, repairs, calibration checks, zero adjustments and span adjustments, and except for allowable data exclusions as per Condition 20 of this appendix.
13. Operating Hours and Operating Days: For purposes of this appendix, the following definitions shall apply. An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Unless otherwise specified by this permit, any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
14. Valid Hourly Averages: Each CEMS shall be designed and operated to sample, analyze and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
 - a. Hours that are not operating hours are not valid hours.
 - b. For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data, the 1-hour block average is not valid, and the hour is considered as “monitor unavailable.”
15. Calculation Approaches: The owner or operator shall implement the calculation approach specified by this permit for each CEMS, as follows:
 - a. *Rolling 12-month average, rolled monthly*: Compliance shall be determined after each operating month by calculating the arithmetic average of all the valid hourly averages from that operating month and the prior x-1 operating months.
 - b. *Rolling 30 day average*. Compliance shall be determined after each operating day by calculating the arithmetic average of all the valid hourly averages from that operating day and the prior 30-1 operating days.

MONITOR AVAILABILITY

16. Monitor Availability: The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for the CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit.

SECTION IV. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) REQUIREMENTS

EXCESS EMISSIONS

17. Definitions:

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- b. *Shutdown* means the cessation of the operation of an emissions unit for any purpose.
- c. *Malfunction* means any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

18. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

19. Data Exclusion Procedures for SIP Compliance: As per the procedures in this condition, limited amounts of CEMS emissions data may be excluded from the corresponding compliance demonstration, provided that best operational practices to minimize emissions are adhered to and the duration of data excluded is minimized. The data exclusion procedures of this condition apply only to SIP-based emission limits.

- a. *Excess Emissions.* Data in excess of the applicable emission standard may be excluded from compliance calculations if the data are collected during periods of permitted excess emissions (for example, during startup, shutdown or malfunction). The maximum duration of excluded data is 2 hours in any 24-hour period, unless some other duration is specified by this permit. For the CEMS on the grate-type suspension boiler stack at the FBE facility, excess emissions of NO_x, SO₂ and CO during periods of startup, shutdown and malfunction cannot be excluded. This is to ensure that the 250 TPY emission limits for these pollutants are not exceeded which if they were would trigger PSD regulations.
- b. *Limited Data Exclusion.* If the compliance calculation using all valid CEMS emission data, as defined in Condition 12 of this appendix, indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
- c. *Event Driven Exclusion.* The underlying event (for example, the startup, shutdown or malfunction event) must precede the data exclusion. If there is no underlying event, then no data may be excluded. Only data collected during the event may be excluded.
- d. *Reporting Excluded Data.* The data exclusion procedures of this condition are not necessarily the same procedures used for excess emissions as defined by federal rules. Quarterly or semi-annual reports required by this permit shall indicate not only the duration of data excluded from SIP compliance calculations but also the number of excess emissions as defined by federal rules.

20. Notification Requirements: The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate noncompliance for a given averaging period. Within one working day of occurrence, the owner or operator shall notify the Compliance Authority of any malfunction resulting in the exclusion of CEMS data. For malfunctions, notification is sufficient for the owner or operator to exclude CEMS data.

ANNUAL EMISSIONS

21. CEMS Used for Calculating Annual Emissions: All valid data, as defined in Condition 12 of this appendix, shall be used when calculating annual emissions.

- a. Annual emissions shall include data collected during startup, shutdown and malfunction periods.

SECTION IV. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) REQUIREMENTS

- b. Annual emissions shall include data collected during periods when the emission unit is not operating but emissions are being generated (for example, when firing fuel to warm up a process for some period of time prior to the emission unit's startup).
 - c. Annual emissions shall not include data from periods of time where the monitor was functioning properly but was unable to collect data while conducting a mandated quality assurance/quality control activity such as calibration error tests, RATA, calibration gas audit or RAA. These periods of time shall be considered missing data for purposes of calculating annual emissions.
 - d. Annual emissions shall not include data from periods of time when emissions are in excess of the calibrated span of the CEMS. These periods of time shall be considered missing data for purposes of calculating annual emissions.
22. Accounting for Missing Data: All valid measurements collected during each hour shall be used to calculate a 1-hour block average. For each hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, the owner or operator shall account for emissions during that hour using site-specific data to generate a reasonable estimate of the 1-hour block average.
23. Emissions Calculation: Hourly emissions shall be calculated for each hour as the product of the 1-hour block average and the duration of pollutant emissions during that hour. Annual emissions shall be calculated as the sum of all hourly emissions occurring during the year.

SECTION 4. APPENDIX CF

CITATION FORMATS AND GLOSSARY OF COMMON TERMS

CITATION FORMATS

The following illustrate the formats used in the permit to identify applicable requirements from permits and regulations.

Old Permit Numbers

Example: Permit No. AC50-123456 or Permit No. AO50-123456

Where: “AC” identifies the permit as an Air Construction Permit

“AO” identifies the permit as an Air Operation Permit

“123456” identifies the specific permit project number

New Permit Numbers

Example: Permit Nos. 099-2222-001-AC, 099-2222-001-AF, 099-2222-001-AO, or 099-2222-001-AV

Where: “099” represents the specific county ID number in which the project is located

“2222” represents the specific facility ID number for that county

“001” identifies the specific permit project number

“AC” identifies the permit as an air construction permit

“AF” identifies the permit as a minor source federally enforceable state operation permit

“AO” identifies the permit as a minor source air operation permit

“AV” identifies the permit as a major Title V air operation permit

PSD Permit Numbers

Example: Permit No. PSD-FL-317

Where: “PSD” means issued pursuant to the preconstruction review requirements of the Prevention of Significant Deterioration of Air Quality

“FL” means that the permit was issued by the State of Florida

“317” identifies the specific permit project number

Florida Administrative Code (F.A.C.)

Example: [Rule 62-213.205, F.A.C.]

Means: Title 62, Chapter 213, Rule 205 of the Florida Administrative Code

Code of Federal Regulations (CFR)

Example: [40 CFR 60.7]

Means: Title 40, Part 60, Section 7

SECTION 4. APPENDIX CF

CITATION FORMATS AND GLOSSARY OF COMMON TERMS

GLOSSARY OF COMMON TERMS

° F: degrees Fahrenheit

acfm: actual cubic feet per minute

ARMS: Air Resource Management System
(Department's database)

BACT: best available control technology

Btu: British thermal units

CAM: compliance assurance monitoring

CEMS: continuous emissions monitoring system

cfm: cubic feet per minute

CFR: Code of Federal Regulations

CO: carbon monoxide

COMS: continuous opacity monitoring system

DEP: Department of Environmental Protection

Department: Department of Environmental
Protection

dscfm: dry standard cubic feet per minute

EPA: Environmental Protection Agency

ESP: electrostatic precipitator (control system for
reducing particulate matter)

EU: emissions unit

F.A.C.: Florida Administrative Code

F.D.: forced draft

F.S.: Florida Statutes

FGR: flue gas recirculation

F: fluoride

ft²: square feet

ft³: cubic feet

gpm: gallons per minute

gr: grains

HAP: hazardous air pollutant

Hg: mercury

I.D.: induced draft

ID: identification

kPa: kilopascals

lb: pound

MACT: maximum achievable technology

MMBtu: million British thermal units

MSDS: material safety data sheets

MW: megawatt

NESHAP: National Emissions Standards for
Hazardous Air Pollutants

NO_x: nitrogen oxides

NSPS: New Source Performance Standards

O&M: operation and maintenance

O₂: oxygen

Pb: lead

PM: particulate matter

PM₁₀: particulate matter with a mean aerodynamic
diameter of 10 microns or less

PSD: prevention of significant deterioration

psi: pounds per square inch

PTE: potential to emit

RATA: relative accuracy test audit

SAM: sulfuric acid mist

scf: standard cubic feet

scfm: standard cubic feet per minute

SIC: standard industrial classification code

SNCR: selective non-catalytic reduction (control
system used for reducing emissions of nitrogen
oxides)

SO₂: sulfur dioxide

TPH: tons per hour

TPY: tons per year

UTM: Universal Transverse Mercator coordinate
system

VE: visible emissions

VOC: volatile organic compounds

SECTION IV. APPENDIX CTR
COMMON TESTING REQUIREMENTS

Unless otherwise specified in the permit, the following testing requirements apply to all emissions units at the FBE facility.

COMPLIANCE TESTING REQUIREMENTS

1. Operating Rate during Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. [Rule 62-297.310(2), F.A.C.]
2. Applicable Test Procedures - Opacity Compliance Tests: When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
 - b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4), F.A.C.]

3. Determination of Process Variables
 - a. *Required Equipment*. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
 - b. *Accuracy of Equipment*. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

4. Frequency of Compliance Tests: The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
 - a. *General Compliance Testing*.

SECTION IV. APPENDIX CTR
COMMON TESTING REQUIREMENTS

1. The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit.
2. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to sub-subparagraph 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
 - (a) Did not operate; or
 - (b) In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours,
3. During each federal fiscal year (October 1 – September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for visible emissions, if there is an applicable standard.
4. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
- b. *Special Compliance Tests.* When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7), F.A.C.]

RECORDS AND REPORTS

5. Test Reports: The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report shall provide the following information.
 - a. The type, location, and designation of the emissions unit tested.
 - b. The facility at which the emissions unit is located.
 - c. The owner or operator of the emissions unit.
 - d. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 - e. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
 - f. The date, starting time and end time of the observation.
 - g. The test procedures used.

SECTION IV. APPENDIX CTR
COMMON TESTING REQUIREMENTS

- h. The names of individuals who furnished the process variable data, conducted the test, and prepared the report.
- i. The applicable emission standard and the resulting maximum allowable emission rate for the emissions unit plus the test result in the same form and unit of measure.
- j. A certification that to the knowledge of the owner or his authorized agent, all data submitted are true and correct. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Draft

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

{Permitting Note: This is a modified version of NSPS, Subpart Db that retains the information applicable to the FBE project. Parts that are critical to the FBE project are provided in “Bold” text. To access the full version of NSPS, Subpart Db, follow the link at the end of this appendix.}

Subpart Db—Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units

Source: 72 FR 32742, June 13, 2007, unless otherwise noted.

§ 60.40b Applicability and delegation of authority.

- (a) The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 100 million British thermal units per hour (MMBtu/hr).
- (b) through (f) are not applicable (NA).
- (g) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, the following authorities shall be retained by the Administrator and not transferred to a State.
 - (1) Section 60.44b(f).
 - (2) Section 60.44b(g).
 - (3) Section 60.49b(a)(4).
- (h) through (k) are NA.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.41b Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

Annual capacity factor means the ratio between the actual heat input to a steam generating unit from the fuels listed in §60.42b(a), §60.43b(a), or §60.44b(a), as applicable, during a calendar year and the potential heat input to the steam generating unit had it been operated for 8,760 hours during a calendar year at the maximum steady state design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility in a calendar year.

Conventional technology means wet flue gas desulfurization (FGD) technology, dry FGD technology, atmospheric fluidized bed combustion technology, and oil hydrosulfurization technology.

Distillate oil means fuel oils that contain 0.05 weight percent nitrogen or less and comply with the specifications for fuel oil numbers 1 and 2, as defined by the American Society of Testing and Materials in ASTM D396 (incorporated by reference, see §60.17) or diesel fuel oil numbers 1 and 2, as defined by the American Society for Testing and Materials in ASTM D975 (incorporated by reference, see §60.17).

Dry flue gas desulfurization technology means a SO₂ control system that is located downstream of the steam generating unit and removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline slurries or solutions used in dry flue gas desulfurization technology include but are not limited to lime and sodium.

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

Federally enforceable means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State Implementation Plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

Fluidized bed combustion technology means combustion of fuel in a bed or series of beds (including but not limited to bubbling bed units and circulating bed units) of limestone aggregate (or other sorbent materials) in which these materials are forced upward by the flow of combustion air and the gaseous products of combustion.

Full capacity means operation of the steam generating unit at 90 percent or more of the maximum steady-state design heat input capacity.

Gaseous fuel means any fuel that is a gas at ISO conditions. This includes, but is not limited to, natural gas and gasified coal (including coke oven gas).

Gross output means the gross useful work performed by the steam generated. For units generating only electricity, the gross useful work performed is the gross electrical output from the turbine/generator set. For cogeneration units, the gross useful work performed is the gross electrical or mechanical output plus 75 percent of the useful thermal output measured relative to ISO conditions that is not used to generate additional electrical or mechanical output or to enhance the performance of the unit (i.e., steam delivered to an industrial process).

Heat input means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

Heat release rate means the steam generating unit design heat input capacity (in MW or Btu/hr) divided by the furnace volume (in cubic meters or cubic feet); the furnace volume is that volume bounded by the front furnace wall where the burner is located, the furnace side waterwall, and extending to the level just below or in front of the first row of convection pass tubes.

Heat transfer medium means any material that is used to transfer heat from one point to another point.

High heat release rate means a heat release rate greater than 70,000 Btu/hr-ft³.

ISO Conditions means a temperature of 288 Kelvin, a relative humidity of 60 percent, and a pressure of 101.3 kilopascals.

Low heat release rate means a heat release rate of 70,000 Btu/hr-ft³ or less.

Maximum heat input capacity means the ability of a steam generating unit to combust a stated maximum amount of fuel on a steady state basis, as determined by the physical design and characteristics of the steam generating unit.

Natural gas means:

- (1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or
- (2) Liquefied petroleum gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see §60.17); or
- (3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 34 and 43 megajoules (MJ) per dry standard cubic meter (910 and 1,150 Btu per dry standard cubic foot).

Oil means crude oil or petroleum or a liquid fuel derived from crude oil or petroleum, including distillate and residual oil.

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

Potential sulfur dioxide emission rate means the theoretical SO₂ emissions (lb/mmBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems. For gasified coal or oil that is desulfurized prior to combustion, the *Potential sulfur dioxide emission rate* is the theoretical SO₂ emissions (lb/mmBtu heat input) that would result from combusting fuel in a cleaned state without using any post combustion emission control systems.

Steam generating unit means a device that combusts any fuel or byproduct/waste and produces steam or heats water or heats any heat transfer medium. This term includes any municipal-type solid waste incinerator with a heat recovery steam generating unit or any steam generating unit that combusts fuel and is part of a cogeneration system or a combined cycle system. This term does not include process heaters as they are defined in this subpart.

Steam generating unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Very low sulfur oil means for units constructed, reconstructed, or modified after February 28, 2005 and not located in a noncontinental area, oil that contains no more than 0.30 weight percent sulfur or that, when combusted without SO₂ emission control, has a SO₂ emission rate equal to or less than 0.32 lb/mmBtu heat input.

Wood means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including, but not limited to, sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.42b Standard for sulfur dioxide (SO₂).

- (a) through (d) are NA.
- (e) Except as provided in paragraph (f) of this section, compliance with the emission limits, fuel oil sulfur limits, and/or percent reduction requirements under this section are determined on a 30-day rolling average basis.
- (f) NA.
- (g) Except as provided in paragraph (i) of this section and §60.45b(a), the SO₂ emission limits and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.
- (h) through (j) are NA.
- (k)
 - (1) NA due to election by applicant to comply with (k)(2) below.
 - (2) **Units firing only very low sulfur oil, gaseous fuel, a mixture of these fuels, or a mixture of these fuels with any other fuels with a potential SO₂ emission rate of 0.32 lb/mmBtu heat input or less are exempt from the SO₂ emissions limit in paragraph (k)(1) of this section.**
 - (3) NA.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

§ 60.43b Standard for particulate matter (PM).

- (a) through (d) are NA.
- (e) For the purposes of this section, the annual capacity factor is determined by dividing the actual heat input to the steam generating unit during the calendar year from the combustion of coal, wood, or municipal-type solid waste, and other fuels, as applicable, by the potential heat input to the steam generating unit if the steam generating unit had been operated for 8,760 hours at the maximum heat input capacity.
- (f) **On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that can combust coal, oil, wood, or mixtures of these fuels with any other fuels shall cause to be discharged into the atmosphere any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity.** Owners and operators of an affected facility that elect to install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring PM emissions according to the requirements of this subpart and are subject to a federally enforceable PM limit of 0.030 lb/mmBtu or less are exempt from the opacity standard specified in this paragraph.
- (g) The PM and opacity standards apply at all times, except during periods of startup, shutdown, or malfunction.
- (h)
- (1) **Except as provided in paragraphs (h)(2), (h)(3), (h)(4), (h)(5), and (h)(6) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 0.030 lb/mmBtu heat input,**
 - (2) NA due to election by applicant to comply with (h)(1) above.
 - (3) through (6) are NA.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.44b Standard for nitrogen oxides (NO_x).

- (a) NA except for subsequent reference to the following table:

Fuel/steam generating unit type	Nitrogen oxide emission limits (expressed as NO ₂) (lb/mmBtu heat input)
(1) Natural gas and distillate oil:	
(i) Low heat release rate	0.10
(ii) High heat release rate	0.20

- (b) Except as provided under paragraphs (k) and (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts mixtures of coal, oil, or

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART Db – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

natural gas shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_x in excess of a limit determined by the use of the following formula:

$$E_n = \frac{(EL_g H_g) + (EL_o H_o) + (EL_c H_c)}{(H_g + H_o + H_c)}$$

Where:

E_n= NO_x emission limit (expressed as NO₂), lb/mmBtu;

EL_{go}= Appropriate emission limit from paragraph (a)(1) for combustion of natural gas or distillate oil, lb/mmBtu;

H_{go}= Heat input from combustion of natural gas or distillate oil, mmBtu;

- (c) Except as provided under paragraph (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts coal or oil, or a mixture of these fuels with natural gas, and wood, municipal-type solid waste, or any other fuel shall cause to be discharged into the atmosphere any gases that contain NO_x in excess of the emission limit for the coal or oil, or mixtures of these fuels with natural gas combusted in the affected facility, as determined pursuant to paragraph (a) or (b) of this section, unless the affected facility has an annual capacity factor for coal or oil, or mixture of these fuels with natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the affected facility to an annual capacity factor of 10 percent (0.10) or less for coal, oil, or a mixture of these fuels with natural gas.
- (d) **On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts natural gas with wood, municipal-type solid waste, or other solid fuel, except coal, shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_x in excess of 0.30 lb/mmBtu heat input** unless the affected facility has an annual capacity factor for natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the affected facility to an annual capacity factor of 10 percent (0.10) or less for natural gas.
- (e) through (g) are NA.
- (h) For purposes of paragraph (i) of this section, the NO_x standards under this section apply at all times including periods of startup, shutdown, or malfunction.
- (i) Except as provided under paragraph (j) of this section, compliance with the emission limits under this section is determined on a 30-day rolling average basis.
- (j) and (k) are NA.
- (l) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction or reconstruction after July 9, 1997 shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_x (expressed as NO₂) in excess of the following limits:
 - (1) If the affected facility combusts coal, oil, natural gas, a mixture of these fuels, or a mixture of these fuels with any other fuels: A limit of 0.20 lb/mmBtu heat input unless the affected facility has an annual capacity factor for coal, oil, and natural gas of 10 percent (0.10) or

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

less and is subject to a federally enforceable requirement that limits operation of the facility to an annual capacity factor of 10 percent (0.10) or less for coal, oil, and natural gas; or

- (2) If the affected facility has a low heat release rate and combusts natural gas or distillate oil in excess of 30 percent of the heat input on a 30-day rolling average from the combustion of all fuels, a limit determined by use of the following formula:

$$E_n = \frac{(0.10 \times H_{go}) + (0.20 \times H_r)}{(H_{go} + H_r)}$$

Where:

E_n = NO_x emission limit, (lb/mmBtu);

H_{go} = 30-day heat input from combustion of natural gas or distillate oil; and

H_r = 30-day heat input from combustion of any other fuel.

- (3) After February 27, 2006, units where more than 10 percent of total annual output is electrical or mechanical may comply with an optional limit of 2.1 lb/MWh gross energy output, based on a 30-day rolling average. Units complying with this output-based limit must demonstrate compliance according to the procedures of §60.48Da(i) of subpart Da of this part, and must monitor emissions according to §60.49Da(c), (k), through (n) of subpart Da of this part.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5086, Jan. 28, 2009]

§ 60.45b Compliance and performance test methods and procedures for sulfur dioxide.

- (a) NA.
- (b) In conducting the performance tests required under §60.8, the owner or operator shall use the methods and procedures in appendix A (including fuel certification and sampling) of this part or the methods and procedures as specified in this section, except as provided in §60.8(b). Section 60.8(f) does not apply to this section. The 30-day notice required in §60.8(d) applies only to the initial performance test unless otherwise specified by the Administrator.
- (c) Through (j) NA.
- (k) The owner or operator of an affected facility seeking to demonstrate compliance in §§60.42b(d)(4), 60.42b(j), 60.42b(k)(2), and 60.42b(k)(3) (when not burning coal) shall follow the applicable procedures in §60.49b(r).

[72 FR 32742, June 13, 2007, as amended at 74 FR 5086, Jan. 28, 2009]

§ 60.46b Compliance and performance test methods and procedures for particulate matter and nitrogen oxides.

- (a) The PM emission standards and opacity limits under §60.43b apply at all times except during periods of startup, shutdown, or malfunction. The NO_x emission standards under §60.44b apply at all times.
- (b) Compliance with the PM emission standards under §60.43b shall be determined through performance testing as described in paragraph (d) of this section, except as provided in paragraph (i) of this section.
- (c) Compliance with the NO_x emission standards under §60.44b shall be determined through performance testing under paragraph (e) or (f), or under paragraphs (g) and (h) of this section, as applicable.
- (d) To determine compliance with the PM emission limits and opacity limits under §60.43b, the owner or operator of an affected facility shall conduct an initial performance test as required under §60.8, and

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART Db – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

shall conduct subsequent performance tests as requested by the Administrator, using the following procedures and reference methods:

- (1) Method 3A or 3B of appendix A–2 of this part is used for gas analysis when applying Method 5 of appendix A–3 of this part or Method 17 of appendix A–6 of this part.
- (2) Method 5, 5B, or 17 of appendix A of this part shall be used to measure the concentration of PM as follows:
 - (i) Method 5 of appendix A of this part shall be used at affected facilities without wet flue gas desulfurization (FGD) systems; and
 - (ii) Method 17 of appendix A–6 of this part may be used at facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160 °C (320 °F).
 - (iii) NA.
- (3) Method 1 of appendix A of this part is used to select the sampling site and the number of traverse sampling points. The sampling time for each run is at least 120 minutes and the minimum sampling volume is 1.7 dscm (60 dscf) except that smaller sampling times or volumes may be approved by the Administrator when necessitated by process variables or other factors.
- (4) For Method 5 of appendix A of this part, the temperature of the sample gas in the probe and filter holder is monitored and is maintained at 160±14 °C (320±25 °F).
- (5) For determination of PM emissions, the oxygen (O₂) or CO₂ sample is obtained simultaneously with each run of Method 5, 5B, or 17 of appendix A of this part by traversing the duct at the same sampling location.
- (6) For each run using Method 5, 5B, or 17 of appendix A of this part, the emission rate expressed in ng/J heat input is determined using:
 - (i) The O₂ or CO₂ measurements and PM measurements obtained under this section;
 - (ii) The dry basis F factor; and
 - (iii) The dry basis emission rate calculation procedure contained in Method 19 of appendix A of this part.
- (7) Method 9 of appendix A of this part is used for determining the opacity of stack emissions.
- (e) To determine compliance with the emission limits for NO_x required under §60.44b, the owner or operator of an affected facility shall conduct the performance test as required under §60.8 using the continuous system for monitoring NO_x under §60.48(b).
 - (1) For the initial compliance test, NO_x from the steam generating unit are monitored for 30 successive steam generating unit operating days and the 30-day average emission rate is used to determine compliance with the NO_x emission standards under §60.44b. The 30-day average emission rate is calculated as the average of all hourly emissions data recorded by the monitoring system during the 30-day test period.
 - (2) NA.
 - (3) Following the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that has a heat input capacity greater than 250 mmBtu/hr and that combusts natural gas, distillate oil, or residual oil having a nitrogen content of 0.30 weight percent or less shall determine compliance with the NO_x standards under §60.44b on a continuous basis through the use of a 30-day rolling average emission rate. A new 30-day rolling average emission rate is

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

calculated each steam generating unit operating day as the average of all of the hourly NO_x emission data for the preceding 30 steam generating unit operating days.

- (4) Following the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that has a heat input capacity of 250 mmBtu/hr or less and that combusts natural gas, distillate oil, gasified coal, or residual oil having a nitrogen content of 0.30 weight percent or less shall upon request determine compliance with the NO_x standards in §60.44b through the use of a 30-day performance test. During periods when performance tests are not requested, NO_x emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NO_x emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NO_x emission data for the preceding 30 steam generating unit operating days.

(5) NA.

(f) through (i) are NA.

(j) NA unless applicant elects to install, calibrate and operate a PM-CEMS.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5086, Jan. 28, 2009]

§ 60.47b Emission monitoring for sulfur dioxide.

- (a) Except as provided in paragraphs (b) and (f) of this section, the owner or operator of an affected facility subject to the SO₂ standards in §60.42b shall install, calibrate, maintain, and operate CEMS for measuring SO₂ concentrations and either O₂ or CO₂ concentrations and shall record the output of the systems. For units complying with the percent reduction standard, the SO₂ and either O₂ or CO₂ concentrations shall both be monitored at the inlet and outlet of the SO₂ control device. If the owner or operator has installed and certified SO₂ and O₂ or CO₂ CEMS according to the requirements of §75.20(c)(1) of this chapter and appendix A to part 75 of this chapter, and is continuing to meet the ongoing quality assurance requirements of §75.21 of this chapter and appendix B to part 75 of this chapter, those CEMS may be used to meet the requirements of this section, provided that:
- (1) When relative accuracy testing is conducted, SO₂ concentration data and CO₂ (or O₂) data are collected simultaneously; and
 - (2) In addition to meeting the applicable SO₂ and CO₂ (or O₂) relative accuracy specifications in Figure 2 of appendix B to part 75 of this chapter, the relative accuracy (RA) standard in section 13.2 of Performance Specification 2 in appendix B to this part is met when the RA is calculated on a lb/MMBtu basis; and
 - (3) The reporting requirements of §60.49b are met. SO₂ and CO₂ (or O₂) data used to meet the requirements of §60.49b shall not include substitute data values derived from the missing data procedures in subpart D of part 75 of this chapter, nor shall the SO₂ data have been bias adjusted according to the procedures of part 75 of this chapter.
- (b) NA.

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

- (c) The owner or operator of an affected facility shall obtain emission data for at least 75 percent of the operating hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement is not met with a single monitoring system, the owner or operator of the affected facility shall supplement the emission data with data collected with other monitoring systems as approved by the Administrator or the reference methods and procedures as described in paragraph (b) of this section.
- (d) The 1-hour average SO₂ emission rates measured by the CEMS required by paragraph (a) of this section and required under §60.13(h) is expressed in ng/J or lb/MMBtu heat input and is used to calculate the average emission rates under §60.42(b). Each 1-hour average SO₂ emission rate must be based on 30 or more minutes of steam generating unit operation. The hourly averages shall be calculated according to §60.13(h)(2). Hourly SO₂ emission rates are not calculated if the affected facility is operated less than 30 minutes in a given clock hour and are not counted toward determination of a steam generating unit operating day.
- (e) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the CEMS.
 - (1) Except as provided for in paragraph (e)(4) of this section, all CEMS shall be operated in accordance with the applicable procedures under Performance Specifications 1, 2, and 3 of appendix B of this part.
 - (2) Except as provided for in paragraph (e)(4) of this section, quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with Procedure 1 of appendix F of this part.
 - (3) For affected facilities combusting coal or oil, alone or in combination with other fuels, the span value of the SO₂CEMS at the inlet to the SO₂control device is 125 percent of the maximum estimated hourly potential SO₂ emissions of the fuel combusted, and the span value of the CEMS at the outlet to the SO₂control device is 50 percent of the maximum estimated hourly potential SO₂ emissions of the fuel combusted. Alternatively, SO₂span values determined according to section 2.1.1 in appendix A to part 75 of this chapter may be used.
 - (4) As an alternative to meeting the requirements of requirements of paragraphs (e)(1) and (e)(2) of this section, the owner or operator may elect to implement the following alternative data accuracy assessment procedures:
 - (i) For all required CO₂and O₂monitors and for SO₂and NO_x monitors with span values greater than or equal to 100 ppm, the daily calibration error test and calibration adjustment procedures described in sections 2.1.1 and 2.1.3 of appendix B to part 75 of this chapter may be followed instead of the CD assessment procedures in Procedure 1, section 4.1 of appendix F to this part.
 - (ii) For all required CO₂and O₂monitors and for SO₂and NO_x monitors with span values greater than 30 ppm, quarterly linearity checks may be performed in accordance with section 2.2.1 of appendix B to part 75 of this chapter, instead of performing the cylinder gas audits (CGAs) described in Procedure 1, section 5.1.2 of appendix F to this part. If this option is selected: The frequency of the linearity checks shall be as specified in section 2.2.1 of appendix B to part 75 of this chapter; the applicable linearity specifications in section 3.2 of appendix A to part 75 of this chapter shall be met; the data validation and out-of-control criteria in section 2.2.3 of appendix B to part 75 of this chapter shall be followed instead of the excessive audit inaccuracy and out-of-control criteria in Procedure 1, section 5.2 of appendix F to this part; and the grace period provisions in section 2.2.4 of appendix B to part 75 of this chapter shall apply. For the purposes of data validation under this subpart, the cylinder gas audits

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS

described in Procedure 1, section 5.1.2 of appendix F to this part shall be performed for SO₂ and NO_x span values less than or equal to 30 ppm; and

- (iii) For SO₂, CO₂, and O₂ monitoring systems and for NO_x emission rate monitoring systems, RATAs may be performed in accordance with section 2.3 of appendix B to part 75 of this chapter instead of following the procedures described in Procedure 1, section 5.1.1 of appendix F to this part. If this option is selected: The frequency of each RATA shall be as specified in section 2.3.1 of appendix B to part 75 of this chapter; the applicable relative accuracy specifications shown in Figure 2 in appendix B to part 75 of this chapter shall be met; the data validation and out-of-control criteria in section 2.3.2 of appendix B to part 75 of this chapter shall be followed instead of the excessive audit inaccuracy and out-of-control criteria in Procedure 1, section 5.2 of appendix F to this part; and the grace period provisions in section 2.3.3 of appendix B to part 75 of this chapter shall apply. For the purposes of data validation under this subpart, the relative accuracy specification in section 13.2 of Performance Specification 2 in appendix B to this part shall be met on a lb/MMBtu basis for SO₂ (regardless of the SO₂ emission level during the RATA), and for NO_x when the average NO_x emission rate measured by the reference method during the RATA is less than 0.100 lb/MMBtu.
- (f) The owner or operator of an affected facility that combusts very low sulfur oil or is demonstrating compliance under §60.45b(k) is not subject to the emission monitoring requirements under paragraph (a) of this section if the owner or operator maintains fuel records as described in §60.49b(r).

[72 FR 32742, June 13, 2007, as amended at 74 FR 5087, Jan. 28, 2009]

§ 60.48b Emission monitoring for particulate matter and nitrogen oxides.

- (a) Except as provided in paragraph (j) of this section, the owner or operator of an affected facility subject to the opacity standard under §60.43b shall install, calibrate, maintain, and operate a continuous opacity monitoring systems (COMS) for measuring the opacity of emissions discharged to the atmosphere and record the output of the system. [The rest of this paragraph is NA because the applicant will install a COMS.]
- (1) through (3) are NA because the applicant will install a COMS.
- (b) Except as provided under paragraphs (g), (h), and (i) of this section, the owner or operator of an affected facility subject to a NO_x standard under §60.44b shall comply with either paragraphs (b)(1) or (b)(2) of this section.
- (1) Install, calibrate, maintain, and operate CEMS for measuring NO_x and O₂ (or CO₂) emissions discharged to the atmosphere, and shall record the output of the system; or
- (2) If the owner or operator has installed a NO_x emission rate CEMS to meet the requirements of part 75 of this chapter and is continuing to meet the ongoing requirements of part 75 of this chapter, that CEMS may be used to meet the requirements of this section, except that the owner or operator shall also meet the requirements of §60.49b. Data reported to meet the requirements of §60.49b shall not include data substituted using the missing data procedures in subpart D of part 75 of this chapter, nor shall the data have been bias adjusted according to the procedures of part 75 of this chapter.
- (c) The CEMS required under paragraph (b) of this section shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.
- (d) The 1-hour average NO_x emission rates measured by the continuous NO_x monitor required by paragraph (b) of this section and required under §60.13(h) shall be expressed in lb/mmBtu heat

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART Db – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

input and shall be used to calculate the average emission rates under §60.44b. The 1-hour averages shall be calculated using the data points required under §60.13(h)(2).

(e) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

- (1) For affected facilities combusting coal, wood or municipal-type solid waste, the span value for a COMS shall be between 60 and 80 percent.
- (2) For affected facilities combusting coal, oil, or natural gas, the span value for NO_x is determined using one of the following procedures:
 - (i) Except as provided under paragraph (e)(2)(ii) of this section, NO_x span values shall be determined as follows:

Fuel	Span values for NO_x (ppm)
Natural gas	500
Oil	500
Coal	1,000
Mixtures	$500(x + y) + 1,000z$

Where:

x = Fraction of total heat input derived from natural gas;

y = Fraction of total heat input derived from oil; and

z = Fraction of total heat input derived from coal.

- (ii) As an alternative to meeting the requirements of paragraph (e)(2)(i) of this section, the owner or operator of an affected facility may elect to use the NO_x span values determined according to section 2.1.2 in appendix A to part 75 of this chapter.
- (3) All span values computed under paragraph (e)(2)(i) of this section for combusting mixtures of regulated fuels are rounded to the nearest 500 ppm. Span values computed under paragraph (e)(2)(ii) of this section shall be rounded off according to section 2.1.2 in appendix A to part 75 of this chapter.
 - (f) When NO_x emission data are not obtained because of CEMS breakdowns, repairs, calibration checks and zero and span adjustments, emission data will be obtained by using standby monitoring systems, Method 7 of appendix A of this part, Method 7A of appendix A of this part, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days.
 - (g) through (i) are NA.
 - (j) NA because applicant will install a COMS.
 - (k) NA.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5087, Jan. 28, 2009]

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

§ 60.49b Reporting and recordkeeping requirements.

- (a) The owner or operator of each affected facility shall submit notification of the date of initial startup, as provided by §60.7. This notification shall include:
 - (1) The design heat input capacity of the affected facility and identification of the fuels to be combusted in the affected facility;
 - (2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under §§60.42b(d)(1), 60.43b(a)(2), (a)(3)(iii), (c)(2)(ii), (d)(2)(iii), 60.44b(c), (d), (e), (i), (j), (k), 60.45b(d), (g), 60.46b(h), or 60.48b(i);
 - (3) The annual capacity factor at which the owner or operator anticipates operating the facility based on all fuels fired and based on each individual fuel fired; and
 - (4) NA because the applicant is not using an emerging technology for SO₂ control.
- (b) The owner or operator of each affected facility subject to the SO₂, PM, and/or NO_x emission limits under §§60.42b, 60.43b, and 60.44b shall submit to the Administrator the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in appendix B of this part. The owner or operator of each affected facility described in §60.44b(j) or §60.44b(k) shall submit to the Administrator the maximum heat input capacity data from the demonstration of the maximum heat input capacity of the affected facility.
- (c) NA because the applicant will demonstrate NO_x compliance by use of a CEMS
- (d) Except as provided in paragraph (d)(2) of this section, the owner or operator of an affected facility shall record and maintain records as specified in paragraph (d)(1) of this section.
 - (1) The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil, residual oil, natural gas, wood, and municipal-type solid waste for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.
 - (2) NA.
- (e) NA.
- (f) For an affected facility subject to the opacity standard in §60.43b, the owner or operator shall maintain records of opacity. In addition, an owner or operator that elects to monitor emissions according to the requirements in §60.48b(a) shall maintain records according to the requirements specified in paragraphs (f)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.
 - (1) NA because the applicant will use a COMS.
 - (2) NA because the applicant will use a COMS.
 - (3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator.
- (g) Except as provided under paragraph (p) of this section, the owner or operator of an affected facility subject to the NO_x standards under §60.44b shall maintain records of the following information for each steam generating unit operating day:
 - (1) Calendar date;
 - (2) The average hourly NO_x emission rates (expressed as NO₂) (lb/mmBtu heat input) measured or predicted;

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

- (3) The 30-day average NO_x emission rates (lb/mmBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days;
 - (4) Identification of the steam generating unit operating days when the calculated 30-day average NO_x emission rates are in excess of the NO_x emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken;
 - (5) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;
 - (6) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data;
 - (7) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted;
 - (8) Identification of the times when the pollutant concentration exceeded full span of the CEMS;
 - (9) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3; and
 - (10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part.
- (h) The owner or operator of any affected facility in any category listed in paragraphs (h)(1) or (2) of this section is required to submit excess emission reports for any excess emissions that occurred during the reporting period.
- (1) Any affected facility subject to the opacity standards in §60.43b(f) or to the operating parameter monitoring requirements in §60.13(i)(1).
 - (2) Any affected facility that is subject to the NO_x standard of §60.44b, and that:
- (i) Combusts natural gas, distillate oil, gasified coal, or residual oil with a nitrogen content of 0.3 weight percent or less; or
- (ii) Has a heat input capacity of 73 MW (250 MMBtu/hr) or less and is required to monitor NO_x emissions on a continuous basis under §60.48b(g)(1) or steam generating unit operating conditions under §60.48b(g)(2).
- (3) For the purpose of §60.43b, excess emissions are defined as all 6-minute periods during which the average opacity exceeds the opacity standards under §60.43b(f).
 - (4) For purposes of §60.48b(g)(1), excess emissions are defined as any calculated 30-day rolling average NO_x emission rate, as determined under §60.46b(e), that exceeds the applicable emission limits in §60.44b.
- (i) The owner or operator of any affected facility subject to the continuous monitoring requirements for NO_x under §60.48(b) shall submit reports containing the information recorded under paragraph (g) of this section.
- (j) The owner or operator of any affected facility subject to the SO₂ standards under §60.42b shall submit reports.
- (k) For each affected facility subject to the compliance and performance testing requirements of §60.45b and the reporting requirement in paragraph (j) of this section, the following information shall be reported to the Administrator:

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART DB – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

- (1) Calendar dates covered in the reporting period;
 - (2) Each 30-day average SO₂ emission rate (lb/mmBtu heat input) measured during the reporting period, ending with the last 30-day period; reasons for noncompliance with the emission standards; and a description of corrective actions taken; For an exceedance due to maintenance of the SO₂ control system covered in paragraph 60.45b(a), the report shall identify the days on which the maintenance was performed and a description of the maintenance;
 - (3) Each 30-day average percent reduction in SO₂ emissions calculated during the reporting period, ending with the last 30-day period; reasons for noncompliance with the emission standards; and a description of corrective actions taken;
 - (4) Identification of the steam generating unit operating days that coal or oil was combusted and for which SO₂ or diluent (O₂ or CO₂) data have not been obtained by an approved method for at least 75 percent of the operating hours in the steam generating unit operating day; justification for not obtaining sufficient data; and description of corrective action taken;
 - (5) Identification of the times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and description of corrective action taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit;
 - (6) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted;
 - (7) Identification of times when hourly averages have been obtained based on manual sampling methods;
 - (8) Identification of the times when the pollutant concentration exceeded full span of the CEMS;
 - (9) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3;
 - (10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part; and
 - (11) The annual capacity factor of each fired as provided under paragraph (d) of this section.
- (l) For each affected facility subject to the compliance and performance testing requirements of §60.45b(d) and the reporting requirements of paragraph (j) of this section, the following information shall be reported to the Administrator:
- (1) Calendar dates when the facility was in operation during the reporting period;
 - (2) The 24-hour average SO₂ emission rate measured for each steam generating unit operating day during the reporting period that coal or oil was combusted, ending in the last 24-hour period in the quarter; reasons for noncompliance with the emission standards; and a description of corrective actions taken;
 - (3) Identification of the steam generating unit operating days that coal or oil was combusted for which SO₂ or diluent (O₂ or CO₂) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and description of corrective action taken;
 - (4) Identification of the times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and description of corrective action

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART Db – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

- taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit;
- (5) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted;
 - (6) Identification of times when hourly averages have been obtained based on manual sampling methods;
 - (7) Identification of the times when the pollutant concentration exceeded full span of the CEMS;
 - (8) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3; and
 - (9) Results of daily CEMS drift tests and quarterly accuracy assessments as required under Procedure 1 of appendix F 1 of this part. If the owner or operator elects to implement the alternative data assessment procedures described in §§60.47b(e)(4)(i) through (e)(4)(iii), each data assessment report shall include a summary of the results of all of the RATAs, linearity checks, CGAs, and calibration error or drift assessments required by §§60.47b(e)(4)(i) through (e)(4)(iii).
- (m) For each affected facility subject to the SO₂ standards in §60.42(b) for which the minimum amount of data required in §60.47b(c) were not obtained during the reporting period, the following information is reported to the Administrator in addition to that required under paragraph (k) of this section:
- (1) The number of hourly averages available for outlet emission rates and inlet emission rates;
 - (2) The standard deviation of hourly averages for outlet emission rates and inlet emission rates, as determined in Method 19 of appendix A of this part, section 7;
 - (3) The lower confidence limit for the mean outlet emission rate and the upper confidence limit for the mean inlet emission rate, as calculated in Method 19 of appendix A of this part, section 7; and
 - (4) The ratio of the lower confidence limit for the mean outlet emission rate and the allowable emission rate, as determined in Method 19 of appendix A of this part, section 7.
- (n) NA.
- (o) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of 2 years following the date of such record.
- (p) The owner or operator of an affected facility described in §60.44b(j) or (k) shall maintain records of the following information for each steam generating unit operating day:
- (1) Calendar date;
 - (2) The number of hours of operation; and
 - (3) A record of the hourly steam load.
- (q) The owner or operator of an affected facility described in §60.44b(j) or §60.44b(k) shall submit to the Administrator a report containing:
- (1) The annual capacity factor over the previous 12 months;
 - (2) The average fuel nitrogen content during the reporting period, if residual oil was fired; and
 - (3) If the affected facility meets the criteria described in §60.44b(j), the results of any NO_x emission tests required during the reporting period, the hours of operation during the reporting period, and the hours of operation since the last NO_x emission test.

SECTION IV. APPENDIX Db

NSPS, 40 CFR 60, SUBPART Db – STANDARDS OF PERFORMANCE SMALL INDUSTRIAL-COMMERCIAL- INSTITUTIONAL STEAM GENERATING UNITS

- (r) The owner or operator of an affected facility who elects to use the fuel based compliance alternatives in §60.42b or §60.43b shall either:
- (1) The owner or operator of an affected facility who elects to demonstrate that the affected facility combusts only very low sulfur oil, natural gas, wood, a mixture of these fuels, or any of these fuels (or a mixture of these fuels) in combination with other fuels that are known to contain an insignificant amount of sulfur in §60.42b(j) or §60.42b(k) shall obtain and maintain at the affected facility fuel receipts from the fuel supplier that certify that the oil meets the definition of distillate oil and gaseous fuel meets the definition of natural gas as defined in §60.41b and the applicable sulfur limit. For the purposes of this section, the distillate oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Reports shall be submitted to the Administrator certifying that only very low sulfur oil meeting this definition, natural gas, wood, and/or other fuels that are known to contain insignificant amounts of sulfur were combusted in the affected facility during the reporting period; or
 - (2) The owner or operator of an affected facility who elects to demonstrate compliance based on fuel analysis in §60.42b or §60.43b shall develop and submit a site-specific fuel analysis plan to the Administrator for review and approval no later than 60 days before the date you intend to demonstrate compliance. Each fuel analysis plan shall include a minimum initial requirement of weekly testing and each analysis report shall contain, at a minimum, the following information:
 - (i) The potential sulfur emissions rate of the representative fuel mixture in ng/J heat input;
 - (ii) The method used to determine the potential sulfur emissions rate of each constituent of the mixture. For distillate oil and natural gas a fuel receipt or tariff sheet is acceptable;
 - (iii) The ratio of different fuels in the mixture; and
 - (iv) The owner or operator can petition the Administrator to approve monthly or quarterly sampling in place of weekly sampling.
 - (s) through (u) are NA.
 - (v) The owner or operator of an affected facility may submit electronic quarterly reports for SO₂ and/or NO_x and/or opacity in lieu of submitting the written reports required under paragraphs (h), (i), (j), (k) or (l) of this section. The format of each quarterly electronic report shall be coordinated with the permitting authority. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this subpart was achieved during the reporting period. Before submitting reports in the electronic format, the owner or operator shall coordinate with the permitting authority to obtain their agreement to submit reports in this alternative format.
 - (w) The reporting period for the reports required under this subpart is each 6 month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.
 - (x) and (y) are NA.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5089, Jan. 28, 2009]

[Link to 40 CFR 60, Subpart Db](#)

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

{Permitting Note: This is the section (Section 5) of Appendix F of 40 CFR 75 including the F-Factor Table for fuels that deals with the calculation of the heat input rate to a steam generating boiler. This procedure is utilized by boilers that fall under the Acid Rain program. This is the procedure that FBE will utilize to calculate the heat input rate to the grate-type suspension biomass boiler. To access the full version of 40 CFR 75, Appendix F, follow the link at the end of this appendix.}

5. Procedures for Heat Input

Use the following procedures to compute heat input rate to an affected unit (in mmBtu/hr or mmBtu/day):

5.1 Calculate and record heat input rate to an affected unit on an hourly basis, except as provided in sections 5.5 through 5.5.7. The owner or operator may choose to use the provisions specified in §75.16(e) or in section 2.1.2 of appendix D to this part in conjunction with the procedures provided in sections 5.6 through 5.6.2 to apportion heat input among each unit using the common stack or common pipe header.

5.2 For an affected unit that has a flow monitor (or approved alternate monitoring system under subpart E of this part for measuring volumetric flow rate) and a diluent gas (O₂ or CO₂) monitor, use the recorded data from these monitors and one of the following equations to calculate hourly heat input rate (in mmBtu/hr).

5.2.1 When measurements of CO₂ concentration are on a wet basis, use the following equation:

$$HI = Q_w \frac{1}{F_c} \frac{\%CO_{2w}}{100} \quad (Eq. F-15)$$

Where:

HI = Hourly heat input rate during unit operation, mmBtu/hr.

Q_w = Hourly average volumetric flow rate during unit operation, wet basis, scfh.

F_c = Carbon-based F-factor, listed in section 3.3.5 of this appendix for each fuel, scf/mmBtu.

%CO_{2w} = Hourly concentration of CO₂ during unit operation, percent CO₂ wet basis.

5.2.2 When measurements of CO₂ concentration are on a dry basis, use the following equation:

$$HI = Q_d \left[\frac{(100 - \%H_2O)}{100 F_c} \right] \left[\frac{\%CO_{2d}}{100} \right] \quad (Eq. F-16)$$

Where:

HI = Hourly heat input rate during unit operation, mmBtu/hr.

Q_d = Hourly average volumetric flow rate during unit operation, wet basis, scfh.

F_c = Carbon-based F-Factor, listed in section 3.3.5 of this appendix for each fuel, scf/mmBtu.

%CO_{2d} = Hourly concentration of CO₂ during unit operation, percent CO₂ dry basis.

%H₂O = Moisture content of gas in the stack, percent.

5.2.3 When measurements of O₂ concentration are on a wet basis, use the following equation:

$$HI = Q_w \frac{1}{F} \left[\frac{(20.9/100)(100 - \%H_2O) - \%O_{2w}}{20.9} \right] \quad (Eq. F-17)$$

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

Where:

HI = Hourly heat input rate during unit operation, mmBtu/hr.

Q_w = Hourly average volumetric flow rate during unit operation, wet basis, scfh.

F = Dry basis F-factor, listed in section 3.3.5 of this appendix for each fuel, dscf/mmBtu.

%O_{2w} = Hourly concentration of O₂ during unit operation, percent O₂ wet basis. For any operating hour where Equation F-17 results in an hourly heat input rate that is ≤ 0.0 mmBtu/hr, 1.0 mmBtu/hr shall be recorded and reported as the heat input rate for that hour.

%H₂O = Hourly average stack moisture content, percent by volume.

5.2.4 When measurements of O₂ concentration are on a dry basis, use the following equation:

$$HI = Q_w \left[\frac{(100 - \%H_2O)}{100 F} \right] \left[\frac{(20.9 - \%O_{2d})}{20.9} \right] \quad (Eq. F-18)$$

Where:

HI = Hourly heat input rate during unit operation, mmBtu/hr.

Q_w = Hourly average volumetric flow during unit operation, wet basis, scfh.

F = Dry basis F-factor, listed in Table 1 at the end of this of this appendix for each fuel, dscf/mmBtu.

%H₂O = Moisture content of the stack gas, percent.

%O_{2d} = Hourly concentration of O₂ during unit operation, percent O₂ dry basis.

5.3 Heat Input Summation (for Heat Input Determined Using a Flow Monitor and Diluent Monitor)

5.3.1 Calculate total quarterly heat input for a unit or common stack using a flow monitor and diluent monitor to calculate heat input, using the following equation:

$$HI_q = \sum_{hour=1}^n HI_i t_i \quad (Eq. F-18a)$$

Where:

HI_q = Total heat input for the quarter, mmBtu.

HI_i = Hourly heat input rate during unit operation, using Equation F-15, F-16, F-17, or F-18, mmBtu/hr.

t_i = Hourly operating time for the unit or common stack, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

5.3.2 Calculate total cumulative heat input for a unit or common stack using a flow monitor and diluent monitor to calculate heat input, using the following equation:

$$HI_c = \sum_{q=1}^{\text{the current quarter}} HI_q \quad (Eq. F-18b)$$

Where:

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

HI_c= Total heat input for the year to date, mmBtu.

HI_q= Total heat input for the quarter, mmBtu.

5.4 [Reserved]

5.5 For a gas-fired or oil-fired unit that does not have a flow monitor and is using the procedures specified in appendix D to this part to monitor SO₂ emissions or for any unit using a common stack for which the owner or operator chooses to determine heat input by fuel sampling and analysis, use the following procedures to calculate hourly heat input rate in mmBtu/hr. The procedures of section 5.5.3 of this appendix shall not be used to determine heat input from a coal unit that is required to comply with the provisions of this part for monitoring, recording, and reporting NO_x mass emissions under a State or federal NO_x mass emission reduction program.

5.5.1 (a) When the unit is combusting oil, use the following equation to calculate hourly heat input rate:

$$HI_o = M_o \frac{GCV_o}{10^6} \quad (Eq. F-19)$$

Where:

HI_o= Hourly heat input rate from oil, mmBtu/hr.

M_o= Mass rate of oil consumed per hour, as determined using procedures in appendix D to this part, in lb/hr, tons/hr, or kg/hr.

GCV_o= Gross calorific value of oil, as measured by ASTM D240–00, ASTM D5865–01a, or ASTM D4809–00 for each oil sample under section 2.2 of appendix D to this part, Btu/unit mass (all incorporated by reference under (§75.6 of this part).

10⁶ = Conversion of Btu to mmBtu.

(b) When performing oil sampling and analysis solely for the purpose of the missing data procedures in §75.36, oil samples for measuring GCV may be taken weekly, and the procedures specified in appendix D to this part for determining the mass rate of oil consumed per hour are optional.

5.5.2 When the unit is combusting gaseous fuels, use the following equation to calculate heat input rate from gaseous fuels for each hour:

$$HI_g = \frac{(Q_g \times GCV_g)}{10^6} \quad (Eq. F-20)$$

Where:

HI_g= Hourly heat input rate from gaseous fuel, mmBtu/hour.

Q_g= Metered flow rate of gaseous fuel combusted during unit operation, hundred standard cubic feet per hour.

GCV_g= Gross calorific value of gaseous fuel, as determined by sampling (for each delivery for gaseous fuel in lots, for each daily gas sample for gaseous fuel delivered by pipeline, for each hourly average for gas measured hourly with a gas chromatograph, or for each monthly sample of pipeline natural gas, or as verified by the contractual supplier at least once every month pipeline natural gas is combusted, as specified in section 2.3 of appendix D to this part) using ASTM D1826–94 (Reapproved 1998), ASTM D3588–98, ASTM D4891–89 (Reapproved 2006), GPA Standard 2172–96 Calculation of Gross Heating Value, Relative Density and

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

Compressibility Factor for Natural Gas Mixtures from Compositional Analysis, or GPA Standard 2261–00 Analysis for Natural Gas and Similar Gaseous Mixtures by Gas Chromatography, Btu/100 scf (all incorporated by reference under §75.6 of this part).

10^6 = Conversion of Btu to mmBtu.

5.5.3 When the unit is combusting coal, use the procedures, methods, and equations in sections 5.5.3.1–5.5.3.3 of this appendix to determine the heat input from coal for each 24-hour period. (All ASTM methods are incorporated by reference under §75.6 of this part.)

5.5.3.1 Perform coal sampling daily according to section 5.3.2.2 in Method 19 in appendix A to part 60 of this chapter and use ASTM D2234–00, Standard Practice for Collection of a Gross Sample of Coal, (incorporated by reference under §75.6 of this part) Type I, Conditions A, B, or C and systematic spacing for sampling. (When performing coal sampling solely for the purposes of the missing data procedures in §75.36, use of ASTM D2234–00 is optional, and coal samples may be taken weekly.)

5.5.3.2 All ASTM methods are incorporated by reference under §75.6 of this part. Use ASTM D2013–01, Standard Practice for Preparing Coal Samples for Analysis, for preparation of a daily coal sample and analyze each daily coal sample for gross calorific value using ASTM D5865–01a, Standard Test Method for Gross Calorific Value of Coal and Coke. On-line coal analysis may also be used if the on-line analytical instrument has been demonstrated to be equivalent to the applicable ASTM methods under §§75.23 and 75.66.

5.5.3.3 Calculate the heat input from coal using the following equation:

$$HI_c = M_c \frac{GCV_c}{500} \quad (Eq. F-21)$$

(Eq. F-21)

where:

HI_c = Daily heat input from coal, mmBtu/day.

M_c = Mass of coal consumed per day, as measured and recorded in company records, tons.

GCV_c = Gross calorific value of coal sample, as measured by ASTM D3176–89 (Reapproved 2002), or ASTM D5865–01a, Btu/lb. (incorporated by reference under §75.6 of this part).

500 = Conversion of Btu/lb to mmBtu/ton.

5.5.4 For units obtaining heat input values daily instead of hourly, apportion the daily heat input using the fraction of the daily steam load or daily unit operating load used each hour in order to obtain HI_i for use in the above equations. Alternatively, use the hourly mass of coal consumed in equation F-21.

5.5.5 If a daily fuel sampling value for gross calorific value is not available, substitute the maximum gross calorific value measured from the previous 30 daily samples. If a monthly fuel sampling value for gross calorific value is not available, substitute the maximum gross calorific value measured from the previous 3 monthly samples.

5.5.6 If a fuel flow value is not available, use the fuel flowmeter missing data procedures in section 2.4 of appendix D of this part. If a daily coal consumption value is not available, substitute the maximum fuel feed rate during the previous thirty days when the unit burned coal.

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

5.5.7 Results for samples must be available no later than thirty calendar days after the sample is composited or taken. However, during an audit, the Administrator may require that the results be available in five business days, or sooner if practicable.

5.6 Heat Input Rate Apportionment for Units Sharing a Common Stack or Pipe

5.6.1 Where applicable, the owner or operator of an affected unit that determines heat input rate at the unit level by apportioning the heat input monitored at a common stack or common pipe using megawatts shall apportion the heat input rate using the following equation:

$$HI_i = HI_{cs} \left(\frac{t_{cs}}{t_i} \right) \left[\frac{MW_i t_i}{\sum_{i=1}^n MW_i t_i} \right] \quad (Eq. F-21a)$$

Where:

HI_i = Heat input rate for a unit, mmBtu/hr.

HI_{cs} = Heat input rate at the common stack or pipe, mmBtu/hr.

MW_i = Gross electrical output, MWe.

t_i = Unit operating time, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

t_{cs} = Common stack or common pipe operating time, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

n = Total number of units using the common stack or pipe.

i = Designation of a particular unit.

5.6.2 Where applicable, the owner or operator of an affected unit that determines the heat input rate at the unit level by apportioning the heat input rate monitored at a common stack or common pipe using steam load shall apportion the heat input rate using the following equation:

$$HI_i = HI_{cs} \left(\frac{t_{cs}}{t_i} \right) \left[\frac{SF_i t_i}{\sum_{i=1}^n SF_i t_i} \right] \quad (Eq. F-21b)$$

Where:

HI_i = Heat input rate for a unit, mmBtu/hr.

HI_{cs} = Heat input rate at the common stack or pipe, mmBtu/hr.

SF = Gross steam load, lb/hr, or mmBtu/hr.

t_i = Unit operating time, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

t_{cs} = Common stack or common pipe operating time, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

n = Total number of units using the common stack or pipe.

i = Designation of a particular unit.

5.7 Heat Input Rate Summation for Units with Multiple Stacks or Pipes

The owner or operator of an affected unit that determines the heat input rate at the unit level by summing the heat input rates monitored at multiple stacks or multiple pipes shall sum the heat input rates using the following equation:

$$HI_{Unit} = \frac{\sum_{s=1}^n HI_s t_s}{t_{Unit}} \quad (Eq. F-21c)$$

Where:

HI_{Unit}= Heat input rate for a unit, mmBtu/hr.

HI_s= Heat input rate for the individual stack, duct, or pipe, mmBtu/hr.

t_{Unit}= Unit operating time, hour or fraction of the hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

t_s= Operating time for the individual stack or pipe, hour or fraction of the hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

s = Designation for a particular stack, duct, or pipe.

5.8 Alternate Heat Input Apportionment for Common Pipes

As an alternative to using Equation F-21a or F-21b in section 5.6 of this appendix, the owner or operator may apportion the heat input rate at a common pipe to the individual units served by the common pipe based on the fuel flow rate to the individual units, as measured by uncertified fuel flowmeters. This option may only be used if a fuel flowmeter system that meets the requirements of appendix D to this part is installed on the common pipe. If this option is used, determine the unit heat input rates using the following equation:

$$HI_i = HI_{CP} \left(\frac{t_{CP}}{t_i} \right) \left[\frac{FF_i t_i}{\sum_{i=1}^n FF_i t_i} \right] \quad (Eq. F-21d)$$

Where:

HI_i= Heat input rate for a unit, mmBtu/hr.

HI_{CP}= Heat input rate at the common pipe, mmBtu/hr.

FF_i= Fuel flow rate to a unit, gal/min, 100 scfh, or other appropriate units.

t_i= Unit operating time, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

SECTION IV. APPENDIX F

40 CFR 75, APPENDIX F, SECTION 5 – MEASUREMENT OF BOILER HEAT INPUT RATE

t_{CP} = Common pipe operating time, hour or fraction of an hour (in equal increments that can range from one hundredth to one quarter of an hour, at the option of the owner or operator).

n = Total number of units using the common pipe.

i = Designation of a particular unit.

3.3.5 F , F_c = a factor representing a ratio of the volume of dry flue gases generated to the caloric value of the fuel combusted (F), and a factor representing a ratio of the volume of CO_2 generated to the calorific value of the fuel combusted (F_c), respectively. Table 1 lists the values of F and F_c for different fuels. The permittee at their discretion may use the procedure of 40 CFR Part 75, Appendix F, Section 3.3.6 to calculate a site specific F factor for the grate-type suspension biomass boiler at the FBE facility.

Table 1—F- and F_c -Factors^{1,2}

Fuel	F-factor (dscf/mmBtu)	F_c-factor (scf CO_2/mmBtu)
Coal (as defined by ASTM D388–99 ³):		
Anthracite	10,100	1,970
Bituminous	9,780	1,800
Subbituminous	9,820	1,840
Lignite	9,860	1,910
Petroleum Coke	9,830	1,850
Tire Derived Fuel	10,260	1,800
Oil	9,190	1,420
Gas:		
Natural gas	8,710	1,040
Propane	8,710	1,190
Butane	8,710	1,250
Wood:		
Bark	9,600	1,920
Wood residue	9,240	1,830

¹ Determined at standard conditions: 20 °C (68 °F) and 29.92 inches of mercury.

² FBE may develop F-Factors specific to the grate-type suspension boiler and woody biomass used at their facility

³ Incorporated by reference under §75.6 of this part.

[Appendix F of 40 CFR 75 including the F-Factor Table](#)

SECTION IV. APPENDIX GC

GENERAL CONDITIONS

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
 - a. Have access to and copy and records that must be kept under the conditions of the permit;
 - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
 - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
 - a. A description of and cause of non-compliance; and
 - b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

SECTION IV. APPENDIX GC

GENERAL CONDITIONS

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
 - a. Determination of Best Available Control Technology ();
 - b. Determination of Prevention of Significant Deterioration ();
 - c. Compliance with National Emission Standards for Hazardous Air Pollutants (); and
 - d. Compliance with New Source Performance Standards (X).
14. The permittee shall comply with the following:
 - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - c. Records of monitoring information shall include:
 - 1) The date, exact place, and time of sampling or measurements;
 - 2) The person responsible for performing the sampling or measurements;
 - 3) The dates analyses were performed;
 - 4) The person responsible for performing the analyses;
 - 5) The analytical techniques or methods used; and
 - 6) The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

SECTION IV. APPENDIX GP

NSPS SUBPART A AND NESHAP SUBPART A - IDENTIFICATION OF GENERAL PROVISIONS

NSPS - SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

The provisions of this Subpart may be provided in full upon request. Emissions units subject to a New Source Performance Standard of 40 CFR 60 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

- § 60.1 Applicability.
- § 60.2 Definitions.
- § 60.3 Units and abbreviations.
- § 60.4 Address.
- § 60.5 Determination of construction or modification.
- § 60.6 Review of plans.
- § 60.7 Notification and Record Keeping.
- § 60.8 Performance Tests.
- § 60.9 Availability of information.
- § 60.10 State Authority.
- § 60.11 Compliance with Standards and Maintenance Requirements.
- § 60.12 Circumvention.
- § 60.13 Monitoring Requirements.
- § 60.14 Modification.
- § 60.15 Reconstruction.
- § 60.16 Priority List.
- § 60.17 Incorporations by Reference.
- § 60.18 General Control Device Requirements.
- § 60.19 General Notification and Reporting Requirements.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.

NESHAP - SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

The provisions of this Subpart may be provided in full upon request. Emissions units subject to a National Emission Standards for Hazardous Air Pollutants of 40 CFR 63 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

- § 63.1 Applicability.
- § 63.2 Definitions.
- § 63.3 Units and abbreviations.
- § 63.4 Prohibited Activities and Circumvention.
- § 63.5 Preconstruction Review and Notification Requirements.
- § 63.6 Compliance with Standards and Maintenance Requirements.

SECTION IV. APPENDIX GP

NSPS SUBPART A AND NESHAP SUBPART A - IDENTIFICATION OF GENERAL PROVISIONS

§ 63.7 Performance Testing Requirements.

§ 63.8 Monitoring Requirements.

§ 63.9 Notification Requirements.

§ 63.10 Recordkeeping and Reporting Requirements.

§ 63.11 Control Device Requirements.

§ 63.12 State Authority and Delegations.

§ 63.13 Addresses of State Air Pollution Control Agencies and EPA Regional Offices.

§ 63.14 Incorporation by Reference.

§ 63.15 Availability of Information and Confidentiality.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.

SECTION IV. APPENDIX IIII

NSPS, SUBPART IIII - STATIONARY COMPRESSION IGNITION INTERNAL COMBUSTION ENGINES

A 500 kW or less emergency generator (EU ID 004) and a 335 hp or less fire pump (EU-005) are proposed for the FBE facility and are subject to the applicable requirements of 40 CFR 60, Subpart IIII--Standards of Performance for Stationary Compression Ignition Internal Combustion Engines. The provisions of this Subpart may be provided in full upon request and are also available at the following link:

[Link to Subpart IIII](#)

Draft

SECTION IV. APPENDIX ZZZZ

NESHAP, SUBPART ZZZZ – STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES

A 500 kW or less emergency generator (EU ID 004) and a 335 hp or less fire pump (EU-005) are proposed for the FBE facility and they are subject to the requirements of 40 CFR 63, Subpart ZZZZ--National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. The complete provisions of Subpart ZZZZ may be provided in full upon request and are also available beginning at Section 63.6580 at:

[Link to Subpart ZZZZ](#)

Draft