



Department of Environmental Protection

Entered RUC 4/6
FILE COPY


Project 006

Lawton Chiles
Governor

Northwest District
160 Governmental Center
Pensacola, Florida 32501-5794

Virginia B. Wetherell
Secretary

AIRS I.D. Number: 0910064
Air Permit Number: 0910064-004-AF
Emissions Units: 001-008
Date of Issue: December 23, 1996
Amended: May 5, 1998
Expiration Date: December 23, 2001



Robert A. Hamel, Lt. Col., USAF
Commander, 16th Civil Engineer Squadron
Building 900523, 415 Independence Rd
Hurlburt Field FL 32544-5244

Dear Lt. Col. Hamel:

received 4/20

This is in response to your April 17, 1998, letter requesting modification of Hurlburt base's operating permit (0910064-004-AF) to include the recently completed 20,000 barrel jet fuel storage tank.

This letter modifies the referenced parts of permit 0910064-004-AF as follows.

1. Add the following to Table 1, Hurlburt Field, Maximum Allowable Operating Rates:

<u>Emission Unit</u>	<u>Emission Point</u>	<u>Description</u>	<u>Maximum Allowable Operating Rate</u>
001	001	20,000 bbl JP-8 tank (NSPS, Kb) HFR/IFP*	As facility

* horizontal fixed roof/internal floating pan

2. Change Specific Condition No. 3 **from:**

3. Emission units 002 (fuel storage tanks), 003 (multi fuel boilers), 004 (NG boilers), 005 (spray paint booths), and 008 (fuel transfer facilities) may operate continuously, ...

to:

3. Emission units 001 (NSPS fuel storage tanks), 002 (fuel storage tanks), 003 (multi fuel boilers), 004 (NG boilers), 005 (spray paint booths), and 008 (fuel transfer facilities) may operate continuously, ...

3. Add the following to Specific Condition No. 5:

5. The maximum allowable emission limit for each pollutant is as follows:

Emission unit 001 - NSPS fuel storage tanks

<u>Pollutant</u>	<u>FAC Rule</u>	<u>Allowable Emissions</u>
VOC	62-204.800	< 0.1 TPY

4. Add the following to Specific Condition No. 8:

8. The following records shall be maintained and made available for Department inspection.

<u>EMU</u>	<u>Record keeping requirements</u>
001	As required by 40 CFR 60 Subpart Kb

5. Change Specific Condition No. 11 **from:**

11. The emission units covered by this permit are:

0910064 002: Fuel storage tanks
etc.

to:

11. The emission units covered by this permit are:


0910064 001: NSPS fuel storage tanks
002: Fuel storage tanks
etc.

A copy of this letter must be attached to and is made a part of the referenced permit.

Your letter also requested changes associated with emission unit 006 - the aircraft engine test stand. As discussed with Ms. Jackie Lynd this will require a separate application fee of \$250 (minor modification, AFMM), as well as calculations showing the changes in emissions. Additionally, this modification will require public notice since the allowed emissions for the facility will increase.

If you have any questions, please contact Bob Kriegel at (850) 595-8364.

Sincerely,



Ed K. Middleswart, P.E.
Air Program Administrator

EKM:bkc

cc: DEP Division of Air Resources Management, Tallahassee