

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION

E-CORRESPONDENCE

**karl.hodges@orhs.org**

In the Matter of an  
Application for Permit by:  
Orlando Regional Healthcare Systems  
65 Sturtevant Street, Suite B  
Mail Point 71  
Orlando, Florida 32806

Orange County - AP  
3 steam boilers and 8 emergency  
generators (Initial FESOP)  
DEP File Number 0950067-001-AF

Attention: Karl Hodges, Vice President Business Development

**INTENT TO ISSUE**

The Department of Environmental Protection (Department) gives notice of its intent to issue a permit (copy enclosed) for the proposed project as detailed in the application specified above. The Central District is issuing this Intent to Issue for the reasons stated below.

The applicant, Orlando Regional Healthcare Systems, applied on March 30, 2007, to the Department for a FESOP permit to operate steam boilers and emergency generators. Orlando Regional Healthcare Systems, Downtown Campus, is a source of air emissions located at 1414 Kuhl Avenue, Orlando, Orange County, Florida. The Department has assigned File Number 0950067-001-AF to the project.

The Department has permitting jurisdiction under Section 403 Florida Statutes (F.S.) and Chapter 62-4.210 and Chapter 62-210.300 Florida Administrative Code (F.A.C.). The project is not exempt from permitting procedures. The Department has determined that a construction permit is required for the proposed work.

Pursuant to Section 403.815, F.S. and Rule 62-103.150, F.A.C., you (the applicant) are required to publish at your own expense the enclosed Notice of Intent to Issue Permit. The Notice shall be published one time only within 30 days, in the legal ad section of a newspaper of general circulation in the area affected. For the purpose of this rule, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. Where there is more than one newspaper of general circulation in the county, the newspaper used must be one with significant circulation in the area that may be affected by the permit. If you are uncertain that a newspaper meets these requirements, please contact the Department at the address or telephone number listed below. The applicant shall provide proof of publication to the Department, at 3319 Maguire Boulevard, Suite 232, Orlando, FL 32803-3767 within seven days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

The Department will issue the permit with the attached conditions unless a response is received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments concerning the proposed permit issuance action for a period of 14 days from the date of publication of "PUBLIC NOTICE OF INTENT TO ISSUE FEDERALLY ENFORCABLE STATE OPERATION PERMIT." Written comments should be provided to the Central District office at 3319 Maguire Boulevard, Orlando, Florida 32803. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel to the Department at 3900 Commonwealth Boulevard, Mail Stop 35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within 14 days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3) of the Florida Statutes must be filed within 14 days of publication of the public notice or within 14 days of receipt of this notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Department for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination;
- (c) A statement of how and when petitioner received notice of the agency action or proposed action;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief; and
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and

- (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573 of the Florida Statutes is not available in this proceeding.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542 F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The petition must specify the following information:


- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of Environmental Protection Agency and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

Executed in Orlando, Florida.


STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION




James N. Bradner, P.E.  
Program Administrator  
Air Resources Management  
3319 Maguire Boulevard  
Suite 232  
Orlando, Florida 32803-3767  
(407) 894-7555


DATE: 5/29/2007

Filed, on this date, pursuant to Section 120.52, F.S., with the designated Department Clerk, receipt of which is hereby acknowledged.

 5/29/07  
Clerk Date

CERTIFICATE OF SERVICE

This is to certify that this INTENT TO ISSUE and all copies were sent electronically before the close of business on 5/29/07 to the listed persons by .

  
JNB/jar

Enclosures: Draft Permit  
Notice of Intent

cc: Katy Forney, EPA Region 4, (forney.kathleen@epa.gov)  
Hamp Pridgen, Air Section Manager, OCEPD, (Hamp.Pridgen@ocfl.net)  
Lori Palin, Environmental Compliance Manager, ORHS, (loriann.palin@orhs.org)  
Thomas W. Davis, P.E., EC&T, Inc., (tdavis@ectinc.com)

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
PUBLIC NOTICE OF INTENT TO ISSUE FEDERALLY ENFORCABLE STATE OPERATION PERMIT

The Department of Environmental Protection gives notice of its intent to issue a FESOP permit to Orlando Regional Healthcare Systems, 65 Sturtevant Street, Suite B, Mail Point 71, Orlando, Florida to operate steam boilers and emergency generators. The facility, Orlando Regional Healthcare Systems, Downtown Campus, is a source of air emissions located at 1414 Kuhl Avenue, Orlando, Orange County, Florida. The Department has assigned File Number 0950067-001-AF to the project.

The Department will issue the permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments concerning the proposed permit issuance action for a period of 14 days from the date of publication of "PUBLIC NOTICE OF INTENT TO ISSUE FEDERALLY ENFORCABLE STATE OPERATION PERMIT." Written comments should be provided to the District office at 3319 Maguire Boulevard, Suite 232, Orlando, Florida 32803. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 Florida Statutes (F.S.), before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within 14 days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3) of the Florida Statutes must be filed within 14 days of publication of the public notice or within 14 days of receipt of this notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Department for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code (F.A.C.).

A petition that disputes the material facts on which the Department's action is based must contain the following information:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination;
- (c) A statement of how and when petitioner received notice of the agency action or proposed action;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief; and
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301 F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573 of the Florida Statutes is not available in this proceeding.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at: the Department of Environmental Protection, 3319 Maguire Boulevard, Suite 232, Orlando, Florida.



# Florida Department of Environmental Protection

Central District Office  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

Charlie Crist  
Governor

Jeff Kottkamp  
Lt. Governor

Michael W. Sole  
Secretary

Permittee:  
Orlando Regional Healthcare Systems  
65 Sturtevant Street, Suite B,  
Mail Point 71  
Orlando, Florida 32806

Attn.: Karl Hodges,  
Vice President Business Development

Facility Number: 0950067  
Permit Number: 0950067-001-AF  
**Expiration Date: June 30, 2012**  
County: Orange  
Latitude/Longitude:  
28° 31' 33"N/81° 22' 56"W  
Project: 3 steam boilers and 8 emergency  
generators (initial FESOP)

This permit is issued under the provisions of Chapter(s) 403, Florida Statutes, and Florida Administrative Code Rule(s) 62-210. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the department and made a part hereof and specifically described as follows:

This is the initial FESOP (Federally Enforceable State Operating Permit) for the facility, which is the Orlando Regional Healthcare Systems, Downtown Campus.

The permittee may operate fuel-burning equipment (including three natural gas-fired steam boilers and eight internal combustion diesel driven emergency generators). Additionally, the permittee may operate the following insignificant sources: 2 diesel driven emergency fire water pumps; numerous small (i.e., less than 150,000 British thermal unit [Btu] each) natural gas-fired kitchen dryers, stoves, ovens, steamers, and grills with a total heat input capacity of 2.0 million British thermal units per hour [MMBtu/hr]); various diesel fuel storage tanks; one ethylene oxide sterilizer; and miscellaneous laboratory equipment.

This facility, Orlando Regional Healthcare Systems, Downtown Campus, is located at 1414 Kuhl Avenue, Orlando, Orange County, Florida.



**GENERAL CONDITIONS:**

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, Florida Statutes (F.S.) The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup and auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
  - (a) Have access to and copy any records that must be kept under conditions of this permit;
  - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and
  - (c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
  - (a) A description of and cause of noncompliance; and
  - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.



**GENERAL CONDITIONS:**

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Section 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Rule 62-4.120 and Rule 62-730.300, Florida Administrative Code (F.A.C.), as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
  - ( ) Determination of Best Available Control Technology (BACT)
  - ( ) Determination of Prevention of Significant Deterioration (PSD)
  - ( ) Certification of compliance with State Water Quality Standards (Section 401, PL 92-500)
  - ( ) Compliance with New Source Performance Standards
14. The permittee shall comply with the following:
  - (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring information) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - (c) Records of monitoring information shall include:
    1. The date, exact place, and time of sampling or measurements;
    2. The person responsible for performing the sampling or measurements;
    3. The dates analyses were performed;
    4. The person responsible for performing the analyses;
    5. The analytical techniques or methods used;
    6. The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

### Operating Conditions

1. Capacity. The total annual fuel consumption for the permitted package steam boilers at the facility is limited to 733.2 million standard cubic feet of natural gas or 0.3540 million gallons of fuel oil containing no more than 0.05 percent sulfur, or an equivalent prorated amount if multiple fuels are used.  
[Rules 62-210.200, (Potential Emissions or Potential to Emit, PTE), F.A.C., and 62-4.070(3), F.A.C., and application received on March 30, 2007]
2. Hours of Operation. The package steam boilers are limited to less than 6000 operational hours of utilizing low sulfur no. 2 fuel oil per consecutive twelve-month period. The steam boilers may operate continuously when utilizing natural gas as a fuel. Emergency generators are limited to 250 non-emergency operation hours per consecutive 12-month period. Emergency generators operational hours are not limited during emergency operation. Other emission sources are permitted to operate continuously.  
[Rules 62-210.200, (Potential Emissions or Potential to Emit, PTE), F.A.C., and 62-4.070(3), F.A.C., and application received on March 30, 2007]

### Emission Limitations and Standards

3. The maximum **facility** nitrogen oxides (NO<sub>x</sub>), Carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), and volatile organic compound (VOCs) emission rates are each limited to less than 88.7 tons, 38.9 tons, 13.4 tons, and 3.2 tons per consecutive twelve-month period. Additionally, total hazardous air pollutant (HAP) emissions are limited to less than 25.0 tons per consecutive 12 months, and each HAP emission is limited to less than 10.0 tons per consecutive 12 months.  
[Rule 62-210.200, (Potential Emissions or Potential to Emit, PTE), F.A.C., and the permit application received on March 30, 2007]
4. Visible emissions from the facility are limited to less than 20% opacity  
[Rule 62-296.320(4)(b)1., F.A.C.].

### Compliance

5. Each of the three largest natural-gas-fired package steam boilers at the facility must be tested for visible emissions in accordance with EPA Method 9 at least 90 days prior to permit expiration date. The required minimum period of observation for a compliance test shall be sixty (60) minutes for boilers which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for boilers which have potential emissions less than 100 tons per year of particulate matter. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur.  
[Rules 62-296.320(4)(b)4.a. and 62-297.310(4)(a)2., F.A.C.]
6. The owner or operator shall notify the air compliance section of the Orange County Environmental Protection Division, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.  
[Rule 62-297.310(7)(a)9., F.A.C.]

7. The owner or operator shall submit a copy of the compliance test results to the air compliance section of the Orange County Environmental Protection Division as soon as practical but no later than 45 days after the last sampling run of each test is completed.  
[Rule 62-297.310(8)(b), F.A.C.]
8. The owner or operator shall complete DEP Form No. 62-210.900(5), F.A.C. "Annual Operating Report for Air Pollutant Emitting Facility", including the Emissions Report, for each calendar year and submit to the air compliance section of the Orange County Environmental Protection Division on or before March 1 of the following year.  
[Rule 62-210.370(3)(a), F.A.C.]
9. For the purpose of submitting well-organized Annual Operating Reports, there shall be two (2) emission sources for the facility as designated:  
  
Emission Unit 1 - Three steam boilers  
Emission Unit 2 - Eight diesel-fired emergency generators  
[Rule 62-4.070(3), F.A.C.]
10. In order to demonstrate compliance with condition numbers 1 and 3, the permittee shall maintain a log at the facility for a period of at least 5 years from the date the data is recorded. The log at a minimum shall contain the following:

Monthly

- a) designation of month and year of operation for which records are being tabulated
  - b) consecutive 12-month total of NOx emissions
  - c) consecutive 12-month total of CO emissions
  - d) consecutive 12-month total of SO<sub>2</sub> emissions
  - e) consecutive 12-month total of VOC emissions
  - f) steam boilers natural gas consumption (consecutive 12-month total)
  - g) steam boilers diesel fuel consumption (consecutive 12-month total)
  - h) emergency generators diesel fuel consumption (consecutive 12-month total)
  - i) emergency generators operational hours (consecutive 12-month total); make a notation whether the operational hours are emergency or non-emergency
  - j) consecutive 12-month total of total HAPs emissions and each HAP emission
- [Rule 62-4.070(3), F.A.C.]

Record keeping is not required for insignificant sources at the facility including the following: 2 diesel driven emergency fire water pumps; numerous small (i.e., less than 150,000 British thermal unit [Btu] each) natural gas-fired kitchen dryers, stoves, ovens, steamers, and grills with a total heat input capacity of 2.0 million British thermal units per hour [MMBtu/hr]; various diesel fuel storage tanks; one ethylene oxide sterilizer; and miscellaneous laboratory equipment.

Note: A consecutive 12-month total is equal to the total for the month in question plus the totals for the eleven months previous to the month in question. A consecutive 12-month total treats each month of the year as the end of a 12-month period. A 12-month total is not a year-to-date total. Facilities that have not been operating for 12 months should retain 12-month totals using whatever number of months of data are available until such a time as a consecutive 12-month total can be maintained each month.

Supporting documentation (chemical usage tracking logs, MSDS sheets, purchase orders, EPA "As Supplied" data sheets, etc.) shall be kept for each chemical and associated products which includes sufficient information to determine usage rates and emissions. These records shall be made available to the Department upon request. Documentation of each chemical reclaimed will use a mass balance method to determine usage/emissions (amount used minus amount collected for disposal or recycle). The log and documents shall be kept at the facility for at least 5 years and made available to the Department. Monthly logs shall be completed by the end of the following month.

[Rule 62-4.070(3), F.A.C.]

#### Permit Application

11. At least sixty days prior to the expiration date of this permit, the permittee shall submit to the **Orange County Environmental Protection Division** this office four air permit applications, DEP Form No. 62-210.900(1), along with the processing fee established in Rule 62-4.050(4), F.A.C.  
[Rule 62-4.090, F.A.C.]

12. If a new or larger steam boiler or emergency generator is to be installed, then the permittee shall submit to the **Orange County Environmental Protection Division** four air construction permit applications, DEP Form No. 62-210.900(1) - Form (effective 02/02/06), or DEP Form No. 62-210.900(3) - Form (effective 2/11/99), along with the processing fee established in Rule 62-4.050(4), F.A.C., and obtain a permit, prior to installation of the new or larger unit.

[Rule 62-4.070(3), F.A.C.]

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION

---

James N. Bradner, P.E.  
Program Administrator  
Air Resources Management

Issued: \_\_\_\_\_