Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

PERMITTEE:

Orlando Utilities Commission (OUC)
P. O. Box 3193
Orlando, Florida 32802

Authorized Representative:
Mr. Jan C. Aspuru, Vice President
Power Resources

DEP File No. 0950137-030-AC
Curtis H. Stanton Energy Center
Stanton Units 1 and 2
SIC No. 4911
Removal of Monthly CO-CEMS Report Requirement
Orange County, Florida

Permit Expires: July 1, 2010

PROJECT AND LOCATION

This permit authorizes the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2 at the OUC Curtis H. Stanton Energy Center. The facility is located at 5100 South Alafaya Trail, Orlando, Orange County. Universal Transverse Mercator (UTM) Coordinates are: Zone 17, 483.50 km East and 3150.60 km North.

This final permit is organized into the following sections: Section 1 (General Information); Section 2 (Administrative Requirements); Section 3 (Emissions Unit Specific Conditions); Section 4 (Appendix CG – General Conditions).

STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of: Chapter 403 of the Florida Statutes (F.S.) and Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to conduct the proposed work in accordance with the conditions of this permit. This project is subject to the general preconstruction review requirements in Rule 62-212.300, F.A.C. and is not subject to the preconstruction review requirements for major stationary sources in Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality.

Upon issuance of this final permit, any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Joseph Kahn, Director
Division of Air Resource Management

4/15/10
(Date)

JK/tlv/jkh/tbc

"More Protection, less Process"
www.dep.state.fl.us

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Final Air Permit Package (including the Final Permit and Final Determination), or a link to these documents available electronically on a publicly accessible server, was sent by electronic mail with received receipt requested to the persons listed below:

Mr. Jan C. Aspuru, Vice President of Power Resources, Orlando Utilities Commission: jaspuru@ouc.com
Ms. Denise M. Stalls, Orlando Utilities Commission: dstalls@ouc.com
Mr. David R. Baez, Orlando Utilities Commission: dbaez@ouc.com
Mr. Scott H. Osbourn, P.E., Golder & Associates: sosbourn@golder.com
Ms. Caroline Shine, DEP - Central District Office: caroline.shine@dep.state.fl.us
Ms. Katy Forney, U.S. EPA Region 4: forney.kathleen@epa.gov
Ms. Ana Oquendo, EPA Region 4: oquendo.ana@epa.gov
Ms. Barbara Friday, DEP - BAR: barbara.friday@dep.state.fl.us (for posting with U.S. EPA, Region 4)
Ms. Victoria Gibson, DEP - BAR: victoria.gibson@dep.state.fl.us (for reading file)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

Barbara J. Friday 4/20/10
(Clerk) (Date)