

**STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION**

NOTICE OF PERMIT REVISION

In the Matter of an
Application for Permit by:

Georgia-Pacific Consumer Operations LLC
P.O. Box 919
Palatka, Florida 32178-0919

Air Permit No. PSD-FL-380(B)
Project No. 1070005-053-AC
Palatka Mill
No. 4 Recovery Boiler, Consumed Air
Project

Authorized Representative:

Mr. Keith Wahoske, Vice President – Palatka Mill Operations

Georgia-Pacific Consumer Operations LLC operates the Palatka Mill in Putnam County located North of CR 216 and West of US 17 in Palatka, Florida. This final air construction permit revision amends the original Permit No. PSD-FL-380 (Project No. 1070005-038-AC) and authorizes the installation of a new automated consumed air control system to improve combustion and efficiency of the No. 4 Recovery Boiler. A copy of this letter shall be filed with the referenced permit and shall become part of the permit. This permit revision is issued pursuant to Chapter 403, Florida Statutes (F.S.).

Any party to this order has the right to seek judicial review of it under Section 120.68, F.S., by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida



Joseph Kahn, Director
Division of Air Resource Management



(Date)

JK/tlv/jfk/bm

PERMIT REVISION

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Permit Revision (including the Final Permit Revision) was sent by electronic mail with received receipt requested to the persons listed below.

Mr. Keith Wahoske, Georgia-Pacific Consumer Operations LLC (keith.wahoske@gapac.com)
Mr. Mike Curtis, Georgia-Pacific Consumer Operations LLC (michael.curtis@gapac.com)
Mr. Mark Aguilar, P.E., Georgia-Pacific Consumer Operations LLC (mjaguila@gapac.com)
Mr. David Buff, P.E., Golder Associates, Inc. (dbuff@golder.com)
Mr. Christopher Kirts, Northeast District Office (christopher.kirts@dep.state.fl.us)
Ms. Kathleen Forney, U.S. EPA, Region 4 (forney.kathleen@epamail.epa.gov)
Mr. Dee Morse, National Park Service (dee_morse@nps.gov)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.



(Clerk)



(Date)

PERMIT REVISION

This permit revision modifies original Permit No. PSD-FL-380 (Project No. 1070005-038-AC).

The following permit condition is revised as follows. Deleted text is marked by ~~striketrough~~ and new text is marked with double underline. All other conditions are unchanged and the affected emissions units remain subject to the applicable requirements.

Section 3. Emissions Unit Specific Conditions. Subsection D. No. 4 Recovery Boiler.

4. No. 4 Recovery Boiler Modifications: The permittee is authorized to perform the following modifications to the No. 4 Recovery Boiler in accordance with the following preliminary schedule: modify the combustion air system; add a fourth level of overfire air (quaternary air); ~~and~~ replace tubes in the superheater, economizer, and walls of the recovery boiler; and install a "Consumed Air" process control system. These changes will not increase the existing permitted capacity of the recovery boiler or the pulp mill. The preliminary schedule is to begin construction in May of 2007. [Application No. 1010005-038-AC; Rules 62-212.300 and 62-212.400 (PSD), F.A.C.; PSD-FL-380; and PSD-FL-380(B)]