

RECEIVED

SEP 05 2000

**ACID MIST AND BERYLLIUM
EMISSION MEASUREMENTS**

STATE OF FLORIDA
DEPT. OF ENV. PROTECTION
NORTHEAST DISTRICT-JAX

KILN/RAW MILL

RECEIVED

SEP 11 2000

FLORIDA ROCK INDUSTRIES
THOMPSON S. BAKER CEMENT PLANT
NEWBERRY, FLORIDA

BUREAU OF AIR REGULATION

PERMIT NO. AC01-267311/PSD-FL-228


JULY 21 AND 24, 2000

KOOGLER & ASSOCIATES
ENVIRONMENTAL SERVICES
4014 NW 13TH STREET
GAINESVILLE, FLORIDA
352-377-5822



KOOGLER & ASSOCIATES
ENVIRONMENTAL SERVICES

To the best of my knowledge, all applicable field and analytical procedures comply with the Florida Department of Environmental Protection requirements and all test data and plant operating data are true and correct.



John B. Koogler, Ph.D., P.E.

State of Florida
Registration No. 12925

2/5/00

Date

TABLE OF CONTENTS

1.0	INTRODUCTION	1
2.0	SAMPLING POINT LOCATIONS	3
3.0	FIELD AND ANALYTICAL PROCEDURES	4
4.0	SUMMARY OF RESULTS	5

APPENDIX



1.0 INTRODUCTION

Florida Rock Industries owns and operates a 2300 ton per day (clinker) dry process precalciner Portland cement plant on CR 235, two miles north of the city center of Newberry, Florida. On July 21 and 24, 2000, Koogler & Associates Environmental Services of Gainesville, Florida, conducted sulfuric acid mist and beryllium emission measurements on the kiln/raw mill stack in accordance with EPA Test Method 8 (40 CFR 60, Appendix A) for acid mist and Test Method 104 (40 CFR 61, Appendix B) for beryllium. The purpose of the testing was to establish emission rates for these two air pollutants as required by Permit AC01-267311/PSD-FL-228.

The Northeast District Office of the Florida Department of Environmental Protection (FDEP) in Jacksonville, the FDEP Northeast District Branch Office in Gainesville and FDEP in Tallahassee, Florida, were notified of the scheduled initial air emission performance tests and testing protocol at the cement plant.

During the acid mist test period, the kiln was operating at a preheater feed rate of 139.8 tons per hour and during the beryllium test period, the kiln was operating at a preheater feed rate of 138.3 tons per hour; both within 10 percent of the permitted feed rate of 149.9 tons per hour. Permit AC01-267311 limits the preheater feed rate to 149.9 tons per hour, which approximately corresponds to a permitted clinker production rate of 95.8 tons per hour.

The permit for the plant limits acid mist and beryllium emissions from the kiln/raw mill to rates established by Best Available Control Technology and specifies that the emission limits for these air pollutants be established based on "future stack tests". The emission measurements reported herein represent the initial emission measurements on the plant for acid mist and beryllium.

The emissions from the kiln/raw mill are controlled by electrostatic precipitators (ESPs). The measured mass emission rate of acid mist from the kiln/raw mill averaged 0.0003 pounds per hour and beryllium emissions averaged 0.06 pounds per hour.

2.0 SAMPLING POINT LOCATIONS

Four sample ports are located in the 112-inch diameter, 241-foot high stack exhausting the kiln/raw mill. The ports are 50.6 feet (5.4 stack diameters) below the top of the stack and 146.8 feet (15.7 diameters) above the point where the kiln/raw mill gases enter the stack. Based on the requirements of EPA Method 1 (40 CFR 60, Appendix A), 12 sample points were selected; three points through each of the four ports.

3.0 FIELD AND ANALYTICAL PROCEDURES

Sulfuric acid mist emission measurements were conducted on the kiln/raw mill stack using EPA Method 8 and beryllium emission measurements were conducted using EPA Method 104. The sampling point locations for the two EPA methods were established in accordance with EPA Method 1. Stack gas velocity measurements and stack gas moisture measurements were made in conjunction with the EPA Method 8 and 104 tests in accordance with EPA Methods 2 and 4. Measurements to determine the dry molecular weight of the stack gas were made in accordance with EPA Method 3. All EPA test methods are described in 40 CFR 60, Appendix A or 40 CFR 61, Appendix B and have been adopted by reference by FDEP by Rule 62-297.401, F.A.C. There were no variations or exceptions to any of the referenced test methods.

4.0 SUMMARY OF RESULTS

The sulfuric acid mist emission measurements made on July 21, 2000, are summarized in Table 1. The acid mist emission rate from the kiln/raw mill ranged from non-detectable to 0.0009 pounds per hour and averaged 0.0003 pounds per hour. The stack gas flow rate from the kiln/raw mill averaged 127,703 standard cubic feet per minute, dry (193,072 acfm). The stack gas temperature averaged 219°F and the moisture content averaged 14.9 percent.

The beryllium emission rate from the kiln/raw mill, measured on July 24, 2000, ranged from 0.01 to 0.12 pounds per hour and averaged 0.06 pounds per hour. These data are summarized in Table 2. The stack gas flow rate from the kiln/raw mill during the beryllium tests averaged 106,903 dry standard cubic feet per minute (165,420 acfm), the stack gas temperature averaged 231°F and the stack gas moisture averaged 16.3 percent.

These emission measurements represent the initial acid mist and beryllium emission measurements on the kiln/raw mill required by Permit AC01-267311. These data will be used by FDEP to establish emission limits for acid mist and beryllium for the kiln/raw mill.

Calculations, field and analytical data sheets, plant operating information, equipment calibration sheets and a list of project participants are included in the Appendix of this report.

TABLE 1
SULFURIC ACID MIST EMISSION TEST DATA

FLORIDA ROCK INDUSTRIES, INC
NEWBERRY, FLORIDA

SOURCE: Kiln/Raw Mill Stack

DATE: July 21, 2000

Run No.	Stack Flow Rate (SCFM)	ACID MIST			
		Conc. (lbs/DSCF)	Emission Rate (Lbs/Hr)	Conc. (mg/DSCF)	Conc. (mg/ACF)
1	124,881	0.00E+00	0.000	0.0000	0.0000
2	126,717	2.88E-09	0.022	0.0013	0.0009
3	131,511	0.00E+00	0.000	0.0000	0.0000
Avg.	127,703	9.59E-10	0.007	0.0004	0.0003

TABLE 2
BERYLLIUM EMISSION TEST DATA

FLORIDA ROCK INDUSTRIES, INC.
NEWBERRY, FLORIDA

SOURCE: Kiln/Raw Mill Stack

DATE: July 24, 2000

Run No.	Process Weight Rate (Tons/hr)	Stack Gas				Conc. (gr/dscf)	Emission Rate (Lbs/Hr)	Total Beryllium
		Flow (SCFMD)	Rate (F)	Temperature (°)	Moisture (%)			
1	135.0	93,275	246	17.0	0.0001	0.06		
2	140.0	98,112	248	16.0	0.0001	0.12		
3	140.0	129,320	200	16.0	0.0000	0.01		
Average	138.3	106,903	231	16.3	0.0001	0.06		

35.31 ft³
m³

1 μg = 1.54 (10)⁻⁵ grain

$$\frac{0.0001 \text{ gr}}{\text{dscf}} \times \frac{1 \mu\text{g}}{1.54 \times 10^{-5} \text{ gr}} = \frac{6.49 \mu\text{g}}{\text{dscf}}$$

$$\frac{6.49 \mu\text{g}}{1 \text{ m}^3 / 35.31 \text{ ft}^3} = \underline{\underline{229.3 \mu\text{g}/\text{m}^3}}$$

APPENDIX

ACID MIST TESTS

CALCULATIONS

SUMMARY OF ACID MIST EMISSION TEST DATA

Florida Rock Industries
Cement Kiln
July 21, 2000

Run No.	Stack Flow Rate (SCFMD)	ACID MIST			
		Conc. (lbs/DSCF)	Emission Rate (Lbs/Hr)	Conc. (mg/DSCF)	Conc. (mg/ACF)
1	124,881	0.00E+00	0.000	0.0000	0.0000
2	126,717	2.88E-09	0.022	0.0013	0.0009
3	131,511	0.00E+00	0.000	0.0000	0.0000
Avg.	127,703	9.59E-10	0.007	0.0004	0.0003

SUMMARY OF SO₂ EMISSION TEST DATA

Florida Rock Industries
Cement Kiln
July 21, 2000

Run No.	Stack Flow Rate (SCFMD)	SO ₂			Emission Rate (lb/hr)	Emission Rate (lb/MMBtu)
		Conc. (ppm)	Conc. at 0% CO ₂ (ppm)	Conc. at 0% O ₂ (ppm)		
1	124,881	0.49			0.61	
2	126,717	0.68			0.86	
3	131,511	0.66			0.87	
Avg.	127,703	0.61			0.78	

GENERAL DATA

DATA FILE NAME: H2SO4

Company : Florida Rock Industries *****
 Source/Unit : Cement Kiln 12:18 PM
 Date : July 21, 2000 Cp : 0.840
 Stack dia. : 112.00 inch OR : Duct Length : 0.00 inch
 Oxygen Corr.: 0.0 percent Duct Width : 0.00 inch
 CO2 Corr. : 0.0 percent Std. Temp. : 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U F Process Wt.

Hydrogen,wt% :	0.00	Run 1 :	135.5 Tons/hr
Carbon, wt% :	0.00	Run 2 :	144
Sulfur, wt% :	0.00	Run 3 :	140
Nitrogen,wt% :	0.00		
Oxygen, wt% :	0.00		
Btu/lb :	0		

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

FIELD DATA	METHOD 5	RUN	RUN	RUN
		1	2	3

Meter Temp., Tm (F)	101	102	101
Stack Temp., Ts (F)	221	219	219
Sq.Rt. dP	0.73	0.74	0.76
dH (in. H2O)	2.44	1.72	1.85
Meter Vol.,Vm (ft3)	56.484	48.731	49.946
Meter Y	0.997	0.997	0.997
Bar. Press.,Pb (in.Hg.)	29.90	29.90	29.90
Vol. H2O, Vlc (ml)	197	168	172
Static Press.,Ps (in.H2O)	-0.25	-0.25	-0.25
Test Time (min.)	60.0	60.0	60.0
Nozzle Dia.,Dn (in.)	0.308	0.278	0.278
Oxygen, O2 (%)	9.7	11.7	11.4
Carbon Dioxide, CO2 (%)	17.6	17.1	16.8
Carbon Monoxide, CO (%)	0.0	0.0	0.0
Report Emission Criteria in ? 1 = lb/hr g = gr/dscf :			L
Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min:			T
Allowable Particulate Matter Emission Rate			

LABORATORY RESULTS	RUN	RUN	RUN
	1	2	3

GRAVIMETRIC ANALYSIS METHOD 5 :

Front Half Wash (FHW) 0.00000 0.00000 0.00000 grams

Filterable Sample (MF) 0.00000 0.00000 0.00000

Condensible Sample (BHW) 0.00000 0.00000 0.00000

----- M E T H O D S 6, 8, & 26 -----
IS FIELD DATA THE SAME AS METHOD 5? (Y=YES, N=NO) Y
Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

FIELD DATA

	RUN 1	RUN 2	RUN 3
Meter Temp., Tm (F)	101	102	101
dH (in. H2O)	2.44	1.72	1.85
Meter Vol.,Vm (ft3)	56.484	48.731	49.946
Meter Y	0.997	0.997	0.997
Bar. Press.,Pb (in.Hg.)	29.90	29.90	29.90
O2 Correction (%)	0.0 %		
CO2 Correction (%)	0.0 %		

SO2 ANALYSIS METHOD 6 OR 8 :

Sample Volume, ml	1000	1000	1000
Sample Aliquot, ml	20	20	20
Volume of Titer, ml	0.33	0.35	0.35
Volume of Titer Blank, ml	0.20	0.20	0.20
Normality of BaCl	0.0097500		

LABORATORY RESULTS (Continued)

ACID MIST ANALYSIS METHOD 8 :

Sample Volume, ml	500	500	500
Sample Aliquot, ml	100	100	100
Volume of Titer, ml	0.20	0.23	0.20
Volume of Titer Blank, ml	0.20	0.20	0.20
Normality of BaCl	0.0097500		

HYDROGEN CHLOIDE (HCl) ANALYSIS METHOD 26 :

Chloride Volume, mg	0.0000	0.0000	0.0000
Hydrogen Chloride (HCl) Volume, mg	0.0000	0.0000	0.0000

A. FIELD DATA SUMMARY

PLANT : Florida Rock Industries
Cement Kiln
DATE : July 21, 2000

	RUN 1	RUN 2	RUN 3
Vlc = Vol water collected in train, ml	197.0	168.0	172.0
Vm = Sample gas vol, meter cond., acf	56.484	48.731	49.946
Y = Meter calibration factor	0.9970	0.9970	0.9970
Pbar = Barometric pressure, in. Hg	29.90	29.90	29.90
Pstatic = Stack static pressure, in. H2O	-0.25	-0.25	-0.25
dH = Avg meter pressure diff, in. H2O	2.44	1.72	1.85
Tm = Absolute meter temp., degrees R	561.0	562.3	561.3
Vm(std) = Sample gas vol, Std. cond., dscf	53.285	45.788	47.028
Bws = Water vapor in gas stream, fraction	0.148	0.147	0.147
MF = Moisture factor (1 - Bws)	0.852	0.853	0.853
CO2 = Carbon Dioxide, dry, volume %	17.60	17.10	16.80
O2 = Oxygen, dry, volume %	9.70	11.70	11.40
N2 = Nitrogen, dry volume %	72.70	71.20	71.80
Md = Molecular weight of stack gas, dry	31.20	31.20	31.14
Ms = Molecular weight of stack gas, wet	29.25	29.26	29.21
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	0.7278	0.7367	0.7632
Ts = Absolute stack temp., degrees R	681.3	679.3	678.5
A = Area of stack, ft2	68.42	68.42	68.42
Qstd = Volumetric flowrate, dscfm	124,881	126,717	131,511
An = Nozzle area, ft2	5.17E-04	4.22E-04	4.22E-04
t = Sample time, minutes	60.00	60.00	60.00
%I = Isokinetic variation, percent	94.04	97.76	96.75

SOURCE TEST CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

RUN NO.: 1
DATE : July 21, 2000

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.25 in. H2O
METER TEMP, Tm =	101 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	221.3 F	STACK I.D. =	112.00 inch
AVG.VEL.HEAD,dP =	0.530 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	2.44 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	56.484 Cu.Ft.	STACK AREA, As =	68.417 Sq.Ft.
METER COFF., Y =	0.997	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	29.90 in.Hg	NOZZLE DIA. =	0.308 inch
COND.(Vlc)	= 197.0 ml	NOZZLE DIA., An =	5.2E-04 Sq.Ft.
GAS ANALYSIS =	9.70 % O2 17.60 % CO2	0.00 % CO 72.70 % N2	

Vm(std) = [(T(std) + 460) / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	53.285 dscf
Vw(std) =(8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	9.273 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.148 Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000
%EA =(%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =	=	102.18
Md =(.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)]	=	31.20
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	29.25
P(stack) = Pbar + (Ps / 13.6)	=	29.88 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))]	=	46.15 ft/sec
Qs = vs x As x 60	=	189,433 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92)	=	124,881 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [Time x P(stack) x An x vs x 60]	=	94.04 %

SOURCE TEST CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

RUN NO.: 2
DATE : July 21, 2000

STD.TEMP, Tstd = 68 F	STATIC PRESS., Ps = -0.25 in. H2O
METER TEMP, Tm = 102.25 F	PITOT COFF., Cp = 0.840
STACK TEMP, Ts = 219.3 F	STACK I.D. = 112.00 inch
Avg.Vel.Head,dP = 0.543 in. H2O	DUCT LENGTH = inch
METER ORIFICE,dH= 1.72 in. H2O	DUCT WIDTH = inch
METER VOL., Vm = 48.731 Cu.Ft.	STACK AREA, As = 68.417 Sq.Ft.
METER COFF., Y = 0.997	TEST TIME = 60.00 min.
BAR. PRESS., Pb = 29.90 in.Hg	NOZZLE DIA. = 0.278 inch
COND.(Vlc) = 168.0 ml	NOZZLE DIA., An = 4.2E-04 Sq.Ft.
 GAS ANALYSIS = 11.70 % O2	0.00 % CO
	17.10 % CO2
	71.20 % N2

Vm(std) = [T(std) + 460 / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	45.788	dscf
Vw(std) =(8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	7.908	scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.147	Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	
%EA =(%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =		164.86	
Md =(.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)]	=	31.20	
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	29.26	
P(stack) = Pbar + (Ps / 13.6)	=	29.88	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))]	=	46.64	ft/sec
Qs = vs x As x 60	=	191,439	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92)	=	126,717	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [Time x P(stack) x An x vs x 60]	=	97.76	%

SOURCE TEST CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

RUN NO.: 3
DATE : July 21, 2000

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.25 in. H2O
METER TEMP, Tm =	101.25 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	218.5 F	STACK I.D. =	112.00 inch
AVG.VEL.HEAD,dP =	0.582 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	1.85 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	49.946 Cu.Ft.	STACK AREA, As =	68.417 Sq.Ft.
METER COFF., Y =	0.997	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	29.90 in.Hg	NOZZLE DIA. =	0.278 inch
COND.(Vlc) =	172.0 ml	NOZZLE DIA., An =	4.2E-04 Sq.Ft.
GAS ANALYSIS =	11.40 % O2	0.00 % CO	
	16.80 % CO2	71.80 % N2	

Vm(std) = [T(std) + 460 / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	47.028 dscf
Vw(std) =(8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	8.096 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.147 Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000
%EA = (%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =	=	150.89
Md = (.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)]	=	31.14
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	29.21
P(stack) = Pbar + (Ps / 13.6)	=	29.88 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))]	=	48.32 ft/sec
Qs = vs x As x 60	=	198,344 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92)	=	131,511 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [Time x P(stack) x An x vs x 60]	=	96.75 %

B. PARTICULATE DATA SUMMARY

PLANT : Florida Rock Industries
Cement Kiln
DATE : July 21, 2000

	RUN 1	RUN 2	RUN 3
Sample Weight (FHW + MF + BHW), mg	0.00	0.00	0.00
Meter Volume, standard cond., Vm(std)	53.285	45.788	47.028
Carbon Dioxide, percent	17.60	17.10	16.80
Oxygen, percent	9.70	11.70	11.40
Sample Concentration :			
gr/scf	0.0000	0.0000	0.0000
gr/dscf	0.0000	0.0000	0.0000
gr/dscf @ 0 % CO ₂	0.0000	0.0000	0.0000
gr/dscf @ 0 % O ₂	0.0000	0.0000	0.0000
ppm * MW (dry gas).....	0.0	0.0	0.0
ppm * MW @ 0% CO ₂	0.0	0.0	0.0
ppm * MW @ 0% O ₂	0.0	0.0	0.0

C. ACID MIST DATA SUMMARY

PLANT : Florida Rock Industries
Cement Kiln
DATE : July 21, 2000

Normality of BaCl₂ : 0.0097500

FILTERABLE ACID MIST :

Sample Volume, ml	500	500	500
Sample Aliquot, ml	100	100	100
Volume of Titer, ml	0.20	0.23	0.20
Volume of Titer Blank, ml	0.20	0.20	0.20

Volume of Acid Mist Meter (dscf) 53.285 45.788 47.028
 $V_m(\text{std}) = [(T(\text{std}) + 460) / 29.92]$
 $\times V_m(\text{SO}_2) \times Y(\text{SO}_2) \times (\text{Pb} + (\text{dH} / 13.6))$
 $/ (T_m + 460)$

Q_s = Volumetric flowrate, acfm 189,433 191,439 198,344

Q_{std} = Volumetric flowrate, dscfm 124,881 126,717 131,511

Total lb Acid Mist 0.00E+00 1.32E-07 0.00E+00
[1.0811E-4 x (V_t - V_{tb}) x N x V_{sol}]
/ Vol(alog)

Total Acid Mist lb/hr 0.00 0.02 0.00
[Acid Mist (lb) / V_m std (ft³)]
x Q_s std x 60

Acid Mist (lb/MMBtu)
[Acid Mist (lb) / V_m std (ft³)] x F-Factor

Acid Mist Concentration lb/dscf 0.00E+00 2.88E-09 0.00E+00
[Acid Mist Concentration (lb) / V_m std (ft³)]

Acid Mist Concentration mg/dscf 0.0000 0.0013 0.0000
[Acid Mist Concentration lb/ft³ * 453,600 mg/lb]

Acid Mist Concentration mg/acf 0.0000 0.0009 0.0000
[Acid Mist Concentration mg/ft³ * Q_s(std) / Q_s]

D. SULFUR DIOXIDE DATA SUMMARY

PLANT : Florida Rock Industries
Cement Kiln
DATE : July 21, 2000

Normality of BaCl₂ 0.0097500

SO₂ ANALYSIS :

Sample Volume, ml	1000	1000	1000
Sample Aliquot, ml	20	20	20
Volume of Titer, ml	0.33	0.35	0.35
Volume of Titer Blank, ml	0.20	0.20	0.20
Volume of SO ₂ Meter	53.285	45.788	47.028
V _m (std) = [(T(std) + 460) / 29.92] x V _m (SO ₂) x Y(SO ₂) x (P _b + (dH / 13.6)) / (T _m + 460)			
Q _{std} = Volumetric flowrate, dscfm	124,881	126,717	131,511
Total lb SO ₂	4.30E-06	5.16E-06	5.16E-06
[7.061E-5 x (V _t - V _{tb}) x N x V _{sol}] / Vol(alog)			
Total SO ₂ lb/hr	0.61	0.86	0.87
[SO ₂ (lb) / V _m std (ft ³)] x Q _s std (ft ³ /min) x 60 (min/hr)			
SO ₂ (lb/MMBtu)			
[SO ₂ (lb) / V _m std (ft ³)] x F (dscf/MMBtu)			
SO ₂ (ppm)	0.49	0.68	0.66
[Mass SO ₂ (lb) x 385 / 64E+6 (ft ³ /lb)] / V _m (std)			
SO ₂ (ppm) @ 0.0 % CO ₂ Corr.			
ppm x 0.0 % Corr. / % CO ₂ in Stack			
SO ₂ (ppm) 0.0% O ₂ Corr.			
ppm x (20.9% - 0.0% O ₂ Corr.) /(20.9% - % O ₂ Stack)			
Heat Input (MMBtu/hr)			
(Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6			
SO ₂ (lb/MMBtu)			
SO ₂ (lb/hr) / Heat Input (MMBtu/hr)			

EMISSION RATE CALCULATIONS

PLANT :Florida Rock Industries
Cement Kiln

STANDARD TEMP. :	68 F	RUN NO.:	1
		DATE :	July 21, 2000
Front Half Wash (FHW)	0.00000 grams	Vm(std)	53.285 ft3
Mass Filter (MF)	0.00000 grams	Vw(std)	9.273 ft3
Back Half Wash (BHW)	0.00000 grams	Qs(std)	124,881 dscfm
Vm(std) SO2	53.285 dscf	Bws	0.148
CO2 CORR	0.0 %	CO2	17.60 %
O2 CORR.	0.0 %	O2	9.70 %
F-FACTOR			
$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (\text{Btu/lb}) \times [(T_{\text{std}} + 460)/528]$	dscf/MMBtu	
FUEL USE			
Use Rate (gal/ton) * Process Wt. (ton/hr)	gal/hr	
Heat Input = (Process Weight (ton/hr) x Heating	MMBtu/hr	
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6			
TOTAL PARTICULATE			
$15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [\text{Vm}(\text{std}) + \text{Vw}(\text{std})]$...	0.0000 gr/scf	
$15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / (\text{Vm}(\text{std})$	0.0000 gr/dscf	
gr/dscf x (12 / %CO2)	0.0000 @ 0% CO2	
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)]	...	0.0000 @ 0% O2	
0.00857 x Qs(std) x gr/dscf	0.00 lb/hr	
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..		lb/MMBtu	
Particulate (lb/hr) / Heat Input (MMBtu/hr)	lb/MMBtu	
TOTAL ACID MIST			
$[1.0811E-4 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)}$	0.00E+00	lb Acid Mist	
[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ...	0.00	lb/hr	
[Acid Mist (lb) / Vm std (ft^3)] x F-Factor		lb/MMBtu	
SULFUR DIOXIDE (SO2)			
$[7.061E-5 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)}$	4.30E-06	lb SO2	
[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60	0.61	lb/hr	
[SO2 (lb) / Vm std (ft^3)] x F		lb/MMBtu	
[Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std)	0.49	ppm	
ppm x 0.0 % Corr. / 17.6 % CO2 in Stack		ppm @ 0% CO2	
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 9.7% O2 Stack)		ppm @ 0% O2	
SO2 (lb/hr / Heat Input)		lb/MMBtu	
HYDROGEN CHLORIDE DATA SUMMARY			
$[\text{Mass HCl(mg)} \times 385 \times 1E6] / [453600 \times 36.5 \times \text{Vm}(\text{std})$		ppm	
ppm x 0.0 % Corr. / 17.6 % CO2 in Stack		ppm @ 0% CO2	
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 17.6% O2 Stack)		ppm @ 0% O2	
[Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)]...		lb/hr	

EMISSION RATE CALCULATIONS

PLANT :Florida Rock Industries
Cement Kiln

STANDARD TEMP. :	68 F	RUN NO.:	2

Front Half Wash (FHW)	0.00000 grams	DATE	July 21, 2000
Mass Filter (MF)	0.00000 grams	Vm(std)	45.788 ft ³
Back Half Wash (BHW)	0.00000 grams	Vw(std)	7.908 ft ³
Vm(std) SO ₂	45.788 dscf	Qs(std)	126,717 dscfm
CO ₂ CORR	0.0 %	BWS	0.147
O ₂ CORR.	0.0 %	CO ₂	17.10 %
		O ₂	11.70 %

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{std} + 460)/528] \dots \dots \dots \text{dscf/MMBtu}$$

FUEL USE

$$\begin{aligned} \text{Use Rate (gal/ton)} * \text{Process Wt. (ton/hr)} &\dots \dots \dots \text{gal/hr} \\ \text{Heat Input} = (\text{Process Weight (ton/hr)} \times \text{Heating}) &\dots \dots \dots \text{MMBtu/hr} \\ \text{Value (Btu/gal)} \times \text{Fuel Use Rate (gal/ton)} / 1E6 & \end{aligned}$$

TOTAL PARTICULATE

$$\begin{aligned} 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [\text{Vm(std)} + \text{Vw(std)}] &\dots \text{0.0000 gr/scf} \\ 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / \text{Vm(std)} &\dots \text{0.0000 gr/dscf} \\ \text{gr/dscf} \times (12 / \% \text{CO}_2) &\dots \text{0.0000 @ 0% CO}_2 \\ \text{gr/dscf} \times [(20.9 - \text{Oxygen corr.}) / (20.9 - \% \text{O}_2)] &\dots \text{0.0000 @ 0% O}_2 \\ 0.00857 \times \text{Qs(std)} \times \text{gr/dscf} &\dots \text{0.00 lb/hr} \\ \text{F-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \% \text{O}_2)] \times \text{gr/dscf} .. &\text{lb/MMBtu} \\ \text{Particulate (lb/hr)} / \text{Heat Input (MMBtu/hr)} &\dots \text{lb/MMBtu} \\ \text{TOTAL ACID MIST} & \end{aligned}$$

$$\begin{aligned} [1.0811E-4 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} &1.32E-07 \text{ lb Acid Mist} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std} \times 60 &\dots \text{0.02 lb/hr} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{F-Factor} &\dots \text{lb/MMBtu} \\ \text{SULFUR DIOXIDE (SO}_2) & \end{aligned}$$

$$\begin{aligned} [7.061E-5 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} &.5.16E-06 \text{ lb SO}_2 \\ [\text{SO}_2 \text{ (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std (ft}^3/\text{min}) \times 60 &\dots \text{0.86 lb/hr} \\ [\text{SO}_2 \text{ (lb)} / \text{Vm std (ft}^3)] \times \text{F} &\dots \text{lb/MMBtu} \\ [\text{Mass SO}_2 \text{ (lb)} \times 385 / 64E+6 \text{ (ft}^3/\text{lb})] / \text{Vm (std)} &\dots \text{0.68 ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 17.6 \% \text{ CO}_2 \text{ in Stack} &\dots \text{ppm @ 0% CO}_2 \\ \text{ppm} \times (20.9\% - 0.0\% \text{ O}_2 \text{ Corr}) / (20.9\% - 17.6\% \text{ O}_2 \text{ Stack}) &\dots \text{ppm @ 0% O}_2 \\ \text{SO}_2 \text{ (lb/hr} / \text{Heat Input}) &\dots \text{lb/MMBtu} \\ \text{HYDROGEN CHLORIDE DATA SUMMARY} & \end{aligned}$$

$$\begin{aligned} [\text{Mass HCl(mg)} \times 385 \times 1E6] / [453600 \times 36.5 \times \text{Vm(std)} &\dots \text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 17.1 \% \text{ CO}_2 \text{ in Stack} &\dots \text{ppm @ 0% CO}_2 \\ \text{ppm} \times (20.9\% - 0.0\% \text{ O}_2 \text{ Corr}) / (20.9\% - 17.1\% \text{ O}_2 \text{ Stack}) &\dots \text{ppm @ 0% O}_2 \\ [\text{Mass HCl(mg)} \times 60 \times \text{Qs} / (\text{Vm(std)} \times 453,600)]... &\text{lb/hr} \end{aligned}$$

EMISSION RATE CALCULATIONS

**PLANT :Florida Rock Industries
Cement Kiln**

STANDARD TEMP. :	68 F	RUN NO.:	3
Front Half Wash (FHW)	0.00000 grams	DATE :	July 21, 2000
Mass Filter (MF)	0.00000 grams	Vm(std)	47.028 ft ³
Back Half Wash (BHW)	0.00000 grams	Vw(std)	8.096 ft ³
Vm(std) SO ₂	47.028 dscf	Qs(std)	131,511 dscfm
CO ₂ CORR	0.0 %	Bws	0.147
O ₂ CORR.	0.0 %	CO ₂	16.80 %
		O ₂	11.40 %
<hr/>			
F-FACTOR			
<hr/>			
10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) - 0.46(%O ₂)] / (Btu/lb) x [(Tstd + 460)/528]			dscf/MMBtu
FUEL USE			
<hr/>			
Use Rate (gal/ton) * Process Wt. (ton/hr)			gal/hr
Heat Input = (Process Weight (ton/hr) x Heating			MMBtu/hr
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6			
TOTAL PARTICULATE			
<hr/>			
15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0000 gr/scf		
15.432 x (FHW + MF + BHW) / (Vm(std)	0.0000 gr/dscf		
gr/dscf x (12 / %CO ₂)	0.0000 @ 0% CO ₂		
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O ₂)] ...	0.0000 @ 0% O ₂		
0.00857 x Qs(std) x gr/dscf	0.00 lb/hr		
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O ₂)] x gr/dscf ..	lb/MMBtu		
Particulate (lb/hr) / Heat Input (MMBtu/hr)	lb/MMBtu		
TOTAL ACID MIST			
<hr/>			
[1.0811E-4 x (Vt - Vtb) x N x Vsol] / Vol(alog) 0.00E+00	lb Acid Mist		
[Acid Mist (lb) / Vm std (ft ³)] x Qs std x 60 ...	0.00 lb/hr		
[Acid Mist (lb) / Vm std (ft ³)] x F-Factor	lb/MMBtu		
SULFUR DIOXIDE (SO₂)			
<hr/>			
[7.061E-5 x (Vt - Vtb) x N x Vsol] / Vol(alog) .5.16E-06	lb SO ₂		
[SO ₂ (lb) / Vm std (ft ³)] x Qs std (ft ³ /min) x 60	0.87 lb/hr		
[SO ₂ (lb) / Vm std (ft ³)] x F	lb/MMBtu		
[Mass SO ₂ (lb) x 385 / 64E+6 (ft ³ /lb)] / Vm (std)	0.66 ppm		
ppm x 0.0 % Corr. / 17.6 % CO ₂ in Stack	ppm @ 0% CO ₂		
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 17.6% O ₂ Stack	ppm @ 0% O ₂		
SO ₂ (lb/hr / Heat Input)	lb/MMBtu		
HYDROGEN CHLORIDE DATA SUMMARY			
<hr/>			
[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std	ppm		
ppm x 0.0 % Corr. / 16.8 % CO ₂ in Stack	ppm @ 0% CO ₂		
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 16.8% O ₂ Stack	ppm @ 0% O ₂		
[Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)]...	lb/hr		

FIELD DATA SHEETS

Plant: FRI - Newberry Cement Plant
 Sample Loc.: Newberry, FL
 Control Type: ESP
 Sample Type: Method 8
 Date: 7/21/00 Run No.: 1
 Time Start: 10:50 Time End: 11:58
 Sample Time: 53 min/port 60 total min.
 Dry Bulb: °F Wet Bulb: °F VP @ DP:
 Bar. Pressure 29.96 Hg Stack Press.: Hg Ps: 0.25 H₂O
 Moisture: 17 % FDA: Gas Density Factor:
 Temperature: 85 °F Wind Dir.: West Wind Speed: 3-5
 Weather: Cloudy Thermocouple Readout: KAK-2
 Sample Box #: M990-1 Meter Box No.: 1A-4
 Meter Y: 0.997 @ Delta H: 1.376 Pitot Corr.: 0.84
 Nozzle Diameter: 0.308 in. Probe Length: 49.65 cm
 Probe Heater Setting: 240-250°f Nomograph Cf: "T.6
 Stack Dimensions : 112" in Umbilical: 200' ft
 Stack Area: ft² Thermocouple
 Effective Stack Area: ft² Probe No.: KAK-38
 Stack Height: 3240' ft Pitot Tube: 1A-50H
 CO₂ = 9.7%
 O₂ = 17.6%

First Imp +78m
 2,3 Imp +89
 Purged for 15 min
 @
 2.45" H₂O
 Stack Dimensions
 Umbilical: 200'
 Thermocouple
 Probe No.: KAK-38
 Pitot Tube: 1A-50H

Material Processing Rate: 350.084 ft³
 Final Gas Meter Reading: 299.600 ft³
 Initial Gas Meter Reading: 264.844 ft³
 Total Metered Gas Volume: 35.446 ft³
 Condensate Gain in Impingers: 167 mL
 Weight Gain in Silica Gel: 3.0 g
 Total Moisture Gain: 1.97 mL
 Silica Gel Container No.: 4
 Filter Number: _____
 Leak Check - Meter Box
 Initial: 0.015 cfm @ 15 in. H₂O
 Final: 0.010 cfm @ 6 in. H₂O
 Leak Check - Pitot Tubes
 Impact 3 H₂O for 15 sec: Stable, Leak
 Static 3 H₂O for 15 sec: Stable, Leak



Test Conducted By: G. Haven, S. Bell
 Stack Test Observers: O₂ = 9.7%
 CO₂ = 17.6%

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft ³)	Stack Velocity Head (H ₂ O)	Meter Orifice Pressure Difference (H ₂ O)	Stack Gas Temperature (°F)	Sample Box Temperature (°F)	Last Impinger Temperature (°F)	Meter Temperature (°F)	Vacuum on Sample Train (Hg)	Oxygen Meter Reading (% O ₂)
Average											
1-1			99.6	0.59	2.71	2.71	215	240	73	98	6
2			304.5	0.58	2.45	2.48	214	241	60	98	6
3			9.3	0.49	2.25	2.25	2142	242	62	98	6
2-1			13.8	0.59	2.71	2.71	214	244	60	98	6
2			16.7	0.57	2.62	2.62	215	244	65	99	6
3			23.6	0.48	2.21	2.21	213	241	66	100	6
3-1			28.3	0.58	2.66	2.66	215	234	63	101	6
2			33.0	0.56	2.58	2.58	219	211	62	101	6

Plant: FBI Cement Kiln
 Sample Loc.: Newberry, FL
 Control Type: ESP
 Sample Type: Method 8
 Date: 7/21/00 Run No.: 2
 Time Start: 2:56 Time End: 19:18
 Sample Time: 5/7/00 min/port 60 total min.
 Dry Bulb: 72°F Wet Bulb: 68°F VP @ DP: 0.25 H₂O
 Bar. Pressure: 29.90 Hg Stack Press.: Hg Ps: 0.25 H₂O
 Moisture: 15% FDA: +/- Gas Density Factor: 1.0
 Temperature: 90°F Wind Dir: West Wind Speed: 2-5
 Weather: Partly Overcast Thermocouple Readout: KAK-2
 Sample Box #: Mon-1 Meter Box No.: KA-4
 Meter Y: 0.997 @ Delta H: 1.376 Pitot Corr.: 0.84
 Nozzle Diameter: 0.278 in. Probe Length: 4 glass
 Probe Heater Setting: 245° Nomograph Cf: 3.14
 Stack Dimensions:
 Stack Area: 112" in²
 Effective Stack Area: ft²
 Stack Height: ≈ 240' ft

Purged
 (5 min)
 (Ac)
 1.72 "H₂O

Material Processing Rate: 420,231 lb/h
 Final Gas Meter Reading: 371,500 lb/h
 Initial Gas Meter Reading: 371,031 lb/h
 Total Metered Gas Volume: 48,731 lb/h
 Condensate Gain in Impingers: 143 mL
 Weight Gain in Silica Gel: 25 g
 Total Moisture Gain: 1.8 mL
 Silica Gel Container No.: 12
 Filter Number:
 Leak Check - Meter Box
 Initial: 0.012 cfm @ 15 in. H₂O
 Final: 0.004 cfm @ 5 in. H₂O
 Leak Check - Pitot Tubes
 Impact 3 H₂O for 15 sec: Stable Leak
 Static 3 H₂O for 15 sec: Stable Leak



Test Conducted By: G. Haven, S. Bell
 Stack Test Observers: CO₂ = 17.1
O₂ = 11.7

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head (H ₂ O)	Meter Orifice Pressure Difference (H ₂ O)	Stack Gas Temperature (°F)	Sample Box Temperature (°F)	Last Impinger Temperature (°F)	Meter Temperature (°F)	Vacuum on Sample Train (in. Hg)	Oxygen Meter Reading (% O ₂)
1-1			71.5	0.63	1.97	1.97	215	248	82	103	5
2			75.8	0.63	1.97	1.97	228	242	56	103	5
3			80.0	0.50	1.57	1.58	217	241	56	102	5
2-1			84.1	0.64	2.0	2.0	218	237	57	102	5
2			88.5	0.60	1.88	1.88	218	244	66	103	5
3			92.7	0.50	1.57	1.57	214	234	62	104	5
3-1			96.7	0.63	1.98	1.98	214	232	64	103	5
2			401.0	0.33	1.04	1.01	214	232	64	103	5

Plant: FRI - Newberry, FL Cement kiln
 Sample Loc.:
 Control Type: ESP
 Sample Type: Metered 8
 Date: 1/21/00 Run No.: 3
 Time Start: 09:50 Time End: 09:50:59
 Sample Time: 3/5/12 min/port 60 total min.
 Dry Bulb: °F Wet Bulb: °F VP @ DP:
 Bar. Pressure 29.90 Hg Stack Press: Hg Ps: 0.25 H2O
 Moisture: 15 % FDA: Gas Density Factor:
 Temperature: 89 °F Wind Dir.: VAR Wind Speed: 8-16
 Weather: Broken Thermocouple Readout: KAK-2
 Sample Box #: 11001 Meter Box No: KA-2
 Meter Y: 0.997 @ Delta H: 1.376 Pilot Corr: 0.84
 Nozzle Diameter: 0.276 in. Probe Length: 4 glass
 Probe Heater Setting: 245°F Nomograph Cf: 3.17
 Stack Dimensions: 112 in
 Stack Area: ft²
 Effective Stack Area: ft²
 Stack Height: ≈ 240' ft

Purged
 15 min @
 1.85 "H2O

Material Processing Rate: 482,852 ft³
 Final Gas Meter Reading: 4329.06 ft³
 Initial Gas Meter Reading: 4329.06 ft³
 Total Metered Gas Volume: 152,952 ft³
 Condensate Gain in Impingers: 148 mL
 Weight Gain in Silica Gel: 27 g
 Total Moisture Gain: 27 mL
 Silica Gel Container No.: 11
 Filter Number:

Leak Check - Meter Box

Initial: 0.011 cfm @ 15 in. H2O
 Final: 0.005 cfm @ 6 in. H2O

Leak Check - Pitot Tubes

Impact 3 H2O for 15 sec: Stable, Leak
 Static 3 H2O for 15 sec: Stable, Leak



Test Conducted By:

Stack Test Observers:

O2 = 11.4
CO2 = 16.8 %

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head (H2O)	Meter Office Pressure Difference (H2O)	Stack Gas Temperature (°F)	Sample Box Temperature (°F)	Last Impinger Temperature (°F)	Meter Temperature (°F)	Vacuum on Sample Train (Hg)	Oxygen Meter Reading (% O2)
Average											
1-1			32.9	0.62	1.96	1.96	262	80	16.98	6	
2			37.4	0.59	1.87	1.87	222	68	199	5	
3			41.5	0.50	1.59	1.59	217	60	100	5	
2-1			45.4	0.66	2.1	2.1	216	738	68	101	6
2			49.7	0.64	2.03	2.03	219	238	62	102	6
3			54.1	0.57	1.65	1.65	216	232	65	102	5
3-1			58.1	0.62	1.97	1.97	219	240	68	102	6
2			62.4	0.63	2.0	2.0	710	777			

SAMPLING RATE CALCULATIONS

Date 7/21/00

Plant Name FLI

Location Hemberry, FL

Source Cement Kiln

- ΔH = Orifice Reading (inches H_2O)
 D_n = Nozzle Diameter (inches)
 ΔH_e = Meter Box Constant
 B_w = Moisture Fraction
 T_m = Meter Temperature ($^{\circ}F$)
 T_s = Stack Temperature ($^{\circ}F$)
 K_s = Wet Molecular Weight of Stack Gas (From Table)
 ΔP = Pitot Reading. (inches H_2O)

$$\frac{T_m + 460}{K_s(T_s + 460)} \cdot (1 - B_w)^2 \cdot \Delta H_e \cdot (D_n)^4 \cdot 17741 \cdot \Delta P = \Delta H$$

Moisture Fraction	K_s
0.0	29.0
0.05	28.5
0.10	27.9
<u>0.15</u>	<u>27.4</u>
0.20	26.8
0.25	26.2
0.30	25.7
0.35	25.2
0.40	24.6

$$\frac{567}{27.2(470)} = \frac{567}{18224} = \frac{560}{27.4(215+460)}$$

	Run 1	Run 2	Run 3
$\frac{T_m + 460}{K_s(T_s + 460)} =$	<u>0.0311</u>	<u>0.0307</u>	<u>0.0300</u>
$\times (1 - B_w)^2 =$	<u>0.6889</u>	<u>0.7225</u>	<u>0.7225</u>
$\times \Delta H_e =$	<u>1.376</u>	<u>1.376</u>	<u>1.376</u>
$\times (D_n)^4 =$	<u>0.0027</u> <u>0.0088</u>	<u>0.0027</u> <u>0.0058</u>	<u>0.0060</u>
$\times 17741 =$	<u>17741</u>	<u>17741</u>	
$\times \Delta P =$			

1.41 4.6 1.46 3.14 3.17

X 0.75

0.8 1.376

0.8



LABORATORY DATA SHEETS

Acid Mist

~~SO₂~~
LAB DATA

Plant Name Florida Rock Industries Date Analyzed 7/28/00
 Analyzed By G.Haven

Stack	Sample No.	V.T.	V.T.B.	N.	V.Soln.	V.A.
Cement Kiln	Run 1-1	0.2	0.2	0.00975	500	100
	1-2	0.2	0.2		1	1
	2-1	0.2	0.2		1	1
	2-2	0.25	0.2		1	1
	3-1	0.2	0.2		1	1
	3-2	0.2	0.2		1	1
IPA BLANK	1 2	0.1 0.1	0.2			
H ₂ O ₂ Blank	1 2	0.1 0.1			100	100
		1				

- V.T. = Volume of Barium perchlorate titrant used for sample (ml)
 V.T.B. = Volume of Barium perchlorate titrant used for blank (ml)
 N. = Normality of Barium perchlorate.
 V.Soln. = Total solution volume
 V.A. = Volume of sample aliquot titrated (ml)



SO_2
LAB DATA

Plant Name Florida Rock Ind. Date Analyzed 7/28/00
 Analyzed By G. Haven

Stack	Sample No.	V.T.	V.T.B.	N.	V.Soln.	V.A.
Cement Kiln	Run 1-1	0.3	0.2	0.00975	1000	20
	1-2	0.35	0.2			
	Run 2-1	0.35	0.2			20 0.35
	Run 2-2	0.35	0.2			20 0.35
	Run 3-1	0.4	0.2			20
	3-2	0.3	0.2			20
Blank	H_2O_2	1 2	0.1 0.1		↓	100
Blank	IPA	1 2	0.1 0.1			100
				↓		

- V.T. = Volume of Barium perchlorate titrant used for sample (ml)
 V.T.B. = Volume of Barium perchlorate titrant used for blank (ml)
 N. = Normality of Barium perchlorate.
 V.Soln. = Total solution volume
 V.A. = Volume of sample aliquot titrated (ml)



CHAIN OF CUSTODY RECORD

Project Number _____
 Project Name Florida Rock Industries
 Sample Location Cement Kiln
Newberry, Fl

Sample Identification	Remarks
<u>FHRI</u>	<u>Front half train Run#1</u>
<u>FHR2</u>	<u>" " " "</u> #2
<u>FHR3</u>	<u>" " " "</u> #3
<u>BHRI</u>	<u>Back Half train Run#1</u>
<u>BHR2</u>	<u>" " " "</u> #2
<u>BHR3</u>	<u>" " " "</u> #3
<u>SG# 4</u>	<u>Silica Gel # 4</u>
<u>SG# 12</u>	<u>" " # 12</u>
<u>SG# 11</u>	<u>" " # 11</u>

Sampled By: (Signature) John A. Olsen Date: 7/21/00 Time: see DATA SHEETS

Relinquished By: (Sign) _____ Date: _____ Time: _____

Received By: (Sign) _____ Date: _____ Time: _____

Relinquished By: (Sign) _____ Date: _____ Time: _____

Received By: (Sign) _____ Date: _____ Time: _____

Relinquished By: (Sign) _____ Date: _____ Time: _____

Received By Lab: (Sign) John A. Olsen Date: 7/21/00 Time: 23:00

Sample Shipped VIA: UPS Fed Express Bus

Shipping Bill Number: _____



PLANT OPERATING DATA

INFORMATION REQUIRED IN
GENERAL STACK TEST REPORTS

Permit Number ACO1 - 267311

Source I.D. # —

Permit Expiration Date —

Permit Conditions:

Production Rate 149.9 139.83

Emission Limits (PM, SO₂, VE, etc.) —

Fuel Limits (Sulfur, etc.) —

Test Conducted (P.M., VE, SO₂, NOx, etc.) Acid mist

Actual Production Rate 139.83

Measured Emission Rates 0.78 lb/hr SO₂, 0.007 lb/hr H₂SO₄ mist

List of Measured Parameters as Required by Permit

Scrubber ΔP —

Scrubber Water Flow —

Scrubber Water Pressure —

Baghouse ΔP —

Baghouse Inlet Temperature —

*Type of Fuel Coal

Fuel Use Rate —

*Fuel Analysis —

Name of DEP Observer L. Lalwani

Date of Last Inspection Performed by Plant Personnel —

Discussion of any Problems (non-isokinetic, missing runs, plant upset, etc.)
—
—
—



KOOGLER & ASSOCIATES

Florida Rock Industries, Inc.
Cement Group
Thompson S. Baker Cement plant

Process Weight Rate Sheet

Source: Kiln/Raw Mill Stack

Test Date: July 21, 2000

Permit No.: AC01-267311


Permitted Rate: 149.9 TPH

Test Parameter(s): Sulfuric Acid Mist (H₂SO₄) & Sulfur Dioxide (SO₂)

	<u>Run Times</u>	<u>Process Input Rate</u>
Run No. 1	<u>1050</u> - <u>1158</u>	<u>135.5</u> TPH
Run No. 2	<u>1250</u> - <u>1918</u>	<u>144</u> TPH
Run No. 3	<u>1950</u> - <u>2059</u>	<u>140</u> TPH

I here by certify that to the best of my knowledge the above data is true and correct.

George Townsend
Name (Print)


Signature

July 31, 2000
Date

Environmental & Safety Manager
Title

EQUIPMENT CALIBRATIONS

NOZZLE CALIBRATION


DATE 7/21/00
PLANT NAME ERI
LOCATION Newberry, FL
SOURCE Cement Kiln

<u>Measurement No.</u>	<u>Inside Diameter (inches)</u>
1	<u>0.308</u> 0.227
2	<u>0.308</u> 0.227
3	<u>0.308</u> 0.227

Average
Area of Nozzle

0.308

calibrated by:



Nozzle X-Section



NOZZLE CALIBRATION

DATE 7/21/00

PLANT NAME ERI

LOCATION Newberry FL

SOURCE Cement Kiln

Measurement No.

Inside Diameter (inches)

1

0.277

2

0.278

3

0.279

Average


0.278

Area of Nozzle

ft²

Calibrated by:

J. A. H.



Nozzle X-Section



PITOT TUBE CALIBRATION MEASUREMENTS

PITOT TUBE IDENTIFICATION NO. KA-55II

DATE CALIBRATED 7-5-00

PITOT TUBE ASSEMBLY LEVEL ? YES NO

PITOT TUBE OPENINGS DAMAGED ? YES (EXPLAIN BELOW) NO

$$\alpha_1 = 1.5^\circ \quad (< 10^\circ) \quad \alpha_2 = 1.5^\circ \quad (< 10^\circ)$$

$$\beta_1 = 2.5^\circ \quad (< 5^\circ) \quad \beta_2 = 2.0^\circ \quad (< 5^\circ)$$

$$Y = 1.5^\circ, \theta = 2.0^\circ, A = 0.948 \text{ IN.} = (P_A + P_B)$$

$$Z = A \sin Y = 0.0248 \text{ IN.} \quad (< 0.125 \text{ IN.})$$

$$W = A \sin \theta = 0.0331 \text{ IN.} \quad (< 0.031 \text{ IN.})$$

$$P_A = 0.464 \text{ IN.} \quad P_B = 0.466 \text{ IN.}$$

$$D_f = 0.377 \text{ IN.} \quad (\geq 0.1875 \text{ IN.} \leq 0.3750 \text{ IN.})$$

COMMENTS: Pitot tube looked ok. day after test.

John H. G.

CALIBRATION REQUIRED? YES NO

CALIBRATED BY: R. Paul

PTCM FORM 1/8/87

POST TEST THERMOCOUPLE
CALIBRATION

DATE 8/8 7/21/00

PLANT NAME Florida Rock Industries

LOCATION Newberry, FL

SOURCE Cement Kiln

Thermocouple Readout # KAK-2

Umbilical Cord # 200'

Switch Box # KAK-2

Thermocouple # KAK-38

Average Stack Temperature °F 220°


*Observed Mercury in Glass (ASTM) °F 215

Observed Thermocouple Reading °F 217

$$\text{Percent Difference } \frac{675 - 677}{(675 - 460)} \times 100 = -0.296\%$$

Tolerance $\leq 1.5\%$

- * Observed Temperature must be within ten percent of the average stack temperature.


Signature



KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
ANNUAL THERMOCOUPLE CALIBRATION

12/27/99

Page 1 of 3

KA70 RO/UMB		ICE (F)	ASTM (F)	AMB. (F)	ASTM (F)	212 (F)	ASTM (F)	400 (F)	ASTM (F)	KA70 RO/UMB
KA1/100'	STACK	32	33	73	72	208	209	405	406	KA1/100'
	BOX	33	32	72	72	210	210	404	406	BOX
	IMP	32	32	73	73	211	212	400	401	IMP
KA2/200'	STACK	33	33	73	72	209	210	415	416	KA2/200'
	BOX	32	32	72	73	211	210	418	418	BOX
	IMP	32	33	71	72	212	212	409	410	IMP
KA3/25'	STACK	32	33	73	73	211	210	409	410	KA3/25'
SWBXKA3	BOX	33	32	72	73	215	215	415	416	BOX
	IMP	33	32	72	73	212	212	408	407	IMP
KA4/25'	STACK	32	32	73	74	205	205	420	420	KA4/25'
SWBXKA3	BOX	32	33	74	74	207	208	422	421	BOX
	IMP	32	33	72	73	211	212	425	425	IMP
KAK/200K	STACK	31	32	74	74	213	213	419	420	KAK/200K
KAK-38	BOX	32	32	72	73	215	216	422	422	KAK-38
SWBXKAK1	IMP	32	33	74	73	219	220	400	401	BOX
	IMP	32	33	74	73	219	220	400	401	IMP
KA1/200'	STACK	33	33	73	73	211	210	422	422	KA1/200'
	BOX	33	33	73	72	214	214	419	418	BOX
	IMP	33	32	73	72	209	209	425	425	IMP
KA2/100'	STACK	33	33	73	72	209	210	422	423	KA2/100'
	BOX	33	32	73	74	212	211	425	425	BOX
	IMP	32	33	72	73	212	211	426	425	IMP

Signature

Date 12/27/99

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
ANNUAL THERMOCOUPLE CALIBRATION

12/27/99

Page 2 of 3

THERMOCOUPLE #	ICE (F)	ASTM (F)	AMB. (F)	ASTM (F)	212 (F)	ASTM (F)	400 (F)	ASTM (F)	THERMOCOUPLE #
KA-06	33	33	73	74	212	212	420	419	KA-06
KA-07	33	32	74	75	209	210	421	422	KA-07
KA-08	34	33	74	74	211	211	415	416	KA-08
KA-09	33	33	74	74	215	216	416	417	KA-09
KA-10	34	33	72	72	214	215	408	407	KA-10
KA-11	33	33	72	72	212	212	415	414	KA-11
KA-12	33	33	73	72	219	220	408	407	KA-12
KA-38	34	33	73	74	211	211	412	411	KA-38
KA-39	34	33	73	73	212	211	416	415	KA-39
KA-50	33	34	74	73	215	214	415	416	KA-50
KA-64	33	33	74	74	211	211	410	411	KA-64
KA-70	33	33	73	74	212	213	405	406	KA-70
KA-71	34	34	73	73	211	210	407	408	KA-71
KA-72	34	33	72	72	216	215	410	410	KA-72
KA-105	34	33	73	73	217	218	404	405	KA-105
KA-108	34	34	72	73	214	215	412	411	KA-108
KA-115	34	33	72	72	213	214	409	410	KA-115
KA-126	34	33	72	72	216	216	410	409	KA-126

THERMOCOUPLE #	ICE (F)	ASTM (F)	AMB. (F)	ASTM (F)	212 (F)	ASTM (F)	400 (F)	ASTM (F)	THERMOCOUPLE #
KAK-08	32	32	73	74	218	217	407	406	KAK-08
KAK-09	31	31	73	73	211	212	405	406	KAK-09
KAK-10	32	32	74	74	209	210	377	376	KAK-10
KAK-11	31	31	75	75	206	206	399	398	KAK-11
KAK-12	32	31	74	74	218	217	407	406	KAK-12
KAK-38	31	31	74	74	210	211	410	410	KAK-38
KAK-65	32	32	74	74	205	205	377	377	KAK-65
KAK-72	31	31	74	75	208	208	400	401	KAK-72
KAK-110	31	32	75	74	209	210	399	400	KAK-110
KAK-07	32	31	75	74	209	210	389	390	KAK-07

VOST SWITCH BOX T.COUPLER

CH#1	C-1	32	33	74	75
CH#2	C-1	33	32	74	74
CH#3	C-1	33	33	75	74

VOST SWITCH BOX

CH#1	C-2	32	33	73	74
CH#2	C-2	33	33	74	75
CH#3	C-2	32	33	75	75

Signature Stacy J. Bee
Date 12/27/99

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
 ANNUAL THERMOCOUPLE CALIBRATION

12/27/99

Page 3 of 3

Range (°C)	Measured Voltage (mV)	Measured Voltage (V)	Calc. Temp. (°C)	Readout Temp. (°C)	Percent Difference (%)
KAK-12	28.7	0.029	690	693	-0.45023
	37.4	0.037	902	900	0.217654
KAK-38	28.9	0.029	694	698	-0.51192
	37.2	0.037	897	900	-0.33898
KAK-72	28.5	0.029	685	687	-0.30387
	37.5	0.038	904	908	-0.39058
KAK-65	28.2	0.028	678	680	-0.32666
	37.8	0.038	912	910	0.218082
KA-110	29	0.029	694	699	-0.65592
	37	0.037	894	899	-0.50758

EQUATIONS :

$$T \text{ (calc.)} = (0.226584602 + (24152.109 * V) + (67233.4248 * V^2) + (2210340.682 * V^3) - (860963914.9 * V^4) + (48350600000 * V^5) - (1184520000000 * V^6) + (13869000000000 * V^7) - (63370800000000 * V^8))$$

Where :

V = Measured Voltage (Volts)

T(calc.) = Temperature calculated based on voltage

Signature

Date

BERYLLIUM TESTS

POST-TEST DRY GAS METER CALIBRATION FORM

COMPANY: Florida Rock Industries
SOURCE: Cement Kiln
DATE: August 9, 2000
PRETEST Y: 0.997
TEST METER NUMBER: KA-1
METER BOX NUMBER: KA-4
BAROMETRIC PRESSURE (Pb): 30.01
DELTA H (dH): 2

	TEST METER READING (ft ³)	DRY GAS READING (ft ³)	TIME (min)	VACUUM SETTING (in. Hg)
INITIAL	304.563	321.225		
FIRST	310.023	326.635	6.1	6
SECOND	319.263	335.835	10.3	6
THIRD	328.421	345.017	10.2	6

DELTA H 2	TEST METER Vt (ft ³)	DRY GAS Vd (ft ³)	TEST METER TEMP. Tt (F)	DRY GAS TEMP. Td (F)
PB	5.460	5.410	77.5	81.5
30.01	9.240	9.200	77.5	84.5
	9.158	9.182	77	87

$$Y_i = \frac{Vt * Pb * (Td + 460)}{Vd * (Pb + dH / 13.6) * (Tt + 460)}$$

RUN 1 (Yi) =	1.011794	88727.26 / 87692.95
RUN 2 (Yi) =	1.012466	150985.7 / 149126.6
RUN 3 (Yi) =	1.011005	150332.8 / 148696.4

$$\text{AVG. } Y = 1.011755$$

PRETEST Y = 0.997
 AVG. DELTA Y = 0.014755
 DELTA Y LIMIT = ± 0.05
 IS TEST WITHIN 5%? YES

Vt = Gas volume passing through the test meter, ft³
Vd = Gas volume passing through the dry gas meter, ft³
Tt = Temperature of the gas in the test meter, |F
Tdi = Temperature of the inlet gas of the dry gas meter, |F
Tdo = Temperature of the outlet gas of the dry gas meter, |F
Td = Average temperature of the gas in the dry gas meter,
 the average of Tdi and Tdo, |F
dH = Pressure difference across the orifice, in, H₂O
Yi = Ratio of test meter to dry gas meter for each run
Y = Average ratio of accuracy of test meter to dry gas meter
 for all three runs, tolerance = pretest • 0.05*Y
Δ = Time of calibration run, min
Pb = Barometric pressure, in Hg.

DRY GAS METER AND ORIFICE CALIBRATION

CONTROL BOX NO.	KA-4	BAROMETRIC PRESS.	30.39	IN. HG.
DATE	FEB. 22, 2000	PERFORMED BY	ROC	

	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5
VACUUM ("Hg)	0.0	0.0	0.0	0.0	0.0
dHw ("H2O)	-0.28	-0.30	-0.33	-0.37	-0.43
dHd ("H2O)	0.50	1.00	1.50	2.50	3.50
INITIAL WTM	3.036	28.727	994.704	20.046	9.754
FINAL WTM	9.754	34.540	1003.036	28.727	20.046
INITIAL DGM	103.007	129.171	94.618	120.249	109.760
FINAL DGM	109.760	135.141	103.007	129.171	120.249
TEMP. WTM (F)	68.00	69.00	68.00	69.00	68.00
TEMP. DGM (F)	76.00	80.00	75.00	80.00	78.00
TEST TIME (MIN.)	14.50	9.00	11.00	9.00	9.00

NET VOLUME WTM	6.718	5.813	8.332	8.681	10.292
NET VOLUME DGM	6.753	5.970	8.389	8.922	10.489
Y	1.009	0.992	1.004	0.988	0.992
dHe	1.264	1.296	1.421	1.453	1.447

AVERAGE Y =	0.997				
ACCEPTABLE Y RANGE = 0.980 TO 1.020	OK				
AVERAGE dHe =	1.376				
Y = (Vw (Pb - (dHw / 13.6)) x (Td + 460)) / (Vd (Pb + (dHd / 13.6)) x (Tw + 460))					
dHe = 0.0317 x dHd / (Pb (Td + 460)) x ((Tw + 460) x time) / Vw)^2					

CALCULATIONS

SUMMARY OF SOURCE EMISSION TEST DATA

Florida Rock Industries
Cement Kiln
July 24, 2000

Run No.	Process Weight Rate (Tons/hr)	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)	Total Beryllium Conc. (gr/dscf)	Emission Rate (Lbs/Hr)
1	135.0	93,275	246	17.0	0.0001	0.06
2	140.0	98,112	248	16.0	0.0001	0.12
3	140.0	129,320	200	16.0	0.0000	0.01
Average	138.3	106,903	231	16.3	0.0001	0.06

GENERAL DATA

DATA FILE NAME: BERYLM

Company : Florida Rock Industries *****
 Source/Unit : Cement Kiln 11:10 AM
 Date : July 24, 2000 Cp : 0.840
 Stack dia. : 112.00 inch OR : Duct Length : 0.00 inch
 Oxygen Corr.: 0.0 percent Duct Width : 0.00 inch
 CO2 Corr. : 0.0 percent Std. Temp. : 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U F Process Wt.

Hydrogen,wt% : 0.00 Run 1 : 135 Tons/hr
 Carbon, wt% : 0.00 Run 2 : 140
 Sulfur, wt% : 0.00 Run 3 : 140
 Nitrogen,wt% : 0.00
 Oxygen, wt% : 0.00
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1
 F-Factor : dscf/MMBtu;

FIELD DATA ----- METHOD 5 RUN RUN RUN
 ----- 1 2 3

Meter Temp., Tm (F)	94	98	98
Stack Temp., Ts (F)	246	248	200
Sq.Rt. dP	0.57	0.60	0.74
dH (in. H2O)	1.04	1.13	1.73
Meter Vol.,Vm (ft3)	75.612	77.352	96.896
Meter Y	0.997	0.997	0.997
Bar. Press.,Pb (in.Hg.)	30.13	30.13	30.13
Vol. H2O, Vlc (ml)	315	299	374
Static Press.,Ps (in.H2O)	-0.24	-0.24	-0.24
Test Time (min.)	120.0	120.0	120.0
Nozzle Dia.,Dn (in.)	0.280	0.280	0.280
Oxygen, O2 (%)	8.5	7.8	9.8
Carbon Dioxide, CO2 (%)	22.4	24.1	15.0
Carbon Monoxide, CO (%)	0.0	0.0	0.0
Report Emission Criteria in ? 1 = lb/hr g = gr/dscf :			L
Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min:			T
Allowable Particulate Matter Emission Rate			

LABORATORY RESULTS RUN RUN RUN
 ----- 1 2 3

GRAVIMETRIC ANALYSIS METHOD 5 :

Front Half Wash (FHW) 0.00036 0.00066 0.00005 grams
 Filterable Sample (MF) 0.00000 0.00000 0.00000
 Condensible Sample (BHW) 0.00000 0.00000 0.00000

SOURCE TEST CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

RUN NO.: 1
DATE : July 24, 2000

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.24 in. H2O
METER TEMP, Tm =	93.5 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	246.3 F	STACK I.D. =	112.00 inch
Avg.Vel.Head,dP =	0.323 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	1.04 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	75.612 Cu.Ft.	STACK AREA, As =	68.417 Sq.Ft.
METER COFF., Y =	0.997	TEST TIME =	120.00 min.
BAR. PRESS., Pb =	30.13 in.Hg	NOZZLE DIA. =	0.280 inch
COND.(Vlc)	315.0 ml	NOZZLE DIA., An =	4.3E-04 Sq.Ft.
GAS ANALYSIS =	8.50 % O2 22.40 % CO2	0.00 % CO 69.10 % N2	

Vm(std) = [(T(std) + 460) / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	72.600 dscf
Vw(std) =(8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	14.827 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.170 Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000
%EA =(%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =	=	87.25
Md =(.44 x %CO2)+(.32 x %O2)+(.28 x (%N2 + %CO))	=	31.92
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	29.56
P(stack) = Pbar + (Ps / 13.6)	=	30.11 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))]	=	36.37 ft/sec
Qs = vs x As x 60	=	149,303 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92)	=	93,275 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [Time x P(stack) x An x vs x 60]	=	103.79 %

SOURCE TEST CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

RUN NO.: 2
DATE : July 24, 2000

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.24 in. H2O
METER TEMP, Tm =	98.33 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	247.8 F	STACK I.D. =	112.00 inch
AVG.VEL.HEAD,dP =	0.355 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	1.13 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	77.352 Cu.Ft.	STACK AREA, As =	68.417 Sq.Ft.
METER COFF., Y =	0.997	TEST TIME =	120.00 min.
BAR. PRESS., Pb =	30.13 in.Hg	NOZZLE DIA. =	0.280 inch
COND.(Vlc)	= 299.0 ml	NOZZLE DIA., An =	4.3E-04 Sq.Ft.
GAS ANALYSIS =	7.80 % O2 24.10 % CO2	0.00 % CO 68.10 % N2	

Vm(std) = [T(std) + 460 / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	73.644	dscf
Vw(std) =(8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	14.074	scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.160	Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	1.000	
%EA =(%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =	=	76.63	
Md =(.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)]	=	32.17	
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	29.89	
P(stack) = Pbar + (Ps / 13.6)	=	30.11	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))]	=	37.92	ft/sec
Qs = vs x As x 60	=	155,646	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92)	=	98,112	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [Time x P(stack) x An x vs x 60]	=	100.09	%

SOURCE TEST CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

RUN NO.: 3
DATE : July 24, 2000

STD.TEMP, Tstd = 68 F	STATIC PRESS., Ps = -0.24 in. H2O
METER TEMP, Tm = 98.17 F	PITOT COFF., Cp = 0.840
STACK TEMP, Ts = 200.3 F	STACK I.D. = 112.00 inch
Avg.Vel.Head, dP = 0.552 in. H2O	DUCT LENGTH = inch
METER ORIFICE, dH = 1.73 in. H2O	DUCT WIDTH = inch
METER VOL., Vm = 96.896 Cu.Ft.	STACK AREA, As = 68.417 Sq.Ft.
METER COFF., Y = 0.997	TEST TIME = 120.00 min.
BAR. PRESS., Pb = 30.13 in.Hg	NOZZLE DIA. = 0.280 inch
COND.(Vlc) = 374.0 ml	NOZZLE DIA., An = 4.3E-04 Sq.Ft.
 GAS ANALYSIS = 9.80 % O2	0.00 % CO
15.00 % CO2	75.20 % N2

Vm(std) = [T(std) + 460 / 29.92] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	92.414	dscf
Vw(std) =(8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	17.604	scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.160	Lower Bws value used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)	=	0.779	
%EA = (%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =		97.49	
Md = (.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)]	=	30.79	
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	28.75	
P(stack) = Pbar + (Ps / 13.6)	=	30.11	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))]	=	46.60	ft/sec
Qs = vs x As x 60	=	191,311	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92)	=	129,320	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [Time x P(stack) x An x vs x 60]	=	95.29	%

A. FIELD DATA SUMMARY

PLANT : Florida Rock Industries
Cement Kiln
DATE : July 24, 2000

	RUN	RUN	RUN
	1	2	3
Vlc = Vol water collected in train, ml	315.0	299.0	374.0
Vm = Sample gas vol, meter cond., acf	75.612	77.352	96.896
Y = Meter calibration factor	0.9970	0.9970	0.9970
Pbar = Barometric pressure, in. Hg	30.13	30.13	30.13
Pstatic = Stack static pressure, in. H2O	-0.24	-0.24	-0.24
dH = Avg meter pressure diff, in. H2O	1.04	1.13	1.73
Tm = Absolute meter temp., degrees R	553.5	558.3	558.2
Vm(std) = Sample gas vol, Std. cond., dscf	72.600	73.644	92.414
Bws = Water vapor in gas stream, fraction	0.170	0.160	0.160
MF = Moisture factor (1 - Bws)	0.830	0.840	0.840
CO2 = Carbon Dioxide, dry, volume %	22.40	24.10	15.00
O2 = Oxygen, dry, volume %	8.50	7.80	9.80
N2 = Nitrogen, dry volume %	69.10	68.10	75.20
Md = Molecular weight of stack gas, dry	31.92	32.17	30.79
Ms = Molecular weight of stack gas, wet	29.56	29.89	28.75
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	0.5686	0.5955	0.7430
Ts = Absolute stack temp., degrees R	706.3	707.8	660.3
A = Area of stack, ft2	68.42	68.42	68.42
Qstd = Volumetric flowrate, dscfm	93,275	98,112	129,320
An = Nozzle area, ft2	4.28E-04	4.28E-04	4.28E-04
t = Sample time, minutes	120.00	120.00	120.00
%I = Isokinetic variation, percent	103.79	100.09	95.29

B. PARTICULATE DATA SUMMARY

PLANT : Florida Rock Industries
Cement Kiln
DATE : July 24, 2000

	RUN 1	RUN 2	RUN 3
Sample Weight (FHW + MF + BHW), mg	0.36	0.66	0.05
Meter Volume, standard cond., Vm(std)	72.600	73.644	92.414
Carbon Dioxide, percent	22.40	24.10	15.00
Oxygen, percent	8.50	7.80	9.80
Sample Concentration :			
gr/scf	0.0001	0.0001	0.0000
gr/dscf	0.0001	0.0001	0.0000
gr/dscf @ 0 % CO ₂	0.0000	0.0001	0.0000
gr/dscf @ 0 % O ₂	0.0001	0.0002	0.0000
ppm * MW (dry gas).....	4.2	7.6	0.4
ppm * MW @ 0% CO ₂	0.0	0.0	0.0
ppm * MW @ 0% O ₂	7.1	12.1	0.8

EMISSION RATE CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

STANDARD TEMP. :	68 F	RUN NO.:	1
		DATE :	July 24, 2000
Front Half Wash (FHW)	0.00036 grams	Vm(std)	72.600 ft ³
Mass Filter (MF)	0.00000 grams	Vw(std)	14.827 ft ³
Back Half Wash (BHW)	0.00000 grams	Qs(std)	93,275 dscfm
Vm(std) SO ₂	dscf	Bws	0.170
CO ₂ CORR	0.0 %	CO ₂	22.40 %
O ₂ CORR.	0.0 %	O ₂	8.50 %
F-FACTOR			

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) - 0.46(%O ₂)] / (Btu/lb) x [(Tstd + 460)/528]			dscf/MMBtu
FUEL USE			

Use Rate (gal/ton) * Process Wt. (ton/hr)			gal/hr
Heat Input = (Process Weight (ton/hr) x Heating			MMBtu/hr
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6			
TOTAL PARTICULATE			

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0001	gr/scf	
15.432 x (FHW + MF + BHW) / (Vm(std)	0.0001	gr/dscf	
gr/dscf x (12 / %CO ₂)	0.0000	@ 0% CO ₂	
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O ₂)] ...	0.0001	@ 0% O ₂	
0.00857 x Qs(std) x gr/dscf	0.06	lb/hr	
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O ₂)] x gr/dscf ..		lb/MMBtu	
Particulate (lb/hr) / Heat Input (MMBtu/hr)		lb/MMBtu	
TOTAL ACID MIST			

[1.0811E-4 x (Vt - Vtb) x N x Vsol] / Vol(alog)			lb Acid Mist
[Acid Mist (lb) / Vm std (ft ³)] x Qs std x 60 ...			lb/hr
[Acid Mist (lb) / Vm std (ft ³)] x F-Factor			lb/MMBtu
SULFUR DIOXIDE (SO ₂)			

[7.061E-5 x (Vt - Vtb) x N x Vsol] / Vol(alog)			lb SO ₂
[SO ₂ (lb) / Vm std (ft ³)] x Qs std (ft ³ /min) x 60			lb/hr
[SO ₂ (lb) / Vm std (ft ³)] x F			lb/MMBtu
[Mass SO ₂ (lb) x 385 / 64E+6 (ft ³ /lb)] / Vm (std)			ppm
ppm x 0.0 % Corr. / 22.4 % CO ₂ in Stack			ppm @ 0% CO ₂
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 8.5% O ₂ Stack)			ppm @ 0% O ₂
SO ₂ (lb/hr / Heat Input)			lb/MMBtu
HYDROGEN CHLORIDE DATA SUMMARY			

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std			ppm
ppm x 0.0 % Corr. / 22.4 % CO ₂ in Stack			ppm @ 0% CO ₂
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 22.4% O ₂ Stack)			ppm @ 0% O ₂
[Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)]...			lb/hr

EMISSION RATE CALCULATIONS

PLANT :Florida Rock Industries
Cement Kiln

STANDARD TEMP. :	68 F	RUN NO.:	2
		DATE :	July 24, 2000

Front Half Wash (FHW)	0.00066 grams	Vm(std)	73.644 ft ³
Mass Filter (MF)	0.00000 grams	Vw(std)	14.074 ft ³
Back Half Wash (BHW)	0.00000 grams	Qs(std)	98,112 dscfm
Vm(std) SO ₂	dscf	Bws	0.160
CO ₂ CORR	0.0 %	CO ₂	24.10 %
O ₂ CORR.	0.0 %	O ₂	7.80 %

F-FACTOR			

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) - 0.46(%O ₂)] / (Btu/lb) x [(Tstd + 460)/528]			dscf/MMBtu
FUEL USE			

Use Rate (gal/ton) * Process Wt. (ton/hr)			gal/hr
Heat Input = (Process Weight (ton/hr) x Heating			MMBtu/hr
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6			
TOTAL PARTICULATE			

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0001	gr/scf	
15.432 x (FHW + MF + BHW) / (Vm(std)	0.0001	gr/dscf	
gr/dscf x (12 / %CO ₂)	0.0001	@ 0% CO ₂	
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O ₂)] ...	0.0002	@ 0% O ₂	
0.00857 x Qs(std) x gr/dscf	0.12	lb/hr	
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O ₂)] x gr/dscf ..		lb/MMBtu	
Particulate (lb/hr) / Heat Input (MMBtu/hr)		lb/MMBtu	
TOTAL ACID MIST			

[1.0811E-4 x (Vt - Vtb) x N x Vsol] / Vol(alog)			lb Acid Mist
[Acid Mist (lb) / Vm std (ft ³)] x Qs std x 60 ...			lb/hr
[Acid Mist (lb) / Vm std (ft ³)] x F-Factor			lb/MMBtu
SULFUR DIOXIDE (SO ₂)			

[7.061E-5 x (Vt - Vtb) x N x Vsol] / Vol(alog) .			lb SO ₂
[SO ₂ (lb) / Vm std (ft ³)] x Qs std (ft ³ /min) x 60			lb/hr
[SO ₂ (lb) / Vm std (ft ³)] x F			lb/MMBtu
[Mass SO ₂ (lb) x 385 / 64E+6 (ft ³ /lb)] / Vm (std)			ppm
ppm x 0.0 % Corr. / 22.4 % CO ₂ in Stack			ppm @ 0% CO ₂
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 22.4% O ₂ Stack			ppm @ 0% O ₂
SO ₂ (lb/hr / Heat Input)			lb/MMBtu
HYDROGEN CHLORIDE DATA SUMMARY			

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std			ppm
ppm x 0.0 % Corr. / 24.1 % CO ₂ in Stack			ppm @ 0% CO ₂
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 24.1% O ₂ Stack			ppm @ 0% O ₂
[Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)...]			lb/hr

EMISSION RATE CALCULATIONS

PLANT : Florida Rock Industries
Cement Kiln

STANDARD TEMP. :	68 F	RUN NO.:	3
*****	*****	DATE	: July 24, 2000
Front Half Wash (FHW)	0.00005 grams	Vm(std)	92.414 ft ³
Mass Filter (MF)	0.00000 grams	Vw(std)	17.604 ft ³
Back Half Wash (BHW)	0.00000 grams	Qs(std)	129,320 dscfm
Vm(std) SO ₂	dscf	Bws	0.160
CO ₂ CORR	0.0 %	CO ₂	15.00 %
O ₂ CORR.	0.0 %	O ₂	9.80 %
*****	*****	*****	*****
F-FACTOR			

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) - 0.46(%O ₂)] / (Btu/lb) x [(Tstd + 460)/528]		dscf/MMBtu	
FUEL USE			

Use Rate (gal/ton) * Process Wt. (ton/hr)		gal/hr	
Heat Input = (Process Weight (ton/hr) x Heating		MMBtu/hr	
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6			
TOTAL PARTICULATE			

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0000 gr/scf		
15.432 x (FHW + MF + BHW) / (Vm(std)	0.0000 gr/dscf		
gr/dscf x (12 / %CO ₂)	0.0000 @ 0% CO ₂		
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O ₂)] ...	0.0000 @ 0% O ₂		
0.00857 x Qs(std) x gr/dscf	0.01 lb/hr		
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O ₂)] x gr/dscf ..	1b/MMBtu		
Particulate (lb/hr) / Heat Input (MMBtu/hr)	1b/MMBtu		
TOTAL ACID MIST			

[1.0811E-4 x (Vt - Vtb) x N x Vsol] / Vol(alog)	1b Acid Mist		
[Acid Mist (lb) / Vm std (ft ³)] x Qs std x 60 ...	lb/hr		
[Acid Mist (lb) / Vm std (ft ³)] x F-Factor	lb/MMBtu		
SULFUR DIOXIDE (SO ₂)			

[7.061E-5 x (Vt - Vtb) x N x Vsol] / Vol(alog) .	1b SO ₂		
[SO ₂ (lb) / Vm std (ft ³)] x Qs std (ft ³ /min) x 60	1b/hr		
[SO ₂ (lb) / Vm std (ft ³)] x F	1b/MMBtu		
[Mass SO ₂ (lb) x 385 / 64E+6 (ft ³ /lb)] / Vm (std)	ppm		
ppm x 0.0 % Corr. / 22.4 % CO ₂ in Stack	ppm @ 0% CO ₂		
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 22.4% O ₂ Stack	ppm @ 0% O ₂		
SO ₂ (lb/hr / Heat Input)	1b/MMBtu		
HYDROGEN CHLORIDE DATA SUMMARY			

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std	ppm		
ppm x 0.0 % Corr. / 15.0 % CO ₂ in Stack	ppm @ 0% CO ₂		
ppm x (20.9% - 0.0% O ₂ Corr)/(20.9% - 15.0% O ₂ Stack	ppm @ 0% O ₂		
[Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)]...	1b/hr		

FIELD DATA SHEETS

Plant: FRI Cement Kiln
 Sample Loc.: Newberry, FL
 Control Type: ESP
 Sample Type: Method 104
 Date: 7/24/00 Run No.: 1
 Time Start: 08:50 Time End: 11:02
 Sample Time: 10/3/12 min/port 120 total min.
 Dry Bulb: °F Wet Bulb: °F VP @ DP:
 Bar. Pressure: 30.13 Hg Stack Press: Hg -0.24 Ps: 8.83 H2O
 Moisture: 15 % FDA: Gas Density Factor:
 Temperature: 83 °F Wind Dir.: South Wind Speed: 5-7
 Weather: Cloudy Thermocouple Readout: KAK-2
 Sample Box #: Mono-1 Meter Box No.: KA-4
 Meter Y: 0.997 @ Delta H: 1.376 Pitot Corr.: 0.84
 Nozzle Diameter: 0.280 in. Probe Length: 49/55 in
 Probe Heater Setting: 245°F Nomograph Cf: 3.19
 Stack Dimensions: 112' in
 Stack Area: ft²
 Effective Stack Area: ft²
 Stack Height: 3246' ft

Material Processing Rate: 371,512 ft³
 Final Gas Meter Reading: 495,900 ft³
 Initial Gas Meter Reading: 15,612 ft³
 Total Metered Gas Volume: 299 mL
 Condensate Gain in Impingers: 16 mL
 Weight Gain in Silica Gel: 16 g
 Total Moisture Gain: 5.5 mL
 Silica Gel Container No.: B
 Filter Number: B

Leak Check - Meter Box
 Initial: 0.011 cfm @ 15 in. H2O
 Final: 0.008 cfm @ 6 in. H2O

Leak Check - Pitot Tubes
 Impact 3 H2O for 15 sec: Stable, Leak
 Static 3 H2O for 15 sec: Stable, Leak



Test Conducted By: G. Haven, S. Bell
 Stack Test Observers: CO₂ = 22.4%
 O₂ = 8.5%

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head (H2O)	Meter Office Pressure Difference (H2O)	Stack Gas Temperature (°F)	Sample Box Temperature (°F)	Last Impinger Temperature (°F)	Meter Temperature (°F)	Vacuum on Sample Train (Hg)	Oxygen Meter Reading (% O ₂)
Average											
1			95.9	0.34	1.08	1.08	247	239	79	88	5
2			2.4	0.30	0.950	0.96	247	233	58	91	5
3			8.5	0.26	0.83	0.83	246	245	62	93	4
2-1			14.2	0.36	1.15	1.15	748	241	67	96	5
2			20.7	0.32	1.02	1.02	249	240	57	97	5
3			27.0	0.25	0.56	0.80	244	235	59	97	5
3-1			32.6	0.35	1.12	1.12	242	248	61	96	5
2			39.1	0.36	1.21	1.21	242	247	61	96	5

6 + CDB + 9842

Plant: FR1 Cement Kiln
 Sample Loc.: Newberry, FL
 Control Type: ESP
 Sample Type: Method 104
 Date: 7/24/00 Run No.: 2
 Time Start: 11:27 Time End: 17:31
 Sample Time: 10/3/12 min/port 60 total min.
 Dry Bulb: °F Wet Bulb: °F VP @ DP:
 Bar. Pressure: 30.13 Hg Stack Press: Hg -0.24 Pa: 0.83 H2O
 Moisture: 15 % FDA: Gas Density Factor:
 Temperature: 87 °F Wind Dir.: West Wind Speed: 3-5
 Weather: Broken Thermocouple Readout: KAK-2
 Sample Box #: M070-1 Meter Box No.: K4-4
 Meter Y: 0.997 @ Delta H: 1.376 Pitot Corr.: 0.84
 Nozzle Diameter: 0.280 in. Probe Length: 4 glass in
 Probe Heater Setting: 245°F Nomograph Cf: 3.12
 Stack Dimensions: 112" in Umbilical: 200' ft²
 Stack Area: ft² Thermocouple
 Effective Stack Area: ft² Probe No.: KAK-38
 Stack Height: 3240 ft Pitot Tube: K4-86II

Material Processing Rate: _____ ft³
 Final Gas Meter Reading: 649,152 ft³
 Initial Gas Meter Reading: 571,800 ft³
 Total Metered Gas Volume: 177,352 ft³
 Condensate Gain in Impingers: 276 mL
 Weight Gain in Silica Gel: 2.3 g
 Total Moisture Gain: 2.9 g mL
 Silica Gel Container No.: 32
 Filter Number: _____

Leak Check - Meter Box
 Initial: 0.0012 cfm @ 15 in. H2O
 Final: 0.011 cfm @ 8 in. H2O
 Leak Check - Pitot Tubes
 Impact 3 H2O for 15 sec: Stable, Leak
 Static 3 H2O for 15 sec: Stable, Leak



Test Conducted By: G. Haugen, S. Bell
 $\text{CO}_2 = 24.1\%$
 Stack Test Observers: $\text{O}_2 = 7.8\%$

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head (H2O)	Meter Office Pressure Difference (H2O)	Stack Gas Temperature (°F)		Sample Box Temperature (°F)	Last Impinger Temperature (°F)	Meter Temperature (°F)	Vacuum on Sample Train (Hg)	Oxygen Meter Reading (% O2)
						Calculated	Actual					
Average												
1-1			71.8	0.49	1.53	1.53	229	242	80	90	8	
2			79.4	0.46	1.44	1.44	243	251	66	92	7	
3			86.6	0.27	0.84	0.84	249	245	66	94	6	
2-1			92.4	0.32	1.0	1.0	247	246	70	96	6	
2			98.5	0.31	0.97	0.97	259	249	65	97	6	
3-1			604.5	0.23	0.72	0.72	253	243	64	98	6	
2			9.7	0.32	1.0	1.0	249	245	64	99	6	
			15.8	0.33	1.03	1.02	227	227				

Plant: ER1 - Cement Kiln
 Sample Loc.: Newberry, FL
 Control Type: ESP
 Sample Type: Method 104
 Date: 7/24/00 Run No.: 3
 Time Start: 4:12 Time End: 16:18
 Sample Time: 10:32 min/port 120 total min.
 Dry Bulb: °F Wet Bulb: °F VP @ DP:
 Bar. Pressure 30.13 Hg Stack Press: 30.11 Hg -0.24 ± 0.03 H2O
 Moisture: 15 % FDA: Gas Density Factor:
 Temperature: 87 °F Wind Dir.: SSW Wind Speed: 7-10
 Weather: Broken Thermocouple Readout: KAK-2
 Sample Box #: Mono-1 Meter Box No.: KAK-21
 Meter Y: 644 @ Delta H: 1.374 Pilot Corr.: 0.84
 Nozzle Diameter: 0.280 in. Probe Length: 49.65 ft
 Probe Heater Setting: 245°F Nomograph Cf: 3.12
 Stack Dimensions :
 Stack Area: 112 in Umbilical: 200' Thermocouple
 Effective Stack Area: 68.4 ft² Probe No.: KAK-38
 Stack Height: 2840 ft Pitot Tube: KA-5516

Material Processing Rate: 746.396 ft³
 Final Gas Meter Reading: 649,500 ft³
 Initial Gas Meter Reading: 56,296 ft³
 Total Metered Gas Volume: 96,289 ft³
 Condensate Gain in Impingers: 355 mL
 Weight Gain in Silica Gel: 19 g
 Total Moisture Gain: 7.2 mL
 Silica Gel Container No.: 33
 Filter Number: C

Leak Check - Meter Box
 Initial: 6.018 cfm @ 15 in. H2O
 Final: 0.002 cfm @ 9 in. H2O

Leak Check - Pilot Tubes
 Impact 3 H2O for 15 sec: Stable Leak
 Static 3 H2O for 15 sec: Stable Leak



Test Conducted By: G. Haven, S. Bell
 CO2 = 15% O2 = 9.8%

Stack Test Observers:

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft)	Stack Velocity Head (H2O)	Meter Office Pressure Difference (H2O)	Stack Gas Temperature (°F)		Sample Box Temperature (°F)	Last Impinger Temperature (°F)	Meter Temperature (°F)	Vacuum on Sample Train (Hg)	Oxygen Meter Reading (% O2)
						Calculated	Actual					
1			49.5	0.65	2.02	2.02	261	248	74	100	8	
2			58.5	0.60	1.92	1.92	200	239	61	100	8	
3			66.8	0.44	1.37	1.37	199	244	64	100	6	
2-1			74.1	0.62	1.93	1.93	200	235	68	98	7	
2			82.5	0.60	1.92	1.92	200	241	63	97	8	
3			90.8	0.43	1.34	1.34	199	243	63	98	6	
3-1			99.2	0.63	1.96	1.96	201	245	67	98	8	
2			100.4	0.58	1.81	1.81	202	245	67	98	8	

FRI 7/24/00

SAMPLING RATE CALCULATIONS

Date 7/24/00

Plant Name FRI

Location Newberry, FL

Source Cement Kiln

ΔH = Orifice Reading (inches H_2O)
 D_n = Nozzle Diameter (inches)
 ΔH_E = Meter Box Constant
 B_V = Moisture Fraction
 T_m = Meter Temperature ($^{\circ}F$)
 T_s = Stack Temperature ($^{\circ}F$)
 K_s = Net Molecular Weight of Stack Gas (From Table)
 ΔP = Pitot Reading (inches H_2O)


$$\left[\frac{T_m + 460}{K_s(T_s + 460)} (1 - B_V)^2 \Delta H_E (D_n)^4 17741 \right] \cdot \Delta P = \Delta H$$

Moisture Fraction	K_s
0.0	29.0
0.05	28.5
0.10	27.9
0.15	27.4
0.20	26.8
0.25	26.2
0.30	25.7
0.35	25.2
0.40	24.6

$$\frac{550}{27.4(215+460)} = 184.95$$

555

	Run 1	Run 2	Run 3
$\frac{T_m + 460}{K_s(T_s + 460)} =$	0.0297	0.629	
$\times (1 - B_V)^2 =$	0.7225	0.7225	
$\times \Delta H_E =$	1.376	1.376	
$\times (D_n)^4 =$	0.0061	0.0061	
$\times 17741 =$	17741	17741	
$\times \Delta P =$			
	3.19	3.12	



LABORATORY DATA SHEETS

FLOWERS



**CHEMICAL
LABORATORIES
INCORPORATED**

Received From:

Koogler Assoc.
4014 NW 13th St.
Gainesville, FL 32609

Date Reported : Aug 29 2000
Project Number : FL Rock Ind.
PO Number : 187-00-09
FLDOH Number : E83018
NYSDOH Number : 11595
CTDPH Number : 0173
NCDEHNR Number : 296
SCDHEC Number : 96019

For: Be

Date Sampled: Jul 25 2000 Date Received: Aug 9 2000 Lab Numbers: 31688-31697
REPORT OF ANALYSIS

Beryllium

mg

Accuracy: 91.8
Precision: .620
Det. Limit: .00010
Client ID
Lab Number

CONT1R1
31688 0.359

CONT2R1
31689 <0.00010

CONT3R1
31690 <0.00010

CONT1R2
31691 0.212

CONT2R2
31692 <0.00010

CONT3R2
31693 0.444


CONT1R3
31694 0.0472

CONT2R3
31695 <0.00010

Certificate of Results

Sample integrity certified prior to analysis. Test results meet all requirements of the NELAC Standards, except as noted in the QA Report Section 4. This Report may not be reproduced in part, results relate only to items tested.

Jefferson L. Flowers, Ph.D
Jefferson S. Flowers, Ph.D
481 NEWBURYPORT AV.
ALTAMONTE SPRINGS
FLORIDA 32715 - 0597
BUS: (407) 339-5984
FAX: (407) 260-6110


Jefferson S. Flowers, Ph.D
President/Technical Director

Serving Your Analytical and Environmental Needs Since 1957

FLOWERS

CHEMICAL
LABORATORIES
INCORPORATED

Received From:

Koogler Assoc.
4014 NW 13th St.
Gainesville, FL 32609

Date Reported : Aug 29 2000
Project Number : FL Rock Ind.
PO Number : 187-00-09
FLDOH Number : E83018
NYSDOH Number : 11595
CTDPH Number : 0173
NCDEHNR Number : 296
SCDHEC Number : 96019

For: Be

Date Sampled: Jul 25 2000 Date Received: Aug 9 2000 Lab Numbers: 31688-31697
REPORT OF ANALYSIS

Beryllium

mg


Accuracy: 91.8
Precision: .620
Det. Limit: .00010
Client ID
Lab Number

CONT3R3
31696 <0.00010

FILTDIBLANKS
31697 <0.00010

Certificate of Results

Sample integrity certified prior to analysis. Test results meet all requirements of the NELAC Standards, except as noted in the QA Report Section 4. This Report may not be reproduced in part, results relate only to items tested.


Jefferson S. Flowers, Ph.D.
President/Technical Director


Section 1 of 5

Page 2 of 2

Jefferson L. Flowers, Ph.D
Jefferson S. Flowers, Ph.D
481 NEWBURYPORT Av.
ALTAMONTE SPRINGS
FLORIDA 32715 - 0597
BUS: (407) 339-5984
FAX: (407) 260-6110

FLOWERS

CHEMICAL
LABORATORIES
INCORPORATED



Received From:

Koogler Assoc.
4014 NW 13th St.
Gainesville, FL 32609

Date Reported : Aug 29 2000
Project Number : FL Rock Ind.
PO Number : 187-00-09
FLDOH Number : E83018
NYSDOH Number : 11595
CTDPH Number : 0173
NCDEHNR Number : 296
SCDHREC Number : 96019

For: Be


Date Sampled: Jul 25 2000 Date Received: Aug 9 2000 Lab Numbers: 31688-31697
REPORT OF INFORMATION

Parameter	Unit	Limit	Expected	Value	Range	Correlation
				31688		
Beryllium	mg	-	-	0.359		
				31689		
Beryllium	mg	-	-	.00020		
				31690		
Beryllium	mg	-	-	.00020		
				31691		
Beryllium	mg	-	-	0.212		
				31692		
Beryllium	mg	-	-	.00020		
				31693		
Beryllium	mg	-	-	0.444		

The above information is intended to highlight exceptional data as compared to the upper control limits (Limit) established for each of the parameters. Range exceedances are flagged by integer values in the Range column. The Expected values are derived from historical data. Expected is computed as either the mean or computed directly from another parameter using linear regression. All known correlation rule exceedances are listed as enumerated rule numbers in the Correlation column. Correlation pair rules are defined on the last page.

FLOWERS

CHEMICAL
LABORATORIES
INCORPORATED



Received From:

Koogler Assoc.
4014 NW 13th St.
Gainesville, FL 32609

Date Reported : Aug29 2000
Project Number : FL Rock Ind.
PO Number : 187-00-09
FLDOH Number : E83018
NYSDOH Number : 11595
CTDPH Number : 0173
NCDEHNR Number : 296
SCDHEC Number : 96019

For: Be

Date Sampled: Jul25 2000 Date Received: Aug 9 2000 Lab Numbers: 31688-31697
REPORT OF INFORMATION

Parameter	Unit	Limit	Expected	Value	Range	Correlation
Beryllium	mg	-	-	31694		
Beryllium	mg	-	-	31695		
Beryllium	mg	-	-	31696		
Beryllium	mg	-	-	31697		
Beryllium	mg	-	-	31697		

The above information is intended to highlight exceptional data as compared to the upper control limits (Limit) established for each of the parameters. Range exceedances are flagged by integer values in the Range column. The Expected values are derived from historical data. Expected is computed as either the mean or computed directly from another parameter using linear regression. All known correlation rule exceedances are listed as enumerated rule numbers in the Correlation column. Correlation pair rules are defined on the last page.

Section 2 of 5

Page 2

481 NEWBURYPORT AVE.
ALTAMONTE SPRINGS,
FLORIDA 32701
P.O. BOX 150597
ALTAMONTE SPRINGS,
FLORIDA 32715-0597
BUS: (407) 339-5984
FAX: (407) 260-6110
WEB: www.flowerslabs.com

Serving Your Analytical and Environmental Needs Since 1957

282		FLOWERS CHEMICAL LABORATORIES ANALYTICAL RESULTS FORM												FLDOH Number E63018						
Parameter	Symbol	Unit	Cont1 R1	Cont2 R1	Cont3 R1	Cont1 R2	Cont2 R2	Cont3 R2	Cont1 R3	Cont2 R3	Cont3 R3	Fl/VI Blanks	QA	Section						
Beryllium	*	mg	0.359	<0.0001U	<0.0001U	0.212	<0.0001U	0.444	0.0472	<0.0001U	<0.0001U	<0.0001U	EPA200.8 0.0001	0.629	91.8	MAN	08-18-2000 10:50			
			Date Received:			08-09-00			Typed:			08-29-00			Sent:			08-29-00		
Project Number	FL Rock Ind.			Qualifier Key																
PO Number	187-00-09			J	Surrogate recovery limits have been exceeded;															
Date Sampled	1 07-25-00 *				No known quality control criteria exists for the component;															
Date Analyzed	0				The sample matrix interfered with the ability to make any accurate determination.															
Compacted				Q	Sample held beyond the accepted holding time.															
Format	NormL			U	Indicates that the compound was analyzed for but not detected.															
Unit Cost	Exted			V	Indicates that the analyte was detected in both the sample and the associated method blank.															
Ba	1200 10 *																			



Quality Assurance Report

Prepared for: Koogler Assoc.

Project Number: FL Rock Ind.

Lab Numbers: 31688 - 31697

Report date: 29-Aug-00





QA SDG Narrative Summary

Client: Koogler Assoc.
Project Number: FL Rock Ind.
P.O. Number: 187-00-09
Date Sampled: 25-Jul-00
Lab Numbers: 31688 - 31697

Sample Handling

Sample handling and holding time criteria were met for all samples.

Samples Collected by Submitter. No unusual events occurred during analysis.

The requested analytes did not require surrogates.

Accuracy / Precision:

QCCS Check Sample:

Standards Traceability:


The t-test limits were met for all calibration standards as shown in section 5.

The t-test limits were met for all QCCS standards as shown in section 5.

The t-test limits were met for all matrix spike standards as shown in section 5.

There was 1 standard blank.

The t-test limits were met for all surrogate spike standards as shown in section 5.



FLOWERS CHEMICAL LABORATORIES, INC.

QA Section 5

Standards Traceability

Client: Koogler Assoc.
Project Number: FL Rock Ind.
P.O. Number: 187-00-09
Date Sampled: 25-Jul-00
Lab Numbers: 31688 - 31697

Compound Name	Manufacturer Name	Manufacturer Lot #	Rec Lot #	Rec By	Date Received	Valid Until	Prep Lot #	Prep By	Date Prepared	Valid Until	t-test range	t-test Mean	Control Std	Control Std	Lot Mean	Lot Std
Standard																
Beryllium OCCS Matrix Spike	Fisher Fisher Fisher	9NFS30Z471 9NFS30Z471 9NFS30Z471	1095 1095 1095	EVB MAN MAN	01-10-00 01-10-00 01-10-00	12-30-00 12-30-00 12-30-00	1446 1734 1570	EVB MAN EVB	01-19-00 07-05-00 03-07-00	12-30-00 11-30-00 09-07-00	3.02 2.77 >1.68	>1.68	1.10 1.03 1.10	0.092	0.962 1.10 1.11	0.068 0.054
EPA200.8 Blank	Flowers Chemical Laboratories	Valid	34	JSF	01-01-95	12-31-01	14	JSF	01-01-95	01-01-01						

Koogler

CHAIN OF CUSTODY RECORD

Project Number

187-00-09

Project Name

Florida Rock Industries

Sample Location

Cement Kiln

Newberry, FL

Please analyze for Beryllium

Sample Identification

Remarks

Cont. 1 RI FRI

Filter Run #1

Florida Rock Ind.

31688

Cont. 2 RI ②

Impinger Catch ^{Run} #1

31689

Cont. 3 RI

Probe Rinse Run #1

31690

Cont. 1 R2

Filter Run #2

31691

Cont. 2 R2

Impinger Catch Run #2

31692

Cont. 3 R2

Probe Rinse Run #2

31693

Cont. 1 R3

Filter Run #3

31694

Cont. 2 R3

Impinger Catch Run #3

31695

Cont. 3 R3

Probe Rinse Run #3

31696

Filter + D₂O ^{Acetone} Blanks

Reagent Blanks

31697

Reagent Blanks

SEE DATA
SHEETS

Sampled By: (Signature)

Date: 7/25/00

Relinquished By: (Sign)

Date: 8/1/00

Received By: (Sign)

Date: _____

Relinquished By: (Sign)

Date: _____

Received By: (Sign)

Date: _____

Relinquished By: (Sign)

Date: _____

Received By Lab: (Sign)

Date: 8/9/00

R. Nooy

Time: 2:00PM

Sample Shipped VIA:

UPS

Fed Express

Bus

Shipping Bill Number:



PM: Kathy Dorris

Flowers Chemical Laboratories, Inc.

Cooler Receipt, Custody Record Verification, Preservation Form

Client: Koogler Assoc.

FCL Lab #:

31688 - 31697

Project: FL Rock Ind.

Cooler Rec'd on 08/09/00 16:0

Cooler opened on: 08-09-00

Rec'd b SJW

Log-in date: 08-09-00

	Yes	No	NA
a. Airbills or airbill stickers		X	
b. Traffic reports or packing lists		X	
c. Custody seals on shipping containers		X	
d. Custody seals intact?			X
e. Custody seal numbers if yes, _____			X
f. Airbill or airbill sticker Shipped via: _____		X	
g. Cooler Temperature upon receipt <u>Room</u> Degrees C			
h. If sample vials received, were bubbles observed?		X	
i. Client/FCL chain-of-custody forms present	X		
j. Was condition of shipping containers OK	X		
k. Sample tags present	X		
l. Were sample containers in good condition	X		
m. Were all containers labeled correctly	X		
n. Did all labels agree with Chain of Custody record	X		
o. Were correct containers sent for requested analysis	X		
p. Were samples properly preserved (see below)	X		
q. Project Manager notified as to discrepancies			X

Explanation of Discrepancies/Remarks: _____

Preservation Check	
pH	Reagent
>12	NaOH
<2	HNO3
<2	H2SO4
<2	HCL
	Na2S2O3

Yes

No

X
X
X
X
X

Returned Containers

P.250mL	1
P.500mL	
P.1L	
P.2L	
Wir-Pac	
40mVil	
G.250mL	
G.500mL	
G.1L	
G.4L	

PLANT OPERATING DATA

Florida Rock Industries, Inc.
Cement Group
Thompson S. Baker Cement plant

Process Weight Rate Sheet

Source: Kiln/Raw Mill Stack

Test Date: July 24, 2000

Permit No.: AC01-267311

Permitted Rate: 149.9 TPH

Test Parameter(s): Beryllium (Be)

	<u>Run Times</u>		<u>Process Input Rate</u>
Run No. 1	<u>850</u> - <u>1102</u>		<u>135</u> TPH
Run No. 2	<u>1127</u> - <u>1331</u>		<u>140</u> TPH
Run No. 3	<u>1412</u> - <u>1618</u>		<u>140</u> TPH

I here by certify that to the best of my knowledge the above data is true and correct.

George Townsend
Name (Print)

George Townsend
Signature

July 31, 2000
Date

Environmental & Safety Manager
Title

EQUIPMENT CALIBRATIONS

NOZZLE CALIBRATION

DATE 7/24/00

PLANT NAME FRI

LOCATION Newberry, FL

SOURCE Cement Kiln

Measurement No.

Inside Diameter (inches)

1 0.280


2 0.280

3 0.280

Average 0.280

Area of Nozzle _____ ft²

Calibrated by: J. A. Haven



Nozzle X-Section



PITOT TUBE CALIBRATION MEASUREMENTS

PITOT TUBE IDENTIFICATION NO. KA-55 II

DATE CALIBRATED 7-5-00

PITOT TUBE ASSEMBLY LEVEL ? YES NO

PITOT TUBE OPENINGS DAMAGED ? YES (EXPLAIN BELOW) NO

$$\alpha_1 = 1.5^\circ \quad (\leq 10^\circ) \quad \alpha_2 = 1.5^\circ \quad (\leq 10^\circ)$$

$$\beta_1 = 2.5^\circ \quad (\leq 5^\circ) \quad \beta_2 = 2.0^\circ \quad (\leq 5^\circ)$$

$$\gamma = 1.5^\circ, \theta = 2.0^\circ, A = 0.948 \text{ IN.} = (PA+PB)$$

$$Z = A \sin \gamma = 0.0248 \text{ IN.} \quad (< 0.125 \text{ IN.})$$

$$W = A \sin \theta = 0.0331 \text{ IN.} \quad (< 0.031 \text{ IN.})$$

$$P_A = 0.464 \text{ IN.} \quad P_B = 0.466 \text{ IN.}$$

$$D_t = 0.377 \text{ IN.} \quad (\geq 0.1875 \text{ IN.} \leq 0.3750 \text{ IN.})$$

COMMENTS: Pitot tube looked ok. day of test.

John H. Paul

CALIBRATION REQUIRED? YES NO

CALIBRATED BY: R Paul

PTCM FORM 1/8/87

POST TEST THERMOCOUPLE
CALIBRATION

DATE 7/24/00

PLANT NAME FRT

LOCATION Newberry, FL

SOURCE Cement Kiln

Thermocouple Readout # KAK-2

Umbilical Cord # 200

Switch Box # KAK-2

Thermocouple # KAK-3F

Average Stack Temperature °F _____


*Observed Mercury in Glass (ASTM) °F _____

Observed Thermocouple Reading °F _____

Percent Difference $\frac{(\text{ASTM} + 460) - (\text{Thermo} + 460)}{(\text{ASTM} - 460)} \times 100 =$ _____

Tolerance $\leq 1.5\%$

- * Observed Temperature must be within ten percent of the average stack temperature.


Signature



KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
 ANNUAL THERMOCOUPLE CALIBRATION 12/27/99

Page 1 of 3

KA70 RO/UMB		ICE (F)	ASTM (F)	AMB. (F)	ASTM (F)	212 (F)	ASTM (F)	400 (F)	ASTM (F)	KA70 RO/UMB
KA1/100'	STACK	32	33	73	72	208	209	405	406	KA1/100' STACK BOX IMP
	BOX	33	32	72	72	210	210	404	406	
	IMP	32	32	73	73	211	212	400	401	
KA2/200'	STACK	33	33	73	72	209	210	415	416	KA2/200' STACK BOX IMP
	BOX	32	32	72	73	211	210	418	418	
	IMP	32	33	71	72	212	212	409	410	
KA3/25' SWBXKA3	STACK	32	33	73	73	211	210	409	410	KA3/25' STACK BOX IMP
	BOX	33	32	72	73	215	215	415	416	
	IMP	33	32	72	73	212	212	408	407	
KA4/25' SWBXKA3	STACK	32	32	73	74	205	205	420	420	KA4/25' STACK BOX IMP
	BOX	32	33	74	74	207	208	422	421	
	IMP	32	33	72	73	211	212	425	425	
KAK/200K KAK-38 SWBXKAK1	STACK	31	32	74	74	213	213	419	420	KAK/200K STACK BOX IMP
	BOX	32	32	72	73	215	216	422	422	
	IMP	32	33	74	73	219	220	400	401	
KA1/200'	STACK	33	33	73	73	211	210	422	422	KA1/200' STACK BOX IMP
	BOX	33	33	73	72	214	214	419	418	
	IMP	33	32	73	72	209	209	425	425	
KA2/100'	STACK	33	33	73	72	209	210	422	423	KA2/100' STACK BOX IMP
	BOX	33	32	73	74	212	211	425	425	
	IMP	32	33	72	73	212	211	426	425	

Signature

Date 12/27/99

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
ANNUAL THERMOCOUPLE CALIBRATION

12/27/99

Page 2 of 3

THERMOCOUPLE #	ICE (F)	ASTM (F)	AMB. (F)	ASTM (F)	212 (F)	ASTM (F)	400 (F)	ASTM (F)	THERMOCOUPLE #
KA-06	33	33	73	74	212	212	420	419	KA-06
KA-07	33	32	74	75	209	210	421	422	KA-07
KA-08	34	33	74	74	211	211	415	416	KA-08
KA-09	33	33	74	74	215	216	416	417	KA-09
KA-10	34	33	72	72	214	215	408	407	KA-10
KA-11	33	33	72	72	212	212	415	414	KA-11
KA-12	33	33	73	72	219	220	408	407	KA-12
KA-38	34	33	73	74	211	211	412	411	KA-38
KA-39	34	33	73	73	212	211	416	415	KA-39
KA-50	33	34	74	73	215	214	415	416	KA-50
KA-64	33	33	74	74	211	211	410	411	KA-64
KA-70	33	33	73	74	212	213	405	406	KA-70
KA-71	34	34	73	73	211	210	407	408	KA-71
KA-72	34	33	72	72	216	215	410	410	KA-72
KA-105	34	33	73	73	217	218	404	405	KA-105
KA-108	34	34	72	73	214	215	412	411	KA-108
KA-115	34	33	72	72	213	214	409	410	KA-115
KA-126	34	33	72	72	216	216	410	409	KA-126

THERMOCOUPLE #	ICE (F)	ASTM (F)	AMB. (F)	ASTM (F)	212 (F)	ASTM (F)	400 (F)	ASTM (F)	THERMOCOUPLE #
KAK-08	32	32	73	74	218	217	407	406	KAK-08
KAK-09	31	31	73	73	211	212	405	406	KAK-09
KAK-10	32	32	74	74	209	210	377	376	KAK-10
KAK-11	31	31	75	75	206	206	399	398	KAK-11
KAK-12	32	31	74	74	218	217	407	406	KAK-12
KAK-38	31	31	74	74	210	211	410	410	KAK-38
KAK-65	32	32	74	74	205	205	377	377	KAK-65
KAK-72	31	31	74	75	208	208	400	401	KAK-72
KAK-110	31	32	75	74	209	210	399	400	KAK-110
KAK-07	32	31	75	74	209	210	389	390	KAK-07

VOST SWITCH BOX

T.COUPLER
C-1 32 33 74 75
C-1 33 32 74 74
C-1 33 33 75 74

VOST SWITCH BOX

CH#1	C-2	32	33	73	74
CH#2	C-2	33	33	74	75
CH#3	C-2	32	33	75	75

Signature Stacy J. Bee

Date 12/27/99

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
 ANNUAL THERMOCOUPLE CALIBRATION

12/27/99

Page 3 of 3

Range ($^{\circ}$ C)	Measured Voltage (mV)	Measured Voltage (V)	Calc. Temp. ($^{\circ}$ C)	Readout Temp. ($^{\circ}$ C)	Percent Difference (%)
KAK-12	28.7	0.029	690	693	-0.45023
	37.4	0.037	902	900	0.217654
KAK-38	28.9	0.029	694	698	-0.51192
	37.2	0.037	897	900	-0.33898
KAK-72	28.5	0.029	685	687	-0.30387
	37.5	0.038	904	908	-0.39058
KAK-65	28.2	0.028	678	680	-0.32666
	37.8	0.038	912	910	0.218082
KA-110	29	0.029	694	699	-0.65592
	37	0.037	894	899	-0.50758

EQUATIONS :

$$T \text{ (calc.)} = (0.226584602 + (24152.109 * V) + (67233.4248 * V^2) + (2210340.682 * V^3) - (860963914.9 * V^4) + (48350600000 * V^5) - (1184520000000 * V^6) + (13869000000000 * V^7) - (63370800000000 * V^8))$$

Where :

V = Measured Voltage (Volts)

T(calc.) = Temperature calculated based on voltage

Signature

Date

POST-TEST DRY GAS METER CALIBRATION FORM

COMPANY: Florida Rock Industries
 SOURCE: Cement Kiln
 DATE: August 9, 2000
 PRETEST Y: 0.997
 TEST METER NUMBER: KA-1
 METER BOX NUMBER: KA-4
 BAROMETRIC PRESSURE (Pb): 30.01
 DELTA H (dH): 2

	TEST METER READING (ft ³)	DRY GAS READING (ft ³)	TIME (min)	VACUUM SETTING (in. Hg)
INITIAL	304.563	321.225		
FIRST	310.023	326.635	6.1	6
SECOND	319.263	335.835	10.3	6
THIRD	328.421	345.017	10.2	6

DELTA H	TEST METER Vt (ft ³)	DRY GAS Vd (ft ³)	TEST METER TEMP. Tt (F)	DRY GAS TEMP. Td (F)
PB	5.460	5.410	77.5	81.5
30.01	9.240	9.200	77.5	84.5
	9.158	9.182	77	87

$$\frac{Y_i}{Vt * Pb * (Td + 460)}$$

$$-----$$

$$Y_i = \frac{Vd * (Pb + dH / 13.6) * (Tt + 460)}{Vt * Pb * (Td + 460)}$$

RUN 1 (Yi) =	1.011794	88727.26 / 87692.95
RUN 2 (Yi) =	1.012466	150985.7 / 149126.6
RUN 3 (Yi) =	1.011005	150332.8 / 148696.4

AVG. Y = 1.011755

PRETEST Y = 0.997
 AVG. DELTA Y = 0.014755
 DELTA Y LIMIT = .05
 IS TEST WITHIN 5%? YES

Vt = Gas volume passing through the test meter, ft³
Vd = Gas volume passing through the dry gas meter, ft³
Tt = Temperature of the gas in the test meter, |F
Tdi = Temperature of the inlet gas of the dry gas meter, |F
Tdo = Temperature of the outlet gas of the dry gas meter, |F
Td = Average temperature of the gas in the dry gas meter,
 the average of Tdi and Tdo, |F
dH = Pressure difference across the orifice, in, H₂O
Yi = Ratio of test meter to dry gas meter for each run
Y = Average ratio of accuracy of test meter to dry gas meter
 for all three runs, tolerance = pretest - 0.05*Y
± = Time of calibration run, min
Pb = Barometric pressure, in Hg.

DRY GAS METER AND ORIFICE CALIBRATION

CONTROL BOX NO. KA-4 BAROMETRIC PRESS. 30.39 IN. HG.

DATE FEB. 22, 2000 PERFORMED BY ROC

	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5
VACUUM ("Hg)	0.0	0.0	0.0	0.0	0.0
dHw ("H2O)	-0.28	-0.30	-0.33	-0.37	-0.43
dHd ("H2O)	0.50	1.00	1.50	2.50	3.50
INITIAL WTM	3.036	28.727	994.704	20.046	9.754
FINAL WTM	9.754	34.540	1003.036	28.727	20.046
INITIAL DGM	103.007	129.171	94.618	120.249	109.760
FINAL DGM	109.760	135.141	103.007	129.171	120.249
TEMP. WTM (F)	68.00	69.00	68.00	69.00	68.00
TEMP. DGM (F)	76.00	80.00	75.00	80.00	78.00
TEST TIME (MIN.)	14.50	9.00	11.00	9.00	9.00

NET VOLUME WTM	6.718	5.813	8.332	8.681	10.292
NET VOLUME DGM	6.753	5.970	8.389	8.922	10.489
Y	1.009	0.992	1.004	0.988	0.992
dHe	1.264	1.296	1.421	1.453	1.447

AVERAGE Y =	0.997				
ACCEPTABLE Y RANGE = 0.980 TO 1.020 OK					
AVERAGE dHe =	1.376				
Y = (Vw (Pb - (dHw / 13.6)) x (Td + 460)) / (Vd (Pb + (dHd / 13.6)) x (Tw + 460))					
dHe = 0.0317 x dHd / (Pb (Td + 460)) x ((Tw + 460) x time) / Vw^2					

PROJECT PARTICIPANTS

PROJECT PARTICIPANTS

KOOGLER & ASSOCIATES

John B. Koogler, Ph.D., P.E.	Project Advisor
Stephen S. Bell	Field Test Crew
Glen A. Haven	Field Test Crew

FLORIDA ROCK INDUSTRIES, INC.

George Townsend	Environmental & Safety Manager
-----------------	--------------------------------