From: Tampas, Patricia
To: McWade, Tammy
Subject: FW: Project No. 25.0007 Eyerly Avenue Water Main Replacement
Date: Thursday, August 21, 2014 7:24:07 AM
Attachments: 25-0007_073014_1_INV-DEP-DIV-AIR.pdf

Hi Tammy,
Any advice? The City Of Casselberry pipebursting projects were sent invoices, so I know this is consistent. I just don't really know how to answer his question.
Thank you,
Patty

From: David Garland [mailto:DGarland@cityofpsl.com]
Sent: Wednesday, August 20, 2014 5:06 PM
To: Tampas, Patricia
Cc: Laney Southerly; Project File
Subject: Project No. 25.0007 Eyerly Avenue Water Main Replacement

Ms. Tampas,

I apologize for this late reply but I have been on an extended vacation. I was notified that an invoice for $800.00 had been sent to the Port St. Lucie Utility Services Department (PSLUSD) in regards to a Notice of Demolition or Asbestos Renovation DEP Form 62-257.900. The invoice is in the attached PDF file. The Port St. Lucie Utility Systems Department is in the process of replacing an asbestos-cement water main located on Eyerly Avenue between Airoso Boulevard and Macedo Boulevard in Port St. Lucie. The existing 8-inch asbestos cement water main piping will be replaced with HDPE piping by using the pipe bursting method and abandoned in place in the right-of-way along Eyerly Avenue.

The backfilling and burial of crushed A/C pipe in place would cause these locations to be considered active disposal sites and subject to section 61.154. If no additional asbestos waste is buried at that location within a year, the site would become an inactive site subject to 61.151(e) and 61.154(h). PSLUSD intends to comply with the requirements for an active disposal site and the subsequent inactive site according to the sections referenced above. It is not clear what fee is required when there is no transport of asbestos material and it is completely contained underground. Is the fee applicable to buried asbestos cement pipe that is never removed from the ground? Please advise us as to whether this fee could be deleted.

Thank you,

David Garland, P.E.
Civil Engineer
Utility Engineering Division
City of Port St. Lucie
121 SW Port St. Lucie Blvd., Bldg. B
Port St. Lucie, FL 34984

Phone 772-807-4414