

Receipt #117516
√# 691151
\$ 500.00
AC 03-145061

WCAP-11541

DER

FEB 05, 1988 *mf*

BAQM

BAY COUNTY, FLORIDA WASTE-TO-ENERGY FACILITY

EMISSION COMPLIANCE TEST

SUBMITTED TO THE FLORIDA
DEPARTMENT OF ENVIRONMENTAL RESOURCES

JUNE 1987

9 10

MOA2

BAY COUNTY, FLORIDA WASTE-TO-ENERGY FACILITY

EMISSION COMPLIANCE TEST

**SUBMITTED TO THE FLORIDA
DEPARTMENT OF ENVIRONMENTAL RESOURCES**

JUNE 1987

**Prepared by: David S. Beachler
Manager, Environmental and Quality Engineering**

Signature: David S Beachler

**Jill Weldon
Senior Engineer**

Signature: Jill Weldon

TABLE OF CONTENTS

<u>SECTION</u>		<u>PAGE</u>
1.0	Introduction	1
2.0	Facility Description	1
3.0	Plant Capacity	4
4.0	Test Program	5
5.0	Test Dates	5
6.0	Testing Personnel	6
7.0	Results	6
8.0	Conclusion	8

APPENDICES

A.	Emission Compliance Report for June 4 and 5 Compiled by ETS, Inc.	14
B.	Opacity Measurements for May 12, 13, and 14, 1987	15
C.	Computer Calculation Sheets for Additional Test Results Reported in Table 2.	16

LIST OF TABLES

	Page
Compliance Test Results for Bay County Energy Resources	10
Additional Test Results from Bay County Energy Resources	11

LIST OF FIGURES

	Page
Process Flow Diagram	2
Westinghouse/O'Connor Water Cooler Rotary Combustor/Boiler	4

**BAY COUNTY, FLORIDA WASTE-TO-ENERGY FACILITY
EMISSION COMPLIANCE TEST REPORT**

1.0 INTRODUCTION

In April 1987, Westinghouse contracted ETS, Inc. of Roanoke, Virginia to conduct stack sampling of the Bay County Resource Recovery Facility. These tests were conducted over a 1-1/2 month period during the start-up and equipment fine-tuning stages, the plant 72-hour acceptance test, and the Florida DER emission compliance tests. The DER offices were notified that tests were being conducted during the time periods of May 12-14, May 18-21, and June 4-5, 1987.

Westinghouse submits this test report to the Florida Department of Environmental Regulations as part of the Certificate of Completion of Construction.

2.0 FACILITY DESCRIPTION

The Bay County Resource Recovery Facility is located on Highway 231, 10 miles Northeast of Panama City, Florida. The facility processes 510 tons per day of municipal solid wastes (MSW) and waste wood. Heat generated by the combustion of waste in the combustor produces steam to drive a turbine generator. A process flow diagram of the Bay County facility is shown in Figure 1.

The plant consists of two combustor/boiler units, a turbine-generator, a truck scale, tipping floor, front end loaders, conveyors, air emission control equipment, a stack, ash handling equipment, a central control room, and all required ancillary equipment. The facility also includes administration offices, change rooms, parking areas, roadways, and security fencing.





Figure 1 Simplified Process Flow Diagram, Gas Cycle

All municipal waste received at the plant enters through an automatic gate system and is unloaded on the tipping floor. Solid waste collection vehicles hauling the material to be processed are weighed at the scale prior to entering the plant and are then directed to a specific bay on the tipping floor. The weight is automatically entered into a computer system that records and files all pertinent data for each transaction. The vehicles enter the designated bay and discharge their load on the floor. The tipping floor accommodates approximately 1500 tons of waste while allowing room for maneuvering the incoming trucks and front end loaders.

A man-operated front-end loader disperses MSW on the tipping floor to separate large and unprocessable objects. Large items are separated from MSW; the combustible ones are processed through a shear shredder; the noncombustible items are removed and stored temporarily for landfill disposal. After sorting, the MSW is pushed onto the horizontal apron conveyor by the front-end loader. The horizontal apron conveyor transfers the MSW to the inclined apron conveyor and then into the combustor charging chute. The incline apron conveyor contains a weigh scale that continuously measures the weight of MSW sent for processing. When one line of apron feed conveyors is down for maintenance, a transfer conveyor at the charging hopper level feeds both combustors by changing the moving direction of the conveyor apron belt.

From the combustor charging chute, the MSW is pushed into the combustor by the hydraulic ram feeders (see Figure 2). The speed of the ram feeders and, consequently, the amount of solid waste fed to the combustor are controlled by the level of the solid waste in the chute. The feed throat of the combustor chute is provided with a water-cooled isolation door to prevent the flames in the rotary combustor barrel from reaching the solid waste in the charging chute. The combustion process begins when the MSW is pushed into the combustor. The slightly inclined combustor barrel rotates slowly, causing the waste to tumble and advance as combustion proceeds. A forced draft fan supplies air to the combustor. The air is preheated before entering the multiple zone windbox located beneath each combustor barrel.



The heat released from the combustion process is recovered through the rotary combustor walls, boiler water walls and tubes, primary and secondary superheater, and the air preheater. Hot gases, produced during the combustion process, flow from the combustor barrel through the boiler's radiant, superheater, and convection sections. To maximize energy recovery and expedite combustion of high-moisture waste, the combustion gases exiting the convection section pass through a heat exchanger which preheats the incoming combustion air. To prevent corrosion problems in the lower part of the boiler air heater, a steam preheater is located at the air heater inlet to increase the air temperature from ambient to 150°F.

The flue gases from the air heater enter the electrostatic precipitator (ESP). The ESP's were manufactured by Environmental Elements Corporation. They are arranged into three mechanical fields, each with its own electrical field and ash removal hopper. They are designed to remove 99.33% of the particulate matter in the flue gas at a gas flow rate of 56,000 ACFM (400°F) and at a particulate inlet loading of 3 gr/dscf.

The flue gas is drawn from the ESP by an induced draft fan which maintains a slightly negative pressure through the entire system. The flue gas from each unit discharges to the atmosphere through a separate flue in the common stack. The stack is made of precast concrete with two 4-ft, 6-in. diameter flues that are constructed of 4-in. thick acid resistant bricks. The stack is 125 feet tall and has air emissions monitoring ports located 60 feet from the stack base.

Three types of ash by-products are produced by the process: fly ash, siftings, and bottom ash. Fly ash is collected in hoppers under the convection, superheater, boiler/air heater, and ESP sections of each unit and is conveyed pneumatically to the bottom ash conveyor. Siftings are collected underneath the combustor by the siftings conveyor and are transferred by an ash drag system to the bottom ash conveyor. Bottom ash is collected on the ash burnout grate and is directed by a bifurcated chute into a water quench

basin. The fly ash, siftings, and bottom ash mixture are water quenched, dewatered, and removed by the bottom ash drag conveyor into trucks that are disposed of at a landfill.

Heat from the combustion of MSW is absorbed in the combustor barrel, boiler, and superheater to produce steam to drive the turbine-generator. Boiler feedwater moves through the boiler tubes by natural circulation as it is transformed into a mixture of saturated steam and water. Pumps circulate water through the rotary combustor by drawing water from the lower drum of the boiler through the rotary joint and into one of the combustor barrel's ring headers. The water passes through the combustor tubes and returns to the boiler steam drum as a mixture of saturated water and steam. Steam leaves the drum and passes through the primary and secondary tubes of the superheater section where the steam is heated to the design steam condition for the turbine (750°F).

The steam flows from the superheater to the turbine-generator where a portion of its energy is converted to electricity. The generator produces 3-phase, 60 Hz electrical power. Transformers provide power at reduced voltage for in-plant use, and at increased voltage for distribution to the utility grid.

3.0 PLANT CAPACITY

Plant capacity is based on the boiler steam flow rate. The facility is designed to process 510 tons per day of 4500 Btu/lb MSW in two units to produce a total of 136,000 lb/hr of steam at 600 psig and 750°F. The steam flow rate per ton of MSW is proportional to the heating value of the garbage. As the heating value fluctuates, the feed rate of MSW is adjusted to maintain a constant steam rate to the turbine. Because one cannot continuously predict the heating value of MSW, the measured steam flow rate is used to determine the capacity of each unit. During compliance testing, plant operators maintained the steam rate of each unit as close to the design condition of 68,000 lb/hr as practical.

4.0 TEST PROGRAM

In May and June 1987, Westinghouse conducted emissions testing of the Bay County Facility in accordance with Permit Numbers AC-03-84703 and AC-03-84704. Environmental testing consultants from ETS, Inc. performed particulate emissions testing in accordance with EPA Methods 1,2,3 and 5, and visible emissions testing in accordance with FAC Rule 17-2.700(6)(a)9., DER Method 9.

All stack sampling was performed through the sampling ports at the 60-ft elevation of the stack. Two sampling ports, positioned 90 degrees from each other, are located on each flue. Visible emissions were measured simultaneously with the stack sampling for particulate emissions.

Although the majority of the testing was conducted by ETS, a number of others also participated. A certified observer from Westinghouse measured visible emissions during the June testing program and environmental specialists from Roy F. Weston, Inc., employed by the Bay County Authority, witnessed at least three compliance test runs at each stack. Westinghouse provided individuals to monitor the plant operating conditions and to coordinate the test runs.

5.0 TEST DATES

Emission tests for determining particulate matter concentration were conducted from April 22 through June 5, 1987. The Florida DER was notified and invited to attend the DER emission compliance and plant acceptance tests as listed in the table below. Mr. Bert Lent of the Panama City Office of the Florida DER observed at least one day of testing on May 13, 1987. Mr. Lent indicated that he would try to attend testing during June 4-5, 1987.

<u>Date</u>	<u>Test</u>
5/12 - 5/14	DER Emission Compliance Test
5/18 - 5/21	Facility 72-hr Acceptance Test
6/4 - 6/5	DER Emission Compliance Test

Officials from Roy F. Weston observed various tests during these three testing periods. Roy F. Weston acted as an independent third-party engineer to observe the stack test for the Bay County Resource Recovery Authority.

6.0 TESTING PERSONNEL

Individuals from Westinghouse (RESO), ETS, Inc., and Roy F. Weston, Inc. participated during various phases of the 1-1/2-month test program. The following is a list of the participating individuals and their responsibility during the test program.

<u>Company</u>	<u>Name</u>	<u>Responsibility</u>
Westinghouse	David Beachler	Test Coordinator
	Jill Weldon	Test Coordinator
	Spencer Brady	Visual Emissions Observer, 6/4-6/5
ETS, Inc.	Jeff Smith	Stack Sampling Test Team Leader
	Jim Eckenrode	Stack Sampling
	Tony Underwood	Stack Sampling
	John Richardson	Visual Emissions Observer, 5/12-14
Roy F. Weston, Inc.	Denise Alston	Test Observer, 5/12-14
	Norman Getz	Test Observer, 5/20-21
	John Mills	Test Observer, 6/5

7.0 RESULTS

Westinghouse has collected a considerable amount of test data on the operation of Units 1 and 2 at the Bay County Resource Recovery Facility. Testing begin in April to evaluate the performance of the ESP and associated

equipment during the start-up and break-in phases of the facility. Since initial compliance testing (May 12-14) was conducted at extremely high firing rates, additional testing was required in late May and June to evaluate the units at the more typical design conditions of the facility.

Scheduled compliance testing was conducted on May 12, 13, 14, and June 4 and 5. The testing was originally to be conducted entirely during the week of May 12. During the original testing period, however, there were a number of problems that disrupted the normal operation of Unit 1. Major leaks were discovered in the valve seals between the fly ash collection hoppers and the pneumatic conveying system. In addition, the water seal at the bottom of the combustor/boiler was not complete, allowing air to leak into a stagnant region where it could possibly re-entrain dust and increase the particulate loading to the ESP.

Compliance efforts were resumed in June to complete the test program. During the week of June 1, Unit 1 was shutdown and, after extensive troubleshooting efforts, major leaks in the fly ash removal system were repaired. The bifurcated chute flap door seal was also secured to provide the water seal at the bottom of the furnace. Plant operation was resumed and Unit 1 compliance testing was rescheduled for June 5. Unit 2 was retested on June 4 to confirm earlier results.

Table 1 contains the emission compliance test results for Units 1 and 2 conducted on June 4-5, 1987. The average outlet particulate emissions for Units 1 and 2 are 0.0193 gr/dscf and 0.0243 gr/dscf corrected to 12% CO₂, respectively. The average emissions for both units comply with the particulate limit of 0.03 gr/dscf corrected to 12% CO₂ set by the Florida DER. The complete testing report prepared by ETS, Inc. containing test results, sample calculations, raw data sheets, and test procedures is given as Appendix A to this report.

Particulate measurements made during the scheduled compliance tests on May 12-14 and May 20-21 are included in Table 2. An environmental specialist

TABLE 1 EMISSION COMPLIANCE TEST RESULTS FROM BAY COUNTY ENERGY RESOURCES

BAY COUNTY COMPLIANCE TEST RESULTS UNIT 1							
DATE	TIME	FLUE GAS FLOW KDSCFM	FLUE GAS FLOW KACFM	STACK TEMP DEG F	STEAM FLOW KLB/HR	PERCENT OF RATED CAPACITY	PARTICULATE GR/DSCF @12%CO2
6/5	959	25.8	52.4	425.0	71.1	104.5	0.0140
6/5	1140	27.9	55.1	429.0	66.5	97.8	0.0240
6/5	1307	25.8	52.8	427.0	65.0	95.6	0.0200
AVERAGE					67.5	99.3	0.0193

BAY COUNTY COMPLIANCE TEST RESULTS UNIT 2							
6/4	945	27.7	52.6	429.0	69.7	102.5	0.0250
6/4	1310	28.4	58.1	449.0	62.7	92.2	0.0190
6/4	1525	29.2	59.0	451.0	62.3	91.6	0.0290
AVERAGE					64.9	95.4	0.0243

TABLE 2 ADDITIONAL TEST RESULTS FROM BAY COUNTY ENERGY RESOURCES

BAY COUNTY ADDITIONAL TEST RESULTS UNIT 1							
DATE	TIME	FLUE GAS FLOW KDSCFM	FLUE GAS FLOW KACFM	STACK TEMP DEG F	STEAM FLOW KLB/HR	PERCENT OF CAPACITY	PARTICULATE GR/DSCF @12% CO2
4/22	1436	25.0	45.5	373.0	58.6	86.2	0.0176
4/22 (1)	1652	25.9	50.3	387.0	70.4	103.5	0.0279
4/27	1505	24.9	48.1	441.0	68.9	101.3	0.0265
4/29	1214	19.9	39.0	441.0	61.1	89.9	0.0252
5/20 (2)	1542	29.8	49.8	426.0	70.4	104	0.0256
6/1	1903	25.5	51.2	426.0	64.0	94.1	0.0177
6/1	2029	23.7	52.3	436.0	57.2	84.0	0.0195
AVERAGE					64.4	94.7	0.0229

BAY COUNTY ADDITIONAL TEST RESULTS UNIT 2							
4/23	925	28.9	56.8	422.0	64.0	94.1	0.0161
4/23	1148	24.3	48.2	422.0	65.6	96.5	0.0215
4/23	1356	23.4	45.4	405.0	62.6	92.1	0.0192
4/30	957	27.4	51.7	427.0	NO DATA	NO DATA	0.0167
5/12 (3)	1350	25.7	54.2	437.0	76.0	112	0.0246
5/13 (3,4)	1635	23.7	48.2	408.0	72.0	106	0.0355
5/14 (3)	826	25.3	51.3	421.0	80.0	118	0.0157
5/21	1016	34.1	57.3	431.0	72.6	107	0.0172
5/21 (5)	1705	30.6	50.2	411.0	69.9	103	0.0184
6/1	927	25.9	54.5	436.0	64.5	94.8	0.0164
6/1	1045	24.3	52.3	428.0	60.8	89.4	0.0173
6/1	1215	25.2	55.4	426.0	57.8	85.0	0.0177
6/3	1023	25.8	52.0	438.0	59.8	87.9	0.0191
AVERAGE					67.1	98.7	0.0196

- (1) TEST DISCONTINUED AFTER 1/2 HOUR DUE TO PLANT SHUTDOWN
- (2) WITNESSED BY CONSULTANT FROM ROY F. WESTON
- (3) DER EMISSION COMPLIANCE TEST WITNESSED BY WESTON CONSULTANT
- (4) FURNACE WENT POSITIVE FOR A FEW MINUTES WHILE CONDUCTING THIS TEST WHEN AN AIR ACTUATOR VALVE WAS BEING REPAIRED.
- (5) INCINERATOR WAS FIRED WITH MUNICIPAL WASTE AND WOOD CHIP MIXTURE.

from Weston witnessed these tests for Bay County. Additional Method 5 particulate testing was conducted before and between compliance runs to evaluate whether the ESP was meeting its performance guarantees and to assist in plant troubleshooting. Table 2 contains the results from some of those tests which show an average particulate emission level of 0.0229 gr/dscf at 12% CO₂ for Unit 1 and 0.0196 gr/dscf at 12% CO₂ for Unit 2. Appendix C of this report contains the computer calculation sheets for each of the test runs listed in Table 2. This data is supplied to reinforce the compliance data and demonstrate overall reliability of the particulate removal system.

The results of Method 9 opacity measurements which were conducted during the June 4-5 compliance tests are contained in the report in Appendix A. Additional opacity measurements for the May compliance tests are contained in Appendix B. Visual measurements of opacity were continuously between 5 and 10% and confirm the low particulate levels measured by Method 5. The measurements meet, in all cases, the Florida DER requirements of less than 10% opacity and no more than 20% opacity for up to three minutes.

8.0 CONCLUSION

The results of scheduled testing indicate that Units 1 and 2 of the Bay County Resource Recovery Facility are in compliance with the particulate and visual emission levels required by the State of Florida Department of Environmental Regulations. The Method 5 particulate measurements conducted on June 4-5 at the design capacity of 255 ton per day per unit averaged 0.0193 gr/dscf at 12% CO₂ for Unit 1 and 0.0243 gr/dscf at 12% CO₂ for Unit 2. Method 9 opacity measurements were consistently at or less than 10% for both units during the test runs. Additional testing, conducted at the plant for verification and troubleshooting purposes, confirmed the low emission levels measured during the compliance test runs with average Unit 1 emissions of 0.0229 gr/dscf at 12% CO₂ and Unit 2 emissions of 0.0196 gr/dscf at 12% CO₂. The performance of the plant from an air quality standpoint is clearly within the acceptable range of less than 0.03 gr/dscf

particulate and less than 10% opacity required by the State of Florida Department of Environmental Regulations. Westinghouse (RESO) submits this report for the Bay County Resource Recovery Facility to the Florida DER and to request the issuance of an operating permit to burn MSW at the maximum plant design capacity rate of 190×10^6 Btu/hr or an equivalent of 510 TPD MSW with a heating value of 4500 Btu/lb.

APPENDIX A

**EMISSION COMPLIANCE REPORT FOR
JUNE 4 AND 5 COMPILED BY
ETS, INC.**

STATIONARY SOURCE SAMPLING
FOR
WESTINGHOUSE ELECTRIC CORP.
BAY COUNTY RESOURCE RECOVERY FACILITY - PANAMA CITY, FL

JUNE, 1987



ETS, inc.

3140 Chaparral Dr., SW

Suite C-103

Roanoke, VA 24018

ETS CONTRACT NO: 87-718-T

CLIENT P.O. NO: RN-15467-H

*Pollution Control Consultants
Specializing In
Fabric Filtration and Sulfur Dioxide Removal*

REPORT CERTIFICATION

The sampling and analysis performed for this report were carried out under my direction and supervision.

DATE: 6/16/87

SIGNATURE: James P. Eckenrode
James Eckenrode

I have reviewed all testing details and results in this report and hereby certify that the test report is authentic and accurate.

DATE: 6/16/87

SIGNATURE: Gary P. Greiner
Gary P. Greiner
Vice President

TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTION.....	1
SUMMARY OF RESULTS.....	1
FACILITY DESCRIPTION.....	3
FIELD TESTING.....	3
DISCUSSION.....	6
APPENDICES.....	8
A-1 SAMPLE CALCULATIONS AND COMPUTER CALCULATION SHEET	
B-1 EPA METHODS 1-5	
C-1 CLEAN-UP/FIELD DATA	
D-1 CALIBRATIONS	

LIST OF TABLES

TABLE I - EMISSION COMPLIANCE TEST RESULTS.....	2
---	---

LIST OF FIGURES

FIGURE 1 - METHOD 5 SAMPLING TRAIN.....	5
---	---

INTRODUCTION

Source sampling was performed on the outlet stack of Units 1 and 2 serving the Bay County Energy Resources MSW incinerators located in Panama City, FL. The purpose of these formal tests was to determine the particulate emissions of the waste incinerators. The test series consisted of EPA Methods 1-5. The tests were performed by Jim Eckenrode, Jeff Smith, and Tony Underwood of ETS, Inc. on June 4 and 5, 1987.

The following people took part or observed this test series:

PERSONNEL

Jim Eckenrode
Jeff Smith
Tony Underwood
Jill Welden
Spencer Brady
John Mills

COMPANY AFFILIATE

ETS, Inc.
ETS, Inc.
ETS, Inc.
Westinghouse
Westinghouse
Weston

SUMMARY

Particulate results are summarized in Table I. The State of Florida requires the incinerator emission concentrations be .03 gr/SCF corrected to 12% CO₂. The average emission rate for the three runs conducted on Unit #1 was 0.0190 gr/SCF corrected to 12% CO₂. The average emission rate for the three runs of Unit #2 was 0.0241 gr/SCF corrected to 12% CO₂. The average of each unit, as well as each test run, were well under the State of Florida standard. These tests were conducted while the system was operating

TABLE I

BAY COUNTY ENERGY RESOURCES EMISSION COMPLIANCE TESTS SUMMARY - JUNE 4-5, 1987

UNIT NO.	TEST REFERENCE NO.	1987 DATE	TIME	Q _s KDSCFM	Q _A KACFM	°F TEMP.	% MOISTURE	STEAM FLOW KLB/HR	% RATED CAPACITY	PARTICULATE CORRECTED 12% gr/SCF
1	1	6/5	0952	25.8	52.4	424.6	17.7	71.1	105	.0140
	2	6/5	1140	27.9	55.1	429.2	14.9	66.5	98	.0236
	3	6/5	1305	25.8	51.8	426.9	16.6	65.0	96	<u>.0195</u>
										AVERAGE =0.0190
<hr/>										
2	1	6/4	0945	26.7	52.6	428.8	14.6	69.7	103	.0248
	2	6/4	1311	28.4	58.1	448.8	16.0	62.7	92	.0188
	3	6/4	1527	29.2	59.0	451.3	14.7	62.3	92	<u>.0288</u>
										AVERAGE =0.0241

2

between 92% and 105% of rated capacity. Inlet feed conditions and operating data was monitored by Westinghouse personnel. John Mills of Weston observed the tests run on 6/5/87.

FACILITY DESCRIPTION

The facility uses two Westinghouse/O'Connor combustors to process 510 tons per day of municipal solid waste (MSW) and waste wood. Heat generated by the combustion of waste in the combustor produces steam to drive a turbine generator.

The flue gases leaving the boiler air heater pass through the pollution control equipment. The air pollution control equipment consists of an Electrostatic Precipitator (ESP), in which the small suspended particles (fly ash) contained in the flue gas, are collected on the collection plates. Periodic rapping of the plates causes fly ash to fall into hoppers located at the bottom of the Electrostatic Precipitator. From there the fly ash is then transferred by a pneumatic conveying system to the boiler bottom ash conveyor (submerged drag conveyor) where it is mixed with bottom ash. The flue gas is drawn from the ESP by the induced draft fan which maintains a controlled slightly negative pressure through the entire system. Using an induced draft fan for each combustion train, the flue gases from each unit discharge to the atmosphere through a separate flue in the common stack.


FIELD TESTING

Field testing was conducted on 6/4 and 6/5/87. All sampling

and analytical procedures used were those recommended by the United States Environmental Protection Agency. EPA Methods 1-5 were used in performing all of the compliance particulate tests.

Each test run was conducted to determine particulate mass emissions at the outlet. The sampling point number and locations were determined according to EPA Method 1 located in the Appendix. The round stack measured 53" I.D. and was traversed on two axes located 90° apart, with 6 traverse points per port. Each point was sampled for 5 minutes, resulting in a 60 minute particulate test excluding the time required to change ports. All tests used a .254" I.D. nozzle.

Testing was conducted utilizing a Method 5 sampling train and a Teflon lined stainless steel probe (see Figure 1). From the nozzle, the sample gas was pulled through the heated probe and then through a heated glass fiber filter which was maintained at a temperature sufficiently high to prevent the condensation of water ($248^{\circ} \pm 25^{\circ}$). Sample gas was subsequently passed through an impinger train consisting of four glass impingers immersed in an ice bath. The first and second impingers contained approximately 100 mls of water. The third impinger was initially dry and the fourth initially contained 200 gms of silica gel. Pre and post test impinger weights for the tests were taken on-site using a Mettler top loading balance. The heated stainless steel probe measured 84 inches in length.



Method 5 Sampling Train

FIGURE 1

Leak checks were performed on the sampling train before and after the tests were run. Post test leak checks were recorded on the field data sheets. All of the field data sheets can be found in Appendix C.

Velocity measurements were made according to Method 2, flue gas composition determinations and molecular weights according to Method 3, moisture determinations according to Method 4, and particulate emission determinations according to Method 5.

Spencer Brady of Westinghouse monitored the visible opacity readings on 6/4 and 6/5 according to EPA Method 9.

DISCUSSION

The tests on Unit #1 were conducted on 6/5 and the tests on Unit #2 were conducted on 6/4. The flows for Unit #1 were slightly less than the flows for Unit #2. In the first unit, gas flows averaged 53,100 ACFM whereas the gas flows for Unit #2 averaged 56,600 ACFM. Unit #1 also had a lower gas temperature. These results may be viewed on Table I. A complete list of calculated values can be seen in Appendix A.

The initial test period on 6/5/87 Unit #1 was aborted at 0839. Jill Welden informed the test team to void the test after sampling for 30 minutes. The test was interrupted because the system was not running at full capacity. The filter and probe wash was discarded and testing re-started when the system was back

to full capacity. Three complete tests were run following the aborted test period.

Weston personnel observed the stack testing and control room operations during the tests on 6/5. Westinghouse personnel were responsible for collecting operational data in the control room.

Lab Activity

Particulate weighings were performed at the ETS lab. Report sheets for each run are included with the computer printouts located in Appendix A.

Post test equipment calibrations were performed and data sheets are included in Appendix D.

Data Analysis

Particulate test calculations such as flue gas volume, flue gas velocity, mass emissions and percent isokinetics were performed by computer. Sample calculations and computer printouts of each run can be found in Appendix A.

APPENDIX A-1
SAMPLE CALCULATIONS
AND
COMPUTER CALCULATION SHEET

ETS

GENERAL

Name of firm	RAY RESOURCES
Location of plant	PANAMA CITY, FLA.
Type of unit	MSW INCINERATOR
Control equipment	ESP
Sampling location	OUTLET UNIT #1
Pollutants sampled	
Date test started	JUNE 5, 1987

REFERENCE METHOD #1

Area of stack, ft ²	A ₁ =	15.32
No. of equivalent dia. upstream	=	NA
No. of equivalent dia. downstream	=	NA
No. of traverse points	=	12
Total test time per run	t =	60

SPECIFIC
RUN No. 1
DATA AND CALCULATIONS

ETS
Test of
RAY RESOURCES

Date : 6/5/87 Run No. 1

REFERENCE METHOD #2

Standard temperature

Degrees Fahrenheit

$t_{std} = 68$

Degrees Rankine

$T_{std} = t_{std} + 459.67$

$T_{std} = 68 + 459.67$

$T_{std} = 528$

Average stack temperature

Degrees Fahrenheit

$t_s = 425$

Degrees Rankine

$T_s = t_s + 459.67$

$T_s = 425 + 459.67$

$T_s = 884$

Barometric pressure, in. Hg

$P_b = 30.02$

Static pressure, in. H₂O

$P_{static} = -.55$

Stack absolute pressure, in. Hg

$P_s = P_b + (P_{static} / 13.6)$

$P_s = 30.02 + (-.55 / 13.6)$

$P_s = 29.98$

Average delta p, in. H₂O

$\Delta p = 0.608$

ETS
Test of
BAY RESOURCES
Date : 6/5/87 Run No. 1

REFERENCE METHOD #3

Gas analysis, % average

sample gas	1	2	3	avg
%CO ₂	11.5	11.5	11.5	11.5
%O ₂	7.3	7.2	7.2	7.2
%CO	0.0	0.0	0.0	0.0

%N₂ determination, % average

$$\%N_2 = 100 - (\%CO_2 + \%O_2 + \%CO)$$

$$\%N_2 = 100 - (11.5 + 7.2 + 0.0)$$

$$\%N_2 = 81.3$$

ETS
Test of
RAY RESOURCES
Date : 6/5/87 Run No. 1

REFERENCE METHOD #4

Water vapor volume collected, SCF

Constants

$K_1 = \text{ft}^3/\text{ml}$ (english/metric units) @ 68 t _{std}	$K_1 =$	0.04707
$K_2 = \text{ft}^3/\text{ml}$ (english/metric units) @ 68 t _{std}	$K_2 =$	0.04715

Impingers

Volume initial, ml	$V_i =$	1147.0
Volume final, ml	$V_f =$	1303.0

$$V_{\text{water}} = K_1 (V_f - V_i)$$

$$V_{\text{water}} = 0.04707 * (1303.0 - 1147.0) \quad V_{\text{water}} = 7.34$$

Silica gel

Weight initial, g	$W_i =$	633.0
Weight final, g	$W_f =$	643.0

$$V_{\text{water}} = K_2 (W_f - W_i)$$

$$V_{\text{water}} = 0.04715 * (643.0 - 633.0) \quad V_{\text{water}} = 0.47$$

ETS
Test of
RAY RESOURCES
Date : 6/5/87 Run No. 1

REFERENCE METHOD #5

Meter calibration factor $V_{...} = 1.001$

Delta H, in. H₂O average $\Delta H = 1.537$

Nozzel diameter, in. $D_{..} = 0.254$

$$A_{..} = \frac{\pi (D_{..} / 2)^2}{144}$$

$$A_{..} = \frac{3.1416 * (0.254 / 2)^2}{144}$$

$A_{..} = 0.000352$

Meter temp., average

Degrees fahrenheit $t_{...} = 94$

Degrees rankine

$$T_{...} = t_{...} + 459.67$$

$$T_{...} = 94 + 459.67$$

$T_{...} = 554$

Volume metered, cf

$V_{...} = 37.846$

ETS
 Test of
 BAY RESOURCES
 Date : 6/5/87 Run No. 1

CALCULATIONS

Dry gas volume corrected to standard conditions

$$P_{std} = P_b + \Delta H / 13.6$$

$$P_{std} = 30.02 + 1.54 / 13.6$$

$$P_{std} = 30.13$$

SCF calculation

$$V_{std} = V_{meas} \cdot V_m \cdot \frac{T_{std}}{T_{meas}} \cdot \frac{P_{meas}}{P_{std}}$$

$$V_{std} = 37.85 * 1.001 * \frac{528}{554} * \frac{30.13}{29.92}$$

$$V_{std} = 36.367$$

Moisture content of stack gas

$$B_{std} = \frac{V_{H_2O(std)} + V_{H_2O(meas)}}{V_{H_2O(std)} + V_{H_2O(meas)} + V_{std}}$$

$$B_{std} = \frac{7.34 + 0.47}{7.34 + 0.47 + 36.367}$$

$$B_{std} = 0.177$$

ETS
 Test of
 BAY RESOURCES
 Date : 6/5/87 Run No. 1

CALCULATIONS

Molecular weight of stack gas, lb/bl-mole

Dry molecular weight

$$M_d = .44 \%CO_2 + .32 \%O_2 + .28 \%CO + .28 \%N_2$$

$$M_d = .44 * 11.5 + .32 * 7.2 + .28 * 0.0 + .28 * 81.3$$

$$M_d = 30.13$$

Wet molecular weight

$$M_w = M_d (1 - B_{H_2O}) + 18 B_{H_2O}$$

$$M_w = 30.13 * (1 - .177) + 18 * .177$$

$$M_w = 27.98$$

Excess air, %

$$\%EA = \frac{\%O_2 - .5 \%CO}{.264 \%N_2 - (\%O_2 - .5 \%CO)} 100$$

$$\%EA = \frac{7.2 - .5 * 0.0}{.264 * 81.3 - (7.2 - .5 * 0.0)} 100$$

$$\%EA = 50.9$$

Average stack gas velocity, ft/sec

Constant

$$K_v = \text{ft/sec (english units)}$$

$$K_v = 85.49$$

$$v_s = K_v C_p (\Delta p)_{avg} \sqrt{\frac{T}{P M_w}}$$

$$v_s = 85.49 * 0.84 * 0.774 * \sqrt{\frac{884}{.2998 * 27.98}}$$

$$v_s = 57.04$$

ETS
 Test of
 RAY RESOURCES
 Date : 6/5/87 Run No. 1

CALCULATIONS

Average stack volumetric flow rate, ACFM

$$Q_s = 60 v_s A_s$$

$$Q_s = 60 * 57.04 * 15.3$$

$$Q_s = 52430$$

Average stack volumetric flow rate @ standard conditions, SCFM

$$Q_s = 60 v_s A_s (1 - B_{s,s}) \frac{T_{std} P_s}{P_{std} T_s}$$

$$Q_s = 60 * 57.04 * 15.3 * (1 - .177) * \frac{528 * 29.98}{29.92 * 884}$$

$$Q_s = 25805$$

Isokinetic, %

$$\%I = \frac{T_s v_{isokinetic} P_{std}}{A_s \theta v_s P_s T_{std} 60 (1 - B_{s,s})} 100$$

$$\%I = \frac{884 * 36.367 * 29.92}{.000352 * 60 * 57.04 * 29.98 * 528 * 60 * (1 - .177)} * 100$$

$$\%I = 102.3$$

ETS
 Test of
 BAY RESOURCES
 Date : 6/5/87 Run No. 1

EMISSION CALCULATIONS

Pollutant mass rate, lb/hr

Constant

$$K_D = \text{gm/lb-hr (english metric units)} \quad K_D = 0.132159$$

Dry - (Particulate catch before and including the filter.)

$$PMR_D = \frac{m_D}{V_{(std)}} \cdot Q \cdot K_D$$

$$PMR_D = \frac{0.0315}{36.37} * 25805 * 0.132159 \quad PMR_D = 2.96$$

Wet - (Particulate catch including dry catch and solids condensed beyond the filter in glassware and impingers.)

$$PMR_W = \frac{m_W}{V_{(std)}} \cdot Q \cdot K_D$$

$$PMR_W = \frac{0.0315}{36.37} * 25805 * 0.132159 \quad PMR_W = 2.96$$

Concentration, gr./SCF

Dry - (Particulate catch before and including the filter.)

$$C_{D,D} = 15.43 \frac{m_D}{V_{(std)}}$$

$$C_{D,D} = 15.43 * \frac{0.0315}{36.367} \quad C_{D,D} = 0.0134$$

Wet - (Particulate catch including dry catch and solids condensed beyond the filter in glassware and impingers.)

$$C_{D,W} = 15.43 \frac{m_W}{V_{(std)}}$$

$$C_{D,W} = 15.43 * \frac{0.0315}{36.367} \quad C_{D,W} = 0.0134$$

ETS
Test of
RAY RESOURCES

Date : 6/5/87 Run No. 1

EMISSION CALCULATIONS

Concentration @ 50% EA, gr./SCF

Dry - (Particulate catch before and including the filter.)

$$C_{\text{dry}} = \frac{C_{\text{w}} (100 + \%EA)}{150}$$

$$C_{\text{dry}} = \frac{0.0134 * (100 + 50.9)}{150}$$

$$C_{\text{dry}} = 0.0135$$

Wet - (Particulate catch including dry catch and solids condensed beyond the filter in glassware and impingers.)

$$C_{\text{wet}} = \frac{C_{\text{w}} (100 + \%EA)}{150}$$

$$C_{\text{wet}} = \frac{0.0134 * (100 + 50.9)}{150}$$

$$C_{\text{wet}} = 0.0135$$

Concentration @ 12% CO₂, gr./SCF

Dry - (Particulate catch before and including the filter.)

$$C_{\text{dry}}_{12\text{CO}_2} = C_{\text{w}} \frac{12}{\%CO_2}$$

$$C_{\text{dry}}_{12\text{CO}_2} = 0.0134 * \frac{12}{11.5}$$

$$C_{\text{dry}}_{12\text{CO}_2} = 0.0140$$

Wet - (Particulate catch including dry catch and solids condensed beyond the filter in glassware and impingers.)

$$C_{\text{wet}}_{12\text{CO}_2} = C_{\text{w}} \frac{12}{\%CO_2}$$

$$C_{\text{wet}}_{12\text{CO}_2} = 0.0134 * \frac{12}{11.5}$$

$$C_{\text{wet}}_{12\text{CO}_2} = 0.0140$$

ETS
Test of
BAY RESOURCES
Date : 6/5/87 Run No. 1

EMISSION CALCULATIONS

Concentration @ 7% O₂, gr./SCF

Dry - (Particulate catch before and including the filter.)

$$C_{dry702} = C_{dry} \frac{20.9 - 7}{20.9 - \%O_2}$$

$$C_{dry702} = 0.0134 * \frac{20.9 - 7}{20.9 - 7.2}$$

$$C_{dry702} = 0.0136$$

Wet - (Particulate catch including dry catch and solids condensed beyond the filter in glassware and impingers.)

$$C_{wet702} = C_{wet} \frac{20.9 - 7}{20.9 - \%O_2}$$

$$C_{wet702} = 0.0134 * \frac{20.9 - 7}{20.9 - 7.2}$$

$$C_{wet702} = 0.0136$$

ETS
Test of
RAY RESOURCES

Date : 6/5/87 Run No. 1

SAMPLE RECOVERY SUMMARY

	Con 1	Con 2	Con 3	Con 4	Con 5
Tare	1.3361	79.1541		633.0	
Gross	1.3489	79.1729		643.0	
m_1	0.0128		NA		
		m_2			
	C_a	0.000		C_a	
	V_{a_w}	100.000		V_{a_w}	
	ρ_a	0.7850		ρ_a	
	W_a	0.00		W_a	0.00
	m_2	0.0187		m_5	NA

Tare and gross weights are in grams. Tare weight is the container without sample, gross weight is the container with sample. Containers 1 thru 5 used in weighing recovered sample are :

Container 1 - filter. (includes weight of filter)
Filter identification : 87-304

Container 2 - washings from probe, cyclone, and front of filter holder.

Container 3 - solids trapped in impingers

Container 4 - silica gel. (method #4)

Container 5 - washings from fluid filled impingers and connecting glassware.

$$m_1 \text{ \& } m_5 = \text{Gross}_{Con} - \text{Tare}_{Con}$$

Additional inputs for containers 2 and 5 are required if container is used. The inputs are :

V_{a_w} - volume of the acetone wash in milliliters.

C_a - acetone blank residue concentration in milligrams per gram.

ρ_a - density of acetone in grams per milliliter.

$$W_a = C_a \cdot V_{a_w} \cdot \rho_a$$

SAMPLE RECOVERY SUMMARY

Dry* particulate mass, g

$$m_d = m_1 + m_2$$

$$m_d = 0.0128 + 0.0187$$

$$m_d = 0.0315$$

Wet* particulate mass, g

$$m_w = m_d + m_3 + m_4$$

$$m_w = \text{NA} + \text{NA} + 0.0315$$

$$m_w = 0.0315$$

Fluid volumes for impingers in milliliters :

V_i - initial

V_f - final

	Imp 1	Imp 2	Imp 3	total
V_i	581.0	566.0	0.0	1147.0
V_f	712.0	591.0	0.0	1303.0

- * Dry - (Particulate catch before and including the filter.)
- * Wet - (Particulate catch including the dry catch and solids condensed beyond the filter in glassware and impingers.)

FIELD DATA SUMMARY

Location: PANAMA CITY, FLA.
 Operator: JIM ECKENRODE
 Date: 6/5/87
 Run number: 1
 Stack diameter, in: 53.00
 Sample box I.D.: NUTECH
 Meter box I.D.: NUTECH #3

Meter calibration (V_L): 1.001
 Pitot tube (C_p): 0.84
 Probe heater setting: 250
 Ambient temperature: 80
 Bar. press. (P_a), in Hg: 30.02
 Assumed moisture, %: 15.0
 Static pres. (P_s), in H₂O: -.55
 Reference (Δp): 0.450

Sheet: 1 of 1
 Nozzle I.D.: .254
 Nozzle diameter, in.: 0.254
 Thermometer I.D.: NONE
 Final leak rate, cfm: 0.000
 Vac. @ leak check, in Hg: 6.0
 Filter I.D.: B7-304
 Meter (ΔH₀): 2.052

Point No.	Time (24h)	Stack temp., °F	Vel. into probe, in. H ₂ O	Pres. diff. static - dynamic, in. H ₂ O	Gas sample volume, ft ³	Temp., °F		FLT	EXT	PVC	LKC
						In	Out				
A 1	09:52:00	428	0.740	1.890	121.757	93	92	236	0	4.0	
A 2	09:57:00	428	0.790	2.000	125.200	91	92	246		4.0	
A 3	10:02:00	428	0.730	1.870	128.800	93	92	250		4.0	
A 4	10:07:00	429	0.680	1.720	132.300	92	92	252		4.0	
A 5	10:12:00	429	0.600	1.500	135.600	93	93	247		3.0	
A 6	10:17:00	396	0.400	1.000	138.600	93	93	252	0	2.0	
A	10:22:00	port	end		141.300						
B 1	10:24:00	428	0.610	1.550	141.300	95	94	249	0	3.0	
B 2	10:29:00	434	0.680	1.720	144.400	95	95	256		4.0	
B 3	10:34:00	435	0.690	1.750	147.700	96	95	257		4.0	
B 4	10:39:00	434	0.560	1.420	151.200	95	95	257		4.0	
B 5	10:44:00	433	0.500	1.250	154.400	96	96	263		3.0	
B 6	10:49:00	393	0.310	0.770	157.300	97	96	260	0	2.0	
B	10:54:00	port	end		159.603						
run	end							max	max		
		avg	avg	avg	sum	avg	avg	263	0	max	
		425	0.608	1.537	37.846	94	94	min	min	4.0	
								236	0		

FLT - Filter temp., °F
 EXT - Gas temp. from train exit, °F
 PVC - Pump vacuum, in. Hg
 LKC - Leak check leak rate, cfm

W02 avg.	11.5	paord	2.956468948082777
W02 avg.	7.233333333333333	pmrw	2.956468948082777
W00 avg.	0	ced	1.337677366069144D-02
As stack area	15.32071832265625	cew	1.337677366069144D-02
W0 avg. DGM	37.846	ced50%	1.345378000791836D-02
W0 avg. delta p	.6075	cew50%	1.345378000791836D-02
ts avg. temp	424.5833333333333	ced12	1.395837251550412D-02
W0 avg. delta H	1.536666666666667	cew12	1.395837251550412D-02
W0i avg. temp	94.08333333333333	ced7	1.360515760761458D-02
W0i avg. temp	93.75	cew7	1.360515760761458D-02
W02 avg.	91.26666666666667	saturation flag	-1
W0 mole wt. dry	30.129333335105578	Ews saturated	.1768698385098112
W0 mole wt.	27.98402012002288	Vm corrected	37.846
W0 area nozzle	3.51880193415625D-04	total # points	12
W0 temp meter	93.91666666666667	Vf impingers	1303
W0 abs temp	553.5866666666667	Vi impingers	1147
W0 abs temp	884.2533333333333	sqr(Dp) avg.	.7736374035997174
W0 abs pres	30.13299019290914	Ews kick flag	0
W0 abs pres	29.97955882466376	Vm C kick flag	0
W0 (std)	36.36733572409156	not in use	NA
W0c (std)	7.34292	Ma2	.0019625
W0sg (std)	.4715	Ma5	0
W0s	.1768698385098112	K1 constant	.04707
W0s velocity	57.03648374168055	K2 constant	.04715
W0 vol rate	25804.82891193186	Tstd abs temp	527.67
W0 time min.	60	container 1	.01279
W0 isokinetic	102.2688935470582	container 2	.0187380374999061
W0a vol rate	52430.35409126303	container 3	NA
W0 mass dry	3.152803749990609D-02	container 4	10
W0 mass wet	3.152803749990609D-02	container 5	NA
W0A	50.8635080757911	not in use	NA

* Variables defined in sample calculations.

UNIT #1

FLA1

run 2

15:37:33

06-15-1987

Page 1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

XCO2 avg. 11.066666666666667
 XO2 avg. 9.333333333333333
 XCO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 40.201
 Dp avg. delta p .6725
 ts avg. temp 429.25
 DH avg. delta H 1.7108333333333333
 tmi avg. temp 99.75
 tmo avg. temp 98.58333333333333
 XM2 avg. 79.6
 Md mole wt. dry 30.1440000017484
 Ma mole wt. 28.33868922581083
 An area nozzle 3.51880193415625D-04
 tm temp meter 99.16666666666667
 Tm abs temp 558.8366666666667
 Ts abs temp 888.92
 Pm abs pre 30.14579656509895
 Ps abs pre 29.97882353056673
 Vm(std) 38.28367482317118
 Vm2(std) 6.07203
 Vm3(std) .61295
 Bws .1486586607112696
 ve velocity 59.89974189443064
 Qa vol rate 27881.22005939102
 time min. 60
 X1 isokinetic 99.64027100939907
 Qa vol rate 55062.42438986302
 md mass dry 5.407803749990775D-02
 mw mass wet 5.407803749990775D-02
 XEA 79.90137964839974

pmrd 5.204822875421487
 pmrw 5.204822875421487
 ced 2.179582086823446D-02
 ceu 2.179582086823446D-02
 ced50% 2.614065496509841D-02
 ceu50% 2.614065496509841D-02
 ced12 2.363402262820604D-02
 ceu12 2.363402262820604D-02
 ced7 2.619267248522116D-02
 ceu7 2.619267248522116D-02
 saturation flag -1
 Bws saturated .1486586607112696
 Vm corrected 40.201
 total # points 12
 Vf impingers 1257
 Vi impingers 1128
 sqn(Dp) avg. .8154478297451962
 Bws kick flag 0
 Vm 0 kick flag 0
 not in use NA
 Wa2 .0019625
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 2.918999999999999D-02
 container 2 2.488903749990775D-02
 container 3 NA
 container 4 13
 container 5 NA
 not in use NA

CO2 avg.	11.4	pard	4.08731404274903
O2 avg.	8.733333333333333	parw	4.08731404274903
XCO avg.	0	csd	1.852943309371419D-02
As stack area	15.32071832265625	csw	1.852943309371419D-02
As avg. DGM	37.669	csd50%	2.108734144345626D-02
As avg. delta p	.5933333333333333	csw50%	2.108734144345626D-02
As avg. temp	426.9166666666667	csd12	1.950466641443599D-02
As avg. delta H	1.5058333333333333	csw12	1.950466641443599D-02
Asi avg. temp	99.25	csd7	.0211692428227097
Asp avg. temp	97.75	csw7	.0211692428227097
AsN2 avg.	79.86666666666667	saturation flag	-1
As mole wt. dry	30.17333333333333	Bws saturated	.166209396381665
As mole wt.	28.15001085268566	Vm corrected	37.669
As area nozzle	3.51880193415625D-04	total # points	12
As temp meter	98.5	Vf impingers	1298
As abs temp	558.17	Vi impingers	1161
As abs temp	886.5866666666667	sqn(Dp) avg.	.765534402716032
As abs pres	30.13072303610999	Bws kick flag	0
As abs pres	29.97882353056673	Vm C kick flag	0
As(std)	35.89732158881965	not in use	NA
Vas(std)	6.44859	Wa2	.0019625
Wag(std)	.70725	Wa5	0
WAs	.166209396381665	K1 constant	.04707
vs velocity	56.34732929108269	K2 constant	.04715
vs vol rate	25754.60632677361	Tstd abs temp	527.67
vs time min.	60	container 1	3.0230000000000001D-02
W1 isokinetic	101.1440140969227	container 2	1.287803749990768D-02
Qs vol rate	51796.89361815814	container 3	NA
Qs mass dry	4.310803749990768D-02	container 4	15
Qs mass wet	4.310803749990768D-02	container 5	NA
WEA	70.70685328152157	not in use	NA

unit #2

X002 avg.	11.346666666666667	pmrd	5.371203480502901
X02 avg.	7.733333333333333	parw	5.371203480502901
X00 avg.	0	ced	2.347715933898702D-02
As stack area	15.32071832265625	cew	2.347715933898702D-02
Vm avg. DBM	38.487000000000001	ced50X	2.453542599677754D-02
Dp avg. delta p	.6225	cew50X	2.453542599677754D-02
ts avg. temp	428.8333333333333	ced12	2.478527085640865D-02
DH avg. delta H	1.5825	cew12	2.478527085640865D-02
tmi avg. temp	104.5	ced7	2.478474799828298D-02
tmo avg. temp	103.4166666666667	cew7	2.478474799828298D-02
XN2 avg.	80.9	saturation flag	-1
Md mole wt. dry	30.12800001402696	Bws saturated	.1461575121652505
Ms mole wt.	28.35540170443666	Vm corrected	38.487000000000001
An area nozzle	3.51880193415625D-04	total # points	12
tm temp meter	103.9583333333333	Vf impingers	1249
Tm abs temp	563.6283333333333	Vi impingers	1132
Ts abs temp	888.5033333333333	sqv (Dp) avg.	.779277121052837
Pm abs pres	30.11636029085383	Bws kick flag	0
Ps abs pres	29.95808823646971	Vm C kick flag	0
Vm(std)	36.30434612283541	not in use	NA
Vwc(std)	5.50719	Wa2	.0019625
Vwsg(std)	.70725	Wa5	0
Bws	.1461575121652505	K1 constant	.04707
vs velocity	57.23228821468709	K2 constant	.04715
vol rate	26711.91358358461	Tstd abs temp	527.67
run time min.	60	container 1	3.038999999999997D-02
XI isokinetic	98.62490004518743	container 2	2.484803749990571D-02
Qa vol rate	52610.38600189799	container 3	NA
md mass dry	5.523803749990569D-02	container 4	15
mw mass wet	5.523803749990569D-02	container 5	NA
XEA	56.76146531939914	not in use	NA

unit #2

PLA2

run 2

15:27:59

06-15-1987

Page 1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

CO2 avg.	10.4	pmnd	3.955833269966886
XO2 avg.	8.833333333333333	parw	3.955833269966886
NO avg.	0	ced	1.625206685830415D-02
stack area	15.32071832265625	cew	1.625206685830415D-02
Vm avg. DGM	41.792	ced50%	.0184979433588628
Dp avg. delta p	.7333333333333333	cew50%	.0184979433588628
avg. temp	448.8333333333333	ced12	1.875238483650479D-02
avg. delta H	1.851666666666667	cew12	1.875238483650479D-02
tmi avg. temp	101.8333333333333	ced7	1.872130361373205D-02
tp avg. temp	99.91666666666667	cew7	1.872130361373205D-02
CO2 avg.	80.76666666666667	saturation flag	-1
Md mole wt. dry	30.01733334163825	Bws saturated	.1595899111659054
Ms mole wt.	28.09948818119513	Vm corrected	41.792
area nozzle	3.51280193415625D-04	total # points	12
temp meter	100.875	Vf impingers	1262
Tm abs temp	560.545	Vi impingers	1114
abs temp	908.5033333333333	sqr(Dp) avg.	.8478833877467027
abs pre	30.13615195696635	Bws kick flag	0
Ps abs pre	29.95955882466376	Vm C kick flag	0
Va(std)	39.66480843599196	not in use	NA
Vc(std)	6.96636	Wa2	.0019625
Vwsg(std)	.5658	Wa5	0
Bws	.1595899111659054	K1 constant	.04707
velocity	63.25241044705001	K2 constant	.04715
vol rate	28418.97560553189	Tstd abs temp	527.67
run time min.	60	container 1	.03128
TI isokinetic	101.2814703368752	container 2	1.049803749990718D-02
vol rate	58144.34182129756	container 3	NA
md mass dry	4.177803749990719D-02	container 4	12
mw mass wet	4.177803749990719D-02	container 5	NA
EA	70.72853120904214	not in use	NA

UNIT #2

XN2 avg.	11.433333333333333	pmrd	6.970056641344015
XO2 avg.	8.533333333333333	pmrw	6.970056641344015
XDO avg.	0	csd	2.7891447517351340-02
As stack area	15.32071832265625	csw	2.7891447517351340-02
Vm avg. DBM	41.904	csd50%	3.1244825664015080-02
Dp avg. delta p	.7616666666666667	csw50%	3.1244825664015080-02
ts avg. temp	451.3333333333333	ced12	2.8770547582368150-02
DH avg. delta H	1.916666666666667	csw12	2.8770547582368150-02
tmi avg. temp	89	ced7	3.1349686399762570-02
tmo avg. temp	89.5	csw7	3.1349686399762570-02
XN2 avg.	79.83333333333333	saturation flag	-1
Md mole wt. dry	30.20266667306423	Bws saturated	.147369669678075
Ms mole wt.	28.4043637162631	Vm corrected	41.904
An area nozzle	3.518801934156250-04	total # points	12
ts temp meter	89.75	Vf impingers	1283
Tm abs temp	549.42	Vi impingers	1146
Ts abs temp	911.0033333333333	sqv(Dp) avg.	.863974970105123
Fm abs pre	30.140931368596	Bws kick flag	0
Ps abs pre	29.95147058959651	Vm C kick flag	0
Vm(std)	40.58285314591153	not in use	NA
Vmc(std)	6.44859	Wa2	.0019625
Vwag(std)	.5658	Wa5	0
Bws	.147369669678075	K1 constant	.04707
vs velocity	64.20282517269598	K2 constant	.04715
Qs vol rate	29177.2458076676	Tstd abs temp	527.67
rt time min.	60	container 1	4.991000000000001D-02
Xi isokinetic	100.9325714585557	container 2	.0234480374999072
Qa vol rate	59018.00399937716	container 3	NA
md mass dry	7.335803749990721D-02	container 4	12
mw mass wet	7.335803749990721D-02	container 5	NA
WEA	68.03444305594532	not in use	NA

APPENDIX B-1
EPA METHODS 1-5

METHOD 1.—SAMPLE AND VELOCITY TRAVERSES FOR STATIONARY SOURCES

1. Principle and Applicability

1.1 Principle. To aid in the representative measurement of pollutant emissions and/or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

1.2 Applicability. This method is applicable to flowing gas streams in ducts, stacks, and flues. The method cannot be used when: (1) flow is cyclonic or swirling (see Section 2.4), (2) a stack is smaller than about 0.30 meter (12 in.) in diameter, or 0.071 m² (113 in.²) cross-sectional area, or (3) the measurement site is less than two stack or duct diameters downstream or less than a half diameter upstream from a flow disturbance.

The requirements of this method must be considered before construction of a new facility from which emissions will be measured; failure to do so may require subsequent alterations to the stack or deviation from the standard procedure. Cases involving variants are subject to approval by the Administrator, U.S. Environmental Protection Agency.

2. Procedure

2.1 Selection of Measurement Site. Sampling or velocity measurement is performed at a site located at least eight stack or duct diameters downstream and two diameters upstream from any flow disturbance such as a bend, expansion, or contraction in the stack, or from a visible flame. If necessary, an alternative location may be selected, at a position at least two stack or duct diameters downstream and a half diameter upstream from any flow disturbance. For a rectangular cross section, an equivalent diameter (D_e) shall be calculated from the following equation, to determine the upstream and downstream distances:

$$D_e = \frac{2 LW}{L+W}$$

where L=length and W=width.

2.2 Determining the Number of Traverse Points

2.2.1 Particulate Traverses. When the eight- and two-diameter criterion can be met, the minimum number of traverse points shall be: (1) twelve, for circular or rectangular stacks with diameters (or equivalent diameters) greater than 0.61 meter (24 in.); (2) eight, for circular stacks with diameters between 0.30 and 0.61 meter (12-24 in.); (3) nine, for rectangular stacks with equivalent diameters between 0.30 and 0.61 meter (12-24 in.).

When the eight- and two-diameter criterion cannot be met, the minimum number of traverse points is determined from Figure 1-1. Before referring to the figure, however, determine the distances from the chosen

measurement site to the nearest upstream and downstream disturbances, and divide each distance by the stack diameter or equivalent diameter, to determine the distance in terms of the number of duct diameters. Then, determine from Figure 1-1 the minimum number of traverse points that corresponds: (1) to the number of duct diameters upstream; and (2) to the number of diameters downstream. Select the higher of the two minimum numbers of traverse points, or a greater value, so that for circular stacks the number is a multiple of 4, and for rectangular stacks, the number is one of those shown in Table 1-1.

TABLE 1-1 CROSS-SECTION LAYOUT FOR RECTANGULAR STACKS

Number of Traverse Points	Stack Layout
9	3x3
12	4x3
16	4x4
20	5x4
25	5x5
30	6x5
36	6x6
42	7x6
49	7x7




Figure 1-1. Minimum number of traverse points for particulate traverses.




Figure 1-2. Minimum number of traverse points for velocity (nonparticulate) traverses.

2.2.2 Velocity (Non-Particulate) Traverses. When velocity or volumetric flow rate is to be determined (but not particulate matter), the same procedure as that for particulate traverses (Section 2.2.1) is followed, except that Figure 1-2 may be used instead of Figure 1-1.

2.3 Cross-sectional Layout and Location of Traverse Points.

2.3.1 Circular Stacks. Locate the traverse points on two perpendicular diameters according to Table 1-2 and the example shown in Figure 1-3. Any equation (for examples, see Citations 2 and 3 in the Bibliography) that gives the same values as those in Table 1-2 may be used in lieu of Table 1-2.

For particulate traverses, one of the diameters must be in a plane containing the greatest expected concentration variation, e.g., after bends, one diameter shall be in the plane of the bend. This requirement becomes less critical as the distance from the disturbance increases; therefore, other diameter locations may be used, subject to approval of the Administrator.

In addition for stacks having diameters greater than 0.61 m (24 in.) no traverse points shall be located within 2.5 centimeters (1.00 in.) of the stack walls; and for stack diameters equal to or less than 0.61 m (24 in.), no traverse points shall be located within 1.3 cm (0.50 in.) of the stack walls.

To meet these criteria, observe the procedures given below.

2.3.1.1 Stacks With Diameters Greater Than 0.61 m (24 in.). When any of the traverse points as located in Section 2.3.1 fall within 2.5 cm (1.00 in.) of the stack walls, relocate them away from the stack walls to: (1) a distance of 2.5 cm (1.00 in.); or (2) a distance equal to the nozzle inside diameter, whichever is larger. These relocated traverse points (on each end of a diameter) shall be the "adjusted" traverse points.

Whenever two successive traverse points are combined to form a single adjusted traverse point, treat the adjusted point as two separate traverse points, both in the sampling (or velocity measurement) procedure, and in recording the data.




Figure 1-3. Example showing circular stack cross section divided into 12 equal areas, with location of traverse points indicated.

TABLE 1-2. LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter—											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.0	6.7	4.4	3.2	2.0	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	25.4	23.0	14.0	10.9	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		78.0	29.0	18.4	14.0	11.8	9.9	8.5	7.5	6.7	6.0	5.6
4		83.3	70.4	32.3	22.0	17.7	14.6	12.5	10.8	9.7	8.7	7.9
5			85.4	57.7	34.2	25.0	20.1	16.8	14.6	12.9	11.8	10.8
6			88.8	65.6	38.5	28.8	22.0	18.8	16.8	15.2	14.0	13.2
7				89.5	77.4	44.4	33.9	26.3	23.8	21.4	19.8	18.1
8				90.8	86.4	73.0	43.4	37.5	33.9	31.0	27.9	25.4
9					91.8	82.3	73.1	62.5	58.2	53.8	49.2	45.0
10						87.4	78.9	71.7	61.8	58.9	51.5	47.2
11							85.3	86.4	78.0	70.4	61.2	56.3
12								87.9	82.1	82.1	78.4	67.7
13									84.3	87.3	81.2	75.0
14										88.2	81.8	75.8
15											88.1	81.5
16												88.4
17												
18												
19												
20												
21												
22												
23												
24												

2.3.1.2 Stacks With Diameters Equal to or Less Than 0.61 m (24 in.). Follow the procedure in Section 2.3.1.1, noting only that any "adjusted" points should be relocated away from the stack walls to: (1) a distance of 1.3 cm (0.50 in.); or (2) a distance equal to the nozzle inside diameter, whichever is larger.

2.3.2 Rectangular Stacks. Determine the number of traverse points as explained in Sections 2.1 and 2.2 of this method. From Table 1-1, determine the grid configuration. Divide the stack cross-section into as many equal rectangular elemental areas as traverse points, and then locate a traverse point at the centroid of each equal area according to the example in Figure 1-4.

If the tester desires to use more than the minimum number of traverse points, expand the "minimum number of traverse points" matrix (see Table 1-1) by adding the extra traverse points along one or the other or both legs of the matrix; the final matrix need not be balanced. For example, if a 4x3 "minimum number of points" matrix were expanded to 36 points, the final matrix could be 9x4 or 12x3, and would not necessarily have to be 6x6. After constructing the final matrix, divide the stack cross-section into as many equal rectangular, elemental areas as traverse points, and locate a traverse point at the centroid of each equal area.

The situation of traverse points being too close to the stack walls is not expected to arise with rectangular stacks. If this problem should ever arise, the Administrator must be contacted for resolution of the matter.

2.4 Verification of Absence of Cyclonic Flow. In most stationary sources, the direction of stack gas flow is essentially parallel to the stack walls. However, cyclonic flow may exist (1) after such devices as cyclones and inertial demisters following venturi scrubbers, or (2) in stacks having tangential inlets or other duct configurations which tend to induce swirling; in these instances, the presence or absence of cyclonic flow at the sampling location must be determined. The following techniques are acceptable for this determination.




Figure 1-4. Example showing rectangular stack cross section divided into 12 equal areas, each a traverse point at centroid of each area.

Level and zero the manometer. Connect a Type S pitot tube to the manometer. Position the Type S pitot tube at each traverse point, in succession, so that the planes of the face openings of the pitot tube are perpendicular to the stack cross-sectional plane; when the Type S pitot tube is in this position, it is at "0° reference." Note the differential pressure (Δp) reading at each traverse point. If a null (zero) pitot reading is obtained at 0° reference at a given traverse point, an acceptable flow condition exists at that point. If the pitot reading is not zero at 0° reference, rotate the pitot tube (up to $\pm 90^\circ$ yaw angle), until a null reading is obtained. Carefully determine and record the value of the rotation angle (α) to the nearest degree. After the null technique has been applied at each traverse point, calculate the average of the absolute values of α ; assign a value of 0° to those points for which no rotation was required, and include these in the overall average. If the average value of α is greater than 10°, the overall flow condition in the stack is unacceptable and alternative methodology, subject to the approval of the Administrator, must be used to perform accurate sample and velocity traverses.

3. Bibliography

1. Determining Dust Concentration in a Gas Stream. ASMOE Performance Test Code No. 27. New York, 1987.
2. Devorkin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District, Los Angeles, CA, November 1963.
3. Methods for Determination of Velocity, Volume, Dust and Mist Content of Gases. Western Precipitation Division of Joy Manufacturing Co. Los Angeles, CA. Bulletin WP-50, 1968.
4. Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Book of ASTM Standards, Part 23. ASTM Designation D-2928-71. Philadelphia, Pa. 1971.
5. Hanson, H. A., et al. Particulate Sampling Strategies for Large Power Plants Including Nonuniform Flow. USEPA, ORD, ESRL, Research Triangle Park, N.C. EPA-600/2-76-170, June 1976.
6. Entropy Environmentalists, Inc. Determination of the Optimum Number of Sampling Points: An Analysis of Method 1 Criteria. Environmental Protection Agency, Research Triangle Park, N.C. EPA Contract No. 68-01-3172, Task 7.
7. Hanson, H.A., R.J. Davini, J.K. Morgan, and A.A. Iversen. Particulate Sampling Strategies for Large Power Plants Including Nonuniform Flow. U.S. Environmental Protection Agency, Research Triangle Park, N.C. Publication No. EPA-600/2-76-170, June 1976, 380 p.
8. Brooks, E.P., and R.L. Williams. Flow and Gas Sampling Manual. U.S. Environmental Protection Agency, Research Triangle Park, N.C. Publication No. EPA-600/2-76-203, July 1976, 83 p.
9. Entropy Environmentalists, Inc. Traverse Point Study. EPA Contract No. 68-02-3172, June 1977, 19 p.
10. Brown, J. and K. Yu. Test Report: Particulate Sampling Strategy in Circular Ducts. Emission Measurement Branch, Emission Standards and Engineering Division. U.S. Environmental Protection Agency, Research Triangle Park, N.C. 27711, July 31, 1980, 12 p.
11. Hawkesley, P.G.W., S. Badnoch, and J.H. Blackett. Measurement of Solids in Flue Gases. Leatherhead, England. The British Coal Utilization Research Association, 1961, p. 129-133.
12. Knapp, K.T. The Number of Sampling Points Needed for Representative Source Sampling. In: Proceedings of the Fourth National Conference on Energy and the Environment. Theodore, L. et al. (ed.). Dayton.

SEE PROPOSED AMENDMENT NEXT PAGE

METHOD 2—DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE (TYPE S PITOT TUBE)

1. Principle and Applicability

1.1 Principle. The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Stauscheibe or reverse type) pitot tube.

1.2 Applicability. This method is applicable for measurement of the average velocity of a gas stream and for quantifying gas flow.

This procedure is not applicable at measurement sites which fail to meet the criteria of Method 1, Section 2.1. Also, the method cannot be used for direct measurement in cyclonic or swirling gas streams; Section 2.4 of Method 1 shows how to determine cyclonic or swirling flow conditions. When unacceptable conditions exist, alternative procedures, subject to the approval of the Administrator, U.S. Environmental Protection Agency, must be employed to make accurate flow rate determinations; examples of such alternative procedures are: (1) to install straightening vanes; (2) to calculate the total volumetric flow rate stoichiometrically, or (3) to move to another measurement site at which the flow is acceptable.

2. Apparatus

Specifications for the apparatus are given below. Any other apparatus that has been demonstrated (subject to approval of the Administrator) to be capable of meeting the specifications will be considered acceptable.

2.1 Type S Pitot Tube. The Type S pitot tube (Figure 2-1) shall be made of metal tubing (e.g. stainless steel). It is recommended that the external tubing diameter (dimension D , Figure 2-2b) be between 0.48 and 0.95 centimeters ($\frac{1}{4}$ and $\frac{1}{2}$ inch). There shall be an equal distance from the base of each leg of the pitot tube to its face-opening plane (dimensions P_1 and P_2 , Figure 2-2b); it is recommended that this distance be between 1.05 and 1.50 times the external tubing diameter. The face openings of the pitot tube shall, preferably, be aligned as shown in Figure 2-2; however, slight misalignments of the openings are permissible (see Figure 2-3).

The Type S pitot tube shall have a known coefficient, determined as outlined in Section 4. An identification number shall be assigned to the pitot tube; this number shall be permanently marked or engraved on the body of the tube.




Figure 2-1. Type S pitot tube manometer assembly.




Figure 2-2. Properly constructed Type B pitot tube, shown in: (a) end view; face opening planes perpendicular to transverse axis; (b) top view; face opening planes parallel to longitudinal axis; (c) side view; both legs of equal length and centerlines coincident, when viewed from both sides. Baseline coefficient values of 0.84 may be assigned to pitot tubes constructed this way.

taken, as above, for the last two back purges at which suitably high Δp readings are observed.

2.2 Differential Pressure Gauge. An inclined manometer or equivalent device is used. Most sampling trains are equipped with a 10-in. (water column) inclined-vertical manometer, having 0.01-in. H₂O divisions on the 0-to 1-in. inclined scale, and 0.1-in. H₂O divisions on the 1- to 10-in. vertical scale. This type of manometer (or other gauge of equivalent sensitivity) is satisfactory for the measurement of Δp values as low as 1.3 mm (0.05 in.) H₂O. However, a differential pressure gauge of greater sensitivity shall be used (subject to the approval of the Administrator), if any of the following is found to be true: (1) the arithmetic average of all Δp readings at the traverse points in the stack is less than 1.3 mm (0.05 in.) H₂O; (2) for traverses of 12 or more points, more than 10 percent of the individual Δp readings are below 1.3 mm (0.05 in.) H₂O; (3) for traverses of fewer than 12 points, more than one Δp reading is below 1.3 mm (0.05 in.) H₂O. Citation 18 in Section 6 describes commercially available instrumentation for the measurement of low-range gas velocities.

As an alternative to criteria (1) through (3) above, the following calculation may be performed to determine the necessity of using a more sensitive differential pressure gauge:

$$T = \frac{\sum_{i=1}^n \sqrt{\Delta p_i + K}}{\sum_{i=1}^n \sqrt{\Delta p_i}}$$

where:

Δp_i = Individual velocity head reading at a traverse point, mm H₂O (in. H₂O).

n = Total number of traverse points.

K = 0.13 mm H₂O when metric units are used and 0.005 in. H₂O when English units are used.

If T is greater than 1.05, the velocity head data are unacceptable and a more sensitive differential pressure gauge must be used.

Note: If differential pressure gauges other than inclined manometers are used (e.g., magnetic gauges), their calibration must be checked after each test series. To check

the calibration of a differential pressure gauge, compare Δp readings of the gauge with those of a gauge-oil manometer at a minimum of three points, approximately representing the range of Δp values in the stack. If, at each point, the values of Δp read by the differential pressure gauge and gauge-oil manometer agree to within 5 percent, the differential pressure gauge shall be considered to be in proper calibration. Otherwise, the test series shall either be voided, or procedures to adjust the measured Δp values and final results shall be used subject to the approval of the Administrator.

2.3 Temperature Gauge. A thermocouple, liquid-filled bulb thermometer, bimetallic thermometer, mercury-in-glass thermometer, or other gauge, capable of measuring temperature to within 1.5 percent of the minimum absolute stack temperature shall be used. The temperature gauge shall be attached to the pitot tube such that the sensor tip does not touch any metal; the gauge shall be in an interference-free arrangement with respect to the pitot tube face openings (see Figure 2-1 and also Figure 2-7 in Section 4). Alternate positions may be used if the pitot tube-temperature gauge system is calibrated according to the procedure of Section 4. Provided that a difference of not more than 1 percent in the average velocity measurement is introduced, the temperature gauge need not be attached to the pitot tube; this alternative is subject to the approval of the Administrator.

2.4 Pressure Probe and Gauge. A piezometer tube and mercury- or water-filled U-tube manometer capable of measuring stack pressure to within 2.5 mm (0.1 in.) Hg is used. The static tap of a standard type pitot tube or one leg of a Type S pitot tube with the face opening planes positioned parallel to the gas flow may also be used as the pressure probe.

2.5 Barometer. A mercury, aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg) may be used. In many cases, the barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the weather station and the sampling point shall be applied at a rate of minus 2.5 mm (0.1 in.) Hg per 30-meter (100 feet) elevation increase or vice-versa for elevation decrease.

2.6 Gas Density Determination Equipment. Method 3 equipment, if needed (see Section 3.6), to determine the stack gas dry molecular weight, and Reference Method 4 or Method 5 equipment for moisture content determination; other methods may be used subject to approval of the Administrator.

2.7 Calibration Pitot Tube. When calibration of the Type S pitot tube is necessary (see Section 4), a standard pitot tube is used as a reference. The standard pitot tube shall, preferably, have a known coefficient, obtained either (1) directly from the National Bureau of Standards, Route 270, Quince Orchard Road, Gaithersburg, Maryland, or (2) by calibration against another standard pitot tube with an NBS-traceable coefficient. Alternatively, a standard pitot tube designed according to the criteria given in 2.7.1 through 2.7.5 below and illustrated in Figure 2-4 (see also Citations 7, 8, and 17 in Section 6) may be used. Pitot tubes designed according to these specifications will have baseline coefficients of about 0.99 ± 0.01 .

2.7.1 Hemispherical (shown in Figure 2-4), ellipsoidal, or conical tip.

2.7.2 A minimum of six diameters straight run (based upon D , the external diameter of the tube) between the tip and the static pressure holes.

2.7.3 A minimum of eight diameters straight run between the static pressure holes and the centerline of the external tube, following the 90 degree bend.

2.7.4 Static pressure holes of equal size (approximately 0.1 D), equally spaced in a piezometer ring configuration.

2.7.5 Ninety degree bend, with curved or mitered junction.

2.8 Differential Pressure Gauge for Type S Pitot Tube Calibration. An inclined manometer or equivalent is used. If the single-velocity calibration technique is employed (see Section 4.1.2.3), the calibration differential pressure gauge shall be readable to the nearest 0.13 mm H₂O (0.005 in. H₂O). For multiveLOCITY calibrations, the gauge shall be readable to the nearest 0.13 mm H₂O (0.005 in. H₂O) for Δp values between 1.3 and 25 mm H₂O (0.05 and 1.0 in. H₂O), and to the nearest 1.3 mm H₂O (0.05 in. H₂O) for Δp values above 25 mm H₂O (1.0 in. H₂O). A special, more sensitive gauge will be required to read Δp values below 1.3 mm H₂O (0.05 in. H₂O) (see Citation 18 in Section 6).




Figure 2-3. Types of face-opening measurement that can result from field use or improper construction of Type S pitot tubes. These will not affect the baseline value of C_{pts} so long as α_1 and α_2 10° , β_1 and β_2 5° , z 0.32 cm ($1/8$ in.) and w 0.08 cm ($1/32$ in.) (caption 11 in Section 6).

A standard pitot tube may be used instead of a Type S, provided that it meets the specifications of Sections 2.7 and 4.2; note, however, that the static and impact pressure holes of standard pitot tubes are susceptible to plugging in particulate-laden gas streams. Therefore, whenever a standard pitot tube is used to perform a traverse, adequate proof must be furnished that the openings of the pitot tube have not plugged up during the traverse period; this can be done by taking a velocity head (Δp) reading at

the final traverse point, cleaning out the impact and static holes of the standard pitot tube by "back-purging" with pressurized air, and then taking another Δp reading. If the Δp readings made before and after the air purge are the same (± 5 percent), the traverse is acceptable. Otherwise, reject the run. Note that if Δp at the final traverse point is unsuitably low, another point may be selected. If "back-purging" at regular intervals is part of the procedure, then comparative Δp readings shall be




Figure 2-4. Standard pitot tube design specifications.

3. Procedure

3.1 Set up the apparatus as shown in Figure 2-1. Capillary tubing or surge tanks installed between the manometer and pitot tube may be used to dampen Δp fluctuations. It is recommended, but not required, that a pretest leak-check be conducted, as follows: (1) blow through the pitot impact opening until at least 7.6 cm (3 in.) H₂O velocity pressure registers on the manometer; then, close off the impact opening. The pressure shall remain stable for at least 15 seconds; (2) do the same for the static pressure side, except using suction to obtain the minimum of 7.6 cm (3 in.) H₂O. Other leak-check procedures, subject to the approval of the Administrator, may be used.


3.2 Level and zero the manometer. Because the manometer level and zero may

drift due to vibrations and temperature changes, make periodic checks during the traverse. Record all necessary data as shown in the example data sheet (Figure 2-5).


3.3 Measure the velocity head and temperature at the traverse points specified by Method 1. Ensure that the proper differential pressure gauge is being used for the range of Δp values encountered (see Section 2.2). If it is necessary to change to a more sensitive gauge, do so, and remeasure the Δp and temperature readings at each traverse point. Conduct a post-test leak-check (mandatory), as described in Section 3.1 above, to validate the traverse run.

3.4 Measure the static pressure in the stack. One reading is usually adequate.

3.5 Determine the atmospheric pressure.



A. BOTTOM VIEW, SHOWING MINIMUM PITOT-NOZZLE SEPARATION.



B. SIDE VIEW, TO PREVENT PITOT TUBE FROM INTERFERING WITH GAS FLOW STREAMLINES APPROACHING THE NOZZLE, THE IMPACT PRESSURE OPENING PLANE OF THE PITOT TUBE SHALL BE EVEN WITH OR ABOVE THE NOZZLE ENTRY PLANE.




Figure 2-7. Proper thermocouple placement to prevent interference; D_1 between 0.48 and 0.95 cm (3/16 and 3/8 in.).




Figure 2-8. Minimum pitot-sample probe separation needed to prevent interference; D_1 between 0.48 and 0.95 cm (3/16 and 3/8 in.).

4.1.1 Type S Pitot Tube Assemblies. During sample and velocity traverses, the isolated Type S pitot tube is not always used; in many instances, the pitot tube is used in combination with other source-sampling components (thermocouple, sampling probe, nozzle) as part of an "assembly." The presence of other sampling components can sometimes affect the baseline value of the Type S pitot tube coefficient (Citation 9 in Section 6); therefore an assigned (or otherwise known) baseline coefficient value may or may not be valid for a given assembly. The baseline and assembly coefficient values will be identical only when the relative placement of the components in the assembly is such that aerodynamic interference effects are eliminated. Figures 2-6 through 2-8 illustrate interference-free component arrangements for Type S pitot tubes having external tubing diameters between 0.48 and 0.95 cm (3/16 and 3/8 in.). Type S pitot tube assemblies that fail to meet any or all of the specifications of Figures 2-6 through 2-8 shall be calibrated according to the procedure outlined in Sections 4.1.2 through 4.1.5 below, and prior to calibration, the values of the intercomponent spacings (pitot-nozzle, pitot-thermocouple, pitot-probe sheath) shall be measured and recorded.

NOTE: Do not use any Type S pitot tube assembly which is constructed such that the impact pressure opening plane of the pitot tube is below the entry plane of the nozzle (see Figure 2-6b).

4.1.2 Calibration Setup. If the Type S pitot tube is to be calibrated, one leg of the tube shall be permanently marked A, and the other, B. Calibration shall be done in a flow system having the following essential design features:

4.1.2.1 The flowing gas stream must be confined to a duct of definite cross-sectional area, either circular or rectangular. For circular cross-sections, the minimum duct diameter shall be 30.5 cm (12 in.); for rectangular cross-sections, the width (shorter side) shall be at least 25.4 cm (10 in.).

4.1.2.2 The cross-sectional area of the calibration duct must be constant over a distance of 10 or more duct diameters. For a rectangular cross-section, use an equivalent diameter, calculated from the following equation, to determine the number of duct diameters:

$$D = \frac{2LW}{L+W}$$

Equation 2-1

where:

D = Equivalent diameter

L = Length

W = Width

To ensure the presence of stable, fully developed flow patterns at the calibration site, or "test section," the site must be located at least eight diameters downstream and two diameters upstream from the nearest disturbances.

NOTE: The eight- and two-diameter criteria are not absolute; other test section locations may be used (subject to approval of the Administrator), provided that the flow at the test site is stable and demonstrably parallel to the duct axis.

4.1.2.3 The flow system shall have the capacity to generate a test-section velocity around 915 m/min (3,000 ft/min). This velocity must be constant with time to guarantee steady flow during calibration. Note that Type S pitot tube coefficients obtained by single-velocity calibration at 915 m/min (3,000 ft/min) will generally be valid to within ± 3 percent for the measurement of velocities above 305 m/min (1,000 ft/min) and to within ± 5 to 6 percent for the measurement of velocities between 180 and 305 m/min (600 and 1,000 ft/min). If a more precise correlation between C_p and velocity is desired, the flow system shall have the capacity to generate at least four distinct, time-invariant test-section velocities covering the velocity range from 180 to 1,525 m/min (600 to 5,000 ft/min), and calibration data shall be taken at regular velocity intervals over this range (see Citations 9 and 14 in Section 6 for details).

4.1.2.4 Two entry ports, one each for the standard and Type S pitot tubes, shall be cut in the test section: the standard pitot entry port shall be located slightly downstream of the Type S port, so that the standard and Type S impact openings will lie in the same cross-sectional plane during calibration. To facilitate alignment of the pitot tubes during calibration, it is advisable that the test section be constructed of plexiglas or some other transparent material.

4.1.3 Calibration Procedure. Note that this procedure is a general one and must not be used without first referring to the special considerations presented in Section 4.1.2. Note also that this procedure applies only to single-velocity calibration. To obtain calibration data for the A and B sides of the Type S pitot tube, proceed as follows:

4.1.3.1 Make sure that the manometer is properly filled and that the oil is free from contamination and is of the proper density. Inspect and leak-check all pitot lines; repair or replace if necessary.

PITOT TUBE IDENTIFICATION NUMBER: _____ DATE: _____

CALIBRATED BY: _____

"A" SIDE CALIBRATION				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P_{(s)}$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(A)$
1				
2				
3				
			\bar{C}_p (SIDE A)	

"B" SIDE CALIBRATION				
RUN NO.	ΔP_{std} cm H ₂ O (in. H ₂ O)	$\Delta P_{(s)}$ cm H ₂ O (in. H ₂ O)	$C_p(s)$	DEVIATION $C_p(s) - \bar{C}_p(B)$
1				
2				
3				
			\bar{C}_p (SIDE B)	

$$\text{AVERAGE DEVIATION} = \frac{1}{3} \sum |C_p(s) - \bar{C}_p(A \text{ OR } B)| \quad \leftarrow \text{MUST BE } < 0.01$$

$$|\bar{C}_p(\text{SIDE A}) - \bar{C}_p(\text{SIDE B})| \quad \leftarrow \text{MUST BE } < 0.01$$

Figure 2-9. Pitot tube calibration data.

4.1.3.2 Level and zero the manometer. Turn on the fan and allow the flow to stabilize. Seal the Type S entry port.

4.1.3.3 Ensure that the manometer is level and zeroed. Position the standard pitot tube at the calibration point (determined as outlined in Section 4.1.2.1), and align the tube so that its tip is pointed directly into the flow. Particular care should be taken in aligning the tube to avoid yaw and pitch angles. Make sure that the entry port surrounding the tube is properly sealed.

4.1.3.4 Read ΔP_{std} and record its value in a data table similar to the one shown in Figure 2-9. Remove the standard pitot tube from the duct and disconnect it from the manometer. Seal the standard entry port.

4.1.3.5 Connect the Type S pitot tube to the manometer. Open the Type S entry port. Check the manometer level and zero. Insert and align the Type S pitot tube so that its A side impact opening is at the same

point as was the standard pitot tube and is pointed directly into the flow. Make sure that the entry port surrounding the tube is properly sealed.

4.1.3.6 Read ΔP_s and enter its value in the data table. Remove the Type S pitot tube from the duct and disconnect it from the manometer.

4.1.3.7 Repeat steps 4.1.3.3 through 4.1.3.6 above until three pairs of ΔP readings have been obtained.

4.1.3.8 Repeat steps 4.1.3.3 through 4.1.3.7 above for the B side of the Type S pitot tube.

4.1.3.9 Perform calculations, as described in Section 4.1.4 below.

4.1.4 Calculations.

4.1.4.1 For each of the six pairs of ΔP readings (i.e., three from side A and three from side B) obtained in Section 4.1.3 above calculate the value of the Type S pitot tube coefficient as follows:

$$C_{meas} = C_{std} \sqrt{\frac{\Delta P_{meas}}{\Delta P_{std}}}$$

Equation 2-2

where:

C_{meas} = Type S pitot tube coefficient

C_{std} = Standard pitot tube coefficient; use 0.99 if the coefficient is unknown and the tube is designed according to the criteria of Sections 2.7.1 to 2.7.3 of this method.

ΔP_{meas} = Velocity head measured by the standard pitot tube, cm H₂O (in. H₂O)

ΔP_{std} = Velocity head measured by the Type S pitot tube, cm H₂O (in. H₂O)

4.1.4.2 Calculate C_a (side A), the mean A-side coefficient, and C_b (side B), the mean B-side coefficient; calculate the difference between these two average values.

4.1.4.3 Calculate the deviation of each of the three A-side values of C_{meas} from C_a (side A), and the deviation of each B-side value of C_{meas} from C_b (side B). Use the following equation:

$$\text{Deviation} = C_{meas} - \bar{C}_s (\text{A or B})$$

Equation 2-3

4.1.4.4 Calculate δ , the average deviation from the mean, for both the A and B sides of the pitot tube. Use the following equation:

$$\delta (\text{side A or B}) = \frac{\sum |C_{meas} - \bar{C}_s (\text{A or B})|}{3}$$

Equation 2-4

4.1.4.5 Use the Type S pitot tube only if the values of δ (side A) and δ (side B) are less than or equal to 0.01 and if the absolute value of the difference between C_a (A) and C_b (B) is 0.01 or less.

4.1.5 Special considerations.

4.1.5.1 Selection of calibration point.

4.1.5.1.1 When an isolated Type S pitot tube is calibrated, select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The Type S pitot coefficients so obtained, i.e., C_a (side A) and C_b (side B), will be valid, so long as either: (1) the isolated pitot tube is used; or (2) the pitot tube is used with other components (nozzle, thermocouple, sample probe) in an arrangement that is free from aerodynamic interference effects (see Figures 2-6 through 2-8).

4.1.5.1.2 For Type S pitot tube-thermocouple combinations (without sample probe), select a calibration point at or near the center of the duct, and follow the procedures outlined in Sections 4.1.3 and 4.1.4 above. The coefficients so obtained will be valid so long as the pitot tube-thermocouple combination is used by itself or with other components in an interference-free arrangement (Figures 2-6, and 2-8).

4.1.5.1.3 For assemblies with sample probes, the calibration point should be located at or near the center of the duct; however, insertion of a probe sheath into a small duct may cause significant cross-sectional area blockage and yield incorrect coefficient values (Citation 9 in Section 6). Therefore, to minimize the blockage effect, the calibration point may be a few inches

off-center if necessary. The actual blockage effect will be negligible when the theoretical blockage, as determined by a projected-area model of the probe sheath, is 2 percent or less of the duct cross-sectional area for assemblies without external sheaths (Figure 2-10a), and 3 percent or less for assemblies with external sheaths (Figure 2-10b).

4.1.5.2 For those probe assemblies in which pitot tube-nozzle interference is a factor (i.e., those in which the pitot-nozzle separation distance fails to meet the specification illustrated in Figure 2-6a), the value of C_{meas} depends upon the amount of free-space between the tube and nozzle, and therefore is a function of nozzle size. In these instances, separate calibrations shall be performed with each of the commonly used nozzle sizes in place. Note that the single-velocity calibration technique is acceptable for this purpose, even though the larger nozzle sizes (>0.635 cm or 1/4 in.) are not ordinarily used for isokinetic sampling at velocities around 915 m/min (3,000 ft/min), which is the calibration velocity; note also that it is not necessary to draw an isokinetic sample during calibration (see Citation 19 in Section 6).

4.1.5.3 For a probe assembly constructed such that its pitot tube is always used in the same orientation, only one side of the pitot tube need be calibrated (the side which will face the flow). The pitot tube must still meet the alignment specifications of Figure 2-2 or 2-3, however, and must have an average deviation (δ) value of 0.01 or less (see Section 4.1.4.4).




Figure 2-10. Projected-area models for typical pitot tube assemblies.

Figure 2-10. Projected-area models for typical pitot tube assemblies.

4.1.6 Field Use and Recalibration.

4.1.6.1 Field Use.

4.1.6.1.1 When a Type S pitot tube (isolated tube or assembly) is used in the field, the appropriate coefficient value (whether assigned or obtained by calibration) shall be used to perform velocity calculations. For calibrated Type S pitot tubes, the A side coefficient shall be used when the A side of the tube faces the flow, and the B side coefficient shall be used when the B side faces the flow; alternatively, the arithmetic average of the A and B side coefficient values may be used, irrespective of which side faces the flow.

4.1.6.1.2 When a probe assembly is used to sample a small duct (12 to 36 in. in diameter), the probe sheath sometimes blocks a significant part of the duct cross-section, causing a reduction in the effective value of $C_{p,avg}$. Consult Citation 9 in Section 6 for details. Conventional pitot-sampling probe assemblies are not recommended for use in ducts having inside diameters smaller than 12 inches (Citation 16 in Section 6).

4.1.6.2 Recalibration.

4.1.6.2.1 Isolated Pitot Tubes. After each field use, the pitot tube shall be carefully reexamined in top, side, and end views. If the pitot face openings are still aligned within the specifications illustrated in Figure 2-2 or 2-3, it can be assumed that the baseline coefficient of the pitot tube has not changed. If, however, the tube has been damaged to the extent that it no longer meets the specifications of Figure 2-2 or 2-3, the damage shall either be repaired to restore proper alignment of the face openings or the tube shall be discarded.

4.1.6.2.2 Pitot Tube Assemblies. After each field use, check the face opening alignment of the pitot tube, as in Section

4.1.6.2.1; also, remeasure the intercomponent spacings of the assembly. If the intercomponent spacings have not changed and the face opening alignment is acceptable, it can be assumed that the coefficient of the assembly has not changed. If the face opening alignment is no longer within the specifications of Figures 2-2 or 2-3, either repair the damage or replace the pitot tube (calibrating the new assembly, if necessary). If the intercomponent spacings have changed, restore the original spacings or recalibrate the assembly.

4.2 Standard pitot tube (if applicable). If a standard pitot tube is used for the velocity traverse, the tube shall be constructed according to the criteria of Section 2.7 and shall be assigned a baseline coefficient value of 0.99. If the standard pitot tube is used as part of an assembly, the tube shall be in an interference-free arrangement (subject to the approval of the Administrator).

4.3 Temperature Gauges. After each field use, calibrate dial thermometers, liquid-filled bulb thermometers, thermocouple-potentiometer systems, and other gauges at a temperature within 10 percent of the average absolute stack temperature. For temperatures up to 405° C (761° F), use an ASTM mercury-in-glass reference thermometer, or equivalent, as a reference; alternatively, either a reference thermocouple and potentiometer (calibrated by NBS) or thermometric fixed points, e.g., ice bath and boiling water (corrected for barometric pressure) may be used. For temperatures above 405° C (761° F), use an NBS-calibrated reference thermocouple-potentiometer system or an alternate reference, subject to the approval of the Administrator.

If, during calibration, the absolute temperatures measured with the gauge being calibrated and the reference gauge agree within 1.5 percent, the temperature data taken in the field shall be considered valid. Otherwise, the pollutant emission test shall either be considered invalid or adjustments (if appropriate) of the test results shall be made, subject to the approval of the Administrator.

4.4 Barometer. Calibrate the barometer used against a mercury barometer.

5. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

5.1 Nomenclature.

- A = Cross-sectional area of stack, m^2 (ft^2).
- B_w = Water vapor in the gas stream (from Method 5 or Reference Method 4), proportion by volume.
- C_p = Pitot tube coefficient, dimensionless.
- K_p = Pitot tube constant.

$$34.97 \frac{m}{sec} \left[\frac{(g/g-mole)(mm\ Hg)}{(10^3)(mm\ H_2O)} \right]^{1/2}$$

for the metric system and

$$34.49 \frac{ft}{sec} \left[\frac{(lb\ lb-mole)(in.\ Hg)}{(10^3)(in.\ H_2O)} \right]^{1/2}$$

for the English system.

- M_d = Molecular weight of stack gas, dry basis (see Section 3.6) g/g-mole (lb/lb-mole).
- M_w = Molecular weight of stack gas, wet basis, g/g-mole (lb/lb-mole).
- $= M_d(1 - B_w) = 18.0 B_w$

Equation 2-5

P_{me} = Barometric pressure at measurement site, mm Hg (in. Hg).

P_s = Stack static pressure, mm Hg (in. Hg).

P_a = Absolute stack gas pressure, mm Hg (in. Hg).

$= P_{me} + P_s$

Equation 2-6

P_{std} = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).

Q_{sc} = Dry volumetric stack gas flow rate corrected to standard conditions, dm^3/hr (scf/hr).

t = Stack temperature, °C (°F).

T = Absolute stack temperature, °K (°R).

$= 273 + t$ for metric

Equation 2-7

$= 460 + t$ for English

Equation 2-8

T_{std} = Standard absolute temperature, 293° K (528° R).

v = Average stack gas velocity, m/sec (ft/sec).

h_w = Velocity head of stack gas, mm H₂O (in. H₂O).

3,600 = Conversion factor, sec/hr .

18.0 = Molecular weight of water, g/g-mole (lb/lb-mole).

5.2 Average stack gas velocity.

$$v = K_p C_p (\sqrt{\Delta p}) \dots \sqrt{\frac{T_{std}}{P_a M_d}}$$

Equation 2-9

5.3 Average stack gas dry volumetric flow rate.

$$Q_{sc} = 3,600 A v \left(\frac{T_{std}}{T_a} \right) \left(\frac{P_a}{P_{std}} \right)$$

Equation 2-10

6. Bibliography

1. Mark, L. S. Mechanical Engineers' Handbook. New York, McGraw-Hill Book Co., Inc. 1951.
2. Perry, J. H. Chemical Engineers' Handbook. New York, McGraw-Hill Book Co., Inc. 1960.
3. Shigehara, R. T., W. P. Todd, and W. S. Smith. Significance of Errors in Stack Sampling Measurements. U.S. Environmental Protection Agency, Research Triangle Park, N.C. (Presented at the Annual Meeting of the Air Pollution Control Association, St. Louis, Mo., June 14-19, 1970.)
4. Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Book of ASTM Standards, Part 23, Philadelphia, Pa. 1971. ASTM Designation D-2923-71.
5. Vennard, J. K. Elementary Fluid Mechanics. New York, John Wiley and Sons, Inc. 1947.
6. Fluid Meters—Their Theory and Application. American Society of Mechanical Engineers, New York, N.Y. 1959.
7. ASHRAE Handbook of Fundamentals. 1972, p. 208.
8. Annual Book of ASTM Standards, Part 26, 1974, p. 648.
9. Vollaro, R. P. Guidelines for Type S Pitot Tube Calibration. U.S. Environmental Protection Agency, Research Triangle Park, N.C. (Presented at 1st Annual Meeting, Source Evaluation Society, Dayton, Ohio, September 18, 1973.)
10. Vollaro, R. P. A Type S Pitot Tube Calibration Study. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. July 1974.
11. Vollaro, R. P. The Effects of Impact Opening Misalignment on the Value of the Type S Pitot Tube Coefficient. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. October 1978.
12. Vollaro, R. P. Establishment of a Baseline Coefficient Value for Properly Constructed Type S Pitot Tubes. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November 1978.
13. Vollaro, R. P. An Evaluation of Single-Velocity Calibration Technique as a Means of Determining Type S Pitot Tubes Coefficient. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. August 1978.
14. Vollaro, R. P. The Use of Type S Pitot Tubes for the Measurement of Low Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November 1978.

15. Smith, Marvin L. Velocity Calibration of EPA Type Source Sampling Probe. United Technologies Corporation, Pratt and Whitney Aircraft Division, East Hartford, Conn. 1973.

16. Vollaro, R. F. Recommended Procedure for Sample Traverses in Ducts Smaller than 12 Inches in Diameter. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park N.C. November 1974.

17. Ower, E. and R. C. Pankhurst. The Measurement of Air Flow, 4th Ed., London, Pergamon Press, 1966.

18. Vollaro, R. F. A Survey of Commercially Available Instrumentation for the Measurement of Low-Range Gas Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park N.C. November 1974. (Unpublished Paper)

19. Gnyp, A. W., C. C. St. Pierre, D. S. Smith, D. Moxson, and J. Steiner. An Experimental Investigation of the Effect of Pitot Tube-Sampling Probe Configurations on the Magnitude of the S Type Pitot Tube Coefficient for Commercially Available Source Sampling Probes. Prepared by the University of Windsor for the Ministry of the Environment, Toronto, Canada, February 1975.

METHOD 3—GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR, AND DRY MOLECULAR WEIGHT

1. Principle and Applicability

1.1 Principle. A gas sample is extracted from a stack, by one of the following methods: (1) single-point, grab sampling; (2) single-point, integrated sampling; or (3) multi-point, integrated sampling. The gas sample is analyzed for percent carbon dioxide (CO₂), percent oxygen (O₂), and, if necessary, percent carbon monoxide (CO). If a dry molecular weight determination is to be made, either an Orsat or a Pyrite analyzer may be used for the analysis; for excess air or emission rate correction factor determination, an Orsat analyzer must be used.

1.2 Applicability. This method is applicable for determining CO₂ and O₂ concentrations, excess air, and dry molecular weight of a sample from a gas stream of a fossil-fuel combustion process. The method may also be applicable to other processes where it has been determined that compounds other than CO₂, O₂, CO, and nitrogen (N₂) are not present in concentrations sufficient to affect the results.

Other methods, as well as modifications to the procedure described herein, are also applicable for some or all of the above determinations. Examples of specific methods and modifications include: (1) a multi-point sampling method using an Orsat analyzer to analyze individual grab samples obtained at each point; (2) a method using CO₂ or O₂ and stoichiometric calculations to determine dry molecular weight and excess air; (3) assigning a value of 30.0 for dry molecular weight in lieu of actual measurements, for processes burning natural gas, coal, or oil. These methods and modifications may be used, but are subject to the approval of the Administrator, U.S. Environmental Protection Agency.

2. Apparatus

As an alternative to the sampling apparatus and systems described herein, other sampling systems (e.g., liquid displacement) may be used provided such systems are capable of obtaining a representative sample and maintaining a constant sampling rate, and are otherwise capable of yielding acceptable results. Use of such systems is subject to the approval of the Administrator.

2.1 Grab Sampling (Figure 3-1).

2.1.1 Probe. The probe should be made of stainless steel or borosilicate glass tubing and should be equipped with an in-stack or out-stack filter to remove particulate matter (a plug of glass wool is satisfactory for this purpose). Any other materials inert to O₂, CO₂, CO, and N₂ and resistant to temperature at sampling conditions may be used for the probe; examples of such material are aluminum, copper, quartz glass and Teflon.

2.1.2 Pump. A one-way squeeze bulb or equivalent is used to transport the gas sample to the analyzer.

2.2 Integrated Sampling (Figure 3-2).

2.2.1 Probe. A probe such as that described in Section 2.1.1 is suitable.

2.2.2 Condenser. An air-cooled or water-cooled condenser, or other condenser that will not remove O₂, CO₂, CO, and N₂, may be used to remove excess moisture which would interfere with the operation of the pump and flow meter.

2.2.3 Valve. A needle valve is used to adjust sample gas flow rate.

2.2.4 Pump. A leak-free, diaphragm-type pump, or equivalent, is used to transport sample gas to the flexible bag. Install a small surge tank between the pump and rate meter to eliminate the pulsation effect of the diaphragm pump on the rotameter.

2.2.5 Rate Meter. The rotameter, or equivalent rate meter, used should be capable of measuring flow rate to within ±2 percent of the selected flow rate. A flow rate range of 500 to 1000 cm³/min is suggested.

2.2.6 Flexible Bag. Any leak-free plastic (e.g., Tedlar, Mylar, Teflon) or plastic-coated aluminum (e.g., aluminized Mylar) bag, or equivalent, having a capacity consistent with the selected flow rate and time

length of the test run, may be used. A capacity in the range of 55 to 90 liters is suggested.

To leak-check the bag, connect it to a water manometer and pressurize the bag to 5 to 10 cm H₂O (2 to 4 in. H₂O). Allow to stand for 10 minutes. Any displacement in the water manometer indicates a leak. An alternative leak-check method is to pressurize the bag to 5 to 10 cm H₂O (2 to 4 in. H₂O) and allow to stand overnight. A deflated bag indicates a leak.

2.2.7 Pressure Gauge. A water-filled U-tube manometer, or equivalent, of about 28 cm (12 in.) is used for the flexible bag leak-check.

2.2.8 Vacuum Gauge. A mercury manometer, or equivalent, of at least 760 mm Hg (30 in. Hg) is used for the sampling train leak-check.

2.3 Analysis. For Orsat and Pyrite analyzer maintenance and operation procedures, follow the instructions recommended by the manufacturer, unless otherwise specified herein.




Figure 3-1. Grab sampling train.




Figure 3-2. Integrated gas-sampling train.

¹ Mention of trade names or specific products does not constitute endorsement by the Environmental Protection Agency.

2.3.1 Dry Molecular Weight Determination. An Orsat analyzer or Fyrite type combustion gas analyzer may be used.

2.3.2 Emission Rate Correction Factor or Excess Air Determination. An Orsat analyzer must be used. For low CO₂ (less than 4.0 percent) or high O₂ (greater than 15.0 percent) concentrations, the measuring burette of the Orsat must have at least 0.1 percent subdivisions.

3. Dry Molecular Weight Determination

Any of the three sampling and analytical procedures described below may be used for determining the dry molecular weight.

3.1 Single-Point, Grab Sampling and Analytical Procedure.

3.1.1 The sampling point in the duct shall either be at the centroid of the cross section or at a point no closer to the walls than 1.00 m (3.3 ft), unless otherwise specified by the Administrator.

3.1.2 Set up the equipment as shown in Figure 3-1, making sure all connections ahead of the analyzer are tight and leak-free. If an Orsat analyzer is used, it is recommended that the analyzer be leak-checked by following the procedure in Section 5; however, the leak-check is optional.

3.1.3 Place the probe in the stack, with the tip of the probe positioned at the sampling point; purge the sampling line. Draw a sample into the analyzer and immediately analyze it for percent CO₂ and percent O₂. Determine the percentage of the gas that is N₂ and CO by subtracting the sum of the percent CO₂ and percent O₂ from 100 percent. Calculate the dry molecular weight as indicated in Section 6.3.

3.1.4 Repeat the sampling, analysis, and calculation procedures, until the dry molecular weights of any three grab samples differ from their mean by no more than 0.3 g/g-mole (0.3 lb/lb-mole). Average these three molecular weights, and report the results to the nearest 0.1 g/g-mole (lb/lb-mole).

3.2 Single-Point, Integrated Sampling and Analytical Procedure.

3.2.1 The sampling point in the duct shall be located as specified in Section 3.1.1.

3.2.2 Leak-check (optional) the flexible bag as in Section 2.2.6. Set up the equipment as shown in Figure 3-2. Just prior to sampling, leak-check (optional) the train by placing a vacuum gauge at the condenser inlet, pulling a vacuum of at least 250 mm Hg (10 in. Hg), plugging the outlet at the quick disconnect, and then turning off the pump. The vacuum should remain stable for at least 0.5 minute. Evacuate the flexible bag. Connect the probe and place it in the stack, with the tip of the probe positioned at the sampling point; purge the sampling line. Next, connect the bag and make sure that all connections are tight and leak free.

3.2.3 Sample at a constant rate. The sampling run should be simultaneous with, and for the same total length of time as, the pollutant emission rate determination. Collection of at least 30 liters (1.00 ft³) of sample gas is recommended; however, smaller volumes may be collected, if desired.

3.2.4 Obtain one integrated flue gas sample during each pollutant emission rate determination. Within 8 hours after the sample is taken, analyze it for percent CO₂ and percent O₂, using either an Orsat analyzer or a Fyrite-type combustion gas analyzer. If an Orsat analyzer is used, it is recommended that the Orsat leak-check described in Section 5 be performed before this determination; however, the check is optional.

Determine the percentage of the gas that is N₂ and CO by subtracting the sum of the percent CO₂ and percent O₂ from 100 percent. Calculate the dry molecular weight as indicated in Section 6.3.

3.2.5 Repeat the analysis and calculation procedures until the individual dry molecular weights for any three analyses differ from their mean by no more than 0.3 g/g-mole (0.3 lb/lb-mole). Average these three molecular weights, and report the results to the nearest 0.1 g/g-mole (0.1 lb/lb-mole).

3.3 Multi-Point, Integrated Sampling and Analytical Procedure.

3.3.1 Unless otherwise specified by the Administrator, a minimum of eight traverse points shall be used for circular stacks having diameters less than 0.61 m (24 in.), a minimum of nine shall be used for rectangular stacks having equivalent diameters less than 0.61 m (24 in.), and a minimum of twelve traverse points shall be used for all other cases. The traverse points shall be located according to Method 1. The use of fewer points is subject to approval of the Administrator.

3.3.2 Follow the procedures outlined in sections 3.2.2 through 3.2.5, except for the following: traverse all sampling points and sample at each point for an equal length of time. Record sampling data as shown in Figure 3-3.

4. Emission Rate Correction Factor or Excess Air Determination

NOTE: A Fyrite-type combustion gas analyzer is not acceptable for excess air or emission rate correction factor determination, unless approved by the Administrator. If both percent CO₂ and percent O₂ are measured, the analytical results of any of the three procedures given below may also be used for calculating the dry molecular weight.

Each of the three procedures below shall be used only when specified in an applicable subpart of the standards. The use of these procedures for other purposes must have specific prior approval of the Administrator.

4.1 Single-Point, Grab Sampling and Analytical Procedure.

4.1.1 The sampling point in the duct shall either be at the centroid of the cross-section or at a point no closer to the walls than 1.00 m (3.3 ft), unless otherwise specified by the Administrator.

4.1.2 Set up the equipment as shown in Figure 3-1, making sure all connections ahead of the analyzer are tight and leak-free. Leak-check the Orsat analyzer according to the procedure described in Section 5. This leak-check is mandatory.

FIGURE 3-3—SAMPLING RATE DATA

Time	Traverse pt.	CO ₂ ppm	% O ₂
Average			

$$\% \text{ Dev.} = \frac{(\text{CO}_2 - \text{CO}_2) / \text{CO}_2}{\text{CO}_2} \times 100 \quad (\text{Must be } < 10\%)$$

4.1.3 Place the probe in the stack, with the tip of the probe positioned at the sampling point; purge the sampling line. Draw a sample into the analyzer. For emission rate correction factor determination, immediately analyze the sample, as outlined in Sections 4.1.4 and 4.1.5, for percent CO₂ or percent O₂. If excess air is desired, proceed as follows: (1) immediately analyze the sample, as in Sections 4.1.4 and 4.1.5, for percent CO₂, O₂, and CO; (2) determine the percentage of the gas that is N₂ by subtracting the sum of the percent CO₂, percent O₂, and percent CO from 100 percent; and (3) calculate percent excess air as outlined in Section 6.2.

4.1.4 To insure complete absorption of the CO₂, O₂, or if applicable, CO, make repeated passes through each absorbing solution until two consecutive readings are the same. Several passes (three or four) should be made between readings. (If constant readings cannot be obtained after three consecutive readings, replace the absorbing solution.)

4.1.5 After the analysis is completed, leak-check (mandatory) the Orsat analyzer once again, as described in Section 5. For the results of the analysis to be valid, the Orsat analyzer must pass this leak test before and after the analysis.

NOTE: Since this single-point, grab sampling and analytical procedure is normally conducted in conjunction with a single-point, grab sampling and analytical procedure for a pollutant, only one analysis is ordinarily conducted. Therefore, great care must be taken to obtain a valid sample and analysis. Although in most cases only CO₂ or O₂ is required, it is recommended that both CO₂ and O₂ be measured, and that Section 4.4 be used to validate the analytical data.

4.2 Single-Point, Integrated Sampling and Analytical Procedure.

4.2.1 The sampling point in the duct shall be located as specified in Section 4.1.1.

4.2.2 Leak-check (mandatory) the flexible bag as in Section 2.2.6. Set up the equipment as shown in Figure 3-2. Just prior to sampling, leak-check (mandatory) the train by placing a vacuum gauge at the condenser inlet, pulling a vacuum of at least 250 mm Hg (10 in. Hg), plugging the outlet at the quick disconnect, and then turning off the pump. The vacuum shall remain stable for at least 0.5 minute. Evacuate the flexible bag. Connect the probe and place it in the stack, with the tip of the probe positioned at the sampling point; purge the sampling line. Next, connect the bag and make sure that all connections are tight and leak free.

4.2.3 Sample at a constant rate, or as specified by the Administrator. The sampling run must be simultaneous with, and for the same total length of time as, the pollutant emission rate determination. Collect at least 30 liters (1.00 ft³) of sample gas. Smaller volumes may be collected, subject to approval of the Administrator.

4.2.4 Obtain one integrated flue gas sample during each pollutant emission rate determination. For emission rate correction factor determination, analyze the sample within 8 hours after it is taken for percent CO₂ or percent O₂, (as outlined in Sections 4.2.5 through 4.2.7). The Orsat analyzer must be leak-checked (see Section 5) before the analysis. If excess air is desired, proceed as follows: (1) within 8 hours after the sample is taken, analyze it (as in Sections 4.2.5 through 4.2.7) for percent CO₂, O₂, and CO; (2) determine the percentage of the gas that is N₂ by subtracting the sum of the percent CO₂, percent O₂, and percent CO from 100 percent; (3) calculate percent excess air, as outlined in Section 6.2.

4.2.3 To insure complete absorption of the CO₂, O₂, or if applicable, CO, make repeated passes through each absorbing solution until two consecutive readings are the same. Several passes (three or four) should be made between readings. (If constant readings cannot be obtained after three consecutive readings, replace the absorbing solution.)

4.2.6 Repeat the analysis until the following criteria are met:

4.2.6.1 For percent CO₂, repeat the analytical procedure until the results of any three analyses differ by no more than (a) 0.3 percent by volume when CO₂ is greater than 4.0 percent or (b) 0.2 percent by volume when CO₂ is less than or equal to 4.0 percent. Average the three acceptable values of percent CO₂ and report the results to the nearest 0.1 percent.

4.2.6.2 For percent O₂, repeat the analytical procedure until the results of any three analyses differ by no more than (a) 0.3 percent by volume when O₂ is less than 15.0 percent or (b) 0.2 percent by volume when O₂ is greater than or equal to 15.0 percent. Average the three acceptable values of percent O₂ and report the results to the nearest 0.1 percent.

4.2.6.3 For percent CO, repeat the analytical procedure until the results of any three analyses differ by no more than 0.3 percent. Average the three acceptable values of percent CO and report the results to the nearest 0.1 percent.

4.2.7 After the analysis is completed, leak-check (mandatory) the Orsat analyzer once again, as described in Section 5. For the results of the analysis to be valid, the Orsat analyzer must pass this leak test before an after the analysis.

NOTE: Although in most instances only CO₂ or O₂ is required, it is recommended that both CO₂ and O₂ be measured, and that Citation 5 in the Bibliography be used to validate the analytical data.

4.3 Multi-Point, Integrated Sampling and Analytical Procedure.

4.3.1 Both the minimum number of sampling points and the sampling point location shall be as specified in Section 3.3.1 of this method. The use of fewer points than specified is subject to the approval of the Administrator.

4.3.2 Follow the procedures outlined in Sections 4.2.3 through 4.2.7, except for the following: Traverse all sampling points and sample at each point for an equal length of time. Record sampling data as shown in Figure 3-3.

4.4 Quality Control Procedures.

4.4.1 Data Validation When Both CO₂ and O₂ Are Measured. Although in most instances, only CO₂ or O₂ measurement is required, it is recommended that both CO₂ and O₂ be measured to provide a check on the quality of the data. The following quality control procedure is suggested.

NOTE: Since the method for validating the CO₂ and O₂ analyses is based on combustion of organic and fossil fuels and dilution of the gas stream with air, this method does not apply to sources that (1) remove CO₂ or O₂ through processes other than combustion, (2) add O₂ (e.g., oxygen enrichment) and N₂ in proportions different from that of air, (3) add CO₂ (e.g., cement or lime kilns), or (4) have no fuel factor. F_u values obtainable (e.g., extremely variable waste mixtures). This method validates the measured proportions of CO₂ and O₂ for the fuel type, but the method does not detect sample dilution resulting from leaks during or after sample collection. The method is applicable

for samples collected downstream of most lime or limestone flue-gas desulfurization units as the CO₂ added or removed from the gas stream is not significant in relation to the total CO₂ concentration. The CO₂ concentrations from other types of scrubbers using only water or basic slurry can be significantly affected and would render the F_u check minimally useful.

4.4.1.1 Calculate a fuel factor, F_u, using the following equation:

$$F_u = \frac{20.9 - \%O_2}{\%CO_2}$$

Eq. 3-3

Where:

%O₂ = Percent O₂ by volume (dry basis).

%CO₂ = Percent CO₂ by volume (dry basis).

20.9 = Percent O₂ by volume in ambient air.

If CO is present in quantities measurable by this method, adjust the O₂ and CO₂ values before performing the calculation for F_u, as follows:

$$\%CO_2(\text{adj}) = \%CO_2 - \%CO$$

$$\%O_2(\text{adj}) = \%O_2 - 0.5 \%CO$$

Where: %CO = Percent CO by volume (dry basis).

4.4.1.2 Compare the calculated F_u factor with the expected F_u values. The following table may be used in establishing acceptable ranges for the expected F_u, if the fuel being burned is known. When fuels are burned in combination, calculate the combined fuel F_u and F_u factors (as defined in Method 19) according to the procedure in Method 19 Section 3.2.3. Then calculate the F_u factor as follows:

$$F_u = \frac{0.209 F_u}{F_u}$$

Eq. 3-4

Fuel type	F _u range	
Coal	Average and typical	1.070-1.130
	Standard	1.080-1.230
Oil	Crude	1.280-1.410
	Residual	1.210-1.370
Gas	Natural	1.120-1.220
	Propane	1.420-1.280
	Butane	1.420-1.280
Wood		1.080-1.120
	Wood chip	1.280-1.120

Calculated F_u values beyond the acceptable ranges shown in this table should be investigated before accepting the test results. For example, the strength of the solutions in the gas analyzer and the analyzing technique should be checked by sampling and analyzing a known concentration, such as air. The fuel factor should be reviewed and verified. An acceptability range of ±12 percent is appropriate for the F_u factor of mixed fuels with variable fuel ratios. The level of the emission rate relative to the compliance level should be considered in determining if a retest is appropriate. I.e., if the measured emissions are much lower or much greater than the compliance limit, repetition of the test would not significantly change the compliance status of the source and would be unnecessarily time-consuming and costly.

5. Leak-Check Procedure for Orsat Analyzers

Moving an Orsat analyzer frequently causes it to leak. Therefore, an Orsat analyzer should be thoroughly leak-checked on site before the flue gas sample is introduced into it. The procedure for leak-checking an Orsat analyzer is:

5.1.1 Bring the liquid level in each pipette up to the reference mark on the capillary tubing and then close the pipette stopcock.

5.1.2 Raise the leveling bulb sufficiently to bring the confining liquid meniscus onto the graduated portion of the burette and then close the manifold stopcock.

5.1.3 Record the meniscus position.

5.1.4 Observe the meniscus in the burette and the liquid level in the pipette for movement over the next 4 minutes.

5.1.5 For the Orsat analyzer to pass the leak-check, two conditions must be met.

5.1.5.1 The liquid level in each pipette must not fall below the bottom of the capillary tubing during this 4-minute interval.

5.1.5.2 The meniscus in the burette must not change by more than 0.2 ml during this 4-minute interval.

5.1.6 If the analyzer fails the leak-check procedure, all rubber connections and stopcocks should be checked until the cause of the leak is identified. Leaking stopcocks must be disassembled, cleaned, and re-greased. Leaking rubber connections must be replaced. After the analyzer is reassembled, the leak-check procedure must be repeated.

6. Calculations

6.1 Nomenclature.

M_d = Dry molecular weight, g/g-mole (lb/lb-mole).

%EA = Percent excess air.

%CO₂ = Percent CO₂ by volume (dry basis).

%O₂ = Percent O₂ by volume (dry basis).

%CO = Percent CO by volume (dry basis).

%N₂ = Percent N₂ by volume (dry basis).

0.284 = Ratio of O₂ to N₂ in air, v/v.

0.280 = Molecular weight of N₂ or CO, divided by 100.

0.320 = Molecular weight of O₂, divided by 100.

0.440 = Molecular weight of CO, divided by 100.

6.2 Percent Excess Air. Calculate the percent excess air (if applicable), by substituting the appropriate values of percent O₂, CO₂, and N₂ (obtained from Section 4.1.3 or 4.2.4) into Equation 3-1.

% EA =

$$\frac{\%O_2 - 0.5\%CO}{0.284\%N_2 - \%CO} \times 100$$

Equation 3-1

NOTE: The equation above assumes that ambient air is used as the source of O₂ and that the fuel does not contain appreciable amounts of N₂ (as do coke oven or blast furnace gases). For those cases when appreciable amounts of N₂ are present (coal, oil, and natural gas do not contain appreciable amounts of N₂) or when oxygen enrichment is used, alternate methods, subject to approval of the Administrator, are required.

6.3 Dry Molecular Weight. Use Equation 3-2 to calculate the dry molecular weight of the stack gas

$$M_d = 0.440(\%CO_2) + 0.320(\%O_2) +$$

$$0.280(\%N_2) + \%CO$$

Equation 3-2

NOTE: The above equation does not consider argon in air (about 0.9 percent, molecular weight of 39.9). A negative error of about 0.4 percent is introduced. The tester may opt to include argon in the analysis using procedures subject to approval of the Administrator.

7. Bibliography

1. Altshuler, A. P. Storage of Gases and Vapors in Plastic Bags. *International Journal of Air and Water Pollution*, 6:73-81, 1963.

2. Conner, William D. and J. S. Nader. Air Sampling with Plastic Bags. *Journal of the American Industrial Hygiene Association*, 25:291-297, 1964.

3. Burrell Manual for Gas Analysts, Seventh edition. Burrell Corporation, 2223 Fifth Avenue, Pittsburgh, Pa. 15219, 1951.

4. Mitchell, W. J. and M. R. Midgrett. Field Reliability of the Orsat Analyzer. *Journal of Air Pollution Control Association* 28:491-495, May 1976.

5. Shigenara, R. T., R. M. Neulicht, and W. S. Smith. Validating Orsat Analysis Data from Possil Fuel-Fired Units. *Stack Sampling News*, 4(2):21-28, August, 1976.

METHOD 4—DETERMINATION OF MOISTURE CONTENT IN STACK GASES

1. Principle and Applicability

1.1 Principle. A gas sample is extracted at a constant rate from the source; moisture is removed from the sample stream and determined either volumetrically or gravimetrically.

1.2 Applicability. This method is applicable for determining the moisture content of stack gas.

Two procedures are given. The first is a reference method, for accurate determinations of moisture content (such as are needed to calculate emission data). The second is an approximation method, which provides estimates of percent moisture to aid in setting isokinetic sampling rates prior to a pollutant emission measurement run. The approximation method described herein is only a suggested approach; alternative means for approximating the moisture content, e.g., drying tubes, wet bulb-dry bulb techniques, condensation techniques, stoichiometric calculations, previous experience, etc., are also acceptable.

The reference method is often conducted simultaneously with a pollutant emission measurement run; when it is, calculation of percent isokinetic, pollutant emission rate, etc., for the run shall be based upon the results of the reference method or its equivalent; these calculations shall not be based upon the results of the approximation method, unless the approximation method is shown, to the satisfaction of the Administrator, U.S. Environmental Protection Agency, to be capable of yielding results within 1 percent E.O. of the reference method.

Note: The reference method may yield questionable results when applied to saturated gas streams or to streams that contain water droplets. Therefore, when these conditions exist or are suspected, a second determination of the moisture content shall be made simultaneously with the reference method, as follows: Assume that the gas stream is saturated. Attach a temperature sensor (capable of measuring to $\pm 1^\circ\text{C}$ (2°F)) to the reference method probe. Measure the stack gas temperature at each traverse point (see Section 2.2.1) during the reference method traverse; calculate the average stack gas temperature. Next, determine the moisture percentage, either by: (1) using a psychrometric chart and making appropriate corrections if stack pressure is different from that of the chart, or (2) using saturation vapor pressure tables. In cases where the psychrometric chart or the saturation vapor pressure tables are not applicable (based on evaluation of the process), alternate methods, subject to the approval of the Administrator, shall be used.

2. Reference Method

The procedure described in Method 5 for determining moisture content is acceptable as a reference method.

2.1 Apparatus. A schematic of the sampling train used in this reference method is shown in Figure 4-1. All components shall be maintained and calibrated according to the procedure outlined in Method 5.




Figure 4-1. Moisture sampling train-reference method.

2.1.1 Probe. The probe is constructed of stainless steel or glass tubing, sufficiently heated to prevent water condensation, and is equipped with a filter, either in-stack (e.g., a plug of glass wool inserted into the end of the probe) or heated out-stack (e.g., as described in Method 5), to remove particulate matter.

When stack conditions permit, other metals or plastic tubing may be used for the probe, subject to the approval of the Administrator.

2.1.2 Condenser. The condenser consists of four impingers connected in series with ground glass, leak-free fittings or any similarly leak-free non-contaminating fittings. The first, third, and fourth impingers shall be of the Greenburg-Smith design, modified by replacing the tip with a 1.3 centimeter ($\frac{1}{2}$ inch) ID glass tube extending to about 1.3 cm ($\frac{1}{2}$ in.) from the bottom of the flask. The second impinger shall be of the Greenburg-Smith design with the standard tip. Modifications (e.g., using flexible connections between the impingers, using materials other than glass, or using flexible vacuum lines to connect the filter holder to the condenser) may be used, subject to the approval of the Administrator.

The first two impingers shall contain known volumes of water, the third shall be empty, and the fourth shall contain a known weight of 6- to 16-mesh indicating type silica gel, or equivalent desiccant. If the silica gel has been previously used, dry at 175°C (350°F) for 2 hours. New silica gel may be used as received. A thermometer, capable of measuring temperature to within 1°C (2°F), shall be placed at the outlet of the fourth impinger, for monitoring purposes.

Alternatively, any system may be used (subject to the approval of the Administrator) that cools the sample gas stream and allows measurement of both the water that has been condensed and the moisture leaving the condenser, each to within 1 ml or 1 g. Acceptable means are to measure the condensed water, either gravimetrically or volumetrically, and to measure the moisture leaving the condenser by: (1) monitoring the temperature and pressure at the exit of the condenser and using Dalton's law of partial pressures, or (2) passing the sample gas stream through a tared silica gel (or equivalent desiccant) trap, with exit gases kept below 30°C (60°F), and determining the weight gain.

If means other than silica gel are used to determine the amount of moisture leaving the condenser, it is recommended that silica gel (or equivalent) still be used between the condenser system and pump, to prevent moisture condensation in the pump and metering devices and to avoid the need to make corrections for moisture in the metered volume.




Figure 4-4. Moisture-sampling train - approximation method.

FIGURE 4-5—FIELD MOISTURE DETERMINATION—APPROXIMATION METHOD

Location _____ Comments _____
 Year _____
 Date _____
 Operator _____
 Barometric pressure _____

Clock time	Gas volume through meter, (V _{sc} , ml (STP))	Rate meter reading ml ² /min. (R _{sc})	Moisture temperature, C (°F)

1.2.2 Connect the probe, insert it into the stack, and sample at a constant rate of 2 lpm (0.071 cfm). Continue sampling until the dry gas meter registers about 30 liters (1.1 ft³) or until visible liquid droplets are carried over from the first impinger to the second. Record temperature, pressure, and dry gas meter readings as required by Figure 4-4.

1.2.3 After collecting the sample, combine the contents of the two impingers and measure the volume to the nearest 0.5 ml.

1.3 Calculations. The calculation method presented is designed to estimate the moisture in the stack gas; therefore, other data, which are only necessary for accurate moisture determinations, are not collected. The following equations adequately estimate the moisture content, for the purpose of determining isokinetic sampling rate settings.

3.3.1 Nomenclature.

B_{sc} = Approximate proportion, by volume, of water vapor in the gas stream leaving the second impinger, 0.025.

B_{sc} = Water vapor in the gas stream, proportion by volume.

M_w = Molecular weight of water, 18.0 g/g-mole (18.0 lb/lb-mole).

P_{sc} = Absolute pressure (for this method, same as barometric pressure) at the dry gas meter.

P_{std} = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).

R = Ideal gas constant, 0.08206 (mm Hg) (m³)/(g-mole) (°K) for metric units and 21.85 (in. Hg) (ft³)/(lb-mole) (°R) for English units.

T_{sc} = Absolute temperature at meter, °K (°R).

T_{std} = Standard absolute temperature, 293° K (528° R).

V_{sc} = Final volume of impinger contents, ml.

V_i = Initial volume of impinger contents, ml.

V_{sc} = Dry gas volume measured by dry gas meter, dcm (def).

V_{sc(Std)} = Dry gas volume measured by dry gas meter, corrected to standard conditions, dcm (dscf).

V_{w(Std)} = Volume of water vapor condensed, corrected to standard conditions, scm (scf).

ρ_w = Density of water, 0.9982 g/ml (0.002201 lb/ml).

Y = Dry gas meter calibration factor.

3.3.2 Volume of water vapor collected, where:

$$V_{w(Std)} = \frac{(V_i - V_f) M_w / RT_{sc}}{\rho_w M_w}$$

$$= K_d (V_i - V_f)$$

Equation 4-3

K_d = 0.001333 m³/ml for metric units
 = 0.04707 ft³/ml for English units.

3.3.3 Gas volume.

$$V_{sc(Std)} = V_{sc} \left(\frac{P_{sc}}{P_{std}} \right) \left(\frac{T_{std}}{T_{sc}} \right)$$

$$= K_v \frac{V_{sc} P_{sc}}{T_{sc}}$$

Equation 4-4

where:

K_v = 0.3858 °K/mm Hg for metric units
 = 17.64 °R/in. Hg for English units

3.3.4 Approximate moisture content.

$$B_{sc} = \frac{V_{w(Std)}}{V_{sc} + V_{w(Std)}} + B_{sc}$$

$$= \frac{V_{w(Std)}}{V_{sc} + V_{w(Std)}} + (0.025)$$

Equation 4-7

4. Calibration

4.1 For the reference method, calibrate equipment as specified in the following sections of Method 3: Section 3.3 (metering system); Section 3.5 (temperature gauges); and Section 3.7 (barometer). The recommended leak check of the metering system (Section 3.6 of Method 3) also applies to the reference method. For the approximation method, use the procedures outlined in Section 3.1.1 of Method 6 to calibrate the metering system, and the procedure of Method 3, Section 3.7 to calibrate the barometer.

5. Bibliography

1. Air Pollution Engineering Manual (Second Edition). Danesi, J. A. (ed.). U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards, Research Triangle Park, N.C. Publication No. AP-40, 1973.

2. Devorkin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District, Los Angeles, Calif. November, 1963.

3. Methods for Determination of Velocity, Volume Dust and Mist Content of Gases, Western Precipitation Division of Joy Manufacturing Co., Los Angeles, Calif. Bulletin WP-60, 1968.

quired on the example data sheet shown in Figure 4-2. Be sure to record the dry gas meter reading at the beginning and end of each sampling time increment and whenever sampling is halted. Take other appropriate readings at each sample point, at least once during each time increment.

2.2.5 To begin sampling, position the probe tip at the first traverse point. Immediately start the pump and adjust the flow to the desired rate. Traverse the cross section, sampling at each traverse point for an equal length of time. Add more ice and, if necessary, salt to maintain a temperature of less 20° C (68° F) at the silica gel outlet.

2.2.6 After collecting the sample, disconnect the probe from the filter holder (or from the first impinger) and conduct a leak check (mandatory) as described in Section 2.2.1. Record the leak rate. If the leakage rate exceeds the allowable rate, the tester shall either reject the test results or shall correct the sample volume as in Section 6.3 of Method 5. Next, measure the volume of the moisture condensed to the nearest ml. Determine the increase in weight of the silica gel (or silica gel plus impinger) to the nearest 0.5 g. Record this information (see example data sheet, Figure 4-3) and calculate the moisture percentage, as described in 2.3 below.

2.2.7 A quality control check of the volume metering system at the field site is suggested before collecting the sample following the procedure in Method 5, Section 4.4.

2.3 Calculations. Carry out the following calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after final calculation.

FIGURE 4-3—ANALYTICAL DATA—REFERENCE METHOD

	Impinger volume, ml	Silica gel weight, g
Final		
Initial		
Change		

2.3.1 Nomenclature.

- B_w = Proportion of water vapor, by volume, in the gas stream.
- M_w = Molecular weight of water, 18.0 g/mole (18.0 lb/lb-mole).
- P_a = Absolute pressure (for this method, same as barometric pressure) at the dry gas meter, mm Hg (in. Hg).
- P_{std} = Standard absolute pressure, 760 mm Hg (29.92 in. Hg).
- R = Ideal gas constant, 0.08206 (mm Hg) (m³)/(g-mole) (°K) for metric units and 21.85 (in. Hg) (ft³)/(lb-mole) (°R) for English units.
- T_a = Absolute temperature at meter, °K (°R).
- T_{std} = Standard absolute temperature, 293° K (528°R).
- V_a = Dry gas volume measured by dry gas meter, dcm (dcf).
- ΔV_a = Incremental dry gas volume measured by dry gas meter at each traverse point, dcm (dcf).
- V_{std} = Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf).
- $V_{std,w}$ = Volume of water vapor condensed corrected to standard conditions, scm (scf).

$V_{std,w}$ = Volume of water vapor collected in silica gel corrected to standard conditions, scm (scf).

V_f = Final volume of condenser water, ml.

V_i = Initial volume, if any, of condenser water, ml.

W_f = Final weight of silica gel or silica gel plus impinger, g.

W_i = Initial weight of silica gel or silica gel plus impinger, g.

Y = Dry gas meter calibration factor.

ρ_w = Density of water, 0.9982 g/ml (0.002201 lb/ml).

2.3.2 Volume of water vapor condensed.

$$V_{std,w} = \frac{(V_f - V_i) \rho_w R T_{std}}{P_{std} M_w}$$

$$= K_1 (V_f - V_i)$$

Equation 4-1 where:

$K_1 = 0.001333 \text{ m}^3/\text{ml}$ for metric units

$= 0.04707 \text{ ft}^3/\text{ml}$ for English units

2.3.3 Volume of water vapor collected in silica gel.

$$V_{std,w} = \frac{(W_f - W_i) R T_{std}}{P_{std} M_w}$$

$$= K_2 (W_f - W_i)$$

Equation 4-2 where:

$K_2 = 0.001333 \text{ m}^3/\text{g}$ for metric units

$= 0.04715 \text{ ft}^3/\text{g}$ for English units

2.3.4 Sample gas volume.

$$V_{std} = V_a Y \frac{(P_a)(T_{std})}{(P_{std})(T_a)}$$

$$= K_3 Y \frac{V_a P_a}{T_a}$$

Equation 4-3 where:

$K_3 = 0.3858 \text{ } ^\circ\text{K}/\text{mm Hg}$ for metric units

$= 17.64 \text{ } ^\circ\text{R}/\text{in. Hg}$ for English units

Note: If the post-test leak rate (Section 2.2.6) exceeds the allowable rate, correct the value of V_a in Equation 4-3, as described in Section 6.3 of Method 5.

2.3.5 Moisture Content.

$$B_w = \frac{V_{std,w} + V_{std}}{V_{std,w} + V_{std} + V_{std}}$$

Equation 4-4

Note: In saturated or moisture droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one using a value based upon the saturated conditions (see Section 1.2), and

another based upon the results of the impinger analysis. The lower of these two values of B_w shall be considered correct.

2.3.6 Verification of constant sampling rate. For each time increment, determine the ΔV_a . Calculate the average. If the value for any time increment differs from the average by more than 10 percent, reject the results and repeat the run.

3. Approximation Method

The approximation method described below is presented only as a suggested method (see Section 1.2).

3.1 Apparatus.

3.1.1 Probe. Stainless steel glass tubing, sufficiently heated to prevent water condensation and equipped with a filter (either in-stack or heated out-stack) to remove particulate matter. A plug of glass wool, inserted into the end of the probe, is a satisfactory filter.

3.1.2 Impingers. Two midget impingers, each with 30 ml capacity, or equivalent.

3.1.3 Ice Bath. Container and ice, to aid in condensing moisture in impingers.

3.1.4 Drying Tube. Tube packed with new or regenerated 6- to 16-mesh indicating-type silica gel (or equivalent desiccant), to dry the sample gas and to protect the meter and pump.

3.1.5 Valve. Needle valve, to regulate the sample gas flow rate.

3.1.6 Pump. Leak-free, diaphragm type, or equivalent, to pull the gas sample through the train.

3.1.7 Volume Meter. Dry gas meter, sufficiently accurate to measure the sample volume within 2%, and calibrated over the range of flow rates and conditions actually encountered during sampling.

3.1.8 Rate Meter. Rotameter, to measure the flow range from 0 to 3 lpm (0 to 0.11 cfm).

3.1.9 Graduated Cylinder. 25 ml.

3.1.10 Barometer. Mercury, aneroid, or other barometer, as described in Section 2.1.5 above.

3.1.11 Vacuum Gauge. At least 160 mm Hg (30 in. Hg) gauge, to be used for the sampling leak check.

3.2 Procedure.

3.2.1 Place exactly 5 ml distilled water in each impinger.

Leak check the sampling train as follows: Temporarily insert a vacuum gauge at or near the probe inlet; then, plug the probe inlet and pull a vacuum of at least 250 mm Hg (10 in. Hg). Note, the time rate of change of the dry gas meter dial; alternatively, a rotameter (0-40 cc/min) may be temporarily attached to the dry gas meter outlet to determine the leakage rate. A leak rate not in excess of 3 percent of the average sampling rate is acceptable.

Note: Carefully release the probe inlet plug before turning off the pump.

LOCATION _____ COMMENTS _____
 TEST _____
 DATE _____
 OPERATOR _____
 BAROMETRIC PRESSURE _____

CLOCK TIME	GAS VOLUME THROUGH METER, (Vm), m ³ (ft ³)	RATE METER SETTING m ³ /min. (ft ³ /min.)	METER TEMPERATURE, °C (°F)

Figure 4-5. Field moisture determination - approximation method.

3.2.2 Connect the probe, insert it into the stack, and sample at a constant rate of 3 lpm (0.071 cfm). Continue sampling until the dry gas meter registers about 30 liters (1.1 ft³) or until visible liquid droplets are carried over from the first impinger to the second. Record temperature, pressure, and dry gas meter readings as required by Figure 4-5.

3.2.3 After collecting the sample, combine the contents of the two impingers and measure the volume to the nearest 0.5 ml.

3.3 Calculations. The calculation method presented is designed to estimate the moisture in the stack gas; therefore, other data, which are only necessary for accurate moisture determinations, are not collected. The following equations adequately estimate the moisture content, for the purpose of determining isokinetic sampling rate settings.

3.3.1 Nomenclature.

B_{app} - Approximate proportion, by volume, of water vapor in the gas stream leaving the second impinger, 0.025.

B_{m} - Water vapor in the gas stream, proportion by volume.

M_w - Molecular weight of water, 18.0 g/mole (18.0 lb/lb-mole).

P_a - Absolute pressure (for this method, same as barometric pressure) at the dry gas meter.

P_{std} - Standard absolute pressure, 760 mm Hg (29.92 in. Hg).

R - Ideal gas constant, 0.08206 (mm Hg) (m³)/(g-mole) (°K) for metric units and 21.85 (in. Hg) (ft³)/(lb-mole) (°R) for English units.

T_m - Absolute temperature at meter, °K (°R).

T_{std} - Standard absolute temperature, 293° K (528° R).

V_f - Final volume of impinger contents, ml.

V_i - Initial volume of impinger contents, ml.

V_d - Dry gas volume measured by dry gas meter, dcm (def).

V_{dstd} - Dry gas volume measured by dry gas meter, corrected to standard conditions, dscm (def).

V_{wstd} - Volume of water vapor condensed, corrected to standard conditions, scm (scf).

ρ_w - Density of water, 0.9982 g/ml (0.0220) lb/ml).

Y - Dry gas meter calibration factor.

3.3.2 Volume of water vapor collected, where:

$$V_{\text{wstd}} = \frac{(V_f - V_i) \rho_w R T_{\text{std}}}{P_{\text{std}} M_w} = K_1 (V_f - V_i)$$

Equation 4-6

$K_1 = 0.001333 \text{ m}^3/\text{ml}$ for metric units
 $= 0.04707 \text{ ft}^3/\text{ml}$ for English units.

3.3.3 Gas volume.

$$V_{\text{dstd}} = V_d \left(\frac{P_a}{P_{\text{std}}} \right) \left(\frac{T_{\text{std}}}{T_m} \right) = K_2 \frac{V_d P_a}{T_m}$$

Equation 4-4

where:

$K_2 = 0.3856 \text{ °K}/\text{mm Hg}$ for metric units
 $= 17.64 \text{ °R}/\text{in. Hg}$ for English units

3.3.4 Approximate moisture content.

$$B_{\text{app}} = \frac{V_{\text{wstd}}}{V_{\text{dstd}} + V_{\text{wstd}}} + B_{\text{m}} = \frac{V_{\text{wstd}}}{V_{\text{dstd}} + V_{\text{wstd}}} + (0.025)$$

Equation 4-

4. Calibration

4.1 For the reference method, calibrate equipment as specified in the following sections of Method 5: Section 5.3 (metering system); Section 5.5 (temperature gauges) and Section 5.7 (barometer). The recommended leak check of the metering system (Section 5.6 of Method 5) also applies to the reference method. For the approximation method, use the procedures outlined in Section 5.1.1 of Method 5 to calibrate the metering system, and the procedure of Method 5, Section 5.7 to calibrate the barometer.

5. Bibliography

1. Air Pollution Engineering Manual (Second Edition), Danielson, J. A. (ed.), U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards, Research Triangle Park, N.C. Publication No. AP-40, 1973.

2. Devorkin, Howard, et al. Air Pollution Source Testing Manual, Air Pollution Control District, Los Angeles, Calif. November, 1963.

3. Methods for Determination of Velocity, Volume Dust and Mist Content of Gases, Western Precipitation Division of Joy Manufacturing Co., Los Angeles, Calif. Bulletin WP-40, 1962.

48 FR 55670 12/14/83

METHOD 5—DETERMINATION OF PARTICULATE EMISSIONS FROM STATIONARY SOURCES

1. Principle and Applicability

1.1 Principle. Particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter maintained at a temperature in the range of 120±14° C (248±25° F) or such other temperature as specified by an applicable subpart of the standards or approved by Administrator.

U.S. Environmental Protection Agency, for a particular application. The particulate mass, which includes any material that condenses at or above the filtration temperature, is determined gravimetrically after removal of uncombined water.

1.2 Applicability. This method is applicable for the determination of particulate emissions from stationary sources.

2. Apparatus

2.1 Sampling Train. A schematic of the sampling train used in this method is shown in Figure 5-1. Complete construction details are given in APTD-0581 (Citation 2 in Bibliography); commercial models of this train are also available. For changes from APTD-0581 and for allowable modifications of the train shown in Figure 5-1, see the following subsections.

The operating and maintenance procedures for the sampling train are described in APTD-0576 (Citation 3 in Bibliography). Since correct usage is important in obtaining valid results, all users should read APTD-0576 and adopt the operating and maintenance procedures outlined in it, unless otherwise specified herein. The sampling train consists of the following components:

2.1.1 Probe Nozzle. Stainless steel (316) or glass with sharp, tapered leading edge. The angle of taper shall be 30° and the taper shall be on the outside to preserve a constant internal diameter. The probe nozzle shall be of the button-hook or elbow design, unless otherwise specified by the Administrator. If made of stainless steel, the nozzle shall be constructed from seamless tubing; other materials of construction may be used, subject to the approval of the Administrator.

A range of nozzle sizes suitable for isokinetic sampling should be available, e.g., 0.32 to 1.27 cm (1/8 to 1/2 in.)—or larger if higher volume sampling trains are used—inside diameter (ID) nozzles in increments of 0.16 cm (1/16 in.). Each nozzle shall be calibrated according to the procedures outlined in Section 5.

2.1.2 Probe Liner. Borosilicate or quartz glass tubing with a heating system capable of maintaining a gas temperature at the exit end during sampling of 120±14° C (248±25° F), or such other temperature as specified by an applicable subpart of the standards or approved by the Administrator for a particular application. (The tester may opt to operate the equipment at a temperature lower than that specified.) Since the actual temperature at the outlet of the probe is not usually monitored during sampling, probes constructed according to APTD-0581 and utilizing the calibration curves of APTD-0576 (or calibrated according to the procedure outlined in APTD-0576) will be considered acceptable.

Either borosilicate or quartz glass probe liners may be used for stack temperatures up to about 480° C (900° F); quartz liners shall be used for temperatures between 48° and 900° C (900 and 1,650° F). Both types of liners may be used at higher temperatures than specified for short periods of time, subject to the approval of the Administrator. The softening temperature for borosilicate is 820° C (1,508° F), and for quartz it is 1,500° C (2,732° F).

Whenever practical, every effort should be made to use borosilicate or quartz glass probe liners. Alternatively, metal liners (e.g., 316 stainless steel, Incoloy 825, or other corrosion resistant metals) made of seamless tubing may be used, subject to the approval of the Administrator.

2.1.3 Pitot Tube. Type S, as described in Section 2.1 of Method 2, or other device approved by the Administrator. The pitot tube shall be attached to the probe (as shown in Figure 5-1) to allow constant monitoring of the stack gas velocity. The impact (high pressure) opening plane of the pitot tube shall be even with or above the nozzle entry plane (see Method 2, Figure 2-6b) during sampling. The Type S pitot tube assembly shall have a known coefficient, determined as outlined in Section 4 of Method 2.

*Mention of trade names or specific product does not constitute endorsement by the Environmental Protection Agency.




Figure 5-1. Particulate sampling train.

2.1.4 **Differential Pressure Gauge.** Inclined manometer or equivalent device (two), as described in Section 2.2 of Method 2. One manometer shall be used for velocity head readings, and the other, for orifice differential pressure readings.

2.1.5 **Filter Holder.** Borosilicate glass, with a glass frit filter support and a silicone rubber gasket. Other materials of construction (e.g., stainless steel, Teflon, Viton) may be used, subject to approval of the Administrator. The holder design shall provide a positive seal against leakage from the outside or around the filter. The holder shall be attached immediately at the outlet of the probe (or cyclone, if used).

2.1.6 **Filter Heating System.** Any heating system capable of maintaining a temperature around the filter holder during sampling of $120 \pm 14^\circ \text{C}$ ($248 \pm 25^\circ \text{F}$), or such other temperature as specified by an applicable subpart of the standards or approved by the Administrator for a particular application. Alternatively, the tester may opt to operate the equipment at a temperature lower than that specified. A temperature gauge capable of measuring temperature to within 3°C (5.4°F) shall be installed so that the temperature around the filter holder can be regulated and monitored during sampling. Heating systems other than the one shown in APTD-0581 may be used.

2.1.7 **Condenser.** The following system shall be used to determine the stack gas moisture content: Four impingers connected in series with leak-free ground glass fittings or any similar leak-free non-contaminating fittings. The first, third, and fourth impingers shall be of the Greenburg-Smith design, modified by replacing the tip with 1.3 cm ($\frac{1}{2}$ in.) ID glass tube extending to about 1.3 cm ($\frac{1}{2}$ in.) from the bottom of the flask. The second impinger shall be of the Greenburg-Smith design with the standard tip. Modifications (e.g., using flexible connections between the impingers, using materials other than glass, or using flexible vacuum lines to connect the filter holder to the condenser) may be used, subject to the approval of the Administrator. The first and second impingers shall contain known quantities of water (Section 4.1.3), the third shall be empty, and the fourth shall contain a known weight of silica gel, or equivalent desiccant. A thermometer, capable of measuring temperature to within 1°C (2°F) shall be placed at the outlet of the fourth impinger for monitoring purposes.

Alternatively, any system that cools the sample gas stream and allows measurement of the water condensed and moisture leaving the condenser, each to within 1 ml or 1 g may be used, subject to the approval of the Administrator. Acceptable means are to measure the condensed water either gravimetrically or volumetrically and to measure the moisture leaving the condenser by: (1) monitoring the temperature and pressure at the exit of the condenser and using Dalton's law of partial pressures; or (2) passing the sample gas stream through a tared silica gel (or equivalent desiccant) trap with exit gases kept below 20°C (68°F) and determining the weight gain.

If means other than silica gel are used to determine the amount of moisture leaving the condenser, it is recommended that silica gel (or equivalent) still be used between the condenser system and pump to prevent moisture condensation in the pump and metering devices and to avoid the need to make corrections for moisture in the metered volume.

NOTE: If a determination of the particulate matter collected in the impingers is desired in addition to moisture content, the impinger system described above shall be used, without modification. Individual States or control agencies requiring this information shall be contacted as to the sample recovery and analysis of the impinger contents.

2.1.8 **Metering System.** Vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 3°C (5.4°F), dry gas meter capable of measuring volume to within 2 percent, and related equipment, as shown in Figure 3-1. Other metering systems capable of maintaining sampling rates within 10 percent of isokinetic and of determining sample volumes to within 2 percent may be used, subject to the approval of the Administrator. When the metering system is used in conjunction with a pitot tube, the system shall enable checks of isokinetic rates.

Sampling trains utilizing metering systems designed for higher flow rates than that described in APTD-0581 or APDT-0576 may be used provided that the specifications of this method are met.

2.1.9 **Barometer.** Mercury aneroid, or other barometer capable of measuring atmospheric pressure to within 2.5 mm Hg (0.1 in. Hg). In many cases the barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the weather station and sampling point shall be applied at a rate of minus 2.5 mm Hg (0.1 in. Hg) per 30 m (100 ft) elevation increase or vice versa for elevation decrease.

2.1.10 **Gas Density Determination Equipment.** Temperature sensor and pressure gauge, as described in Sections 2.3 and 2.4 of Method 2, and gas analyzer, if necessary, as described in Method 1. The temperature sensor shall, preferably, be permanently attached to the pitot tube or sampling probe in a fixed configuration, such that the tip of the sensor extends beyond the leading edge of the probe sheath and does not touch any metal. Alternatively, the sensor may be attached just prior to use in the field. Note, however, that if the temperature sensor is attached in the field, the sensor must be placed in an interference-free arrangement with respect to the Type S pitot tube openings (see Method 2, Figure 2-7). As a second alternative, if a difference of not more than 1 percent in the average velocity measurement is to be introduced, the temperature gauge need not be attached to the probe or pitot tube. (This alternative is subject to the approval of the Administrator.)

2.2 **Sample Recovery.** The following items are needed.

2.2.1 **Probe-Liner and Probe-Nozzle Brushes.** Nylon bristle brushes with stainless steel wire handles. The probe brush shall have extensions (at least as long as the probe) of stainless steel, Nylon, Teflon, or similarly inert material. The brushes shall be properly sized and shaped to brush out the probe liner and nozzle.

2.2.2 **Wash Bottles—Two.** Glass wash bottles are recommended; polyethylene wash bottles may be used at the option of the tester. It is recommended that acetone not be stored in polyethylene bottles for longer than a month.

2.2.3 **Glass Sample Storage Containers.** Chemically resistant, borosilicate glass bottles, for acetone washes, 300 ml or 1000 ml. Screw cap liners shall either be rubber-backed Teflon or shall be constructed so as to be leak-free and resistant to chemical attack by acetone. (Narrow mouth glass bottles have been found to be less prone to leakage.) Alternatively, polyethylene bottles may be used.

2.2.4 **Petri Dishes.** For filter samples, glass or polyethylene, unless otherwise specified by the Administrator.

2.2.5 **Graduated Cylinder and/or Balance.** To measure condensed water to within 1 ml or 1 g. Graduated cylinders shall have subdivisions no greater than 2 ml. Most laboratory balances are capable of weighing to the nearest 0.5 g or less. Any of these balances is suitable for use here and in Section 2.3.4.

2.2.6 **Plastic Storage Containers.** Airtight containers to store silica gel.

2.2.7 **Funnel and Rubber Policeman.** To aid in transfer of silica gel to container; not

2.2.8 **Funnel, Glass or polyethylene.** To aid in sample recovery.

2.2 **Analysis.** For analysis, the following equipment is needed.

2.3.1 **Glass Weighing Dish.**

2.3.2 **Desiccator.**

2.3.3 **Analytical Balance.** To measure to within 0.1 mg.

2.3.4 **Balance.** To measure to within 0.5 g.

2.3.5 **Beakers, 250 ml.**

2.3.6 **Hygrometer.** To measure the relative humidity of the laboratory environment.

2.3.7 **Temperature Gauge.** To measure the temperature of the laboratory environment.

3. Reagents

3.1 **Sampling.** The reagents used in sampling are as follows:

3.1.1 **Filters.** Glass fiber filters, without organic binder, exhibiting at least 99.95 percent efficiency (<0.05 percent penetration) on 0.3-micron dioctyl phthalate smoke particles. The filter efficiency test shall be conducted in accordance with ASTM standard method D2984-71 (Reapproved, 1978) (incorporated by reference—see § 60.17). Test data from the supplier's quality control program are sufficient for this purpose. In sources containing SO_2 or SO_3 , the filter material must be of a type that is unreactive to SO_2 or SO_3 . Citation 10 in Section 7 Bibliography, may be used to select the appropriate filter.

3.1.2 **Silica Gel.** Indicating type, 6 to 18 mesh. If previously used, dry at 178°C (350°F) for 2 hours. New silica gel may be used as received. Alternatively, other types of desiccants (equivalent or better) may be used, subject to the approval of the Administrator.

3.1.3 **Water.** When analysis of the material caught in the impingers is required, distilled water shall be used. Run blanks prior to field use to eliminate a high blank on test samples.

3.1.4 **Crushed Ice.**

3.1.5 **Stopcock Grease.** Acetone-insoluble, heat-stable silicone grease. This is not necessary if screw-on connectors with Teflon sleeves, or similar, are used. Alternatively, other types of stopcock grease may be used, subject to the approval of the Administrator.

3.2 Sample Recovery. Acetone-reagent grade, <0.001 percent residue, in glass bottles—is required. Acetone from metal containers generally has a high residue blank and should not be used. Sometimes, suppliers transfer acetone to glass bottles from metal containers; thus, acetone blanks shall be run prior to field use and only acetone with low blank values (<0.001 percent) shall be used. In no case shall a blank value of greater than 0.001 percent of the weight of acetone used be subtracted from the sample weight.

3.3 Analysis. Two reagents are required for the analysis:

3.3.1 Acetone. Same as 3.2.

3.3.2 Desiccant. Anhydrous calcium sulfate, indicating type. Alternatively, other types of desiccants may be used, subject to the approval of the Administrator.

4. Procedure

4.1 Sampling. The complexity of this method is such that, in order to obtain reliable results, testers should be trained and experienced with the test procedures.

4.1.1 Pretest Preparation. It is suggested that sampling equipment be maintained according to the procedures described in APTD-0576.

Weigh several 200 to 300 g portions of silica gel in air-tight containers to the nearest 0.5 g. Record the total weight of the silica gel plus container, on each container. As an alternative, the silica gel need not be preweighed, but may be weighed directly in the impinger or sampling holder just prior to train assembly.

Check filters visually against light for irregularities and flaws or pinhole leaks. Label filters of the proper diameter on the back side near the edge using numbering machine ink. As an alternative, label the shipping containers (glass or plastic petri dishes) and keep the filters in these containers at all times except during sampling and weighing.

Desiccate the filters at $20 \pm 3.0^\circ\text{C}$ ($68 \pm 10^\circ\text{F}$) and ambient pressure for at least 24 hours and weigh at intervals of at least 6 hours to a constant weight, i.e., 0.5 mg change from previous weighing; record results to the nearest 0.1 mg. During each weighing the filter must not be exposed to the laboratory atmosphere for a period greater than 2 minutes and a relative humidity above 50 percent. Alternatively (unless otherwise specified by the Administrator), the filters may be oven dried at 105°C (220°F) for 2 to 3 hours, desiccated for 2 hours, and weighed. Procedures other than those described, which account for relative humidity effects, may be used, subject to the approval of the Administrator.

4.1.2 Preliminary Determinations. Select the sampling site and the minimum number of sampling points according to Method 1 or as specified by the Administrator. Determine the stack pressure, temperature, and the range of velocity heads using Method 2. It is recommended that a leak-check of the pitot lines (see Method 2, Section 3.1) be performed. Determine the moisture content using Approximation Method 4 or its alternatives for the purpose of making isokinetic sampling rate settings. Determine the stack

gas dry molecular weight, as described in Method 2, Section 3.6; if integrated Method 3 sampling is used for molecular weight determination, the integrated bag sample shall be taken simultaneously with, and for the same total length of time as, the particulate sample run.

Select a nozzle size based on the range of velocity heads, such that it is not necessary to change the nozzle size in order to maintain isokinetic sampling rates. During the run, do not change the nozzle size. Ensure that the proper differential pressure gauge is chosen for the range of velocity heads encountered (see Section 2.2 of Method 2).

Select a suitable probe liner and probe length such that all traverse points can be sampled. For large stacks, consider sampling from opposite sides of the stack to reduce the length of probes.

Select a total sampling time greater than or equal to the minimum total sampling time specified in the test procedures for the specific industry such that (1) the sampling time per point is not less than 2 min (or some greater time interval as specified by the Administrator), and (2) the sample volume taken (corrected to standard conditions) will exceed the required minimum total gas sample volume. The latter is based on an approximate average sampling rate.

It is recommended that the number of minutes sampled at each point be an integer or an integer plus one-half minute, in order to avoid timekeeping errors. The sampling time at each point shall be the same.

In some circumstances, e.g., batch cycles, it may be necessary to sample for shorter times at the traverse points and to obtain smaller gas sample volumes. In these cases, the Administrator's approval must first be obtained.

4.1.3 Preparation of Collection Train. During preparation and assembly of the sampling train, keep all openings where contamination can occur covered until just prior to assembly or until sampling is about to begin.

Place 100 ml of water in each of the first two impingers, leave the third impinger empty, and transfer approximately 200 to 300 g of preweighed silica gel from its container to the fourth impinger. More silica gel may be used, but care should be taken to ensure that it is not entrained and carried out from the impinger during sampling. Place the container in a clean place for later use in the sample recovery. Alternatively, the weight of the silica gel plus impinger may be determined to the nearest 0.5 g and recorded.

Using a tweezer or clean disposable surgical gloves, place a labeled (identified) and weighed filter in the filter holder. Be sure that the filter is properly centered and the gasket properly placed so as to prevent the sample gas stream from circumventing the filter. Check the filter for tears after assembly is completed.

When glass liners are used, install the selected nozzle using a Viton A O-ring when stack temperatures are less than 280°C (500°F) and an asbestos string gasket when temperatures are higher. See APTD-0576 for details. Other connecting systems using either 316 stainless steel or Teflon (ferrules) may be used. When metal liners are used, install the nozzle as above or by a leak-free direct mechanical connection. Mark the probe with heat resistant tape or by some other method to denote the proper distance into the stack or duct for each sampling point.

Set up the train as in Figure 3-1, using (if necessary) a very light coat of silicone grease on all ground glass joints, greasing only the outer portion (see APTD-0576) to avoid possibility of contamination by the silicone grease. Subject to the approval of the Administrator, a glass cyclone may be used between the probe and filter holder when the total particulate catch is expected to exceed 100 mg or when water droplets are present in the stack gas.

Place crushed ice around the impingers.

4.1.4 Leak-Check Procedures.

4.1.4.1 Pretest Leak-Check. A pretest leak-check is recommended, but not required. If the tester opts to conduct the pretest leak-check, the following procedure shall be used.

After the sampling train has been assembled, turn on and set the filter and probe heating systems at the desired operating temperatures. Allow time for the temperatures to stabilize. If a Viton A O-ring or other leak-free connection is used in assembling the probe nozzle to the probe liner, leak-check the train at the sampling site by plugging the nozzle and pulling a 380 mm Hg (15 in. Hg) vacuum.

NOTE: A lower vacuum may be used, provided that it is not exceeded during the test.

If an asbestos string is used, do not connect the probe to the train during the leak-check. Instead, leak-check the train by first plugging the inlet to the filter holder (cyclone, if applicable) and pulling a 380 mm Hg (15 in. Hg) vacuum (see Note immediately above). Then connect the probe to the train and leak-check at about 25 mm Hg (1 in. Hg) vacuum; alternatively, the probe may be leak-checked with the rest of the sampling train, in one step, at 380 mm Hg (15 in. Hg) vacuum. Leakage rates in excess of 4 percent of the average sampling rate or 0.00037 m³/min (0.02 cfm), whichever is less, are unacceptable.

The following leak-check instructions for the sampling train described in APTD-0576 and APTD-0581 may be helpful. Start the pump with bypass valve fully open and coarse adjust valve, completely closed. Partially open the coarse adjust valve and slowly close the bypass valve until the desired vacuum is reached. Do not reverse direction of bypass valve; this will cause water to back up into the filter holder. If the desired vacuum is exceeded, either leak-check at this higher vacuum or end the leak-check as shown below and start over.

When the leak-check is completed, first slowly remove the plug from the inlet to the probe, filter holder, or cyclone (if applicable) and immediately turn off the vacuum pump. This prevents the water in the impingers from being forced backward into the filter holder and silica gel from being entrained backward into the third impinger.

4.1.4.2 Leak-Checks During Sample Run. If, during the sampling run, a component (e.g., filter assembly or impinger) change becomes necessary, a leak-check shall be conducted immediately before the change is made. The leak-check shall be done according to the procedure outlined in Section 4.1.4.1 above, except that it shall be done at a vacuum equal to or greater than the maximum value recorded up to that point in the test. If the leakage rate is found to be no greater than 0.00037 m³/min (0.02 cfm) or 4 percent of the average sampling rate (whichever is less), the results are acceptable, and no correction will need to be applied to the total volume of dry gas metered;

If, however, a higher leakage rate is obtained, the tester shall either record the leakage rate and plan to correct the sample volume as shown in Section 6.3 of this method, or shall void the sampling run.

Immediately after component changes, leak-checks are optional; if such leak-checks are done, the procedure outlined in Section 4.1.4.1 above shall be used.

4.1.4.3 Post-test Leak-Check. A leak-check is mandatory at the conclusion of each sampling run. The leakcheck shall be done in accordance with the procedures outlined in Section 4.1.4.1, except that it shall be conducted at a vacuum equal to or greater than the maximum value reached during the sampling run. If the leakage rate is found to be no greater than 0.00057 m³/min (0.02 cfm) or 4 percent of the average sampling rate (whichever is less), the results are acceptable, and no correction need be applied to the total volume of dry gas metered.

If, however, a higher leakage rate is obtained, the tester shall either record the leakage rate and correct the sample volume as shown in Section 6.3 of this method, or shall void the sampling run.

4.1.5 Particulate Train Operation. During the sampling run, maintain an isokinetic sampling rate (within 10 percent of true isokinetic unless otherwise specified by the Administrator) and a temperature around the filter of 120±14° C (248±25° F), or such other temperature as specified by an applicable subpart of the standards or approved by the Administrator.

For each run, record the data required on a data sheet such as the one shown in Figure 5-2. Be sure to record the initial dry gas meter reading. Record the dry gas meter readings at the beginning and end of each sampling time increment, when changes in flow rates are made, before and after each leak-check, and when sampling is halted.

Take other readings required by Figure 5-2 at least once at each sample point during each time increment and additional readings when significant changes (20 percent variation in velocity head readings) necessitate additional adjustments in flow rate. Level and zero the manometer. Because the manometer level and zero may drift due to vibrations and temperature changes, make periodic checks during the traverse.

Clean the portholes prior to the test run to minimize the chance of sampling deposited material. To begin sampling, remove the nozzle cap, verify that the filter and probe heating systems are up to temperature, and that the pitot tube and probe are properly positioned. Position the nozzle at the first traverse point with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Nomographs are available, which aid in the rapid adjustment of the isokinetic sampling rate without excessive computations. These nomographs are designed for use when the Type S pitot tube coefficient is 0.88±0.02, and the stack gas equivalent density (dry, molecular weight) is equal to 29±4. APTD-0878 details the procedure for using the nomographs. If C_s and M_s are outside the above stated ranges do not use the nomographs, unless appropriate steps (see Citation 7 in Bibliography) are taken to compensate for the deviations.

When the stack is under significant negative pressure (height of impinger stem), take care to close the coarse adjust valve before inserting the probe into the stack to prevent water from backing into the filter holder. If necessary, the pump may be turned on with the coarse adjust valve closed.

When the probe is in position, block off the openings around the probe and porthole to prevent unrepresentative dilution of the gas stream.

Traverse the stack cross-section, as required by Method 1 or as specified by the Administrator, being careful not to bump the probe nozzle into the stack walls when sampling near the walls or when removing or inserting the probe through the portholes; this minimizes the chance of extracting deposited material.

During the test run, make periodic adjustments to keep the temperature around the filter holder at the proper level; add more ice and, if necessary, salt to maintain a temperature of less than 20° C (68° F) at the condenser/silica gel outlet. Also, periodically check the level and zero of the manometer.

If the pressure drop across the filter becomes too high, making isokinetic sampling difficult to maintain, the filter may be replaced in the midst of a sample run. It is recommended that another complete filter assembly be used rather than attempting to change the filter itself. Before a new filter assembly is installed, conduct a leak-check (see Section 4.1.4.2). The total particulate weight shall include the summation of all filter assembly catches.

A single train shall be used for the entire sample run, except in cases where simultaneous sampling is required in two or more separate ducts or at two or more different locations within the same duct, or, in cases where equipment failure necessitates a change of trains. In all other situations, the use of two or more trains will be subject to the approval of the Administrator.

FIGURE 5-2—PARTICULATE FIELD DATA

Form for recording particulate field data. Includes fields for: Part, Location, Operator, Date, Run No, Sample box No, Meter box No, Meter J/H, C factor, and Real time coefficient, Cp. Also includes a schematic of stack cross section and a list of parameters to be recorded: Ambient temperature, Barometric pressure, Assumed moisture, %; Probe length, m (ft); Nozzle identification No.; Average calibrated nozzle diameter, cm (in.); Probe heater setting; Leak rate, m³/min (cfm); Probe test results; Stack pressure, mm Hg (in. Hg); Filter No.

SCHEMATIC OF STACK CROSS SECTION

Table with 10 main columns: Traverse point number, Sampling time (in min), Velocity (cm Hg (in. Hg)), Stack temperature (T_s, °C (°F)), Velocity head (in. P_s, mm (in.) H₂O), Pressure differential across orifice meter (mm H₂O (in. H₂O)), Gas sample volume (m³ (ft³)), Gas sample temperature at dry gas meter (Inlet °C (°F), Outlet °C (°F)), Filter holder temperature (°C (°F)), Temperature of gas leaving condenser or last impinger (°C (°F)). Includes 'Avg' and 'Average' rows at the bottom.

Note that when two or more trains are used, separate analyses of the front-half and (if applicable) impinger catches from each train shall be performed, unless identical nozzle sizes were used on all trains, in which case, the front-half catches from the individual trains may be combined (as may the impinger catches) and one analysis of front-half catch and one analysis of impinger catch may be performed. Consult with the Administrator for details concerning the calculation of results when two or more trains are used.

At the end of the sample run, turn off the coarse adjust valve, remove the probe and nozzle from the stack, turn off the pump, record the final dry gas meter reading, and conduct a post-test leak-check, as outlined in Section 4.1.4.3. Also, leak-check the pitot lines as described in Method 2, Section 3.1; the lines must pass this leak-check, in order to validate the velocity head data.

4.1.6 Calculation of Percent Isokinetic. Calculate percent isokinetic (see Calculations, Section 6) to determine whether the run was valid or another test run should be made. If there was difficulty in maintaining isokinetic rates due to source conditions, consult with the Administrator for possible variance on the isokinetic rates.

4.2 Sample Recovery. Proper cleanup procedure begins as soon as the probe is removed from the stack at the end of the sampling period. Allow the probe to cool.

When the probe can be safely handled, wipe off all external particulate matter near the tip of the probe nozzle and place a cap over it to prevent losing or gaining particulate matter. Do not cap off the probe tip tightly while the sampling train is cooling down as this would create a vacuum in the filter holder, thus drawing water from the impingers into the filter holder.

Before moving the sample train to the cleanup site, remove the probe from the sample train, wipe off the silicone grease, and cap the open outlet of the probe. Be careful not to lose any condensate that might be present. Wipe off the silicone grease from the filter inlet where the probe was fastened and cap it. Remove the umbilical cord from the last impinger and cap the impinger. If a flexible line is used between the first impinger or condenser and the filter holder, disconnect the line at the filter holder and let any condensed water or liquid drain into the impingers or condenser. After wiping off the silicone grease, cap off the filter holder outlet and impinger inlet. Either ground-glass stoppers, plastic caps, or serum caps may be used to close these openings.

Transfer the probe and filter-impinger assembly to the cleanup area. This area should be clean and protected from the wind so that the chances of contaminating or losing the sample will be minimized.

Save a portion of the acetone used for cleanup as a blank. Take 200 ml of this acetone directly from the wash bottle being used and place it in a glass sample container labeled "acetone blank."

Inspect the train prior to and during disassembly and note any abnormal conditions. Treat the samples as follows:

Container No. 1. Carefully remove the filter from the filter holder and place it in its identified petri dish container. Use a pair of tweezers and/or clean disposable surgical gloves to handle the filter. If it is necessary to fold the filter, do so such that the particulate cake is inside the fold. Carefully transfer to the petri dish any particulate matter and/or filter fibers which adhere to the filter holder gasket, by using a dry Nylon

bristle brush and/or a sharp-edged blade. Seal the container.

Container No. 2. Taking care to see that dust on the outside of the probe or other exterior surfaces does not get into the sample, quantitatively recover particulate matter or any condensate from the probe nozzle, probe fitting, probe liner, and front half of the filter holder by washing these components with acetone and placing the wash in a glass container. Distilled water may be used instead of acetone when approved by the Administrator and shall be used when specified by the Administrator; in these cases, save a water blank and follow the Administrator's directions on analysis. Perform the acetone rinses as follows:

Carefully remove the probe nozzle and clean the inside surface by rinsing with acetone from a wash bottle and brushing with a Nylon bristle brush. Brush until the acetone rinse shows no visible particles, after which make a final rinse of the inside surface with acetone.

Brush and rinse the inside parts of the Swagelok fitting with acetone in a similar way until no visible particles remain.

Rinse the probe liner with acetone by tilting and rotating the probe while squirting acetone into its upper end so that all inside surfaces will be wetted with acetone. Let the acetone drain from the lower end into the sample container. A funnel (glass or polyethylene) may be used to aid on transferring liquid washes to the container. Follow the acetone rinses with a probe brush. Hold the probe in an inclined position, squirt acetone into the upper end as the probe brush is being pushed with a twisting action through the probe; hold a sample container underneath the lower end of the probe, and catch any acetone and particulate matter which is brushed from the probe. Run the brush through the probe three times or more until no visible particulate matter is carried out with the acetone or until none remains in the probe liner on visual inspection. With stainless steel or other metal probes, run the brush through in the above prescribed manner at least six times since metal probes have small crevices in which particulate matter can be entrapped. Rinse the brush with acetone, and quantitatively collect these washings in the sample container. After the brushing, make a final acetone rinse of the probe as described above.

It is recommended that two people be used to clean the probe to minimize sample losses. Between sampling runs, keep brushes clean and protected from contaminations.

After ensuring that all joints have been wiped clean of silicone grease, clean the inside of the front half of the filter holder by rubbing the surfaces with a Nylon bristle brush and rinsing with acetone. Rinse each surface three times or more if needed to remove visible particulate. Make a final rinse of the brush and filter holder. Carefully rinse out the glass cyclone, also (if applicable). After all acetone washings and particulate matter have been collected in the sample container, tighten the lid on the sample container so that acetone will not leak out when it is shipped to the laboratory. Mark the height of the fluid level to determine whether or not leakage occurred during transport. Label the container to clearly identify its contents.

Container No. 3. Note the color of the indicating silica gel to determine if it has been completely spent and make a notation of its condition. Transfer the silica gel from the fourth impinger to its original container and seal. A funnel may make it easier to pour the silica gel without spilling. A rubber policeman may be used as an aid in removing the silica gel from the impinger; it is not necessary to remove the small amount of dust particles that may adhere to the impinger wall and are difficult to remove. Since the gain in weight is to be used for moisture calculations, do not use any water or other liquids to transfer the silica gel. If a balance is available in the field, follow the procedure for container No. 3 in Section 4.3.

Impinger Water. Treat the impingers as follows: Make a notation of any color or film in the liquid catch. Measure the liquid which is in the first three impingers to within ± 1 ml by using a graduated cylinder or by weighing it to within ± 0.5 g by using a balance (if one is available). Record the volume or weight of liquid present. This information is required to calculate the moisture content of the effluent gas.

Discard the liquid after measuring and recording the volume or weight, unless analysis of the impinger catch is required (see Note, Section 2.1.7).

If a different type of condenser is used, measure the amount of moisture condensed either volumetrically or gravimetrically.

Whenever possible, containers should be shipped in such a way that they remain upright at all times.

4.3 Analysis. Record the data required on a sheet such as the one shown in Figure 5-3. Handle each sample container as follows:

FIGURE 5-3—ANALYTICAL DATA

Plant _____
 Date _____
 Run No. _____
 Filter No. _____
 Amount liquid lost during transport _____
 Acetone blank volume, ml _____
 Acetone wash volume, ml _____
 Acetone blank concentration, mg/mg (equation 5-4) _____
 Acetone wash blank, mg (equation 5-5) _____

Container number	Weight of particulate collected, mg		
	Final weight	Total weight	Weight gain
1			
2			
Total _____			
Loss during transport _____			
Weight of particulate matter _____			

Plant	Volume of liquid water collected	
	Impinger volume, ml	Silica gel weight, g
Plant _____		
Imp _____		
Liquid collected _____		
Total volume collected _____		

*Convert weight of water to volume by dividing total weight increase by density of water (1 g/ml).

$$\text{Volume, g} = \frac{\text{Weight water, mg}}{1 \text{ g/ml}}$$

Container No. 1. Leave the contents in the shipping container or transfer the filter and any loose particulate from the sample container to a tared glass weighing dish. Desiccate for 24 hours in a desiccator containing anhydrous calcium sulfate. Weigh to a constant weight and report the results to the nearest 0.1 mg. For purposes of this Section, 4.1, the term "constant weight" means a difference of no more than 0.5 mg or 1 percent of total weight less tare weight, whichever is greater, between two consecutive weighings, with no less than 6 hours of desiccation time between weighings.

Alternatively, the sample may be oven dried at 105° C (230° F) for 2 to 3 hours, cooled in the desiccator, and weighed to a constant weight, unless otherwise specified by the Administrator. The tester may also opt to oven dry the sample at 105° C (230° F) for 2 to 3 hours, weigh the sample, and use this weight as a final weight.

Container No. 2. Note the level of liquid in the container and confirm on the analysis sheet whether or not leakage occurred during transport. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Measure the liquid in this container either volumetrically to ±1 ml or gravimetrically to ±0.5 g. Transfer the contents to a tared 250-ml beaker and evaporate to dryness at ambient temperature and pressure. Desiccate for 24 hours and weigh to a constant weight. Report the results to the nearest 0.1 mg.

Container No. 3. Weigh the spent silica gel (or silica gel plus impinger) to the nearest 0.5 g using a balance. This step may be conducted in the field.

"Acetone Blank" Container. Measure acetone in this container either volumetrically or gravimetrically. Transfer the acetone to a tared 250-ml beaker and evaporate to dryness at ambient temperature and pressure. Desiccate for 24 hours and weigh to a constant weight. Report the results to the nearest 0.1 mg.

NOTE: At the option of the tester, the contents of Container No. 3 as well as the acetone blank container may be evaporated at temperatures higher than ambient. If evaporation is done at an elevated temperature, the temperature must be below the boiling point of the solvent; also, to prevent "bumping," the evaporation process must be closely supervised, and the contents of the beaker must be stirred occasionally to maintain an even temperature. Use extreme care, as acetone is highly flammable and has a low flash point.

4.4 Quality Control Procedures. The following quality control procedures are suggested to check the volume metering system calibration values at the field test site prior to sample collection. These procedures are optional for the tester.

4.4.1 Meter Orifice Check. Using the calibration data obtained during the calibration procedure described in Section 4.1, determine the ΔH_0 for the metering system orifice. The ΔH_0 is the orifice pressure differential in units of in. H₂O that correlates to 0.75 cfm of air at 32°R and 29.92 in. Hg. The ΔH_0 is calculated as follows:

$$\Delta H_0 = 0.0319 \Delta H \frac{T_a}{P_m} \frac{\Theta^3}{Y V_a}$$

Eq. 5-9

Where:

ΔH - Average pressure differential across the orifice meter, in. H₂O.

T_a - Absolute average dry gas meter temperature, °R.

P_m - Barometric pressure, in. Hg.

Θ - Total sampling time, min.

Y - Dry gas meter calibration factor, dimensionless.

V_a - Volume of gas sample as measured by dry gas meter, ccf.

$0.0319 = (0.0067 \text{ in. Hg}/^\circ\text{R}) \times (0.75 \text{ cfm})^3$

Before beginning the field test (a set of three runs usually constitutes a field test), operate the metering system (i.e., pump, volume meter, and orifice) at the ΔH_0 pressure differential for 10 minutes. Record the volume collected, the dry gas meter temperature, and the barometric pressure. Calculate a dry gas meter calibration check value, Y_c , as follows:

$$Y_c = \frac{10}{V_a} \left[\frac{0.0319 T_a}{P_m} \right] \Theta$$

Eq. 5-10

Where:

Y_c - Dry gas meter calibration check value, dimensionless.

10 - 10 minutes of run time.

Compare the Y_c value with the dry gas meter calibration factor Y to determine that:

$0.97Y < Y_c < 1.03Y$

If the Y_c value is not within this range, the volume metering system should be investigated before beginning the test.

4.4.2 Calibrated Critical Orifice. A calibrated critical orifice, calibrated against a wet test meter or spirometer and designed to be inserted at the inlet of the sampling meter box, may be used as a quality control check, such procedure being subject to approval by the Administrator.

5. Calibration

Maintain a laboratory log of all calibrations.

5.1 Probe Nomsie. Probe nomsies shall be calibrated before their initial use in the field. Using a micrometer, measure the inside diameter of the nomsie to the nearest 0.025 mm (0.001 in.). Make three separate measurements using different diameters each time, and obtain the average of the measurements. The difference between the high and low numbers shall not exceed 0.1 mm (0.004 in.). When nomsies become nicked, dented, or corroded, they shall be reshaped, sharpened, and recalibrated before use. Each nomsie shall be permanently and uniquely identified.

5.2 Pitot Tube. The Type 5 pitot tube assembly shall be calibrated according to the procedure outlined in Section 4 of Method 2.

5.3 Metering System. Before its initial use in the field, the metering system shall be calibrated according to the procedure outlined in APTD-0678. Instead of physically adjusting the dry gas meter dial readings to correspond to the wet test meter readings, calibration factors may be used to mathematically correct the gas meter dial readings to the proper values. Before calibrating the metering system, it is suggested that a leak-check be conducted. For metering systems having diaphragm pumps, the normal leak-check procedure will not detect leakages within the pump, for these cases

the following leak-check procedure is suggested: make a 10-minute calibration run at 0.0057 m³/min (0.02 cfm); at the end of the run, take the difference of the measured wet test meter and dry gas meter volumes divide the difference by 10, to get the leak rate. The leak rate should not exceed 0.00057 m³/min (0.02 cfm).

After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single intermediate orifice setting (based on the previous field test). With the vacuum set at the maximum value reached during the test series. To adjust the vacuum, insert a valve between the wet test meter and the inlet of the metering system. Calculate the average value of the calibration factor. If the calibration has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as outlined in APTD-0678.

Alternative procedures, e.g., using the orifice meter coefficients, maybe used, subject to the approval of the Administrator.

NOTE: If the dry gas meter coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

5.3.1 Calibration Prior to Use. Before its initial use in the field, the metering system shall be calibrated as follows: Connect the metering system inlet to the outlet of a wet test meter that is accurate to within 1 percent. Refer to Figure 5.3. The wet test meter should have a capacity of 30 liters/rev (1 ft³/rev). A spirometer of 400 liters (14 ft³) or more capacity, or equivalent, may be used for this calibration, although a wet test meter is usually more practical. The wet test meter should be periodically calibrated with a spirometer or a liquid displacement meter to ensure the accuracy of the wet test meter. Spirometers or wet test meters of other sizes may be used, provided that the specified accuracies of the procedure are maintained. Run the metering system pump for about 15 minutes with the orifice manometer indicating a median reading as expected in field use to allow the pump to warm up and to permit the interior surface of the wet test meter to be thoroughly wetted. Then, at each of a minimum of three orifice manometer settings, pass an exact quantity of gas through the wet test meter and note the gas volume indicated by the dry gas meter. Also note the barometric pressure, and the temperatures of the wet test meter, the inlet of the dry gas meter, and the outlet of the dry gas meter. Select the highest and lowest orifice settings to bracket the expected field operating range of the orifice. Use a minimum volume of 0.15 m³ (5 cf) at all orifice settings. Record all the data on a form similar to Figure 5.4 and calculate Y_c , the dry gas meter calibration factor, and ΔH_0 , the orifice calibration factor, at each orifice setting as shown on Figure 5.4. Allowable tolerances for individual Y and ΔH_0 values are given in Figure 5.4. Use the average of the Y values in the calculations in Section 6.

ing procedure is suggested (see Figure 5-4): Close the main valve on the meter box. Insert a one-hole rubber stopper with rubber tubing attached into the orifice exhaust pipe. Disconnect and vent the low side of the orifice manometer. Close off the low side orifice tap. Pressurize the system to 13 to 18 cm (5 to 7 in.) water column by blowing into the rubber tubing. Pinch off the tubing and observe the manometer for one minute. A loss of pressure on the manometer indicates a leak in the meter box; leaks, if present, must be corrected.

5.7 Barometer. Calibrate against a mercury barometer.

6. Calculations

Carry out calculations, retaining at least one extra decimal figure beyond that of the acquired data. Round off figures after the final calculation. Other forms of the equations may be used as long as they give equivalent results.

6.1 Nomenclature

- A_n = Cross-sectional area of nozzle, $m^2 (ft^2)$.
- B_w = Water vapor in the gas stream, proportion by volume.
- C_a = Acetone blank residue concentration, mg/g .
- c = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, $g/dscm (g/dscf)$.
- f = Percent of isokinetic sampling.
- L_m = Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to $0.0037 m^3/min (0.02 cfm)$ or 4 percent of the average sampling rate, whichever is less.
- L_i = Individual leakage rate observed during the leak check conducted prior to the " i^{th} " component change ($i=1, 2, 3, \dots, n$), $m^3/min (cfm)$.
- L_p = Leakage rate observed during the post-test leak check, $m^3/min (cfm)$.
- m_t = Total amount of particulate matter collected, mg .
- M_w = Molecular weight of water, 18.0 $g/g\text{-mole} (18.0 lb/lb\text{-mole})$.
- m_a = Mass of residue of acetone after evaporation, mg .
- P_{atm} = Barometric pressure at the sampling site, $mm Hg (in. Hg)$.

- P_s = Absolute stack gas pressure, $mm Hg (in. Hg)$.
- P_{std} = Standard absolute pressure, 760 $mm Hg (29.92 in. Hg)$.
- R = Ideal gas constant, $0.06236 mm Hg\text{-}m^3 / K\text{-}g\text{-mole} (21.85 in. Hg\text{-}ft^3 / R\text{-}lb\text{-mole})$.
- T_m = Absolute average dry gas meter temperature (see Figure 5-2), $^{\circ}K (R)$.
- T_s = Absolute average stack gas temperature (see Figure 5-2), $^{\circ}K (R)$.
- T_{std} = Standard absolute temperature, 293 $^{\circ}K (528 R)$.
- V_b = Volume of acetone blank, ml .
- V_w = Volume of acetone used in wash, ml .
- V_t = Total volume of liquid collected in impingers and silica gel (see Figure 5-3), ml .
- V_m = Volume of gas sample as measured by dry gas meter, $dscm (dscf)$.
- V_{mstd} = Volume of gas sample measured by the dry gas meter, corrected to standard conditions, $dscm (dscf)$.
- V_{wstd} = Volume of water vapor in the gas sample, corrected to standard conditions, $dscm (dscf)$.
- v = Stack gas velocity, calculated by Method 2, Equation 2-9, using data obtained from Method 5, $m/sec (ft/sec)$.
- W_r = Weight of residue in acetone wash, mg .
- Y = Dry gas meter calibration factor.
- ΔH = Average pressure differential across the orifice meter (see Figure 5-2), $mm H_2O (in. H_2O)$.
- ρ_a = Density of acetone, mg/ml (see label on bottle).




Figure 5-4. Leak check of meter box.

- ρ_w = Density of water, 0.9982 g/ml (0.002201 lb/ml).
- τ = Total sampling time, min.
- θ_i = Sampling time interval, from the beginning of a run until the first component change, min.
- θ_j = Sampling time interval, between two successive component changes, beginning with the interval between the first and second changes, min.
- θ_n = Sampling time interval, from the final (n^{th}) component change until the end of the sampling run, min.
- 13.6 = Specific gravity of mercury.
- 60 = Sec/min.
- 100 = Conversion to percent.

6.2 Average dry gas meter temperature and average orifice pressure drop. See data sheet (Figure 3-2).

6.3 Dry Gas Volume. Correct the sample volume measured by the dry gas meter to standard conditions (20° C, 760 mm Hg or 68° F, 29.92 in. Hg) by using Equation 5-1.

$$V_{n(100)} = V_n Y \left(\frac{T_{std}}{T_n} \right) \left[\frac{P_{std} + \frac{\Delta H}{13.6}}{P_{n(n)}} \right]$$

$$= K_1 V_n Y \frac{P_{std} + (\Delta H/13.6)}{T_n}$$

Equation 5-1

where:

- $K_1 = 0.3858$ °K/mm Hg for metric units
- $= 17.64$ °R/in. Hg for English units

NOTE: Equation 5-1 can be used as written unless the leakage rate observed during any of the mandatory leak checks (i.e., the post-test leak check or leak checks conducted prior to component changes) exceeds L_n . If L_n or L_n exceeds L_n , Equation 5-1 must be modified as follows:

(a) Case I. No component changes made during sampling run. In this case, replace V_n in Equation 5-1 with the expression:

$$V_n = (L_n - L_n) \theta$$

(b) Case II. One or more component changes made during the sampling run. In this case, replace V_n in Equation 5-1 by the expression:

$$V_n = (L_1 - L_n) \theta_1 - \sum_{i=2}^n (L_i - L_n) \theta_i - (L_n - L_n) \theta_n$$

and substitute only for those leakage rates (L_n or L_n) which exceed L_n .

6.4 Volume of water vapor.

$$V_{w(100)} = V_{10} \left(\frac{P_w}{P_{10}} \right) \left(\frac{RT_{std}}{P_{std}} \right) = K_2 V_{10}$$

Equation 5-2

where:

- $K_2 = 0.001333$ ml³/ml for metric units
- $= 0.04707$ ft³/ml for English units.

6.5 Moisture Content.

$$B_m = \frac{V_{w(100)}}{V_{n(100)} + V_{w(100)}}$$

Equation 5-3

NOTE: In saturated or water droplet-laden gas streams, two calculations of the moisture content of the stack gas shall be made, one from the impinger analysis (Equation 5-3), and a second from the assumption of saturated conditions. The lower of the two values of B_m shall be considered correct. The procedure for determining the moisture content based upon assumption of saturated conditions is given in the Note of Section 1.2 of Method 4. For the purposes of this method, the average stack gas temperature from Figure 3-2 may be used to make this determination, provided that the accuracy of the in-stack temperature sensor is ± 1 ° C (1° F).

6.6 Acetone Blank Concentration.

Equation 5-4

$$C_n = \frac{m_n}{V_{n(n)}}$$

6.7 Acetone Wash Blank.

$$W_n = C_n V_{n(n)} \quad \text{Equation 5-5}$$

6.8 Total Particulate Weight. Determine the total particulate catch from the sum of the weights obtained from containers 1 and 2 less the acetone blank (see Figure 3-3).

NOTE: Refer to Section 4.1.3 to assist in calculation of results involving two or more filter assemblies or two or more sampling trains.

6.9 Particulate Concentration.

$$C_n = (0.001 \text{ g/wg}) (m_n / V_{n(n)}) \quad \text{Equation 5-6}$$

6.10 Conversion Factors:

From	To	Multiply by
mg	g	0.001000
g/R	g/R	15.43
g/R	g/R	2.205×10^{-1}
g/m ³	g/m ³	35.31

6.11 Isokinetic Variation.

6.11.1 Calculation From Raw Data.

$$I = \frac{100 T_1 K_1 V_{10} (P_n / T_n) (P_{std} + \Delta H / 13.6)}{60 \rho_w P_n A_n}$$

Equation 5-7

where:

- $K_1 = 0.903464$ mm Hg-cm³/ml-°K for metric units.
- $= 0.002868$ in. Hg-ft³/ml-°R for English units.

6.11.2 Calculation From Intermediate Values.

$$I = \frac{T_1 V_{n(100)} P_{std} (100)}{T_n V_n \rho_w P_n (1 - B_m)}$$

$$= K_1 \frac{T_1 V_{n(100)}}{P_n V_n A_n \theta (1 - B_m)}$$

Equation 5-8

where:

- $K_1 = 4.320$ for metric units
- $= 0.09450$ for English units.

6.12 Acceptable Results. If 90 percent $< I < 110$ percent, the results are acceptable. If the particulate results are low in comparison to the standard, and I is over 110 percent or less than 90 percent, the Administrator may accept the results. Citation 4 in the bibliography section can be used to make acceptability judgments. If I is judged to be unacceptable, reject the particulate results and repeat the test.

7. Alternative Procedures

7.1 Dry Gas Meter as a Calibration Standard. A dry gas meter may be used as a calibration standard for volume measurements in place of the wet test meter specified in Section 3.3, provided that it is calibrated initially and recalibrated periodically as follows:

7.1.1 Standard Dry Gas Meter Calibration.

7.1.1.1 The dry gas meter to be calibrated and used as a secondary reference meter should be of high quality and have an appropriately sized capacity, e.g., 3 liters/rev (0.1 ft³/rev). A spirometer (400 liters or more capacity), or equivalent, may be used for this calibration, although a wet test meter is usually more practical. The wet test meter should have a capacity of 30 liters/rev (1 ft³/rev) and capable of measuring volume to within ± 1.0 percent; wet test meters should be checked against a spirometer or a liquid displacement meter to ensure the accuracy of the wet test meter. Spirometers or wet test meters of other sizes may be used, provided that the specified accuracies of the procedure are maintained.

7.1.1.2 Set up the components as shown in Figure 3.7. A spirometer, or equivalent,

may be used in place of the wet test meter in the system. Run the pump for at least 5 minutes at a flow rate of about 10 liters/min (0.35 cfm) to condition the interior surface of the wet test meter. The pressure drop indicated by the manometer at the inlet side of the dry gas meter should be minimized (no greater than 100 mm H₂O (4 in. H₂O) at a flow rate of 30 liters/min (1 cfm). This can be accomplished by using large diameter tubing connections and straight pipe fittings.




Figure 5.7 . Equipment arrangement for dry-gas meter calibration.

7.1.1.3 Collect the data as shown in the example data sheet (see Figure 5-8). Make triplicate runs at each of the flow rates and at no less than five different flow rates. The

range of flow rates should be between 10 and 34 liters/min (0.35 and 1.2 cfm) or over the expected operating range.

DATE: _____
 DRY GAS METER IDENTIFICATION: _____
 BAROMETRIC PRESSURE (P_b): _____ in. Hg

APPROXIMATE FLOW RATE (Q̄) cfm	SPIROMETER (WET METER) GAS VOLUME (V _w) ft ³	DRY GAS METER VOLUME (V _{dg}) ft ³	TEMPERATURES				DRY GAS METER PRESSURE (Δp) in. H ₂ O	TIME (t) min.	FLOW RATE (Q) cfm	METER METER COEFFICIENT (Y _{dg})	AVERAGE METER COEFFICIENT (Ȳ _{dg})
			SPIROMETER (WET METER) (t _w) °F	DRY GAS METER							
				INLET (t _i) °F	OUTLET (t _o) °F	AVERAGE (t _a) °F					
0.40											
0.60											
0.80											
1.00											
1.20											

$$Q = 17.08 \frac{V_w}{t_w} \frac{P_b}{P_b + \Delta p}$$

$$V_{dg} = \frac{V_w}{V_{dg}} \cdot \frac{t_w + 460}{t_a + 460} \cdot \frac{P_b}{P_b + \Delta p}$$

Figure 5.8. Example data sheet for calibration of a standard dry gas meter for method 5 sampling equipment (English units).

7.1.1.4 Calculate flow rate, Q, for each run using the wet test meter gas volume, V_w , and the run time, θ . Calculate the dry gas meter coefficient, Y_m , for each run. These calculations are as follows:

$$Q = K \frac{P_m V_w}{L_w + L_m \theta}$$

$$Y_m = \frac{V_w (L_w + L_m) P_m}{V_m (L_w + L_m) \left(P_m + \frac{10}{13.6} \right)}$$

Where:

K = 0.3558 for international system of units (SI); 17.64 for English units.

V_w = Wet test meter volume, liters (ft³).

V_m = Dry gas meter volume, liters (ft³).

L_w = Average dry gas meter temperature, °C (°F).

L_m = 773° C for SI units; 490° F for English units.

L_w = Average wet test meter temperature, °C (°F).

P_m = Barometric pressure, mm Hg (in. Hg).

Δp = Dry gas meter inlet differential pressure, mm H₂O (in. H₂O).

θ = Run time, min.

7.1.1.5 Compare the three Y_m values at each of the flow rates and determine the maximum and minimum values. The difference between the maximum and minimum values at each flow rate should be no greater than 0.030. Extra sets of triplicate runs may be made in order to complete this requirement. In addition, the meter coefficients should be between 0.95 and 1.05. If these specifications cannot be met in three sets of successive triplicate runs, the meter is not suitable as a calibration standard and should not be used as such. If these specifications are met, average the three Y_m values at each flow rate resulting in five average meter coefficients, Y_m .

7.1.1.6 Prepare a curve of meter coefficient, Y_m , versus flow rate, Q, for the dry gas meter. This curve shall be used as a reference when the meter is used to calibrate other dry gas meters and to determine whether recalibration is required.

7.1.2 Standard Dry Gas Meter Recalibration.

7.1.2.1 Recalibrate the standard dry gas meter against a wet test meter or spherometer annually or after every 300 hours of operation, whichever comes first. This require-

ment is valid provided the standard dry gas meter is kept in a laboratory and, if transported, cared for as any other laboratory instrument. Abuse to the standard meter may cause a change in the calibration and will require more frequent recalibrations.

7.1.2.2 As an alternative to full recalibration, a two-point calibration check may be made. Follow the same procedure and equipment arrangement as for a full recalibration, but run the meter at only two flow rates (suggested rates are 14 and 28 liters/min (0.5 and 1.0 cfm)). Calculate the meter coefficients for these two points and compare the values with the meter calibration curve. If the two coefficients are within ±1.5 percent of the calibration curve values at the same flow rates, the meter need not be recalibrated until the next date for a recalibration check.

8. Bibliography

1. Addendum to Specifications for Incinerator Testing at Federal Facilities. PHS, NCAPC, Dec. 6, 1967.
2. Martin, Robert M. Construction Details of Isokinetic Source-Sampling Equipment. Environmental Protection Agency, Research Triangle Park, N.C. APTD-0581, April 1971.
3. Rom, Jerome J. Maintenance, Calibration, and Operation of Isokinetic Source Sampling Equipment. Environmental Protection Agency, Research Triangle Park, N.C. APTD-0576, March, 1972.
4. Smith, W. S., R. T. Shigehara, and W. P. Todd. A method of Interpreting Stack Sampling Data. Paper Presented at the 63d Annual Meeting of the Air Pollution Control Association, St. Louis, Mo. June 14-19, 1970.
5. Smith, W. S., et al. Stack Gas Sampling Improved and Simplified With New Equipment. APCA Paper No. 67-119, 1967.
6. Specifications for Incinerator Testing at Federal Facilities. PHS, NCAPC, 1967.
7. Shigehara, R. T. Adjustments in the EPA Nomograph for Different Pitot Tube Coefficients and Dry Molecular Weights. Stack Sampling News 24-11, October, 1974.
8. Vollaro, R. F. A Survey of Commercially Available Instrumentation For the Measurement of Low-Range Gas Velocities. U.S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, N.C. November, 1976 (unpublished paper).
9. Annual Book of ASTM Standards, Part 28. Gaseous Fuels: Coal and Coke; Atmospheric Analysis. American Society for Testing and Materials, Philadelphia, Pa. 1974, pp. 617-622.
10. Fetiz, L. G., G. L. Clizard, G. E. Lacey, and J. D. McCain. Inertial Cascade Impactor Substrate Media for Fine Gas Sampling. U.S. Environmental Protection Agency, Research Triangle Park, N.C. 5771, Publication No. EPA-600/7-77-020, June 1977, 23 p.
11. Westin, P. B. and R. T. Shigehara. Procedure for Calibrating and Using Dry Gas Volume Meters as Calibration Standards. Source Evaluation Society Newsletter, XI:17-30, February 1972.

APPENDIX C-1
CLEAN-UP/FIELD DATA

METHOD 5 OR 17 FIELD DATA SHEET

ETS, INC.

PROJECT Westinghouse BAY RESOURCES
 LOCATION Panama City, Fla.
 PROCESS MISW
 CONTROL EQUIPMENT ESP
 SAMPLING POINT OUTLET
 POLLUTANTS _____


DATE 6/4-6/5/87 STD TEMP 68 °F
 RUN # 1-6 METER BOX 3
 OPERATOR Jim Eckenrode GAS METER 2.052 ΔHe
 AMBIENT TEMP 80-90 GAS METER Y 1.001

	P _h
611	30.04
612	30.03
613	30.10
614	30.00
615	30.02

Cp .84 PITOT TUBE COEFFICIENT
 P BAR _____ "HG" LOCAL BAROMETRIC PRESSURE
 DN .254 "NOZZLE" DIAMETER
 AS 15.32072 ft² STACK AREA
 ASSUMED Bws 15% * MOISTURE

STACK SCHEMATIC

UPSTREAM DISTURBANCE >8
 DOWNSTREAM DISTURBANCE >2




TRAVERSE POINTS

		13" ports	
NUMBER	INCHES	NUMBER	INCHES
A 1	50.67		63.67
2	45.26		58.26
3	37.31		50.31
4	15.69		38.69
5	7.74		20.74
6	2.33		15.33
B 1	50.67		
2	45.26		
3	37.31		
4	15.69		
5	7.74		
6	2.33		

ORSAT MEASUREMENT

CO ₂	O ₂	CO	N ₂



AVG

cmthd5

FLA 2

Run 2 unit #2

PLANT Westinghouse

DATE June 4, 1957

RUN # unit #2

START TIME: 1311

P #	SAMPLE TIME	CLOCK TIME	STATIC PRESS.	Ts °F	STACK Δ P	METER Δ h	Vm ft ³	Tm INLET	Tm OUTLET	OVEN TEMP.	TEXT	VAC in Hg
1	0			437	.49	1.24	196.56	101	99	250	<70	3
2	5		-.47	437	.46	1.15	22.6	99	99	270	<70	3
3	10			437	.45	1.12	25.4	99	99	251	<70	3
4	15			444	.71	1.80	28.2	100	99	254	<70	4
5	20			448	.72	1.82	31.7	102	100	253	<70	4
6	25			431	.57	1.44	35.2	103	100	251	<70	3
							38.3					
1	30			447	.90	2.29	38.3	102	100	251	<70	5
2	35			459	1.00	2.50	42.2	103	101	257	<70	5
3	40		-.69	462	1.05	2.65	46.3	104	101	257	<70	6
4	45			463	.87	2.20	50.4	102	100	253	<70	5
5	50			465	.90	2.30	54.3	103	100	256	<70	5
6	55			455	.68	1.71	58.1	104	101	256	<70	4
	60						61.448					

AVG:

TIME: 1413

LEAK CHECK .01 @ 10" Hg

cmthd5

FLA1

Run 2 Unit #1

PLANT Westinghouse

DATE June 5, 1987

RUN # Unit #1

START TIME: 1140

P #	SAMPLE TIME	CLOCK TIME	STATIC PRESS.	Ts °F	STACK Δ P	METER Δ h	Vm ft ³	Tm INLET	Tm OUTLET	OVEN TEMP.	TEXIT	VAC IN H.
1	0			433	.66	1.70	159.753	97	96	251	<70	3
2	5			433	.70	1.79	162.8	97	97	254	<70	4
3	10		-56	433	.77	1.96	166.2	97	97	251	<70	4
4	15			434	.65	1.70	169.7	98	96	256	<70	4
5	20			434	.66	1.70	173.1	99	98	256	<70	4
6	25			399	.38	0.95	176.5	101	99	255	<70	2.5
					81	20	179.0					
1	30			434	.81	2.0	179.0	101	99	255	<70	4.5
2	35			435	.80	2.10	182.7	102	100	256	<70	5.0
3	40			435	.82	2.09	186.3	102	100	254	<70	5.0
4	45			434	.71	1.82	190.0	101	101	253	<70	5.0
5	50			435	.63	1.59	193.5	101	100	253	<70	4.0
6	55			412	.45	1.13	196.8	101	100	256	<70	3
	60						199.954					

AVG: END TIME: 1244

LEAK CHECK .008 @ 7 " Hg

cmthd5

FLA1

Run 3 unit #1

PLANT Westinghouse

DATE June 5, 1987

RUN # unit #1

START TIME: 1305

#	SAMPLE TIME	CLOCK TIME	STATIC PRESS.	Ts °F	STACK Δ P	METER Δ h	Vm ft ³	Tm INLET	Tm OUTLET	OVEN TEMP.	TEXT	VAC. in Hg
1	0			431	.67	1.70	200.05	100	99	246	<70	5
2	5			434	.70	1.80	203.3	98	97	260	<70	5
3	10		-56	435	.70	1.80	206.6	98	97	257	<70	5
4	15			435	.66	1.68	210.1	101	97	257	<70	5
5	20			435	.58	1.48	213.4	100	98	262	<70	5
6	25			370	.31	.78	216.4	101	98	267	<70	3
							219.1					
1	30			429	.66	1.68	219.1	100	99	257	<70	5
2	35			431	.67	1.70	222.3	99	98	261	<70	5
3	40			434	.65	1.65	225.6	98	97	262	<70	5
4	45			435	.61	1.52	228.9	98	97	262	<70	5
	50			434	.52	1.30	232.1	99	98	263	<70	4
	55			420	.39	.98	235.1	99	98	262	<70	4
	60						237.20					

AVG:

TIME:

LEAK CHECK .001 @ 5" Hg

cmthd5

METHOD 5 LAB ANALYSIS

CLIENT Westinghouse

DATE OF TEST June 5, 1987

DATE OF ANALYSIS June 5, 1987 / June 8, 1987

SAMPLE BOX # Nitech #3

ΔH @ 2.052 Y 1.001

BAROMETRIC PRESSURE 30.02 inches Hg

	* RUN 1 unit #1	RUN 1 RUN 2 unit #1	RUN 2 RUN 3 unit #1	RUN 3 RUN 4 unit #1
PROBE WASH				
BEAKER				
	TARE _____ mg	TARE <u>79.15413</u>	TARE <u>81.31562</u>	TARE <u>77.18925</u>
	FINAL _____ mg	FINAL <u>79.1787</u>	FINAL <u>81.34051</u>	FINAL <u>77.20215</u>
FILTER				
	# <u>87-305</u>	# <u>87-304</u>	# <u>86-262</u>	# <u>86-263</u>
	TARE _____ mg	TARE <u>1.33607</u>	TARE <u>1.4115</u>	TARE <u>1.22594</u>
	FINAL _____ mg	FINAL <u>1.34886</u>	FINAL <u>1.17034</u>	FINAL <u>1.25617</u>
IMPINGER				
	#1 <u>544</u> / ml	#1 <u>581</u> / <u>712</u>	#1 <u>575</u> / <u>678</u>	#1 <u>591</u> / <u>702</u>
	#2 <u>551</u> / ml	#2 <u>566</u> / <u>591</u>	#2 <u>553</u> / <u>579</u>	#2 <u>570</u> / <u>596</u>
	#3 _____ ml	#3 _____	#3 _____	#3 _____
SILICA GEL				
	TARE <u>623</u> mg	TARE <u>633</u>	TARE <u>616</u>	TARE <u>639</u>
	FINAL _____ mg	FINAL <u>643</u>	FINAL <u>629</u>	FINAL <u>654</u>
ORSAT				
	CO ₂ _____ %	CO ₂ <u>11.5</u> <u>11.5</u> %	CO ₂ <u>11.0</u> <u>11.1</u> <u>11.1</u> %	CO ₂ <u>11.4</u> <u>11.4</u> %
	O ₂ _____ %	O ₂ <u>7.3</u> <u>7.2</u> <u>7.2</u> %	O ₂ <u>9.4</u> <u>9.3</u> <u>9.3</u> %	O ₂ <u>8.6</u> <u>8.8</u> <u>8.8</u> %

* VOIDED - STEAM FLOW ONLY ABOUT 60% OF MAX.

METHOD 5 LAB ANALYSIS

CLIENT Westinghouse

DATE OF TEST June 4, 1987 DATE OF ANALYSIS June 4, 1987 / June 8, 1987

SAMPLE BOX # Nutech #3 ΔH @ 2.052 Y 1.001

BAROMETRIC PRESSURE 30.0 inches Hg

	<u>RUN 1</u> <u>Unit #2</u>	<u>RUN 2</u> <u>Unit #2</u>	<u>RUN 3</u> <u>unit #2</u>	<u>RUN 4</u>
PROBE WASH				BLANK
BEAKER	TARE <u>77.38123</u> mg FINAL <u>77.4008</u> mg	TARE <u>78.94502</u> FINAL <u>78.9552</u>	TARE <u>77.88238</u> FINAL <u>77.90583</u>	TARE <u>82.13472</u> FINAL <u>82.13657</u>
FILTER	# <u>86-275</u> TARE <u>1.18793</u> mg FINAL <u>1.21832</u> mg	# <u>86-261</u> TARE <u>1.20971</u> FINAL <u>1.24099</u>	# <u>86-274</u> TARE <u>1.14692</u> FINAL <u>1.19683</u>	# <u>86-233</u> TARE <u>1.34697</u> FINAL <u>1.34695</u>
IMPINGER	#1 <u>567/637</u> ml #2 <u>565/612</u> ml #3 <u>—</u> ml	#1 <u>555/673</u> #2 <u>559/589</u> #3 <u>—</u>	#1 <u>574/683</u> #2 <u>572/600</u> #3 <u>—</u>	#1 <u>—</u> #2 <u>—</u> #3 <u>—</u>
SILICA GEL	TARE <u>617</u> mg FINAL <u>632</u> mg	TARE <u>612</u> FINAL <u>624</u>	TARE <u>635</u> FINAL <u>647</u>	TARE <u>—</u> FINAL <u>—</u>
ORSAT	CO ₂ <u>11.3 11.4 11.4</u> % O ₂ <u>7.6 7.8 7.8</u> %	CO ₂ <u>10.4 10.4</u> % O ₂ <u>8.9 8.8 8.8</u> %	CO ₂ <u>11.5 11.7 11.7</u> % O ₂ <u>8.6 8.5 8.5</u> %	

Acetone Blank

$$C_a = \frac{m_a}{V_a \cdot \rho_a}$$

$C_a = .000025$

$$m_a = 82.13472 - 82.13667 = .001937$$


$$V_a = 100 \text{ ml}$$

$$\rho_a = .785$$

USEPA METHOD 9
 OPACITY OBSERVATION
 BAY COUNTY
 RESOURCE RECOVERY FACILITY
 PANAMA CITY, FLORIDA

UNIT: 1
 DATE: 9:53 6/5/87
 TIME STARTED: 9:53
 TIME ENDED: 10:53
 OBSERVER: S. J. BEADY
 WIND SPEED/DIRECTION: 3-5 E
 SKY CONDITIONS: CLEAR

OBSERVER POSITION



SEC 15 30 45 60

15 30 45 60

UNIT #	15	30	45	60
1	10	5	5	10
2	5	5	5	5
3	5	5	5	5
4	5	5	5	5
5	5	5	5	5
6	5	5	5	5
7	5	5	5	5
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	5	5	5	5
12	5	5	5	5
13	5	5	5	5
14	5	5	5	5
15	5	5	5	5
16	5	5	5	5
17	5	5	5	5
18	5	5	5	5
19	5	5	5	5
20	5	5	5	5
21	5	5	5	5
22	5	5	5	5
23	5	10	10	10
24	10	10	5	5
25	5	5	5	5
26	5	5	5	5
27	10	10	10	5
28	10	5	5	5
29	5	5	5	5
30	5	5	5	5


UNIT #	15	30	45	60
31	10	10	10	10
32	5	5	5	5
33	5	5	5	5
34	5	5	5	10
35	5	5	5	5
36	5	5	5	5
37	5	5	5	10
38	5	5	10	10
39	5	5	10	10
40	10	10	10	15
41	10	10	10	10
42	10	10	10	10
43	10	5	10	10
44	5	5	5	5
45	5	5	5	5
46	5	5	5	5
47	5	5	5	5
48	5	5	5	5
49	5	5	5	5
50	5	5	5	5
51	5	5	5	5
52	5	5	5	5
53	5	5	5	5
54	5	5	5	5
55	5	5	5	5
56	5	5	5	5
57	5	5	5	5
58	5	5	10	5
59	5	5	5	5
60	10	10	10	10

UNIT # 1 on UNIT #

USEPA METHOD 9
 OPACITY OBSERVATION
 BAY COUNTY
 RESOURCE RECOVERY FACILITY
 PANAMA CITY, FLORIDA

UNIT: 1
 DATE: 6/5/87
 TIME STARTED: 11:40
 TIME ENDED: 12:40
 OBSERVER: S.J. Beard
 WIND SPEED/DIRECTION: 2-3 N
 SKY CONDITIONS: Partly Cloudy

OBSERVER POSITION



SEC 15 30 45 60

15 30 45 60

MIN	15	30	45	60
1	5	5	5	5
2	5	5	5	5
3	5	5	5	5
4	5	5	5	5
5	5	5	10	5
6	5	5	5	5
7	5	5	5	5
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	5	5	5	5
12	5	5	5	5
13	5	5	5	5
14	5	5	5	5
15	5	5	5	5
16	5	5	5	5
17	5	5	5	5
18	5	5	6	5
19	5	5	5	5
20	5	5	5	6
21	5	5	5	5
22	5	5	5	5
23	5	5	5	5
24	5	5	5	5
25	5	5	5	5
26	5	5	5	5
27	5	5	5	5
28	5	5	5	5
29	10	5	5	5
30	10	5	5	5

	15	30	45	60
31	5	5	5	5
32	5	5	5	5
33	5	5	5	5
34	5	5	5	5
35	5	5	5	5
36	5	5	5	5
37	5	5	5	5
38	5	5	5	5
39	5	5	5	5
40	5	5	5	5
41	5	5	5	5
42	5	5	5	5
43	5	5	5	5
44	5	5	5	5
45	5	5	5	5
46	5	5	5	5
47	5	5	5	5
48	5	5	5	5
49	5	5	5	5
50	5	5	5	5
51	5	5	5	5
52	10	5	5	5
53	5	5	5	5
54	5	5	5	5
55	5	5	5	5
56	5	5	5	5
57	5	5	5	5
58	5	10	10	10
59	5	5	5	5
60	5	5	5	5


Ret. 3 and Unit #1

USEPA METHOD 9 OPACITY OBSERVATION

BAY COUNTY
RESOURCE RECOVERY FACILITY
PANAMA CITY, FLORIDA

UNIT: 1
 DATE: 6/5/97
 TIME STARTED: 1:10
 TIME ENDED: 2:10
 OBSERVER: S. J. BRADY
 WIND SPEED/DIRECTION: 2 - W
 SKY CONDITIONS: CLEAR

OBSERVER POSITION



SEC 15 30 45 60

15 30 45 60

MIN	15	30	45	60
1	5	5	5	5
2	5	5	5	5
3	5	5	5	5
4	5	5	5	5
5	5	5	5	5
6	5	5	5	5
7	5	5	5	5
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	5	5	5	5
12	5	5	5	5
13	5	5	5	5
14	5	5	5	5
15	5	5	5	5
16	5	5	5	5
17	5	5	5	5
18	5	5	5	5
19	5	5	5	5
20	5	5	5	5
21	5	5	5	5
22	5	5	5	5
23	5	5	5	5
24	5	5	5	5
25	5	5	5	5
26	5	5	5	5
27	5	5	5	5
28	5	5	5	5
29	5	5	5	5
30	5	5	5	5

	15	30	45	60
31	5	5	5	5
32	5	5	5	5
33	5	5	5	5
34	5	5	5	5
35	5	5	5	5
36	5	5	5	5
37	5	5	5	5
38	5	5	5	5
39	5	5	5	5
40	5	5	5	5
41	5	5	5	5
42	5	5	5	5
43	5	5	5	5
44	5	5	5	5
45	5	5	5	5
46	5	5	5	5
47	5	5	5	5
48	5	5	5	5
49	5	5	5	5
50	5	5	5	5
51	5	5	5	5
52	5	5	5	5
53	5	5	5	5
54	5	5	5	5
55	5	5	5	5
56	5	5	5	5
57	5	5	5	5
58	5	5	5	5
59	5	5	5	5
60	5	5	5	5


RUN # 3 ON UNIT #1

USEPA METHOD 9
OPACITY OBSERVATION

BAY COUNTY
RESOURCE RECOVERY FACILITY
PANAMA CITY, FLORIDA

UNIT: 2
DATE: 6/14/87
TIME STARTED: 10:10 AM
TIME ENDED: 10:47
OBSERVER: S. J. BEAN
WIND SPEED/DIRECTION: < 2 S
SKY CONDITIONS: SCATTERED CLOUDS

OBSERVER POSITION




	SEC 15	30	45	60
MIN 1	5	5	5	5
2	5	5	5	5
3	5	5	5	5
4	5	5	5	5
5	5	5	5	5
6	5	5	5	5
7	5	5	5	5
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	5	5	5	5
12	5	5	5	5
13	5	5	5	5
14	5	5	5	5
15	5	5	5	5
16	5	5	5	5
17	5	5	5	5
18	5	5	5	5
19	5	5	5	5
20	5	5	5	5
21	5	5	5	5
22	5	5	5	5
23	5	5	5	5
24	5	5	5	5
25	5	5	5	5
26	5	5	5	5
27	5	5	5	5
28	5	5	5	5
29	5	5	5	5
30	5	5	5	10

	15	30	45	60
31	10	10	5	5
32	10	10	10	10
33	10	10	5	5
34	5	5	10	5
35	5	5	5	5
36	5	5	5	5
37	5	5	5	5
38	END OF TEST			
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				
60				

USEPA METHOD 9
 OPACITY OBSERVATION
 BAY COUNTY
 RESOURCE RECOVERY FACILITY
 PANAMA CITY, FLORIDA

UNIT: 2
 DATE: 6/14/67
 TIME STARTED: 1:10 PM
 TIME ENDED: 2:10 PM
 OBSERVER: S.J. Beary
 WIND SPEED/DIRECTION: 2-4 S
 SKY CONDITIONS: Partly Cloudy

OBSERVER POSITION



SEC 15 30 45 60

15 30 45 60


MIN 1	5	5	5	5
2	5	5	5	5
3	5	5	5	5
4	5	5	5	5
5	5	5	5	5
6	5	5	5	5
7	5	5	5	5
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	5	5	5	5
12	5	5	5	10
13	10	10	10	10
14	10	10	10	5
15	10	5	5	10
16	5	5	5	5
17	5	5	5	5
18	5	5	5	5
19	5	5	5	5
20	5	5	5	5
21	5	5	5	5
22	5	5	5	5
23	5	5	5	5
24	5	5	5	5
25	10	10	10	10
26	10	5	10	5
27	5	5	5	5
28	5	5	5	5
29	5	5	5	5
30	5	5	5	5

31	5	5	5	5
32	5	5	5	5
33	5	5	5	5
34	5	5	5	5
35	5	5	5	5
36	5	5	5	5
37	5	5	5	5
38	5	5	5	5
39	5	5	5	5
40	5	5	5	5
41	5	5	5	5
42	5	5	5	5
43	5	5	5	5
44	5	5	5	5
45	5	5	5	5
46	5	10	10	10
47	5	10	5	5
48	5	5	5	5
49	5	5	5	5
50	5	5	5	5
51	5	5	5	5
52	5	5	5	5
53	5	5	5	5
54	5	5	5	5
55	5	5	5	5
56	5	5	5	5
57	5	5	5	5
58	5	5	5	5
59	5	5	5	5
60	5	5	5	5

Run # 1 in Unit # 2

USEPA METHOD 9
 OPACITY OBSERVATION
 BAY COUNTY
 RESOURCE RECOVERY FACILITY
 PANAMA CITY, FLORIDA

OBSERVER POSITION



UNIT: 2
 DATE: 6/4/87
 TIME STARTED: 3:25
 TIME ENDED: 4:25
 OBSERVER: S. B. B. B.
 WIND SPEED/DIRECTION: 3-4 SW
 SKY CONDITIONS: P. Cloudy

SEC 15 30 45 60

15 30 45 60

MIN 1	5	5	5	5
2	5	5	5	5
3	5	5	5	5
4	5	5	5	5
5	5	5	5	5
6	5	5	5	5
7	5	5	5	5
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	10	10	5	5
12	10	10	10	5
13	5	5	5	5
14	5	5	5	5
15	10	10	10	5
16	5	5	5	10
17	5	5	5	5
18	5	5	5	5
19	5	5	5	5
20	5	5	5	5
21	5	5	5	5
22	5	5	5	5
23	5	5	5	5
24	5	5	5	6
25	5	5	5	5
26	5	5	5	5
27	5	5	5	6
28	5	5	5	5
29	5	5	5	5
30	5	5	5	5

31	5	5	5	5
32	5	5	5	5
33	5	5	5	5
34	5	10	5	5
35	5	5	5	5
36	5	5	5	5
37	5	5	5	5
38	5	5	5	5
39	10	10	10	10
40	10	10	10	10
41	10	10	10	5
42	10	10	5	5
43	5	5	10	5
44	5	5	5	5
45	5	5	5	5
46	5	5	5	5
47	5	5	5	5
48	5	5	5	5
49	10	5	5	5
50	5	5	5	5
51	10	5	5	5
52	5	10	10	5
53	10	10	5	5
54	10	5	5	5
55	10	10	5	10
56	5	5	5	5
57	5	5	5	5
58	5	5	10	5
59	10	5	5	5
60	20	20	10	10

Change
 Wind
 5-7
 8-12
 12-15

COLM
 2-4

APPENDIX D-1
CALIBRATIONS

ETS, INC.

Pitot tube assembly level? ✓ yes _____ no _____

Pitot tube openings damaged? _____ yes (explain below) ✓ no _____

$a_1 = 2.5^\circ (<10^\circ)$, $a_2 = 1.5^\circ (<10^\circ)$, $B_1 = 1^\circ (<5^\circ)$,

$B_2 = 1^\circ (<5^\circ)$

$\gamma = 4.0$ $\theta = 0.0$

$Z = A \sin \gamma = 0.67$ cm (in.); < 0.32 cm ($< 1/8$ in.),

$W = A \sin \theta = 0.0$ cm (in.); < 0.08 cm ($< 1/32$ in.)

$P_A = .58$ cm (in.) $P_b = .58$ cm (in.)

$D_t = .313$ cm (in.)

Comments: Pitot tube meets all baseline criteria \therefore

C_p of .84 may be assumed

JS

Calibration required? No

THERMOCOUPLE CALIBRATION DATA SHEET

Date: 1-12-87 Thermocouple No.: NUTECH 3
 Ambient Temperature: 69°F °F Barometric pressure: 30.00 "Hg
 Calibrator: J. SMITH Reference: Mercury-in-glass:
 Other: _____

Reference point No. ^a	Source* (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Difference, % ^b
32°	ICE BATH	32	32	0.0
100	HOT OIL	100	98	2.0
200	↓	200	199	1.0
300		300	300	0.0
400		400	400	0.0
			Average % difference	0.60

^a Every 100°F for each reference point when using furnace up to 500°F.

- * Source: 1) Ice bath
- 2) Furnace

^b Percent difference ≤ 1.5%

$$\frac{\text{Ref. temp. } ^\circ\text{F} - \text{thermocouple temp. } ^\circ\text{F}}{\text{Ref. temp. } ^\circ\text{F}} \times 100$$

NOZZLE CALIBRATION

Date 6/4/87Calibrated by Jim Eckersode

Nozzle identification number	D ₁ , in.	D ₂ , in.	D ₃ , in.	ΔD, in.	D _{avg}
(1/4")	.255	.254	.254	.001	.254

where:

D_{1,2,3} = nozzle diameter measured of a different diameter, in.
Tolerance = measure within 0.001 in.

ΔD = maximum difference in any two measurements, in.
Tolerance = 0.004 in.

D_{avg} = average of D₁, D₂, and D₃.

ETS, INC.

DRY GAS METER AND ORIFICE
POST TEST CALIBRATION

Date 6/16/87

Box No. #3

Barometric pressure, $P_b = \overset{29.95}{\underline{\quad}} \text{ in. Hg}$

Dry gas meter No. 710917

$\Delta H = \underline{1.67} \text{ in. H}_2\text{O}$

Vac. = 10" Hg

Orifice manometer setting, ΔH , in. H ₂ O	Gas volume wet test meter V_w , ft ³	Gas volume dry gas meter V_d , ft ³	Temperature				Time θ , min	γ	$\Delta H\theta$
			Wet test		Dry gas meter				
			Meter t_w , °F	Inlet t_{di} , °F	Outlet t_{do} , °F	Average t_d , °F			
1.67	13.853	14.396	70	92	94	93	21	1.002	2.054
1.67	12.619	13.086	70	93	94	93.5	19	1.003	2.034
1.67	12.624	13.090	70	94	95	94.5	19	1.005	2.028
Average								1.003	2.039

Calculations

ΔH	$\frac{\Delta H}{13.6}$	γ	$\Delta H\theta$
		$\frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$
1.67	.1228	1.002	2.054
1.67	.1228	1.003	2.034
1.67	.1228	1.005	2.028

γ = Ratio of accuracy of wet test meter to dry test meter. Tolerance = ± 0.01
 $\Delta H\theta$ = Orifice pressure differential that gives 0.75 cfm of air at 70 F and 29.92 inches of mercury, in. H₂O. Tolerance = ± 0.15


JE.

APPENDIX B

**OPACITY MEASUREMENTS FOR
MAY 12, 13, AND 14, 1987
COMPLIANCE TESTS**

	INITIAL	FINAL
OBSERVER LOCATION		
DISTANCE TO DISCHARGE	350'	
DIRECTION TO DISCHARGE	N-NE	
HEIGHT OF OBSERVATION POINT	61.5 M	
BACKGROUND DESCRIPTION	LIGHT BLUE	
WEATHER CONDITIONS		
WIND DIRECTION	S-SE	
WIND SPEED	0-5 MPH	
AMBIENT TEMPERATURE	75°F	
SKY CONDITIONS	PARTLY CLOUDY	
PLUME DESCRIPTION		
COLOR	Light Gray w/ some	
DISTANCE VISIBLE	61.5 M	

DIAGRAM OF OBSERVER AND EMISSION POINT



COMMENTS

PARTLY CLOUDY - PLUME NOW APPEARS LIGHT GRAY W/ SOME BROWN.

OBSERVER SIGNATURE

John Richardson

ETS, INC.

DATE: 5/12/87
 COMPANY: Bay County Resource REGISTRATION NO. _____
 LOCATION: Panama City, Fla.
 EMISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT ≈ 150'
 OBSERVER: John Richardson CERTIFICATION EXPIRATION DATE 10/87

CLOCK TIME: INITIAL 2 : 15 A.M. (P.M.) FINAL 2 : 35 A.M. (P.M.)
Run 1, Unit 2

VISIBLE EMISSION READINGS

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	0							
	1							
	2							
	3							
	4							
	5							
	6							
	7							
	8							
	9							
	10							
	11							
	12							
	13							
	14							
2	15	5	5	5	5			
	16	5	5	5	5			
	17	5	5	5	5			
	18	5	5	5	5			
	19	5	5	5	5			
	20	5	5	5	5			
	21	5	5	5	5			
	22	5	5	5	5			
	23	5	5	5	5			
	24	5	5	5	5			
	25	5	5	5	5			
	26	5	5	5	5			
	27	5	5	5	5			
	28	5	5	5	5			
	29	5	5	5	5			

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	30	5	5	5	5			
	31	5	5	5	5			
	32	5	5	5	5			
	33	5	5	5	5			
	34	5	5	5	5			
	35	5	5	5	5			
	36							
	37							
	38							
	39							
	40							
	41							
	42							
	43							
	44							
	45							
	46							
	47							
	48							
	49							
	50							
	51							
	52							
	53							
	54							
	55							
	56							
	57							
	58							
	59							

INITIAL

FINAL

DIAGRAM OF OBSERVER AND EMISSION POINT

OBSERVER LOCATION

DISTANCE TO DISCHARGE

DIRECTION TO DISCHARGE

HEIGHT OF OBSERVATION POINT

BACKGROUND DESCRIPTION

WEATHER CONDITIONS

WIND DIRECTION

WIND SPEED

AMBIENT TEMPERATURE


SEA CONDITIONS

MOON DESCRIPTION

COLOR

DISTANCE VISIBLE

350'		
N-NE		
GROUND		
GRAY/WHITE CLOUDS		
SOUTH		
0-5 MPH		
85°F		
CLOUDY		
FAINT GRAY		
5-10'		



* OBSERVATION PT.

COMMENTS



HAS BECOME COMPLETELY CLOUDY NOW. BACKGROUND IS STILL SOMEWHAT LIGHT.

OBSERVER SIGNATURE

John Richardson

ETS, INC.

5/13/87

COMPANY BAY CO. RESOURCES REGISTRATION NO. _____
 LOCATION MANAMA CITY 11.
 EMISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT 150'
 OPERATOR JOHN RICHMOND CERTIFICATION EXPIRATION DATE 10/87

CLOCK TIME: INITIAL 5 : 10 A.M./P.M. FINAL 5 : 35 A.M./P.M.

VISIBLE EMISSION READINGS


RUN 2 BOILER 2

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	0							
	1							
	2							
	3							
	4							
	5							
	6							
	7							
	8							
	9							
5	10	5	10	5	10			
	11	5	5	5	5			
	12	5	5	5	5			
	13	5	5	5	5			
	14	5	5	5	5			
	15	5	5	5	5			
	16	5	5	5	5			
	17	5	5	5	5			
	18	5	5	5	5			
	19	5	5	5	5			
	20	5	5	5	5			
	21	5	5	5	5			
	22	5	5	5	5			
	23	5	5	5	5			
	24	5	5	5	5			
	25	5	5	5	5			
	26	5	5	5	5			
	27	5	5	5	5			
	28	5	5	5	5			
	29	5	5	5	5			
	30	5	5	5	5			
	31	5	5	5	5			
	32	5	5	5	5			
	33	5	5	5	5			
	34	5	5	5	5			
	35	5	5	5	5			
	36							
	37							
	38							
	39							
	40							
	41							
	42							
	43							
	44							
	45							
	46							
	47							
	48							
	49							
	50							
	51							
	52							
	53							
	54							
	55							
	56							
	57							
	58							
	59							

INITIAL FINAL

SERVER LOCATION		
DISTANCE TO DISCHARGE	350'	
DIRECTION TO DISCHARGE	N-NE	
HEIGHT OF OBSERVATION POINT	GROUND	
BACKGROUND DESCRIPTION	BLUE-GRAY SKY	
WEATHER CONDITIONS		
WIND DIRECTION	SOUTH	
WIND SPEED	0-5 MPH	
AMBIENT TEMPERATURE	75°F	
SMOKE CONDITIONS	MODERATELY CLOUDY	
SMOKE DESCRIPTION		
COLOR	LIGHT GRAY	
DISTANCE VISIBLE		

DIAGRAM OF OBSERVER AND EMISSION POINT



COMMENTS



READINGS AGAIN VERY LOW W/ EXCEPTION OF ≈ 7:29 PM
 WHEN OPACITY ROSE TO ≈ 10%. BACKGROUND IMPROVED
 OVER RUN 2 @ 1:50 PM.
 RUN 3 ↑, Boiler 1 @ 9:10

OBSERVER SIGNATURE

John Richards

ETS, INC.

5/13/87

COMPANY Bay County Resources REGISTRATION NO. _____

LOCATION Panama City, Fl.

MISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT 5 150'

SERVER JOHN RICHARDSON CERTIFICATION EXPIRATION DATE 10/87

CLOCK TIME: INITIAL 7 : 10 A.M./P.M. FINAL 7 : 30 A.M./P.M.
RUN 3 BOILER 2


VISIBLE EMISSION READINGS

HR.	MIN.	SECONDS				STEAM PLUME CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	0							
	1							
	2							
	3							
	4							
	5							
	6							
	7							
	8							
	9							
<u>7</u>	10	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	11	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	12	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	13	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	14	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	15	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	16	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	17	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	18	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	19	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	20	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	21	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	22	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	23	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	24	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	25	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	26	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	27	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	28	<u>3</u>	<u>5</u>	<u>5</u>	<u>10</u>			
	29	<u>10</u>	<u>10</u>	<u>10</u>	<u>5</u>			

HR.	MIN.	SECONDS				STEAM PLUME CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	30							
	31							
	32							
	33							
	34							
	35							
	36							
	37							
	38							
	39							
	40							
	41							
	42							
	43							
	44							
	45							
	46							
	47							
	48							
	49							
	50							
	51							
	52							
	53							
	54							
	55							
	56							
	57							
	58							
	59							

	INITIAL	FINAL
OBSERVER LOCATION		
DISTANCE TO DISCHARGE	500'	
DIRECTION TO DISCHARGE	N-NW	
HEIGHT OF OBSERVATION POINT	GROUND	
BACKGROUND DESCRIPTION	BLUE SKY W SOFT CLOUDS	
WEATHER CONDITIONS		
WIND DIRECTION	EAST	
WIND SPEED	0-5 MPH	
AIR TEMPERATURE	75°F	
MOON CONDITIONS		
MOON DESCRIPTION		
MOON COLOR	FAINT WHITE	
MOON DISTANCE VISIBLE	15-20'	

DIAGRAM OF OBSERVER AND EMISSION POINT



* OBS. POINT

COMMENTS

Mostly sunny today. Plume is lighter color now - more white but still very light not exceeding 5%.

OBSERVER SIGNATURE

John Richardson

ETS, INC.

DATE: 5/14/87
 COMPANY: BAY COUNTY REFINERIES REGISTRATION NO. _____
 LOCATION: PANAMA CITY, FL.
 EMISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT ≈ 150'
 OBSERVER: JOHN RICHMOND CERTIFICATION EXPIRATION DATE: 10/87

CLOCK TIME: INITIAL 8 : 35 A.M./P.M. FINAL 9 : 00 A.M./P.M.


VISIBLE EMISSION READINGS
RUN 4 BOILER 2

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	0							
	1							
	2							
	3							
	4							
	5							
	6							
	7							
	8							
	9							
	10							
	11							
	12							
	13							
	14							
	15							
	16							
	17							
	18							
	19							
	20							
	21							
	22							
	23							
	24							
	25							
	26							
	27							
	28							
	29							

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	30							
	31							
	32							
	33							
	34							
<u>8</u>	35	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	36	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	37	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	38	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	39	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	40	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	41	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	42	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	43	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	44	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	45	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	46	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	47	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	48	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	49	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	50	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	51	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	52	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	53	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	54	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	55	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	56	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	57	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	58	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			
	59	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>			

	INITIAL	FINAL
OBSERVER LOCATION		
DISTANCE TO DISCHARGE	500'	
DIRECTION TO DISCHARGE	NE-NW	
HEIGHT OF OBSERVATION POINT	GROUND	
BACKGROUND DESCRIPTION	BLUE SKY	
WEATHER CONDITIONS		
WIND DIRECTION	S-SE	
WIND SPEED	5-10 MPH	
AMBIENT TEMPERATURE	75°F	
SKY CONDITIONS	Partly Cloudy	
PLUME DESCRIPTION		
COLOR	GRAY	
DISTANCE VISIBLE	5-10'	

DIAGRAM OF OBSERVER AND EMISSION POINT



COMMENTS

EMISSIONS ARE QUITE LOW.
 BACKGROUND PRETTY GOOD, MOSTLY CLEAR SKY.

OBSERVER SIGNATURE

John Richardson

ETS, INC.

5/13/87

COMPANY BAY COUNTY REFINERIES REGISTRATION NO. _____
 LOCATION MOBILE CITY, FL.
 EMISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT 5' 12.5'
 OBSERVER JOHN RICARDSON CERTIFICATION EXPIRATION DATE 10/87

CLOCK TIME: INITIAL 9 : 35 (A.M./P.M.) FINAL 10 : 00 (A.M./P.M.)
RUN 1 Boiler 1


VISIBLE EMISSION READINGS

HR.	MIN.	SECONDS				STEAM PLUME CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	0							
	1							
	2							
	3							
	4							
	5							
	6							
	7							
	8							
	9							
	10							
	11							
	12							
	13							
	14							
	15							
	16							
	17							
	18							
	19							
	20							
	21							
	22							
	23							
	24							
	25							
	26							
	27							
	28							
	29							

HR.	MIN.	SECONDS				STEAM PLUME CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	30							
	31							
	32							
	33							
	34							
9	35	5	5	5	5			
	36	5	5	5	5			
	37	5	5	5	5			
	38	5	5	5	5			
	39	5	5	5	5			
	40	5	5	5	5			
	41	5	5	5	5			
	42	5	5	5	5			
	43	5	5	5	5			
	44	5	5	5	5			
	45	5	5	5	5			
	46	5	5	5	5			
	47	5	5	5	5			
	48	5	5	5	5			
	49	5	5	5	5			
	50	5	5	5	5			
	51	5	5	5	5			
	52	5	5	5	5			
	53	5	5	5	5			
	54	5	5	5	5			
	55	5	5	5	5			
	56	5	5	5	5			
	57	5	5	5	5			
	58	5	5	5	5			
	59	5	5	5	5			

	INITIAL	FINAL
OBSERVER LOCATION		
DISTANCE TO DISCHARGE	500'	
DIRECTION TO DISCHARGE	N-NW	
HEIGHT OF OBSERVATION POINT	GROUND	
BACKGROUND DESCRIPTION	WHITE CLOUDS	
WEATHER CONDITIONS		
WIND DIRECTION	SE	
WIND SPEED	0-5 MPH	
Ambient Temperature	80°F	
SKY CONDITIONS	MOSTLY CLOUDY	
SMOKE DESCRIPTION	FAINT GRAY	
COLOR		
DISTANCE VISIBLE	5-10'	

DIAGRAM OF OBSERVER AND EMISSION POINT



COMMENTS

HAS BECOME MORE CLOUDY THAN RUN 1, IS NOW MOSTLY CLOUDY. EMISSIONS AGAIN VERY LOW & NEARLY NONDETECTABLE!

OBSERVER SIGNATURE

John Richardson

ETS, INC.

DATE 5/13/87
 COMPANY BAY COUNTY RESOURCES REGISTRATION NO. _____
 LOCATION PANAMA CITY, FL.
 EMISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT 150'
 OBSERVER JOHN RICHMOND CERTIFICATION EXPIRATION DATE 10/87

CLOCK TIME: INITIAL 11 : 45 A.M./P.M. FINAL 12 : 10 A.M./P.M.
RUN 2 BOILER 1

VISIBLE EMISSION READINGS

HR.	MIN.	SECONDS				STEAM PLUME CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
12	0	5	5	5	5			
	1	5	5	5	5			
	2	5	5	5	5			
	3	5	5	5	5			
	4	5	5	5	5			
	5	5	5	5	5			
	6	5	5	5	5			
	7	5	5	5	5			
	8	5	5	5	5			
	9	5	5	5	5			
	10	5	5	5	5			
	11							
	12							
	13							
	14							
	15							
	16							
	17							
	18							
	19							
	20							
	21							
	22							
	23							
	24							
	25							
	26							
	27							
	28							
	29							


HR.	MIN.	SECONDS				STEAM PLUME CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	30							
	31							
	32							
	33							
	34							
	35							
	36							
	37							
	38							
	39							
	40							
	41							
	42							
	43							
	44							
11	45	5	5	5	5			
	46	5	5	5	5			
	47	5	5	5	5			
	48	5	5	5	5			
	49	5	5	5	5			
	50	5	5	5	5			
	51	5	5	5	5			
	52	5	5	5	5			
	53	5	5	5	5			
	54	5	5	5	5			
	55	5	5	5	5			
	56	5	5	5	5			
	57	5	5	5	5			
	58	5	10	5	5			
	59	5	5	5	5			

INITIAL

FINAL

OBSERVER LOCATION		
DISTANCE TO DISCHARGE	400'	
DIRECTION TO DISCHARGE		
HEIGHT OF OBSERVATION POINT	GROUND	
BACKGROUND DESCRIPTION	WHITE CLOUDS	
WEATHER CONDITIONS		
WIND DIRECTION		
WIND SPEED	10-15 MPH	
AIR TEMPERATURE	85°	
SKY CONDITIONS	Mostly Cloudy CLOUDY	
PLUME DESCRIPTION		
COLOR	HARDLY DISCERNABLE	
DISTANCE VISIBLE		

DIAGRAM OF OBSERVER AND EMISSION POINT



COMMENTS

EMISSIONS ARE VERY LOW, JUST BARELY DETECTABLE. BACKGROUND WAS FAIRLY GOOD AT ONSET OF READING BUT CHANGED TO MEDIUM GRAY CLOUDS. FAINT GRAY EMISSIONS OBSERVED THROUGHOUT READINGS.

OBSERVER SIGNATURE

John V. ...

ETS, INC.

DATE 5/13/87
 COMPANY DAVY COUNTY RESOURCES REGISTRATION NO. _____
 LOCATION PANAMA CITY, FL.
 EMISSION POINT NAME _____ HEIGHT TO DISCHARGE POINT 150'
 OBSERVER JOHN RICHARDSON CERTIFICATION EXPIRATION DATE 10/87

CLOCK TIME: INITIAL 1 : 50 A.M. / P.M. FINAL 2 : 20 A.M. / P.M.
RUN 3 BOILER 1

VISIBLE EMISSION READINGS

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
2	0	5	5	5	5			
	1	5	5	5	5			
	2	5	5	5	5			
	3	5	5	5	5			
	4	5	5	5	5			
	5	5	5	5	5			
	6	5	5	5	5			
	7	5	5	5	5			
	8	5	5	5	5			
	9	5	5	5	5			
	10	5	5	5	5			
	11	5	5	5	5			
	12	5	5	5	5			
	13	5	5	5	5			
	14	5	5	5	5			
	15	5	5	5	5			
	16	5	5	5	5			
	17	5	5	5	5			
	18	5	5	5	5			
	19	5	5	5	5			
	20	5	5	5	5			
	21							
	22							
	23							
	24							
	25							
	26							
	27							
	28							
	29							

HR.	MIN.	SECONDS				STEAM FLUVE CHECK IF APPLICABLE		
		0	15	30	45	DET.	ATT.	COMMENT
	30							
	31							
	32							
	33							
	34							
	35							
	36							
	37							
	38							
	39							
	40							
	41							
	42							
	43							
	44							
	45							
	46							
	47							
	48							
	49							
1	50	5	5	5	5			
	51	5	5	5	5			
	52	5	5	5	5			
	53	5	5	5	5			
	54	5	5	5	5			
	55	5	5	5	5			
	56	5	5	5	5			
	57	5	5	5	5			
	58	5	5	5	5			
	59	5	5	5	5			

APPENDIX C

**COMPUTER CALCULATION SHEETS FOR
ADDITIONAL TEST RESULTS
REPORTED IN TABLE 2**

4/22 1436 #1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

%CO2 avg. 13.1
 %O2 avg. 20.9
 %CO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 47.149
 Dp avg. delta p .4908333333333333
 ts avg. temp 373.75
 DH avg. delta H 2.389166666666667
 tmi avg. temp 92.4166666666667
 tmo avg. temp 91.08333333333333
 %N2 avg. 81
 Md mole wt. dry 30.32000002264977
 Ms mole wt. 28.68253348934865
 area nozzle 4.97440652865625D-04
 Tm temp meter 91.75
 Tm abs temp 551.42
 Ts abs temp 833.42
 Pm abs prs 30.11567401468032
 Ps abs prs 29.9105882361191
 Vm(std) 45.45874602257414
 Vwc(std) 5.93082
 Vwsg(std) 1.0373
 Bws .1329112443417778
 vs velocity 49.46539289227205
 vol rate 24954.98114192209
 run time min. 60
 %I isokinetic 93.50757805391747
 Ga vol rate 45470.72107332136
 md mass dry 5.616999999999978D-02
 mw mass wet 5.616999999999978D-02
 39.00156035616007

pmrd 4.075032751833441
 pmrw 4.075032751833441
 csd 1.906570629048159D-02
 csw 1.906570629048159D-02
 csd50% 1.766775282446131D-02
 csw50% 1.766775282446131D-02
 csd12 1.759911349890608D-02
 csw12 1.759911349890608D-02
 csd7 1.778612865433382D-02
 csw7 1.778612865433382D-02
 saturation flag -1
 Bws saturated .1329112443417778
 Vm corrected 47.149
 total # points 12
 Vf impingers 326
 Vi impingers 200
 sqr(Dp) avg. .6988695723679337
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 1.140000000000000D-02
 container 2 4.476999999999975D-02
 container 3 NA
 container 4 22
 container 5 NA
 not in use NA

* Definitions & units of the variables are given in the sample calculations

Q2 avg.	13	Q2	6.683764211788342
Q1 avg.	6	Q1	6.683764211788342
Q3 avg.	0	Q3	3.3207266809406788E-02
stack area	15.32071832265625	Q4	3.3207266809406788E-02
Vm avg. DGM	25.383000000000001	csd50%	2.799238147068358E-02
Op avg. delta p	.58	csd50%	2.799238147068358E-02
ts avg. temp	387.33333333333333	csd12	2.788363090099088E-02
OH avg. delta H	2.7783333333333333	csd12	2.788363090099088E-02
tsi avg. temp	89.33333333333333	csd7	.0281799334145898
tsi avg. temp	87	csd7	.0281799334145898
%N avg.	81	saturation flag	-1
Ms mole wt. dry	30.32000002264977	Bws saturated	.1748840164916596
Ms mole wt.	28.16542893551144	Vm corrected	25.383000000000001
Area nozzle	4.97440652865625D-04	total # points	6
ts temp meter	88.16666666666667	Vf impingers	296
ts abs temp	547.8366666666667	Vi impingers	200
ts abs temp	847.00333333333333	sqr(Dp) avg.	.7595053951150426
ts abs pres	30.14428920995612	Bws kick flag	0
ts abs pres	29.91132353021612	Vm C kick flag	0
ts std)	24.65652072063845	not in use	NA
ts std)	4.51872	Wa2	0
ts std)	.70725	Wa5	0
Bws	.1748840164916596	K1 constant	.04707
ts velocity	54.68799812415877	K2 constant	.04715
ts vol rate	25833.82598045883	Tstd abs temp	527.67
run time min.	30	container 1	1.071999999999998D-02
%I isokinetic	97.98501469721418	container 2	3.754999999999953D-02
ts vol rate	50271.56489341139	container 3	NA
ts mass dry	4.826999999999951D-02	container 4	15
ts mass wet	4.826999999999951D-02	container 5	NA
ts	39.00156035616007	not in use	NA

4/27 1505 #1

WEST1

08:58:31

04-29-1987

Page 1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

%CO2 avg. 13
 %O2 avg. 6
 %CO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 47.399
 Dp avg. delta p .5158333333333333
 ts avg. temp 440.6666666666667
 DH avg. delta H 2.324166666666667
 tmi avg. temp 85.5
 tmo avg. temp 82.9166666666667
 %N2 avg. 81
 Md mole wt. dry 30.32000002264977
 Ms mole wt. 28.79913123086259
 An area nozzle 4.97440652865625D-04
 tm temp meter 84.20833333333333
 abs temp 543.8783333333333
 abs temp 900.3366666666667
 Pm abs prs 30.43089460304967
 Ps abs prs 30.21367647188758
 Vm(std) 46.81845015367414
 Vwc(std) 4.37751
 Vwsg(std) 2.21605
 Bws .1234471419635653
 vs velocity 52.28566395485316
 vol rate 24933.92032259212
 run time min. 60
 %I isokinetic 96.38580271252002
 vol rate 48063.23578592198
 mass dry 8.700999999999962D-02
 mass wet 8.700999999999962D-02
 %EA 39.00156035616007

pmd 6.123921122589676
 pmrw 6.123921122589676
 csd 2.667596632509704D-02
 csw 2.867596632509704D-02
 csd50% 2.657336042606127D-02
 csw50% 2.657336042606127D-02
 csd12 2.647012276162804D-02
 csw12 2.647012276162804D-02
 csd7 2.675140477749577D-02
 csw7 2.675140477749577D-02
 saturation flag -1
 Bws saturated .1234471419635653
 Vm corrected 47.399
 total # points 12
 Vf impingers 393
 Vi impingers 300
 sqr(Dp) avg. .7157758413700035
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 3.85299999999998D-02
 container 2 4.847999999999963D-02
 container 3 NA
 container 4 47
 container 5 NA
 not in use NA

4/29 1214 #1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

%O2 avg. 13
 %CO avg. 6
 %CO2 avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 36.997999999999999
 Dp avg. delta p .353333333333333333
 ts avg. temp 418.25
 Dp avg. delta H 1.6283333333333333
 tm avg. temp 94.5
 tmo avg. temp 91.75
 %N2 avg. 81
 M mole wt. dry 30.32000002264977
 M mole wt. 28.51828482440424
 A area nozzle 4.97440652865625D-04
 tm temp meter 93.125
 T abs temp 552.795
 T abs temp 877.92
 P abs prs 30.01973038879852
 P abs prs 29.87352941250719
 V (std) 35.46956164476588
 Vwc (std) 3.90681
 Vwg (std) 2.1689
 Bw .1462431164718465
 vs velocity 42.42563001861055
 Qs vol rate 19981.37193655277
 r time min. 60
 %I isokinetic 91.1207152800595
 Qa vol rate 38999.4676305817
 md mass dry 6.273899999999979D-02
 mw mass wet 6.273899999999979D-02
 %EA 39.00156035616007

pmrd 4.670828915775861
 pmrw 4.670828915775861
 csd 2.729277513196588D-02
 csw 2.729277513196588D-02
 csd50% 2.529158886528706D-02
 csw50% 2.529158886528706D-02
 csd12 2.519333089104542D-02
 csw12 2.519333089104542D-02
 csd7 2.546104521044135D-02
 csw7 2.546104521044135D-02
 saturation flag -1
 Bws saturated .1462431164718465
 Vm corrected 36.997999999999999
 total # points 12
 Vf impingers 383
 Vi impingers 300
 sqr (Dp) avg. .5819842002140952
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 3.245000000000001D-02
 container 2 3.028899999999979D-02
 container 3 NA
 container 4 46
 container 5 NA
 not in use NA

5/20 1542 #1

wh1

07:12:47

05-27-1987

Page

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

ZCO2 avg. 12.4
 ZO2 avg. 8
 ZCO avg. 0
 Ae stack area 15.320718322265625
 Vm avg. DGM 35.478000000000001
 Dp avg. delta p .5533333333333333
 ta avg. temp 425.6666666666667
 DH avg. delta H 1.341666666666667
 tmi avg. temp 93.33333333333333
 tep avg. temp 92.25
 ZN2 avg. 79.6
 Md mole wt. dry 30.304000000810623
 Ms mole wt. 28.58128558475201
 An area nozzle 3.74394940740625D-04
 ta temp meter 92.79166666666667
 Ta abs temp 552.4616666666667
 Ts abs temp 885.3366666666667
 Pa abs pres 30.0986519580172
 Ps abs pres 29.9705882361191
 Ptd (atd) 34.122348722763515
 Vwd (atd) 4.89528
 Vwag (atd) .6601
 Rws .140012550570485
 vs velocity 54.15535493600144
 va vol rate 25559.45142488106
 run time min. 60
 XI isokinetic 91.05112052753139
 Qa vol rate 49781.93631827699
 md mass dry 5.843999999999999D-02
 mw mass wet 5.843999999999999D-02
 XED 61.47037181887387

pard 5.785084440056904
 parw 5.785084440056904
 cad 2.6426352044269229D-02
 caw 2.6426352044269229D-02
 cad50% 2.844715260099988D-02
 caw50% 2.844715260099988D-02
 cad12 2.557388907357319D-02
 caw12 2.557388907357319D-02
 cad7 2.847490652518484D-02
 caw7 2.847490652518484D-02
 saturation flag -1
 Rws saturated .140012550570485
 Vm corrected 35.478000000000001
 total # points 12
 Vf impingers 304
 Vi impingers 200
 spr (Dp) avg. .7417901993534804
 Rws kick flag 0
 Vm C kick flag 0
 not in use NA
 We2 0
 We5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 5.843999999999999D-02
 container 2 NA
 container 3 NA
 container 4 14
 container 5 NA
 not in use NA

6/1 1903 #1

10:10:25

06-16-1987

Page 1

ENVIRONMENTAL PROCESSOR direct variable dump V1.0 English/Metric units

Q2 avg.	11.7	parm	4.160724421388723
Q12 avg.	8.2	parm	4.160724421388723
Q avg.	0	ced	1.903243669898595D-01
A stack area	15.32071832265625	new	1.903243669898595D-01
Vm avg. DGM	37.97799999999999	ced50%	2.072481002660821D-01
Q avg. delta p	.6008333333333333	new50%	2.072481002660821D-01
t avg. temp	436.1666666666667	ced12	1.952044789639585D-02
DH avg. delta H	1.463333333333333	new12	1.952044789639585D-01
mi avg. temp	83.08333333333333	ced7	2.083077722849742D-01
tp avg. temp	82.25	new7	2.083077722849742D-01
W2 avg.	80.1	saturation flag	-1
Md mole wt. dry	30.20000000089407	Bws saturated	.1734456583746612
M mole wt.	28.08396297521911	Vm corrected	37.97799999999999
A area nozzle	3.51880193415625D-04	total # points	12
Q temp meter	82.66666666666667	Vf impingers	1276
T abs temp	542.3366666666667	Vi impingers	1133
abs temp	895.8366666666667	scr (Dp) avg.	.7683717843300268
abs pre	30.12759803619764	Bws kick flag	0
abs pre	29.98176470695482	Vm D kick flag	0
V (std)	37.24453212224598	not in use	NA
W (std)	6.73101	Wd2	0
Wwg (std)	1.08445	Wd5	0
Bs	.1734456583746612	K1 constant	.04707
v velocity	56.91446229232026	K2 constant	.04715
Qs vol rate	25524.28579381761	Tstd abs temp	527.67
run time min.	60	container 1	2.462999999999999D-02
isokinetic	105.8868380398462	container 2	2.130999999999997D-02
Wd vol rate	52318.22671596475	container 3	NA
md mass dry	.04593999999999997	container 4	23
W mass wet	.04593999999999997	container 5	NA
Wd	63.33807137563551	not in use	NA

X2 avg. 10.3
 X12 avg. 9.6
 X20 avg. 0
 Ae stack area 15.32071832265625
 Vm avg. DGM 35.37100000000001
 Dp avg. delta p .5291666666666667
 te avg. temp 442.5
 DH avg. delta H 1.2741666666666667
 tai avg. temp 85
 tao avg. temp 82.41666666666667
 XN2 avg. 80.1
 Md mole wt. dry 30.03200000226498
 Ms mole wt. 27.95913401979631
 An area nozzle 3.51880193415625D-04
 ta temp meter 83.70933333333333
 abs temp 543.3783333333333
 abs temp 902.17
 Pa abs pres 30.1136887228623
 Ps abs pres 29.98470588334291
 Vm(std) 34.60539969155991
 Vm2(std) 6.63687
 Vm5(std) .5658
 Bws .1722794200530634
 vs velocity 53.16074185230925
 Ds vol rate 23709.22679019665
 run time min. 60
 isokinetic 105.9155033195273
 Da vol rate 48867.6451045604
 md mass dry 4.763999999999882D-02
 mw mass wet 4.763999999999882D-02
 TA 83.14279858023556

pmnd 4.31352340932869
 pmnw 4.31352340932869
 ced 2.124192197032377D-01
 csw 2.124192197032377D-01
 ced50% 2.593536691245391D-03
 csw50% 2.593536691245391D-03
 ced12 2.474787025668789D-02
 csw12 2.474787025668789D-02
 ced7 2.612944400459664D-01
 csw7 2.612944400459664D-01
 saturation flag -1
 Bws saturated .1722794200530634
 Vm corrected 35.37100000000001
 total # points 12
 Vt impingers 1222
 Vi impingers 1081
 eqr(Dp) avg. .7136150383847175
 Bws kick flag 0
 Vm 0 kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 2.579000000000001D-02
 container 2 2.184999999999881D-02
 container 3 NA
 container 4 12
 container 5 NA
 not in use NA

4/23 0925 #2

ST1

08:57:57 04-29-1987

Page 1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

CO2 avg. 13
 %O2 avg. 6
 %CO avg. 0
 stack area 15.32071832265625
 Vm avg. DGM 53.721
 Dp avg. delta p .725
 Tavg. temp 422.33333333333333
 H avg. delta H 3.3258333333333333
 tmi avg. temp 90.25
 tmo avg. temp 85
 T2 avg. 81
 md mole wt. dry 30.32000002264977
 Ms mole wt. 28.45249131102209
 area nozzle 4.97440652865625D-04
 temp meter 87.625
 Tm abs temp 547.295
 Ts abs temp 882.00333333333333
 Pm abs prs 30.2645465617681
 Ps abs prs 29.97220588369353
 Vm(std) 52.44350037054014
 (std) 7.62534
 sg(std) 1.74455
 Bws .1515834990417485
 velocity 61.75414579682566
 vol rate 28863.89253254145
 run time min. 60
 isokinetic 93.26600518257677
 vol rate 56767.07238056474
 md mass dry 5.916999999999978D-02
 mw mass wet 5.916999999999978D-02
 EA 39.00156035616007

pmrd 4.303796045924327
 pmrw 4.303796045924327
 csd 1.740908012526307D-02
 csw 1.740908012526307D-02
 csd50% 1.613259534517987D-02
 csw50% 1.613259534517987D-02
 csd12 1.606992011562744D-02
 csw12 1.606992011562744D-02
 csd7 1.624068545607043D-02
 csw7 1.624068545607043D-02
 saturation flag -1
 Bws saturated .1515834990417485
 Vm corrected 53.721
 total # points 12
 Vf impingers 362
 Vi impingers 200
 sqr(Dp) avg. .8455823430303623
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 2.523999999999998D-02
 container 2 3.392999999999997D-02
 container 3 NA
 container 4 37
 container 5 NA
 not in use NA

4/23 1148 #2

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

%CO2 avg. 13
 CO2 avg. 6
 CO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 46.967
 Dp avg. delta p .5208333333333333
 ts avg. temp 422.33333333333333
 DH avg. delta H 2.395
 tmi avg. temp 90.09090909090909
 tmo avg. temp 90.54545454545455
 %N2 avg. 81
 Md mole wt. dry 30.32000002264977
 Ms mole wt. 28.37725967539609
 area nozzle 4.97440652865625D-04
 temp meter 90.31818181818182
 Tm abs temp 549.98818181818181
 Ts abs temp 882.00333333333333
 Pm abs prs 30.19610293623692
 Ps abs prs 29.9905882361191
 Vm(std) 45.52241066555498
 Vwc(std) 6.96636
 Vwsg(std) 1.55595
 Bws .1576899629612044
 velocity 52.40519890147679
 vol rate 24334.2049187623
 run time min. 60
 AI isokinetic 96.02729476090306
 Da vol rate 48175.87519003611
 md mass dry 6.8819999999999949D-02
 mw mass wet 6.8819999999999949D-02
 39.00156035616007

pmrd 4.861759395706837
 pmrw 4.861759395706837
 csd .0233268094653750
 csw .0233268094653758
 csd50% 2.161641942545387D-02
 csw50% 2.161641942545387D-02
 csd12 2.153243950650074D-02
 csw12 2.153243950650074D-02
 csd7 2.176125174305441D-02
 csw7 2.176125174305441D-02
 saturation flag -1
 Bws saturated .1576899629612044
 Vm corrected 46.967
 total # points 12
 Vf impingers 348
 Vi impingers 200
 sqr(Dp) avg. .7168812763440377
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 .02165
 container 2 4.7169999999999949D-02
 container 3 NA
 container 4 33
 container 5 NA
 not in use NA

INLET

4/23 1356 #2

%O2 avg.	13	pmrd	4.183341112101452
%CO2 avg.	6	pmrw	4.183341112101452
%CO avg.	0	csd	2.084698151429925D-02
As stack area	15.32071632265625	csw	2.084698151429925D-02
Vm avg. DGM	45.07599999999999	csd50%	1.931841972802413D-02
Dp avg. delta p	.4708333333333333	csw50%	1.931841972802413D-02
ts avg. temp	405.25	csd12	1.924336755166084D-02
DH avg. delta H	2.205	csw12	1.924336755166084D-02
tmi avg. temp	90	csd7	1.944785520235136D-02
tms avg. temp	87.66666666666667	csw7	1.944785520235136D-02
%N avg.	81	saturation flag	-1
M mole wt. dry	30.32000002264977	Bws saturated	.155309863080446
M mole wt.	28.40658250598094	Vm corrected	45.07599999999999
area nozzle	4.97440652865625D-04	total # points	12
temp meter	88.83333333333333	Vf impingers	345
bs temp	548.5033333333333	Vi impingers	200
abs temp	864.92	sqr(Dp) avg.	.6819317163956953
P abs prs	30.18213234839349	Bws kick flag	0
P abs prs	29.9905882361191	Vm C kick flag	0
Vm(std)	43.78757660306248	not in use	NA
Vm(std)	6.82515	Wa2	0
Vwg(std)	1.2259	Wa5	0
Bws	.155309863080446	K1 constant	.04707
velocity	49.34253726153965	K2 constant	.04715
vol rate	23429.2905497124	Tstd abs temp	527.67
run time min.	60	container 1	1.313999999999999D-02
%isokinetic	95.93528605455597	container 2	4.602000000000000D-02
vol rate	45357.78688255315	container 3	NA
mass dry	5.916000000000000D-02	container 4	26
mass wet	5.916000000000000D-02	container 5	NA
	39.00156035616007	not in use	NA

4/30 0957 #2

WEST5

07:33:25

05-04-1987

Page

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

%CO2 avg. 13
 %O2 avg. 6
 %CO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 49.375
 Dp avg. delta p .6008333333333333
 ts avg. temp 426.83333333333333
 DH avg. delta H 2.746666666666667
 tmi avg. temp 92.08333333333333
 tmo avg. temp 88.08333333333333
 %N2 avg. 81
 Md mole wt. dry 30.32000002264977
 Ms mole wt. 28.97628804400551
 In area nozzle 4.97440652865625D-04
 In temp meter 90.08333333333333
 Tm abs temp 549.75333333333333
 Ts abs temp 886.50333333333333
 Pm abs pres 30.09196077864888
 Ps abs pres 29.8605882361191
 Vm(std) 47.71166982051774
 Vwc(std) 3.38904
 Vwsg(std) 2.4518
 Bws .1090675305335957
 velocity 56.2466379644777
 vol rate 27364.69008279531
 time min. 60
 %i isokinetic 89.49951570796815
 Qa vol rate 51704.33381101117
 md mass dry .05593999999999998
 mw mass wet .05593999999999998
 %EA 39.00156035616007

pmrd 4.240091853977272
 pmrw 4.240091853977272
 csd 1.809104990973947D-02
 csw 1.809104990973947D-02
 csd50% 1.676456110623303D-02
 csw50% 1.676456110623303D-02
 csd12 1.669943068591336D-02
 csw12 1.669943068591336D-02
 csd7 1.687688545518199D-02
 csw7 1.687688545518199D-02
 saturation flag -1
 Bws saturated .1090675305335957
 Vm corrected 49.375
 total # points 12
 Vf impingers 372
 Vi impingers 300
 sqr(Dp) avg. .7738064284392416
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 .03489
 container 2 2.1049999999999979D-02
 container 3 NA
 container 4 52
 container 5 NA
 not in use NA

5/12 1353 UNIT #2

O2 avg.	10.233333333333333	pmrd	4.615307284361401
%2 avg.	9.7	pmrw	4.615307284361401
%CO avg.	0	csd	2.096669303877474D-02
A stack area	15.32071832265625	csw	2.096669303877474D-02
V avg. DGM	48.067	csd50%	2.583208440074983D-02
Dp avg. delta p	.6566666666666667	csw50%	2.583208440074983D-02
ts avg. temp	436.8333333333333	csd12	2.458635014318862D-02
D avg. delta H	2.669166666666667	csw12	2.458635014318862D-02
tai avg. temp	90.16666666666667	csd7	2.602116385420505D-02
tmo avg. temp	90.75	csw7	2.602116385420505D-02
%2 avg.	80.06666666666667	saturation flag	-1
M mole wt. dry	30.025333333500226	Bws saturated	.1958879733752114
Ms mole wt.	27.6697151588473	Vm corrected	48.067
area nozzle	4.97440652865625D-04	total # points	12
v temp meter	90.45833333333333	Vf impingers	408
Tm abs temp	550.1283333333333	Vi impingers	200
Ts abs temp	896.5033333333333	sqr(Dp) avg.	.790002785072928
F abs prs	30.19626224939695	Bws kick flag	0
F abs prs	29.95808823646971	Vm C kick flag	0
Vm(std)	46.57695413358648	not in use	NA
Vvc(std)	9.79056	Wa2	0
Vvsg(std)	1.55595	Wa5	0
Bws	.1958879733752114	K1 constant	.04707
vs velocity	58.99833938977261	K2 constant	.04715
vol rate	25700.98245786192	Tstd abs temp	527.67
time min.	60	container 1	3.518000000000002D-02
isokinetic	93.02677438327585	container 2	2.810999999999986D-02
vol rate	54233.81635771087	container 3	NA
mass dry	6.328999999999987D-02	container 4	33
mw mass wet	6.328999999999987D-02	container 5	NA
%EA	84.80800252794236	not in use	NA

5/13 1632 UNIT #2

%CO2 avg. 10.4
 %O2 avg. 9.6
 %CO avg. .15
 As stack area 15.32071832265625
 Vm avg. DGM 47.911
 Dp avg. delta p .5258333333333333
 ts avg. temp 408.8333333333333
 DH avg. delta H 2.455833333333333
 tmi avg. temp 100.5833333333333
 tmo avg. temp 98.08333333333333
 %N2 avg. 79.85
 Md mole wt. dry 30.04800000190735
 Ms mole wt. 27.73863421839339
 An area nozzle 4.97440652865625D-04
 tm temp meter 99.33333333333333
 Tm abs temp 559.0033333333333
 Ts abs temp 868.5033333333333
 Pm abs prs 30.18057597532714
 Ps abs prs 29.9610294128578
 Vm(std) 45.6649780900539
 Vwc(std) 9.27279
 Vwsg(std) 1.55595
 Bws .1916804268881441
 vs velocity 52.46689434732531
 vs vol rate 23718.37259849367
 n time min. 60
 %I isokinetic 98.8291293231339
 vol rate 48229.83057359619
 mass dry 9.116999999999964D-02
 mw mass wet 9.116999999999964D-02
 %EA 82.42899505128014

pmd 6.258070821786027
 pmrw 6.258070821786027
 csd 3.080595149363257D-02
 csw 3.080595149363257D-02
 csd50% 3.746599181721248D-02
 csw50% 3.746599181721248D-02
 csd12 3.554532864649912D-02
 csw12 3.554532864649912D-02
 csd7 3.789404676684836D-02
 csw7 3.789404676684836D-02
 saturation flag -1
 Bws saturated .1916804268881441
 Vm corrected 47.911
 total # points 12
 Vf impingers 397
 Vi impingers 200
 sqr(Dp) avg. .714703505575787
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 .01693
 container 2 7.423999999999964D-02
 container 3 NA
 container 4 33
 container 5 NA
 not in use NA

5/14 0825 UNIT #2

W02 avg.	10.2	pmrd	2.892550182725949
X02 avg.	9.7	pmrw	2.892550182725949
Z00 avg.	0	ced	1.334679936634712D-02
A stack area	15.32071832265625	cew	1.334679936634712D-02
V avg. DGM	49.185	ced50%	1.643816742478097D-02
Dp avg. delta p	.5875	cew50%	1.643816742478097D-02
ts avg. temp	421.16666666666667	ced12	1.570211690158485D-02
th avg. delta H	2.4566666666666667	cew12	1.570211690158485D-02
ti avg. temp	97.66666666666667	ced7	1.656433146603715D-02
tm avg. temp	91.16666666666667	cew7	1.656433146603715D-02
W02 avg.	80.1	saturation flag	-1
M mole wt. dry	30.02000000178814	Bws saturated	.1783223462470211
Mw mole wt.	27.87656539958008	Vm corrected	49.185
An area nozzle	4.97440652865625D-04	total # points	12
t temp meter	94.41666666666667	Vf impingers	382
T abs temp	554.08666666666667	Vi impingers	200
Te abs temp	880.83666666666667	egr(Dp) avg.	.7571383251240413
F abs pre	30.18063724983522	Bws kick flag	0
Fw abs pre	29.9705882361191	Vm C kick flag	0
Vm(std)	47.29533146288439	not in use	NA
Vw(std)	8.56674	Wa2	0
Veg(std)	1.6974	Wa5	0
Bws	.1783223462470211	K1 constant	.04707
vs velocity	55.82776733136082	K2 constant	.04715
v vol rate	25303.62897807033	Tstd abs temp	527.67
t time min.	60	container 1	2.4679999999999998D-02
isokinetic	95.94493775269678	container 2	1.6230000000000019D-02
g vol rate	51319.28987199428	container 3	NA
m mass dry	4.0910000000000017D-02	container 4	36
mw mass wet	4.0910000000000017D-02	container 5	NA
WFA	84.74280207839728	not in use	NA

5/21 1016 #2

08:27:43

05-28-1987

Page 1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

ZCO2 avg. 10.9
 ZO2 avg. 8.7
 ZCO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 30.06
 Dp avg. delta p .5666666666666667
 ts avg. temp 411.5
 Df avg. delta H 1.1175
 ts avg. temp 111.25
 ts avg. temp 111.25
 IN2 avg. 80.4
 Md mole wt. dry 30.09200000762939
 Ms mole wt. 28.05536619073703
 An area nozzle 3.74394940740625D-04
 tm temp meter 111.25
 Tm abs temp 570.92
 Ts abs temp 871.17
 Pm abs pre 30.14216911534228
 Ps abs pre 30.0305882361191
 Vm(std) 29.05269261874298
 VmC(std) 5.50719
 VmWG(std) .3772
 F s .1684282017538337
 V velocity 54.60235474606763
 Qs vol rate 25374.83606135349
 run time min. 48
 XI isokinetic 97.60926967189145
 Qa vol rate 50192.83780909529
 md mass dry 3.145000000000001D-02
 mw mass wet 3.145000000000001D-02
 XEA 69.45775116469892

parrd 3.63014849707071
 parrw 3.63014849707071
 ced 1.670321943539691D-02
 cew 1.670321943539691D-02
 ced50X 1.886993335155235D-02
 cew50X 1.886993335155235D-02
 ced12 1.838886543346449D-02
 cew12 1.838886543346449D-02
 ced7 .0190307172983514
 cew7 .0190307172983514
 saturation flag -1
 Bws saturated .1684282017538337
 Vm corrected 30.06
 total # points 12
 Vf impingers 317
 Vi impingers 200
 sgr(Dp) avg. .7477479030408388
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 3.145000000000001D-02
 container 2 NA
 container 3 NA
 container 4 8
 container 5 NA
 not in use NA

5/21 1705 #2

08:27:58

05-28-1987

Page 1

ENVIRO-PRO processor direct variable dump V1.0 English/Metric units

ZC02 avg.	11.5	pmnd	4.330703635654533
Z02 avg.	9	pmnw	4.330703635654533
Z00 avg.	0	ced	1.641596898375574D-02
As stack area	15.32071832265625	cew	1.641596898375574D-02
Vm avg. DSM	40.885	ced50%	1.916018009301828D-02
As avg. delta p	.7441666666666667	cew50%	1.916018009301828D-02
As avg. temp	431	ced12	1.712970676565816D-02
DH avg. delta H	2.650833333333333	cew12	1.712970676565816D-02
Asi avg. temp	106.25	ced7	1.917495545602307D-02
Aso avg. temp	106.25	cew7	1.917495545602307D-02
ZN2 avg.	79.5	saturation flag	-1
M mole wt. dry	30.20000000298023	Bws saturated	9.481966548862889D-02
M mole wt.	29.04320008373638	Vm corrected	40.885
An area nozzle	4.97440652865625D-04	total # points	12
As temp meter	106.25	Vf impingers	261
As abs temp	565.92	Vi impingers	200
As abs temp	890.67	sqr(Dp) avg.	.8578449567575251
Pm abs pre	30.25491421021908	Bws kick flag	0
As abs pre	30.0305882361191	Vm C kick flag	0
As (std)	40.01317867071964	not in use	NA
Vwc (std)	2.87127	Wa2	0
Vwg (std)	1.3202	Wa5	0
As	9.481966548862889D-02	K1 constant	.04707
As velocity	62.25262439380102	K2 constant	.04715
As vol rate	30801.43728733193	Tstd abs temp	527.67
Asn time min.	48	container 1	1.846999999999999D-02
As isokinetic	83.35443015154688	container 2	2.4100000000000068D-02
As vol rate	57225.29539101268	container 3	NA
As mass dry	4.257000000000066D-02	container 4	28
As mass wet	4.257000000000066D-02	container 5	NA
WEA	75.07507578728418	not in use	NA

Q2 avg. 10.6
 Q02 avg. 81.8
 X00 avg. 0
 An stack area 15.32071632265625
 Vm avg. DSM 35.675
 Dp avg. delta p .6383333333333333
 ts avg. temp 436.5833333333333
 DH avg. delta H 1.6058333333333333
 tmi avg. temp 89.41666666666667
 tmo avg. temp 87.66666666666667
 XN2 avg. 80.6
 Md mole wt. dry 30.048000000786781
 Me mole wt. 27.70263862031667
 An area nozzle 3.51880193415625D-04
 tm temp meter 88.04166666666667
 Tm abs temp 547.7116666666667
 Ts abs temp 896.2533333333333
 Tm abs pres 30.14807597708021
 Ts abs pres 29.98955882466376
 Vm(std) 34.66621953131728
 Vwc(std) 7.67241
 Vweg(std) .70725
 Bws .1946681097293766
 vs velocity 59.27024533877442
 Qs vol rate 25892.98428569535
 run time min. 60
 isokinetic 97.15327179850558
 Wa vol rate 54483.76402500555
 md mass dry .03245999999999991
 mw mass wet .03245999999999991
 WEA 70.52186242876619

para 3.204126629371747
 pmw 3.20413663027374
 ced 1.444800750619818D-04
 csw 1.444800750619818D-04
 ced50% 1.642467432227205D-04
 csw50% 1.642467432227205D-04
 ced12 1.635623491267719D-03
 csw12 1.635623491267719D-03
 ced7 1.659729794678049D-02
 csw7 1.659729794678049D-02
 saturation flag -1
 Bws saturated .1946681097293766
 Vm corrected 35.675
 total # points 12
 Vf impingers 1345
 Vi impingers 1182
 sqr(Dp) avg. .7946435024367213
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 1.835999999999999D-02
 container 2 1.4099999999999991D-02
 container 3 NA
 container 4 15
 container 5 NA
 not in use NA

12 avg.	11.2	pmrd	3.370052009906408
742 avg.	7.7	pmrw	3.370052009906408
0 avg.	0	ced	1.617701744012152D-02
4 stack area	15.32071832265625	cew	1.617701744012152D-02
Vm avg. DGM	36.765	ced50%	1.684154195617942D-02
0 avg. delta p	.5483333333333333	cew50%	1.684154195617942D-02
0 avg. temp	428.4166666666667	ced12	1.733251848584448D-02
0H avg. delta H	1.3475	cew12	1.733251848584448D-02
0ni avg. temp	92.83333333333333	ced7	1.703488960188949D-02
0e avg. temp	91.25	cew7	1.703488960188949D-02
0n2 avg.	81.1	saturation flag	-1
Md mole wt. dry	30.10000001490116	Bws saturated	.1850815321982904
M mole wt.	27.86051347254392	Vm corrected	36.765
4 area nozzle	3.51880193415625D-04	total # points	12
0m temp meter	92.04166666666667	Vf impingers	1324
0 abs temp	551.7116666666667	Vi impingers	1165
0 abs temp	888.0866666666667	egr(Dp) avg.	.7363830463136791
Fm abs pres	30.1290808795738	Bws kick flag	0
F0 abs pres	29.9910294128578	Vm 0 kick flag	0
0 (std)	35.44403670963133	not in use	NA
0mc (std)	7.48413	Ma2	0
0wag (std)	.5658	Ma5	0
0s	.1850815321982904	K1 constant	.04707
0 velocity	54.51748525187301	K2 constant	.04715
0s vol rate	24323.00283671308	Tstd abs temp	527.67
0n time min.	60	container 1	1.4640000000000001D-02
0 isokinetic	105.7448055184965	container 2	2.250000000000085D-02
0a vol rate	50114.82211221077	container 3	NA
0d mass dry	3.716000000000086D-02	container 4	12
0 mass wet	3.716000000000086D-02	container 5	NA
0A	56.16174630321331	not in use	NA

CO2 avg. 10.8
 CO2 avg. 8.3
 CO avg. 0
 As stack area 15.32071832265625
 Vm avg. DGM 35.629
 Dp avg. delta p .5725
 ts avg. temp 426.25
 DH avg. delta H 1.41
 tmi avg. temp 92.33333333333333
 tmo avg. temp 92
 XN2 avg. 80.9
 Md mole wt. dry 30.06000001132488
 Me mole wt. 27.95814955443721
 An area nozzle 3.51880193415625D-04
 tm temp meter 92.16666666666667
 Tm abs temp 551.8366666666667
 Ts abs temp 885.92
 tm abs pre 30.13367646768019
 Ts abs pre 29.99250000105185
 vm(std) 34.34631055999344
 VmC(std) 6.87222
 Vweg(std) .3772
 Bws .1742827906230467
 ve velocity 55.64896050896046
 Qs vol rate 25219.57401876082
 run time min. 60
 Y isokinetic 98.82695205734149
 wa vol rate 51154.92293438428
 md mass dry 3.536000000000034D-02
 mw mass wet 3.536000000000034D-02
 EA 63.56451471604416

pond 3.431285032015861
 pondw 3.431285032015861
 ced 1.588539761925785D-01
 cedw 1.588539761925785D-01
 ced50% 1.732191568443525D-01
 cedw50% 1.732191568443525D-01
 ced12 1.765044179917521D-01
 cedw12 1.765044179917521D-01
 ced7 1.752436726451581D-01
 cedw7 1.752436726451581D-01
 saturation flag -1
 Bws saturated .1742827906230467
 Vm corrected 35.629
 total # points 12
 Vf impingers 1250
 Vi impingers 1104
 spr(Dp) avg. .7539208355672653
 Bws kick flag 0
 Vm C kick flag 0
 not in use NA
 Wa2 0
 Wa5 0
 K1 constant .04707
 K2 constant .04715
 Tstd abs temp 527.67
 container 1 .01538
 container 2 1.998000000000033D-02
 container 3 NA
 container 4 8
 container 5 NA
 not in use NA

6/3 1023 **

10:12:29

06-16-1987

Page 1

ENVIRO and processor direct variable dump V1.0 English/Metric units

Q12 avg.	12	pard	4.23278376386771
Q22 avg.	7.8	parw	4.23278376326771
QD avg.	0	ced	1.911786248478093D-02
stack area	15.320718322265425	csw	1.911786248478093D-02
Vm avg. DGM	37.265	ced50%	2.017920356230977D-02
avg. delta p	.59666666666666667	csw50%	2.017920356230977D-02
avg. temp	438.5	ced12	1.911786248478093D-02
DH avg. delta H	1.4575	csw12	1.911786248478093D-02
ai avg. temp	96	ced7	2.028536557128412D-02
op avg. temp	95.25	csw7	2.028536557128412D-02
Q12 avg.	80.2	saturation flag	-1
Md mole wt. dry	30.23200001120567	Bws saturated	.157390402281733
Mw mole wt.	28.30680060873185	Vm corrected	37.265
area nozzle	3.51880193415625D-04	total # points	12
ta temp meter	95.625	Vf impingers	1263
abs temp	555.295	Vi impingers	1129
abs temp	898.17	sqr(Dp) avg.	.7663568122153158
Pa abs pre	30.20716911464105	Bws kick flag	0
Pb abs pre	30.06176470695482	Vm O kick flag	0
h(std)	35.78675181624649	not in use	NA
hc(std)	6.30738	Wa2	0
Vwsg(std)	.3772	Wa5	0
Ww	.157390402281733	K1 constant	.04707
velocity	56.53953981358393	K2 constant	.04715
Qs vol rate	25850.31205268073	Tstd abs temp	527.67
run time min.	60	container 1	.02653
isokinetic	100.459161047966	container 2	1.7809999999999899D-02
Ww vol rate	51973.58181459167	container 3	NA
md mass dry	4.433999999999999D-02	container 4	8
Ww mass wet	4.433999999999999D-02	container 5	NA
Ww	58.32735154131695	not in use	NA