


STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

0050031

NORTHWEST DISTRICT  
160 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501-5794



BOB MARTINEZ  
GOVERNOR  
DALE TWACHTMANN  
SECRETARY  
ROBERT V. KRIEDEL  
DISTRICT MANAGER

October 24, 1988

RECEIVED

OCT 25 1988

DER-BAQM

Mr. David E. Banka  
Utilities Director  
City of Panama City  
Post Office Box 1880  
Panama City, Florida 32402

Dear Mr. Banka:

This letter is in response to your request of October 11, 1988.

The burning of sewage sludge is specifically prohibited in condition 16 of permits A003-140648 and -140649. These prohibitions are based on condition 2 of AC03-84703 and -84704. Further, Florida Administrative Code Rule 17-2.500(6)(b) requires any operating permit shall include provisions set forth in the original or amended construction permit. Thus the Northwest District of DER can not grant your request.

This letter shall be copied to Mr. John J. Zebroski, Westinghouse Electric Corporation, permittee of A003-140648 and -140649 (Authorized Representative of the Resource Recovery Facility in Bay County) with a copy of your request letter. Any action toward amendments to permits would have to be initiated by the Resource Recovery Facility. If any such action was initiated, it would be addressed to Central Air Permitting section of the Department's Bureau of Air Quality Management (originators of the referenced air construction permits).

Sincerely,

Ed K. Middleswart, P.E.  
Air Program Administrator

EKM/jpl

cc: John J. Zebroski (w/enclosure)  
Clair Fancy, ✓BAQM  
DER Tallahassee (w/enclosure)

DEPARTMENT OF ENVIRONMENTAL REGULATION

**ROUTING AND TRANSMITTAL SLIP**

ACTION NO  
ACTION DUE DATE

1. TO: (NAME, OFFICE, LOCATION)	306 F	Initial
	Clair Jancy BAQM T.L. T.T.	Date
2.	<del>B. H. F.</del> 10/25	Initial
		Date
3.	<del>B. H. F.</del>	Initial
		Date
4.	<del>Patley</del>	Initial
		Date

REMARKS:

**RECEIVED**

OCT 25 1988

DER - BAQM

INFORMATION	
<input type="checkbox"/>	Review & Return
<input type="checkbox"/>	Review & File
<input type="checkbox"/>	Initial & Forward
<input type="checkbox"/>	
DISPOSITION	
<input type="checkbox"/>	Review & Respond
<input type="checkbox"/>	Prepare Response
<input type="checkbox"/>	For My Signature
<input type="checkbox"/>	For Your Signature
<input type="checkbox"/>	Let's Discuss
<input type="checkbox"/>	Set Up Meeting
<input type="checkbox"/>	Investigate & Report
<input type="checkbox"/>	Initial & Forward
<input type="checkbox"/>	Distribute
<input type="checkbox"/>	Concurrence
<input type="checkbox"/>	For Processing
<input type="checkbox"/>	Initial & Return

FROM *Ed M. Galeswast* *N.W.*  
*Jack Treese*  
*Sensacola Air Program*

DATE *8/24/88*  
PHONE



# CITY OF PANAMA CITY

POST OFFICE BOX 1880  
PANAMA CITY, FLORIDA 32402

October 11, 1988

Mr. Ed Middlestuart  
Air Quality  
DER District Office  
160 Governmental Center  
2nd Floor  
Pensacola, FL 32501

Dear Mr. Middlestuart:

As per the phone conversation on 9/29/88 between Ms. Janice Moore and Mr. Moody and Mr. Middlestuart, the City of Panama City requests the approval of the Department of Environmental Regulation to burn its wastewater treatment sludges at the Bay Resource Management Center. If a permit modification is needed, the City requests that those necessary modifications be made.

At present the City's wastewater treatment sludges are primarily from treatment of domestic wastes with an industrial flow of approximately 3-5% maximum. There are no known categorical contributors. The City presently operates under an Industrial Pretreatment Program approved and audited by EPA.

Historically, the sludges have mainly been Grade I and Grade II. At present, the City is in the process of having sludge analysis done for the 129 priority pollutants as required by EPA. Hopefully, that data will be available by December 15, 1988. There is also historical data presently available on other sludge parameters if needed.

Approximate, estimated volumes of sludges generated presently are: St. Andrew WWTP - 5,382 cubic yards/year and Millville WWTP - 1,200 cubic yards/year.

Thank you for your prompt consideration of this matter.

Sincerely,  
  
David E. Banka  
Utilities Director

DEB:sbk

cc: John E. Baxter, City Manager  
James M. Southall, City Engineer  
John Goin, BCM Converse

RECEIVED

OCT 13 1988

Northwest Florida  
DER

5400  
1200  
-----  
6600

6600 (27) <sup>est</sup> (40 lb) / 0.83  
-----  
2000 (360)

= 10 Tns / day