



# Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Bob Martinez, Governor

Dale Twachtmann, Secretary

John Shearer, Assistant Secretary

June 18, 1990

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Alvin N. Critzer, Plant Manager  
Harris Semiconductor  
P. O. Box 883  
Melbourne, Florida 32901

Dear Mr. Critzer:

Re: Amendment to Construction Permit: AC 05-157786  
Harris Semiconductor: Building 51

The Department has reviewed your cover letter with enclosures received May 14, 1990, which requested a reduction in the allowable VOC/solvent emission limit contained in the above referenced construction permit. The Department agrees with the request and the following will be changed:

Specific Condition No. 1

FROM:

The maximum allowable VOC/solvent emissions from Building No. 51 shall be 33.3 tons per year.

TO:

The maximum allowable VOC/solvent emissions from Building No. 51 shall be 27.3 tons per year.

Attachment to be Incorporated

- Mr. Alvin N. Critzer's letter with enclosures received May 14, 1990.

Mr. Alvin N. Critzer  
Page 2  
June 18, 1990

This letter must be attached to the construction permit, No. AC 05-157786, and shall become a part of the permit.

Sincerely,



for STEVE SMALLWOOD, P.E.  
Director  
Division of Air Resources  
Management

SS/BM/plm

Attachment

c: C. Collins, Central Dist.  
K. Smith, HS



May 3, 1990

RECEIVED

Mr. C. H. Fancy  
Deputy Bureau Chief  
Department of Environmental Regulation  
Bureau of Air Quality Management  
2600 Blair Stone Road  
Tallahassee, Florida 32301

MAY 14 1990

DER-BAQM

Subject: HARRIS SEMICONDUCTOR, PALM BAY  
B-59 & B-51 Consolidated Air Permit Modifications  
Permit nos. AC 05-174445 & AC 05-157786

Dear Mr. Fancy:

On March 30, 1990, Harris Semiconductor submitted the required 1989 solvent mass balance report for the Palm Bay facility. The results of this report showed building 59's solvent (VOC) emissions to be 5.46 tons/year. The current permit estimates the building's emissions to be 2.37 tons/year.

While activity and operations in building 59 has increased, consolidation of wafer fabrication operations in building 51 indicate a decrease in chemical activity and the resulting air emissions. The current permit limit for building 51 is 33.29 tons/year; however, mass balance results for 1989 demonstrated that the emissions for this building are considerably less (17.30 tons/year.)

As discussed in the 'Conclusions and Recommendations' section of the mass balance report, we specifically request that the annual VOC emission limit for building 59 be increased to 8.37 tons/year to account for the emissions, and, in turn, the permit limit for building 51 be reduced to 27.29 tons/year.


Consequently, the following table presents the projected potential VOC emissions from the facility:

SOURCE	POTENTIAL VOC EMISSIONS (tpy)
BUILDING 4	10.96
51	27.29
54	95.65
55	0.28 (fugitive)
57	1.66
58	3.24
59	8.37
60	0.75
61	0.25
62	0.83
63	6.14
TOTAL	= 155.42

Please note that the requested modifications do not effect the current VOC emission limit for the site.

Enclosed are the modified permit applications for buildings 51 and 59. If you should have any questions about the enclosed information, please contact Nancy Baldisserotto at (407) 729-4061.

Sincerely,

A handwritten signature in cursive script, appearing to read "Al N. Critzer".


Al N. Critzer  
Plant Manager

cc: C. Collins  
B. Mitchell

Attachment Available Upon Request

## DEPARTMENT OF ENVIRONMENTAL REGULATION

WIN TOWERS OFFICE BUILDING  
2600 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301-8241



BOB GRAHAM  
GOVERNOR  
VICTORIA J. TSCHINKEL  
SECRETARY

## APPLICATION TO OPERATE/CONSTRUCT AIR POLLUTION SOURCES

SOURCE TYPE: Stationary [ ] New<sup>1</sup> [X] Existing<sup>1</sup>

APPLICATION TYPE: [ ] Construction [ ] Operation [X] Modification

COMPANY NAME: Harris Semiconductor COUNTY: Brevard

Identify the specific emission point source(s) addressed in this application (i.e. Lime Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired) Building 51

SOURCE LOCATION: Street Palm Bay Road City Palm Bay

UTM: East 17-538700 North 17-3100900

Latitude 28 ° 01 ' 20 "N Longitude 80 ° 36 ' 10 "W

APPLICANT NAME AND TITLE: Al N. Critzer, Plant Manager

APPLICANT ADDRESS: P.O. Box 883, Melbourne, Fl 32901

## SECTION I: STATEMENTS BY APPLICANT AND ENGINEER

## A. APPLICANT

I am the undersigned owner or authorized representative\* of Harris Semiconductor

I certify that the statements made in this application for a modified permit are true, correct and complete to the best of my knowledge and belief. Further I agree to maintain and operate the pollution control source and pollution control facilities in such a manner as to comply with the provision of Chapter 403, Florida Statutes, and all the rules and regulations of the department and revisions thereof. I also understand that a permit, if granted by the department, will be non-transferable and I will promptly notify the department upon sale or legal transfer of the permitted establishment.

\*Attach letter of authorization

Signed: Alvin N. Critzer

Alvin N. Critzer, Plant Manager

Name and Title (Please Type)

Date: 5/9/90 Telephone No. (407) 724-7078

## B. PROFESSIONAL ENGINEER REGISTERED IN FLORIDA (where required by Chapter 471, F.S.)

This is to certify that the engineering features of this pollution control project have been designed/examined by me and found to be in conformity with modern engineering principles applicable to the treatment and disposal of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgment, that

<sup>1</sup> See Florida Administrative Code Rule 17-2.100(57) and (104)

the pollution control facilities, when properly maintained and operated, will discharge an effluent that complies with all applicable statutes of the State of Florida and the rules and regulations of the department. It is also agreed that the undersigned will furnish, if authorized by the owner, the applicant a set of instructions for the proper maintenance and operation of the pollution control facilities and, if applicable, pollution sources.

Signed Lawrence R. Hutker

Lawrence R. Hutker

Name (Please Type)

Harris Semiconductor

Company Name (Please Type)

P.O. Box 883, Melbourne, Florida 32901

Mailing Address (Please Type)

Florida Registration No. 35972 Date: 5/9/90 Telephone No. (407) 729-4655

SECTION II: GENERAL PROJECT INFORMATION

- Describe the nature and extent of the project. Refer to pollution control equipment, and expected improvements in source performance as a result of installation. State whether the project will result in full compliance. Attach additional sheet if necessary.

This is a modification of Building 51 Consolidated Air Permit No. AC 05-157786.

- 1. Schedule of project covered in this application (Construction Permit Application Only)

Start of Construction N/A Completion of Construction \_\_\_\_\_

- 2. Costs of pollution control system(s): (Note: Show breakdown of estimated costs only for individual components/units of the project serving pollution control purposes. Information on actual costs shall be furnished with the application for operation permit.)

N/A

- Indicate any previous DER permits, orders and notices associated with the emission point, including permit issuance and expiration dates.

AO 05-109853 issued 11/5/85; expires 10/30/90. AO 05-109855 issued 11/5/85; expires 10/30/90. AO 05-117085 issued 05/20/86; expires 05/22/91. AU 05-71405 issued 09/13/83; expires 09/12/88. AC 05-157786 issued 03/31/89; expires 12/30/90.

E. Requested permitted equipment operating time: hrs/day 24 ; days/wk 7 ; wks/yr 52  
if power plant, hrs/yr \_\_\_\_\_; if seasonal, describe: \_\_\_\_\_

F. If this is a new source or major modification, answer the following questions.  
(Yes or No)

1. Is this source in a non-attainment area for a particular pollutant? No  
a. If yes, has "offset" been applied? \_\_\_\_\_  
b. If yes, has "Lowest Achievable Emission Rate" been applied? \_\_\_\_\_  
c. If yes, list non-attainment pollutants. \_\_\_\_\_

2. Does best available control technology (BACT) apply to this source?  
If yes, see Section VI. No

3. Does the State "Prevention of Significant Deterioration" (PSD)  
requirement apply to this source? If yes, see Sections VI and VII. No

4. Do "Standards of Performance for New Stationary Sources" (NSPS)  
apply to this source? No

5. Do "National Emission Standards for Hazardous Air Pollutants"  
(NESHAP) apply to this source? No

H. Do "Reasonably Available Control Technology" (RACT) requirements apply  
to this source? No

a. If yes, for what pollutants? \_\_\_\_\_

b. If yes, in addition to the information required in this form,  
any information requested in Rule 17-2.650 must be submitted.

Attach all supportive information related to any answer of "Yes". Attach any justifi-  
cation for any answer of "No" that might be considered questionable.



SECTION III: AIR POLLUTION SOURCES & CONTROL DEVICES (Other than Incinerators)

A. Raw Materials and Chemicals Used in your Process, if applicable:

Description	Contaminants		Utilization Rate - lbs/hr	Relate to Flow Diagram
	Type	% Wt		
---SEE ATTACHMENT C ----				

B. Process Rate, if applicable: (See Section V, Item 1)

1. Total Process Input Rate (lbs/hr): not applicable

2. Product Weight (lbs/hr): not applicable

C. Airborne Contaminants Emitted: (Information in this table must be submitted for each emission point, use additional sheets as necessary)

Name of Contaminant	Emission <sup>1</sup>		Allowed Emission Rate per Rule 17-2	Allowable <sup>3</sup> Emission lbs/hr	Potential <sup>4</sup> Emission		Relate to Flow Diagram
	Maximum lbs/hr	Actual T/yr			lbs/yr	T/yr	
---SEE ATTACHMENT B ----							

<sup>1</sup>See Section V, Item 2.

<sup>2</sup>Reference applicable emission standards and units (e.g. Rule 17-2.600(5)(b)2. Table II, E. (1) - 0.1 pounds per million BTU heat input)

<sup>3</sup>Calculated from operating rate and applicable standard.

<sup>4</sup>Emission, if source operated without control (See Section V, Item 3).

J. Control Devices: (See Section V, Item 4)

Name and Type (Model & Serial No.)	Contaminant	Efficiency	Range of Particles Size Collected (in microns) (If applicable)	Basis for Efficiency (Section V Item 5)
---SEE ATTACHMENT D ---				

E. Fuels

Type (Be Specific)	Consumption*		Maximum Heat Input (MMBTU/hr)
	avg/hr	max./hr	

\*Units: Natural Gas--MMCF/hr; Fuel Oils--gallons/hr; Coal, wood, refuse, other--lbs/hr.

Fuel Analysis:

Percent Sulfur: \_\_\_\_\_ Percent Ash: \_\_\_\_\_

Density: \_\_\_\_\_ lbs/gal Typical Percent Nitrogen: \_\_\_\_\_

Heat Capacity: \_\_\_\_\_ BTU/lb \_\_\_\_\_ BTU/gal

Other Fuel Contaminants (which may cause air pollution): \_\_\_\_\_

F. If applicable, indicate the percent of fuel used for space heating.

Annual Average \_\_\_\_\_ Maximum \_\_\_\_\_

G. Indicate liquid or solid wastes generated and method of disposal.

Waste water from air scrubbers is discharged to on-site Waste Water Treatment

Plant--discharge to deepwell under UIC - Permit #UC05-126519.

1

-----SEE ATTACHMENT D-----

H. Emission Stack Geometry and Flow Characteristics (Provide data for each stack):

Stack Height: \_\_\_\_\_ ft. Stack Diameter: \_\_\_\_\_ ft.

Gas Flow Rate: \_\_\_\_\_ ACFM \_\_\_\_\_ DSCFM Gas Exit Temperature: \_\_\_\_\_ °F.

Water Vapor Content: \_\_\_\_\_ % Velocity: \_\_\_\_\_ FPS

SECTION IV: INCINERATOR INFORMATION

not applicable

Type of Waste	Type 0 (Plastics)	Type I (Rubbish)	Type II (Refuse)	Type III (Garbage)	Type IV (Pathological)	Type V (Liq. & Gas By-prod.)	Type VI (Solid By-prod.)
Actual lb/hr Incinerated							
Uncontrolled (lbs/hr)							

Description of Waste \_\_\_\_\_

Total Weight Incinerated (lbs/hr) \_\_\_\_\_ Design Capacity (lbs/hr) \_\_\_\_\_

Approximate Number of Hours of Operation per day \_\_\_\_\_ day/wk \_\_\_\_\_ wks/yr. \_\_\_\_\_

Manufacturer \_\_\_\_\_

Date Constructed \_\_\_\_\_ Model No. \_\_\_\_\_

	Volume (ft) <sup>3</sup>	Heat Release (BTU/hr)	Fuel		Temperature (°F)
			Type	BTU/hr	
Primary Chamber					
Secondary Chamber					

Stack Height: \_\_\_\_\_ ft. Stack Diameter: \_\_\_\_\_ Stack Temp. \_\_\_\_\_

Gas Flow Rate: \_\_\_\_\_ ACFM \_\_\_\_\_ DSCFM\* Velocity: \_\_\_\_\_ FPS

\*If 50 or more tons per day design capacity, submit the emissions rate in grains per standard cubic foot dry gas corrected to 50% excess air.

Type of pollution control device: [ ] Cyclone [ ] Wet Scrubber [ ] Afterburner  
 [ ] Other (specify) \_\_\_\_\_

Brief description of operating characteristics of control devices: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Ultimate disposal of any effluent other than that emitted from the stack (scrubber water, ash, etc.):

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NOTE: Items 2, 3, 4, 6, 7, 8, and 10 in Section V must be included where applicable.

**SECTION V: SUPPLEMENTAL REQUIREMENTS**

Please provide the following supplements where required for this application.

1. Total process input rate and product weight -- show derivation [Rule 17-2.100(127)]
2. To a construction application, attach basis of emission estimate (e.g., design calculations, design drawings, pertinent manufacturer's test data, etc.) and attach proposed methods (e.g., FR Part 60 Methods 1, 2, 3, 4, 5) to show proof of compliance with applicable standards. To an operation application, attach test results or methods used to show proof of compliance. Information provided when applying for an operation permit from a construction permit shall be indicative of the time at which the test was made.
3. Attach basis of potential discharge (e.g., emission factor, that is, AP42 test).
4. With construction permit application, include design details for all air pollution control systems (e.g., for baghouse include cloth to air ratio; for scrubber include cross-section sketch, design pressure drop, etc.)
5. With construction permit application, attach derivation of control device(s) efficiency. Include test or design data. Items 2, 3 and 5 should be consistent: actual emissions = potential (1-efficiency).
6. An 8 1/2" x 11" flow diagram which will, without revealing trade secrets, identify the individual operations and/or processes. Indicate where raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particles are evolved and where finished products are obtained.
7. An 8 1/2" x 11" plot plan showing the location of the establishment, end points of airborne emissions, in relation to the surrounding area, residences and other permanent structures and roadways (Example: Copy of relevant portion of USGS topographic map).
8. An 8 1/2" x 11" plot plan of facility showing the location of manufacturing processes and outlets for airborne emissions. Relate all flows to the flow diagram.

- 9. The appropriate application fee in accordance with Rule 17-4.05. The check should be made payable to the Department of Environmental Regulation.
- 10. With an application for operation permit, attach a Certificate of Completion of Construction indicating that the source was constructed as shown in the construction permit.

**SECTION VI: BEST AVAILABLE CONTROL TECHNOLOGY**

A. Are standards of performance for new stationary sources pursuant to 40 C.F.R. Part 60 applicable to the source?

Yes  No

Contaminant	Rate or Concentration

B. Has EPA declared the best available control technology for this class of sources (if yes, attach copy)

Yes  No

Contaminant	Rate or Concentration

C. What emission levels do you propose as best available control technology?

Contaminant	Rate or Concentration

D. Describe the existing control and treatment technology (if any).

- |                           |                          |
|---------------------------|--------------------------|
| 1. Control Device/System: | 2. Operating Principles: |
| 3. Efficiency:            | 4. Capital Costs:        |

Explain method of determining

5. Useful Life:

6. Operating Costs:

7. Energy:

8. Maintenance Cost:

9. Emissions:

Contaminant

Rate or Concentration

Contaminant	Rate or Concentration

10. Stack Parameters

a. Height:

ft.

b. Diameter:

ft.

c. Flow Rate:

ACFM

d. Temperature:

°F.

e. Velocity:

FPS

E. Describe the control and treatment technology available (As many types as applicable use additional pages if necessary).

1.

a. Control Device:

b. Operating Principles:

c. Efficiency:<sup>1</sup>

d. Capital Cost:

e. Useful Life:

f. Operating Cost:

g. Energy:<sup>2</sup>

h. Maintenance Cost:

i. Availability of construction materials and process chemicals:

j. Applicability to manufacturing processes:

k. Ability to construct with control device, install in available space, and operate within proposed levels:

2.

a. Control Device:

b. Operating Principles:

c. Efficiency:<sup>1</sup>

d. Capital Cost:

e. Useful Life:

f. Operating Cost:

g. Energy:<sup>2</sup>

h. Maintenance Cost:

i. Availability of construction materials and process chemicals:

<sup>1</sup>Explain method of determining efficiency.

<sup>2</sup>Energy to be reported in units of electrical power - KWH design rate.

j. Applicability to manufacturing processes:

k. Ability to construct with control device, install in available space, and operate within proposed levels:

3.

a. Control Device:

b. Operating Principles:

c. Efficiency:<sup>1</sup>

d. Capital Cost:

e. Useful Life:

f. Operating Cost:

g. Energy:<sup>2</sup>

h. Maintenance Cost:

i. Availability of construction materials and process chemicals:

j. Applicability to manufacturing processes:

k. Ability to construct with control device, install in available space, and operate within proposed levels:

4.

a. Control Device:

b. Operating Principles:

c. Efficiency:<sup>1</sup>

d. Capital Costs:

e. Useful Life:

f. Operating Cost:

g. Energy:<sup>2</sup>

h. Maintenance Cost:

i. Availability of construction materials and process chemicals:

j. Applicability to manufacturing processes:

k. Ability to construct with control device, install in available space, and operate within proposed levels:

F. Describe the control technology selected:

1. Control Device:

2. Efficiency:<sup>1</sup>

3. Capital Cost:

4. Useful Life:

5. Operating Cost:

6. Energy:<sup>2</sup>

7. Maintenance Cost:

8. Manufacturer:

9. Other locations where employed on similar processes:

a. (1) Company:

(2) Mailing Address:

(3) City:

(4) State:

\* Explain method of determining efficiency.

Energy to be reported in units of electrical power - KWH design rate.

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions:<sup>1</sup>

Contaminant	Rate or Concentration

(8) Process Rate:<sup>1</sup>

b. (1) Company:

(2) Mailing Address:

(3) City:

(4) State:

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions:<sup>1</sup>

Contaminant	Rate or Concentration

(8) Process Rate:<sup>1</sup>

10. Reason for selection and description of systems:

<sup>1</sup>Applicant must provide this information when available. Should this information not be available, applicant must state the reason(s) why.

### SECTION VII - PREVENTION OF SIGNIFICANT DETERIORATION

#### A. Company Monitored Data

1. \_\_\_\_\_ no. sites \_\_\_\_\_ TSP \_\_\_\_\_ ( ) SO<sub>2</sub> \_\_\_\_\_ Wind spd/dir

Period of Monitoring \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ to \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
month day year month day year

Other data recorded \_\_\_\_\_

Attach all data or statistical summaries to this application.

Specify bubbler (B) or continuous (C).



2. Instrumentation, Field and Laboratory

- a. Was instrumentation EPA referenced or its equivalent?  Yes  No
- b. Was instrumentation calibrated in accordance with Department procedures?  
 Yes  No  Unknown

B. Meteorological Data Used for Air Quality Modeling

- 1. \_\_\_\_\_ Year(s) of data from \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ to \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
month day year month day year
- 2. Surface data obtained from (location) \_\_\_\_\_
- 3. Upper air (mixing height) data obtained from (location) \_\_\_\_\_
- 4. Stability wind rose (STAR) data obtained from (location) \_\_\_\_\_

C. Computer Models Used

- 1. \_\_\_\_\_ Modified? If yes, attach description.
- 2. \_\_\_\_\_ Modified? If yes, attach description.
- 3. \_\_\_\_\_ Modified? If yes, attach description.
- 4. \_\_\_\_\_ Modified? If yes, attach description.

Attach copies of all final model runs showing input data, receptor locations, and principle output tables.

D. Applicants Maximum Allowable Emission Data

Pollutant	Emission Rate
TSP	_____ grams/sec
SO <sup>2</sup>	_____ grams/sec

E. Emission Data Used in Modeling

Attach list of emission sources. Emission data required is source name, description of point source (on NEDS point number), UTM coordinates, stack data, allowable emissions, and normal operating time.

- F. Attach all other information supportive to the PSD review.
- G. Discuss the social and economic impact of the selected technology versus other applicable technologies (i.e., jobs, payroll, production, taxes, energy, etc.). Include assessment of the environmental impact of the sources.
- H. Attach scientific, engineering, and technical material, reports, publications, journals, and other competent relevant information describing the theory and application of the requested best available control technology.

**ATTACHMENT A.**  
**PROCESS DESCRIPTION**

## PROCESS DESCRIPTION - BUILDING 51

Building 51 is a wafer fabrication facility. The second floor of the two-story building houses two clean room modules. Both fabrication areas employ a series of manufacturing procedures referred to as layering, patterning, doping and heating processes. The frequency and sequence of these processes can vary depending on the desired nature of the final product.

In the controlled environment of the fabrication clean rooms, wafer surfaces first undergo acid and/or solvent cleaning, followed by thermal oxidation in furnaces to form a layer of silicon dioxide on the wafer surface.

During the patterning process, the wafers are initially baked and primed. Coaters then spin a thin layer of "photoresist" on the wafer, after which the wafers are soft baked. Next, the circuit pattern is projected onto the wafers via "aligners" or "steppers." Developers are then applied to remove unpolymerized areas of photoresist. This is followed by a solvent rinse.

Next, the wafers hard-baked, inspected to determine accuracy, and etched by wet (acid bath) or dry (plasma vapor) mechanisms. Once etching is complete, the photoresist is stripped off the wafer using chemical baths or plasma techniques.

In another step of the fabrication process, "dopant" atoms are either diffused into the wafer in diffusion furnaces, or accelerated into the wafer using "ion implantation." Additional material may be layered on the wafer surface in vapor and crystal (epitaxial) deposition furnaces. Metallization to interconnect uppermost circuit layers is performed by deposition (using "sputtering" systems) or evaporation.

Wet stations that house vats containing a variety of acid and caustic compounds are located throughout the clean rooms. Storage cabinets safely hold virgin chemicals until they are ready for use. Exhausted gas cabinets house cylinders that supply process gases to the 'fab' operations.

The exhaust system for the building is divided amongst five scrubbers. The scrubbers numbered F51S01, F51S02, and F51S03 serve the east module, while F51S04 and F51S05 serve the west module. Scrubbers numbered F51S01, F51S03 and F51S04 are acid scrubbers, while F51S02 and F51S05 provide pollution control and exhaust for equipment containing solvents.

**ATTACHMENT B.**  
**AIR EMISSIONS**

## SOLVENT EMISSIONS - BUILDING 51

A solvent mass balance was performed on building 51 for calendar year 1989, with the following results;

1. 1988 ENDING INVENTORY = 5.61 tons
2. SOLVENTS PURCHASED = 97.01 tons
3. WASTE SHIPMENTS = 78.12 tons
4. TRACE AMOUNTS DEEPWELL INJECTED = 5.82 tons
5. 1989 ENDING INVENTORY = 1.38 tons
6. VOC AIR EMISSIONS = 17.30 tons

Note: Please refer to 1989 Solvent Mass Balance Report for lists of assumptions.

**TOTAL PROJECTED VOC EMISSIONS FOR BUILDING 51 = 27.29 TONS/YEAR.**

## SOLVENT MONITORING--BUILDING 51

Monitoring work was conducted on the building 51 solvent scrubber systems F51S02, F51S03, F51S04, & F51S05 in August of 1987. Tests employed were EPA methods 25A (flame ionization detection) and TO-1 (Tenax adsorption and GC/ms analysis.)

FID test results revealed that total accumulative monitored VOC emissions for the building were 6.25 pounds/hour expressed as propane. The following assumptions were made regarding monitoring work on this building:

-VOC values refer to all organic emissions including organic solvents.

-All data was corrected for 2 ppm background noise that is normally present in the ambient air.

AUGUST 1989

EPA METHOD 25-A (F.I.D. ANALYSIS) BUILDING 51  
AVERAGE MONITORED VOC EMISSIONS DURING PRODUCTION HOURS

F51S02 (LB/HR)	F51S03 (LB/HR)	F51S04 (LB/HR)	F51S05 (LB/HR)
<u>2.69</u>	<u>0.18</u>	<u>0.14</u>	<u>3.24</u>

## ACID MONITORING--BUILDING 51

Monitoring was performed on the building 51 scrubbers F51S01, F51S03, and F51S04 during August of 1989. Samples were collected using modified EPA method 8 sampling train. The impinger medium consisted of a 0.1 N sodium hydroxide solution. The analytical methodology utilized to determine the ions of highest concentration is as follows:

Chloride ion--EPA Method 325.3

Fluoride ion--EPA Method 340.2

Nitrate, phosphite, and sulfate ions--ion chromatography

All results were in pounds per hour as "X", where "X" represents the acid compound present in highest concentration.

The test results revealed that the total accumulative monitored acid emissions for the building were 2.61 tons/year expressed as hydrochloric, hydrofluoric, nitric, phosphoric and sulfuric acids. This figure is based on a hypothetical production schedule of 8760 hours a year. The monitoring was performed over an 8 hour time interval when the full production was occurring.

When a resulting acid concentration was expressed as a "less than 'y' " value, where 'y' represents the lowest detectable limit possible using the analytical methodology employed, acid emissions were taken to be equal to this 'y' limit value.



RESULTS OF ACID MONITORING--BUILDING 51  
PERFORMED IN AUGUST OF 1989

Scrubber #		HCl	HF	Nitric Acid	Phosphoric Acid	Sulfuric Acid	TOTAL (TON/YR)
OUTLET 51S01	(lb/hr)	0.029	0.001	0.048	0.001	0.022	
	(ton/yr)	0.1270	0.0044	0.2102	0.0044	0.0964	0.4424
OUTLET 51S03	(lb/hr)	0.0710	0.0240	0.1220	0.0010	0.0880	
	(ton/yr)	0.3110	0.1051	0.5344	0.0044	0.3854	1.3403
OUTLET 51S04	(lb/hr)	0.0560	0.0650	0.0010	0.0010	0.0660	
	(ton/yr)	0.2453	0.2847	0.0044	0.0044	0.2891	0.8278
							2.6105

TOTAL ACID EMISSIONS INTO SCRUBBER OUTLETS = 2.61 TONS/YEAR

**ATTACHMENT C.**  
**RAW MATERIALS & CHEMICALS**

BUILDING 51  
SOLVENTS  
-----

1,1,1 TRICHLOROETHANE  
1,2,4 TRICHLOROBENZENE  
1-METHOXY-2-PROPANOL  
2-ETHOXYETHYL ACETATE  
2-METHOXY-2-PROPANOL  
ACETONE  
AMMONIUM FLUORIDE  
AROMATIC PHENOL  
BUTYL CELLOSOLVE  
CELLOSOLVE ACETATE  
CHLOROPENTAFLUOROETHANE  
CHLOROTRIFLUOROMETHANE  
DICHLORODIFLUOROMETHANE  
ETHANOL  
ETHANOLAMINE  
ETHYL BENZENE  
ETHYLENE GLYCOL MONOBUTYL ETHER  
ETHYLENE GLYCOL MONOETHYL ETHER ACETATE  
GLYCOL ETHER  
ISOPARAFFINIC HYDROCARBONS  
ISOPROPANOL  
METHANOL  
METHYL ETHYL KETONE  
METHYLENE CHLORIDE  
MONOETHANOLAMINE  
N-BUTYL ACETATE  
N-METHYLPYRROLIDONE  
POLYPHENYL ETHER  
PROPYLENE GLYCOL MONOETHYL ETHER ACETATE  
PROPYLENE GLYCOL MONOMETHYL ETHER  
Tetrafluoroethane  
Tetrafluoromethane  
TRICHLORODIFLUOROETHANE  
TRICHLOROTRIFLUOROETHANE  
TRICHLOROTRIFLUOROMETHANE  
XYLENE

BUILDING 51  
PROCESS CHEMICALS

---

ACETIC ACID  
AMMONIA  
AMMONIUM FLUORIDE  
AMMONIUM HYDROXIDE  
CERIC SULFATE  
CHROMIC ACID  
CHROMIUM TRIOXIDE  
CHROMIUM TRIOXIDE  
COPPER SULFATE  
DICHLOROBENZENE  
DIMETHYLPOLYSILOXANE  
DODECYLBENZENESULFONIC ACID  
ETHYLENE DIAMINE TETRAACETIC ACID  
FERRIC CHLORIDE  
GUM RESIN  
HEXAMETHYLDISILAZANE  
HYDROFLUORIC ACID  
HYDROGEN PEROXIDE  
NITRIC ACID  
PHENOL-FORMALDEHYDE RESIN  
PHOSPHATE  
PHOSPHORIC ACID  
POTASSIUM HYDROXIDE  
SILICON  
SODIUM HYDROXIDE  
SULFURIC ACID  
TETRAMETHYL AMMONIUM HYDROXIDE

BUILDING 51  
PROCESS GASES

---

ALUMINUM OXIDE  
ARGON  
ARSINE  
BORON TRIFLUORIDE  
SULFUR HEXAFLUORIDE  
CARBON DIOXIDE  
DICHLOROSILANE  
HELIUM  
NITROGEN  
NITROUS OXIDE  
OXYGEN  
PHOSPHINE  
SILANE  
ARSENIC  
BORON TRIBROMIDE  
NITROGEN DIOXIDE  
HYDROGEN CHLORIDE  
PHOSPHORUS TRICHLORIDE  
HYDROGEN

**ATTACHMENT D.**  
**CONTROL EQUIPMENT**

HARRIS SEMICONDUCTOR

-- AIR PERMIT INFORMATION

CURRENT PERMIT

BUILDING: 51  
PERMIT NUMBER: AO 05-117085  
PERMIT TYPE : OPERATING

DATE ISSUED : 05/20/86  
RENEWAL DATE: 03/23/91  
DATE EXPIRES: 05/22/91

AREA SERVED: ANALOG EXPANSION  
PROCESS DESCRIPTION: EXHAUST SYSTEM SCRUBBER

PERMIT LIMITS

VOL. RATE (SCFM): 9.500  
ACID MIST (LB/HR): 0.0437  
SOLVENTS (LB/HR): --  
VOCS (LB/HR): --  
OPER. (HRS/YEAR): 6336

SPECIFIC CONDITIONS

ANNUAL OPERATING REPORT : 03/01  
NOTIFICATION OF VE TEST : NOT SPEC.  
ANNUAL VIS EMISSION TEST: NOT SPEC.

EQUIPMENT INFORMATION

MANUFACTURER : TRI-MER CORP.  
LOCATION : B51 ROOF  
HARRIS ID NUMBER : F51S01  
VOLUME FLOW RATE (CFM): 9.500  
RECIRCULATION RATE (GPM): 30  
MAKEUP WATER RATE (GPM): 3.0

MODEL NUMBER : F/W 3  
STACK HEIGHT (FT):  
STACK DIAMETER (IN):  
STACK VELOCITY (FPM):  
DUCT MATERIAL :

PERMIT HISTORY

PERMIT NUMBER: AO 05-38487  
DATE EXPIRED : 04/08/86

PERMIT NUMBER:  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

SCRUBBER INFORMATION

HARRIS ID # : F51S01  
MANUFACTURER : TRI-MER CORP. MODEL NUMBER : F/W 3  
SERIAL NUMBER: 7026 MATERIAL : PVC  
DESCRIPTION : HORIZONTAL COUNTER-FLOW. MIST ELIMINATOR.  
POLYPRO FILTER PACK: DRAWING D1000-585 (6/80)

DESIGN DATA

VOLUME FLOW RATE (CFM): 9.500 PRESSURE DROP (IN):  
RECIRCULATION RATE (GPM): 30 MAKE UP RATE (GPM): 3.0

ACTUAL DATA

VOLUME FLOW RATE (CFM): PRESSURE DROP (IN): N/E DATE: 6/3/87  
RECIRCULATION RATE (GPM): N/E MAKE UP RATE (GPM): N/R DATE: "

RECIRCULATION PUMP INFORMATION

MANUFACTURER : FLOTEK MODEL NUMBER : C7P3-1194V  
SERIAL NUMBER: 603887B801 HP : 1 RPM : 3450/2850  
BRKR LOCATION: NEXT TO UNIT FED FROM MCC : TAC 76127

FAN INFORMATION

HARRIS ID # : F51E13  
MANUFACTURER : TRI-MER CORP. MODEL NUMBER: 24 UB  
SERIAL NUMBER: 7026 MATERIAL : PVC  
DESCRIPTION : CENTRIFUGAL BLOWER. BACKWARD INCLINED BLADES

DESIGN DATA

VOLUME FLOW RATE (CFM): 6.000 STATIC PRESS (IN):

ACTUAL DATA

VOLUME FLOW RATE (CFM): SPEED (RPM): DATE:  
STATIC PRESS (IN): DATE:

FAN MOTOR INFORMATION

MANUFACTURER : LINCOLN MODEL NUMBER :  
SERIAL NUMBER: HP : 15 RPM : 1750  
BRKR LOCATION: NEXT TO UNIT FED FROM MCC : TAC 76127



HARRIS SEMICONDUCTOR

-- AIR PERMIT INFORMATION

CURRENT PERMIT

BUILDING: 51  
PERMIT NUMBER: AO 05-109855  
PERMIT TYPE : OPERATING

DATE ISSUED : 11/05/85  
RENEWAL DATE: 08/31/90  
DATE EXPIRES: 10/30/90

AREA SERVED:

PROCESS DESCRIPTION: SILICON WAFER CHEM. TREAT AIR WASHER (SYS 6)

PERMIT LIMITS

VOL. RATE (SCFM): 10.000  
ACID MIST (LB/HR): --  
SOLVENTS (LB/HR): --  
VOCS (LB/HR): 1.246  
OPER. (HRS/YEAR): 6336

SPECIFIC CONDITIONS

ANNUAL OPERATING REPORT : 03/01  
NOTIFICATION OF VE TEST : 11/06  
ANNUAL VIS EMISSION TEST: 11/21

EQUIPMENT INFORMATION

MANUFACTURER : DUALL IND.  
LOCATION : B51 PENTHOUSE  
HARRIS ID NUMBER : F51S02  
VOLUME FLOW RATE (CFM): 10.000  
RECIRCULATION RATE (GPM): 30  
MAKEUP WATER RATE (GPM): 1.5

MODEL NUMBER : F-101  
STACK HEIGHT (FT):  
STACK DIAMETER (IN):  
STACK VELOCITY (FPM):  
DUCT MATERIAL :

PERMIT HISTORY

PERMIT NUMBER: AO 05-36166  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

SCRUBBER INFORMATION

HARRIS ID # : F51502  
MANUFACTURER : DUALL IND. MODEL NUMBER : F-101  
SERIAL NUMBER: 4476 MATERIAL : PVC  
DESCRIPTION : HORIZONTAL CROSS-FLOW. FOUR STAGE. MIST ELIMINATOR.  
SINGLE FILTER PACK. OPEN ORIFICE TYPE SPRAY NOZZLES

DESIGN DATA

VOLUME FLOW RATE (CFM): 10.000 PRESSURE DROP (IN): 2.0  
RECIRCULATION RATE (GPM): 30 MAKE UP RATE (GPM): 1.5

ACTUAL DATA

VOLUME FLOW RATE (CFM): 8,200 PRESSURE DROP (IN): N/E DATE: 1/16/87  
RECIRCULATION RATE (GPM): 12 MAKE UP RATE (GPM): N/E DATE: 6/3/87

RECIRCULATION PUMP INFORMATION

MANUFACTURER : GENERAL ELECT. MODEL NUMBER : 5K47SG976  
SERIAL NUMBER: N/A HP : 2 RPM : 3450  
BRKR LOCATION: FED FROM MCC :

FAN INFORMATION

HARRIS ID # : F51E18  
MANUFACTURER : DUALL IND. MODEL NUMBER: 49  
SERIAL NUMBER: 4476 MATERIAL : PVC  
DESCRIPTION : CENTRIFUGAL BLOWER

DESIGN DATA

VOLUME FLOW RATE (CFM): 10.000 STATIC PRESS (IN):

ACTUAL DATA

VOLUME FLOW RATE (CFM): 8.200 SPEED (RPM): DATE:  
STATIC PRESS (IN): 4.3 DATE: 1/16/87

FAN MOTOR INFORMATION

MANUFACTURER : MODEL NUMBER :  
SERIAL NUMBER: HP : 15 RPM : 1750  
BRKR LOCATION: FED FROM MCC :

Attachment :

HARRIS SEMICONDUCTOR

-- AIR PERMIT INFORMATION

CURRENT PERMIT

BUILDING: 51  
PERMIT NUMBER: AO 05-109853  
PERMIT TYPE : OPERATING

DATE ISSUED : 11/05/85  
RENEWAL DATE: 08/31/90  
DATE EXPIRES: 10/30/90

AREA SERVED:

PROCESS DESCRIPTION: SILICON WAFER CHEM TREAT AIR WASHER (SYS 3 AND 5)

PERMIT LIMITS

VOL. RATE (SCFM): 24.000  
ACID MIST (LB/HR): 0.0649  
SOLVENTS (LB/HR): --  
VOCS (LB/HR): 0.0174  
OPER. (HRS/YEAR): 6336

SPECIFIC CONDITIONS

ANNUAL OPERATING REPORT : 03/01  
NOTIFICATION OF VE TEST : 11/06  
ANNUAL VIS EMISSION TEST: 11/21

EQUIPMENT INFORMATION

MANUFACTURER : DUALL IND.  
LOCATION : B51 PENTHOUSE  
HARRIS ID NUMBER : F51S03  
VOLUME FLOW RATE (CFM): 24,000  
RECIRCULATION RATE (GPM): 72  
MAKEUP WATER RATE (GPM): 4.0

MODEL NUMBER : F-101  
STACK HEIGHT (FT):  
STACK DIAMETER (IN):  
STACK VELOCITY (FPM):  
DUCT MATERIAL :

PERMIT HISTORY

PERMIT NUMBER: AO 05-36165  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

SCRUBBER INFORMATION

HARRIS ID # : F51S03  
MANUFACTURER : DUALL IND. MODEL NUMBER : F-101  
SERIAL NUMBER: 419 MATERIAL : PVC  
DESCRIPTION : HORIZONTAL CROSS-FLOW. FOUR STAGE. MIST ELIMINATOR.  
SINGLE FILTER PACK. OPEN ORIFICE TYPE SPRAY NOZZLES

DESIGN DATA

VOLUME FLOW RATE (CFM): 24.000 PRESSURE DROP (IN): 2.0  
RECIRCULATION RATE (GPM): 72 MAKE UP RATE (GPM): 4.0

ACTUAL DATA

VOLUME FLOW RATE (CFM): PRESSURE DROP (IN): N/E DATE: 6/3/87  
RECIRCULATION RATE (GPM): N/E MAKE UP RATE (GPM): N/E DATE: "

RECIRCULATION PUMP INFORMATION

MANUFACTURER : LINCOLN MODEL NUMBER : 2509  
SERIAL NUMBER: 1605666 3420 HP : 1.5 RPM : 3420  
BRKR LOCATION: FED FROM MCC : #5

FAN INFORMATION

HARRIS ID # : F51E03  
MANUFACTURER : TRI-MER CORP. MODEL NUMBER: 44 CW  
SERIAL NUMBER: 5303 MATERIAL : PVC  
DESCRIPTION : CENTRIFUGAL BLOWER. BACKWARD INCLINED BLADES

DESIGN DATA

VOLUME FLOW RATE (CFM): 30.000 STATIC PRESS (IN):

ACTUAL DATA

VOLUME FLOW RATE (CFM): SPEED (RPM): DATE:  
STATIC PRESS (IN): DATE:

FAN MOTOR INFORMATION

MANUFACTURER : MODEL NUMBER :  
SERIAL NUMBER: HP : 30 RPM : 1750  
BRKR LOCATION: FED FROM MCC : #5

HARRIS SEMICONDUCTOR

-- AIR PERMIT INFORMATION

CURRENT PERMIT

-----  
BUILDING: 51  
PERMIT NUMBER: AO 05-109853  
PERMIT TYPE : OPERATING

DATE ISSUED : 11/05/85  
RENEWAL DATE: 08/31/90  
DATE EXPIRES: 10/30/90

AREA SERVED:

PROCESS DESCRIPTION: SILICON WAFER CHEM TREAT AIR WASHER (SYS 3 AND 5)

PERMIT LIMITS

-----  
VOL. RATE (SCFM): 24.000  
ACID MIST (LB/HR): 0.0649  
SOLVENTS (LB/HR): --  
VOCS (LB/HR): 0.0174  
OPER. (HRS/YEAR): 6336

SPECIFIC CONDITIONS

-----  
ANNUAL OPERATING REPORT : 03/01  
NOTIFICATION OF VE TEST : 11/06  
ANNUAL VIS EMISSION TEST: 11/21

EQUIPMENT INFORMATION

-----  
MANUFACTURER :  
LOCATION : B51 PENTHOUSE  
HARRIS ID NUMBER : F51S04  
VOLUME FLOW RATE (CFM): 12.100  
RECIRCULATION RATE (GPM):  
MAKEUP WATER RATE (GPM):

MODEL NUMBER :  
STACK HEIGHT (FT):  
STACK DIAMETER (IN):  
STACK VELOCITY (FPM):  
DUCT MATERIAL :

PERMIT HISTORY

-----  
PERMIT NUMBER: 36163  
DATE EXPIRED : 11/21/85

PERMIT NUMBER:  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

SCRUBBER INFORMATION

HARRIS ID # : F51S04  
MANUFACTURER : DUALL IND. MODEL NUMBER : F-101  
SERIAL NUMBER: 4104 MATERIAL : PVC  
DESCRIPTION : HORIZONTAL CROSS-FLOW. FOUR STAGE. MIST ELIMINATOR.  
SINGLE FILTER PACK. OPEN ORIFICE TYPE SPRAY NOZZLES

DESIGN DATA

VOLUME FLOW RATE (CFM): 24.000 PRESSURE DROP (IN):  
RECIRCULATION RATE (GPM): 72 MAKE UP RATE (GPM): 4.0

ACTUAL DATA

VOLUME FLOW RATE (CFM): PRESSURE DROP (IN): N/E DATE: 6/3/87  
RECIRCULATION RATE (GPM): N/E MAKE UP RATE (GPM): N/E DATE: "

RECIRCULATION PUMP INFORMATION

MANUFACTURER : LINCOLN MODEL NUMBER : 2500  
SERIAL NUMBER: 1597787 HP : 1.5 RPM : 3420  
BRKR LOCATION: FED FROM MCC : #5

FAN INFORMATION

HARRIS ID # :  
MANUFACTURER : HARTZELL MODEL NUMBER: 41-40-GR3  
SERIAL NUMBER: 15530 MATERIAL : FIBERGLASS  
DESCRIPTION : CENTRIFUGAL BLOWER. BACKWARD CURVED BLADES

DESIGN DATA

VOLUME FLOW RATE (CFM): 24500 STATIC PRESS (IN):

ACTUAL DATA

VOLUME FLOW RATE (CFM): SPEED (RPM): DATE:  
STATIC PRESS (IN): DATE:

FAN MOTOR INFORMATION

MANUFACTURER : MODEL NUMBER :  
SERIAL NUMBER: HP : 30 RPM :  
BRKR LOCATION: FED FROM MCC : #5

Attachment :

HARRIS SEMICONDUCTOR

-- AIR PERMIT INFORMATION

CURRENT PERMIT

-----  
BUILDING: 51  
PERMIT NUMBER: AO 05-71405  
PERMIT TYPE : OPERATING

DATE ISSUED : 09/13/83  
RENEWAL DATE: 07/14/88  
DATE EXPIRES: 09/12/88

AREA SERVED:

PROCESS DESCRIPTION: SILICON WAFER CHEM TREAT SOLVENT SCRUBBER (SYS 6)

PERMIT LIMITS

-----  
VOL. RATE (SCFM): NOT SPEC.  
ACID MIST (LB/HR): --  
SOLVENTS (LB/HR): 0.0893  
VOCS (LB/HR): 0.0008  
OPER. (HRS/YEAR): 6336

SPECIFIC CONDITIONS

-----  
ANNUAL OPERATING REPORT : 03/01  
NOTIFICATION OF VE TEST : 08/10  
ANNUAL VIS EMISSION TEST: 08/20

EQUIPMENT INFORMATION

-----  
MANUFACTURER : HARRISON  
LOCATION : B51 PENTHOUSE  
HARRIS ID NUMBER : F51S05  
VOLUME FLOW RATE (CFM): 18,000  
RECIRCULATION RATE (GPM): 45  
MAKEUP WATER RATE (GPM): 4.5

MODEL NUMBER : HF-180  
STACK HEIGHT (FT):  
STACK DIAMETER (IN):  
STACK VELOCITY (FPM):  
DUCT MATERIAL :

PERMIT HISTORY

-----  
PERMIT NUMBER: N/A  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

PERMIT NUMBER:  
DATE EXPIRED :

SCRUBBER INFORMATION

HARRIS ID # : F51S05  
MANUFACTURER : HARRISON MODEL NUMBER : HF-180  
SERIAL NUMBER : N/ MATERIAL : POLYPRO  
DESCRIPTION : HORIZONTAL CROSS-FLOW. PLASTIC SADDLE PACKING. LIQUID  
DISTRIBUTION THROUGH MAIN HEADER. NO SPRAY NOZZLES  
DWG HPS-217-C 11/21/83

DESIGN DATA

VOLUME FLOW RATE (CFM): 18.000 PRESSURE DROP (IN):  
RECIRCULATION RATE (GPM): 45 MAKE UP RATE (GPM): 4.5

ACTUAL DATA

VOLUME FLOW RATE (CFM): PRESSURE DROP (IN): N/E DATE: 6/3/87  
RECIRCULATION RATE (GPM): N/E MAKE UP RATE (GPM): N/E DATE: "

RECIRCULATION PUMP INFORMATION

MANUFACTURER : GENERAL ELECT. MODEL NUMBER : 5K33KN42  
SERIAL NUMBER: AYD/ HP : 1/3 RPM : 1725  
BRKR LOCATION: FED FROM MCC : #5

FAN INFORMATION

HARRIS ID # :  
MANUFACTURER : TRANE MODEL NUMBER: 81 TYPE AF  
SERIAL NUMBER: K3H244576 MATERIAL :  
DESCRIPTION : SIZE 44. CLASS I

DESIGN DATA

VOLUME FLOW RATE (CFM): STATIC PRESS (IN):

ACTUAL DATA

VOLUME FLOW RATE (CFM): SPEED (RPM): DATE:  
STATIC PRESS (IN): DATE:

FAN MOTOR INFORMATION

MANUFACTURER : US ELECTRICAL MODEL NUMBER :  
SERIAL NUMBER: HP : 30 RPM : 1760  
BRKR LOCATION: FED FROM MCC :



# Plastic Packed Scrubbers



## THE HARRISON SYSTEM

Harrison is a prime designer and producer of complete plastic exhaust systems, custom engineered scrubbing systems, as well as duct and fittings, tanks, and hoods. As a result of this capability and experience, design and manufacture of standard, pre-engineered fume scrubbers is a natural extension:

### MATERIALS

Self-supporting or fiberglass armored PVC and Polypropylene, fiberglass armored Kynar, and solid fiberglass construction offers a wide range of resistance to acids, alkalis, solvents, and other corrosives at operating temperatures to approximately 250°F. Harrison systems do not use any metal in contact with the process stream.

### PRE-ENGINEERING

Pre-engineered design reduces cost by eliminating the necessity to re-invent each item ordered. It results in more reliable service thru improved workmanship achieved by repetitive production control, and speeds quotations and approval drawings because costs and designs are immediately available. In addition to significant savings in approval and order time, Harrison reduces delivery time by stocking scrubber components including packing, support grids, distributor plates, nozzles, duct reducers, and sheet stock.

### SCRUBBER CONFIGURATION

Most fume removal applications can be served by the two scrubber designs shown in this catalog. Vertical Counter Current style directs liquid down vertically, and unwanted fumes upward in the opposite direction. Horizontal Cross Flow unit directs liquid down vertically, but unwanted fumes are driven horizontally at 90° to the liquid. In both designs, liquid and fumes are inter-mixed in the packed bed section of the scrubber where fumes are removed by chemical reaction or water solubility. Scrubber shape does not affect performance. Horizontal design presents a low profile and is suitable where head room is limited. Verticals require more head room, but use only minimum floor space.

### SCRUBBER DESIGN AND OPERATION

Highest scrubber efficiency (volumetric % of contaminate removed) is obtained by having the proper amount of contact surface area (packing) wetted by sufficient liquid (recirculated liquid rate) for an optimum residence time (packing depth) to allow unwanted fumes to take a treacherous path thru the wetted packing to permit their maximum removal from the carrier air stream by chemical reaction or water solubility.

Air stream resistance encountered in the packing (static pressure loss) is a function of air velocity, cross-sectional packing area, and packing depth. Harrison scrubbers utilize proven packing depth to achieve efficiencies approaching 99+%, when operated within recommendations.

### LIQUID DISTRIBUTION AND MIST ELIMINATION

Simple liquid distribution is achieved thru a main header pipe feeding perforated laterals, without use of troublesome spray nozzles. Nozzles are subject to plugging, and produce a difficult-to-remove atomized mist carryover. In the Harrison design, any large droplets of liquid caught in the upward moving air stream are easily and efficiently removed by a short bed of dry packing located above the liquid distributor.

### STATIC PRESSURE LOSS



Use of high-surface-area, low-pressure-drop plastic saddles in a balanced design result in low static pressure loss of only 0.4 inches H<sub>2</sub>O (w.g.) per foot of packed depth in Vertical Counter Current scrubbers, and 0.33 in Horizontal Cross Flow units. At the same time, sufficient irrigation rates constantly keep saddles clear of potential sludge buildup. Thereby, continuous, non-clogging operation at a proper rate of intermixing turbulence between liquid and fumes is achieved for 99+% efficiency.

### LIQUID SUMP OPERATION


Harrison scrubbers employ an integral liquid recirculating sump which reduces amount of liquid consumption required by 90 to 95% in most applications. Therefore, considerably less effluent must be handled and treated. The sump reservoir is contained within the scrubber itself. Harrison recommends optimum rate of effluent removal. When effluent is acidic only, additional liquid conservation can be obtained with either scrubber design with the simple optional recovery system shown with the vertical scrubber drawing on page 4. If central treating facilities exist, no sump, recirculation, or independent recovery is needed. In this case, treated liquid would be directed over the packing in a single pass, then treated, then returned to the scrubber, etc. In both instances where effluent is treated, liquid consumption would be reduced to only that amount lost by evaporation.

# Harrison


201 1st St. N. • Chicago, Illinois 60612 • Tel. (312) 344-1111



TOP VIEW



SIDE VIEW (CUT-A-WAY)



INLET SIDE VIEW

# HORIZONTAL CROSS-FLOW


Model	CFM	Inlet & Outlet A x B In.	Length L Ft.	Width W In.	C In.	D In.	E In.	F In.	G In.	Sump Capacity Gal.	Rec. Liquid GPM	Overall Height In.	Ship* Wt. Lbs.	Operating Wt. Lbs.
HF-8	800	11x11	6	17	¾	1	1	1¼	1	58	17	35	182	646
HF-12	1,200	14x14	6	20	¾	1	1	1¼	1	69	21	38	224	781
HF-17	1,700	18x18	6	24	¾	1	1	1½	1¼	82	24	42	275	926
HF-21	2,100	21x21	6	27	¾	1	1	1½	1¼	92	28	45	316	1028
HF-25	2,500	24x24	6	30	¾	1½	1½	1½	1¼	102	32	48	357	1166
HF-31	3,100	27x27	6	33	¾	1½	1½	1½	1¼	113	35	51	419	1313
HF-37	3,700	30x30	6	36	¾	1½	1½	1½	1¼	125	39	54	481	1445
HF-45	4,500	33x33	6	39	¾	1½	1½	1½	1¼	134	42	57	563	1669
HF-50	5,000	36x36	6	42	¾	1½	1½	1½	1¼	144	45	5.0 ft.	615	1733
HF-57	6,700	36x36	6	48	1	2	2	1½	1¼	165	51	5.5	690	1980
HF-85	8,500	42x42	6	54	1	2	2	2	1½	186	56	6.0	824	2276
HF-106	10,500	48x48	6	60	1	2	2	2	1½	206	60	6.5	1035	2639
HF-128	12,500	54x54	6	66	1	2	2	2	1½	227	64	7.0	1242	2890
HF-156	15,000	60x60	6	72	1	2	2	2½	2	247	68	7.5	1545	3459
HF-176	17,500	66x66	6	78	1	2	2	2½	2	268	72	8.0	1751	3893
HF-200	19,000	66x72	6	84	1	2	2	2½	2	288	76	8.5	1957	4327
HF-250	22,000	72x72	6	90	1	2	2	2½	2	308	80	9.0	2163	4761
HF-275	24,500	72x78	6	96	1	2	2	2½	2	328	84	9.5	2369	5195
HF-325	27,000	78x78	6	102	1	2	2	2½	2	348	88	10.0	2575	5629
HF-375	30,000	84x84	6	108	1	2	2	2½	2	368	92	10.5	2781	6063
HF-377	32,700	84x84	6	114	1	2	2	2½	2	388	96	11.0	2987	6497




MEET YOUR  
**POLLUTION  
 CONTROL  
 REQUIREMENTS**  
 WITH THE LEADER IN  
**PVC** FABRICATIONS




# *Duall*



CONTROLLED ENVIRONMENTS FOR INDUSTRY  
 P. O. BOX 10428 - 904/396-7733  
 JACKSONVILLE, FLORIDA 32247-0428  
 DANIEL J. KLOS



**PVC CONSTRUCTED**  
**FUME SCRUBBERS**  
**CENTRIFUGAL FANS**  
**DUCTING and HOODS**  
**OIL MIST COLLECTORS**  
**COMPLETE SYSTEMS**



*Duall*  
**INDUSTRIES, INC.**

700 S. McMillan Street • Owosso, Michigan 48866

# Duall


## Fume Scrubbers in 6 Types

### F-101 SERIES




Single Pack

Double Pack




### FW-300 SERIES



Single Pack

Double Pack




### PT-500 SERIES

Single Pack



Double Pack



Duall Single Pack (four Stage) Fume Scrubbers solve most industrial air pollution problems. They are especially effective on water soluble fumes and odors, or with pH control on many low soluble contaminants.

Some typical proven applications are:

- Acid fumes.
- Plating fumes.
- Cleaning fumes.
- Lab hood fumes.
- Anodizing fumes.
- Pickling fumes.
- Rust-proofing fumes.
- Die-casting fumes.
- Water soluble odors.

Duall Single Pack Fume Scrubbers incorporate these advantages:

- Low cost.
- Low maintenance.
- Low water consumption.
- Low static pressure drop.
- 100% corrosion resistant.

Duall Double Pack (six stage) Fume Scrubbers offer the broadest range of answers to industrial air pollution problems. By double scrubbing the air these scrubbers provide maximum efficiency on tough fumes and odors which can not be completely absorbed in a single pack type scrubber.

Duall's Double Pack Scrubbers have proven effective on the following typical applications:

- Bright dip fumes.
- Strip tank fumes.
- Etching fumes.
- Most low solubility fumes and odors.

Our Double Pack Fume Scrubbers offer all the advantages of the Single Pack units as well as the broadest range of applications.

All Duall Fume Scrubbers can be modified for custom installation with multiple packs or extended depth packs. Multiple modular units are available for capacities larger than standard.


*See page 6 for complete specs and performance data.*

# F-101 HORIZONTAL SINGLE FILTER PACK

Being our most popular scrubber design, this compact 100% corrosion resistant P.V.C. unit has proven its efficiency nationwide. The Dual F-101 incorporates high efficiency, low maintenance filter media and the open orifice type spray nozzles, for the assurance of a thoroughly saturated collection chamber. Our mist eliminator outlet section gives four air direction changes to properly remove the entrained moisture. Where a horizontal installation is preferred, the F-101 should be your choice.




CFM in 000's	DIMENSIONS IN INCHES										CFM in 000's	DIMENSIONS IN INCHES									
	A	B	C	D	E	H	I	Q	¢	A		B	C	D	E	H	I	Q	¢		
0.5	18	10	10	49	30	10	10	37	21	20	88	61	72	66	87	61	72	46	52 1/2		
1	22	14	14	50	34	14	14	38	23	22	97	61	81	66	87	61	81	46	52 1/2		
2	28	20	20	50	40	20	20	38	26	24	104	61	88	66	87	61	88	46	52 1/2		
3	32	24	24	51	44	24	24	39	28	26	112	61	96	66	87	61	96	46	52 1/2		
4	37	29	29	52	49	29	29	40	30 1/2	28	123	61	107	66	87	61	107	46	52 1/2		
5	41	33	33	52	53	33	33	40	32 1/2	30	135	61	119	66	87	61	119	46	52 1/2		
6	45	37	37	53	58	37	37	41	35 1/2	35	157	61	141	66	87	61	141	46	52 1/2		
8	52	44	44	54	65	44	44	42	39	40	179	61	163	66	87	61	163	46	52 1/2		
10	58	46	46	59	71	46	46	43	42	45	102	61	186	66	87	61	186	46	52 1/2		
12	64	52	52	60	77	52	52	44	45	50	224	61	208	66	87	61	208	46	52 1/2		
14	69	57	57	60	82	57	57	44	47 1/2	55	247	61	231	66	87	61	231	46	52 1/2		
16	74	62	62	61	87	62	62	45	50	60	269	61	253	66	87	61	253	46	52 1/2		
18	81	65	65	61	91	65	65	45	52 1/2	ø	Larger sizes on request.										







# F-101D HORIZONTAL DOUBLE FILTER PACK

An extra heavy duty scrubber for real "tuffies". It incorporates two filter packs with two sets of sprays for more thorough scrubbing... plus an effective mist eliminator at the air outlet. Serious concentrations of rough fumes, such as nitric, hydrofluoric, and hydrochloric acid are double scrubbed through six stages for maximum efficiency. Use this high efficiency fume scrubber, at only a small increase in price.



CFM in 000's	DIMENSIONS IN INCHES										CFM in 000's	DIMENSIONS IN INCHES									
	A	B	C	D	E	H	I	Q	¢	A		B	C	D	E	H	I	Q	¢		
0.5	18	10	10	70	30	10	10	58	21	20	88	61	72	87	91	61	72	67	52 1/2		
1	22	14	14	71	34	14	14	59	23	22	97	61	81	87	91	61	81	67	52 1/2		
2	28	20	20	71	40	20	20	59	26	24	104	61	88	87	91	61	88	67	52 1/2		
3	32	24	24	72	44	24	24	60	28	26	112	61	96	87	91	61	96	67	52 1/2		
4	37	29	29	73	49	29	29	61	30 1/2	28	123	61	107	87	91	61	107	67	52 1/2		
5	41	33	33	73	53	33	33	61	32 1/2	30	135	61	119	87	91	61	119	67	52 1/2		
6	45	37	37	74	58	37	37	62	35 1/2	35	157	61	141	87	91	61	141	67	52 1/2		
8	52	44	44	75	65	44	44	63	39	40	179	61	163	87	91	61	163	67	52 1/2		
10	58	46	46	80	71	46	46	64	42	45	202	61	186	87	91	61	186	67	52 1/2		
12	64	52	52	81	77	52	52	65	45	50	224	61	208	87	91	61	208	67	52 1/2		
14	69	57	57	81	82	57	57	65	47 1/2	55	247	61	231	87	91	61	231	67	52 1/2		
16	74	62	62	82	87	62	62	66	50	60	269	61	253	87	91	61	253	67	52 1/2		
18	81	65	65	82	91	65	65	66	52 1/2	ø	Larger sizes on request.										





# Duall

PVC Constructed, 100% Corrosion Free

## FUME SCRUBBERS

### FW-300 Vertical Pack with Blower

500 TO 12,000 C.F.M. . . plus multiple installations

This packed tower type scrubber is not only a space saver, it's also a true economy model. It incorporates a built-in rugged fan with convenient exterior, belt driven, TEFCBB motor. During installation, the horizontal air discharge can be swivelled 360° before sealing into permanent position. Efficiency is equal to the F-101 and the PT-500. Compactness and versatility make it an unusually popular model. This FW-300 saves three ways . . . in initial cost, installation, and in space. Also available with double pack.

### F-101 Horizontal Single Filter Pack

500 TO OVER 60,000 C.F.M. . . plus multiple installations

Being our most popular scrubber design, this compact 100% corrosion resistant P.V.C. unit has proven its efficiency in 46 states. The Duall F-101 incorporates high efficiency, low maintenance filter media and the open orifice type spray nozzles, for the assurance of a thoroughly saturated collection chamber. Our mist eliminator outlet section gives four air direction changes to properly remove the entrained moisture. Where a horizontal installation is preferred, the F-101 should be your choice.

### F-101-D Horizontal Double Filter Pack

500 TO OVER 60,000 C.F.M. . . plus multiple installations

An extra heavy duty scrubber for real "tuffies". It incorporates two filter packs with two sets of sprays for more thorough scrubbing . . . plus an effective mist eliminator at the air outlet. Serious concentrations of rough fumes, such as nitric, hydrofluoric, and hydrochloric acid are double scrubbed through six stages for maximum efficiency. For such problems in your plant, use this high efficiency fume scrubber, at only a small increase in price.

### PT-500 Vertical Pack

500 TO OVER 30,000 C.F.M. . . plus multiple installations

The upright PT-500 is the space saver. This scrubber is a vertical packed tower type designed to fit into restricted spaces where floor space is at a premium. Its efficiency is equal to the F-101, and also 100% corrosion-free. Air flow is up through a thoroughly water saturated bed of filter media. The mist eliminator pack near the top outlet assures properly dried air. If space is your problem, take a good look at the PT-500. Also available with double pack.



# Duall FUME SCRUBBERS

## SPECIFICATIONS and PERFORMANCE DATA

### DESCRIPTIONS

**F-101.** Horizontal (cross-flow), four stage, wet scrubber. This model has maximum efficiency on water soluble contaminants and odors, but is also effective on low soluble contaminants with the use of chemical neutralizers.

**F-101D.** Horizontal (cross-flow), six stage, wet scrubber. The F-101D is especially designed for use on stubborn low solubility contaminants or where extremely high scrubbing efficiency is required on normal contaminants.

**FW-300.** Vertical (counter-flow), four stage, wet scrubber with integral blower. Efficiency is equal to the F-101.

**FW-300D.** Vertical (counter-flow), six stage, wet scrubber with integral blower. Efficiency is equal to the F-101D.

**PT-500.** Vertical (counter-flow), four stage, wet scrubber. Efficiency is equal to the F-101.

**PT-500D.** Vertical (counter-flow), six stage, wet scrubber. Efficiency is equal to the F-101D.

All Duall Fume Scrubbers are constructed of P.V.C. and Polypropylene corrosion resistant materials and include a rugged coated steel base with lifting lugs. All above units are available with extended depth packing.

### SCRUBBING PRINCIPLES

Contaminant removal is accomplished by first slowing the fumes to a velocity below 500 fpm and then passing the fumes through two scrubbing stages in the single pack models and four stages in the double pack types. The fumes first pass through a water spray or curtain during which a percentage of the larger contaminant particles drop out and the remaining fumes are saturated. The second stage consists of a 12" deep pack of polypropylene high surface, non-clogging, spherical plate packing media\* which is continuously wetted by the spray nozzles. The saturated fumes are impinged upon the packing and the contaminants are absorbed and carried away in the wash water. The first and second stages are repeated in the double pack fume scrubbers.

\*Several types of alternate packing media are available on request.

### MIST ELIMINATION

After passing through the scrubbing sections, the air is moisture laden and must pass through a two stage gravity mist eliminator section. This final stage of P.V.C. eliminator blades provides four 30° changes in direction and eliminates entrained water.

### WATER SUPPLY

All Duall Fume Scrubbers may be supplied with water either directly from your supply or from an integral or remote recirculation system supplied with the scrubber. It is generally recommended that a recirculation system be used to conserve water except on very low cfm units. The actual fresh water consumption on the single pack series with recirculation is only 0.05 to 0.15 gpm/1000 cfm depending on the contaminant involved. On the double pack models, water consumption ranges from 0.1 to 0.3 gpm/1000 cfm. This represents 5% of the water being recirculated. Duall scrubbers are self-draining and may be installed out-doors in sub-zero conditions without freeze-up. If these conditions exist, a remote recirculation system should be specified for placement in a heated area.

All Duall Scrubbers come complete with fittings for the addition of chemical neutralizers, if required. A complete chemical metering and pumping system is available upon request.

### MATERIALS

Every Duall Fume Scrubber is shipped complete with an integral coated steel base. No special mounting is required. Simply connect the duct, the water and power supply, and the unit is ready for operation. Complete installation and operating instructions are supplied with all Duall Scrubbers.

### PRESSURE DROP

The following pressure drops are applicable for Scrubbers operated at design CFM:

F-101*	2.0" w.g.	FW-300D	3.0" w.g.
F-101D	3.0" w.g.	PT-500	2.0" w.g.
FW-300	2.0" w.g.	PT-500D	3.0" w.g.

On the FW-300 series, the blower is designed for 2.0" external

### FW-300 BLOWER SECTION

The top section of the FW-300 Fume Scrubber consists of a Duall P.V.C. centrifugal blower complete with motor and OSHA belt guard and shaft cover. The blower section may be rotated through 360° to obtain any desired angle between scrubber inlet and blower outlet. This blower section is same low maintenance, guaranteed corrosion resistant blower described in Duall Brochure No. CI-131, and NH-151.

### MAINTENANCE

All Duall Fume Scrubbers incorporate low maintenance components from front to back, including the packing, plumbing system and eliminators. Quick opening inspection doors are at all critical points.

**DUALL FUME SCRUBBERS**  
Typical Average Fume Removal Efficiencies

MODELS▶  CONTAMINATES ▼	Single Pack Series:	Double Pack Series:	Single Pack Series:	Double Pack Series:
	F-101 PT-500 FW-300	F-101D PT-500D FW-300D	with added Chemical Neutralizer (pH Control)	
Acetic Acid	95-98	98-99	—	—
Alkaline Cleaners	96-99	98-99	—	—
Aluminum Bright Dip*	80-85	85-90	—	—
Anodizing	96-99	98-99	—	—
Aqua Regia	80-85	85-90	85-90	90-95
Boric Acid	85-90	90-95	—	—
Caustic Cleaners	98-99	99	—	—
Caustic Soda	98-99	99	—	—
Chlorine	80-85	85-90	85-90	90-95
Chromic Acid	98-99	99	—	—
Copper Chloride	75-80	80-85	85-90	90-95
Cyanide Solutions	98-99	99	—	—
Ferric Chloride	80-85	83-88	—	—
Ferric Nitrate	96-98	98-99	—	—
Ferrous Chloride	90-95	95-98	—	—
Ferrous Sulfate	95-97	96-98	—	—
Fluosilicic Acid	95-98	98-99	—	—
Hydrochloric Acid	80-85	85-90	90-95	95-98
Hydrogen Cyanide	85-90	90-95	—	—
Hydrofluoric Acid	90-93	95-98	—	—
Hydrofluosilicic Acid	95-98	98-99	—	—
Hydrogen Peroxide	90-95	95-99	—	—
Hydrogen Sulfide	70-75	75-80	85-90	95-98
Nickel Chloride	80-85	85-90	90-95	95-98
Nickel Sulfate	80-85	85-90	90-95	95-98
Nitric Acid	75-80	85-90	—	—
Nitrogen Dioxide (NO <sub>2</sub> )	45-50	50-60	65-70	70-75
Nitric — HF Acid	75-80	85-90	—	—
Perchloric Acid	95-98	96-99	—	—
Phosphoric Acid	96-99	98-99	—	—
Potassium Dichromate	96-98	98-99	—	—
Selenium Sulfide	96-98	98-99	—	—
Sodium Chloride	96-98	98-99	—	—
Sodium Fluoride	90-95	95-98	—	—
Sodium Glutamate	96-98	98-99	—	—
Sodium Hydroxide	98-99	99	—	—
Sulfur Dioxide	70-75	75-80	80-85	85-90
Sulfuric Acid	36-98	98-99	—	—
Tin Chlorides	75-80	80-85	85-90	90-95
Zinc Chloride	75-80	80-85	—	—
Zinc Nitrate	96-98	98-99	—	—
Zinc Sulfate	96-98	98-99	—	—

\* These efficiencies are for the combined nitric and phosphoric fume. The efficiency for the NO<sub>2</sub> portion of the fume only will be as listed above.

● The above efficiencies are intended as guide representing

# TECHNICAL BULLETIN

*Duall  
Industries*

No. 121-9

## DUALL SCRUBBERS INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS

Date 3/1/80

Superseding Bulletin 4/24/79

Page 1

### 1. AIR FLOW

Units are normally designed to be on the suction side of the fan. Air flow through units must be in the direction indicated. Too large a deviation from the design flow (CFM) will affect the efficiency of the scrubber.

### 2. SUPPORTING THE UNIT

The scrubber rests on a steel channel base making the unit self-supporting. This steel base may be suspended from overhead structure or rest on any media suitable to support the unit's weight.

### 3. CONNECTION TO VENTILATION DUCT

To eliminate the possibility of water running down the duct, there should be a minimum of 4 ft. of horizontal duct before the scrubber transition. This should be sloped slightly towards the bottom of the scrubber. The flanges should be field drilled on approximately 4"-5" centers. A soft foam type chemically compatible gasket material is recommended between the scrubber flange and the duct flange.

### 4. ELECTRICAL CONNECTION

Proper electrical connection complying with local codes should be made to the pump motor.

### 5. UNITS WITH INTERNAL RECIRCULATION SYSTEM

Units should be installed in heated areas or protected from freezing. Fresh water must be supplied by connecting the supply line to the flowmeter provided. This flowmeter is mounted on the side of the scrubber. The make-up water line should be valved to provide a maximum of 5% of the recirculation rate as shown on the side of the scrubber. The scrubber drain is connected to customer's waste drain line. If this line must go to a sump, it must be submerged 6"-8" below the lowest expected level, or a plumber's "P" trap should be installed. This will prevent air from flowing into the drain line and interfering with proper drainage of the scrubber. Liquid build-up in the scrubber can interfere seriously with the proper operation of the scrubber.

BEFORE START-UP, INSPECT THE INSIDE OF THE SCRUBBER AND REMOVE ANY FOREIGN MATERIAL FROM THE UNIT. SHUT THE WASTE DRAIN VALVE AND FILL THE SCRUBBER BASE SUMP WITH WATER UNTIL WATER FLOWS FROM THE OVERFLOW DRAIN. WATER IS INTRODUCED THRU THE FLOWMETER AND CAN ALSO BE INTRODUCED BY A HOSE PLACED THRU THE INSPECTION DOORS. When the water reaches the overflow level, the pump and fan may be started.

6. UNITS DESIGNED WITH REMOTE RECIRCULATION TANK AND PUMP

All units designed for remote recirculation require a separate recirculation tank with an adequately sized overflow and waste drain. The use of the remote recirculation tank will permit the installation of self-draining scrubber outside the building and the recirculation tank inside the building. The scrubber must be elevated for proper drain return to the recirculation tank. The scrubber drain pipe must be submerged 6" to 8" below the lowest expected liquid level in the tank and on the opposite side from the pump suction. The pipe end should be cut on a 60° angle with the long opening facing the tank side. For information on start-up and make-up water, please refer to Section 5 above. Make-up water may be introduced into the recirculation tank through the separate flowmeter provided for installation into water line.

7. PUMPS

Pumps should be operated in accordance with the enclosed manufacturer's instructions. Pumps with mechanical seals should be given particularly special attention to assure operation as directed. Pump motor should be electrically bumped to check for proper rotation. Motors and pumps are aligned and checked for proper operation before shipment. Customer is cautioned that misalignment may occur during shipment. Check for misalignment by manually rotating the shaft while observing coupling alignment using a straight edge or a dial indicator. Pumps provided with a packing gland are pre-adjusted to drip approximately 30 drops per minute. Drain fittings are provided on the pump or on a collection pan which should be plumbed to the waste drain. Pump motor should be interlocked with fan to provide approximately two (2) minutes pump operation before fan may be started. Pumps should not be started until the scrubber base or remote recirculation tank are filled to the overflow level. During the early break-in period, the pump packing gland should be checked for proper weeping. If incorrect, check pump manufacturer's instructions for correction procedure.

8. CHEMICAL ADDITIONS

In some cases, liquid caustic (sodium hydroxide solution) or an acid solution may be metered into the recirculation system to increase scrubber efficiency. A threaded coupling is provided in the side of the self-contained recirculation scrubbers for introduction of this chemical addition. Chemical addition for scrubbers provided with remote recirculation tanks is made by adding the solution to the recirculation tank. When using solid caustic, care should be taken in mixing to assure that no solid material is pumped into the scrubber or recirculation tank which may cause a build-up. The pH of the recirculation tank should be maintained in a range that will achieve the desired scrubber efficiency while preventing the appearance of a build-up on the packing. A pH control package may be purchased from Duall to provide a chemical feed pump and pH control to maintain the recirculation solution in the satisfactory range.

# TECHNICAL BULLETIN

*Duall  
Industries*

No. 121-9

## DUALL SCRUBBERS INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS

Date 3/1/80

Superseding Bulletin 4/24/79

Page 3




### 9. PERIODIC MAINTENANCE SCHEDULE

Inspection doors are provided in all scrubber units for periodic inspection. While it is not expected that maintenance will be required, periodic inspection on a monthly basis is suggested. This inspection should include the following:

- A. Check spray nozzles with the pump and fan in operation. All nozzles should produce a full 360° spray pattern. If any nozzles are found to be spraying incorrectly, the pump should be stopped, the header pipe removed, and each nozzle cleaned individually. When the cleaned header system has been replaced, the pump may be re-started.
- B. Check the face of the scrubber and the spray nozzles for any indication of a build-up of solids. If a surface build-up has occurred, it may be removed by spraying the pack with high pressure water, by chemical treatment of the scrubbing solution to dissolve the scale, or by manually removing the surface build-up. An analysis of the material build-up can be made to determine its nature. A dissolving additive, compatible with P.V.C. then could be added to the recycling reservoir for closed loop cleaning. During this type of cleaning, the drain and make-up water valves should be closed. During this operation, someone should frequently check the operation of the nozzles, and solution level to prevent pump damage. Prior to putting the system back in service, the cleaning solution should be drained and the scrubber refilled with fresh water. Steam should not be used to clean the scrubber.
- C. Check the water level in the scrubber. While the scrubber is in operation, it should maintain a solution of approximately 3"-6" in the bottom of the scrubber on a remote recirculation system and to the overflow on others.

CFM	0.5	1	2	3	4	5	6	8	10	12	14	16	18	20	22	24	26	28	30	35	40	45	50	55	60
A	18	22	28	32	37	41	45	52	58	64	69	74	81	88	97	104	112	121	135	157	179	202	224	247	269
B	10	14	20	24	29	33	37	44	46	52	57	62	65	71	77	81	87	91	97	107	119	141	163	186	208
C	10	14	20	24	29	33	37	44	46	52	57	62	65	71	77	81	87	91	97	107	119	141	163	186	208
D	49	50	50	51	52	52	53	54	59	60	60	61	61	66	66	66	66	66	66	66	66	66	66	66	66
E	30	34	40	44	49	53	58	65	71	77	82	87	91	91	91	91	91	91	91	91	91	91	91	91	91
F	3 1/2	1 1/2	3 1/2	3 1/2	3 1/2	3 1/2	4 1/2	4 1/2	4 1/2	4 1/2	4 1/2	4 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2
G	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
H	2	2	2	2	2	2	3	3	3	3	3	3	4	4	4	4	4	4	4	4	4	4	4	4	4
I	37	39	39	39	40	40	41	42	43	44	44	45	45	46	46	46	46	46	46	46	46	46	46	46	46
J	31	35	41	45	50	54	58	65	71	77	82	87	94	101	110	117	125	136	148	170	192	215	237	260	
K	21	23	26	28	30 1/2	32 1/2	35 1/2	39	42	45	47 1/2	50	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2
OVERFLOW	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2
PUMP SUCTION	1	1	1	1	1	1	1	1 1/8	1 1/8	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
PUMP DISCHARGE	3/4	1/4	3/4	3/4	3/4	3/4	1	1	1	1 1/8	1 1/8	1 1/4	1 1/2	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2
LIQUID RECIRCULATION RATE GPM	15	3	6	9	12	15	18	24	30	36	42	48	54	60	66	72	78	84	90	105	120	135	150	165	180

NOTE CFM IN THOUSANDS



**F-101 FUME SCRUBBER**  
WITH SELF CONTAINED RECIRCULATION

DUAL INDUSTRIES, INC OWOSSO, MI

DATE: \_\_\_\_\_ DUAL JOB NO: \_\_\_\_\_

PURCHASER: \_\_\_\_\_

PURCHASER PO NO: \_\_\_\_\_

PURCHASER LOCATION: \_\_\_\_\_

JOB NAME: \_\_\_\_\_

JOB LOCATION: \_\_\_\_\_

SPECIFICATION NO: \_\_\_\_\_ ITEM NO: \_\_\_\_\_

CAPACITY \_\_\_\_\_ CFM

PRESSURE DROP \_\_\_\_\_ WG

LIQUID RECIRCULATION RATE \_\_\_\_\_ GPM

LIQUID PRESSURE \_\_\_\_\_ TDH

MAKEUP RATE \_\_\_\_\_ GPM

RECIRCULATION PUMP \_\_\_\_\_

PUMP CAPACITY \_\_\_\_\_ GPM TDH

PUMP HP \_\_\_\_\_

PUMP VOLTAGE \_\_\_\_\_ V PH NE

TAG:

D-101-1016

**F-101 FUME SCRUBBER**  
WITH SELF CONTAINED RECIRCULATION

SCALE	QUANTITY	DATE	ISSUED BY	REVISION

CFM	0.5	1	2	3	4	5	6	8	10	12	14	16	18	20	22	24	26	28	30	35	40	45	50	55	60
A	18	22	28	32	37	41	45	52	58	64	69	74	81	88	97	104	112	123	135	147	179	202	224	247	269
B/D	10	14	20	24	29	33	37	44	48	52	57	62	65	61	61	61	61	61	61	61	61	61	61	61	61
C/D	10	14	20	24	29	33	37	44	48	52	57	62	65	72	81	90	98	107	119	141	163	186	208	231	253
D	49	50	50	51	52	52	51	54	50	60	60	61	61	64	64	64	64	64	64	66	64	64	66	66	66
E	30	34	40	44	49	51	56	65	71	77	82	87	91	91	91	91	91	91	91	91	91	91	91	91	91
F	3 1/2	3 1/2	3 1/2	3 1/2	3 1/2	3 1/2	4 1/2	4 1/2	4 1/2	4 1/2	4 1/2	4 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2	5 1/2
G	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
H	2	2	2	2	2	2	3	3	3	3	3	3	4	4	4	4	4	4	4	4	4	4	4	4	4
I	37	38	38	39	40	40	41	42	43	44	44	45	45	46	46	46	46	46	46	46	46	46	46	46	46
J	18	22	28	32	37	41	45	52	58	64	69	74	81	88	97	104	112	123	135	147	179	202	224	247	269
U/DIA	15 1/2	19 1/2	22 1/2	22 1/2	22 1/2	22 1/2	30	30	30	30	30	30	30	30	30	30	34	34	36	36	36	36	36	36	36
V	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42
W	21	23	28	28	30 1/2	32 1/2	35 1/2	39	42	45	47 1/2	50	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2	52 1/2
OVERFLOW DRAIN PUMP SUCTION	1 1/2	1 1/2	1 1/2	2	2	2	2	2	3	3	3	3	3	3	3	4	4	4	4	4	4	4	4	4	4
PUMP DISCHARGE LIQUID RATE GPM	15	3	8	9	12	15	18	24	30	36	42	48	54	60	66	72	78	84	90	108	120	135	150	165	180


NOTE: CFM IN THOUSANDS

D-101-1017



FIOI FUME SCRUBBER				ITEM NO.
WITH REMOTE RECIRCULATION				REV.
SCALE	ORIENT	DATE	BY	DATE
DUALL INDUSTRIES Inc. OWOSSO, MI.				REV. NO.

F-101 FUME SCRUBBER	
WITH REMOTE RECIRCULATION	
DUALL INDUSTRIES, INC. OWOSSO, MI.	
DATE	DUALL JOB NO.
PURCHASER	
PURCHASER PO NO.	
PURCHASER LOCATION	
JOB NAME	
JOB LOCATION	
SPECIFICATION NO.	ITEM NO.
CAPACITY	CFM
PRESSURE DROP	IN. WG
LIQUID RECIRCULATION RATE	GPM
LIQUID PRESSURE	PSI
MAKEUP RATE	GPM
RECIRCULATION PUMP	
PUMP CAPACITY	GPM
PUMP HP	PSI
PUMP VOLTAGE	V PHASE


TAG:




SPRAY LINE CONNECTS TO PUMP DISCHARGE




CHANNEL STEEL BASE EPOXY COATED AS SHOWN PROVIDED WITH SCRUBBER






DUALL F-101 FUME SCRUBBER PARTS LIST	
NO:	PART
100	EPOXY COATED STEEL BASE
101	CORROSION RESISTANT PUMP
102	TEFCBB MOTOR _____V/ PH./ _____CY. _____H.P. _____R.P.M.
103	PUMP SUCTION COUPLING (P.V.C.)
104	OVERFLOW COUPLING (P.V.C.)
105	DRAIN VALVE (P.V.C.)
106	PUMP DISCHARGE LINE (P.V.C.)
107	FLANGE (P.V.C.)
108	CLEAR OR P.V.C. CLEANOUT DOORS
109	FLOW METER _____
110	ELIMINATOR SECTION (P.V.C.)
111	POLYPROPYLENE PACKING
113	SPRAY HEADER VALVE (P.V.C.)
114	SPRAY HEADER (P.V.C.)
115	SPRAY NOZZLES

PARTS LIST FOR REMOTE RECIRCULATION TANK	
116	OVERFLOW (P.V.C.)
117	REMOTE TANK (P.V.C.)
118	DRAIN (P.V.C.)
119	PUMP SUCTION COUPLING (P.V.C.)




# The Tri-Mer Fume Washer





# Design Features of the Tri-Mer Fume Washer

TRI-MER fume washers offer an efficient economically packaged solution to your corrosive fume problems. Couple this unit to a TRI-MER all PVC fan, or use your existing fan, and you're ready for operation. A simple inexpensive installation.



Flanged inlet and outlet make transition installation quick and trouble free.

Counterflow spray nozzles prewet fumes.

The packaged F/W unit is entirely constructed of corrosion proof PVC with polypropylene filter and mist eliminator packs.

An overflow weir keeps the polypropylene filter pack flooded with water.

Downstream mist eliminator packs pull excess moisture from the air stream.

All F/W units come with self supporting frames.

Units through Model F/W-9 are available with integral recirculation tank and pump as shown.


NOTE: Models F/W-10 through F/W-16 require

F/W with integral recirculation tank. F W v il interal recirculation tank


F/W	A	B	C	D	E	F	G	H	J	K	L	M	R	CHANNEL	ANGLE	DRAIN	G P M	HEADERS	PIPE	CFM CAPACITY			
1	3'-11 1/2"	4'-4 1/2"	3'-6"	4'-3"	5'-3"	3'-4"	3'-4"	4'-10"	6"	6"	28"	28"	1'-8"	2'-0 1/4"	3'-0 1/4"	8"	4"@5.4#	1 1/2"x1 1/2"x3/16"	3"	8	2	3/4"	3,000 to 5,500
2	4'-3 1/2"	4'-8 1/2"	3'-10"	4'-6 1/4"	5'-6 1/4"	3'-8"	3'-4"	5'-2"	4 1/2"	4 1/2"	35"	35"	1'-10"	2'-2 1/4"	3'-2 1/4"	8"	4"@5.4#	1 1/2"x1 1/2"x3/16"	3"	9	2	3/4"	5,500 to 7,000
3	5'-0 1/2"	5'-5 1/2"	3'-8"	5'-3 3/4"	6'-3 3/4"	4'-6"	4'-6"	4'-10"	8"	8"	32"	32"	2'-4 1/2"	2'-7 1/2"	3'-7 1/2"	8"	4"@5.4#	1 1/2"x1 1/2"x3/16"	3"	12	2	3/4"	7,000 to 9,500
4	5'-6"	5'-11"	4'-0"	5'-8 1/4"	6'-8 1/4"	4'-10"	4'-10"	5'-6"	6 1/2"	6 1/2"	45"	45"	2'-5"	2'-9 1/4"	3'-9 1/4"	9"	4"@5.4#	2"x2"x1/4"	3"	14	2	3/4"	9,500 to 11,600
5	6'-0"	6'-5"	3'-8 1/2"	6'-2 1/4"	7'-2 1/4"	5'-4"	5'-4"	5'-2 1/2"	9 1/2"	9 1/2"	45"	45"	2'-8"	3'-0 1/4"	4'-0 1/4"	9"	4"@5.4#	2"x2"x1/4"	3"	16	2	3/4"	11,500 to 14,000
6	6'-8"	7'-1"	4'-1 1/2"	6'-10 1/4"	7'-10 1/4"	6'-0"	6'-0"	6'-1 1/2"	11"	11"	50"	50"	3'-0"	3'-4 1/4"	4'-4 1/4"	1'-0"	4"@5.4#	2"x2"x1/4"	3"	19	2	3/4"	14,000 to 17,000
7	6'-11"	7'-5"	3'-10 1/4"	7'-3"	8'-3"	6'-4"	6'-4"	5'-10 1/4"	11"	11"	54"	54"	3'-2"	3'-6 1/4"	4'-6 1/4"	1'-0"	4"@5.4#	2"x2"x1/4"	3"	22	2	3/4"	17,000 to 20,000
8	7'-8"	8'-1"	4'-3"	7'-10 1/4"	8'-10 1/4"	7'-0"	7'-0"	6'-3"	1'-0 1/2"	1'-0 1/2"	59"	59"	3'-6"	3'-9 1/4"	3'-9 1/4"	1'-0"	4"@5.4#	2"x2"x1/4"	3"	28	2	3/4"	20,000 to 24,000
9	8'-5"	9'-0"	4'-0 1/4"	8'-8"	9'-8"	7'-9"	7'-9"	6'-0 1/4"	1'-1 1/2"	1'-1 1/2"	66"	66"	3'-10 1/2"	4'-2 1/4"	5'-2 1/4"	1'-0"	4"@5.4#	2"x2"x1/4"	3"	34	3	3/4"	24,000 to 30,000
10	9'-7"	4'-5"	9'-11 1/4"	8'-11"	8'-11"	6'-5"	1'-3 1/2"	1'-3 1/2"	76"	76"	4'-5 1/2"	5'-0 1/4"	1'-0"	6"@8.2#	2"x2"x1/4"	3"	44	3	1"	30,000 to 40,000			
11	12'-1"	4'-2 1/2"	9'-9 1/4"	8'-9"	11'-5"	6'-2 1/2"	10"	2'-2"	85"	85"	5'-8"	4'-11 1/4"	1'-0"	6"@8.2#	2"x2"x1/4"	3"	56	3	1"	40,000 to 50,000			
12	14'-5"	4'-5 1/2"	9'-9 1/4"	8'-9"	13'-9"	8'-5 1/2"	10"	2'-7 1/2"	85"	102"	6'-10 1/2"	4'-11 1/4"	2'-0"	6"@8.2#	2"x2"x1/4"	3"	66	3	1"	50,000 to 60,000			
14	17'-9"	4'-5 1/2"	9'-9 1/4"	8'-9"	17'-1"	8'-5 1/2"	10"	3'-2 1/2"	85"	128"	8'-5 1/2"	4'-11 1/4"	2'-0"	6"@8.2#	2"x2"x1/4"	3"	81	3	1"	60,000 to 75,000			
15	20'-8"	4'-2 1/2"	9'-9 1/4"	8'-9"	19'-10"	8'-2 1/2"	10"	3'-9 1/2"	85"	147"	9'-11"	4'-11 1/4"	2'-0"	6"@8.2#	2"x2"x1/4"	3"	93	3	1 1/2"	75,000 to 87,000			
16	20'-8"	4'-7"	11'-0 1/4"	10'-0"	20'-0"	8'-7"	1'-5 1/2"	3'-0"	85"	240"	10'-0"	5'-6 1/4"	2'-0"	6"@8.2#	2"x2"x1/4"	3"	106	3	1 1/2"	87,000 to 100,000			

\* NOTE — For exact unit weight check with manufacturers.

\* NOTE — Double pack models are available where particularly heavy loadings exist. Check with manufacturer for dimensional changes.




Typical three view drawing of units with integral recirculation tanks.




# Other TRI-MER PVC Equipment


As long time specialists in designing corrosive fume control systems, TRI-MER offers a complete line of PVC air movers and associated equipment. This includes the patented fan/separator (fume scrubber), fume washers (crossflow scrubbers), PVC centrifugal fans, an *all PVC* stack fan, as well as PVC hoods and duct. Special fabrications such as consoles, tanks, and small plating lines are available.



Fan/Separator




Fume/Washer (Crossflow Scrubber)




PVC Centrifugal Fan



PVC Stack Fan (Cutaway View)



PVC Hoods & Duct



Special Fabrications



**Tri-Mer Corporation**

Factory and Main Offices  
1400 Monroe, Owosso, Michigan 48867  
Phone (517) 723-7838 Telex 228545




**Tri-Mer Corporation**

California Sales Offices  
P.O. Box 1152, Costa Mesa, California 92626  
Phone: (714) 548-5853

**K** EUROPEAN REPRESENTATIVE  
**JAEGER K. G.**  
D. BRAUNSCHWEIG, WEST GERMANY


**ATTACHMENT E.**  
**LOCATION MAPS**



HARRIS SEMICONDUCTOR  
SCRUBBER LOCATIONS  
BUILDING 51

LEGEND

	- Horizontal Scrubber
	- Vertical Scrubber
	- Exhaust Stack
	- Exhaust Fan
	- Stack mounted on fan
	- Epitaxial Scrubber



APOLLO BLVD

# Harris Semiconductor Complex

## SCRUBBER LOCATIONS

POND

F62S02  
F62S01

62B 62A

PARKING LOT  
F58S02  
F58S01

PARKING LOT

59

PARKING LOT

F57S01

58

POND

PALM BAY BLVD

F04S05  
F04S06  
F04S01

F59S01  
F59S03

63

F63S02  
F63S01  
F63S03

F54S03  
F54S04  
F54S01  
F54S02  
F60S01  
F55S01

54

PARKING LOT

60

56

53

PARKING LOT

6

BORROW PIT

55

52

51

LN2

51

51

TROUTMAN

F51S01  
F51S02  
F51S03  
F51S04  
F51S05

F04S08  
F04S04  
F04S03  
F04S02

F61S02  
F61S01

61

PARKING LOT

N

LIPSCOMB ST

