

Lawton Chiles
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

December 17, 1998

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Richard L. Wolfinger, Vice President
Oleander Power Project, L.P.
250 West Pratt Street, 23rd floor
Baltimore, MD 21201

Re: Request for Additional Information
DEP File No. 0090180-001-AC (PSD-FL-258)
Oleander Power Project - Five 190 MW Combustion Turbines

Dear Mr. Wolfinger:

On November 24 the Department has received your application and complete fee for an air construction/operation permit for five 190-MW dual fuel, proposed 'F' class combustion turbines for the Oleander Power Project in Brevard County. The application is incomplete. In order to continue processing your application, the Department will need the additional information below. Should your response to any of the below items require new calculations, please submit the new calculations, assumptions, reference material and appropriate revised pages of the application form.

1. Please provide a detailed cost analysis in terms of overall and marginal cost effectiveness (annualized dollars/ton of nitrogen oxides removed) for the following distillate fuel oil use scenarios. This does not constitute any intent regarding a Best Available Control Technology (BACT) determination. It is for cost sensitivity purposes.

| Hours of Distillate Fuel Oil Used | NO _x , ppmvd @ 15% O ₂ |
|-----------------------------------|--|
| First 500 | 42 |
| Second 500 | 36 |
| Third 500 | 30 |
| Fourth 500, 2000 total | 24 |

2. Please provide the rationale for the 16 ppmvd @ 15% O₂ limit proposed for CO as BACT. The combustors capable of meeting 9 ppm NO_x typically achieve 12 ppm of CO.
3. Please describe the adequacy of the 60 foot stack height with respect to both plume rise/bouyancy and possibilities of localized downwash.
4. Please submit overlays (isopleths) of the maximum ground-level concentrations of NO_x, PM/PM₁₀, CO, and SO₂ with respect to residential communities up to 2 miles (3.2 kilometers) from the proposed site.
5. Please provide a detailed map showing the location of all of the fence-line receptors used in the air quality impact analysis. These receptor locations should be shown in UTM coordinates since the UTM coordinate system is used in the modeling. In addition send us diskettes containing all of the air quality impact analysis modeling output files.
6. How will fuel oil be delivered to the site, e.g. pipeline or trucks?

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

7. At the rated of 100,000 pounds per hour per turbine, the amount of fuel oil used in one day for the entire facility is 1.5 million gallons. The two 2.8 million gallon storage tanks can store only four days-worth of fuel oil. Please comment on the practicality of actually operating 2000 hours per year on fuel oil given this apparent limitation.
8. The emission limits proposed do comport with recent Department Best Available Control Technology (BACT) determinations for natural gas firing with fuel oil back-up. However the Department's BACT determinations include minimization of fuel oil-firing and maximization of natural gas use.
9. Please re-examine the use of natural gas versus fuel oil and the cost-effectiveness of NO_x emission control strategies from the stand-point of average expected revenues and profitability per MW-hr versus pollution control costs per MW-hr. The approach towards cost-effectiveness of pollution control in peaking operation mode should parallel the economics of a project that presumably maximizes revenues and profitability under peaking mode. Because the project otherwise comports with very recent and draft BACT Department determinations (especially for peaking units), this analysis is not required if Oleander can agree to minimize its operation in the fuel oil use mode.
10. Please provide the emission characteristics of the Siemens, Westinghouse, General Electric and ABB combustion turbines under consideration for this project. Include any information regarding their ability to meet 9 ppm NO_x by Dry Low NO_x (DLN) technology or high temperature selective catalytic reduction. If a vendor has been identified and the information is available, it will not be necessary to provide the information regarding other suppliers.
11. Provide the worst case start-up and shutdown emissions characteristics for the units under consideration including start-up curves and duration of excess emissions. The Department plans to address excess emissions in its BACT determination.

We received a request to conduct a public meeting. We will advise you of the schedule. It will partially depend on the status of the Department's review of this application.

Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. Please note that per Rule 62-4.055(1): *"The applicant shall have ninety days after the Department mails a timely request for additional information to submit that information to the Department..... Failure of an applicant to provide the timely requested information by the applicable date shall result in denial of the application."*

If you have any questions, please call Susan DeVore-Fillmore at 850/921-9537 or Mike Halpin at 850/921-9530 (engineers). Matters regarding review of the modeling should be directed to Cleve Holladay (meteorologist) at 850/921-8986.


Sincerely,



A.A. Linero, P.E. Administrator
New Source Review Section

AAL/sdf

cc: Gregg Worley, EPA
Mr. John Bunyak, NPS
Len Koslov, DEP CD
Ken Kosky, P.E., Golder Associates



Lawton Chiles
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

December 22, 1998

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Richard L. Wolfinger, Vice President
Oleander Power Project, L.P.
250 West Pratt Street, 23rd floor
Baltimore, MD 21201

Re: Request for Additional Information No. 2
DEP File No. 0090180-001-AC (PSD-FL-258)
Oleander Power Project - Five 190 MW Combustion Turbines

Dear Mr. Wolfinger:

Further to our letter dated December 17, 1998 and in an effort by the Department to gain reasonable assurance as to how the proposed power plant will operate, additional information is requested. Should your response to any of the below items require new calculations, please submit the new calculations, assumptions, reference material and appropriate revised pages of the application form.

1. What commitment has been received from FGT concerning their ability to supply OPP's gas consumption requirements? Please provide documentation from FGT specifying that:
 - FGT is capable of accommodating OPP's gas supply needs. [Based upon application, the requirements appear to be 1.81 mmcf/hr per machine or 9.05 mmcf/hr for all 5 machines]
 - What quantity of the 9 mmcf/hr gas is to be contracted as readily available or "firm."
 - What quantity of the 9 mmcf/hr gas is to be considered as occasionally available or "interruptible".
2. For "interruptible" supplies, please provide FGT's probability estimates for gas availability during peak power periods in quantities up to 9 mmcf/hr.
3. What commitments have been received concerning water supplies? Please provide documentation from local water suppliers (e.g. the City of Cocoa) or appropriate permitting agencies that:
 - OPP's water supply needs for NO_x control (water injection during oil firing) can be met [based upon application, the requirements appear to be at least 120,900 lb/hr per machine or 362,000 gallons/hr for all 5 machines]

- Annual water consumption for NO_x control of 724 million gallons per year can be met [assumes 2000 hours per year oil operation on all 5 turbines].
4. Describe the impacts of the fuel oil delivery. Based upon the application, trucking of the fuel oil is contemplated. At 2000 hours per year of oil operation on all 5 turbines, an annual oil consumption of approximately 146 million gallons may be consumed, or approximately 20,000 truckloads.

Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. Please note that per Rule 62-4.055(1): *"The applicant shall have ninety days after the Department mails a timely request for additional information to submit that information to the Department..... Failure of an applicant to provide the timely requested information by the applicable date shall result in denial of the application."*

If you have any questions, please call Mike Halpin (permit engineer) at 850/921-9530.

Sincerely,



A.A. Linero, P.E. Administrator
New Source Review Section

cc: Gregg Worley, EPA
John Bunyak, NPS
Len Koslov, DEP CD
Ken Kosky, P.E., Golder Associates

Golder Associates Fax

To: MIKE HALPIN

Fax Number: 850-922-6979

Company:

Date: 3/17/99

From: BOB McCANN

e-mail: @golder.com

Our ref: 9839514-0300

Voice Mail:

RE:

Total pages (including cover): 40 Hard copy to follow

MESSAGE

SEE ATTACHED FAX.

CALL IF YOU HAVE ANY QUESTIONS.

Response



Golder Associates

6241 NW 23rd St., Suite 500
Gainesville, FL 32653
U.S.A.
Telephone: (352) 336-5600
Fax: (352) 336-6603

**Comprehensive Consulting
Services in Geotechnical
Engineering, Environmental
Remediation and Waste
Management**

Environmental Remediation

Waste Management

Air Resources

Water Resources

Landfill Siting & Design

Geophysics

Civil Engineering & Construction

Mining & Quarrying

Oil and Gas Waste Management

Soil and Rock Mechanics

Nuclear Waste Management

Risk Assessment

Energy Projects

Transportation

Offices in Australia, Canada,
Finland, Germany, Hong Kong,
Hungary, Indonesia, Italy, South
America, Sweden,
United Kingdom, United States

The document(s) included with this transmission are only for the recipient named above and contain privileged/confidential information. Unauthorized disclosure, dissemination, or copying of this transmission is strictly prohibited. If received in error, please destroy. Questions or problems with this transmission should be referred to the receptionist at the number provided above.

Golder Associates Inc.

6241 NW 23rd Street, Suite 600
Gainesville, FL 32653-1500
Telephone (352) 336-5600
Fax (352) 336-6603



March 17, 1999

9839514Y/F1/WP/3

New Source Review Section
Bureau of Air Regulation
Florida Department of Environmental Protection
111 S. Magnolia Drive, Suite 4
Tallahassee, FL 32301

Attention: Mr. A. A. Linero, P.E., Administrator

RE: Oleander Power Project
PSD-FL-258

Dear Al:

As a follow-up to my letter dated February 25, 1999 regarding Oleander's decision to limit oil used to an equivalent 1,000 hours/year/CT at full load, I am enclosing sections of the application form and changes in the appended material that reflect this commitment. In addition, the updated forms and information reflect data representative of the General Electric (GE) Frame 7FA combustion turbine as the primary vendor, which I indicated in my February 1, 1999 letter. The changes specific to the GE machine reflect a decrease in the emission rate of particulate matter (PM) for distillate fuel oil-firing, and a decrease in the emission rates for carbon monoxide (CO) and volatile organic compounds (VOCs) for both actual gas- and oil-firing. Taken together, the total reduction in pollutant emissions is about 30 percent lower than the previous information submitted. The reduction by pollutant is: PM - 53%, sulfur dioxide (SO₂) - 29%, nitrogen oxides (NO_x) - 22%, CO - 41.4% and VOC - 32.6%.

Over the last several months, the applicant has recognized the concern by the Department and the general public over the higher emission rates when firing distillate fuel oil relative to natural gas. Both the reduction in hours of firing oil and the lower emission rates with the GE machine substantially reduce emissions, a desired goal.

We have also reviewed the relationships of the ambient ozone concentrations for the various monitoring sites in the Central Florida region. For 1998, the data appear to follow a similar temporal trend among the monitoring stations located in Orange County, Brevard County, and St. Lucie County. This suggests a regional relationship in ozone concentrations. Because ozone is currently monitored at two locations in Brevard County, additional monitoring in the vicinity of the Oleander site that was suggested at the March 4, 1999 public meeting would be unwarranted. In addition, the maximum VOC emissions from the project is proposed as 64 tons/year which is well below the Prevention of Significant Deterioration (PSD) *de minimis* monitoring criteria of 100 tons/year for VOCs.

FDEF
A.A. Linero

- 2 -


March 17, 1999
9839514Y/F1/WP/3

These emission reductions coupled with our previous air quality impacts analyses clearly indicate that the project will fully comply with EPA's and the Department's ambient air quality standards. Indeed, the impacts are many times lower than the Department's significant impact levels for both natural gas- and distillate oil-firing. The air quality modeling was also performed assuming that either natural gas or oil would be used at all times over the 5 years of meteorological data used in the model. This produces very conservative estimates of impacts given that the facility is a peaking plant and will not operate over all hours in any year.

Oleander appreciates this opportunity to provide the Department with this additional information. Please call or contact me via e-mail if you have questions or would like to discuss this further.

Sincerely,

GOLDER ASSOCIATES INC.



Kennard F. Kosky, P.E.
Project Engineer

KFK/arz

cc: R. Wolfinger, Oleander Power Project
R.A. Zwolak, GAI

G:\DATA\DP\PROJECTS\98\9839\9839514Y\F1\WP\#03-1.TR.doc

100-100000000
100-100000000

ATTACHMENT (March 17, 1999 Letter)

PSD APPLICATION REPLACEMENT PAGES, TEXT, AND TABLES

100-100000000
100-100000000

100-100000000
100-100000000

4. Professional Engineer's Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

Signature
(seal)

Date

* Attach any exception to certification statement.

4. Professional Engineer's Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

Harold J. Hoday
Signature
(seal) *[initials]*

March 16, 1999
Date

* Attach any exception to certification statement.

Emissions Unit Information Section 1 of 6

Combustion Turbine 1

F. SEGMENT (PROCESS/FUEL) INFORMATION
 (Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 2

| | |
|---|---------------------------------------|
| 1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Distillate (No. 2) Fuel Oil | |
| 2. Source Classification Code (SCC): 20100101 | |
| 3. SCC Units: 1,000 gallons used | |
| 4. Maximum Hourly Rate: 14.6 | 5. Maximum Annual Rate: 14,563 |
| 6. Estimated Annual Activity Factor: | |
| 7. Maximum Percent Sulfur: 0.05 | 8. Maximum Percent Ash: |
| 9. Million Btu per SCC Unit: 132 | |
| 10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 131.8 (rounded to 132). Based on 7.1 lb/gal; LHV of 18,660 Btu/lb, - ISO conditions, 1,000 hrs/yr operation. | |

Emissions Unit Information Section 1 of 6Combustion Turbine 1
Particulate Matter - Total**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

| | |
|--|--|
| 1. Pollutant Emitted: PM | |
| 2. Total Percent Efficiency of Control: | % |
| 3. Potential Emissions: | 17 lb/hour 19.3 tons/year |
| 4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| 5. Range of Estimated Fugitive/Other Emissions: | |
| <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr | |
| 6. Emission Factor: | |
| Reference. GE, '88; Golder, '99 | |
| 7. Emissions Method Code: | |
| <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5 | |
| 8. Calculation of Emissions (limit to 600 characters): | |
| See Attachment PSD-FCLASS; Section 2.0; Appendix A. | |
| 9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): | |
| Lb/hr based on oil firing, all loads. Tons/year based on 2,390 hrs/yr gas firing and 1,000 hrs/yr oil firing; ISO conditions. | |

**Combustion Turbine 1
Particulate Matter - Total**

**Emissions Unit Information Section 1 of 6
Allowable Emissions (Pollutant identified on front page)**

A.

| | | |
|---|-------------------|----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 17 lb/hr | | |
| 4. Equivalent Allowable Emissions: | 17 lb/hour | 8.5 tons/year |
| 5. Method of Compliance (limit to 60 characters): Annual stack test; EPA Methods 5 or 17; if < 400 hours | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Oil firing - all loads; 1,000 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

B.

| | | |
|---|------------------|-----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 10 percent opacity | | |
| 4. Equivalent Allowable Emissions: | 9 lb/hour | 15.3 tons/year |
| 5. Method of Compliance (limit to 60 characters): VE Test < 10% opacity | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Gas firing - all loads; 3,390 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

Combustion Turbine 1
Sulfur Dioxide

Emissions Unit Information Section 1 of 6
Allowable Emissions (Pollutant identified on front page)

A.

| | | |
|---|----------------------|-----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 0.05 % Sulfur Oil | | |
| 4. Equivalent Allowable Emissions: | 103.8 lb/hour | 51.9 tons/year |
| 5. Method of Compliance (limit to 60 characters): Fuel Sampling | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Oil firing - 32 degrees F; 100% load; 1,000 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

B.

| | | |
|---|--------------------|----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: See Comment | | |
| 4. Equivalent Allowable Emissions: | 5.5 lb/hour | 9.3 tons/year |
| 5. Method of Compliance (limit to 60 characters): Fuel Sampling | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions and Units: Pipeline Natural Gas. Gas firing, 1 gram/100 cf - 32 degrees F, 100% load; 3,390 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

Emissions Unit Information Section 1 of 6

Combustion Turbine 1
Nitrogen Oxides

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

| | |
|--|--|
| 1. Pollutant Emitted: NOx | |
| 2. Total Percent Efficiency of Control: | % |
| 3. Potential Emissions: | 344 lb/hour 247.1 tons/year |
| 4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| 5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr | |
| 6. Emission Factor: Reference: Applicant | |
| 7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5 | |
| 8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-FCLASS; Section 2.0; Appendix A. | |
| 9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Lb/hr based on oil firing, 100% load, 59 degrees F. Tons/yr based on 2,390 hrs/yr gas firing and 1,000 hrs/yr oil firing; ISO conditions. | |

Combustion Turbine 1

Nitrogen Oxides

Emissions Unit Information Section 1 of 6
Allowable Emissions (Pollutant identified on front page)

A.

| | | |
|--|--------------------|------------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 42 ppmvd | | |
| 4. Equivalent Allowable Emissions: | 344 lb/hour | 172.2 tons/year |
| 5. Method of Compliance (limit to 60 characters): CEM - 30 Day Rolling Average | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions is at 15% O2-100% load. Oil firing; 59 degrees F; 100% load; 1,000 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

B.

| | | |
|--|---------------------|------------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 9 ppmvd | | |
| 4. Equivalent Allowable Emissions: | 64.9 lb/hour | 109.9 tons/year |
| 5. Method of Compliance (limit to 60 characters): CEM 30-Day Rolling Average | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions and Units is at 15% O2-100 percent load. Gas firing; 32 degrees F; 100 percent load, 3,390 hrs/yr; see Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

Emissions Unit Information Section 1 of 6Combustion Turbine 1
Carbon Monoxide**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

| | | |
|---|----------------------------|--|
| 1. Pollutant Emitted: CO | | |
| 2. Total Percent Efficiency of Control: | | % |
| 3. Potential Emissions: | 66.9 lb/hour | 82.5 tons/year |
| 4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 5. Range of Estimated Fugitive/Other Emissions: | | |
| <input type="checkbox"/> 1 | <input type="checkbox"/> 2 | <input type="checkbox"/> 3 _____ to _____ tons/yr |
| 6. Emission Factor: | | |
| Reference: Applicant | | |
| 7. Emissions Method Code: | | |
| <input type="checkbox"/> 0 | <input type="checkbox"/> 1 | <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5 |
| 8. Calculation of Emissions (limit to 600 characters): | | |
| See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |
| 9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): | | |
| Lb/hr based on oil firing; 100% load; 59 degrees F. Tons/yr based on 2,390 hrs/yr gas firing and 1,000 hrs/yr oil firing; ISO conditions. | | |

Combustion Turbine 1

Carbon Monoxide

**Emissions Unit Information Section 1 of 6
Allowable Emissions (Pollutant identified on front page)**

A.

| | | |
|--|---------------------|-----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 20 ppmvd | | |
| 4. Equivalent Allowable Emissions: | 66.9 lb/hour | 33.5 tons/year |
| 5. Method of Compliance (limit to 60 characters): EPA Method 10; high load | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Oil firing; 59 degrees F; 100% load; 1,000 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

B.

| | | |
|--|---------------------|-----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 12 ppmvd | | |
| 4. Equivalent Allowable Emissions: | 41.9 lb/hour | 71.1 tons/year |
| 5. Method of Compliance (limit to 60 characters): EPA Method 10; high load | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Gas firing; 32 degrees F; 100% load; 3,390 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

Emissions Unit Information Section 1 of 6

Combustion Turbine 1
Volatile Organic Compounds

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

| | | |
|---|----------------------------|--|
| 1. Pollutant Emitted: VOC | | |
| 2. Total Percent Efficiency of Control: | % | |
| 3. Potential Emissions: | 11.5 lb/hour | 12.8 tons/year |
| 4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| 5. Range of Estimated Fugitive/Other Emissions: | | |
| <input type="checkbox"/> 1 | <input type="checkbox"/> 2 | <input type="checkbox"/> 3 _____ to _____ tons/yr |
| 6. Emission Factor: | | |
| Reference: Applicant | | |
| 7. Emissions Method Code: | | |
| <input type="checkbox"/> 0 | <input type="checkbox"/> 1 | <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5 |
| 8. Calculation of Emissions (limit to 600 characters): | | |
| See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |
| 9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): | | |
| Lb/hr based on oil firing, 100% load; 59 degrees F. Tons/yr based on 2,390 hrs/yr gas firing and 1,000 hrs/yr oil firing; ISO conditions. | | |

Combustion Turbine 1
Volatile Organic Compounds

Emissions Unit Information Section 1 of 6
Allowable Emissions (Pollutant identified on front page)

A.

| | | |
|--|---------------------|----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 6 ppmvd | | |
| 4. Equivalent Allowable Emissions: | 11.5 lb/hour | 5.7 tons/year |
| 5. Method of Compliance (limit to 60 characters): EPA Method 25A; high load | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Oil firing; 59 degrees F; 100% load; 1,000 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

B.

| | | |
|--|------------------|-----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 3 ppmvd | | |
| 4. Equivalent Allowable Emissions: | 6 lb/hour | 10.1 tons/year |
| 5. Method of Compliance (limit to 60 characters): EPA Method 25A; high load | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Gas firing; 32 degrees F; 100% load; 3,390 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

Emissions Unit Information Section 1 of 6

Combustion Turbine 1
Particulate Matter - PM10

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

| | | |
|---|--|----------------|
| 1. Pollutant Emitted: PM10 | | |
| 2. Total Percent Efficiency of Control: | | % |
| 3. Potential Emissions: | 17 lb/hour | 19.3 tons/year |
| 4. Synthetically Limited? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| 5. Range of Estimated Fugitive/Other Emissions: | <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr | |
| 6. Emission Factor: | Reference: Applicant | |
| 7. Emissions Method Code: | <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5 | |
| 8. Calculation of Emissions (limit to 600 characters): | See Attachment PSD-FCLASS; Section 2.0; Appendix A. | |
| 9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): | Lb/hr based on oil firing, all loads. Tons/year based on 2,390 hrs/yr gas firing and 1,000 hrs/yr oil firing; ISO conditions. | |

Combustion Turbine 1
Particulate Matter - PM10

Emissions Unit Information Section 1 of 6
Allowable Emissions (Pollutant identified on front page)

A.

| | | |
|---|-------------------|----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 17 lb/hr | | |
| 4. Equivalent Allowable Emissions: | 17 lb/hour | 8.5 tons/year |
| 5. Method of Compliance (limit to 60 characters): Annual stack test; EPA Methods 5 or 17; if < 400 hours | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Oil firing - all loads; 1,000 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

B.

| | | |
|---|------------------|-----------------------|
| 1. Basis for Allowable Emissions Code: OTHER | | |
| 2. Future Effective Date of Allowable Emissions: | | |
| 3. Requested Allowable Emissions and Units: 9 lb/hr | | |
| 4. Equivalent Allowable Emissions: | 9 lb/hour | 15.3 tons/year |
| 5. Method of Compliance (limit to 60 characters): VE Test < 20% opacity | | |
| 6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Gas firing - all loads; 3,390 hrs/yr. See Attachment PSD-FCLASS; Section 2.0; Appendix A. | | |

9839514Y/P1/WP
3/10/99

2.0 PROJECT DESCRIPTION

2.1 SITE DESCRIPTION

The project site, shown in Figure 2-1, consists of 38 acres that is currently zoned for light industry which allows for the siting of an electric power plants. There is minimal industrial, commercial, and residential development within a 3-km radius of the site. The plant elevation will be approximately 25 feet above sea level. The terrain surrounding the site is flat.

Natural gas will be supplied by a lateral pipeline connected to the Florida Gas Transmission (FGT) natural gas pipeline located immediately to the west of the site. The site has access to transmission facilities from a 230 kV transmission line and electrical substation that is located to the north of the site. Water for the evaporative cooler, and NO_x control when firing oil, will be supplied by nearby groundwater or surface water sources, including reclaimed water and storm water, largely developed by the city of Cocoa. Potable water and additional fire protection supply water will be served from the potable water supply pipe near Townsend Road.

2.2 POWER PLANT

The proposed project will consist of five "F" class CTs and associated facilities. The annual capacity factor of the plant will be 39 percent which is equivalent to operating 3,390 hours/year at full load. Natural gas will be used as the primary fuel and fuel oil will be used as a backup fuel. Fuel oil usage will be limited to the equivalent of 1,000 hours/year at full load.

Plant performance with General Electric 7FA and Westinghouse 501F combustion turbines was developed for natural gas and oil; at 50, 75, and 100 percent load; and at 32°F, 59°F, and 95°F ambient dry bulb temperatures. Nominal part load percentages herein are relative to 100 percent load without evaporative cooling. Generic "F" class combustion turbine performance is based on a performance envelope and has been adjusted to reflect anticipated future performance improvements. In particular, the future "F" class combustion turbine performance assumes 7 percent higher power output and a 1 percent lower heat rate (see Appendix A).

9830514Y/F1/WP
3/10/99

| Pollutant | Natural Gas | Distillate Oil |
|--|--|--|
| NO _x , ppmvd @ 15% O ₂ | 9 | 42 |
| CO ₂ , ppmvd | 12 | 20 |
| VOC as CH ₄ , ppmvd | 3 | 6 |
| SO _x as SO ₂ | Calculated Based on Fuel (1.0 grains S/100 SCF) | Calculated Based on Fuel (0.05% sulfur) |
| PM ₁₀ lb/hr (dry filterable) | 9 | 17 |

The maximum short-term emission rates (lb/hr) generally occur at base load, 32°F operation, where the CT has the greatest output and greatest fuel consumption.

Based on an ambient temperature of 59°F, the emission rates used to calculate maximum potential annual emissions for the proposed facility for regulated air pollutants are presented in Table 2-7 for one and 5 CTs. To produce the maximum annual emissions, the CTs are assumed to operate at baseload for 3,390 hours (39 percent capacity factor) firing natural gas for 2,390 hours and fuel oil for 1,000 hours. The potential emissions are based on the 59°F ambient air condition since it represents a nominal average between the higher emission levels at the 32°F ambient condition (winter) and the infrequent 95°F ambient condition (summer).

Process flow diagrams of the facility operating at summer and winter base load conditions are presented in Figures 2-2 and 2-3, respectively for the "F" Class CT.

Based on a review of the emission rates for natural gas and fuel oil combustion, the highest emission rates for the regulated pollutants generally occur when firing fuel oil. Combustion of natural gas and fuel oil result in slightly different exhaust flow gas rates and stack exit temperatures; however, the differences are minor. As a result of the higher emissions when firing oil, the air modeling analyses were based on determining maximum ground-level impacts with fuel oil.

As discussed in Section 6.0, the air modeling analyses that addressed compliance with ambient standards were based on modeling the CTs for the operating load and ambient temperature which produced the maximum impacts from the load impact analysis that was performed. Although the highest emission rates occur with low ambient temperatures (i.e., 32°F) and baseload conditions, the lowest exhaust gas flow rates occur with an ambient temperature of 95°F and 50 percent operating

9839514Y/F1/WP
3/17/99Table 2-1. Stack, Operating, and Emission Data for the Proposed "F" Class Combustion Turbine with Dry Low-NO_x Combustors firing Natural Gas-- Base Load for Simple Cycle Operation

| Parameter | Operating and Emission Data ^a for Ambient Temperature | | | |
|---|--|-------------------------------|-------------------------------|-------------------------------|
| | 32°F | 59°F | 95°F | |
| <u>Stack Data (ft)</u> | | | | |
| Height | 60 | 60 | 60 | |
| Diameter | 22 | 22 | 22 | |
| <u>Operating Data</u> | | | | |
| Temperature(°F) | 1,109 | 1,115 | 1,138 | |
| Velocity (ft/sec) | 113.9 | 112.5 | 107.6 | |
| <u>Maximum Hourly Emission per Unit^b</u> | | | | |
| SO ₂ | lb/hr | 5.5 | 5.5 | 5.0 |
| | Basis | 1.0 grain S/100CF | 1.0 grain S/100CF | 1.0 grain S/100CF |
| PM/PM10 | lb/hr | 9.0 | 9.0 | 9.0 |
| | Basis | Dry filterables | Dry filterables | Dry filterables |
| NO _x | lb/hr | 64.9 | 62.6 | 58.7 |
| | Basis | 9 ppmvd at 15% O ₂ | 9 ppmvd at 15% O ₂ | 9 ppmvd at 15% O ₂ |
| CO | lb/hr | 41.9 | 41.0 | 37.9 |
| | Basis | 12 ppmvd | 12 ppmvd | 12 ppmvd |
| VOC (as methane) | lb/hr | 6.0 | 5.9 | 5.5 |
| | Basis | 3 ppmvd | 3 ppmvd | 3 ppmvd |
| Sulfuric Acid Mist | lb/hr | 0.85 | 0.85 | 0.77 |
| | Basis | 10% SO ₂ | 10% SO ₂ | 10% SO ₂ |

Note: ppmvd = parts per million volume dry; O₂ = oxygen; S = sulfur; CF = cubic feet

^a Refer to Appendix A for detailed information.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, mercury, arsenic, asbestos, vinyl chloride, and radionuclides.

98395147/F1/WP
3/10/99Table 2-2. Stack, Operating, and Emission Data for the Proposed "F" Class Combustion Turbine with Dry Low-NO_x Combustors firing Natural Gas-- 75 Percent Load for Simple Cycle Operation

| Parameter | Operating and Emission Data ^a for Ambient Temperature | | | |
|---|--|---------------------------------------|---------------------------------------|---------------------------------------|
| | 32°F | 59°F | 95°F | |
| <u>Stack Data (ft)</u> | | | | |
| Height | 60 | 60 | 60 | |
| Diameter | 22 | 22 | 22 | |
| <u>Operating Data</u> | | | | |
| Temperature (°F) | 1,173 | 1,186 | 1,190 | |
| Velocity (ft/sec) | 98.4 | 95.5 | 91.4 | |
| <u>Maximum Hourly Emission per Unit^b</u> | | | | |
| SO ₂ | lb/hr Basis | 4.5 1.0 grain S/ 100CF | 4.5 1.0 grain S/ 100CF | 4.0 1.0 grain S/ 100CF |
| PM/PM10 | lb/hr Basis | 9.0 Dry filterables | 9.0 Dry filterables | 9.0 Dry filterables |
| NO _x | lb/hr Basis | 53.9 9 ppmvd at 15% O ₂ | 50.9 9 ppmvd at 15% O ₂ | 48.2 9 ppmvd at 15% O ₂ |
| CO | lb/hr Basis | 34.8 12 ppmvd | 33.4 12 ppmvd | 31.2 12 ppmvd |
| VOC (as methane) | lb/hr Basis | 4.9 3 ppmvd | 4.8 3 ppmvd | 4.6 3 ppmvd |
| Sulfuric Acid Mist | lb/hr Basis | 0.69 10% SO ₂ | 0.69 10% SO ₂ | 0.61 10% SO ₂ |

Note: ppmvd = parts per million volume dry; O₂ = oxygen; S = sulfur; CF = cubic feet

^a Refer to Appendix A for detailed information.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, mercury, arsenic, asbestos, vinyl chloride, and radionuclides.

9839314Y/F1/WP
3/10/99Table 2-3. Stack, Operating, and Emission Data for the Proposed "F" Class Combustion Turbine with Dry Low-NO_x Combustors firing Natural Gas-- 50 Percent Load for Simple Cycle Operation

| Parameter | Operating and Emission Data ^a for Ambient Temperature | | | |
|---|--|-------------------------------|-------------------------------|-------------------------------|
| | 32°F | 59°F | 95°F | |
| Stack Data (ft) | | | | |
| Height | 60 | 60 | 60 | |
| Diameter | 22 | 22 | 22 | |
| Operating Data | | | | |
| Temperature (°F) | 1,043 | 1,059 | 1,087 | |
| Velocity (ft/sec) | 82.1 | 80.1 | 77.3 | |
| Maximum Hourly Emission per Unit^b | | | | |
| SO ₂ | lb/hr | 3.5 | 3.5 | 3.0 |
| | Basis | 1.0 grain S/ 100CF | 1.0 grain S/ 100CF | 1.0 grain S/ 100CF |
| PM/PM10 | lb/hr | 9.0 | 9.0 | 9.0 |
| | Basis | Dry filterables | Dry filterables | Dry filterables |
| NO _x | lb/hr | 48.8 | 46.3 | 43.5 |
| | Basis | 9 ppmvd at 15% O ₂ | 9 ppmvd at 15% O ₂ | 9 ppmvd at 15% O ₂ |
| CO | lb/hr | 31.9 | 30.5 | 26.9 |
| | Basis | 12 ppmvd | 12 ppmvd | 12 ppmvd |
| VOC (as methane) | lb/hr | 4.5 | 4.4 | 4.0 |
| | Basis | 3 ppmvd | 3 ppmvd | 3 ppmvd |
| Sulfuric Acid Mist | lb/hr | 0.54 | 0.54 | 0.46 |
| | Basis | 10% SO ₂ | 10% SO ₂ | 10% SO ₂ |

Note: ppmvd = parts per million volume dry; O₂ = oxygen; S = sulfur; CF = cubic feet^a Refer to Appendix A for detailed information.^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, mercury, arsenic, asbestos, vinyl chloride, and radionuclides.

9839514Y/F1/WP
3/16/99

Table 2-4. Stack, Operating, and Emission Data for the Proposed "F" Class Combustion Turbine with Water Injection firing Distillate Fuel Oil- Base Load for Simple Cycle Operation

| Parameter | Operating and Emission Data ^a for Ambient Temperature | | | |
|---|--|--------------------------------|--------------------------------|--------------------------------|
| | 32°F | 59°F | 95°F | |
| Stack Data (ft) | | | | |
| Height | 60 | 60 | 60 | |
| Diameter | 22 | 22 | 22 | |
| Operating Data | | | | |
| Temperature(°F) | 1,114 | 1,109 | 1,123 | |
| Velocity (ft/sec) | 112.7 | 114.4 | 111.4 | |
| Maximum Hourly Emission per Unit^b | | | | |
| SO ₂ | lb/hr | 103.8 | 103.4 | 98.0 |
| | Basis | 0.05 % S | 0.05 % S | 0.05 % S |
| PM/PM10 | lb/hr | 17.0 | 17.0 | 17.0 |
| | Basis | Dry filterables | Dry filterables | Dry filterables |
| NO _x | lb/hr | 344.1 | 344.4 | 327.7 |
| | Basis | 42 ppmvd at 15% O ₂ | 42 ppmvd at 15% O ₂ | 42 ppmvd at 15% O ₂ |
| CO | lb/hr | 66.0 | 66.9 | 63.8 |
| | Basis | 20 ppmvd | 20 ppmvd | 20 ppmvd |
| VOC (as methane) | lb/hr | 11.3 | 11.5 | 11.0 |
| | Basis | 6 ppmvd | 6 ppmvd | 6 ppmvd |
| Sulfuric Acid Mist | lb/hr | 15.9 | 15.8 | 15.0 |
| | Basis | 10% SO ₂ | 10% SO ₂ | 10% SO ₂ |

Note: ppmvd = parts per million volume dry; O₂ = oxygen; S = sulfur; CF = cubic feet; ppmvw = parts per million volume wet

^a Refer to Appendix A for detailed information.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, mercury, arsenic, asbestos, vinyl chloride, and radionuclides.

9839514Y/F1/WP
3/16/99

Table 2-5. Stack, Operating, and Emission Data for the Proposed "F" Class Combustion Turbine with Water Injection firing Distillate Fuel Oil-- 75 Percent Load for Simple Cycle Operation

| Parameter | Operating and Emission Data ^a for Ambient Temperature | | | |
|---|--|--------------------------------|--------------------------------|--------------------------------|
| | 32°F | 59°F | 95°F | |
| <u>Stack Data (ft)</u> | | | | |
| Height | 60 | 60 | 60 | |
| Diameter | 22 | 22 | 22 | |
| <u>Operating Data</u> | | | | |
| Temperature(°F) | 1,166 | 1,179 | 1,190 | |
| Velocity (ft/sec) | 100.6 | 97.5 | 93.3 | |
| <u>Maximum Hourly Emission per Unit^b</u> | | | | |
| SO ₂ | lb/hr | 90.1 | 84.8 | 78.0 |
| | Basis | 0.05 % S | 0.05 % S | 0.05 % S |
| PM/PM10 | lb/hr | 17.0 | 17.0 | 17.0 |
| | Basis | Dry filterables | Dry filterables | Dry filterables |
| NO _x | lb/hr | 297.4 | 281.0 | 263.5 |
| | Basis | 42 ppmvd at 15% O ₂ | 42 ppmvd at 15% O ₂ | 42 ppmvd at 15% O ₂ |
| CO | lb/hr | 57.1 | 54.7 | 51.3 |
| | Basis | 20 ppmvd | 20 ppmvd | 20 ppmvd |
| VOC (as methane) | lb/hr | 9.7 | 9.3 | 9.0 |
| | Basis | 6 ppmvd | 6 ppmvd | 6 ppmvd |
| Sulfuric Acid Mist | lb/hr | 13.8 | 13.0 | 11.9 |
| | Basis | 10% SO ₂ | 10% SO ₂ | 10% SO ₂ |

Note: ppmvd = parts per million volume dry; O₂ = oxygen; S = sulfur; CF = cubic feet; ppmvw = parts per million volume wet

^a Refer to Appendix A for detailed information.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, mercury, arsenic, asbestos, vinyl chloride, and radionuclides.

9839514Y/F1/WP
3/16/99

Table 2-6. Stack, Operating, and Emission Data for the Proposed "F" Class Combustion Turbine with Water Injection firing Distillate Fuel Oil-- 50 Percent Load for Simple Cycle Operation

| Parameter | Operating and Emission Data ^a for Ambient Temperature | | | |
|---|--|--------------------------------|--------------------------------|--------------------------------|
| | 32°F | 59°F | 95°F | |
| Stack Data (ft) | | | | |
| Height | 60 | 60 | 60 | |
| Diameter | 22 | 22 | 22 | |
| Operating Data | | | | |
| Temperature(°F) | 998 | 1,014 | 1,043 | |
| Velocity (ft/sec) | 83.2 | 81.2 | 78.4 | |
| Maximum Hourly Emission per Unit^b | | | | |
| SO ₂ | lb/hr | 67.2 | 63.6 | 59.0 |
| | Basis | 0.05 % S | 0.05 % S | 0.05 % S |
| PM/PM10 | lb/hr | 17.0 | 17.0 | 17.0 |
| | Basis | Dry filterables | Dry filterables | Dry filterables |
| NO _x | lb/hr | 274.1 | 260.2 | 242.9 |
| | Basis | 42 ppmvd at 15% O ₂ | 42 ppmvd at 15% O ₂ | 42 ppmvd at 15% O ₂ |
| CO | lb/hr | 52.8 | 50.8 | 46.3 |
| | Basis | 20 ppmvd | 20 ppmvd | 20 ppmvd |
| VOC (as methane) | lb/hr | 9.0 | 8.6 | 8.2 |
| | Basis | 6 ppmvd | 6 ppmvd | 6 ppmvd |
| Sulfuric Acid Mist | lb/hr | 10.3 | 9.7 | 9.0 |
| | Basis | 10% SO ₂ | 10% SO ₂ | 10% SO ₂ |

Note: ppmvd = parts per million volume dry; O₂ = oxygen; S = sulfur; CF = cubic feet; ppmvw = parts per million volume wet

^a Refer to Appendix A for detailed information.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, mercury, arsenic, asbestos, vinyl chloride, and radionuclides.

9839514Y/F1/WP/Tab2-7r4/tab2x7
3/17/99

Table 2-7b. Summary of Pollutant Emissions for the Proposed Oicander Power Project (Revised 3/8/99; 1,000 hours oil; Revised CO, VOC, PM (oil); Proposed 'F' Class Combustion Turbines, Simple-Cycle Mode

| Load (%) | Pollutant | Pollutant Emissions Proposed 'F' Class Combustion Turbine | | | | | | | | |
|--|-----------------|--|-------|-------|--------|-------|-------|--------|-------|-------|
| | | 32 °F | | | 59 °F | | | 95 °F | | |
| | | ppmv/d | lb/hr | TPY | ppmv/d | lb/hr | TPY | ppmv/d | lb/hr | TPY |
| ONE UNIT | | | | | | | | | | |
| Natural gas | | | | | | | | | | |
| 100 | NOx | 9.0 | 64.9 | 109.9 | 9.0 | 62.6 | 106.2 | 9.0 | 58.7 | 99.4 |
| | CO | 9.6 | 41.9 | 71.1 | 9.7 | 41.0 | 69.5 | 9.6 | 37.9 | 64.2 |
| | SO ₂ | 0.5 | 5.5 | 9.3 | 0.5 | 5.5 | 9.3 | 0.5 | 5.0 | 8.5 |
| | VOC | 2.4 | 6.0 | 10.1 | 2.4 | 5.9 | 10.0 | 2.4 | 5.5 | 9.2 |
| | PM/PM10 | NA | 9.0 | 15.3 | NA | 9.0 | 15.3 | NA | 9.0 | 15.3 |
| 75 | NOx | 9.0 | 33.9 | 91.3 | 9.0 | 50.9 | 86.3 | 9.0 | 48.2 | 81.8 |
| | CO | 9.6 | 34.8 | 58.9 | 9.7 | 33.4 | 56.6 | 9.6 | 31.2 | 52.9 |
| | SO ₂ | 0.5 | 4.5 | 7.6 | 0.5 | 4.5 | 7.6 | 0.5 | 4.0 | 6.8 |
| | VOC | 2.4 | 4.9 | 8.4 | 2.4 | 4.8 | 8.1 | 2.4 | 4.6 | 7.8 |
| | PM/PM10 | NA | 9.0 | 15.3 | NA | 9.0 | 15.3 | NA | 9.0 | 15.3 |
| 50 | NOx | 9.0 | 48.8 | 82.7 | 9.0 | 46.3 | 78.4 | 9.0 | 43.5 | 73.8 |
| | CO | 9.6 | 31.9 | 54.1 | 9.7 | 30.5 | 51.6 | 9.6 | 26.9 | 45.7 |
| | SO ₂ | 0.5 | 3.5 | 5.9 | 0.5 | 3.5 | 5.9 | 0.5 | 3.0 | 5.1 |
| | VOC | 2.4 | 4.5 | 7.6 | 2.4 | 4.4 | 7.4 | 2.4 | 4.0 | 6.8 |
| | PM/PM10 | NA | 9.0 | 15.3 | NA | 9.0 | 15.3 | NA | 9.0 | 15.3 |
| Distillate Oil | | | | | | | | | | |
| 100 | NOx | 42.0 | 344.1 | 172.1 | 42.0 | 344.4 | 172.2 | 42.0 | 327.7 | 163.9 |
| | CO | 13.3 | 66.0 | 33.0 | 13.4 | 66.9 | 33.5 | 13.4 | 63.8 | 31.9 |
| | SO ₂ | 9.1 | 103.8 | 51.9 | 9.0 | 103.4 | 51.7 | 9.0 | 98.0 | 49.0 |
| | VOC | 4.0 | 11.3 | 5.7 | 4.0 | 11.5 | 5.7 | 4.0 | 11.0 | 5.5 |
| | PM/PM10 | NA | 17.0 | 8.5 | NA | 17.0 | 8.5 | NA | 17.0 | 8.5 |
| 75 | NOx | 42.0 | 297.4 | 144.7 | 42.0 | 281.0 | 140.5 | 42.0 | 263.5 | 131.8 |
| | CO | 13.3 | 57.1 | 28.6 | 13.4 | 54.7 | 27.4 | 13.4 | 51.3 | 25.6 |
| | SO ₂ | 9.1 | 90.1 | 45.1 | 9.1 | 84.8 | 42.4 | 8.9 | 78.0 | 39.0 |
| | VOC | 4.0 | 9.7 | 4.8 | 4.0 | 9.3 | 4.7 | 4.0 | 9.0 | 4.5 |
| | PM/PM10 | NA | 17.0 | 8.5 | NA | 17.0 | 8.5 | NA | 17.0 | 8.5 |
| 50 | NOx | 42.0 | 274.1 | 137.1 | 42.0 | 260.2 | 130.1 | 42.0 | 242.9 | 121.5 |
| | CO | 13.3 | 52.8 | 26.4 | 13.4 | 50.8 | 25.4 | 13.4 | 46.3 | 23.2 |
| | SO ₂ | 7.4 | 67.2 | 33.6 | 7.4 | 63.6 | 31.8 | 7.3 | 59.0 | 29.5 |
| | VOC | 4.0 | 9.0 | 4.5 | 4.0 | 8.6 | 4.3 | 4.0 | 8.2 | 4.1 |
| | PM/PM10 | NA | 17.0 | 8.5 | NA | 17.0 | 8.5 | NA | 17.0 | 8.5 |
| Maximum Emissions (Maximum oil/balance gas) (2) | | | | | | | | | | |
| | NOx | | | 249.6 | | | 247.1 | | | 233.9 |
| | CO | | | 83.1 | | | 82.3 | | | 77.2 |
| | SO ₂ | | | 58.5 | | | 58.3 | | | 55.0 |
| | VOC | | | 12.8 | | | 12.8 | | | 12.0 |
| | PM10 (1) | | | 19.3 | | | 19.3 | | | 19.3 |
| 5 UNITS | | | | | | | | | | |
| Maximum Emissions (Maximum oil/balance gas) (2) | | | | | | | | | | |
| | NOx | | | 1,248 | | | 1,235 | | | 1,170 |
| | CO | | | 415 | | | 412 | | | 386 |
| | SO ₂ | | | 292 | | | 291 | | | 275 |
| | VOC | | | 64 | | | 64 | | | 60 |
| | PM10 (1) | | | 96 | | | 96 | | | 96 |

(1) Emission rates are ppmvd at 15 percent O₂. PM/PM10 are dry filterables only.

(2) Assumed hours firing oil and natural gas are 1,000 and 2,390, respectively.

9839514Y/F1/WP
3/16/99**Table 3-3b. Maximum Emissions Due to the Proposed Oleander Power Project Compared to the PSD Significant Emission Rates**

| Pollutant | Pollutant Emissions (TPY) | | PSD Review |
|--------------------------------|---|---------------------------|------------|
| | Potential Emissions from Proposed Facility ^a | Significant Emission Rate | |
| Sulfur Dioxide | 291 | 40 | Yes |
| Particulate Matter [PM(TSP)] | 96 | 25 | Yes |
| Particulate Matter (PM10) | 96 | 15 | Yes |
| Nitrogen Dioxide | 1,235 | 40 | Yes |
| Carbon Monoxide | 412 | 100 | Yes |
| Volatile Organic Compounds | 64 | 40 | Yes |
| Lead | NEG | 0.6 | No |
| Sulfuric Acid Mist | 44.4 | 7 | Yes |
| Total Fluorides | NEG | 3 | No |
| Total Reduced Sulfur | NEG | 10 | No |
| Reduced Sulfur Compounds | NEG | 10 | No |
| Hydrogen Sulfide | NEG | 10 | No |
| Mercury | NEG | 0.1 | No |
| MWC Organics (as 2,3,7,8-TCDD) | < 8.8x10 ⁻⁶ | 3.5x10 ⁻⁶ | No |
| MWC Metals (as Be, Cd) | NEG | 15 | No |
| MWC Acid Gases (as HCl) | 11.3 | 40 | No |

Note: NEG = Negligible.

- ^a Based on emissions from operating at baseload at 59°F; firing natural gas and distillate fuel oil for 2,390 and 1,000 hours per year per turbine for a total of five CTs, respectively (Refer to Table 2-7).

9839514Y/F1/WP
3/17/99

**Table 3-4b. Predicted Net Increase in Impacts Due To the Proposed Oleander Power Project
Compared to PSD *De Minimis* Monitoring Concentrations**

| Pollutant | Concentration ($\mu\text{g}/\text{m}^3$) | |
|----------------------------|--|--|
| | Predicted Increase in Impacts ^a | <i>De Minimis</i> Monitoring Concentration |
| Sulfur Dioxide | 1.1 | 13, 24-hour |
| Particulate Matter (PM10) | 0.3 | 10, 24-hour |
| Nitrogen Dioxide | 0.3 | 14, annual |
| Carbon Monoxide | 2.4 | 575, 8-hour |
| Volatile Organic Compounds | 64 TPY | 100 TPY |

Note: NA = not applicable.
 NM = no ambient measurement method.
 TPY = tons per year.

^a See Section 6.0 for air dispersion modeling results.

9839514Y/F1/WP
3/10/99Table 4-1. NO_x Emission Estimates (TPY) of BACT Alternative Technologies (per Unit)

| Alternative BACT Control Technologies | Operating Mode ^a | | Total |
|---------------------------------------|-----------------------------|-------|-------|
| | Oil | Gas | |
| <u>NO_x Emission (TPY)</u> | | | |
| Dry Low-NO _x (DLN) only | 172 | 75 | 247 |
| DLN with SCR ^b | 69 | 30 | 99 |
| Reduction | (103) | (45) | (148) |
| <u>Basis of Emissions (ppmv)</u> | | | |
| DLN only | 42 | 9 | |
| DLN with SCR | 16.8 | 3.6 | |
| Hours of Operation | 1,000 | 2,390 | 3,390 |

Note: DLN = Dry low-NO_x.
 - SCR = selective catalytic reduction.
 TPY = tons per year.

- ^a Emission rates were based on a "F" class combustion turbine operating at 100-percent capacity and firing natural gas for 2,390 hours and distillate fuel oil for 1,000 hours. Emission data are based on an ambient temperature of 59°F at maximum emission rates.
- ^b Based on primary emissions with SCR; no account is made for additional emissions (secondary) due to lost energy from heat rate penalty and electrical usage for SCR operation (see Table 4-3).

9839514Y/F1/WP
3/10/99**Table 4-2b. Comparison of Alternative BACT Control Technologies for NO_x (per Unit)**

| | Alternative BACT Control Technologies | |
|---|---------------------------------------|------------------|
| | DLN Only | SCR |
| Technical Feasibility | Feasible | Feasible for gas |
| Economic Impact ^a | | |
| Capital Costs | included | \$7,507,200 |
| Annualized Costs | included | \$2,603,640 |
| Cost Effectiveness | | |
| NO _x Removed (per ton of NO _x) | NA | \$17,568 |
| NO _x Removed (per ton of total pollutants) | NA | \$44,813 |
| Environmental Impact ^b | | |
| Total NO _x (TPY) | 247 | 99 |
| NO _x Reduction (TPY) | NA | (148) |
| Ammonia Emissions (TPY) | 0 | 39.1 |
| PM Emissions (TPY) | 0 | 18.0 |
| Secondary Emissions (TPY) | 0 | 32.8 |
| Net Emission Reduction (TPY) | NA | (58.1) |
| Energy Impacts ^c | | |
| Energy Use (kWh/yr) | 0 | 4,200,210 |
| Energy Use (mmBtu/yr) at 10,000 Btu/kWh | 0 | 50,400 |
| Energy Use (mmcf/yr) at 1,000 Btu/cf for natural gas | 0 | 41 |

^a See Appendix B for detailed development of capital costs (including recurring costs) and annualized costs.

^b See emission data presented in Table 4-3.

^c Energy impacts are estimated due to the lost energy from heat rate penalty and electrical usage for the SCR operation at 3,390 hours per year. Lost energy is based on 0.5 percent of 192 MW. SCR electrical usage is based on 0.080 MWh per SCR system and 0.20 MWh for cooling fan.

9839314Y/F1/WP
3/10/99

Table 4-3b. Maximum Potential Incremental Emissions (TPY) with Selective Catalytic Reduction

| Pollutants | Incremental Emissions (TPY) of Project with SCR | | |
|-----------------------------|---|------------------------|---------|
| | Primary | Secondary ^a | Total |
| Particulate | 15.9 ^b | 0.96 | 25.6 |
| Sulfur Dioxide | — | 12.7 | 12.7 |
| Nitrogen Oxides | (148) ^c | 17.6 | (172.4) |
| Carbon Monoxide | — | 1.21 | 1.21 |
| Volatile Organic Compounds | — | 0.30 | 0.3 |
| Ammonia | 39.1 ^d | 0 | 39.1 |
| Total | (93.0) | 32.8 | (92.5) |
| Carbon Dioxide ^e | — | 4,330 | 4,330 |

Note: Btu/kWh = British thermal units per kilowatt-hour
 CT = combustion turbine
 MW = megawatt
 % = percent
 SCR = selective catalytic reduction
 TPY = tons per year
 — = no differences in the project's emissions with SCR and without SCR

- ^a Lost energy from heat rate penalty and electrical usage for 3,390 hours per year operation (0.5% of 192 MW per CT plus 0.080 MWh for SCR system and 0.2 MWh for dilution fan). Assumes baseloaded oil-fired unit would replace lost energy. EPA emission factors based on oil-fired peaking turbines used were (lb/10⁶ Btu): PM = 0.038; SO₂ = 0.505; NO_x = 0.698, CO = 0.048, and VOC = 0.017. Example calculation for PM is ((0.5% x 192 + 0.28) MW x 12,000 Btu/kWh x 1,000 kW/MW x 3,390 hr/yr x 0.038 lb pm/10⁶ Btu ÷ 2,000 lb/ton = 0.96 TPY.
- ^b Assume 5% SO₂ conversion in catalyst and SO₃ and the SO₃ formed in the combustion process reacts with ammonia to form ammonium sulfate: 58.3 TPY SO₂ x 0.05 = 2.92 TPY SO₂; 2.92 TPY SO₂ x 98 MW of H₂SO₄ ÷ 64 MW SO₂ = 4.46 TPY H₂SO₄; 8.88 TPY H₂SO₄ from combustion of oil and gas for total H₂SO₄ = 13.4 TPY SO₃ x 132 (MW of ammonia salt) ÷ 98 (MW of H₂SO₄) = 18.0 TPY.
- ^c Based on the maximum difference between the project's emissions with SCR and without SCR (see Table 4-1).
- ^d 10 ppm ammonia slip (ideal gas law): 2,591,756 acfm x (10 ppm ÷ 10⁶) x 17 x 2,116.8 ÷ 1,545 ÷ (460 + 1,111) x 60 x 3,390 ÷ 2,000 = 39.1 TPY (flow average of gas and oil).
- ^e Reflects differential emissions due to lost energy efficiency with SCR (i.e., calculated from total heat input lost; 1.24 MW times 12,000 Btu/kWh; CO₂ calculated based on 85.7% carbon in fuel oil and 18,300 Btu/lb for 0.5% sulfur oil).

989514YF1AWPCE_BACT08A45-344
3/10/99

Table B-4b. Annualized Cost for Selective Catalytic Reduction for Frame "F" Simple Cycle Operation

| Cost Component | Costs | Basis of Cost Component |
|---|--------------------|--|
| Direct Annual Costs | | |
| Operating Personnel | \$24,960 | 24 hours/week at \$20/hr |
| Supervision | \$3,744 | 15% of Operating Personnel; OAQPS Cost Control Manual |
| Maintenance - Labor | \$13,104 | 0.5 hr per shift, \$24/hr; OAQPS Cost Manual |
| - Materials | \$13,104 | 100% of maintenance labor; OAQPS Cost Manual |
| Ammonia | \$64,332 | \$300 per ton NH3 Aqueous |
| PSM/RAF Update | \$5,000 | Engineering Estimate |
| Inventory Cost | \$93,044 | Capital Recovery (11.74%) for 1/3 catalyst |
| Catalyst Disposal Cost | \$15,793 | \$28/1,000 lb/hr mass flow over 3 years; developed from vendor quotes |
| Contingency | \$7,599 | 3% of Direct Annual Costs |
| Total Direct Annual Costs (TDAC) | \$260,900 | |
| Energy Costs | | |
| Electrical | \$47,460 | 80kW/h for SCR; 200 kW/h for cooling fan @ \$0.05/KWh times Capacity Factor |
| Heat Rate Penalty | \$162,551 | 0.5% of MW output; EPA, 1993 (Page 6-20) |
| MW Loss Penalty | \$230,100 | 3 days lost energy costs @ \$0.05 kWh each three period |
| Fuel Escalation | \$13,205 | Escalation of fuel over inflation; 3% of energy costs |
| Contingency | \$13,601 | 3% of Energy Costs |
| Total Energy Costs (TEC) | \$466,917 | |
| Indirect Annual Costs | | |
| Overhead | \$17,222 | 60% of Operating/Supervision Labor and Ammonia |
| Property Taxes, Insurance, Admin. | \$300,289 | 4% of Total Capital Costs |
| Annualized Total Direct Capital | \$602,665 | 11.75% Capital Recovery Factor of 10% over 20 years times sum of TDCC, TDIC, and ThC |
| Annualized Total Direct Recurring | 395,587 | 0.21% Capital Recovery Factor of 10% over 3 years times RCC |
| Total Indirect Annual Costs (TIAC) | \$1,875,763 | |
| TOTAL ANNUALIZED COSTS | \$2,603,640 | Sum of TDAC, TEC and TIAC |
| COST EFFECTIVENESS | \$17,568 | |

0030814V/FINANCE_BACTEM/0008-007
3/16/99

Table B-7b. Annualized Cost for CO Catalyst for Frame "F" Simple Cycle Operation

| Cost Component | Cost | Basis of Cost Estimate |
|---|------------------|--|
| Direct Annual Costs | | |
| Operating Personnel | \$8,320 | 8 hours/week at \$20/hr |
| Supervision | \$1,248 | 1.5% of Operating Personnel; OAQPS Cost Control Manual |
| Maintenance - Labor | \$4,368 | 0.5 hr per shift, \$24/hr; OAQPS Cost Manual |
| - Materials | \$4,368 | 100% of maintenance labor; OAQPS Cost Manual |
| Laboratory Cost | \$27,401 | Capital Recovery (11.74%) for 1/3 catalyst |
| Catalyst Disposal Cost | \$35,793 | \$28/1,000 lb/hr mass flow over 3 years; developed from vendor quotes |
| Contingency | \$3,445 | 3% of direct costs |
| Total Direct Annual Costs (TDAC) | \$83,943 | |
| Energy Costs | | |
| Heat Rate Penalty | \$66,105 | 0.2% of MW output; EPA, 1993 (Page 6-20) |
| MW Loss Penalty | \$46,800 | 2 days replacement energy costs @ \$0.01 kWh each three period |
| Fuel Escalation | \$3,387 | Escalation of fuel over inflation; 3% of energy costs |
| Contingency | \$11,629 | 10% of energy costs |
| Total Energy Costs (TEC) | \$127,921 | |
| Indirect Annual Costs | | |
| Overhead | \$0 | 60% of Operating/Supervision Labor and Ammonia |
| Property Taxes, insurance, admin. | \$0 | 4% of Total Capital Costs |
| Annualized Total Direct Capital | \$0 | 11.75% Capital Recovery Factor of 10% over 20 years times sum of TDCC, TDIC and TI |
| Annualized Total Direct Recurring | \$0 | 40.21% Capital Recovery Factor of 10% over 3 years times RCC |
| Total Indirect Annual Costs (TIAC) | \$0 | |
| TOTAL ANNUALIZED COSTS | \$211,864 | Sum of TDAC, TEC and TIAC |
| COST EFFECTIVENESS | \$3,424 | |

Table 6-2b. Maximum Predicted Pollutant Concentrations For One Simple-Cycle Combustion Turbine- Screening Analysis
Class F Combustion Turbine, Natural Gas-Fired

| Pollutant | Maximum Emission Rates (lb/hr) by Operating Load and Air Temperature | | | | | | Averaging Time | Maximum Predicted Concentrations (ug/m ³) by Operating Load and Air Temperature (1) | | | | | |
|---------------------|---|-------|----------|-------|----------|-------|-------------------|--|---------|----------|---------|----------|---------|
| | Base Load | | 75% Load | | 50% Load | | | Base Load | | 75% Load | | 50% Load | |
| | 32 °F | 95 °F | 32 °F | 95 °F | 32 °F | 95 °F | | 32 °F | 95 °F | 32 °F | 95 °F | 32 °F | 95 °F |
| Generic (10 g/s) | 79.37 | 79.37 | 79.37 | 79.37 | 79.37 | 79.37 | Annual | 0.012 | 0.013 | 0.013 | 0.015 | 0.018 | 0.019 |
| | | | | | | | 24-Hour | 0.153 | 0.155 | 0.169 | 0.178 | 0.241 | 0.314 |
| | | | | | | | 8-Hour | 0.365 | 0.385 | 0.435 | 0.455 | 0.654 | 0.875 |
| | | | | | | | 3-Hour | 0.885 | 0.908 | 1.124 | 1.143 | 1.669 | 2.258 |
| | | | | | | | 1-Hour | 1.760 | 1.893 | 2.074 | 2.543 | 5.008 | 6.774 |
| SO ₂ | 5.5 | 5.0 | 4.5 | 4.0 | 3.5 | 3.0 | Annual | 0.00086 | 0.00079 | 0.00076 | 0.00074 | 0.00078 | 0.00073 |
| | | | | | | | 24-Hour | 0.0106 | 0.0107 | 0.0096 | 0.0090 | 0.0106 | 0.0119 |
| | | | | | | | 3-Hour | 0.061 | 0.063 | 0.064 | 0.058 | 0.074 | 0.085 |
| NO _x | 64.9 | 58.7 | 53.9 | 48.2 | 48.8 | 43.5 | Annual | 0.010 | 0.009 | 0.009 | 0.009 | 0.011 | 0.011 |
| PM10 | 9.0 | 9.0 | 9.0 | 9.0 | 9.0 | 9.0 | Annual | 0.0014 | 0.0014 | 0.0015 | 0.0017 | 0.0020 | 0.0022 |
| | | | | | | | 24-Hour | 0.017 | 0.018 | 0.019 | 0.020 | 0.027 | 0.036 |
| CO | 41.9 | 37.9 | 34.8 | 31.2 | 31.9 | 26.9 | 8-Hour | 0.2 | 0.2 | 0.2 | 0.2 | 0.3 | 0.3 |
| | | | | | | | 1-Hour | 0.9 | 0.9 | 0.9 | 1.0 | 2.0 | 2.3 |

(1) Concentrations are based on highest predicted concentrations using five years of meteorological for 1987 to 1991 of surface and upper air data from the National Weather Service stations in Orlando and Ruskin, respectively.

Pollutant concentrations were based on a modeled or generic concentration predicted using a modeled emission rate of 79.37 lb/hr (10 g/s). Specific pollutant concentrations were estimated by multiplying the modeled concentration (at 10 g/s) by the ratio of the specific pollutant emission rate to the modeled emission rate of 10 g/s.

Brevimp3.xls
03/17/99

Table 6-3b. Maximum Pollutant Concentrations Predicted for 5 Simple-Cycle Combustion Turbines (Natural Gas-Fired)
Compared to EPA Significant Impact and De minimis Monitoring Levels- Screening Analysis

| Pollutant | Averaging Time | Maximum Predicted Concentrations (ug/m ³) by Operating Load and Air Temperature (1) | | | | | | EPA Significant Impact Levels (ug/m ³) | EPA De minimis Levels (ug/m ³) |
|-----------------|----------------|--|---------|----------|---------|----------|---------|---|---|
| | | Base Load | | 75% Load | | 50% Load | | | |
| | | 32 °F | 95 °F | 32 °F | 95 °F | 32 °F | 95 °F | | |
| SO ₂ | Annual | 0.00430 | 0.00394 | 0.00380 | 0.00370 | 0.00392 | 0.00363 | 1 | NA |
| | 24-Hour | 0.053 | 0.054 | 0.048 | 0.045 | 0.053 | 0.059 | 5 | 13 |
| | 3-Hour | 0.307 | 0.314 | 0.319 | 0.288 | 0.368 | 0.427 | 25 | NA |
| NO _x | Annual | 0.051 | 0.046 | 0.046 | 0.045 | 0.055 | 0.053 | 1 | 14 |
| PM10 | Annual | 0.007 | 0.007 | 0.008 | 0.008 | 0.010 | 0.011 | 1 | NA |
| | 24-Hour | 0.087 | 0.088 | 0.096 | 0.101 | 0.136 | 0.178 | 5 | 10 |
| CO | 8-Hour | 1.0 | 0.9 | 1.0 | 0.9 | 1.3 | 1.5 | 500 | 575 |
| | 1-Hour | 5 | 5 | 5 | 5 | 10 | 11 | 2,000 | NA |

(1) Concentrations are based on highest predicted concentrations using five years of meteorological for 1987 to 1991 of surface and upper air data from the National Weather Service stations in Orlando and Ruskin, respectively.

Table 6-4b. Maximum Predicted Pollutant Concentrations For One Simple-Cycle Combustion Turbine- Screening Analysis
Class F Combustion Turbine, Distillate Fuel Oil- Fired

| Pollutant | Maximum Emission Rates (lb/hr) by Operating Load and Air Temperature | | | | | | Averaging Time | Maximum Predicted Concentrations (ug/m ³) by Operating Load and Air Temperature (t) | | | | | |
|---------------------|---|-------|----------|-------|----------|-------|-------------------|--|--------|----------|--------|----------|--------|
| | Base Load | | 75% Load | | 50% Load | | | Base Load | | 75% Load | | 50% Load | |
| | 32 °F | 95 °F | 32 °F | 95 °F | 32 °F | 95 °F | | 32 °F | 95 °F | 32 °F | 95 °F | 32 °F | 95 °F |
| Generic (10 g/s) | 79.37 | 79.37 | 79.37 | 79.37 | 79.37 | 79.37 | Annual | 0.013 | 0.013 | 0.013 | 0.014 | 0.018 | 0.019 |
| | | | | | | | 24-Hour | 0.154 | 0.154 | 0.167 | 0.174 | 0.227 | 0.297 |
| | | | | | | | 8-Hour | 0.369 | 0.372 | 0.431 | 0.445 | 0.612 | 0.823 |
| | | | | | | | 3-Hour | 0.889 | 0.894 | 1.120 | 1.137 | 1.557 | 2.121 |
| | | | | | | | 1-Hour | 1.762 | 1.770 | 2.038 | 2.197 | 4.671 | 6.362 |
| SO ₂ | 103.8 | 98 | 90.1 | 78 | 67.2 | 59 | Annual | 0.016 | 0.015 | 0.015 | 0.014 | 0.015 | 0.014 |
| | | | | | | | 24-Hour | 0.20 | 0.20 | 0.19 | 0.17 | 0.19 | 0.22 |
| | | | | | | | 3-Hour | 1.2 | 1.2 | 1.3 | 1.1 | 1.3 | 1.6 |
| NO _x | 344.1 | 327.7 | 297.4 | 263.5 | 274.1 | 242.9 | Annual | 0.054 | 0.052 | 0.049 | 0.047 | 0.061 | 0.059 |
| PM10 | 17 | 17 | 17 | 17 | 17 | 17 | Annual | 0.0027 | 0.0027 | 0.0028 | 0.0030 | 0.0038 | 0.0041 |
| | | | | | | | 24-Hour | 0.033 | 0.033 | 0.036 | 0.037 | 0.049 | 0.064 |
| CO | 66 | 63.8 | 57.1 | 51.3 | 52.8 | 46.3 | 8-Hour | 0.31 | 0.30 | 0.31 | 0.29 | 0.41 | 0.48 |
| | | | | | | | 1-Hour | 1.5 | 1.4 | 1.5 | 1.4 | 3.1 | 3.7 |

(1) Concentrations are based on highest predicted concentrations using five years of meteorological for 1987 to 1991 of surface and upper air data from the National Weather Service stations in Orlando and Rudkin, respectively.

Pollutant concentrations were based on a modeled or generic concentration predicted using a modeled emission rate of 79.37 lb/hr (10 g/s). Specific pollutant concentrations were estimated by multiplying the modeled concentration (at 10 g/s) by the ratio of the specific pollutant emission rate to the modeled emission rate of 10 g/s.

Table 6-5b. Maximum Pollutant Concentrations Predicted for 5 Simple-Cycle Combustion Turbines (Distillate Fuel Oil-Fired) Compared to EPA Significant Impact and De minimis Monitoring Levels- Screening Analysis

| Pollutant | Averaging Time | Maximum Predicted Concentrations (ug/m ³) by Operating Load and Air Temperature (1) | | | | | | EPA Significant Impact Levels (ug/m ³) | EPA De minimis Levels (ug/m ³) |
|-----------------|----------------|--|-------|----------|-------|----------|-------|--|--|
| | | Base Load | | 75% Load | | 50% Load | | | |
| | | 32 °F | 95 °F | 32 °F | 95 °F | 32 °F | 95 °F | | |
| SO ₂ | Annual | 0.082 | 0.077 | 0.074 | 0.070 | 0.073 | 0.071 | 1 | NA |
| | 24-Hour | 1.0 | 1.0 | 0.9 | 0.9 | 1.0 | 1.1 | 5 | 13 |
| | 3-Hour | 5.8 | 5.8 | 6.4 | 5.6 | 6.6 | 7.9 | 25 | NA |
| NO _x | Annual | 0.27 | 0.26 | 0.25 | 0.24 | 0.31 | 0.29 | 1 | 14 |
| PM10 | Annual | 0.013 | 0.013 | 0.014 | 0.015 | 0.019 | 0.021 | 1 | NA |
| | 24-Hour | 0.16 | 0.16 | 0.18 | 0.19 | 0.24 | 0.32 | 5 | 10 |
| CO | 8-Hour | 1.5 | 1.5 | 1.6 | 1.4 | 2.0 | 2.4 | 500 | 575 |
| | 1-Hour | 7 | 7 | 7 | 7 | 16 | 19 | 2,000 | NA |

(1) Concentrations are based on highest predicted concentrations using five years of meteorological for 1987 to 1991 of surface and upper air data from the Federal Aviation Administration and National Weather Service stations in Ft. Myers and Ruskin, respectively.

Table 6-6b. Summary of Maximum Pollutant Concentrations Predicted for 5 Simple-Cycle Combustion Turbines Compared to EPA Significant Impact and Derrimis Monitoring Levels- Refined Analysis

| Pollutant | Averaging Time | Maximum Predicted Concentrations (ug/m ³) | | EPA Significant Impact Levels (ug/m ³) | EPA Derrimis Levels (ug/m ³) |
|-----------------|----------------|---|-----------|--|--|
| | | Natural Gas-Fired | Oil-Fired | | |
| SO ₂ | Annual | 0.0043 (1) | 0.082 (1) | 1 | NA |
| | 24-Hour | 0.059 (2) | 1.10 (2) | 5 | 13 |
| | 3-Hour | 0.43 (2) | 7.9 (2) | 25 | NA |
| NO _x | Annual | 0.055 (3) | 0.31 (3) | 1 | 14 |
| PM10 | Annual | 0.011 (2) | 0.021 (2) | 1 | NA |
| | 24-Hour | 0.18 (2) | 0.32 (2) | 5 | 10 |
| CO | 8-Hour | 1.5 (2) | 2.4 (2) | 500 | 575 |
| | 1-Hour | 11.5 (2) | 18.6 (2) | 2,000 | NA |

- (1) Based on operating conditions at base load and ambient temperature of 32 °F.
 (2) Based on operating conditions at 50 percent load and ambient temperature of 95 °F.
 (3) Based on operating conditions at 50 percent load and ambient temperature of 52 °F.