

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NOTICE OF PERMIT

In the Matter of an  
Application for Permit by:

Mr. James O. Vick, Director  
Environmental Affairs  
Gulf Power Company  
One Energy Place  
Pensacola, Florida 32520

DEP File No. 0090180-003-AC  
Oleander Power Project Unit 5  
Brevard County

Enclosed is the Final Permit, number 0090180-003-AC, authorizing the construction of one GE 7FA simple cycle combustion turbine electrical generator and associated fuel oil storage tank at the existing Oleander Power Project in Cocoa, Brevard County. This permit is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief  
Bureau of Air Regulation


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Final Permit (including the Final Permit) and all copies were sent electronically (with Received Receipt) before the close of business on 11/17/06 to the persons listed:

James O. Vick, Gulf Power Company: [jovick@southernco.com](mailto:jovick@southernco.com)  
Kevin White, Gulf Power Company: [kwhite@southernco.com](mailto:kwhite@southernco.com)  
Mayor, City of Cocoa: [mblake@cocoaf1.org](mailto:mblake@cocoaf1.org)  
Chair, Brevard County BCC: [helen.voltz@brevardcounty.us](mailto:helen.voltz@brevardcounty.us)  
Gregg Worley, EPA Region 4: [worley.gregg@epa.gov](mailto:worley.gregg@epa.gov)  
John Bunyak, National Park Service: [john\\_bunyak@nps.gov](mailto:john_bunyak@nps.gov)  
Len Kozlov, DEP CD: [leonard.kozlov@dep.state.fl.us](mailto:leonard.kozlov@dep.state.fl.us)  
Thomas W. Davis, P.E., ECT, Inc.: [tdavis@ectinc.com](mailto:tdavis@ectinc.com)

**Clerk Stamp**

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.



(Clerk)

11/17/06  
(Date)

## FINAL DETERMINATION

Oleander Power Project, L.P.

Simple Cycle Unit 5

Fuel Oil Storage Tank

DEP File No. 0090180-003-AC (PSD-FL-377)

On October 9, 2006 the Florida Department of Environmental Protection (Department) distributed an "Intent to Issue Air Construction Permit" authorizing the construction of a simple cycle combustion turbine electrical generator (nominal 190 MW) and associated fuel oil storage tank at the existing Oleander Power Project, L.C. Oleander Power Project is a subsidiary of Southern Power Company (SPC) located in the city of Cocoa, Brevard County.

The package included the Department's Draft Air Construction Permit, the "Intent to Issue Air Construction Permit," the "Technical Evaluation and Preliminary Determination," and the "Public Notice of Intent to Issue Air Construction Permit." The Department sent copies of the package to various persons, agencies, and municipalities. SPC published the Public Notice in the *Orlando Sentinel* on October 17, 2006 and provided to the Department the required proof of publication.

The Department received no comments from agencies or the public throughout the comment period regarding the Draft Air Construction Permit. Comments received from SPC are listed below (*italics*) followed by the Department's responses.

Any additions to permit conditions are double underlined and deletions are indicated by double strike-through notation.

- 1) *Previously, Southern Power requested the Startup, Shutdown, Malfunction language be changed to the rule based 2 hours in any 24 hour period (Rule 62-210.700, F.A.C.) and the following additional language included (currently contained in the Title V permit): "Operation below 50% output shall be limited to 2 hours per unit cycle." This additional language was requested to allow fuel switching in the turbine at a decreased load (below 50%), which is the facility's current standard operating procedure. Fuel switching at low load poses less risk of a unit trip.*

**Response**

Rather than allowing two hours of excess emissions for startups, shutdowns, and malfunctions in any 24-hour period, the Department has allowed data exclusions of up to 30 minutes for each startup and shutdown, and up to two hours for documented malfunctions during an operating day. Such limitations can be found in other permits recently issued by the Department, and are a direct response to recommendations by EPA to limit excess emissions during these events. Documented malfunctions resulting in excess emissions are not expected to be a common occurrence with this unit.

The "additional language" requested by the applicant is contained in the current Title V operating permit for the facility. The Title V condition states: "Operation below 50% output shall be limited to 2 hours per unit cycle (breaker closed to breaker open)." The Title V permit doesn't specify what activities are included in the operation below 50 % output. Therefore it must be assumed that all low load activities such as startup, shutdown, and fuel switching are included, thus limiting the sum of these activities to two hours per unit cycle. The Department is allowing reasonable data exclusions during these periods without limiting operation below 50 % output. Lean premix (Low-NO<sub>x</sub>) conditions can occur, under certain conditions, during operation below 50 % load. For these reasons, the Department no longer considers the addition of the above language to be necessary or even beneficial.

Representatives from General Electric and an operator at another Florida facility with similar existing units were contacted to discuss the procedures involved in fuel switching. Data from the existing units at the Oleander facility during these events were also supplied by the applicant. Although, these units are capable of fuel switching quickly at higher loads, the likelihood of malfunctions and trips are much greater when doing so. A trip of the unit can be detrimental from a maintenance standpoint. Any environmental gains of attempting to switch fuels only marginally more quickly, could be offset by the additional startup required following a “trip” of the unit. Based on information obtained, the Department agrees that by reasonably balancing best management practices to minimize both environmental and maintenance impacts, fuel switching for this unit (including both gas-to-oil and oil-to-gas switches), may routinely require periods greater than 30 minutes.

The Department will modify Section III, Part A, Condition 24(e) to allow additional time for fuel switches. Additionally, the word “shutdown” will be replaced with “fuel switching” to correct a typing error. The condition will be modified as follows:

- e. *Fuel Switching:* Up to ~~30~~ 60 minutes of CEMS data may be excluded for each ~~oil-to-gas~~ fuel switch. For fuel switches of less than ~~30~~ 60 minutes in duration, only those minutes attributable to ~~shutdown~~ fuel switching may be excluded.
- 2) *Specific Condition 28.f covers CEMS Availability.* It is Southern Power’s opinion that 95% monitor availability requirement should have a minimum number of operational hours boundary, due to the possibility of low operational hour units (i.e. peaking units) could easily exceed the > 95% availability threshold with just a few monitor issues. Although any future such issue could be handled by the Department taking enforcement discretion, such an event will penalize Southern Power in the annual Certification of Compliance. In order to alleviate this possible issue, Southern Power suggest a minimum of 760 operating hour as a threshold for the >95% availability requirement.

### Response

Monitor downtime typically includes periods when the monitor is functioning properly, but is not collecting emissions data due to calibrations or other systems quality performance checks. The Department agrees that minimal operation could significantly increase monitor downtime on a percentage basis without properly reflecting the system’s true availability.

The following changes will be made to Section III, Part A, Condition 28(f):

- f. *Availability:* The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for the CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. ~~The quarterly excess emissions report shall be used to demonstrate monitor availability.~~ In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department’s Compliance Authority.

The final decision by the Department is to issue the permit with the changes noted.



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

## PERMITTEE:

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, Florida 32926

### *Authorized Representative:*

James O. Vick, Director Environmental Affairs

Oleander Power Project
Simple Cycle Unit 5
Permit No. PSD-FL-377
Project No. 0090180-003-AC
Expires: June 1, 2008

## PROJECT AND LOCATION

This permit authorizes the construction of a nominal 190 MW simple cycle combustion turbine electrical generator at the existing Oleander Power Project. The facility is located in Cocoa just off Interstate 95 and State Road 520 in Brevard County.

## STATEMENT OF BASIS

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The project was processed in accordance with the requirements of Rule 62-212.400, F.A.C., the preconstruction review program for the Prevention of Significant Deterioration (PSD) of Air Quality. The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

Joseph Kahn, Director  
Division of Air Resource Management

"More Protection, Less Process"

Printed on recycled paper.



## SECTION I - GENERAL INFORMATION

### FACILITY DESCRIPTION

The regulated emissions units at the existing Oleander Power Project include four nominal 190 MW simple cycle combustion turbines (Units 001 through 004) capable of firing either natural gas or low-sulfur fuel oil (0.05 percent sulfur), and two 1.8 million-gallon fuel oil storage tanks (Units 006 and 007).

### PROJECT DESCRIPTION

The project is for the construction of one additional General Electric PG7241(FA) simple cycle combustion turbine electrical generator (Unit 5) equipped with evaporative cooling, capable of firing natural gas, with a nominal output of 190 megawatts. The project also includes the installation of one 900,000 gallon distillate fuel oil storage tank. Low sulfur fuel oil will be used as a backup fuel to the combustion turbine.

### NEW EMISSIONS UNITS

This permit authorizes construction and installation of the following new emissions units:

EU ID NO.	EMISSION UNIT DESCRIPTION
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.
008	Unit 8- One 900,000 gallon distillate fuel oil storage tank.

### REGULATORY CLASSIFICATION

*Title I, Part C, Clean Air Act (CAA):* The facility is a PSD-major facility pursuant to Rule 62-212, F.A.C.

*Title I, Section 111, CAA:* Unit 5 is subject to the New Source Performance Standards of 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines).

*Title I, Section 112, CAA:* The facility is not a "Major Source" of hazardous air pollutants (HAPs).

*Title IV, CAA:* The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

*Title V, CAA:* The facility is a Title V or "Major Source of air pollution" in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), sulfuric acid mist (SAM), and volatile organic compounds (VOC).

*CAIR:* As an electric generating unit, Unit 5 may be subject to the Clean Air Interstate Rule pending the finalization of DEP rules.

### PERMITTING AUTHORITY

All documents related to applications for permits to construct, operate or modify an emissions unit shall be submitted to the Bureau of Air Regulation of the Florida Department of Environmental Protection (DEP) at 2600 Blair Stone Road (MS #5505), Tallahassee, Florida 32399-2400. Copies of all such documents shall also be submitted to the Compliance Authority.

### COMPLIANCE AUTHORITY

All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Department of Environmental Protection Central District, 3319 Maguire Boulevard, Suite 232, Orlando, Florida 32803-3767.

## SECTION I - GENERAL INFORMATION

---

### APPENDICES

The following Appendices are attached as part of this permit.

Appendix A	NSPS Subparts A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

### RELEVANT DOCUMENTS:

The documents listed below are not a part of this permit, however they are specifically related to this permitting action and are on file with the Department.

- Application for Air Construction Permit received on May 4, 2006;
- Department's Request for Additional Information dated June 2, 2006;
- Applicant's Response to Request for Additional Information Received July 13, 2006 (complete);
- Department's Intent to Issue and Public Notice Package distributed October 10, 2006;
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.

## SECTION II. ADMINISTRATIVE REQUIREMENTS

---

1. General Conditions: The permittee shall operate under the attached General Conditions listed in Appendix GC of this permit. General Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
2. Applicable Regulations, Forms and Application Procedures: Unless otherwise indicated in this permit, the construction and operation of the subject emissions unit shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403 of the Florida Statutes (F.S.); Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.); and the Title 40, Parts 51, 52, 60, 63, 72, 73, and 75 of the Code of Federal Regulations (CFR), adopted by reference in Rule 62-204.800, F.A.C. The terms used in this permit have specific meanings as defined in the applicable chapters of the Florida Administrative Code. The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations. [Rules 62-204.800, 62-210.300 and 62-210.900, F.A.C.]
3. Construction and Expiration: Authorization to construct shall expire if construction is not commenced within 18 months after receipt of the permit, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. This provision does not apply to the time period between construction of the approved phases of a phased construction project except that each phase must commence construction within 18 months of the commencement date established by the Department in the permit. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. In conjunction with an extension of the 18-month period to commence or continue construction (or to construct the project in phases), the Department may require the permittee to demonstrate the adequacy of any previous determination of Best Available Control Technology (BACT) for emissions units regulated by the project. For good cause, the permittee may request that this PSD air construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation at least sixty (60) days prior to the expiration of this permit. [Rules 62-4.070(4), 62-4.080, 62-210.300(1), and 62-212.400(12), F.A.C.]
4. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
5. Source Obligation.
  - a. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.
  - b. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by exceeding its projected actual emissions, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.

[Rule 62-212.400(12), F.A.C.]

## SECTION II. ADMINISTRATIVE REQUIREMENTS

---

6. Modifications: No emissions unit or facility subject to this permit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. This permit authorizes construction of the referenced facilities.  
[Chapters 62-210 and 62-212, F.A.C.]
7. Application for Title IV Permit: At least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW, the permittee shall submit an application for a Title IV Acid Rain Permit to the Department's Bureau of Air Regulation in Tallahassee and a copy to the Region 4 Office of the U.S. Environmental Protection Agency in Atlanta, Georgia. [40 CFR 72]
8. Title V Permit: This permit authorizes construction of the permitted emissions unit and initial operation to determine compliance with Department rules. A Title V operation permit is required for regular operation of the permitted emission units. The permittee shall apply for and obtain a Title V operation permit in accordance with Rule 62-213.420, F.A.C. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the Department's Bureau of Air Regulation and a copy to the Compliance Authority.  
[Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The specific conditions of this subsection apply to the following emissions unit after construction is complete.

E.U. ID	Emission Unit Description
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.

#### APPLICABLE STANDARDS AND REGULATIONS

1. **BACT Determinations:** A determination of the Best Available Control Technology (BACT) was made for nitrogen oxides (NO<sub>x</sub>), and particulate matter (PM/PM<sub>10</sub>). [Rule 62-210.200 (BACT), F.A.C.]
2. **NSPS Requirements:** This unit shall comply with the applicable New Source Performance Standards (NSPS) in 40 CFR 60, including: Subpart A (General Provisions) and Subpart KKKK (Standards of Performance for Stationary Gas Turbines). See Appendix A and Appendix KKKK of this permit. The BACT emissions standards for NO<sub>x</sub> and the fuel sulfur specifications for PM/PM<sub>10</sub> are as stringent as, or more stringent than the NO<sub>x</sub> and SO<sub>2</sub> limits imposed by the applicable NSPS provisions. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(7)(b), F.A.C.; 40 CFR 60, Subparts A and KKKK]

#### EQUIPMENT DESCRIPTION

3. **Combustion Turbine:** The permittee is authorized to install, tune, operate, and maintain one General Electric Model PG7241FA gas turbine-electrical generator set with a nominal generating capacity of 190 MW. The combustion turbine will be equipped with GE's DLN combustor, and an inlet air filtration system with evaporative coolers. The combustion turbine will be designed for operation in simple cycle mode and will have dual-fuel capability. [Application; Design]

#### CONTROL TECHNOLOGY

4. **DLN Combustion:** The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO<sub>x</sub> emissions from the combustion turbine when firing natural gas. Prior to the initial emissions performance tests required for the gas turbine, the DLN combustors and automated gas turbine control system shall be tuned to achieve the permitted levels for NO<sub>x</sub>. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Design; Rule 62-212.400(10)(BACT), F.A.C.]
5. **Wet Injection:** The permittee shall install, operate, and maintain a water injection system to reduce NO<sub>x</sub> emissions from the combustion turbine when firing distillate fuel oil. Prior to the initial emissions performance tests, the water injection system shall be tuned to achieve sufficiently low NO<sub>x</sub> values to meet the NO<sub>x</sub> limits of this permit. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Applicant request; Rule 62-212.400(10)(BACT), F.A.C.]

#### PERFORMANCE REQUIREMENTS

6. **Hours of Operation:** The combustion turbine may operate no more than 3,390 hours per calendar year. Restrictions on individual methods of operation are specified in separate conditions. [Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD), F.A.C.]
7. **Permitted Capacity:** The nominal heat input rate to the combustion turbine is 1,722 MMBtu per hour when firing natural gas and 1,920 MMBtu per hour when firing fuel oil (based on a compressor inlet air temperature of 59° F, the lower heating value (LHV) of each fuel, and 100% load). Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department.

[Rule 62-210.200(PTE), F.A.C.]

8. **Authorized Fuels:** The combustion turbine shall fire natural gas as the primary fuel, which shall contain no more than 1.5 grains of sulfur per 100 standard cubic feet of natural gas. As a restricted alternate fuel, the combustion turbine may fire low sulfur fuel oil containing no more than 0.05% sulfur by weight. The gas turbine shall fire no more than 500 hours of fuel oil, during any calendar year.  
[Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD, and PSD Avoidance), F.A.C.]
9. **Simple Cycle, Intermittent Operation:** The turbine shall operate only in simple cycle mode not to exceed the permitted hours of operation allowed by this permit. This restriction is based on the permittee's request, which formed the basis of the PSD applicability and BACT determination and resulted in the emission standards specified in this permit. For any request to convert this unit to combined cycle operation by installing/connecting to heat recovery steam generators, including changes to the fuel quality or quantity related to combined cycle conversion which may cause an increase in short or long-term emissions, the permittee may be required to submit a full PSD permit application complete with a new proposal of the best available control technology as if the unit had never been built.  
[Rules 62-212.400(12) and 62-212.400(BACT), F.A.C.]

#### EMISSIONS AND TESTING REQUIREMENTS

10. **Emission Standards:** Emissions from the combustion turbine shall not exceed the following standards.

Pollutant	Emission Standard <sup>c</sup>	Averaging Time	Compliance Method	Basis
NO <sub>x</sub> (Gas)	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr rolling	CEMS	BACT
	62.5 lb/hr	3 1-hr runs	Stack Test	
NO <sub>x</sub> (Oil)	42.0 ppmvd @ 15% O <sub>2</sub>	4-hr rolling	CEMS	NSPS
	336.8 lb/hr	3 1-hr runs	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	10 % Opacity	6-minute block	Visible Emissions Test	BACT
	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	PSD Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the visible emissions standard shall serve as an indicator of good combustion.
- b. The fuel sulfur specifications and limited hours of operation effectively limit the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from the gas turbine.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

*{Permitting Note: In combination with the annual restriction on hours of operation, the above emissions standards effectively limit annual potential emissions from the combustion turbine to: 174.5 tons/year of NO<sub>x</sub>, 34.5 tons/year of PM/PM<sub>10</sub>, and 37.1 tons/year of SO<sub>2</sub>.}*

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD and PSD Avoidance), F.A.C, and 40 CFR 60, Subpart KKKK]

11. **Nitrogen Oxides (NO<sub>x</sub>):** Emissions of NO<sub>x</sub> from the CT shall not exceed the following standards on a continuous basis and as measured by the required CEMS for the averaging period specified, and as measured during the required stack tests.

a. *While firing natural gas:*

9.0 ppmvd @ 15% O<sub>2</sub> on a 24-hour rolling average (as measured by the required CEMS and defined by this permit)

62.5 /lb/hr (3 1-hr run stack test)

b. *While firing fuel oil:*

42.0 ppmvd @ 15% O<sub>2</sub> on a 4-hr rolling average (as measured by the required CEMS and defined by subpart KKKK attached as an Appendix to this permit)

336.8 lb/hr (3 1-hr run stack test)

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD), F.A.C, and 40 CFR 60.4380]

12. **Sulfur Dioxide (SO<sub>2</sub>):**

a. *While firing natural gas:* The fuel sulfur specifications, established in condition 8 of this subsection, of 1.5 grains per 100 standard cubic feet effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing natural gas.

b. *While firing fuel oil:* The fuel sulfur specification, established in condition 8 of this subsection, of 0.05 % sulfur by weight effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing fuel oil.

[Rules 62-4.070(3), and 62-212.400 (PSD Avoidance), F.A.C]

13. **Particulate Matter (PM/PM<sub>10</sub>):** The fuel sulfur specifications, established in condition 8 of this subsection, combined with the efficient combustion, design, and operation of the combustion turbine represent BACT for PM/PM10 emissions. Compliance with the fuel specifications and visible emissions standard shall serve as indicators of good combustion. Visible emissions shall not exceed 10 % opacity as observed during the required 30-minute visible emissions tests.

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD), and 62-297.310(4)(a)2, F.A.C]

14. **Unconfined Particulate Emissions:** During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering, confining, or applying water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

15. **Test Methods:** Required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of NO <sub>x</sub> Emissions (Instrumental).
9	Visual Determination of Opacity
20	Determination of NO <sub>x</sub> , SO <sub>2</sub> , and Diluent Emissions from Stationary Gas Turbines

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C. [Rules 62-204.800, F.A.C.; 40 CFR 60, Appendix A]

16. **Testing Requirements:** Initial tests shall be conducted between 90% and 100% of permitted capacity; otherwise, this permit shall be modified to reflect the true maximum capacity as constructed. Subsequent annual tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. Tests shall be conducted for each pollutant while firing each fuel in the CT. For each run during tests for visible emissions, emissions of NO<sub>x</sub> recorded by the CEMS shall also be reported. Data collected from the reference method during the required CEMS quality assurance RATA tests may substitute for annual compliance tests for NO<sub>x</sub>, provided the owner or operator indicates this intent in the submitted test protocol, and obtains approval prior to testing. If the RATA is conducted at less than permitted capacity, and the data is used for annual compliance, the requirements of 62-297.310(2) (Operating Rate During Testing) still apply. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department. [Rule 62-297.310(2), and (7)(a), F.A.C.; and 40 CFR 60.8]
17. **Initial Compliance Demonstration:** Initial compliance stack tests while firing natural gas shall be conducted within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup. Initial testing on fuel oil shall be conducted within 60 days of any fuel oil firing in the CT. In accordance with the test methods specified in this permit, the combustion turbine shall be tested to demonstrate initial compliance with the emission standards for NO<sub>x</sub> and with the visible emissions standard. The permittee shall provide the Compliance Authority with any other initial emissions performance tests conducted to satisfy vendor guarantees including CO and particulate tests. [Rules 62-4.070, 62-297.310(7)(a), F.A.C. and 40 CFR 60.8]
18. **Subsequent Compliance Testing:** Annual compliance tests for NO<sub>x</sub>, and visible emissions shall be conducted during each federal fiscal year (October 1<sup>st</sup>, to September 30<sup>th</sup>). If normal operation on fuel oil is less than 400 hours per calendar year, then subsequent compliance testing on fuel oil is not required for that year. If normal operation on fuel oil exceeds 400 hours per year, the Department shall require compliance testing for NO<sub>x</sub> and visible emissions while firing fuel oil. [Rules 62-4.070, 62-210.200(BACT), and 62-297.310(7)(a)4, F.A.C.]
19. **Continuous Compliance:** Continuous compliance with the permit standard for emissions of NO<sub>x</sub> shall be demonstrated with data collected from the required continuous monitoring system. [Rules 62-4.070, and 62-210.200(BACT), F.A.C.]
20. **Special Compliance Tests:** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

### EXCESS EMISSIONS

*{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Condition No 10 and 11 of this subsection. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, NESHAP, or Acid Rain programs.}*



## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

#### 21. Definitions:

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose.
- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

*{Permitting Note: The applicant has described startup of this unit as the period from 0 to 50% load, and shutdown as the period beginning at 50 % load to no load operation.}*

[Rule 62-210.200(165, 242, and 258), F.A.C.]

22. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]
23. Data Exclusion Procedures for SIP Compliance: As per the procedures in this condition, limited amounts of CEMS emissions data, as specified in condition 24, may be excluded from the corresponding SIP-based compliance demonstration, provided that best operational practices to minimize emissions are adhered to, the duration of data excluded is minimized, and the procedures for data exclusion listed below are followed. As provided by the authority in Rule 62-210.700(5), F.A.C., these conditions replace the provisions in Rule 62-210.700(1), F.A.C.
  - a. *Limiting Data Exclusion.* If the compliance calculation using all valid CEMS emission data indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
  - b. *Event Driven Exclusion.* There must be an underlying event (startup, shutdown, malfunction, or fuel switching) in order to exclude data. If there is no underlying event, then no data may be excluded.
  - c. *Continuous Exclusion.* Data shall be excluded on a continuous basis. Data from discontinuous periods shall not be excluded for the same underlying event.

[Rule 62-210.700 F.A.C.]

24. Allowable Data Exclusions: The following data may be excluded from the corresponding SIP-based compliance demonstration for each of the events listed below in accordance with the Data Exclusion Procedures of condition 23:

- a. *Startup:* Up to 30 minutes of CEMS data may be excluded for each combustion turbine startup. For startups of less than 30 minutes in duration, only those minutes attributable to startup may be excluded.
- b. *Shutdown:* Up to 30 minutes of CEMS data may be excluded for each combustion turbine shutdown. For shutdowns of less than 30 minutes in duration, only those minutes attributable to shutdown may be excluded.
- c. *Malfunction:* Up to two hours (in any operating day) of CEMS data may be excluded due to a documented malfunction. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic email.

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- d. *DLN Tuning*: CEMS data collected during initial or other DLN tuning sessions may be excluded from the compliance demonstrations provided the tuning session is performed in accordance with the manufacturer's specifications or determined best practices. Prior to performing any tuning session, the permittee shall provide the Compliance Authority with an advance notice of at least one (1) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Design; Rule 62-4.070(3), F.A.C.]
- e. *Fuel Switching*: Up to 60 minutes of CEMS data may be excluded for each fuel switch. For fuel switches of less than 60 minutes in duration, only those minutes attributable to fuel switching may be excluded.

All valid emissions data (including data collected during startup, shutdown, malfunction, DLN tuning, and fuel switching) shall be used to report emissions for the Annual Operating Report.

[Rules 62-210.200(BACT), 62-210.370, and 62-210.700, F.A.C.]

- 25. Notification Requirements: The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate non-compliance for a given averaging period. [Rule 62-4.070, F.A.C.]

### CONTINUOUS MONITORING REQUIREMENTS

- 26. CEM Systems: Subject to the following, the permittee shall install, calibrate, operate, and maintain a continuous emission monitoring system (CEMS) to measure and record the emissions of NO<sub>x</sub> from the combustion turbine in terms of the applicable standards. The monitoring system shall be installed, and functioning within the required performance specifications by the time of the initial compliance demonstration.
  - a. *NO<sub>x</sub> Monitor*: Each NO<sub>x</sub> monitor shall be certified pursuant to the specifications of 40 CFR 75. Quality assurance procedures shall conform to the requirements of 40 CFR 75. The annual and required RATA tests required for the NO<sub>x</sub> monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.
  - b. *Diluent Monitor*: The oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) content of the flue gas shall be monitored at the location where NO<sub>x</sub> is monitored to correct the measured emissions rates to 15% oxygen. If a CO<sub>2</sub> monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

[Rules 62-4.070(3), 62-210.200(BACT), F.A.C., and 40 CFR 60, Subpart 75]

- 27. Moisture Correction: If necessary, the owner or operator shall determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). [Rules 62-4.070(3), 62-210.200(BACT), F.A.C.]

- 28. CEMS Data Requirements for BACT Standards:

*{Permitting Note: The following conditions apply only to the SIP-based NO<sub>x</sub> emissions standards specified in Condition Nos. 10-11 of this section. These requirements cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs. Additional reporting and monitoring may be required by the individual subparts.}*

- a. *Data Collection*: Except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments, emissions shall be monitored and recorded during all operation including startup, shutdown, and malfunction.

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- b. *Operating Hours and Operating Days:* An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
- c. *Valid Hour:* Each CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
- 1) Hours that are **not operating** hours are **not valid** hours.
  - 2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data and the 1-hour block average is not valid.
  - 3) During fuel switching an hour in which fuel oil is fired is attributed towards compliance with the permit standards for oil firing.
- d. *Rolling 24-Hour Average:* Compliance shall be determined after each valid hourly average is obtained by calculating the arithmetic average of that valid hourly average and the preceding 23 valid hourly averages.
- e. *Data Exclusion:* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, DLN tuning, and fuel switches. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of conditions 23 and 24 of this subsection.
- f. *Availability:* The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for the CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Compliance Authority.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

### CEMS REQUIREMENTS FOR ANNUAL EMISSIONS

29. CEMS Annual Emissions Requirement: The owner or operator shall use data from the NO<sub>x</sub> CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit. [Rules 62-210.200, and 62-210.370(3), F.A.C.]

### REPORTING AND RECORD KEEPING REQUIREMENTS

30. Monitoring of Capacity: The permittee shall monitor and record the operating rate of the combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction, DLN tuning, and fuel switching). Such monitoring shall be made by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

31. Monthly Operations Summary: By the 15th calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the combustion turbine for the previous month of operation: fuel consumption, hours of operation on each fuel, and the updated calendar year totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]
32. Fuel Sulfur Records: The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
- Natural Gas Sulfur Limit*: Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.
  - Distillate Fuel Oil Sulfur Limit*: Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91, D1552-90, D2622-94, or D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of the Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.
- The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]
33. Emissions Performance Test Reports: A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix SC of this permit. [Rule 62-297.310(8), F.A.C.].
34. Excess Emissions Reporting:
- Malfunction Notification*: If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
  - SIP Quarterly Report*: Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of NO<sub>x</sub> emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. A summary of data excluded from SIP compliance calculations should also be provided. In addition, the report shall summarize the NO<sub>x</sub> CEMS system monitor availability for the previous quarter.
  - NSPS Reporting*: Within 30 days following the calendar quarter, the permittee shall submit the written reports required by 40 CFR 60 Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) for the previous semi-annual period to the Compliance Authority.

### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

---

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

*{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}*

[Rules 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C., and 40 CFR 60.7 and 60.4375]

35. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating hours and emissions from this facility in accordance with 62-210.370. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

**SECTION IV – UNREGULATED EMISSIONS UNITS**

**A. Fuel Oil Storage Tank (EU 008)**

ID	Emission Unit Description
008	Unit 8– One 900,000 gallon distillate fuel oil storage tank.

**NSPS APPLICABILITY**

NSPS Subpart Kb Applicability: The distillate fuel oil storage tank is not subject to Subpart Kb which applies to storage vessels with a capacity greater than or equal to 75 cubic meters that is used to store volatile organic liquids for which construction, reconstruction, or modification is commenced after July 23, 1984. Tanks with a capacity greater than or equal to 151 cubic meters (40,000 gallons) storing a liquid with a maximum true vapor pressure less than 3.5 kPa, are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb. The fuel oil storage tank (EU 008) has a capacity greater than 151 cubic meters and the vapor pressure of the low sulfur fuel oil is less than 3.5 kPa, therefore NSPS Kb, including the monitoring requirements, does not apply to this unit.  
[40 CFR 60.110b(a) and (b), and 60.116b(c); Rule 62-204.800(7)(b), F.A.C.]

## SECTION IV. APPENDICES

---

### CONTENTS

Appendix A	NSPS Subpart A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

## SECTION IV. APPENDIX A

### NSPS SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

---

Emissions units subject to a New Source Performance Standard of 40 CFR 60 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

- § 60.1 Applicability.
- § 60.2 Definitions.
- § 60.3 Units and abbreviations.
- § 60.4 Address.
- § 60.5 Determination of construction or modification.
- § 60.6 Review of plans.
- § 60.7 Notification and Record Keeping.
- § 60.8 Performance Tests.
- § 60.9 Availability of information.
- § 60.10 State Authority.
- § 60.11 Compliance with Standards and Maintenance Requirements.
- § 60.12 Circumvention.
- § 60.13 Monitoring Requirements.
- § 60.14 Modification.
- § 60.15 Reconstruction.
- § 60.16 Priority List.
- § 60.17 Incorporations by Reference.
- § 60.18 General Control Device Requirements.
- § 60.19 General Notification and Reporting Requirements.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.



**SECTION IV. APPENDIX BD**

**FINAL BACT DETERMINATIONS AND EMISSIONS STANDARDS**

The Department establishes the following standards as the Best Available Control Technology for the simple cycle combustion turbine Unit 5 at the Oleander Power Project.

**BACT Determinations – Oleander Power Project Unit 5**

<b>Pollutant</b>	<b>Fuel</b>	<b>Emission Standard/Limit<sup>c</sup></b>	<b>Averaging Time</b>	<b>Compliance Method</b>	<b>Basis</b>
NO <sub>x</sub>	Gas	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr rolling	CEMS	BACT
		62.5 lb/hr	3-hr	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	Gas/Oil	10 % Opacity	6-minute block	Stack Test	BACT
		1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	Gas/Oil	1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	BACT Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the gas turbine represents (BACT) for PM/PM10 emissions.
- b. The fuel sulfur specifications effectively limit the potential emissions of SO2 and sulfuric acid mist (SAM) from the gas.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

## SECTION IV. APPENDIX GC

### GENERAL CONDITIONS

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
  - a. Have access to and copy and records that must be kept under the conditions of the permit;
  - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
  - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
  - a. A description of and cause of non-compliance; and
  - b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida

## SECTION IV. APPENDIX GC

### GENERAL CONDITIONS

Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
  - a. Determination of Best Available Control Technology (X);
  - b. Determination of Prevention of Significant Deterioration (X);
  - c. Compliance with National Emission Standards for Hazardous Air Pollutants (Not Applicable); and
  - d. Compliance with New Source Performance Standards (X).
14. The permittee shall comply with the following:
  - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - c. Records of monitoring information shall include:
    - 1) The date, exact place, and time of sampling or measurements;
    - 2) The person responsible for performing the sampling or measurements;
    - 3) The dates analyses were performed;
    - 4) The person responsible for performing the analyses;
    - 5) The analytical techniques or methods used; and
    - 6) The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

This subpart establishes emission standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification or reconstruction after February 18, 2005.

#### Applicability

##### § 60.4305 Does this subpart apply to my stationary combustion turbine?

(a) If you are the owner or operator of a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005, your turbine is subject to this subpart. Only heat input to the combustion turbine should be included when determining whether or not this subpart is applicable to your turbine. Any additional heat input to associated heat recovery steam generators (HRSG) or duct burners should not be included when determining your peak heat input. However, this subpart does apply to emissions from any associated HRSG and duct burners.

(b) Stationary combustion turbines regulated under this subpart are exempt from the requirements of subpart GG of this part. Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.

##### § 60.4310 What types of operations are exempt from these standards of performance?

- (a) Emergency combustion turbines, as defined in §60.4420(i), are exempt from the nitrogen oxides (NOX) emission limits in §60.4320.
- (b) Stationary combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements are exempt from the NOX emission limits in §60.4320 on a case-by-case basis as determined by the Administrator.
- (c) Stationary combustion turbines at integrated gasification combined cycle electric utility steam generating units that are subject to subpart Da of this part are exempt from this subpart.
- (d) Combustion turbine test cells/stands are exempt from this subpart.

#### Emission Limits

##### § 60.4315 What pollutants are regulated by this subpart?

The pollutants regulated by this subpart are nitrogen oxide (NOX) and sulfur dioxide (SO<sub>2</sub>).

##### § 60.4320 What emission limits must I meet for nitrogen oxides (NOX)?

- (a) You must meet the emission limits for NOX specified in Table 1 to this subpart.
- (b) If you have two or more turbines that are connected to a single generator, each turbine must meet the emission limits for NOX.

##### § 60.4325 What emission limits must I meet for NOX if my turbine burns both natural gas and distillate oil (or some other combination of fuels)?

You must meet the emission limits specified in Table 1 to this subpart. If your total heat input is greater than or equal to 50 percent natural gas, you must meet the corresponding limit for a natural gas-fired turbine when you are burning that fuel. Similarly, when your total heat input is greater than 50 percent distillate oil and fuels other than natural gas, you must meet the corresponding limit for distillate oil and fuels other than natural gas for the duration of the time that you burn that particular fuel.

##### § 60.4330 What emission limits must I meet for sulfur dioxide (SO<sub>2</sub>)?

(a) If your turbine is located in a continental area, you must comply with either paragraph (a)(1) or (a)(2) of this section. If your turbine is located in Alaska, you do not have to comply with the requirements in paragraph (a) of this section until January 1, 2008.

- (1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh)) gross output, or
- (2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

(b) If your turbine is located in a noncontinental area or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit, you must comply with one or the other of the following conditions:

- (1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 780 ng/J (6.2 lb/MWh) gross output, or

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total sulfur with potential sulfur emissions in excess of 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

#### General Compliance Requirements

##### § 60.4333 What are my general requirements for complying with this subpart?

(a) You must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.

(b) When an affected unit with heat recovery utilizes a common steam header with one or more combustion turbines, the owner or operator shall either:

(1) Determine compliance with the applicable NOX emissions limits by measuring the emissions combined with the emissions from the other unit(s) utilizing the common heat recovery unit; or

(2) Develop, demonstrate, and provide information satisfactory to the Administrator on methods for apportioning the combined gross energy output from the heat recovery unit for each of the affected combustion turbines. The Administrator may approve such demonstrated substitute methods for apportioning the combined gross energy output measured at the steam turbine whenever the demonstration ensures accurate estimation of emissions related under this part.

#### Monitoring

##### § 60.4335 How do I demonstrate compliance for NOX if I use water or steam injection?

(a) If you are using water or steam injection to control NOX emissions, you must install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine when burning a fuel that requires water or steam injection for compliance.

(b) Alternatively, you may use continuous emission monitoring, as follows:

(1) Install, certify, maintain, and operate a continuous emission monitoring system (CEMS) consisting of a NOX monitor and a diluent gas (oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>)) monitor, to determine the hourly NOX emission rate in parts per million (ppm) or pounds per million British thermal units (lb/MMBtu); and

(2) For units complying with the output-based standard, install, calibrate, maintain, and operate a fuel flow meter (or flow meters) to continuously measure the heat input to the affected unit; and

(3) For units complying with the output-based standard, install, calibrate, maintain, and operate a watt meter (or meters) to continuously measure the gross electrical output of the unit in megawatt-hours; and

(4) For combined heat and power units complying with the output-based standard, install, calibrate, maintain, and operate meters for useful recovered energy flow rate, temperature, and pressure, to continuously measure the total thermal energy output in British thermal units per hour (Btu/h).

##### § 60.4340 How do I demonstrate continuous compliance for NOX if I do not use water or steam injection?

(a) If you are not using water or steam injection to control NOX emissions, you must perform annual performance tests in accordance with §60.4400 to demonstrate continuous compliance. If the NOX emission result from the performance test is less than or equal to 75 percent of the NOX emission limit for the turbine, you may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NOX emission limit for the turbine, you must resume annual performance tests.

(b) As an alternative, you may install, calibrate, maintain and operate one of the following continuous monitoring systems:

(1) Continuous emission monitoring as described in §§60.4335(b) and 60.4345, or

(2) Continuous parameter monitoring as follows:

(i) For a diffusion flame turbine without add-on selective catalytic reduction (SCR) controls, you must define parameters indicative of the unit's NOX formation characteristics, and you must monitor these parameters continuously.

(ii) For any lean premix stationary combustion turbine, you must continuously monitor the appropriate parameters to determine whether the unit is operating in low-NOX mode.

(iii) For any turbine that uses SCR to reduce NOX emissions, you must continuously monitor appropriate parameters to verify the proper operation of the emission controls.

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

(iv) For affected units that are also regulated under part 75 of this chapter, with state approval you can monitor the NOX emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19, the requirements of this paragraph (b) may be met by performing the parametric monitoring described in section 2.3 of part 75 appendix E or in §75.19(c)(1)(iv)(H).

**§ 60.4345 What are the requirements for the continuous emission monitoring system equipment, if I choose to use this option?**

If the option to use a NOX CEMS is chosen:

- (a) Each NOX diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NOX diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.
- (b) As specified in §60.13(e)(2), during each full unit operating hour, both the NOX monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NOX emission rate for the hour.
- (c) Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.
- (d) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions.
- (e) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

**§ 60.4350 How do I use data from the continuous emission monitoring equipment to identify excess emissions?**

For purposes of identifying excess emissions:

- (a) All CEMS data must be reduced to hourly averages as specified in §60.13(h).
- (b) For each unit operating hour in which a valid hourly average, as described in §60.4345(b), is obtained for both NOX and diluent monitors, the data acquisition and handling system must calculate and record the hourly NOX emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of this part. For any hour in which the hourly average O2 concentration exceeds 19.0 percent O2 (or the hourly average CO2 concentration is less than 1.0 percent CO2), a diluent cap value of 19.0 percent O2 or 1.0 percent CO2 (as applicable) may be used in the emission calculations.
- (c) Correction of measured NOX concentrations to 15 percent O2 is not allowed.
- (d) If you have installed and certified a NOX diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under §60.7(c).
- (e) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages.
- (f) Calculate the hourly average NOX emission rates, in units of the emission standards under §60.4320, using either ppm for units complying with the concentration limit or the following equation for units complying with the output based standard:

(1) For simple-cycle operation:

$$E = \frac{(NO_x)_h * (HI)_h}{P} \quad (\text{Eq. 1})$$

Where:

E = hourly NOX emission rate, in lb/MWh, (NOX)<sub>h</sub> = hourly NOX emission rate, in lb/MMBtu,

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

(HI)h = hourly heat input rate to the unit, in MMBtu/h, measured using the fuel flowmeter(s), e.g., calculated using Equation D-15a in appendix D to part 75 of this chapter, and

P = gross energy output of the combustion turbine in MW.

(2) For combined-cycle and combined heat and power complying with the output-based standard, use Equation 1 of this subpart, except that the gross energy output is calculated as the sum of the total electrical and mechanical energy generated by the combustion turbine, the additional electrical or mechanical energy (if any) generated by the steam turbine following the heat recovery steam generator, and 100 percent of the total useful thermal energy output that is not used to generate additional electricity or mechanical output, expressed in equivalent MW, as in the following equations:

$$P = (Pe)_e + (Pe)_m + Ps + Po \quad (\text{Eq. 2})$$

Where:

P = gross energy output of the stationary combustion turbine system in MW.

(Pe)t = electrical or mechanical energy output of the combustion turbine in MW,

(Pe)c = electrical or mechanical energy output (if any) of the steam turbine in MW, and

$$Ps = \frac{Q * H}{3.413 \times 10^6 \text{ Btu/MWh}} \quad (\text{Eq. 3})$$

Where:

Ps = useful thermal energy of the steam, measured relative to ISO conditions, not used to generate additional electric or mechanical output, in MW,

Q = measured steam flow rate in lb/h,

H = enthalpy of the steam at measured temperature and pressure relative to ISO conditions, in Btu/lb, and  $3.413 \times 10^6 =$  conversion from Btu/h to MW.

Po = other useful heat recovery, measured relative to ISO conditions, not used for steam generation or performance enhancement of the combustion turbine.

(3) For mechanical drive applications complying with the output-based standard, use the following equation:

$$E = \frac{(NO_x)_m}{BL * AL} \quad (\text{Eq. 4})$$

Where:

E = NOX emission rate in lb/MWh,

(NOX)m = NOX emission rate in lb/h,

BL = manufacturer's base load rating of turbine, in MW, and

AL = actual load as a percentage of the base load.

(g) For simple cycle units without heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 4-hour rolling average basis, as described in §60.4380(b)(1).

(h) For combined cycle and combined heat and power units with heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 30 unit operating day rolling average basis, as described in §60.4380(b)(1).

**§ 60.4355 How do I establish and document a proper parameter monitoring plan?**

(a) The steam or water to fuel ratio or other parameters that are continuously monitored as described in §§60.4335 and 60.4340 must be monitored during the performance test required under §60.8, to establish acceptable values and ranges. You may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. You must develop and keep onsite a parameter monitoring plan which explains the procedures used to document proper operation of the NOX emission controls. The plan must:

(1) Include the indicators to be monitored and show there is a significant relationship to emissions and proper operation of the NOX emission controls,

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

- (2) Pick ranges (or designated conditions) of the indicators, or describe the process by which such range (or designated condition) will be established,
- (3) Explain the process you will use to make certain that you obtain data that are representative of the emissions or parameters being monitored (such as detector location, installation specification if applicable),
- (4) Describe quality assurance and control practices that are adequate to ensure the continuing validity of the data,
- (5) Describe the frequency of monitoring and the data collection procedures which you will use (e.g., you are using a computerized data acquisition over a number of discrete data points with the average (or maximum value) being used for purposes of determining whether an exceedance has occurred), and
- (6) Submit justification for the proposed elements of the monitoring. If a proposed performance specification differs from manufacturer recommendation, you must explain the reasons for the differences. You must submit the data supporting the justification, but you may refer to generally available sources of information used to support the justification. You may rely on engineering assessments and other data, provided you demonstrate factors which assure compliance or explain why performance testing is unnecessary to establish indicator ranges. When establishing indicator ranges, you may choose to simplify the process by treating the parameters as if they were correlated. Using this assumption, testing can be divided into two cases:
  - (i) All indicators are significant only on one end of range (e.g., for a thermal incinerator controlling volatile organic compounds (VOC) it is only important to insure a minimum temperature, not a maximum). In this case, you may conduct your study so that each parameter is at the significant limit of its range while you conduct your emissions testing. If the emissions tests show that the source is in compliance at the significant limit of each parameter, then as long as each parameter is within its limit, you are presumed to be in compliance.
  - (ii) Some or all indicators are significant on both ends of the range. In this case, you may conduct your study so that each parameter that is significant at both ends of its range assumes its extreme values in all possible combinations of the extreme values (either single or double) of all of the other parameters. For example, if there were only two parameters, A and B, and A had a range of values while B had only a minimum value, the combinations would be A high with B minimum and A low with B minimum. If both A and B had a range, the combinations would be A high and B high, A low and B low, A high and B low, A low and B high. For the case of four parameters all having a range, there are 16 possible combinations.

(b) For affected units that are also subject to part 75 of this chapter and that have state approval to use the low mass emissions methodology in §75.19 or the NOX emission measurement methodology in appendix E to part 75, you may meet the requirements of this paragraph by developing and keeping onsite (or at a central location for unmanned facilities) a QA plan, as described in §75.19(e)(5) or in section 2.3 of appendix E to part 75 of this chapter and section 1.3.6 of appendix B to part 75 of this chapter.

#### **§ 60.4360 How do I determine the total sulfur content of the turbine's combustion fuel?**

You must monitor the total sulfur content of the fuel being fired in the turbine, except as provided in §60.4365. The sulfur content of the fuel must be determined using total sulfur methods described in §60.4415. Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than half the applicable limit, ASTM D4084, D4810, D5504, or D6228, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17), which measure the major sulfur compounds, may be used.

#### **§ 60.4365 How can I be exempted from monitoring the total sulfur content of the fuel?**

You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for units located in continental areas and 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for units located in noncontinental areas or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit. You must use one of the following sources of information to make the required demonstration:

- (a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for oil use in continental areas is 0.05 weight percent (500 ppmw) or less and 0.4 weight percent (4,000 ppmw) or less for noncontinental areas, the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet and 140 grains of sulfur or less per 100 standard cubic feet for noncontinental areas, has potential sulfur emissions of less than less than 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas and has potential sulfur emissions of less than less than 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas; or
- (b) Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas or 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.



## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

#### § 60.4370 How often must I determine the sulfur content of the fuel?

The frequency of determining the sulfur content of the fuel must be as follows:

(a) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (*i.e.*, flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank).

(b) *Gaseous fuel.* If you elect not to demonstrate sulfur content using options in §60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and recorded once per unit operating day.

(c) *Custom schedules.* Notwithstanding the requirements of paragraph (b) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (c)(1) and (c)(2) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.4330.

(1) The two custom sulfur monitoring schedules set forth in paragraphs (c)(1)(i) through (iv) and in paragraph (c)(2) of this section are acceptable, without prior Administrative approval:

(i) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (c)(1)(ii), (iii), or (iv) of this section, as applicable.

(ii) If none of the 30 daily measurements of the fuel's total sulfur content exceeds half the applicable standard, subsequent sulfur content monitoring may be performed at 12-month intervals. If any of the samples taken at 12-month intervals has a total sulfur content greater than half but less than the applicable limit, follow the procedures in paragraph (c)(1)(iii) of this section. If any measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section.

(iii) If at least one of the 30 daily measurements of the fuel's total sulfur content is greater than half but less than the applicable limit, but none exceeds the applicable limit, then:

(A) Collect and analyze a sample every 30 days for 3 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(B) of this section.

(B) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(C) of this section.

(C) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, continue to monitor at this frequency.

(iv) If a sulfur content measurement exceeds the applicable limit, immediately begin daily monitoring according to paragraph (c)(1)(i) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than the applicable limit, are obtained. At that point, the applicable procedures of paragraph (c)(1)(ii) or (iii) of this section shall be followed.

(2) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(i) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf, no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(ii) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds half the applicable limit, then the minimum required sampling frequency shall be one sample at 12 month intervals.

(iii) If any sample result exceeds half the applicable limit, but none exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iii) of this section.

(iv) If the sulfur content of any of the 720 hourly samples exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iv) of this section.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

#### Reporting

##### § 60.4375 What reports must I submit?

- (a) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.
- (b) For each affected unit that performs annual performance tests in accordance with §60.4340(a), you must submit a written report of the results of each performance test before the close of business on the 60th day following the completion of the performance test.

##### § 60.4380 How are excess emissions and monitor downtime defined for NOX?

For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that must be reported are defined as follows:

- (a) For turbines using water or steam to fuel ratio monitoring:
- (1) An excess emission is any unit operating hour for which the 4-hour rolling average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.4320, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine when a fuel is being burned that requires water or steam injection for NOX control will also be considered an excess emission.
  - (2) A period of monitor downtime is any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
  - (3) Each report must include the average steam or water to fuel ratio, average fuel consumption, and the combustion turbine load during each excess emission.
- (b) For turbines using continuous emission monitoring, as described in §§60.4335(b) and 60.4345:
- (1) An excess emissions is any unit operating period in which the 4-hour or 30-day rolling average NOX emission rate exceeds the applicable emission limit in §60.4320. For the purposes of this subpart, a "4- hour rolling average NOX emission rate" is the arithmetic average of the average NOX emission rate in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given hour and the three unit operating hour average NOX emission rates immediately preceding that unit operating hour. Calculate the rolling average if a valid NOX emission rate is obtained for at least 3 of the 4 hours. For the purposes of this subpart, a "30-day rolling average NOX emission rate" is the arithmetic average of all hourly NOX emission data in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given day and the twenty-nine unit operating days immediately preceding that unit operating day. A new 30-day average is calculated each unit operating day as the average of all hourly NOX emissions rates for the preceding 30 unit operating days if a valid NOX emission rate is obtained for at least 75 percent of all operating hours.
  - (2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NOX concentration, CO2 or O2 concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if you will use this information for compliance purposes.
  - (3) For operating periods during which multiple emissions standards apply, the applicable standard is the average of the applicable standards during each hour. For hours with multiple emissions standards, the applicable limit for that hour is determined based on the condition that corresponded to the highest emissions standard.
- (c) For turbines required to monitor combustion parameters or parameters that document proper operation of the NOX emission controls:
- (1) An excess emission is a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
  - (2) A period of monitor downtime is a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

##### § 60.4385 How are excess emissions and monitoring downtime defined for SO2?

If you choose the option to monitor the sulfur content of the fuel, excess emissions and monitoring downtime are defined as follows:

- (a) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the combustion turbine exceeds the applicable limit and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(b) If the option to sample each delivery of fuel oil has been selected, you must immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.05 weight percent. You must continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and you must evaluate excess emissions according to paragraph (a) of this section. When all of the fuel from the delivery has been burned, you may resume using the as-delivered sampling option.

(c) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

#### § 60.4390 What are my reporting requirements if I operate an emergency combustion turbine or a research and development turbine?

(a) If you operate an emergency combustion turbine, you are exempt from the NOX limit and must submit an initial report to the Administrator stating your case.

(b) Combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements may be exempted from the NOX limit on a case-by-case basis as determined by the Administrator. You must petition for the exemption.

#### § 60.4395 When must I submit my reports?

All reports required under §60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

#### Performance Tests

#### § 60.4400 How do I conduct the initial and subsequent performance tests, regarding NOX?

(a) You must conduct an initial performance test, as required in §60.8. Subsequent NOX performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).

(1) There are two general methodologies that you may use to conduct the performance tests. For each test run:

(i) Measure the NOX concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NOX emission rate:

$$E = \frac{1.194 \times 10^{-7} * (NOX)_c * Q_{std}}{P} \quad (\text{Eq. 5})$$

Where:

E = NOX emission rate, in lb/MWh

$1.194 \times 10^{-7}$  = conversion constant, in lb/dscf-ppm

(NOX)<sub>c</sub> = average NOX concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(ii) Measure the NOX and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NOX emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the NOX emission rate in lb/MWh.

(2) Sampling traverse points for NOX and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multihole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NOX and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NOX concentrations is within  $\pm 10$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 5$  ppm or  $\pm 0.5$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average NOX concentration during the stratification test; or

(B) For turbines with a NOX standard greater than 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NOX concentrations is within  $\pm 5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 3$  ppm or  $\pm 0.3$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points; or

(C) For turbines with a NOX standard less than or equal to 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NOX concentrations is within  $\pm 2.5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 1$  ppm or  $\pm 0.15$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

(2) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), you must measure the total NOX emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test.

(3) If water or steam injection is used to control NOX with no additional post-combustion NOX control and you choose to monitor the steam or water to fuel ratio in accordance with §60.4335, then that monitoring system must be operated concurrently with each EPA Method 20 or EPA Method 7E run and must be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.4320 NOX emission limit.

(4) Compliance with the applicable emission limit in §60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NOX emission rate at each tested level meets the applicable emission limit in §60.4320.

(5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in §60.4405) as part of the initial performance test of the affected unit.

(6) The ambient temperature must be greater than 0 °F during the performance test.

#### § 60.4405 How do I perform the initial performance test if I have chosen to install a NOX-diluent CEMS?

If you elect to install and certify a NOX-diluent CEMS under §60.4345, then the initial performance test required under §60.8 may be performed in the following alternative manner:

(a) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs.

(b) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit.

(c) Use the test data both to demonstrate compliance with the applicable NOX emission limit under §60.4320 and to provide the required reference method data for the RATA of the CEMS described under §60.4335.

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

(d) Compliance with the applicable emission limit in §60.4320 is achieved if the arithmetic average of all of the NOX emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit.

**§ 60.4410 How do I establish a valid parameter range if I have chosen to continuously monitor parameters?**

If you have chosen to monitor combustion parameters or parameters indicative of proper operation of NOX emission controls in accordance with §60.4340, the appropriate parameters must be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.4355.

**§ 60.4415 How do I conduct the initial and subsequent performance tests for sulfur?**

(a) You must conduct an initial performance test, as required in §60.8. Subsequent SO2 performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). There are three methodologies that you may use to conduct the performance tests.

(1) If you choose to periodically determine the sulfur content of the fuel combusted in the turbine, a representative fuel sample would be collected following ASTM D5287 (incorporated by reference, see §60.17) for natural gas or ASTM D4177 (incorporated by reference, see §60.17) for oil. Alternatively, for oil, you may follow the procedures for manual pipeline sampling in section 14 of ASTM D4057 (incorporated by reference, see §60.17). The fuel analyses of this section may be performed either by you, a service contractor retained by you, the fuel vendor, or any other qualified agency. Analyze the samples for the total sulfur content of the fuel using:

- (i) For liquid fuels, ASTM D129, or alternatively D1266, D1552, D2622, D4294, or D5453 (all of which are incorporated by reference, see §60.17); or
- (ii) For gaseous fuels, ASTM D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17).

(2) Measure the SO2 concentration (in parts per million (ppm)), using EPA Methods 6, 6C, 8, or 20 in appendix A of this part. In addition, the American Society of Mechanical Engineers (ASME) standard, ASME PTC 19–10–1981–Part 10, “Flue and Exhaust Gas Analyses,” manual methods for sulfur dioxide (incorporated by reference, see §60.17) can be used instead of EPA Methods 6 or 20. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then use the following equation to calculate the SO2 emission rate:

$$E = \frac{1.664 \times 10^{-7} * (SO_2)_c * Q_{std}}{P} \quad (\text{Eq. 6})$$

Where:

E = SO2 emission rate, in lb/MWh

1.664 × 10<sup>-7</sup> = conversion constant, in lb/dscf-ppm

(SO2)<sub>c</sub> = average SO2 concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(3) Measure the SO2 and diluent gas concentrations, using either EPA Methods 6, 6C, or 8 and 3A, or 20 in appendix A of this part. In addition, you may use the manual methods for sulfur dioxide ASME PTC 19–10–1981–Part 10 (incorporated by reference, see §60.17). Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the SO2 emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the SO2 emission rate in lb/MWh.

(b) [Reserved]

**Definitions**

**§ 60.4420 What definitions apply to this subpart?**

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

As used in this subpart, all terms not defined herein will have the meaning given them in the Clean Air Act and in subpart A (General Provisions) of this part.

*Combined cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to generate steam that is only used to create additional power output in a steam turbine.

*Combined heat and power combustion turbine* means any stationary combustion turbine which recovers heat from the exhaust gases to heat water or another medium, generate steam for useful purposes other than additional electric generation, or directly uses the heat in the exhaust gases for a useful purpose.

*Combustion turbine model* means a group of combustion turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

*Combustion turbine test cell/stand* means any apparatus used for testing uninstalled stationary or uninstalled mobile (motive) combustion turbines.

*Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary combustion turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

*Efficiency* means the combustion turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output—based on the higher heating value of the fuel.

*Emergency combustion turbine* means any stationary combustion turbine which operates in an emergency situation. Examples include stationary combustion turbines used to produce power for critical networks or equipment, including power supplied to portions of a facility, when electric power from the local utility is interrupted, or stationary combustion turbines used to pump water in the case of fire or flood, etc. Emergency stationary combustion turbines do not include stationary combustion turbines used as peaking units at electric utilities or stationary combustion turbines at industrial facilities that typically operate at low capacity factors. Emergency combustion turbines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are required by the manufacturer, the vendor, or the insurance company associated with the turbine. Required testing of such units should be minimized, but there is no time limit on the use of emergency combustion turbines.

*Excess emissions* means a specified averaging period over which either (1) the NOX emissions are higher than the applicable emission limit in §60.4320; (2) the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.4330; or (3) the recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

*Gross useful output* means the gross useful work performed by the stationary combustion turbine system. For units using the mechanical energy directly or generating only electricity, the gross useful work performed is the gross electrical or mechanical output from the turbine/generator set. For combined heat and power units, the gross useful work performed is the gross electrical or mechanical output plus the useful thermal output (i.e., thermal energy delivered to a process).

*Heat recovery steam generating unit* means a unit where the hot exhaust gases from the combustion turbine are routed in order to extract heat from the gases and generate steam, for use in a steam turbine or other device that utilizes steam. Heat recovery steam generating units can be used with or without duct burners.

*Integrated gasification combined cycle electric utility steam generating unit* means a coal-fired electric utility steam generating unit that burns a synthetic gas derived from coal in a combined-cycle gas turbine. No solid coal is directly burned in the unit during operation.

*ISO conditions* means 288 Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

*Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture before delivery to the combustor. Mixing may occur before or in the combustion chamber. A lean premixed turbine may operate in diffusion flame mode during operating conditions such as startup and shutdown, extreme ambient temperature, or low or transient load.

*Natural gas* means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1,100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, the Northern Mariana Islands, or offshore platforms.

*Peak load* means 100 percent of the manufacturer's design capacity of the combustion turbine at ISO conditions.

*Regenerative cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine.

*Simple cycle combustion turbine* means any stationary combustion turbine which does not recover heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine, or which does not recover heat from the combustion turbine exhaust gases for purposes other than enhancing the performance of the combustion turbine itself.

*Stationary combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and sub-components comprising any simple cycle stationary combustion turbine, any regenerative/recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.

*Unit operating day* means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

*Useful thermal output* means the thermal energy made available for use in any industrial or commercial process, or used in any heating or cooling application, i.e., total thermal energy made available for processes and applications other than electrical or mechanical generation. Thermal output for this subpart means the energy in recovered thermal output measured against the energy in the thermal output at 15 degrees Celsius and 101.325 kilopascals of pressure.

**Table 1\_to Subpart KKKK of Part 60\_Nitrogen Oxide Emission Limits for New Stationary Combustion Turbines**

Combustion turbine type	Combustion turbine heat input at peak load (HHV)	NOX emission standard
New turbine firing natural gas, electric generating	[le] 50 MMBtu/h...	42 ppm at 15. percent O2 or 290 ng/J of useful output (2.3 lb/MWh).
New turbine firing natural gas, mechanical drive.	[le] 50 MMBtu/h...	100 ppm at 15 percent O2 or 690 ng/J of useful output (5.5 lb/MWh).
New turbine firing natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h	25 ppm at 15 percent O2 or 150 ng/J of useful output (1.2 lb/MWh).
New, modified, or reconstructed turbine firing natural gas.	> 850 MMBtu/h...	15 ppm at 15 percent O2 or 54 ng/J of useful output (0.43 lb/MWh)
New turbine firing fuels other than natural gas, electric generating	[le] 50 MMBtu/h...	96 ppm at 15 percent O2 or 700 ng/J of useful output (5.5 lb/MWh).
New turbine firing fuels other than natural gas, mechanical drive.	[le] 50 MMBtu/h...	150 ppm at 15 percent O2 or 1,100 ng/J of useful output (8.7 lb/MWh).
New turbine firing fuels other than natural gas	>.50 MMBtu/h and [le] 850 MMBtu/h	74 ppm at 15 percent O2 or 460 ng/J of useful output (3.6 lb/MWh).
New, modified, or reconstructed turbine firing fuels other than	> 850 MMBtu/h...	42 ppm at 15 percent O2 or 160 ng/J of useful output (1.3

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

natural gas.		lb/MWh).
Modified or reconstructed turbine.	[le] 50 MMBtu/h...	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
Modified or reconstructed turbine firing natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h.	42 ppm at 15 percent O <sub>2</sub> or 250 ng/J of useful output (2.0 lb/MWh).
Modified or reconstructed turbine firing fuels other than natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h	96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful output (4.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F.	[le] 30 MW output.	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0°F.	> 30 MW output.	96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful 75 output (4.7 lb/MWh).
Heat recovery units operating independent of the combustion turbine.	All sizes.....	54 ppm at 15 percent O <sub>2</sub> or 110 ng/J of useful output (0.86 lb/MWh).



## SECTION IV. APPENDIX SC

### STANDARD CONDITIONS

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at this facility.

#### EMISSIONS AND CONTROLS

1. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
2. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]
3. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
4. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]
5. Excess Emissions - Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]
6. VOC or OS Emissions: No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]
7. Objectionable Odor Prohibited: No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and 62-210.200(203), F.A.C.]
8. General Visible Emissions: No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20 percent opacity. [Rule 62-296.320(4)(b)1, F.A.C.]
9. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

#### TESTING REQUIREMENTS

10. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20% below the allowable emission limiting standard. [Rule 62-297.310(1), F.A.C.]

**SECTION IV. APPENDIX SC**  
**STANDARD CONDITIONS**

---

11. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2), F.A.C.]
12. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
13. Test Procedures: Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.
  - a. Required Sampling Time. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.
  - b. Minimum Sample Volume. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.
  - c. Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.[Rule 62-297.310(4), F.A.C.]
14. Determination of Process Variables
  - a. Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
  - b. Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.[Rule 62-297.310(5), F.A.C.]
15. Sampling Facilities: The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C.
16. Test Notification: The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator. [Rule 62-297.310(7)(a)9, F.A.C.]
17. Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]
18. Test Reports: The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide

**SECTION IV. APPENDIX SC**  
**STANDARD CONDITIONS**

---

sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

- 1) The type, location, and designation of the emissions unit tested.
- 2) The facility at which the emissions unit is located.
- 3) The owner or operator of the emissions unit.
- 4) The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
- 5) The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
- 6) The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
- 7) A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
- 8) The date, starting time and duration of each sampling run.
- 9) The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
- 10) The number of points sampled and configuration and location of the sampling plane.
- 11) For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
- 12) The type, manufacturer and configuration of the sampling equipment used.
- 13) Data related to the required calibration of the test equipment.
- 14) Data on the identification, processing and weights of all filters used.
- 15) Data on the types and amounts of any chemical solutions used.
- 16) Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
- 17) The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
- 18) All measured and calculated data required to be determined by each applicable test procedure for each run.
- 19) The detailed calculations for one run that relate the collected data to the calculated emission rate.
- 20) The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21) A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

**RECORDS AND REPORTS**

19. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2, F.A.C.]
20. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

**Adams, Patty**

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 1:46 PM  
**To:** 'worley.gregg@epa.gov'; 'kwhite@southernco.com'; 'jovick@southernco.com'  
**Cc:** Mulkey, Cindy; Adams, Patty  
**Subject:** FW:  
**Attachments:** 377FPERMIT.PDF; 377FDETERM.PDF; 377FinalNotice.pdf; 377FAPP.PDF

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

11/28/2006

**Adams, Patty**

---

**From:** Harvey, Mary  
**Sent:** Friday, November 17, 2006 3:34 PM  
**To:** 'jovick@southernco.com'; 'kwhite@southernco.com'; 'mblake@cocoaf1.org'; 'helen.voltz@brevardcounty.us'; 'worley.gregg@epa.gov'; 'john\_bunyak@nps.gov'; Kozlov, Leonard; 'TDAVIS@ECTINC.COM'  
**Cc:** Mulkey, Cindy; Adams, Patty; Gibson, Victoria  
**Subject:** Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL  
**Attachments:** 0090180.003.AC.F\_pdf.zip

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

**Adams, Patty**

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 2:47 PM  
**To:** Mulkey, Cindy; Adams, Patty  
**Subject:** FW:

---

**From:** Vick, James O. [mailto:JOVICK@southernco.com]  
**Sent:** Monday, November 20, 2006 2:14 PM  
**To:** Harvey, Mary  
**Subject:** RE:

We are in receipt of the permit.

---

**From:** Harvey, Mary [mailto:Mary.Harvey@dep.state.fl.us]  
**Sent:** Monday, November 20, 2006 12:46 PM  
**To:** worley.gregg@epa.gov; White, Kevin; Vick, James O.  
**Cc:** Mulkey, Cindy; Adams, Patty  
**Subject:** FW:

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

**Adams, Patty**

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 3:43 PM  
**To:** Mulkey, Cindy; Adams, Patty  
**Subject:** FW:

---

**From:** White, Kevin [mailto:KWHITE@southernco.com]  
**Sent:** Monday, November 20, 2006 3:22 PM  
**To:** Harvey, Mary  
**Subject:** RE:

I have received the Oleander Unit 5 AC permit.

Thank You

---

**From:** Harvey, Mary [mailto:Mary.Harvey@dep.state.fl.us]  
**Sent:** Monday, November 20, 2006 12:46 PM  
**To:** worley.gregg@epa.gov; White, Kevin; Vick, James O.  
**Cc:** Mulkey, Cindy; Adams, Patty  
**Subject:** FW:

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

**Adams, Patty**

---

**From:** Harvey, Mary  
**Sent:** Friday, November 17, 2006 3:58 PM  
**To:** Adams, Patty; Mulkey, Cindy  
**Subject:** FW: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

---

**From:** Tom Davis [mailto:tdavis@ectinc.com]  
**Sent:** Friday, November 17, 2006 3:45 PM  
**To:** Harvey, Mary  
**Subject:** RE: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

---

**From:** Harvey, Mary [mailto:Mary.Harvey@dep.state.fl.us]  
**Sent:** Friday, November 17, 2006 3:34 PM  
**To:** jovick@southernco.com; kwhite@southernco.com; mblake@cocoaf1.org; helen.voltz@brevardcounty.us; worley.gregg@epa.gov; john\_bunyak@nps.gov; Kozlov, Leonard; TDAVIS@ECTINC.COM  
**Cc:** Mulkey, Cindy; Adams, Patty; Gibson, Victoria  
**Subject:** Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

---

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation



## Adams, Patty

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 9:31 AM  
**To:** Adams, Patty; Mulkey, Cindy  
**Subject:** FW: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

---

**From:** Voltz, Helen P [<mailto:Helen.Voltz@brevardcounty.us>]  
**Sent:** Friday, November 17, 2006 3:59 PM  
**To:** Harvey, Mary  
**Subject:** Read: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

Your message

To: [Helen.Voltz@brevardcounty.us](mailto:Helen.Voltz@brevardcounty.us)  
Subject:

was read on 11/17/2006 3:59 PM.

## Adams, Patty

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 9:27 AM  
**To:** Adams, Patty; Mulkey, Cindy  
**Subject:** FW: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

**Attachments:** 0090180.003.AC.F\_pdf.zip



0090180.003.AC.F  
\_pdf.zip (2 MB...)

-----Original Message-----

**From:** John Bunyak@nps.gov [mailto:John.Bunyak@nps.gov]  
**Sent:** Friday, November 17, 2006 6:56 PM  
**To:** Harvey, Mary  
**Cc:** Dee\_Morse@nps.gov; Meredith\_Bond@fws.gov  
**Subject:** Re: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

Mary: Got it. Please add Dee Morse and Meredith Bond at the e-mail addresses above to your mailing list for future permit-related messages.  
Thanks. John

"Harvey, Mary"  
<Mary.Harvey@dep.s  
<kwhite@southernco.com>, <mblake@cocoafl.org>, <helen.voltz@brevardcounty.us>,  
<worley.gregg@epa.gov>, <john\_bunyak@nps.gov>, "Kozlov,  
Leonard"  
<Leonard.Kozlov@dep.state.fl.us>, <TDAVIS@ECTINC.COM>  
11/17/2006 03:33 cc: "Mulkey, Cindy"  
<Cindy.Mulkey@dep.state.fl.us>, "Adams, Patty"  
PM EST <Patty.Adams@dep.state.fl.us>, "Gibson,  
Victoria" <Victoria.Gibson@dep.state.fl.us>  
Subject: Environmental Affairs/Gulf Power  
Company #0090180-003-AC-FINAL

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site:  
<http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,  
DEP, Bureau of Air Regulation  
(See attached file: 0090180.003.AC.F\_pdf.zip)

## Adams, Patty

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 9:27 AM  
**To:** Adams, Patty; Mulkey, Cindy  
**Subject:** FW: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

---

**From:** Mary L. Stearns [<mailto:mstearns@cocoaf1.org>]  
**Sent:** Monday, November 20, 2006 7:46 AM  
**To:** Harvey, Mary  
**Subject:** Not read: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

Your message

To: [mstearns@cocoaf1.org](mailto:mstearns@cocoaf1.org)  
Subject:

was deleted without being read on 11/20/2006 7:46 AM.

THE STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION


In Re:

OGC CASE NO.: 06-2056

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, FL 32926

Oleander Power Project  
Simple Cycle Combustion Turbine Unit 5  
DEP File No. 0090180-003-AC  
Draft Permit No. PSD-FL-377  
Brevard County

Authorized Representative:  
James O. Vick  
c/o Gulf Power Company  
One Energy Place  
Pensacola, FL 32520




**NOTICE OF WITHDRAWAL OF REQUEST FOR EXTENSION OF TIME**

Oleander Power Project, L.P., (Oleander) and James O. Vick (Vick), by and through undersigned counsel, hereby withdraw their Request for Extension of Time to file a Petition for Administrative Proceedings in accordance with Chapter 120, Florida Statutes. Oleander and Vick filed their request for extension of time on October 12, 2006 requesting an extension through November 27, 2006, and the order granting such extension was granted on October 17, 2006. This withdrawal is conditioned upon changes to the draft permit agreed to between the Department of Environmental Protection (DEP) and Oleander, which are reflected in the document attached as Exhibit A.

Respectfully submitted this 15th day of November, 2006.

HOPPING GREEN & SAMS, P.A.

  
Angela Morrison Umland  
Florida Bar No. 0855766  
123 South Calhoun Street  
Post Office Box 6526 (32314)  
Tallahassee, Florida 32301  
(850) 222-7500  
Attorney for Oleander Power Project, L.P.  
and James O. Vick

**CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that a copy of the foregoing has been furnished to the following by  
U.S. Mail on this 15<sup>th</sup> day of November, 2006:

Trina Vielhauer, Chief  
Bureau of Air Regulation  
Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Patricia Comer, Esquire  
Office of General Counsel  
Department of Environmental Protection  
3900 Commonwealth Blvd.  
Tallahassee, FL 32399-2600

  
\_\_\_\_\_  
Attorney

## Memorandum

# Florida Department of Environmental Protection

---

TO: Joseph Kahn, Director, DARM  
Through: Trina L. Vielhauer, Chief, BAR  
From: A.A. Linero/Cindy Mulkey *caM*  
DATE: November 16, 2006  
SUBJECT: Oleander Power Project – Brevard County  
Simple Cycle Combustion Turbine  
DEP File No. 0090180-003-AC (PSD-FL-377)

Attached is the Final PSD Permit for the construction of a fifth simple cycle combustion turbine electrical generator (Unit 5) at the existing Oleander Power Project, a subsidiary of Southern Power Company (SPC). The original construction permit issued in 1999 to the previous owners, Constellation Energy, authorized the construction of five simple cycle units, only four of which were actually constructed. Constellation sold the plant to SPC who then decided to add the fifth unit. This permit “re-authorizes” construction of Unit 5. The existing four units have been operating for several years and we have no reason to believe that this is part of a phased project.

The unit is a nominal 190 MW General Electric 7FA. A determination of BACT was required for emissions of NO<sub>x</sub> and PM/PM<sub>10</sub>.

Unit 5 will fire natural gas as the primary fuel and No. 2 low sulfur fuel oil (0.05 % sulfur) as back-up fuel. The unit is permitted to operate a total of 3,390 hours per year with a maximum of 500 hours of fuel oil firing.

We have determined that BACT for NO<sub>x</sub> is 9.0 ppmvd @15% O<sub>2</sub>. The limit will be achieved by use of inherently clean natural gas and use of Dry Low NO<sub>x</sub>/CO combustors. A limit of 42 ppmvd NO<sub>x</sub> @15% O<sub>2</sub> will apply while firing the back-up fuel oil.

Emissions of CO, PM/PM<sub>10</sub>, SAM, SO<sub>2</sub>, and VOCs will be minimized by the efficient, high-temperature combustion of clean fuels.

No comments were received from EPA or the public. Those received from Southern Company were discussed and are addressed in the attached Final Determination to Issue a PSD Permit.

We recommend your approval of the attached Final Notice and Permit.

AAL/cem

Attachments

## Adams, Patty

---

**From:** Harvey, Mary  
**Sent:** Monday, November 20, 2006 1:18 PM  
**To:** Adams, Patty; Mulkey, Cindy  
**Subject:** FW: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

---

**From:** Kozlov, Leonard  
**Sent:** Monday, November 20, 2006 11:22 AM  
**To:** Harvey, Mary  
**Subject:** Read: Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL

Your message

**To:** 'jovick@southernco.com'; 'kwhite@southernco.com'; 'mblake@cocoaf1.org'; 'helen.voltz@brevardcounty.us'; 'worley.gregg@epa.gov'; 'john\_bunyak@nps.gov'; Kozlov, Leonard; 'TDAVIS@ECTINC.COM'  
**Cc:** Mulkey, Cindy; Adams, Patty; Gibson, Victoria  
**Subject:** Environmental Affairs/Gulf Power Company #0090180-003-AC-FINAL  
**Sent:** 11/17/2006 3:34 PM

was read on 11/20/2006 11:22 AM.



# Orlando Sentinel

Published Daily

State of Florida } S.S.  
COUNTY OF ORANGE

Before the undersigned authority personally appeared Rachael Washington, who on oath says


that he/she is the Legal Advertising Representative of Orlando Sentinel, a daily newspaper published at Orlando in Orange County, Florida; that the attached copy of advertisement, being a PUBLIC NOTICE OF in the matter of Oleander Power Project Unit 5

in the Orange Court, was published in said newspaper in the issue; of 10/17/06

Affiant further says that the said Orlando Sentinel is a newspaper published at Orlando in said Orange County, Florida, and that the said newspaper has heretofore been continuously published in said Orange County, Florida, each Week Day and has been entered as second-class mail matter at the post office in Orlando in said Orange County, Florida, for a period of one year next preceding the first publication of the attached copy of advertisement; and affiant further says that he/she has neither paid nor promised any person, firm or corporation any discount, rebate, commission or refund for the purpose of securing this advertisement for publication in the said newspaper.

The foregoing instrument was acknowledged before me this 20 day of October, 2006, by Rachael Washington who is personally known to me and who did take an oath.

(SEAL)



## PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DEP File No. 0090180-003-AC, PSD-FL-377

Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine-Electrical Generator  
Brevard County

The Department of Environmental Protection (Department) gives notice of its intent to issue an Air Construction Permit to Oleander Power Project, L.P. The permit is to construct a 190 megawatt (MW) simple cycle combustion turbine-electrical generator (CT) to be known as Unit 5 of the Oleander Power Project in the City of Cocoa, Brevard County. A review under the Rules for the Prevention of Significant Deterioration of Air Quality (PSD) and a Best Available Control Technology (BACT) determination were required for emissions of nitrogen oxides (NOX) and particulate matter (PM/PM10) pursuant to Rule 62-212.400, Florida Administrative Code (F.A.C.). The applicant's name and address are Oleander Power Project, L.P., 555 Townsend Road, Cocoa, Florida 32926.

The original Air Construction Permit issued in 1999 authorized construction of five General Electric 7FA Simple cycle CTs with 60-foot stacks and two 1.8 million gallon fuel oil storage tanks. Only four CTs with stacks and the two fuel oil storage tanks were constructed. This draft permitting action re-authorizes construction of the fifth 190 MW CT, a 60-foot stack and a smaller fuel oil storage tank with a nominal capacity of 900,000 gallons.

Unit 5 will be an intermittent duty CT (typically known as a peaking unit) and will fire natural gas as the primary fuel and No. 2 low sulfur fuel oil as back-up fuel. Unit 5 will be permitted to operate a total of 3,390 hours per year with a maximum of 500 hours of fuel oil firing. The Department has determined that BACT for NOX is 9.0 parts per million by volume, dry corrected to percent oxygen (ppmv @ 15% O2). The limit will be achieved by use of inherently clean natural gas and use of Dry Low NOX/CO combustors.

A limit of 42 ppmvd NOX @ 15% O2 will apply while firing back-up fuel oil and will be achieved by water injection into the combustors for flame temperature control. Emissions of carbon monoxide (CO), PM/PM10, sulfuric acid mist (SAM), sulfur dioxide (SO2), volatile organic compounds (VOCs) and visible emissions (Opacity) will be minimized by the efficient, high-temperature combustion of clean fuels.

Estimates of maximum potential annual emissions from CT Unit 5 are summarized in the following table.

Pollutant	Maximum 2005/2006	PSD Significant Emissions Rule		PSD Review Required
		Local Area	Statewide	
CO	77.0	100	No	No
NOx	174.5	40	Yes	Yes
PM/PM10	54.2/24.5	25/13	Yes	Yes
SO2	37.1	10	No	No
SAM	2.7	1	No	No
VOC	11.4	40	No	No
Mercury	0.0096	0.1	No	No
Pb	0.0085	0.6	No	No
Formaldehyde	0.053	Not Applicable	No	No

According to the applicant and as verified by the Department, maximum predicted air quality impacts due to worst case emissions from the proposed new project are less than the significant impact levels applicable to all PSD Class II areas. Therefore, multi-source (PSD increment) modeling was not required. The impacts to the nearest Class I area (Chassahowitzka National Wildlife Refuge on the Gulf coast) will be negligible. Based on the required analyses, the Department has reasonable assurance that the proposed project will not cause or contribute to a violation of any state or federal ambient air quality standard.

The Department will issue the final permit, in accordance with the conditions of the draft permit, unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for a public meeting concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of this Public Notice of Intent to Issue Air Construction Permit. Written comments or requests for public meetings should be submitted to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below. Mediation is not available in this proceeding.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen (14) days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen (14) days of publication of the public notice or within fourteen (14) days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C. Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Department of Environmental Protection  
Bureau of Air Regulation  
111 S. Magnolia Drive, Suite 4  
Tallahassee, Florida, 32301  
Telephone: 850/488-0114  
Fax: 850/921-9533

Department of Environmental Protection  
Central District Office  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767  
Telephone: 407/894-7555  
Fax: 407/897-2966

The complete project file includes the application, technical evaluations, Draft Permit, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Program Administrator, South Permitting Section of the Bureau of Air Regulation at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114 for additional information. Key documents related to this permitting action are available at: [www.dep.state.fl.us/Air/permitting/construction/oleander.htm](http://www.dep.state.fl.us/Air/permitting/construction/oleander.htm)

COR103574-OCT.17

**Southern Company Services, Inc.**

One Energy Place  
Pensacola, Florida 32520

850.444.6111

**RECEIVED**

DEC 07 2006

BUREAU OF AIR REGULATION



December 5, 2006

Len Kozlov, P.E.  
Air Program Administrator  
Central District Office  
Florida Department of Environmental Protection  
3319 Maguire Blvd, Suite 232  
Orlando, Florida 32803-3767

**RE: Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine  
Initial Construction Notification**

Dear Mr. Kozlov:

Air permit No. 0090180-003-AC (PSD-FL-377), which authorized the construction of the Oleander Power Project Unit 5 was issued by the Florida Department of Environmental Protection's (FDEP), Division of Air Resources Management (DARM) on November 17, 2006.

The permit specifically states that Oleander Power Project Unit 5 is subject to the requirements of 40 CFR 60 Subpart KKKK – Requirements of Stationary Combustion Turbines. Therefore, the notification and record keeping requirements of 40 CFR 60.7 are required. In accordance with 40 CFR 60.7(a)(1), Southern Power hereby provides notification that construction of the Oleander Power Project Unit 5 began on November 29, 2006.

If you have any questions concerning this notification or the future construction activities of Oleander Power Project Unit 5, please let me know.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin M. White".

Kevin M. White, P.E.  
Environmental Affairs

cc: Jim Vick  
Brian Toth  
Phillip Williams  
Patty Adams



## Gibson, Victoria

---

**From:** Gibson, Victoria  
**Sent:** Tuesday, November 28, 2006 2:58 PM  
**To:** Vielhauer, Trina  
**Subject:** RE: Oleander permit action 0090180-003-AC

I haven't received anything on the October draft... I will bring in the information that I still have open for the September draft.

Vickie

---

**From:** Vielhauer, Trina  
**Sent:** Tuesday, November 28, 2006 2:29 PM  
**To:** Gibson, Victoria  
**Subject:** FW: Oleander permit action 0090180-003-AC

I'm working on a response. Did you have anything on a new petition filed for Oleander? I know there was an extension filed on our September draft, but didn't see anything on our October re-issuance....that I remember anyway.

---

**From:** Comer, Patricia  
**Sent:** Tuesday, November 28, 2006 1:59 PM  
**To:** Vielhauer, Trina  
**Cc:** Miskelley, Valerie  
**Subject:** Oleander permit action 0090180-003-AC

Trina I have a problem that's come up----

On November 15, OGC received a conditional withdrawal of a Motion for Extension of Time to file a Petition from counsel for the applicant. The conditional withdrawal requires that the agency issue a permit as a precondition of the withdrawal. Since the agency is precluded by statute from issuing a permit with an extension of time outstanding, the conditional withdrawal created a legal logic loop and was of no effect so OGC did not close the litigation case on this matter. But it looks like you guys purported to take "final permit action". I can't tell if that action was outside legal parameters or not because I can't tell if the intent that was the basis for the extension was withdrawn and replaced. I can see that the original September intent was replaced by an October intent but I have no records of any subsequent withdrawal/replacement. Also, if the permit was issued before the 14-day petition period on the changes expired it was premature because any change to the intent to issue for any reason (with the sole exception of resolving an actual EPA objection on a Title V permit) begins a new 14-day APA petition period for everyone-- the applicant (who can waive the timeframe if nobody else is involved), but also for all the other persons who were given the original intent. But I don't see where that happened either. (And, by the way, when third party persons are given copies of an intent to issue but subsequent changes are made, those person should be given copies of all the changes as well.)

Anyway, I don't know what happened and I can't tell if the permit was legally issued or should be re-issued. Can you help me?

Thanks

Pat

## Gibson, Victoria

---

**From:** Crandall, Lea  
**Sent:** Wednesday, November 15, 2006 4:31 PM  
**To:** Gibson, Victoria  
**Subject:** RE: Any Comments, etc.

**Attachments:** Di4700611150425.PDF

I just received a Notice of Withdrawal of Request for Extension of Time.



Di4700611150425.  
PDF (6 MB)

### Lea Crandall

Agency Clerk  
Department of Environmental Protection  
3900 Commonwealth Boulevard, MS 35  
Tallahassee, FL 32399-3000  
Phone: (850) 245-2212 SC: 205-2212  
Fax: (850) 245-2303

-----Original Message-----

**From:** Gibson, Victoria  
**Sent:** Wednesday, November 15, 2006 3:20 PM  
**To:** Crandall, Lea  
**Subject:** Any Comments, etc.  
**Importance:** High

Hi,


Have you received any comments on Oleander Unit 5 0090180-003-AC PSD-FL-377?

Thank you.

*Vickie*

Victoria Gibson, Administrative Secretary for  
Trina Vielhauer, Chief  
DEP/Bureau of Air Regulation  
victoria.gibson@dep.state.fl.us  
850-921-9504 fax 850-921-9533

THE STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION




In Re:

OGC CASE NO.: 06-2056

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, FL 32926

Oleander Power Project  
Simple Cycle Combustion Turbine Unit 5  
DEP File No. 0090180-003-AC  
Draft Permit No. PSD-FL-377  
Brevard County

Authorized Representative:  
James O. Vick  
c/o Gulf Power Company  
One Energy Place  
Pensacola, FL 32520



**NOTICE OF WITHDRAWAL OF REQUEST FOR EXTENSION OF TIME**

Oleander Power Project, L.P., (Oleander) and James O. Vick (Vick), by and through undersigned counsel, hereby withdraw their Request for Extension of Time to file a Petition for Administrative Proceedings in accordance with Chapter 120, Florida Statutes. Oleander and Vick filed their request for extension of time on October 12, 2006 requesting an extension through November 27, 2006, and the order granting such extension was granted on October 17, 2006. This withdrawal is conditioned upon changes to the draft permit agreed to between the Department of Environmental Protection (DEP) and Oleander, which are reflected in the document attached as Exhibit A.

Respectfully submitted this 15th day of November, 2006.

HOPPING GREEN & SAMS, P.A.

A handwritten signature in cursive script, appearing to read "Angela Morrison Umland".

Angela Morrison Umland  
Florida Bar No. 0855766  
123 South Calhoun Street  
Post Office Box 6526 (32314)  
Tallahassee, Florida 32301  
(850) 222-7500  
Attorney for Oleander Power Project, L.P.  
and James O. Vick

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a copy of the foregoing has been furnished to the following by  
U.S. Mail on this 15<sup>th</sup> day of November, 2006:

Trina Vielhauer, Chief  
Bureau of Air Regulation  
Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Patricia Comer, Esquire  
Office of General Counsel  
Department of Environmental Protection  
3900 Commonwealth Blvd.  
Tallahassee, FL 32399-2600

  
\_\_\_\_\_  
Attorney

**PERMITTEE:**

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, Florida 32926

*Authorized Representative:*

James O. Vick, Director Environmental Affairs

Oleander Power Project
Simple Cycle Unit 5
Permit No. PSD-FL-377
Project No. 0090180-003-AC
Expires: June 1, 2008

**PROJECT AND LOCATION**

This permit authorizes the construction of a nominal 190 MW simple cycle combustion turbine electrical generator at the existing Oleander Power Project. The facility is located in Cocoa, just off Interstate 95 and State Road 520 in Brevard County.

**STATEMENT OF BASIS**

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The project was processed in accordance with the requirements of Rule 62-212.400, F.A.C., the preconstruction review program for the Prevention of Significant Deterioration (PSD) of Air Quality. The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

---

Joseph Kahn, Director  
Division of Air Resource Management



## SECTION I - GENERAL INFORMATION

### FACILITY DESCRIPTION

The regulated emissions units at the existing Oleander Power Project include four nominal 190 MW simple cycle combustion turbines (Units 001 through 004) capable of firing either natural gas or low-sulfur fuel oil (0.05 percent sulfur), and two 1.8 million-gallon fuel oil storage tanks (Units 006 and 007).

### PROJECT DESCRIPTION

The project is for the construction of one additional General Electric PG7241(FA) simple cycle combustion turbine electrical generator (Unit 5) equipped with evaporative cooling, capable of firing natural gas, with a nominal output of 190 megawatts. The project also includes the installation of one 900,000 gallon distillate fuel oil storage tank. Low sulfur fuel oil will be used as a backup fuel to the combustion turbine.

### NEW EMISSIONS UNITS

This permit authorizes construction and installation of the following new emissions units:

EU ID NO.	EMISSION UNIT DESCRIPTION
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.
008	Unit 8- One 900,000 gallon distillate fuel oil storage tank.

### REGULATORY CLASSIFICATION

*Title I, Part C, Clean Air Act (CAA):* The facility is a PSD-major facility pursuant to Rule 62-212, F.A.C.

*Title I, Section 111, CAA:* Unit 5 is subject to the New Source Performance Standards of 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines).

*Title I, Section 112, CAA:* The facility is not a "Major Source" of hazardous air pollutants (HAPs).

*Title IV, CAA:* The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

*Title V, CAA:* The facility is a Title V or "Major Source of air pollution" in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), sulfuric acid mist (SAM), and volatile organic compounds (VOC).

*CAIR:* As an electric generating unit, Unit 5 may be subject to the Clean Air Interstate Rule pending the finalization of DEP rules.

### PERMITTING AUTHORITY

All documents related to applications for permits to construct, operate or modify an emissions unit shall be submitted to the Bureau of Air Regulation of the Florida Department of Environmental Protection (DEP) at 2600 Blair Stone Road (MS:#5505), Tallahassee, Florida 32399-2400. Copies of all such documents shall also be submitted to the Compliance Authority.

### COMPLIANCE AUTHORITY

All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Department of Environmental Protection Central District, 3319 Maguire Boulevard, Suite 232, Orlando, Florida 32803-3767.

## SECTION I - GENERAL INFORMATION

---

### APPENDICES

The following Appendices are attached as part of this permit.

Appendix A	NSPS Subparts A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

### RELEVANT DOCUMENTS:

The documents listed below are not a part of this permit, however they are specifically related to this permitting action and are on file with the Department.

- Application for Air Construction Permit received on May 4, 2006;
- Department's Request for Additional Information dated June 2, 2006;
- Applicant's Response to Request for Additional Information Received July 13, 2006 (complete);
- Department's Intent to Issue and Public Notice Package distributed October 10, 2006;
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.

## SECTION II. ADMINISTRATIVE REQUIREMENTS

1. General Conditions: The permittee shall operate under the attached General Conditions listed in Appendix GC of this permit. General Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
2. Applicable Regulations, Forms and Application Procedures: Unless otherwise indicated in this permit, the construction and operation of the subject emissions unit shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403 of the Florida Statutes (F.S.); Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.); and the Title 40, Parts 51, 52, 60, 63, 72, 73, and 75 of the Code of Federal Regulations (CFR), adopted by reference in Rule 62-204.800, F.A.C. The terms used in this permit have specific meanings as defined in the applicable chapters of the Florida Administrative Code. The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations. [Rules 62-204.800, 62-210.300 and 62-210.900, F.A.C.]
3. Construction and Expiration: Authorization to construct shall expire if construction is not commenced within 18 months after receipt of the permit, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. This provision does not apply to the time period between construction of the approved phases of a phased construction project except that each phase must commence construction within 18 months of the commencement date established by the Department in the permit. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. In conjunction with an extension of the 18-month period to commence or continue construction (or to construct the project in phases), the Department may require the permittee to demonstrate the adequacy of any previous determination of Best Available Control Technology (BACT) for emissions units regulated by the project. For good cause, the permittee may request that this PSD air construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation at least sixty (60) days prior to the expiration of this permit. [Rules 62-4.070(4), 62-4.080, 62-210.300(1), and 62-212.400(12), F.A.C.]
4. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
5. Source Obligation.
  - a. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.
  - b. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by exceeding its projected actual emissions, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.[Rule 62-212.400(12), F.A.C.]
6. Modifications: No emissions unit or facility subject to this permit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning

## SECTION II. ADMINISTRATIVE REQUIREMENTS

---

construction or modification. This permit authorizes construction of the referenced facilities.  
[Chapters 62-210 and 62-212, F.A.C.]

7. Application for Title IV Permit: At least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW, the permittee shall submit an application for a Title IV Acid Rain Permit to the Department's Bureau of Air Regulation in Tallahassee and a copy to the Region 4 Office of the U.S. Environmental Protection Agency in Atlanta, Georgia. [40 CFR 72]
8. Title V Permit: This permit authorizes construction of the permitted emissions unit and initial operation to determine compliance with Department rules. A Title V operation permit is required for regular operation of the permitted emission units. The permittee shall apply for and obtain a Title V operation permit in accordance with Rule 62-213.420, F.A.C. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the Department's Bureau of Air Regulation and a copy to the Compliance Authority.  
[Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]

DRAFT

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The specific conditions of this subsection apply to the following emissions unit after construction is complete.

E.U. ID	Emission Unit Description
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.

#### APPLICABLE STANDARDS AND REGULATIONS

1. **BACT Determinations:** A determination of the Best Available Control Technology (BACT) was made for nitrogen oxides (NO<sub>x</sub>), and particulate matter (PM/PM<sub>10</sub>). [Rule 62-210.200 (BACT), F.A.C.]
2. **NSPS Requirements:** This unit shall comply with the applicable New Source Performance Standards (NSPS) in 40 CFR 60, including: Subpart A (General Provisions) and Subpart KKKK (Standards of Performance for Stationary Gas Turbines). See Appendix A and Appendix KKKK of this permit. The BACT emissions standards for NO<sub>x</sub> and the fuel sulfur specifications for PM/PM<sub>10</sub> are as stringent as, or more stringent than the NO<sub>x</sub> and SO<sub>2</sub> limits imposed by the applicable NSPS provisions. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(7)(b), F.A.C.; 40 CFR 60, Subparts A and KKKK]

#### EQUIPMENT DESCRIPTION

3. **Combustion Turbine:** The permittee is authorized to install, tune, operate, and maintain one General Electric Model PG7241FA gas turbine-electrical generator set with a nominal generating capacity of 190 MW. The combustion turbine will be equipped with GE's DLN combustor, and an inlet air filtration system with evaporative coolers. The combustion turbine will be designed for operation in simple cycle mode and will have dual-fuel capability. [Application, Design]

#### CONTROL TECHNOLOGY

4. **DLN Combustion:** The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO<sub>x</sub> emissions from the combustion turbine when firing natural gas. Prior to the initial emissions performance tests required for the gas turbine, the DLN combustors and automated gas turbine control system shall be tuned to achieve the permitted levels for NO<sub>x</sub>. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Design; Rule 62-212.400(10)(BACT), F.A.C.]
5. **Wet Injection:** The permittee shall install, operate, and maintain a water injection system to reduce NO<sub>x</sub> emissions from the combustion turbine when firing distillate fuel oil. Prior to the initial emissions performance tests, the water injection system shall be tuned to achieve sufficiently low NO<sub>x</sub> values to meet the NO<sub>x</sub> limits of this permit. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Applicant request; Rule 62-212.400(10)(BACT), F.A.C.]

#### PERFORMANCE REQUIREMENTS

6. **Hours of Operation:** The combustion turbine may operate no more than 3,390 hours per calendar year. Restrictions on individual methods of operation are specified in separate conditions. [Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD), F.A.C.]
7. **Permitted Capacity:** The nominal heat input rate to the combustion turbine is 1,722 MMBtu per hour when firing natural gas and 1,920 MMBtu per hour when firing fuel oil (based on a compressor inlet air temperature of 59° F, the lower heating value (LHV) of each fuel, and 100% load). Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department.  
[Rule 62-210.200(PTE), F.A.C.]

8. **Authorized Fuels:** The combustion turbine shall fire natural gas as the primary fuel, which shall contain no more than 1.5 grains of sulfur per 100 standard cubic feet of natural gas. As a restricted alternate fuel, the combustion turbine may fire low sulfur fuel oil containing no more than 0.05% sulfur by weight. The gas turbine shall fire no more than 500 hours of fuel oil, during any calendar year.  
[Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD, and PSD Avoidance), F.A.C.]
9. **Simple Cycle, Intermittent Operation:** The turbine shall operate only in simple cycle mode not to exceed the permitted hours of operation allowed by this permit. This restriction is based on the permittee's request, which formed the basis of the PSD applicability and BACT determination and resulted in the emission standards specified in this permit. For any request to convert this unit to combined cycle operation by installing/connecting to heat recovery steam generators, including changes to the fuel quality or quantity related to combined cycle conversion which may cause an increase in short or long-term emissions, the permittee may be required to submit a full PSD permit application complete with a new proposal of the best available control technology as if the unit had never been built.  
[Rules 62-212.400(12) and 62-212.400(BACT), F.A.C.]

**EMISSIONS AND TESTING REQUIREMENTS**

10. **Emission Standards:** Emissions from the combustion turbine shall not exceed the following standards.

Pollutant	Emission Standard <sup>c</sup>	Averaging Time	Compliance Method	Basis
NO <sub>x</sub> (Gas)	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr rolling	CEMS	BACT
	62.5 lb/hr	3 1-hr runs	Stack Test	
NO <sub>x</sub> (Oil)	42.0 ppmvd @ 15% O <sub>2</sub>	4-hr rolling	CEMS	NSPS
	336.8 lb/hr	3 1-hr runs	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	10 % Opacity	6-minute block	Visible Emissions Test	BACT
	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	PSD Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the visible emissions standard shall serve as an indicator of good combustion.
- b. The fuel sulfur specifications and limited hours of operation effectively limit the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from the gas turbine.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

*{Permitting Note: In combination with the annual restriction on hours of operation, the above emissions standards effectively limit annual potential emissions from the combustion turbine to: 174.5 tons/year of NO<sub>x</sub>, 34.5 tons/year of PM/PM<sub>10</sub>, and 37.1 tons/year of SO<sub>2</sub>.}*

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD and PSD Avoidance), F.A.C, and 40 CFR 60, Subpart KKKK]

11. Nitrogen Oxides (NO<sub>x</sub>): Emissions of NO<sub>x</sub> from the CT shall not exceed the following standards on a continuous basis and as measured by the required CEMS for the averaging period specified, and as measured during the required stack tests.

a. *While firing natural gas:*

9.0 ppmvd @ 15% O<sub>2</sub> on a 24-hour rolling average (as measured by the required CEMS and defined by this permit)

62.5 /lb/hr (3 1-hr run stack test)

b. *While firing fuel oil:*

42.0 ppmvd @ 15% O<sub>2</sub> on a 4-hr rolling average (as measured by the required CEMS and defined by subpart KKKK attached as an Appendix to this permit)

336.8 lb/hr (3 1-hr run stack test)

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD), F.A.C, and 40 CFR 60.4380]

12. Sulfur Dioxide (SO<sub>2</sub>):

a. *While firing natural gas:* The fuel sulfur specifications, established in condition 8 of this subsection, of 1.5 grains per 100 standard cubic feet effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing natural gas.

b. *While firing fuel oil:* The fuel sulfur specification, established in condition 8 of this subsection, of 0.05 % sulfur by weight effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing fuel oil.

[Rules 62-4.070(3), and 62-212.400 (PSD Avoidance), F.A.C]

13. Particulate Matter (PM/PM<sub>10</sub>): The fuel sulfur specifications, established in condition 8 of this subsection, combined with the efficient combustion design, and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the fuel specifications and visible emissions standard shall serve as indicators of good combustion. Visible emissions shall not exceed 10 % opacity as observed during the required 30-minute visible emissions tests.

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD), and 62-297.310(4)(a)2, F.A.C]

14. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering, confining, or applying water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

15. Test Methods: Required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of NO <sub>x</sub> Emissions (Instrumental).
9	Visual Determination of Opacity
20	Determination of NO <sub>x</sub> , SO <sub>2</sub> , and Diluent Emissions from Stationary Gas Turbines

### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C. [Rules 62-204.800, F.A.C.; 40 CFR 60, Appendix A]

16. **Testing Requirements:** Initial tests shall be conducted between 90% and 100% of permitted capacity; otherwise, this permit shall be modified to reflect the true maximum capacity as constructed. Subsequent annual tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. Tests shall be conducted for each pollutant while firing each fuel in the CT. For each run during tests for visible emissions, emissions of NO<sub>x</sub> recorded by the CEMS shall also be reported. Data collected from the reference method during the required CEMS quality assurance RATA tests may substitute for annual compliance tests for NO<sub>x</sub>, provided the owner or operator indicates this intent in the submitted test protocol, and obtains approval prior to testing. If the RATA is conducted at less than permitted capacity, and the data is used for annual compliance, the requirements of 62-297.310(2) (Operating Rate During Testing) still apply. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department. [Rule 62-297.310(2), and (7)(a), F.A.C.; and 40 CFR 60.8]
17. **Initial Compliance Demonstration:** Initial compliance stack tests while firing natural gas shall be conducted within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup. Initial testing on fuel oil shall be conducted within 60 days of any fuel oil firing in the CT. In accordance with the test methods specified in this permit, the combustion turbine shall be tested to demonstrate initial compliance with the emission standards for NO<sub>x</sub> and with the visible emissions standard. The permittee shall provide the Compliance Authority with any other initial emissions performance tests conducted to satisfy vendor guarantees including CO and particulate tests. [Rules 62-4.070, 62-297.310(7)(a), F.A.C. and 40 CFR 60.8]
18. **Subsequent Compliance Testing:** Annual compliance tests for NO<sub>x</sub> and visible emissions shall be conducted during each federal fiscal year (October 1<sup>st</sup>, to September 30<sup>th</sup>). If normal operation on fuel oil is less than 400 hours per calendar year, then subsequent compliance testing on fuel oil is not required for that year. If normal operation on fuel oil exceeds 400 hours per year, the Department shall require compliance testing for NO<sub>x</sub> and visible emissions while firing fuel oil. [Rules 62-4.070, 62-210.200(BACT), and 62-297.310(7)(a)4, F.A.C.]
19. **Continuous Compliance:** Continuous compliance with the permit standard for emissions of NO<sub>x</sub> shall be demonstrated with data collected from the required continuous monitoring system. [Rules 62-4.070, and 62-210.200(BACT), F.A.C.]
20. **Special Compliance Tests:** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

#### EXCESS EMISSIONS

*{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Condition No 10 and 11 of this subsection. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, NESHAP, or Acid Rain programs.}*



### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

21. Definitions:

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose.
- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

*{Permitting Note: The applicant has described startup of this unit as the period from 0 to 50% load, and shutdown as the period beginning at 50 % load to no load operation.}*

[Rule 62-210.200(165, 242, and 258), F.A.C.]

22. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]
23. Data Exclusion Procedures for SIP Compliance: As per the procedures in this condition, limited amounts of CEMS emissions data, as specified in condition 24, may be excluded from the corresponding SIP-based compliance demonstration, provided that best operational practices to minimize emissions are adhered to, the duration of data excluded is minimized, and the procedures for data exclusion listed below are followed. As provided by the authority in Rule 62-210.700(5), F.A.C., these conditions replace the provisions in Rule 62-210.700(1), F.A.C.
- a. *Limiting Data Exclusion.* If the compliance calculation using all valid CEMS emission data indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
  - b. *Event Driven Exclusion.* There must be an underlying event (startup, shutdown, malfunction, or fuel switching) in order to exclude data. If there is no underlying event, then no data may be excluded.
  - c. *Continuous Exclusion.* Data shall be excluded on a continuous basis. Data from discontinuous periods shall not be excluded for the same underlying event.

[Rule 62-210.700 F.A.C.]

24. Allowable Data Exclusions: The following data may be excluded from the corresponding SIP-based compliance demonstration for each of the events listed below in accordance with the Data Exclusion Procedures of condition 23:
- a. *Startup:* Up to 30 minutes of CEMS data may be excluded for each combustion turbine startup. For startups of less than 30 minutes in duration, only those minutes attributable to startup may be excluded.
  - b. *Shutdown:* Up to 30 minutes of CEMS data may be excluded for each combustion turbine shutdown. For shutdowns of less than 30 minutes in duration, only those minutes attributable to shutdown may be excluded.
  - c. *Malfunction:* Up to two hours (in any operating day) of CEMS data may be excluded due to a documented malfunction. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic email.

### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- d. *DLN Tuning*: CEMS data collected during initial or other DLN tuning sessions may be excluded from the compliance demonstrations provided the tuning session is performed in accordance with the manufacturer's specifications or determined best practices. Prior to performing any tuning session, the permittee shall provide the Compliance Authority with an advance notice of at least one (1) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Design; Rule 62-4.070(3), F.A.C.]
- e. *Fuel Switching*: Up to 60 minutes of CEMS data may be excluded for each fuel switch. For fuel switches of less than 60 minutes in duration, only those minutes attributable to fuel switching may be excluded.

All valid emissions data (including data collected during startup, shutdown, malfunction, DLN tuning, and fuel switching) shall be used to report emissions for the Annual Operating Report.

[Rules 62-210.200(BACT), 62-210.370, and 62-210.700, F.A.C.]

25. Notification Requirements: The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate non-compliance for a given averaging period. [Rule 62-4.070, F.A.C.]

#### CONTINUOUS MONITORING REQUIREMENTS

26. CEM Systems: Subject to the following, the permittee shall install, calibrate, operate, and maintain a continuous emission monitoring system (CEMS) to measure and record the emissions of NO<sub>x</sub> from the combustion turbine in terms of the applicable standards. The monitoring system shall be installed, and functioning within the required performance specifications by the time of the initial compliance demonstration.
- a. *NO<sub>x</sub> Monitor*: Each NO<sub>x</sub> monitor shall be certified pursuant to the specifications of 40 CFR 75. Quality assurance procedures shall conform to the requirements of 40 CFR 75. The annual and required RATA tests required for the NO<sub>x</sub> monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.
- b. *Diluent Monitor*: The oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) content of the flue gas shall be monitored at the location where NO<sub>x</sub> is monitored to correct the measured emissions rates to 15% oxygen. If a CO<sub>2</sub> monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

[Rules 62-4.070(3), 62-210.200(BACT), F.A.C., and 40 CFR 60, Subpart 75]

27. Moisture Correction: If necessary, the owner or operator shall determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). [Rules 62-4.070(3), 62-210.200(BACT), F.A.C.]
28. CEMS Data Requirements for BACT Standards:

*{Permitting Note: The following conditions apply only to the SIP-based NO<sub>x</sub> emissions standards specified in Condition Nos. 10-11 of this section. These requirements cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs. Additional reporting and monitoring may be required by the individual subparts.}*

- a. *Data Collection*: Except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments, emissions shall be monitored and recorded during all operation including startup, shutdown, and malfunction.

### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- b. *Operating Hours and Operating Days:* An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
- c. *Valid Hour:* Each CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
- 1) Hours that are **not operating** hours are **not valid** hours.
  - 2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data and the 1-hour block average is not valid.
  - 3) During fuel switching an hour in which fuel oil is fired is attributed towards compliance with the permit standards for oil firing.
- d. *Rolling 24-Hour Average:* Compliance shall be determined after each valid hourly average is obtained by calculating the arithmetic average of that valid hourly average and the preceding 23 valid hourly averages.
- e. *Data Exclusion:* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, DLN tuning, and fuel switches. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of conditions 23 and 24 of this subsection.
- f. *Availability:* The quarterly excess emissions report shall be used to demonstrate monitor availability for each quarter in which the unit operated. Monitor availability for the CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Compliance Authority.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

#### CEMS REQUIREMENTS FOR ANNUAL EMISSIONS

29. *CEMS Annual Emissions Requirement:* The owner or operator shall use data from the NO<sub>x</sub> CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit. [Rules 62-210.200, and 62-210.370(3), F.A.C.]

#### REPORTING AND RECORD KEEPING REQUIREMENTS

30. *Monitoring of Capacity:* The permittee shall monitor and record the operating rate of the combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction, DLN tuning, and fuel switching). Such monitoring shall be made by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

31. Monthly Operations Summary: By the 15th calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the combustion turbine for the previous month of operation: fuel consumption, hours of operation on each fuel, and the updated calendar year totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]
32. Fuel Sulfur Records: The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
- Natural Gas Sulfur Limit*: Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.
  - Distillate Fuel Oil Sulfur Limit*: Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91, D1552-90, D2622-94, or D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of the Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-4.160(d5)-E.A.C.]

33. Emissions Performance Test Reports: A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix SC of this permit. [Rule 62-297.310(8), F.A.C.]
34. Excess Emissions Reporting:
- Malfunction Notification*: If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
  - SIP Quarterly Report*: Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of NO<sub>x</sub> emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. A summary of data excluded from SIP compliance calculations should also be provided. In addition, the report shall summarize the NO<sub>x</sub> CEMS system monitor availability for the previous quarter.
  - NSPS Reporting*: Within 30 days following the calendar quarter, the permittee shall submit the written reports required by 40 CFR 60 Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) for the previous semi-annual period to the Compliance Authority.

{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart KKKK, a

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

---

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

*statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}*

[Rules 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C., and 40 CFR 60.7 and 60.4375]

35. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating hours and emissions from this facility in accordance with 62-210.370. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

DRAFT

SECTION IV – UNREGULATED EMISSIONS UNITS

A. Fuel Oil Storage Tank (EU 008)

ID	Emission Unit Description
008	Unit 8– One 900,000 gallon distillate fuel oil storage tank.

**NSPS APPLICABILITY**

NSPS Subpart Kb Applicability: The distillate fuel oil storage tank is not subject to Subpart Kb which applies to storage vessels with a capacity greater than or equal to 75 cubic meters that is used to store volatile organic liquids for which construction, reconstruction, or modification is commenced after July 23, 1984. Tanks with a capacity greater than or equal to 151 cubic meters (40,000 gallons) storing a liquid with a maximum true vapor pressure less than 3.5 kPa, are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb. The fuel oil storage tank (EU 008) has a capacity greater than 151 cubic meters and the vapor pressure of the low sulfur fuel oil is less than 3.5 kPa, therefore NSPS Kb, including the monitoring requirements, does not apply to this unit.

[40 CFR 60.110b(a) and (b), and 60.116b(c); Rule 62-204.800(7)(b), F.A.C.]

DRAFT

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

**OLEANDER POWER PROJECT, L.P.,**

Petitioner,

v.

DEPARTMENT OF ENVIRONMENTAL  
PROTECTION,

Respondent.

OGC No. 06-2146  
DEP Permit No. 0090180-003-AC  
PSD-FL-377

**ORDER GRANTING REQUEST FOR EXTENSION  
OF TIME TO FILE PETITION FOR HEARING**

This cause has come before the Florida Department of Environmental Protection (FDEP) upon receipt of a request made by Petitioner, Oleander Power Project, L.P., to grant an extension of time to file a petition for an administrative hearing to allow time to discuss with FDEP several specific permit conditions for its facility in Brevard County, Florida. Because the request shows good cause for the extension of time,

IT IS ORDERED:

The request for an extension of time to file a petition for administrative proceeding is granted. Petitioner shall have until **November 27, 2006**, to file a petition in this matter. Filing shall be complete on receipt by the Office of General Counsel, Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

DONE AND ORDERED on this 10<sup>th</sup> day of October, 2006, in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION



JACK CHISOLM, Deputy General Counsel  
3900 Commonwealth Boulevard MS - 35  
Tallahassee, Florida 32399-3000  
850/245-2242 facsimile 850/245-2302


CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished via  
 U. S. Mail  facsimile  **ONLY**, this \_\_\_\_ day of October, 2006, to:

Angela R. Morrison  
HOPPING GREEN & SAMS, P.A.  
Post Office Box 6526  
Tallahassee, FL 32314

Facsimile: 850/224-8551

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION



Patricia E. Comer, Assistant General Counsel  
FL Bar 0224146  
3900 Commonwealth Boulevard - MS 35  
Tallahassee, Florida 32399-3000  
850/245-2242 Facsimile: 850/245-2302

with a courtesy copy via electronic mail to:

Trina L. Vielhauer - Chief, Bureau of Air Regulation  
Cindy Mulkey - Engineering Specialist, Bureau of Air Regulation



## Gibson, Victoria

---

**From:** Miskelley, Valerie  
**Sent:** Tuesday, October 17, 2006 3:11 PM  
**To:** Mulkey, Cindy; Gibson, Victoria  
**Subject:** Oleander OGC Case No. 06-2146

**Attachments:** Order Granting on Oleander 06-2146.PDF

Cindy and Vickie,  
Here is the Order Granting for Oleander. Let me know if you need anything else.



Order Granting on  
Oleander 06-...

Thanks,  
Valerie Miskelley  
Administrative Secretary  
FDEP Office of General Counsel  
3900 Commonwealth Blvd. MS 35  
Tallahassee, FL 32399-3000  
(850) 245-2260 SC 205-2260  
Fax: (850) 245-2302  
Valerie.Miskelley@dep.state.fl.us

RECEIVED

OCT 16 2006

THE STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

BUREAU OF AIR REGULATION

In the Matter of an  
Application for Permit by:

OGC No. \_\_\_\_\_

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, FL 32926

Oleander Power Project  
Simple Cycle Combustion Turbine Unit 5  
DEP File No. 0090180-003-AC  
Draft Permit No. PSD-FL-377  
Brevard County

Authorized Representative:  
James O. Vick  
c/o Gulf Power Company  
One Energy Place  
Pensacola, FL 32520

**REQUEST FOR EXTENSION OF TIME**

By and through undersigned counsel, Oleander Power Project, L.P., (Oleander) and its authorized representative, James O. Vick, hereby request, pursuant to Florida Administrative Code Rule 62-110.106(4), an extension of time to and including November 27, 2006, in which to file a Petition for Administrative Proceedings in the above-styled matter. As good cause for granting this request, Oleander and Mr. Vick state the following:

1. On October 9, 2006, the Department of Environmental Protection (Department) issued a draft Prevention of Significant Deterioration (PSD) Permit (Permit No. 0090180-003-AC, PSD-FL-377) (dated October 9, 2006) and associated documents for the Oleander Power Project, Unit 5, located in Brevard County, Florida.

2. The draft permit and associated technical evaluation and preliminary determination contain several provisions that warrant clarification or correction.

3. Mr. Vick and other representatives of Oleander have corresponded and will continue to correspond with staff of the Department's Bureau of Air Regulation in an effort to resolve all issues.


4. This request is filed simply as a protective measure to avoid waiver of Oleander's right to challenge certain conditions contained in the draft PSD Permit. Grant of this request will not prejudice either party, but will further their mutual interests and likely avoid the need to file a petition and proceed to a formal administrative hearing.

5. Counsel for Oleander and Mr. Vick has contacted Pat Comer with the Department's Office of General Counsel and requested that she consult with representatives of the Department's Bureau of Air Regulation regarding any potential objection to this request.

WHEREFORE, Oleander and Mr. Vick respectfully request that the time for filing of a Petition for Administrative Proceedings in regard to the Department's draft PSD Permit (Permit No. 0090180-003-AC, PSD-FL-377) be formally extended to and including November 27, 2006. If the Department denies this request, Oleander and Mr. Vick request the opportunity to file a Petition for Administrative Proceedings within 10 days of such denial.

Respectfully submitted this 1<sup>st</sup> day of October, 2006.

HOPPING GREEN & SAMS, P.A.



Angela R. Morrison  
Fla. Bar No. 0855766  
123 South Calhoun Street  
Post Office Box 6526  
Tallahassee, FL 32314  
Office: (850) 222-7500  
Fax: (850) 224-8551

E-mail: [AngelaM@hgslaw.com](mailto:AngelaM@hgslaw.com)


Attorney for OLEANDER POWER PROJECT, L.P.  
AND JAMES O. VICK, ITS AUTHORIZED  
REPRESENTATIVE

**CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that a copy of the foregoing has been furnished to the following by  
U.S. Mail on this 12<sup>th</sup> day of October, 2006:

Trina Vielhauer, Chief  
Bureau of Air Regulation  
Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Pat Comer, Esquire  
Office of General Counsel  
Department of Environmental Protection  
3900 Commonwealth Blvd.  
Tallahassee, FL 32399-2600

  
\_\_\_\_\_  
Attorney

**Chronology of Activities**

OGC Number     District  County

Style of Case

Program Area  Mode

Lead Attorney    Status

Forum Name  Forum Case Number

Permit Appl  Final Order Number

Date *	Code	Activity Description
10/12/2006	AA	ASSIGNED TO LEAD ATTORNEY JACK J CHISOLM
10/12/2006	ACO	ADMIN. CASE OPENED IN OGC
10/12/2006	REX1	RECEIVED FIRST REQUEST FOR EXTENSION OF TIME
10/17/2006		ORD GRANTING REQ FOR EXT OF TIME - UNTIL 11/27/06
10/18/2006	AR	RE-ASSIGNED TO LEAD ATTORNEY PATRICIA E COMER
11/15/2006		WITHDRAWAL OF REQUEST FOR EXTENSION OF TIME
11/17/2006		PERMIT ISSUED
12/07/2006	CC	CASE CLOSED IN OGC

**Southern Company Services, Inc.**

One Energy Place  
Pensacola, Florida 32520

850.444.6111



RECEIVED

OCT 26 2006

BUREAU OF AIR REGULATION

October 24, 2006

Trina L. Vielhauer, Chief  
Bureau of Air Regulation  
Department's Bureau of Air Regulation  
2600 Blair Stone Road  
Mail Station #5505  
Tallahassee, FL 32399-2400.

**RE: Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine  
DEP File No. 0090180-003-AC (PSD-FL-377)**

Dear Ms. Vielhauer:

This letter is in response to the Department's second "Intent to Issue Air Construction Permit" package, issued October 10, 2006. Southern Power would like to thank the Department for its consideration of our previously submitted comments, associated with the initial intent package. However, Southern Power still has the following concerns:

**Specific Condition Comments**

1. Previously, Southern Power requested the Startup, Shutdown, Malfunction language be changed to the rule based 2 hours in any 24 hour period (Rule 62-210.700, F.A.C.) and the following additional language included (currently contained in the Title V permit): "Operation below 50% output shall be limited to 2 hours per unit cycle." This additional language was requested to allow fuel switching in the turbine at a decreased load (below 50%), which is the facility's current standard operating procedure.

The second draft permit includes a new fuel switching limitation (Specific Condition 24.e); however, contains the same 30 minute startup and shutdown limitations (Specific Condition 24) of the initial draft permit. The new fuel switching condition limits the exclusion of CEMS data to 30 minutes when switching from oil-to-gas and allows no exclusion of data when switching from gas-to-oil.

Fuel oil-to-gas transfers should be conducted at 10 MW (mode 1), based on Southern Power's correspondence with General Electric (GE). The necessity of this lower mode is due to nozzle to nozzle pressure differences in higher modes, which can cause combustion backflow during the transfer while the purge system is brought in service. The difference between mode 1 and higher modes is that gas flows through the center nozzle only and oil flows to the five outer

nozzles. A secondary benefit is that the water injection system is offline, which reduces the complexity of the transfer.

Gas-to-oil transfers have the best chance for success, based on correspondence with GE and past operating experience, at low load (mode 1). This success is due to the minimizing of trip risks for the following reasons.

- If a problem occurs while swapping to liquid fuel, you can revert back to gas only when in mode 1. In any other mode, a problem would cause the unit to trip.
- In mode 1 the unit is more tolerant to water injection because water injection is not established until the unit reaches 50 MW and is ramped in at a slow rate. If water injection is ramped in at a high rate at mode 6, it can cause temperature excursions and cause the unit to trip.
- If you have gas purge valve issues during the fuel switch, you can address these issues in mode 1 at a lower firing rate, which cannot be accomplished in mode 6.
- Mode 1 fuel switching gives the operators an opportunity to recover (cancel the fuel switch, as mentioned in the first reason, and conduct repairs) when problems do occur instead of having the unit trip or having to come offline to fix problems.
- A trip in mode 6 is far more damaging to the unit and greatly increases maintenance requirements compared to a trip in mode 1. GE considers a trip in mode 6 over five times more damaging to the machines than a trip in mode 1.
- Oleander currently uses best practice operating procedures for gas-to-oil switching, which were developed by Plant Oleander and Mr. Ken Dunn of GE, assigned technical advisor for Plants Oleander and Stanton. These procedures simplify the switching process and give a step by step way to transfer to oil.
- The other four Oleander units have been using these operating procedures and have had great success in the past.

For the reasons listed above, it is Southern Power's experience that fuel switching at higher modes is far more complicated and likely to trip the unit than switching in mode 1. In addition, a unit trip will result in further startup and shutdown events. Therefore, Southern Power requests the Startup, Shutdown, Malfunction language be changed to the rule based 2 hours in any 24 hour period (Rule 62-210.700, F.A.C.) and the following additional language included (currently contained in the Title V permit): "Operation below 50% output shall be limited to 2 hours per unit cycle." This additional language is requested to allow fuel switching in the turbine (from both oil-to-gas and gas-to-oil) at a decreased load (below 50%), which is the facility's current standard operating procedure.

2. Specific Condition 28.f covers CEMS Availability. It is Southern Power's opinion that 95% monitor availability requirement should have a minimum number of operational hours boundary, due to the possibility of low operational hour units (i.e. peaking units) could easily exceed the >95% availability threshold with just a few monitor issues. Although any future such issue could be handled by the Department taking enforcement discretion, such an event will penalize Southern Power in the annual Certification of Compliance. In order to alleviate this possible issue, Southern Power suggest a minimum of 760 operating hour as a threshold for the >95% availability requirement.

Oleander Power Project Unit 5

October 24, 2006

Page 3

Southern Power appreciates the opportunity to provide these comments and looks forward to the opportunity to discuss the resolution of our concerns. If you should have any questions regarding this information or would like recommended language submitted, please feel free to give me a call at (850) 444-6537.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin M. White". The signature is fluid and cursive, with a prominent initial "K" and "W".

Kevin M. White, P.E.

Engineer of Environmental Affairs

cc: Cindy Mulkey, FDEP Bureau of Air Regulation  
Jim Vick, Gulf Power Company  
Dwain Waters, Gulf Power Company  
Brian Toth, Southern Power Company



# Orlando Sentinel

Published Daily


State of Florida } s.s.  
COUNTY OF ORANGE

Before the undersigned authority personally appeared Rachael Washington, who on oath says that he/she is the Legal Advertising Representative of Orlando Sentinel, a daily newspaper published at Orlando in Orange County, Florida; that the attached copy of advertisement, being a PUBLIC NOTICE in the matter of Oleander Power Project Unit 5 in the Orange Court, was published in said newspaper in the issue; of 10/17/06

Affiant further says that the said Orlando Sentinel is a newspaper published at Orlando, in said Orange County, Florida, and that the said newspaper has heretofore been continuously published in said Orange County, Florida, each Week Day and has been entered as second-class mail matter at the post office in Orlando in said Orange County, Florida, for a period of one year next preceding the first publication of the attached copy of advertisement; and affiant further says that he/she has neither paid nor promised any person, firm or corporation any discount, rebate, commission or refund for the purpose of securing this advertisement for publication in the said newspaper.

The foregoing instrument was acknowledged before me this 20 day of October, 2006, by Rachael Washington, who is personally known to me and who did take an oath.

(SEAL)



## PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION DEP File No. 0090180-003-AC, PSD-FL-377

Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine-Electrical Generator  
Brevard County

The Department of Environmental Protection (Department) gives notice of its intent to issue an Air Construction Permit to Oleander Power Project, L.P. The permit is to construct a 190 megawatt (MW) simple cycle combustion turbine-electrical generator (CT) to be known as Unit 5 of the Oleander Power Project in the City of Cocoa, Brevard County. A review under the Rules for the Prevention of Significant Deterioration of Air Quality (PSD) and a Best Available Control Technology (BACT) determination were required for emissions of nitrogen oxides (NOx) and particulate matter (PM/PMD) pursuant to Rule 62-212.400, Florida Administrative Code. The applicant's name and address are Oleander Power Project, L.P., 555 Townsend Road, Cocoa, Florida 32926.

The original Air Construction Permit issued in 1999 authorized construction of five General Electric 7FA simple cycle CTs with 60-foot stacks and two 1.8 million gallon fuel oil storage tanks. Only four CTs with stacks and the two fuel oil storage tanks were constructed. This draft permitting action re-authorizes construction of the fifth 7FA MW CT, a 60-foot stack and a smaller fuel oil storage tank with a nominal capacity of 900,000 gallons.

Unit 5 will be an intermittent duty CT (typically known as a peaking unit) and will fire natural gas as the primary fuel and No. 2 low sulfur fuel oil as back-up fuel. Unit 5 will be permitted to operate a total of 350 hours per year with a maximum of 500 hours of fuel oil firing. The Department has determined that BACT for NOx is 9.0 parts per million by volume, dry corrected to 15 percent oxygen (ppmv @15% O2). The limit will be achieved by use of inherently clean natural gas and use of Dry Low NOx/CO combustors.

A limit of 42 ppmvd NOx @15% O2 will apply while firing back-up fuel oil and will be achieved by water injection into the combustors for flame temperature control. Emissions of carbon monoxide (CO), PM/PMD, sulfuric acid mist (SAM), sulfur dioxide (SO2), volatile organic compounds (VOCs) and visible emissions (Opacity) will be minimized by the efficient, high-temperature combustion of clean fuels.

Estimates of maximum potential annual emissions from CT Unit 5 are summarized in the following table.

Parameter	PSD Maximum Potential Annual Emissions Rate	PSD Applicable Emissions Rate	PSD Applicable Emissions Rate
CO	124.8	124.8	124.8
NOx	124.8	124.8	124.8
PM10	124.8	124.8	124.8
SO2	124.8	124.8	124.8
VOC	124.8	124.8	124.8
Opacity	124.8	124.8	124.8

According to the applicant and as verified by the Department, maximum predicted air quality impacts due to worst case emissions from the proposed new project are less than the significant impact levels applicable to all PSD Class II areas. Therefore, multi-source PSD increment modeling was not required. The impacts on the nearest Class I area (Chassahowitzko National Wildlife Refuge on the Gulf coast) will be negligible. Based on the required analysis, the Department has reasonable assurance that the proposed project will not cause or contribute to a violation of any state or federal ambient air quality standard.

The Department will issue the final permit, in accordance with the conditions of the draft permit, unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for a public meeting concerning the proposed permit issuance for a period of 30 (thirty) days from the date of publication of this Public Notice of Intent to Issue Air Construction Permit. Written comments or requests for public meetings should be provided to the Department, Bureau of Air Regulation, 2605 State Avenue, Tallahassee, Florida 32399-2400. All written comments filed shall be made available for public inspection, if comments received result in a significant change to the proposed agency action, the Department shall revise the proposed permit and, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 F.S. before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below. Mediation is not available in this proceeding.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen (14) days of receipt of notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen (14) days of publication of the public notice or within fourteen (14) days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication, and another shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact; if there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C. Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Department of Environmental Protection  
Bureau of Air Regulation  
111 S. Magnolia Drive, Suite 4  
Tallahassee, Florida, 32301  
Telephone: 850/488-0114  
Fax: 850/921-9533

Department of Environmental Protection  
Central District Office  
3319 Maquire Boulevard, Suite 230  
Orlando, Florida 32805-3767  
Telephone: 407/894-7555  
Fax: 407/897-2966

The complete project file includes the application, technical evaluations, Draft Permit, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Program Administrator, South Permitting Section of the Bureau of Air Regulation at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114 for additional information. Key documents related to this permitting action are available at: [www.dep.state.fl.us/air/permits/permits/oleander.htm](http://www.dep.state.fl.us/air/permits/permits/oleander.htm).

COR103574-OCT-17



**STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION**

**OLEANDER POWER PROJECT, L.P.,**

**Petitioner,**

**v.**

**DEPARTMENT OF ENVIRONMENTAL  
PROTECTION,**

**Respondent.**

**OGC No. 06-2056  
DEP Permit No. 0090180-003-AC  
PSD-FL-377**

---

**ORDER CLOSING FILE**


On September 26, 2006, the Florida Department of Environmental Protection (Department) received a request for extension of time from Petitioner, Oleander Power Project, L.P. and Gulf Power Company, it's authorized representative, to file a petition for administrative hearing challenging the Department's decision to issue Permit No. 0090180-003-AC PSD-FL-377 for the Petitioner's facility in Brevard County, Florida. On October 09, 2006, the Department withdrew it's intent to issue the permit. There being no further matters to consider,

**IT IS ORDERED:**

- A. The intent having been withdrawn, the Department's file in this matter is closed.
- B. This order constitutes final agency action of the Department.
- C. Any party to this proceeding has the right to seek judicial review of this order under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within thirty days after the date this order is filed with the clerk of the Department.

DONE AND ORDERED this 12<sup>th</sup> day of October, 2006, in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION



JACK CHISOLM, Deputy General Counsel  
3900 Commonwealth Boulevard - MS 35  
Tallahassee, Florida 32399-3000  
850-245-2242 facsimile 850-245-2302

FILED on this date, pursuant to § 120.52, Florida Statutes,  
with the designated Department clerk, receipt of which is  
hereby acknowledged.

Sealandall  
CLERK

10/12/06  
DATE


**CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished  
via  U. S. Mail  facsimile  only, this 12<sup>th</sup> day of October, 2006, to:

Angela R. Morrison  
HOPPING GREEN & SAMS, P.A.  
Post Office Box 6526  
Tallahassee, FL 32314

Facsimile: 850/224-8551

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION



PATRICIA E. CORNER, Assistant General Counsel  
FL Bar 0224146  
3900 Commonwealth Boulevard - MS 35  
Tallahassee, Florida 32399-3000  
850/245-2242 Facsimile: 850/245-2302

with a courtesy copy via electronic mail to:

Trina L. Vielhauer - Chief, Bureau of Air Regulation  
Cindy Mulkey - Engineering Specialist, Bureau of Air Regulation

## Gibson, Victoria

---

**From:** Miskelley, Valerie  
**Sent:** Thursday, October 12, 2006 9:47 AM  
**To:** Gibson, Victoria; Mulkey, Cindy  
**Subject:** Oleander

**Attachments:** Ord Closing File Oleander 06-2056.pdf

Vickie and Cindy,

Here is the Order Closing File in the Oleander case (06-2056) for permit 00900180-003-AC PSD-FL-377. Let me know if you need anything else.



Ord Closing File  
Oleander 06-2...

Thanks,  
Valerie Miskelley  
Administrative Secretary  
FDEP Office of General Counsel  
3900 Commonwealth Blvd. MS 35  
Tallahassee, FL 32399-3000  
(850) 245-2260 SC 205-2260  
Fax: (850) 245-2302  
Valerie.Miskelley@dep.state.fl.us

## Gibson, Victoria

---

**From:** Mulkey, Cindy  
**Sent:** Friday, October 13, 2006 11:41 AM  
**To:** Linero, Alvaro; Comer, Patricia; Vielhauer, Trina  
**Cc:** Gibson, Victoria  
**Subject:** RE: Oleander Request For Extension

Pat,  
Go ahead and let them have the extension.  
Thanks,  
cindy

Cindy Mulkey  
Engineering Specialist  
Bureau of Air Regulation  
South Permitting Section  
(850) 921-8968  
FAX (850) 921-9533  
SC 291-8968

-----Original Message-----

From: Linero, Alvaro  
Sent: Friday, October 13, 2006 11:33 AM  
To: Comer, Patricia; Mulkey, Cindy; Vielhauer, Trina  
Subject: RE: Oleander Request For Extension

Thank you Pat. .

Thank you Cindy.

Cindy. I think you have full command of this issue. Just let Pat know your recommendation when you have one. Go ahead and copy me, Trina and Vicky when you let Pat know.

Al.

-----Original Message-----

From: Comer, Patricia  
Sent: Friday, October 13, 2006 10:28 AM  
To: Mulkey, Cindy; Linero, Alvaro; Vielhauer, Trina  
Subject: RE: Oleander Request For Extension

Thanks

I'll let Angela know you have the letter. Let me know about the final decision on the extension when you have it (no rush--we haven't even got a case or a file yet) Pat

-----Original Message-----

From: Mulkey, Cindy  
Sent: Friday, October 13, 2006 9:58 AM  
To: Comer, Patricia; Linero, Alvaro; Vielhauer, Trina  
Subject: RE: Oleander Request For Extension

Pat,  
We did receive the letter from Southern authorizing Jim Vick to act as agent for Oleander.

Al and Trina,

I just spoke to Kevin White. He sent the public notice to the paper yesterday to be published on the 17th. I don't have a problem with granting the motion unless you have any reason to object. Their biggest (and supposedly only) issue now is the limit of 30 minutes for fuel switching. They are saying it may take a little longer and are gathering some information to send to me. I am looking in to it.

**Best Available Copy**

Cindy

Cindy Mulkey  
Engineering Specialist  
Bureau of Air Regulation  
South Permitting Section  
(850) 921-8968  
FAX (850)921-9533  
SC 291-8968

-----Original Message-----

From: Comer, Patricia  
Sent: Thursday, October 12, 2006 2:50 PM  
To: Mulkey, Cindy; Linero, Alvaro; Vielhauer, Trina  
Subject: FW: Oleander Request For Extension

FYI  
For those wondering...my not objecting to their filing a motion doesn't act to grant the motion...so how do you guys feel about granting a motion to extend the time to petition on the new intent? Angela says 30-days is what she'll be asking for.  
Also, here's a draft of a letter that you are supposed to have a final of (?)... & if you don't already have it and don't get it in a week or so, please let me know and I'll follow up with Angela.  
Pat

-----Original Message-----

From: Comer, Patricia  
Sent: Thursday, October 12, 2006 2:42 PM  
To: 'ANGELA R MORRISON'  
Subject: RE: Oleander Request For Extension

Angela

Thanks for the heads-up.  
I have no objections to your filing a motion to extend the time to petition on the new Oleander intent. The timeframe for filing starts anew with the new intent, but I don't have anything nearby to calculate from...so 14 days from when the new intent to issue was received by your client, when ever that is.  
FYI-The OGC case file relating to the withdrawn intent is closed (you received the order), so if you file for an extension on the new intent, DEP OGC will open a new case file and won't be using the old case file number.

DARM needs to have the authorized representative letter. I really don't need a copy if they have it in their records. The only reason I asked last time was that DARM's records didn't reflect the information on your motion for extension. I'll forward the draft to them but a signed letter is needed as soon as possible. If you can follow up on that I'd really appreciate it.

I look forward to hearing from you.  
Pat

-----Original Message-----

From: ANGELA R MORRISON [mailto:AngelaM@hgslaw.com]  
Sent: Thursday, October 12, 2006 2:16 PM  
To: Comer, Patricia  
Subject: RE: Oleander Request For Extension

Pat: Thank you for sending by fax today the Order Closing File on the Oleander permit (OGC No. 06-2056, DEP Permit No. 0090180-003-AC). I had not realized that this permit had been withdrawn and an entirely new draft permit issued (dated October 9, 2006). I consulted with Jim Vick, the authorized representative for Oleander Power Project, L.P., and he would like another 30-day extension because there are apparently still some issues to work out. We would like to request an extension through November 27th for this new draft permit. I also realized that I never received the final letter appointing Jim as

the authorized rep. I saw a draft, and I have included the text of the letter in the body of this e-mail (at the end). I have requested a copy of the final, signed letter, and as soon as it has been received, I will forward a copy to you. Please let me know if the Department has any objections related to another 30-day extension for the new draft permit (issued October 9th). Thank you for your help with this. I sincerely appreciate it.  
Angela

Text of letter:

Mr. James O. Vick  
Environmental Affairs Director  
Gulf Power Company  
One Energy Place  
Bin 0328  
Pensacola, FL 32520

Dear Mr. Vick:

Southern Power Company, through its subsidiaries Oleander Power Project, LP, and Desoto County Generating Company, LLC, owns and operates electric generating units at these facilities. Also, through its Southern Company-Florida, LLC subsidiary, co-owns and operates the Stanton Unit A Combined-Cycle.

You are hereby authorized to represent and/or act as an agent of Southern Power Company in any and all matters dealing with the Florida Department of Environmental Protection (FDEP) relating to the Oleander Power Project, LP, the DeSoto County Generating Company, LLC, and the Stanton Unit A Combined-Cycle.

Very truly yours,

Robert G. Moore  
Sr. Vice President & SPO  
Southern Power Company

Angela R. Morrison, Esq.  
Hopping Green & Sams, P.A.  
Post Office Box 6526  
Tallahassee, FL 32314  
850.425.2258  
850.224.8551 (fax)  
Email: amorrisson@hgslaw.com  
Legal Assistant: Becky Berentsen  
Email: BeckyB@hgslaw.com  
Website: www.hgslaw.com

Notice: The information contained in this e-mail message and/or its attachment(s) may be an attorney-client matter and may include privileged and confidential information. If you are not the intended recipient, please delete this message and any attachments. Thank you.

>>> "Comer, Patricia" <Patricia.Comer@dep.state.fl.us> 10/3/2006 11:39 AM >>>  
Thanks, Angela.  
Pat

-----Original Message-----

From: ANGELA R MORRISON [mailto:AngelaM@hgslaw.com]  
Sent: Tuesday, October 03, 2006 11:20 AM  
To: Comer, Patricia  
Subject: Oleander Request For Extension

Pat,

Thank you for your call today. I spoke to Jim Vick, and he said that Southern Power will be preparing a letter to send Cindy within the next day or two explaining and clarifying that Southern Power owns Oleander Power Project, L.P., and Oleander Power Project, L.P., has appointed Jim Vick,



## Best Available Copy

individually, as its authorized representative for air permitting purposes. Also, I noted that the Title V permit for the existing units at the Oleander plant was issued to Oleander Power Project, L.P. Once I receive the letter from Jim, I will send you a copy immediately. I hope that this helps. If you have any questions in the meantime, please let me know.

Thanks,  
Angela

Angela R. Morrison, Esq.  
Hopping Green & Sams, P.A.  
Post Office Box 6526  
Tallahassee, FL 32314  
850.425.2258  
850.224.8551 (fax)  
Email: amorrisson@hgslaw.com  
Legal Assistant: Becky Berentsen  
Email: BeckyB@hgslaw.com  
Website: www.hgslaw.com

Notice: The information contained in this e-mail message and/or its attachment(s) may be an attorney-client matter and may include privileged and confidential information. If you are not the intended recipient, please delete this message and any attachments. Thank you.

THE STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

RECEIVED

SEP 26 2006

BUREAU OF AIR REGULATION

In the Matter of an  
Application for Permit by:

OGC No. \_\_\_\_\_

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, FL 32926

Oleander Power Project  
Simple Cycle Combustion Turbine Unit 5  
DEP File No. 0090180-003-AC  
Draft Permit No. PSD-FL-377  
Brevard County

Authorized Representative:  
Gulf Power Company  
One Energy Place  
Pensacola, FL 32520

**REQUEST FOR EXTENSION OF TIME**

By and through undersigned counsel, Oleander Power Project, L.P., (Oleander) and Gulf Power Company (Gulf) hereby request, pursuant to Florida Administrative Code Rule 62-110.106(4), an extension of time to and including October 27, 2006, in which to file a Petition for Administrative Proceedings in the above-styled matter. As good cause for granting this request, Oleander and Gulf state the following:

1. On September 13, 2006, Gulf received via electronic mail from the Department of Environmental Protection (Department) a website link to the draft Prevention of Significant Deterioration (PSD) Permit (Permit No. 0090180-003-AC, PSD-FL-377) and associated documents for the Oleander Power Project, Unit 5 located in Brevard County, Florida.
2. The draft permit and associated technical evaluation and preliminary determination contain several provisions that warrant clarification or correction.
3. Representatives of Oleander and Gulf have corresponded and will continue to correspond with staff of the Department's Bureau of Air Regulation in an effort to resolve all issues.


4. This request is filed simply as a protective measure to avoid waiver of Oleander's and Gulf's right to challenge certain conditions contained in the draft PSD Permit. Grant of this request will not prejudice either party, but will further their mutual interests and likely avoid the need to file a petition and proceed to a formal administrative hearing.

5. Counsel for Oleander and Gulf has contacted Pat Comer with the Department's Office of General Counsel and she is consulting with representatives of the Department's Bureau of Air Regulation regarding any potential objection to this request.

WHEREFORE, Oleander and Gulf respectfully request that the time for filing of a Petition for Administrative Proceedings in regard to the Department's draft PSD Permit (Permit No. 0090180-003-AC, PSD-FL-377) be formally extended to and including October 27, 2006. If the Department denies this request, Oleander and Gulf request the opportunity to file a Petition for Administrative Proceedings within 10 days of such denial.

Respectfully submitted this 25<sup>th</sup> day of September, 2006.

HOPPING GREEN & SAMS, P.A.



Angela R. Morrison  
Fla. Bar No. 0855766  
123 South Calhoun Street  
Post Office Box 6526  
Tallahassee, FL 32314  
Office: (850) 222-7500  
Fax: (850) 224-8551

E-mail: [AngelaM@hgslaw.com](mailto:AngelaM@hgslaw.com)


Attorney for OLEANDER POWER PROJECT, L.P.  
AND GULF POWER COMPANY

**CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that a copy of the foregoing has been furnished to the following by  
U.S. Mail on this 25<sup>th</sup> day of September, 2006:

Trina Vielhauer, Chief  
Bureau of Air Regulation  
Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Pat Comer, Esquire  
Office of General Counsel  
Department of Environmental Protection  
3900 Commonwealth Blvd.  
Tallahassee, FL 32399-2600

  
Attorney

**Gibson, Victoria**

---

**From:** Gibson, Victoria  
**Sent:** Tuesday, September 26, 2006 2:53 PM  
**To:** Mulkey, Cindy; Linero, Alvaro  
**Subject:** FW: Request for Extension of Time - 0090180-003-AC - Oleander Power Project, LP

**Importance:** High

**Attachments:** Di4700609252203A.PDF

FYI,

Attached is a copy of their request. Please cc me on your e-mail to Pat Comer when you decide to grant or deny.

Thanks.

Vickie

---

**From:** Crandall, Lea  
**Sent:** Tuesday, September 26, 2006 2:18 PM  
**To:** Gibson, Victoria  
**Subject:** FW: Request for Extension of Time - 0090180-003-AC - Oleander Power Project, LP



Di4700609252203A  
.PDF (533 KB)

**Lea Crandall**

Agency Clerk  
Department of Environmental Protection  
3900 Commonwealth Boulevard, MS 35  
Tallahassee, FL 32399-3000  
Phone: (850) 245-2212 SC: 205-2212  
Fax: (850) 245-2303

-----Original Message-----

**From:** Crandall, Lea  
**Sent:** Tuesday, September 26, 2006 9:59 AM  
**To:** Chisolm, Jack; Gingery, Betsy; Gibson, Victoria; Mulkey, Cindy  
**Subject:** Request for Extension of Time - 0090180-003-AC - Oleander Power Project, LP

FYI, a Request for Extension of Time was rec'd. today re: 0090180-003-AC - Oleander Power Project, LP.

Thanks,  
Lea

**Lea Crandall**

Agency Clerk  
Department of Environmental Protection  
3900 Commonwealth Boulevard, MS 35  
Tallahassee, FL 32399-3000  
Phone: (850) 245-2212 SC: 205-2212  
Fax: (850) 245-2303

## Gibson, Victoria

---

**From:** Mulkey, Cindy  
**Sent:** Tuesday, September 26, 2006 2:57 PM  
**To:** Gibson, Victoria  
**Subject:** FW: Oleander Turbine #5 PSD permit

Vickie,

Here is the correspondence with Pat C. yesterday regarding the extension of time for Oleander #5.

Cindy Mulkey  
Engineering Specialist  
Bureau of Air Regulation  
South Permitting Section  
(850) 921-8968  
FAX (850)921-9533  
SC 291-8968

---

**From:** Mulkey, Cindy  
**Sent:** Monday, September 25, 2006 4:43 PM  
**To:** Comer, Patricia  
**Cc:** Linero, Alvaro  
**Subject:** RE: Oleander Turbine #5 PSD permit

Pat, I just spoke to Al.  
He said this is fine.

Cindy Mulkey  
Engineering Specialist  
Bureau of Air Regulation  
South Permitting Section  
(850) 921-8968  
FAX (850)921-9533  
SC 291-8968

---

**From:** Comer, Patricia  
**Sent:** Monday, September 25, 2006 2:47 PM  
**To:** Mulkey, Cindy  
**Subject:** Oleander Turbine #5 PSD permit

Cindy

I got a phone call today from Angela Morrison with the Hopping law firm asking if we had any objections to a 30 day extension to petition, so I presume they'll be filing for one today or tomorrow. I left a voice message with Al but I think you worked on this permit.....any problem with a 30 day extension?

Thanks  
Pat

**Chronology of Activities**

OGC Number	<b>06</b>	<b>2056</b>	<b>05</b>	<b>AC</b>	District	<b>CENTRAL</b>	County	<b>BREVARD</b>
Style of Case	<b>OLEANDER POWER PROJECT, L.P. VS. DEP</b>							
Program Area	<b>AIR CONSTRUCT</b>				Mode	<b>ADMINISTRATIVE</b>		
Lead Attorney	<b>PATRICIA</b>	<b>E</b>	<b>COMER</b>		Status	<b>CLOSED</b>		
Forum Name				Forum Case Number				
Permit Appl	<b>0090180-003-AC</b>			Final Order Number				

Date *	Code	Activity Description
<b>09/12/2006</b>	<b>ITIP</b>	<b>INTENT TO ISSUE PERMIT</b>
<b>09/26/2006</b>	<b>AA</b>	<b>ASSIGNED TO LEAD ATTORNEY JACK J CHISOLM</b>
<b>09/26/2006</b>	<b>ACO</b>	<b>ADMIN. CASE OPENED IN OGC</b>
<b>09/26/2006</b>	<b>REX1</b>	<b>RECEIVED FIRST REQUEST FOR EXTENSION OF TIME</b>
<b>09/29/2006</b>	<b>AR</b>	<b>RE-ASSIGNED TO LEAD ATTORNEY PATRICIA E COMER</b>
<b>10/09/2006</b>		<b>WITHDRAWAL OF INTENT TO ISSUE PERMIT</b>
<b>10/12/2006</b>		<b>ORDER CLOSING FILE</b>
<b>10/12/2006</b>	<b>CC</b>	<b>CASE CLOSED IN OGC</b>

**Robert G. Moore**  
Senior Vice President  
Southern Power

**Southern Company Generation**  
600 North 18th Street / 15N-8193  
Post Office Box 2641  
Birmingham, Alabama 35291  
  
Tel 205.257.2120  
Fax 205.257.1407



October 3, 2006

BUREAU OF AIR REGULATION

OCT 11 2006

RECEIVED

Mr. James O. Vick  
Environmental Affairs Director  
Gulf Power Company  
One Energy Place  
Bin 0328  
Pensacola, FL 32520

Dear Mr. Vick:

Southern Power Company, through its subsidiaries Oleander Power Project, LP, and Desoto County Generating Company, LLC, owns and operates electric generating units at these facilities. Also, through its Southern Company-Florida, LLC subsidiary, co-owns and operates the Stanton Unit A Combined-Cycle.

You are hereby authorized to represent and/or act as an agent of Southern Power Company in any and all matters dealing with the Florida Department of Environmental Protection (FDEP) relating to the Oleander Power Project, LP, the DeSoto County Generating Company, LLC, and the Stanton Unit A Combined-Cycle.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert". The signature is stylized with a large, sweeping initial "R" and a horizontal line extending to the right.

RGM/mnb



## Mulkey, Cindy

---

**From:** White, Kevin [KWHITE@southernco.com]  
**Sent:** Wednesday, October 11, 2006 11:55 AM  
**To:** Mulkey, Cindy  
**Cc:** Vick, James O.  
**Subject:** Authorized Agent for SOuthern Power Company

**Attachments:** Scan001.pdf



Scan001.pdf (97  
KB)

Cindy,

As we discussed by telephone, the attached is an authorization letter for Mr. Jim Vick to act as an agent of the Southern Power Company. If you determine an original copy of this letter is required, please let me know.

Thank you for all your help on the Oleander Unit 5 permitting.

Kevin M. White, P.E.  
Environmental Affairs  
Gulf Power Company  
Phone: 850-444-6537  
Cell: 850-336-6222  
Radio: 30\*3018

<<Scan001.pdf>>

RECEIVED  
OCT 11 2006  
BUREAU OF AIR REGULATION



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

October 9, 2006

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. James O. Vick, Director  
Environmental Affairs  
Gulf Power Company  
One Energy Place  
Pensacola, Florida 32520

Re: Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine  
DEP File No. 0090180-003-AC (PSD-FL-377)

Dear Mr. Vick:

Enclosed is the Department's preliminary determination to issue an Air Construction Permit pursuant to the rules for the Prevention of Significant Deterioration of Air Quality (PSD) to Oleander Power Project, L.P. to construct a 190 megawatt simple cycle combustion turbine unit, stack, and fuel oil storage tank at the Oleander Power Project in Brevard County. The documents include: the "Intent to Issue Air Construction Permit"; the "Public Notice of Intent to Issue Air Construction Permit"; the Department's "Technical Evaluation and Preliminary Determination"; and the Draft Permit.

The Department hereby withdraws the Intent to Issue and the Draft Permit distributed on September 12, 2006.

The Public Notice must be published one time only in a newspaper of general circulation in the area affected, pursuant to Chapter 50, Florida Statutes. Proof of publication, i.e., newspaper affidavit, must be provided to the Department's Bureau of Air Regulation office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

Please submit any written comments you wish to have considered concerning the Department's proposed action to A. A. Linero at the above letterhead address. If you have any questions, please call Cindy Mulkey at 850/921-8968 (review engineer) or Debbie Nelson at 850/921-9537.

Sincerely,

Trina L. Vielhauer, Chief  
Bureau of Air Regulation

TLV/aal/cm

Enclosures

"More Protection, Less Process"

Printed on recycled paper.

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	<p>A. Signature  <i>James O. Vick</i> <input checked="" type="checkbox"/> Agent <input type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) <i>James O. Vick</i> C. Date of Delivery <i>10 13 06</i></p>
<p>1. Article Addressed to:</p> <p>Mr. James O. Vic, Director          Environmental Affairs          Gulf Power Company          One Energy Place          Pensacola, Florida 32520</p>	<p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes <input type="checkbox"/> No          If YES, enter delivery address below:</p> <p>3. Service Type  <input type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail  <input checked="" type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise  <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p> <p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>
<p>2. Article Number          (Transfer from service label)</p>	<p><i>7000 1670 0013 3110 0826</i></p>
<p>PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540</p>	

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
 (Domestic Mail Only; No Insurance Coverage Provided)

---

OFFICIAL USE

Mr. James O. Vick, Director

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
<b>Total Postage &amp; Fees</b>	<b>\$</b>	

Sent To  
 Mr. James O. Vick, Director  
 Street, Apt. No., or PO Box No.  
 One Energy Place  
 City, State, ZIP+4  
 Pensacola, Florida 32520

PS Form 3800, May 2000 See Reverse for Instructions

9290 DTTE ET00 029T 0002

In the Matter of an  
Application for Permit by:

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, Florida 32926

*Authorized Representative:*  
Mr. James O. Vick

DEP File No. 0090180-003-AC  
Draft Permit No. PSD-FL-377  
Oleander Power Project  
Unit 5 Simple Cycle Combustion Turbine  
Brevard County, Florida

### **INTENT TO ISSUE AIR CONSTRUCTION PERMIT**

The Department of Environmental Protection (Department) gives notice of its intent to issue an Air Construction Permit, copy of Draft Permit attached, for the proposed project as detailed in the application specified above and the attached Technical Evaluation and Preliminary Determination for the reasons stated below.

The applicant, Oleander Power Project, L.P., applied on May 4, 2006 to the Department for an Air Construction Permit to construct a 190 megawatt simple cycle combustion turbine, Unit 5, at the existing Oleander Power Project in the city of Cocoa, Brevard County.

The Department has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-212. The above actions are not exempt from permitting procedures. The Department has determined that an Air Construction Permit pursuant to the Rules for the Prevention of Significant Deterioration of Air Quality (PSD) is required.

The Department intends to issue this Air Construction Permit based on the belief that reasonable assurances have been provided to indicate that operation of these emissions units will not adversely impact air quality, and the emissions units will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C.

Pursuant to Section 403.815, F.S., and Rules 62-110.106(7)(a)1., and 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Construction Permit. The notice shall be published one time only in the legal advertisement section of a newspaper of general circulation in the area affected. Rule 62-110.106(7)(b), F.A.C., requires that the applicant cause the notice to be published as soon as possible after notification by the Department of its intended action. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Department at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-0114; Fax 850/921-9533). You must provide proof of publication within seven days of publication, pursuant to Rule 62-110.106(5), F.A.C. No permitting action for which published notice is required shall be granted until proof of publication of notice is made by furnishing a uniform affidavit in substantially the form prescribed in section 50.051, F.S. to the office of the Department issuing the permit. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rules 62-110.106(9) & (11), F.A.C.

The Department will issue the final permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for public meetings concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of the enclosed Public Notice of Intent to Issue Air Construction Permit. Written comments should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If comments received result in a

significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available in this proceeding.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief  
Bureau of Air Regulation

**PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT**

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DEP File No. 0090180-003-AC, PSD-FL-377

Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine-Electrical Generator

Brevard County

The Department of Environmental Protection (Department) gives notice of its intent to issue an Air Construction Permit to Oleander Power Project, L.P. The permit is to construct a 190 megawatt (MW) simple cycle combustion turbine-electrical generator (CT) to be known as Unit 5 at the Oleander Power Project in the City of Cocoa, Brevard County. A review under the Rules for the Prevention of Significant Deterioration of Air Quality (PSD) and a Best Available Control Technology (BACT) determination were required for emissions of nitrogen oxides (NO<sub>x</sub>) and particulate matter (PM/PM<sub>10</sub>) pursuant to Rule 62-212.400, Florida Administrative Code (F.A.C.). The applicant's name and address are Oleander Power Project, L.P., 555 Townsend Road, Cocoa, Florida 32926.

The original Air Construction Permit issued in 1999 authorized construction of five General Electric 7FA simple cycle CTs with 60-foot stacks and two 1.8 million gallon fuel oil storage tanks. Only four CTs with stacks and the two fuel oil storage tanks were constructed. This draft permitting action re-authorizes construction of the fifth 190 MW CT, a 60-foot stack and a smaller fuel oil storage tank with a nominal capacity of 900,000 gallons.

Unit 5 will be an intermittent duty CT (typically known as a peaking unit) and will fire natural gas as the primary fuel and No. 2 low sulfur fuel oil as back-up fuel. Unit 5 will be permitted to operate a total of 3,390 hours per year with a maximum of 500 hours of fuel oil firing. The Department has determined that BACT for NO<sub>x</sub> is 9.0 parts per million by volume, dry corrected to 15 percent oxygen (ppmvd @15% O<sub>2</sub>). The limit will be achieved by use of inherently clean natural gas and use of Dry Low NO<sub>x</sub>/CO combustors.

A limit of 42 ppmvd NO<sub>x</sub> @15% O<sub>2</sub> will apply while firing back-up fuel oil and will be achieved by water injection into the combustors for flame temperature control. Emissions of carbon monoxide (CO), PM/PM<sub>10</sub>, sulfuric acid mist (SAM), sulfur dioxide (SO<sub>2</sub>), volatile organic compounds (VOCs) and visible emissions (Opacity) will be minimized by the efficient, high-temperature combustion of clean fuels.

Estimates of maximum potential annual emissions from CT Unit 5 are summarized in the following table.

<u>Pollutant</u>	<u>Maximum Tons Per Year</u>	<u>PSD Significant Emission Rate Tons Per Year</u>	<u>PSD Review Required?</u>
CO	77.0	100	No
NO <sub>x</sub>	174.5	40	Yes
PM/PM <sub>10</sub>	34.5/34.5	25/15	Yes
SO <sub>2</sub>	37.1	40	No
SAM	2.7	7	No
VOC	11.4	40	No
Mercury	0.0006	0.1	No
Pb	0.0495	0.6	No
Formaldehyde	0.655	Not Applicable	No

According to the applicant and as verified by the Department, maximum predicted air quality impacts due to worst case emissions from the proposed new project are less than the significant impact levels applicable to all PSD Class II areas. Therefore, multi-source (PSD Increment) modeling was not required. The impacts to the nearest Class I area (Chassahowitzka National Wildlife Refuge on the Gulf coast) will be negligible. Based on the required analyses, the Department has reasonable assurance that the proposed project will not cause or contribute to a violation of any state or federal ambient air quality standard.

The Department will issue the final permit, in accordance with the conditions of the draft permit, unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for a public meeting concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of this Public Notice of Intent to Issue Air Construction Permit. Written comments or requests for public meetings should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below. Mediation is not available in this proceeding.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen (14) days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen (14) days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C. Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Department of Environmental Protection  
Bureau of Air Regulation  
111 S. Magnolia Drive, Suite 4  
Tallahassee, Florida, 32301  
Telephone: 850/488-0114  
Fax: 850/921-9533

Department of Environmental Protection  
Central District Office  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767  
Telephone: 407/894-7555  
Fax: 407/897-2966

The complete project file includes the application, technical evaluations, Draft Permit, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Program Administrator, South Permitting Section at the Bureau of Air Regulation at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114 for additional information. Key documents related to this permitting action are available at: [www.dep.state.fl.us/Air/permitting/construction/oleander.htm](http://www.dep.state.fl.us/Air/permitting/construction/oleander.htm)

**TECHNICAL EVALUATION  
AND  
PRELIMINARY DETERMINATION**

Oleander Power Project, L.P.

190 MW Simple Cycle Gas Turbine

Cocoa, Brevard County

DEP File No. 0090180-003-AC (PSD-FL-377)



Florida Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation – Air Permitting South  
2600 Blair Stone Road, MS #5505  
Tallahassee, FL 32399-2400

October 9, 2006



**I. APPLICATION INFORMATION**

**A. APPLICANT**

Oleander Power Project, L.P.  
 555 Townsend Road  
 Cocoa, Florida 32926

*Authorized Representative*

James O. Vick, Director Environmental Affairs  
 Gulf Power Company  
 One Energy Place  
 Pensacola, Florida 32520

**B. PROCESSING SCHEDULE**

- Application for Air Construction Permit received on May 4, 2006;
- Department's Request for Additional Information dated June 2, 2006;
- Applicant's Response to Request for Additional Information Received July 13, 2006 (complete);
- Department's Intent to Issue and Public Notice Package dated October 10, 2006.

**C. FACILITY LOCATION**

Oleander Power Project (OPP) is located in Cocoa just off Interstate 95 and State Road 520 in Brevard County. The site is 175 km from the nearest Federal Prevention of Significant Deterioration (PSD) Class I Area, the Chassahowitzka National Wildlife Refuge. The UTM coordinates for this site are Zone 17, 520.1 km East and 3,137.6 km North. The locations of Cocoa and OPP are shown in the following figures.




Figure 1. Location of Cocoa



Figure 2. OPP Location




Figure 3. Site Aerial Photograph

**D. FACILITY DESCRIPTION**

The regulated emissions units at the existing Oleander Power Project include four 190 megawatt (MW) General Electric 7FA simple cycle combustion turbine-electric generators (CT Units 001 through 004). The CTs have evaporative coolers, Dry Low NO<sub>x</sub>/CO (DLN) combustors and water injection equipment and can fire natural gas or No. 2 low sulfur (0.05 percent) fuel oil. The facility also includes four 60-foot stacks, two 1.8 million-gallon fuel oil storage tanks (Units 006 and 007) and water storage tanks. The original application included the construction of five combustion turbines (CTs), of which only four were constructed.

The facility's Standard Industrial Classification Codes are listed in the following Table:

**Table 1. Oleander Power Project SIC Codes**

STANDARD INDUSTRIAL CLASSIFICATION CODES (SIC)		
Industry Group No.	49	Electric, Gas, and Sanitary Services
Industry No.	4911	Electric Services

**E. REGULATORY CATEGORIES**

*Title I, Part C, Clean Air Act (CAA):* The facility is located in an area that is designated as “attainment”, “maintenance”, or “unclassifiable” for each pollutant subject to a National Ambient Air Quality Standard. The facility does not fall into one of the 28 Prevention of Significant Deterioration (PSD) Major Facility Categories with the lower PSD applicability threshold therefore the 250 tons per year threshold is applicable. Potential emissions of at least one regulated pollutant exceed 250 tons per year, therefore the facility is classified as a “Major Stationary Source” of air pollution with respect to Rule 62-212.400 F.A.C., Prevention of Significant Deterioration of Air Quality.

*Title I, Section 111, CAA:* Unit 5 will be subject to 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines for Which Construction is Commenced After February 18, 2005).

*Title I, Section 112, CAA:* The facility is not a “Major Source” of hazardous air pollutants (HAPs). Unit 005 will not be subject to 40 CFR 63, Subpart YYYY, National Emissions Standard for Hazardous Air Pollutants for Stationary Combustion Gas Turbines.

*Title IV, CAA:* The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

*Title V, CAA:* The facility is a Title V or “Major Source of Air Pollution” in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), and volatile organic compounds (VOC).

**F. PROJECT DESCRIPTION AS PROPOSED BY APPLICANT**

The applicant proposes to install one 190 megawatt (MW) General Electric (GE) 7FA simple cycle combustion turbine-electrical generator (CT Unit 5, ID 005) equipped with evaporative cooling, DLN combustors and water injection equipment. OPP also plans to install a new 60-foot stack and a nominal 900,000 gallon distillate fuel oil storage tank.

Additional project details, as proposed, are described below:

*Fuel:* Operation of Unit 5 for a total of 3,390 hours per year using natural gas as the primary fuel. The use of low sulfur fuel oil (0.05 % sulfur) as a back up fuel has been requested for up to 1000 hours, included in the 3,390.

*Controls:* NO<sub>x</sub> emission will be reduced with DLN combustion technology while firing natural gas, and water injection while firing fuel oil. Advanced burner design with good combustion practices will be used to minimize incomplete combustion of CO, PM<sub>10</sub>, and VOC. The use of natural gas and restricted operation on fuel oil will minimize emissions of SO<sub>2</sub> and sulfuric acid mist (SAM).

*Continuous Monitors:* The combustion turbine is required to continuously monitor NO<sub>x</sub> emissions in accordance with the acid rain provisions. The same monitor will be employed for demonstration of continuous compliance with the Best Available Control Technology (BACT) determination. Flue gas oxygen content or carbon dioxide content will be monitored as a diluent gas.


*Stack parameters:* Unit 5 will have a stack that is 60 feet tall with an approximate exit diameter of 22 feet. The following table summarizes the exhaust characteristics of the unit. Values given are approximate for operation at 59 degrees Fahrenheit (°F) and the characteristics of the actual delivered unit may differ somewhat. At 59 °F, the nominal capacity is approximately 170 MW when firing natural gas whereas the capacity is greater (nominally 180 to 190 MW) at lower temperature or when firing fuel oil.

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

**Table 2. Approximate Exhaust Characteristics of Unit 5 at 100% Load and 59° F**

<u>Fuel</u>	<u>Total Heat Input (LHV)</u>	<u>Compressor Inlet Temp.</u>	<u>Turbine Exhaust Temp., °F</u>	<u>Stack Flow ACFM @ 15% O<sub>2</sub></u>
Gas	1722 mmBtu/hr	59° F	1,111 °F	2,882,847
Oil	1920 mmBtu/hr	59° F	1,095 °F	3,297,214

The key components, with a focus on fairly recent improvements, of the GE 7FA CT are shown in the “quarter section” internal diagram. The overall look can be appreciated by the “three-quarter” section graphic of the similar 7FB following the diagram.



**Figure 4. Quarter Section of GE 7FA (top). Three-Quarter Section of GE 7FB (bottom) (GE Reports)**

**G. PROCESS DESCRIPTION**

A gas turbine is an internal combustion engine that operates with rotary rather than reciprocating motion. Ambient air is drawn into the 18-stage compressor of the GE 7FA (Figure 4) where it is compressed by a pressure ratio of about 15.5 times atmospheric pressure. The compressed air is then directed to the combustor section, where fuel is introduced, ignited, and burned. The combustion section consists of 14 separate can-annular combustors.

In general, flame temperatures in a typical combustor section can reach 3600°F. Units such as the GE 7FA operate at lower flame temperatures, which minimize NO<sub>x</sub> formation. The hot combustion gases are then diluted with additional cool air and directed to the turbine section at temperatures of approximately 2500°F. Energy is recovered in the turbine section in the form of shaft horsepower, of which typically more than 50 percent is required to drive the internal compressor section. The balance of recovered shaft energy is available to drive the external load unit such as an electrical generator. Turbine exhaust gas is discharged at a temperature greater than 1000 °F and high excess oxygen and is available for additional energy recovery.

There are three basic operating cycles for gas turbines. These are simple, regenerative, and combined cycles. In the OPP project, the unit will operate in simple cycle mode only, meaning that the gas turbine drives an electric generator while the exhausted gases are directed through the stack with no additional heat recovery.

**II. RULE APPLICABILITY**

**A. STATE REGULATIONS**

The project is subject to the applicable environmental laws specified in Section 403 of the Florida Statutes (F.S.). The Florida Statutes authorize the Department of Environmental Protection to establish rules and regulations regarding air quality as part of the Florida Administrative Code (F.A.C.). This project is subject to the following rules in the F.A.C.

<b>Chapter</b>	<b>Description</b>
62-4	Permitting Requirements
62-204	Air Pollution Control (Includes Adoption of Federal Regulations)
62-210	Stationary Sources – General Requirements
62-212	Stationary Sources – Preconstruction Review (including PSD Requirements)
62-213	Operation Permits for Major Sources of Air Pollution
62-214	Acid Rain Program Requirements
62-296	Stationary Sources – Emission Limiting Standards
62-297	Stationary Sources – Emissions Monitoring

**B. FEDERAL REGULATIONS**

This project is also subject to certain applicable federal provisions regarding air quality as established by the EPA in the Code of Federal Regulations (CFR) and summarized below.

<b>Title 40</b>	<b>Description</b>
Part 60	Standards of Performance for New Stationary Sources (NSPS)
Part 72	Acid Rain – Permits Regulation
Part 73	Acid Rain – Sulfur Dioxide Allowance System
Part 75	Acid Rain – Continuous Emissions Monitoring
Part 76	Acid Rain – Nitrogen Oxides Emissions Reduction Program
Part 77	Acid Rain – Excess Emissions

*Note: Acid rain requirements will be included in the Title V air operation permit.*

### **C. PSD PRECONSTRUCTION REVIEW REQUIREMENTS**

The Department regulates major air pollution sources in accordance with Florida's Prevention of Significant Deterioration (PSD) program, as described in Rule 62-212.400, F.A.C. A PSD review is only required in areas that are currently in attainment with the National Ambient Air Quality Standard (AAQS) for a given pollutant or areas designated as "unclassifiable" for the pollutant. A new facility is considered "major" with respect to PSD if the facility emits or has the potential to emit:

- 250 tons per year or more of any regulated air pollutant; or
- 100 tons per year or more of any regulated air pollutant and the facility belongs to one of the 28 Major Facility Categories; or
- 5 tons per year of lead.

For new PSD-major facilities and modifications to existing PSD-major sources, each regulated pollutant is reviewed for PSD applicability based on emissions thresholds known as the Significant Emission Rates (SERs) identified in Rule 62-210.200(243), F.A.C. Each pollutant exceeding the respective SER is considered "significant" and the applicant must employ the Best Available Control Technology (BACT) to minimize emissions, and evaluate the air quality impacts. Although a facility may be considered a "major stationary source" with respect to PSD because of only one regulated pollutant, it is required to implement BACT for each "PSD-significant" pollutant. In accordance with Rule 62-212.400(4), F.A.C., for the construction of any new "major stationary source" or the major "modification" of any existing major stationary source, the applicant must provide the following information:

- (a) A description of the nature, location, design capacity, and typical operating schedule of the source or modification, including specifications and drawings showing its design and plant layout;*
- (b) A detailed schedule for construction of the source or modification;*
- (c) A detailed description as to what system of continuous emission reduction is planned for the source or modification, emission estimates, and any other information necessary to determine best available control technology (BACT) including a proposed BACT;*
- (d) The air quality impact of the source or modification, including meteorological and topographical data necessary to estimate such impact and an analysis of "good engineering practice" stack height; and*
- (e) The air quality impacts, and the nature and extent of any or all general commercial, residential, industrial, and other growth which has occurred since August 7, 1977, in the area the source or modification would affect.*

## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

---

“Best Available Control Technology” or “BACT” as defined in Rule 62-210.200(38), F.A.C. is as follows:

- (a) *An emission limitation, including a visible emissions standard, based on the maximum degree of reduction of each pollutant emitted which the Department, on a case by case basis, taking into account:*
  1. *Energy, environmental and economic impacts, and other costs,*
  2. *All scientific, engineering, and technical material and other information available to the Department; and*
  3. *The emission limiting standards or BACT determinations of Florida and any other state; determines is achievable through application of production processes and available methods, systems and techniques (including fuel cleaning or treatment or innovative fuel combustion techniques) for control of each such pollutant.*
- (b) *If the Department determines that technological or economic limitations on the application of measurement methodology to a particular part of an emissions unit or facility would make the imposition of an emission standard infeasible, a design, equipment, work practice, operational standard or combination thereof, may be prescribed instead to satisfy the requirement for the application of BACT. Such standard shall, to the degree possible, set forth the emissions reductions achievable by implementation of such design, equipment, work practice or operation.*
- (c) *Each BACT determination shall include applicable test methods or shall provide for determining compliance with the standard(s) by means which achieve equivalent results.*
- (d) *In no event shall application of best available control technology result in emissions of any pollutant which would exceed the emissions allowed by any applicable standard under 40 CFR Parts 60, 61, and 63.*

The Department conducts its case-by-case BACT determinations in accordance with the requirements given above. Additionally the Department generally conducts its reviews in such a manner that the determinations are consistent with those conducted using the Top/Down Methodology described by EPA.<sup>1</sup>

In addition to a determination of BACT, PSD review also requires an Air Quality Analysis for each pollutant exceeding the SER. The Air Quality Analysis consists of: an air dispersion modeling analysis to estimate the resulting ambient air pollutant concentrations; a comparison of modeled concentrations from the project with National Ambient Air Quality Standards and PSD Increments; an analysis of the air quality impacts from the proposed project upon soils, vegetation, wildlife, and visibility (Air Quality Related Values – AQRVs); and an evaluation of the air quality impacts resulting from associated commercial, residential, and industrial growth related to the proposed project.

### **D. PSD APPLICABILITY FOR THE PROJECT**

The project will result in emissions of carbon monoxide, nitrogen oxides, sulfur dioxides, particulate matter, sulfuric acid mist (SAM), volatile organic compounds, lead (Pb), mercury (Hg), formaldehyde, and flourides. The following table summarizes the annual potential emissions in tons per year (TPY) from the project as proposed by the applicant.

Table 3. Estimate of Potential Annual Emissions as Proposed by Applicant.

Pollutant	Project Emissions TPY	PSD Significant Emission Rate TPY	PSD Review Required?
NO <sub>x</sub>	243.1	40	Yes
SO <sub>2</sub>	58.9	40	Yes
CO	83.7	100	No
PM	38.5	25	Yes
PM <sub>10</sub>	38.5	15	Yes
VOC	12.9	40	No
SAM	4.5	7	No
Mercury	0.0012	0.1	No
Lead	0.0489	0.6	No
Formaldehyde	0.672	Not Applicable	NAo
Total Fluorides	Negligible	3.	No

As proposed by Applicant, the project is subject to PSD preconstruction review and BACT determinations for NO<sub>x</sub>, SO<sub>2</sub>, and PM/PM<sub>10</sub>.

III. BEST AVAILABLE CONTROL TECHNOLOGY (BACT) – Draft Determinations

A. NITROGEN OXIDES (NO<sub>x</sub>)

1. Discussion of NO<sub>x</sub> Formation

Nitrogen oxides form in the combustion turbine process as a result of the dissociation of molecular nitrogen and oxygen to their atomic forms and subsequent recombination into seven different oxides of nitrogen. Uncontrolled emissions range from about 100 to over 600 parts per million by volume, dry, corrected to 15 percent oxygen (ppmvd @15% O<sub>2</sub>). The Department estimates uncontrolled emissions at approximately 200 ppmvd @15% O<sub>2</sub> for a GE 7FA combustion turbine.<sup>2</sup>

Thermal NO<sub>x</sub> forms in the high temperature area of the combustor. Thermal NO<sub>x</sub> increases exponentially with increases in flame temperature and linearly with increases in residence time. Flame temperature is dependent upon the ratio of fuel burned in a flame to the amount of fuel that consumes all of the available oxygen, also known as the equivalence ratio. By maintaining a low fuel ratio (lean combustion), the flame temperature will be lower, thus reducing the potential for NO<sub>x</sub> formation. The changes in NO<sub>x</sub> production as flame temperatures vary due to increasing/decreasing equivalence ratios can be seen in Figure 5 below.





Figure 5. NO<sub>x</sub> vs. Temperature, Equivalence Ratio.<sup>3</sup> Figure 6. Hot Gas Path Parts, NO<sub>x</sub> Control

In most combustor designs, the high temperature combustion gases are cooled to an acceptable temperature with dilution air prior to entering the turbine (expansion) section. The sooner this cooling occurs, the lower the thermal  $\text{NO}_x$  formation. The relationship between flame temperature, firing temperature, unit efficiency, and  $\text{NO}_x$  formation is depicted in Figure 6, which is from a General Electric discussion on these principles.

Prompt  $\text{NO}_x$  is formed in the proximity of the flame front as intermediate combustion products. The contribution of prompt to overall  $\text{NO}_x$  is relatively small in near-stoichiometric combustors and increases for leaner fuel mixtures. This provides a practical limit for  $\text{NO}_x$  control by lean combustion.

Fuel  $\text{NO}_x$  is formed when fuels containing bound nitrogen are burned. This phenomenon is not of great concern when combusting natural gas.

For the purpose of further discussion, concentrations expressed in terms of ppmvd presume correction to 15%  $\text{O}_2$  unless otherwise noted.

## 2. Descriptions of Available $\text{NO}_x$ Controls

Wet Injection. Fuel and air are mixed within traditional combustors and the combustion actually occurs on the boundaries of the flame. This is termed “diffusion flame” combustion. Injection of either water or steam directly into the combustor lowers the flame temperature and thereby reduces thermal  $\text{NO}_x$  formation. There is a physical limit to the amount of water or steam that may be injected before flame instability or cold spots in the combustion zone would cause adverse operating conditions for the combustion turbine. Carbon monoxide (CO) and hydrocarbon (HC) emissions are relatively low for most gas turbines. However steam and (more so) water injection may increase emissions of both of these pollutants.

Advanced dual fuel combustor designs can tolerate large amounts of steam or water without causing flame instability and can achieve  $\text{NO}_x$  emissions in the range of 30 to 42 ppmvd when employing wet injection for backup fuel oil firing. Wet injection results in control efficiencies on the order of 80 to 90% for oil firing. These values often form the basis, particularly in combined cycle turbines, for further reduction to BACT limits by other techniques as discussed below. During dry low- $\text{NO}_x$  combustion while gas firing, wet injection is not employed.

Dry Low  $\text{NO}_x$ /CO (DLN) Combustion. The excess air in lean combustion cools the flame and reduces the rate of thermal  $\text{NO}_x$  formation. Lean premixing of fuel and air prior to combustion can further reduce  $\text{NO}_x$  emissions. This is accomplished by minimizing localized fuel-rich pockets (and high temperatures) that can occur when trying to achieve lean mixing within the combustion zones. This principle is incorporated into the General Electric DLN-2.6 can-annular combustor shown in the following figure.




Figure 7. DLN-2.6 Fuel Nozzle Arrangement




## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Each combustor includes six nozzles within which fuel and air have been fully pre-mixed. There are 16 small fuel passages around the circumference of each combustor can known as quaternary fuel pegs. The six nozzles are sequentially ignited as load increases in a manner that maintains lean pre-mixed combustion and flame stability.

Design NO<sub>x</sub>, CO, and VOC emission characteristics of the DLN-2.6 combustor while firing natural gas are given in Figure 8 below for a unit tuned to meet a limit of 9 ppmvd. The values for CO are “uncorrected” for O<sub>2</sub>. Values for VOC are uncorrected, “wet basis”, and do not include methane and ethane because they are not defined as VOC.

The combustor design is such that NO<sub>x</sub> concentrations equal 9 ppmvd at loads between 50 and 100 percent of capacity, but concentrations as high as 100 ppmvd may occur at less than 50 percent of capacity. This suggests the need to minimize operation at low load conditions.



**Figure 8. Design Emission Characteristics for DLN-2.6. Figure 9. NO<sub>x</sub> Performance of DLN-2.6**

Figure 9 is from a GE publication and is a plot of NO<sub>x</sub> data from actual installations or possibly a test facility: Actual NO<sub>x</sub> emissions are less than the design values. The Department has reviewed numerous reports and low load operation data from GE 7FA CTs in Florida and can confirm the accuracy of the graph on the right. Also actual emissions of CO and VOC have proven to be much less than suggested by the diagram.


Table 4 summarizes the results of the new and clean tests conducted on a dual-fuel GE 7FA CT with DLN 2.6 combustors operating in simple cycle mode and burning natural gas at the existing Tampa Electric Polk Power Station.<sup>4</sup> The test results confirm that NO<sub>x</sub>, CO, and VOC emissions are less than the design characteristics published by GE and given on the left hand side of the figure 8 above.

**Table 4. Actual Performance of DLN-2.6 Combustors at Tampa Electric Polk Power Station.**



Percent of Full Load	NO <sub>x</sub> (ppmvd @15% O <sub>2</sub> )	CO (ppmvd)	VOC (ppmvd)
50	5.3	1.6	0.5
70	6.3	0.5	0.4
85	6.2	0.4	0.2
100	7.6	0.3	0.1

Numerous simple cycle GE 7FA units with DLN technology for NO<sub>x</sub> control have been installed in Florida and throughout the United States with guarantees of 9 ppmvd. This represents a reduction of approximately 95 percent compared with uncontrolled emissions if assumed to equal 200 ppmvd.

Selective Catalytic Reduction (SCR). Selective catalytic reduction (SCR) is an add-on NO<sub>x</sub> control technology that is employed in the exhaust stream following the gas turbine. SCR reduces NO<sub>x</sub> emissions by injecting ammonia into the flue gas in the presence of a catalyst. Ammonia reacts with NO<sub>x</sub> in the presence of a catalyst and excess oxygen yielding molecular nitrogen and water according to the following simplified reaction:



The catalysts used in combined cycle, low temperature applications (conventional SCR), are usually vanadium (V) and titanium oxide (TiO<sub>2</sub>) formulations and account for most installations. At high temperatures, V can contribute to ammonia oxidation forming more NO<sub>x</sub> or forming nitrogen (N<sub>2</sub>) without reducing NO<sub>x</sub> according to:



For high temperature applications (hot SCR up to approximately 1100 °F), such as large frame simple cycle turbines, special formulations or strategies are required. SCR technology has progressed considerably over the last decade with Zeolite catalyst now being used for high temperature applications. SCR units are typically used in combination with wet injection or DLN combustion controls.

In the past, sulfur was found to poison the catalyst material. Sulfur-resistant catalyst materials are now available as evidenced by both hot and conventional installations at coal-fired plants. Such improvements have proven effective in resisting sulfur-induced performance degradation with fuel oil in Europe and Japan, where conventional SCR (low temperature) catalyst life in excess of 4 to 6 years has been achieved, while 8 to 10 years catalyst life has been reported with natural gas.

There are several examples of combined cycle SCR systems operating in Florida including:

- Kissimmee Utilities Authority Unit 3. 3.5 ppmvd NO<sub>x</sub> on gas, 12 ppmvd on fuel oil.
- Progress Energy Hines Block 2. 3.5 ppmvd on gas and 12 ppmvd on fuel oil.
- JEA Brandy Branch. 3.5 ppmvd on gas and 12 ppmvd on fuel oil.
- TEC Bayside – seven combustion turbines. 3.5 ppmvd on gas.
- FP&L Manatee Unit 3. 2.5 ppmvd on gas and 10 ppmvd on fuel oil
- FP&L Martin Unit 8. 2.5 ppmvd on gas and 10 ppmvd on fuel oil.

More recently, DEP issued permits for the Treasure Coast Energy Center Unit 1 and FP&L Turkey Point Unit 5 with NO<sub>x</sub> limits of 2.0 ppmvd on gas and 8.0 ppmvd on fuel oil. The Department also required SCR on two recently constructed GE LM6000 simple cycle units at the City of Tallahassee's Hopkins facility.

SCR is a commercially available, demonstrated control technology currently employed on numerous combustion turbine projects permitted with very low NO<sub>x</sub> emissions.

### 3. Applicant's NO<sub>x</sub> BACT Proposal

The applicant eliminated several NO<sub>x</sub> control strategies (including XONON<sup>TM</sup>, Selective Non-Catalytic Reduction, Non-Selective Catalytic Reduction, and SCONOX<sup>TM</sup>), based on either present technical infeasibility or unavailability for the size of CT under review. Therefore, the submitted BACT analysis was limited to DLN combustors for natural gas firing, wet injection for oil firing, and SCR as an add-on control.

The applicant estimated the installed capital cost of a hot SCR system at \$7,919,200 and the total annualized cost to be \$1,985,500 per year to further reduce emissions from 9/42 ppmvd (gas/oil) to 3.5/10 ppmvd (gas/oil). This yields an overall reduction in NO<sub>x</sub> emissions of 174 tons per year. The cost effectiveness for an SCR system was estimated to be \$11,414 per ton of NO<sub>x</sub> removed. The applicant concluded that the use of hot SCR on Unit 5 is not cost effective.

The applicant proposed BACT limits of 9.0 ppmvd while firing natural gas and 42.0 ppmvd while firing fuel oil, based on the use of Dry Low NO<sub>x</sub> combustors and water injection for natural gas and fuel oil firing respectively.

#### **4. Department's Review and Draft NO<sub>x</sub> BACT Determination**

##### SCR Considerations:

California has one of the most stringent New Source Review programs in the country. The current BACT level for NO<sub>x</sub> emissions from natural gas-fired electrical generation turbines is  $\leq 2.0$  and  $\leq 3.0$  ppmvd for cogeneration/combined-cycle and simple-cycle power plants, respectively.<sup>5</sup>

The definition of BACT in California is closer to the Lowest Achievable Emissions Rate (LAER) definition that applies in most states under Non-attainment New Source Review. Nevertheless, LAER (in this case California BACT) is typically considered to be the "top" control in BACT reviews.

The Department considers 3 ppmvd NO<sub>x</sub> as the "top" control and it is achievable by SCR. A permit recently issued to the City of Tallahassee for two simple cycle units includes BACT limits of 5 ppmvd achievable by SCR for NO<sub>x</sub>.

The previously mentioned Tallahassee Hopkins project allows more frequent operation (up to 5,840 hours per CT per year) than the proposed unit (3,390 hours), a large portion of which may be oil firing. Also the pre-control emissions are greater for the natural gas firing case (25 ppmvd) compared with the present case. As a result, the cost per ton of reducing emissions from 25 to 5 ppmvd for the Tallahassee units is less compared with emission reductions from 9 to 3.5 ppmvd for the present project.

The Department does not agree with the analysis provided by the applicant and yielding a cost-effectiveness of \$11,414/ton NO<sub>x</sub> removed. The value given is an incremental cost-effectiveness value that is not the sole basis for making a final conclusion regarding cost-effectiveness. The average cost-effectiveness of control and the credit for the power produced by water injection (mass throughput increase) are not included.

However, the Department agrees that SCR is not cost-effective for the project given that it is indeed a natural gas-fired unit. For example a recently permitted simple cycle CT project at the Tampa Electric Company (TEC) Bayside and Polk Power Stations were issued with limits of 9 ppmvd and no back-up fuel oil firing.

##### Fuel Oil Considerations

It is recognized that some allowance can and should be made for limited back-up fuel oil firing to account for interruptions in the natural gas supply or sudden and unexpected price spikes. In that case a limit of 42 ppmvd achieved by wet injection during 500 hours of incidental fuel oil firing is appropriate but is not BACT.

For reference, the facility is already permitted to use fuel oil up to 5,000 hours aggregate for the four previously constructed CTs. The large back-up fuel oil allowance was made prior to the significant expansion of the gas delivery system in Florida. The subsequent gas network expansions included several construction phases by the Florida Gas Transmission Company (FGT), construction of the Gulfstream Pipeline, and expansion of the liquefied natural gas (LNG) terminal at Elba Island, Georgia.

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

Historically fuel oil usage at the Oleander site has actually been very low. The oil and gas usage from each of the four existing CTs as reported to FDEP is presented in Table 5. The percentage of allowable fuel use is based on total annual heat input and the 12-month allowable heat input adjusted for four units.

**Table 5. Historical Fuel Use, Oleander Units 1, 2, 3, and 4.**

YEAR	EU ID	Gas			Oil			Total Hrs Operation
		Annual Rate (mm ft <sup>3</sup> )	Total Heat Input (mmBtu)	% of Allowable	Annual Rate (1000 Gallons)	Total Heat Input (mmBtu)	% of Allowable	
2002	1	1,395	1,295,955		795	105,002		976
	2	994	923,547		2,785	367,620		880
	3	643	597,078		522	68,950		509
	4	592	550,210		394	51,949		486
	All Units	3,624	3,366,789	14.42	4,496	593,521	7.73	2,851
2003	1	2,228	2,069,812		3,260	430,320		1,534
	2	2,267	2,106,043		1,784	235,488		1,697
	3	2,304	2,140,416		847	111,804		1,755
	4	2,065	1,918,385		1,282	169,224		1,600
	All Units	8,864	8,234,656	35.27	7,173	946,836	12.34	6,586
2004	1	1,357	1,261,099		1,545	203,990		1,106
	2	970	900,740		1,136	150,013		862
	3	817	759,337		954	125,941		681
	4	1,041	967,488		620	81,837		861
	All Units	4,186	3,888,664	16.65	4,256	561,781	7.32	3,510
2005	1	1,288	1,196,487		641	84,657		906
	2	607	564,070		1,798	237,337		576
	3	499	463,432		1,428	188,438		467
	4	236	219,309		1,457	192,327		270
	All Units	2,630	2,443,298	10.46	5,324	702,759	9.16	2,219

The column on the far right suggests that typically individual units run less than 1000 hours per year on both fuels combined. The greatest amount of fuel oil use on any unit was during 2003 on Unit 1. By proportioning the heat input for each fuel to total hours of operation, an estimate of approximately 400 hours of fuel oil firing is obtained. A similar calculation for Unit 4 during 2005 suggests approximately 130 hours of fuel oil firing. Overall, the historical use of fuel oil (even before completion of the gas expansion projects and during several hurricane seasons) at the existing units supports the adequacy of a 500 hour limit on fuel oil firing.

Typically distillate fuel oil prices are significantly greater than natural gas prices and the fuels do not typically compete within the power industry in Florida. Distillate fuel oil is only used during short-term supply interruptions and temporary natural gas price dislocations. Within the power industry, natural gas and the higher sulfur residual fuel oil (not allowed for the proposed project) do in fact compete for use in older conventional power plants.

According to a recent (July 2006) U.S. Department of Energy report, “changing market conditions in the United States over the past 7 months have led to dramatic decreases in natural gas prices from the historically high levels prevailing at the beginning of the year.”<sup>6</sup>

## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

---

According to the same report, "in the near-term, natural gas prices are expected to not be constrained unduly by residual fuel oil prices. Although natural gas prices are projected again to exceed residual fuel oil prices by the 2006-2007 winter, this historical pattern is expected to be reversed by April 2007. However, while the current trend continues, natural gas will be an economically attractive choice for electric utilities, as well as other energy customers." Here the attractiveness is in relative terms.

A similar comparison (to the natural gas/residual fuel oil comparison) between distillate fuel oil and natural gas would be even more pronounced in favor of lower relative natural gas prices. It is reasonable to conclude that natural gas will continue to be more attractive for use in combustion turbines than distillate fuel oil on the basis of price. It is also more favorable on the basis of equipment maintenance.

### BACT Determination:

Considering the above discussions, the Department has made the following determination for the control of NO<sub>x</sub> emissions from proposed Unit 5:

- NO<sub>x</sub> emissions while firing natural gas shall be limited to 9.0 ppmvd as BACT achievable by natural gas firing and use of Dry Low NO<sub>x</sub> combustion.
- The continuous limits for NO<sub>x</sub> shall be based on 24-hr rolling averages.

### Incidental Back up Fuel Oil Limits:

Back-up fuel oil use shall be limited to 500 hours per year and NO<sub>x</sub> emissions shall be limited to 42.0 ppmvd (NSPS) achievable by injection of water into the combustors for flame cooling.

## **B. SULFUR DIOXIDE (SO<sub>2</sub>)**

The Department determined that BACT for NO<sub>x</sub> is 9 ppmvd and limited the use of back-up low sulfur (0.05% sulfur) fuel oil to 500 hours per year. As a result, the potential emissions of SO<sub>2</sub> for the project decreased by 21.8 tons per year (TPY) from 58.9 to 37.1 TPY which is below the PSD significant threshold at which the BACT and Air Quality Analyses are required.

A BACT determination is not required for SO<sub>2</sub>. The Department will not require use of ultra low sulfur diesel for this project.

The Department will set the following emission limits to insure that emissions from the project will be less than 40 tons per year and not trigger PSD.

- Natural gas containing no more than 1.5 grains of sulfur per 100 standard cubic feet may be fired for up to 3,390 hours per year.
- Unit 5 may be fired using low sulfur diesel fuel oil (0.05 % sulfur) for up to 500 hours of the total 3,390 allowable operating hours.

## **C. PARTICULATE MATTER (PM/PM<sub>10</sub>)**

Particulate matter (PM/PM<sub>10</sub>) is emitted from combustion turbines due to incomplete combustion of ash and sulfur present in the fuels. They are minimized by use of clean fuels, with low ash and sulfur contents, and good combustion practices. Clean fuels are a necessity in combustion turbines in order to avoid excessive maintenance due to damaged turbine blades and other components already exposed to very high temperatures and pressures.

The use of DLN combustor technology to maximize combustion efficiency, and the use of low ash, low sulfur fuels is proposed as BACT for PM/PM<sub>10</sub>. The Department also recognizes that PM<sub>2.5</sub> is now a regulated pollutant. PM<sub>10</sub> will be used as a surrogate for PM<sub>2.5</sub> as per EPA guidance. According to the applicant, combustion efficiency is projected to be greater than 99 percent with the DLN technology. Additionally, a visible emissions limit of 10 percent opacity has been proposed as a surrogate limit for

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

PM/PM<sub>10</sub>. The Department agrees with the applicant, and the draft BACT standard for PM/PM<sub>10</sub> is the proposed fuel specifications and opacity limit.

**D. SUMMARY OF DEPARTMENT DRAFT BACT DETERMINATIONS**

The Department establishes the following standards as the Best Available Control Technology for the simple cycle combustion turbine Unit 5 at the Oleander Power Project.

**Table 6. Draft BACT Determinations – Oleander Power Project Unit 5**

Pollutant	Fuel	Emission Standard/Limit <sup>c</sup>	Averaging Time	Compliance Method	Basis
NO <sub>x</sub>	Gas	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr rolling	CEMS	BACT
		62.5 lb/hr	3-hr	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	Gas/Oil	10 % Opacity	6-minute block	Stack Test	BACT
		1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	Gas/Oil	1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	BACT Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the gas turbine represents (BACT) for PM/PM<sub>10</sub> emissions.
- b. The fuel sulfur specifications effectively limit the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from the gas turbine.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

In combination with the annual restriction of hours of operation on oil and gas, the above emissions standards effectively limit annual potential emissions from the combustion turbine to the amounts listed in the table below. The parenthetical numbers reflect the applicant’s original proposal.

**Table 7. Project Potential Annual Emissions Estimates after BACT and (as Proposed)**

Pollutant	Project Emissions (TPY)	PSD Significant Emission Rate (TPY)	PSD Review Required?
NO <sub>x</sub>	174.5 (243.1)	40	Yes
SO <sub>2</sub>	37.1 (58.9)	40	No
CO	77 (83.7)	100	No
PM	34.5 (38.5)	25	Yes
PM <sub>10</sub>	34.5 (38.5)	15	Yes
VOC	11.4 (12.9)	40	No
SAM	2.7 (4.5)	7	No
Mercury	0.0006 (0.0012)	0.1	No
Lead	0.0495 (0.0489)	0.6	No
Total Fluorides	Negligible	3	No
Formaldehyde	0.655 (0.672)	NA	NA

#### IV. NEW SOURCE PERFORMANCE STANDARDS

##### A. COMBUSTION TURBINES

New stationary gas turbines are subject to the federal New Source Performance Standards in Subpart KKKK of 40 CFR 60. This federal regulation establishes the following emission standards for new combustion turbines with a heat input at peak load of > 850 mmBtu/hr.

- NO<sub>x</sub> (while firing natural gas) - 15 ppm @ 15 percent O<sub>2</sub> or 0.43 lb/ MWh
- NO<sub>x</sub> (while firing fuels other than natural gas) - 42 ppm at 15 percent O<sub>2</sub> or 1.3 lb/MWh
- SO<sub>2</sub> - 0.90 lb/MWh gross output, or 0.060 lb SO<sub>2</sub>/MMBtu heat input

The Department considers the draft BACT standards more stringent than the NSPS standards. However, the NSPS also has other specific requirements for notification, record keeping, performance testing, and monitoring of operations. An Appendix to the permit will summarize applicable federal requirements.

#### V. PERIODS OF EXCESS EMISSIONS

##### A. EXCESS EMISSIONS PROHIBITED

In accordance with Rule 62-210.700(4), F.A.C., "Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited." All such preventable emissions shall be included in the compliance determinations for NO<sub>x</sub> emissions.

##### B. ALLOWABLE DATA EXCLUSIONS

In accordance with Rule 62-210.700, F.A.C., "Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration." In addition, the rule states that, "Considering operational variations in types of industrial equipment operations affected by this rule, the Department may adjust maximum and minimum factors to provide reasonable and practical regulatory controls consistent with the public interest."

Operation of the General Electric Frame 7FA combustion turbine in lean premix mode is achieved at least by 50% of base load conditions. Simple cycle gas turbines are designed for quick startup and operate at high load levels. Operation of the large frame gas turbines is generally automated and malfunctions have been infrequent.

Dry Low NO<sub>x</sub> combustion systems require initial and periodic "tuning" to account for changing ambient conditions, changes in fuels and normal wear and tear on the unit. Tuning involves optimizing NO<sub>x</sub> and CO emissions, and extends the life of the unit components. During tuning, it is possible to have elevated emissions while collecting emission data used in the tuning process. However, the duration of data collection is relatively short, and once tuned, the gas turbine emissions will be minimized. A major tuning session would typically occur after completion of initial construction, a combustor change-out, a major repair or maintenance to a combustor, or other similar event. Other minor tuning sessions are expected to occur periodically on an as needed basis between major tuning sessions.

Based on information from General Electric regarding startup and shutdown, and the information above regarding tuning, the Department establishes the following conditions for excess emissions for the combustion turbine for which a limited amount of data may be excluded from the NO<sub>x</sub> continuous compliance determinations.

- Excess emissions resulting from startup, shutdown, or malfunction shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized.

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

- For each startup, up to 30 consecutive minutes of excess emissions may be excluded from the continuous compliance determinations.
- For each shutdown, up to 30 consecutive minutes of excess emissions may be excluded from the continuous compliance determinations.
- No more than 2 hours of CEMS data in any 24-hour period shall be excluded from compliance demonstrations due to a malfunction.
- CEMS data collected during initial or other DLN tuning sessions may be excluded from the compliance demonstrations provided that tuning session is performed in accordance with the manufacturer's specifications. Prior to performing any tuning sessions, the permittee shall provide the Compliance Authority with an advance notice detailing the activity and proposed tuning schedule.

**VI. AIR QUALITY IMPACT ANALYSIS**

**A. INTRODUCTION**

The proposed project will increase emissions of two pollutants at levels in excess of PSD significant amounts: PM/PM<sub>10</sub> and NO<sub>x</sub>. PM<sub>10</sub> and NO<sub>x</sub> are criteria pollutants and have national and state ambient air quality standards (AAQS), PSD increments, significant impact levels and de minimis monitoring levels defined for them.

**B. MAJOR STATIONARY SOURCES IN BREVARD COUNTY**

The current largest stationary sources of air pollution in Brevard County are listed below. The information is from annual operating reports submitted to the Department from 2005.

**Table 8. Largest Sources of PM in Brevard County**

<u>Owner</u>	<u>Site Name</u>	<u>Tons per year</u>
Florida Power and Light	Cape Canaveral Plant	778
Reliant Energy Florida	Reliant Indian River Plant	207
<b>Oleander Power Project</b>	<b>Oleander Unit 5 (Applicant Proposal)</b>	<b>39</b>
R.A Connor Paving	R.A Connor Paving	28
Oleander Power Project	Oleander Power Project (Existing)	13

**Table 9. Largest Sources of NO<sub>x</sub> in Brevard County**

<u>Owner</u>	<u>Site Name</u>	<u>Tons per year</u>
Florida Power and Light	Cape Canaveral Plant	4566
Reliant Energy Florida	Reliant Indian River Plant	1295
<b>Oleander Power Project</b>	<b>Oleander Unit 5 (Applicant Proposal )</b>	<b>243</b>
Oleander Power Project	Oleander Power Project (Existing)	128
USAF/Cape Canaveral AFS	Cape Canaveral Air Force Station	60



C. AIR QUALITY AND MONITORING IN BREVARD COUNTY

The Florida Department of Environmental Protection Central District currently operates three monitors at two sites measuring PM<sub>2.5</sub> and ozone (O<sub>3</sub>). The 2005 monitoring network is shown in the figure below. Brevard County is expected to have three additional new monitoring sites in the near future. Those monitors will be located at Atlantis Elementary School and Fay Park.




Figure 10. Brevard County Ambient Air Monitoring Network (Existing)

The following table summarizes 2005 ambient air quality data from ambient monitoring stations near the OPP project site.

Table 10. Ambient Air Quality Nearest to Project Site (2005)

Pollutant	Location	Averaging Period	Ambient Concentration				
			High	2nd High	Mean	Standard	Units
PM <sub>10</sub>	Titusville	24-hour	60	48		150 <sup>a</sup>	ug/m <sup>3</sup>
		Annual			15.5*	50 <sup>b</sup>	ug/m <sup>3</sup>
SO <sub>2</sub>	Orlando	3-hour	11	9		500 <sup>a</sup>	ppb
		24-hour	4	3		100 <sup>a</sup>	ppb
		Annual			1	20 <sup>b</sup>	ppb
NO <sub>2</sub>	Orlando	Annual			9	53 <sup>b</sup>	ppb
CO	Orlando	1-hour	9	8		35 <sup>a</sup>	ppm
		8-hour	5	3		9 <sup>a</sup>	ppm
Ozone	Cocoa Beach	1-hour	0.082	0.081		0.12 <sup>c</sup>	ppm
		8-hour	0.078	0.075		0.08 <sup>c</sup>	ppm

\* The Mean does not satisfy summary criteria due to missing data.

a - Not to be exceeded more than once per year

b - Arithmetic mean

c - Not to be exceeded on more than an average of one day per year over a three-year period.

**D. AIR QUALITY IMPACT ANALYSIS**

**1. Significant Impact Analysis**

Significant Impact Levels (SILs) are defined for PM/PM<sub>10</sub> and NO<sub>x</sub>. A significant impact analysis is performed on each of these pollutants to determine if a project can cause an increase in ground level concentration greater than the SIL for each pollutant.

In order to conduct a significant impact analysis, the applicant uses the proposed project's emissions at worst load conditions as inputs to the model. The model used in this analysis and any required subsequent modeling analyses are described below. The highest predicted short-term concentrations and highest predicted annual averages predicted by this modeling are compared to the appropriate SILs for the PSD Class II Area (everywhere except the designated Class I areas such as the Chassahowitzka National Wildlife Refuge).

The Class II analysis includes a combination of fence line, near-field and far-field receptors chosen for predicting maximum concentrations in the vicinity of the project. The fence line receptors consisted of discrete Cartesian receptors spaced at 50-meter intervals around the facility fence line. The near-field receptor grid consisted of densely spaced Cartesian receptors at 100 meters apart starting at the property line and extending to 3 kilometers. Beyond 3 kilometers, Cartesian receptors with a spacing of 250 meters were used out to 6 kilometers from the facility. From 6 to 15 kilometers, Cartesian receptors with a spacing of 500 meters were used.

If this modeling at worst-load conditions shows ground-level increases less than the SILs, the applicant is exempt from conducting any further modeling. If the modeled concentrations from the project exceed the SILs, then additional modeling including emissions from all major facilities or projects in the region (multi-source modeling) is required to determine the proposed project's impacts compared to the AAQS or PSD increments.

The applicant's initial PM/PM<sub>10</sub> and NO<sub>x</sub> air quality impact analyses for this project indicated that maximum predicted impacts from all pollutants are less than the applicable SILs for the Class II area. These values are tabulated in the table below and compared with existing ambient air quality measurements from the local ambient monitoring network.

**Table 11. Maximum Projected Air Quality Impacts from Oleander Unit 5 for Comparison to the PSD Class II Significant Impact Levels**

Pollutant	Averaging Time	Max Predicted Impact (ug/m <sup>3</sup> )	Significant Impact Level (ug/m <sup>3</sup> )	Baseline Concentrations (ug/m <sup>3</sup> )	Ambient Air Standards (ug/m <sup>3</sup> )	Significant Impact?
PM <sub>10</sub>	Annual	0.1	1	~16	50	NO
	24-Hour	1	5	~60	150	NO
NO <sub>x</sub>	Annual	0.3	1	~17	100	NO

Maximum predicted impacts from the project are much less than the respective AAQS and the baseline concentrations in the area. PM<sub>10</sub> and NO<sub>x</sub> are also less than the respective significant impact levels that would otherwise require more detailed modeling efforts.

The nearest PSD Class I area is the Chassahowitzka National Wildlife Refuge located about 175 km to the west-northwest of the project site. According to the applicant, air quality impacts on this Class I area will be "negligible based on the distance from the project site." The Department provided this information to the U.S. Fish and Wildlife Service and they did not make any comments regarding the Class I Significant Impact Analysis specifically. However, they did state that the "Fish and Wildlife Service does not anticipate that this modification at Oleander will have significant impacts to visibility and Air Quality

Related Values at Chassahowitzka.” This conclusion was based on the use of control technologies, emission rates and distance to the Class I area. Therefore, no modeling was required for the Class I area.

**2. Preconstruction Ambient Monitoring Requirements**

A preconstruction monitoring analysis is done for those pollutants with listed de minimis impact levels. These are levels, which, if exceeded, would require pre-construction ambient monitoring. For this analysis, as was done for the significant impact analysis, the applicant uses the proposed project's emissions at worst load conditions as inputs to the models. As shown in the following table, the maximum predicted impacts for all pollutants with listed de minimis impact levels were less than these levels. Therefore, no pre-construction monitoring is required for those pollutants.

**Table 12. Maximum Air Quality Impacts for Comparison to the De Minimis Ambient Impact Levels.**

Pollutant	Averaging Time	Max Predicted Impact (ug/m <sup>3</sup> )	De Minimis Level (ug/m <sup>3</sup> )	Baseline Concentrations (ug/m <sup>3</sup> )	Impact Greater Than De Minimis?
PM <sub>10</sub>	24-hour	1	10	~60	NO
NOx	Annual	0.3	14	~17	NO

Based on the preceding discussions, the only additional detailed air quality analysis required by the PSD regulations for this project is an analysis of impacts on soils, vegetation, and of past growth-related air quality effects.

**3. Models and Meteorological Data Used in the Foregoing Air Quality Analysis**

**PSD Class II Area:** The AERMOD modeling system was used to evaluate the pollutant emissions from the proposed project in the surrounding Class II Area. AERMOD was approved by the EPA November 2005 and will officially replace the ISCST3 model November 2006. During this “transition” time period from November 2005 to November 2006, both the ISCST and AERMOD model may be used. This “transition” will allow applicants and the Department assimilate AERMOD guidance and procedures.

The AERMOD modeling system incorporates air dispersion based on planetary boundary layer turbulence structure and scaling concepts, including the treatment of both surface and elevated sources, and both simple and complex terrain. AERMOD contains two input data processors, AERMET and AERMAP. AERMAP is the terrain processor and AERMET is the meteorological data processor.

A series of specific model features, recommended by the EPA, are referred to as the regulatory options. The applicant and the Department used the EPA recommended regulatory options. Direction-specific downwash parameters were used for all sources for which downwash was considered. The stacks associated with this project all satisfied the good engineering practice (GEP) stack height criteria.

The modeling submitted with the application included an AERMET file created by the applicant. The meteorological data consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service at Orlando International Airport and Tampa/Ruskin respectively. The 5-year period of meteorological data was from 1996 through 2000. These airport stations were selected for use in the study because they are most representative of the project site.

Along with National Weather Service data, the AERMET processor requires an input of surface parameters based on land use. These characteristics include albedo, surface roughness and bowen ratio. The Department is currently creating a series of AERMET files for National Weather Service stations in Florida. Due to the variations in surface parameter values, by using uniform data sets created by one entity, the Department will ensure continuity from project to project. The data created by the Department for Orlando

International Airport and Tampa/Ruskin was completed after the application for Unit 5 was received. Therefore, the Department modeled Unit 5 with this data to verify the applicant's results.

The Department AERMET data consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service at Orlando International Airport and Tampa/Ruskin respectively. However, the 5-year period of meteorological data was from 1999-2003. The results of the Significant Impact Analysis listed above are indicative of the highest concentrations modeled with both data sets.

In reviewing this permit application, the Department has determined that the application complies with the applicable provisions of the stack height regulations as revised by EPA on July 8, 1985 (50 FR 27892). Portions of the regulations have been remanded by a panel of the U.S. Court of Appeals for the D.C. Circuit in *NRDC v. Thomas*, 838 F. 2d 1224 (D.C. Cir. 1988). Consequently, this permit may be subject to modification should EPA revise the regulation in response to the court decision. This may result in revised emission limitations or may affect other actions taken by the source owners or operators. A more detailed discussion of the required analyses follows.

## **E. ADDITIONAL IMPACTS ANALYSIS**

### **1. Impact on Soils, Vegetation, and Wildlife**

Very low emissions are expected from this natural gas-fired combustion turbine in comparison with conventional power plants generating equal power. Emissions of acid rain and ozone precursors will be very low. The maximum ground-level concentrations predicted to occur for PM<sub>10</sub> and NO<sub>x</sub> as a result of the proposed project, including background concentrations will be less than the respective ambient air quality standards (AAQS).

The project impacts are also less than the significant impact levels for PM<sub>10</sub> and NO<sub>x</sub>, which in-turn, are less than the applicable allowable increments for each pollutant. Because the AAQS are designed to protect both the public health and welfare, and the project impacts are less than significant, it is reasonable to assume the impacts on soils, vegetation, and wildlife will be minimal or insignificant.

### **2. Impact on Visibility and Air Quality Related Values (AQRV) in the Class I Area**

As mentioned previously, the Fish and Wildlife Service does not anticipate that this modification at Oleander will have significant impacts to visibility and Air Quality Related Values (rates of nitrogen deposition) at the Chassahowitzka based on the use of control technologies, emission rates and distance to the Class I area.

### **3. Growth-Related Impacts Due to the Proposed Project**

Increases in the labor force are not expected due to this project. Commercial and residential growth will not occur. Therefore, there will be no adverse air impacts due to growth from this project.

### **4. Growth-Related Air Quality Impacts since 1977**

According to the applicant, population growth in the area of the proposed project, Brevard County, has nearly doubled from 1980 to 2000, growing to 470,000 from approximately 275,000. Brevard growth corresponds with Florida growth. According to the City of Palm Bay, Palm Bay grew in excess of 200% in the 1980's and is the ninth fastest growing Florida city.

Despite the population growth and obvious increases in vehicular traffic, Brevard County has remained in attainment with the Ambient Air Quality Standards. For example, for the pollutant ozone, the Air Quality Index (which reports daily air quality) from 2000-2003 was "Good" for 96.4%, "Moderate" for 3.3% and "Unhealthy for Sensitive Groups" for 0.3% of the days over the 3-year period. There were no "Generally Unhealthy" or "Very Unhealthy" days.

**VII. PRELIMINARY DETERMINATION**

The Department makes a preliminary determination that the proposed project will comply with all applicable state and federal air pollution regulations as conditioned by the Draft Permit. This determination is based on a technical review of the complete PSD application, reasonable assurances provided by the applicant, the draft determinations of Best Available Control Technology (BACT), review of the air quality impact analysis, and the conditions specified in the draft permit.

Cindy Mulkey is the project review engineer and is responsible for preparing the draft permit. She may be contacted at [cindy.mulkey@dep.state.fl.us](mailto:cindy.mulkey@dep.state.fl.us) and 850-921-8968. Debbie Nelson is the project meteorologist responsible for reviewing and validating the air quality impact analysis. She may be contacted at [deborah.nelson@dep.state.fl.us](mailto:deborah.nelson@dep.state.fl.us) and 850-921-9537.

**REFERENCES**

- <sup>1</sup> Manual. EPA, Office of Air Quality Planning and Standards, "DRAFT New Source Review Workshop Manual", October 1990.
- <sup>2</sup> Technical Report GE 3695E. Badeer, G. H., General Electric. "GE Aeroderivative Gas Turbines – Design and Operating Features." 2000.
- <sup>3</sup> Technical Report GE Power Systems GER 3568G. Davis, L. B., and S.H. Black, General Electric. "Dry Low NO<sub>x</sub> Combustion Systems for GE Heavy-Duty Gas Turbines." 2000.
- <sup>4</sup> Report. Cubix Corporation. "Exhaust Emissions from a GE PG7241FA Simple Cycle Power Turbine at TEC Polk Power Station." September 2000.
- <sup>5</sup> Report to Legislature. California Environmental Protection Agency, Air Resources Board. Gas-Fired Power Plant NO<sub>x</sub> Emission Controls and Related Environmental Impacts. May 2004.
- <sup>6</sup> Energy Information Administration, Department of Energy, Natural Gas Weekly Update, July 7, 2006.

**PERMITTEE:**

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, Florida 32926

*Authorized Representative:*

James O. Vick, Director Environmental Affairs

Oleander Power Project
Simple Cycle Unit 5
Permit No. PSD-FL-377
Project No. 0090180-003-AC
Expires: June 1, 2008

**PROJECT AND LOCATION**

This permit authorizes the construction of a nominal 190 MW simple cycle combustion turbine electrical generator at the existing Oleander Power Project. The facility is located in Cocoa just off Interstate 95 and State Road 520 in Brevard County.

**STATEMENT OF BASIS**

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The project was processed in accordance with the requirements of Rule 62-212.400, F.A.C., the preconstruction review program for the Prevention of Significant Deterioration (PSD) of Air Quality. The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

DRAFT

DRAFT

Joseph Kahn, P.E., Director  
Division of Air Resource Management

## SECTION I - GENERAL INFORMATION

### FACILITY DESCRIPTION

The regulated emissions units at the existing Oleander Power Project include four nominal 190 MW simple cycle combustion turbines (Units 001 through 004) capable of firing either natural gas or low-sulfur fuel oil (0.05 percent sulfur), and two 1.8 million-gallon fuel oil storage tanks (Units 006 and 007).

### PROJECT DESCRIPTION

The project is for the construction of one additional General Electric PG7241(FA) simple cycle combustion turbine electrical generator (Unit 5) equipped with evaporative cooling, capable of firing natural gas, with a nominal output of 190 megawatts. The project also includes the installation of one 900,000 gallon distillate fuel oil storage tank. Low sulfur fuel oil will be used as a backup fuel to the combustion turbine.

### NEW EMISSIONS UNITS

This permit authorizes construction and installation of the following new emissions units:

EU ID NO.	EMISSION UNIT DESCRIPTION
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.
008	Unit 8- One 900,000 gallon distillate fuel oil storage tank.

### REGULATORY CLASSIFICATION

*Title I, Part C, Clean Air Act (CAA):* The facility is a PSD-major facility pursuant to Rule 62-212, F.A.C.

*Title I, Section 111, CAA:* Unit 5 is subject to the New Source Performance Standards of 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines).

*Title I, Section 112, CAA:* The facility is not a "Major Source" of hazardous air pollutants (HAPs).

*Title IV, CAA:* The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

*Title V, CAA:* The facility is a Title V or "Major Source of air pollution" in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), sulfuric acid mist (SAM), and volatile organic compounds (VOC).

*CAIR:* As an electric generating unit, Unit 5 may be subject to the Clean Air Interstate Rule pending the finalization of DEP rules.

### PERMITTING AUTHORITY

All documents related to applications for permits to construct, operate or modify an emissions unit shall be submitted to the Bureau of Air Regulation of the Florida Department of Environmental Protection (DEP) at 2600 Blair Stone Road (MS #5505), Tallahassee, Florida 32399-2400. Copies of all such documents shall also be submitted to the Compliance Authority.

### COMPLIANCE AUTHORITY

All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Department of Environmental Protection Central District, 3319 Maguire Boulevard, Suite 232, Orlando, Florida 32803-3767.



## SECTION I - GENERAL INFORMATION

---

### APPENDICES

The following Appendices are attached as part of this permit.

Appendix A	NSPS Subparts A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

### RELEVANT DOCUMENTS:

The documents listed below are not a part of this permit, however they are specifically related to this permitting action and are on file with the Department.

- Application for Air Construction Permit received on May 4, 2006;
- Department's Request for Additional Information dated June 2, 2006;
- Applicant's Response to Request for Additional Information Received July 13, 2006 (complete);
- Department's Intent to Issue and Public Notice Package distributed October 10, 2006;
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.

DRAFT

## SECTION II. ADMINISTRATIVE REQUIREMENTS

1. General Conditions: The permittee shall operate under the attached General Conditions listed in Appendix GC of this permit. General Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
2. Applicable Regulations, Forms and Application Procedures: Unless otherwise indicated in this permit, the construction and operation of the subject emissions unit shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403 of the Florida Statutes (F.S.); Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.); and the Title 40, Parts 51, 52, 60, 63, 72, 73, and 75 of the Code of Federal Regulations (CFR), adopted by reference in Rule 62-204.800, F.A.C. The terms used in this permit have specific meanings as defined in the applicable chapters of the Florida Administrative Code. The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations. [Rules 62-204.800, 62-210.300 and 62-210.900, F.A.C.]
3. Construction and Expiration: Authorization to construct shall expire if construction is not commenced within 18 months after receipt of the permit, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. This provision does not apply to the time period between construction of the approved phases of a phased construction project except that each phase must commence construction within 18 months of the commencement date established by the Department in the permit. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. In conjunction with an extension of the 18-month period to commence or continue construction (or to construct the project in phases), the Department may require the permittee to demonstrate the adequacy of any previous determination of Best Available Control Technology (BACT) for emissions units regulated by the project. For good cause, the permittee may request that this PSD air construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation at least sixty (60) days prior to the expiration of this permit. [Rules 62-4.070(4), 62-4.080, 62-210.300(1), and 62-212.400(12), F.A.C.]
4. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
5. Source Obligation.
  - a. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.
  - b. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by exceeding its projected actual emissions, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.

[Rule 62-212.400(12), F.A.C.]

## SECTION II. ADMINISTRATIVE REQUIREMENTS

---

6. Modifications: No emissions unit or facility subject to this permit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. This permit authorizes construction of the referenced facilities. [Chapters 62-210 and 62-212, F.A.C.]
7. Application for Title IV Permit: At least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW, the permittee shall submit an application for a Title IV Acid Rain Permit to the Department's Bureau of Air Regulation in Tallahassee and a copy to the Region 4 Office of the U.S. Environmental Protection Agency in Atlanta, Georgia. [40 CFR 72]
8. Title V Permit: This permit authorizes construction of the permitted emissions unit and initial operation to determine compliance with Department rules. A Title V operation permit is required for regular operation of the permitted emission units. The permittee shall apply for and obtain a Title V operation permit in accordance with Rule 62-213.420, F.A.C. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the Department's Bureau of Air Regulation and a copy to the Compliance Authority. [Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]

DRAFT

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The specific conditions of this subsection apply to the following emissions unit after construction is complete.

E.U. ID	Emission Unit Description
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.

#### APPLICABLE STANDARDS AND REGULATIONS

1. **BACT Determinations:** A determination of the Best Available Control Technology (BACT) was made for nitrogen oxides (NO<sub>x</sub>), and particulate matter (PM/PM<sub>10</sub>). [Rule 62-210.200 (BACT), F.A.C.]
2. **NSPS Requirements:** This unit shall comply with the applicable New Source Performance Standards (NSPS) in 40 CFR 60, including: Subpart A (General Provisions) and Subpart KKKK (Standards of Performance for Stationary Gas Turbines). See Appendix A and Appendix KKKK of this permit. The BACT emissions standards for NO<sub>x</sub> and the fuel sulfur specifications for PM/PM<sub>10</sub> are as stringent as, or more stringent than the NO<sub>x</sub> and SO<sub>2</sub> limits imposed by the applicable NSPS provisions. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(7)(b), F.A.C.; 40 CFR 60, Subparts A and KKKK]

#### EQUIPMENT DESCRIPTION

3. **Combustion Turbine:** The permittee is authorized to install, tune, operate, and maintain one General Electric Model PG7241FA gas turbine-electrical generator set with a nominal generating capacity of 190 MW. The combustion turbine will be equipped with GE's DLN combustor, and an inlet air filtration system with evaporative coolers. The combustion turbine will be designed for operation in simple cycle mode and will have dual-fuel capability. [Application; Design]

#### CONTROL TECHNOLOGY

4. **DLN Combustion:** The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO<sub>x</sub> emissions from the combustion turbine when firing natural gas. Prior to the initial emissions performance tests required for the gas turbine, the DLN combustors and automated gas turbine control system shall be tuned to achieve the permitted levels for NO<sub>x</sub>. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Design; Rule 62-212.400(10)(BACT), F.A.C.]
5. **Wet Injection:** The permittee shall install, operate, and maintain a water injection system to reduce NO<sub>x</sub> emissions from the combustion turbine when firing distillate fuel oil. Prior to the initial emissions performance tests, the water injection system shall be tuned to achieve sufficiently low NO<sub>x</sub> values to meet the NO<sub>x</sub> limits of this permit. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations or determined best practices. [Applicant request; Rule 62-212.400(10)(BACT), F.A.C.]

#### PERFORMANCE REQUIREMENTS

6. **Hours of Operation:** The combustion turbine may operate no more than 3,390 hours per calendar year. Restrictions on individual methods of operation are specified in separate conditions. [Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD), F.A.C.]
7. **Permitted Capacity:** The nominal heat input rate to the combustion turbine is 1,722 MMBtu per hour when firing natural gas and 1,920 MMBtu per hour when firing fuel oil (based on a compressor inlet air temperature of 59° F, the lower heating value (LHV) of each fuel, and 100% load). Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

evaporative cooling. The permittee shall provide manufacturer’s performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department.

[Rule 62-210.200(PTE), F.A.C.]

8. **Authorized Fuels:** The combustion turbine shall fire natural gas as the primary fuel, which shall contain no more than 1.5 grains of sulfur per 100 standard cubic feet of natural gas. As a restricted alternate fuel, the combustion turbine may fire low sulfur fuel oil containing no more than 0.05% sulfur by weight. The gas turbine shall fire no more than 500 hours of fuel oil, during any calendar year.

[Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD, and PSD Avoidance), F.A.C.]

9. **Simple Cycle, Intermittent Operation:** The turbine shall operate only in simple cycle mode not to exceed the permitted hours of operation allowed by this permit. This restriction is based on the permittee’s request, which formed the basis of the PSD applicability and BACT determination and resulted in the emission standards specified in this permit. For any request to convert this unit to combined cycle operation by installing/connecting to heat recovery steam generators, including changes to the fuel quality or quantity related to combined cycle conversion which may cause an increase in short or long-term emissions, the permittee may be required to submit a full PSD permit application complete with a new proposal of the best available control technology as if the unit had never been built.

[Rules 62-212.400(12) and 62-212.400(BACT), F.A.C.].

**EMISSIONS AND TESTING REQUIREMENTS**

10. **Emission Standards:** Emissions from the combustion turbine shall not exceed the following standards.

Pollutant	Emission Standard <sup>c</sup>	Averaging Time	Compliance Method	Basis
NO <sub>x</sub> (Gas)	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr rolling	CEMS	BACT
	62.5 lb/hr	3 1-hr runs	Stack Test	
NO <sub>x</sub> (Oil)	42.0 ppmvd @ 15% O <sub>2</sub>	4-hr rolling	CEMS	NSPS
	336.8 lb/hr	3 1-hr runs	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	10 % Opacity	6-minute block	Visible Emissions Test	BACT
	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	PSD Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the visible emissions standard shall serve as an indicator of good combustion.
- b. The fuel sulfur specifications and limited hours of operation effectively limit the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from the gas turbine.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

*{Permitting Note: In combination with the annual restriction on hours of operation, the above emissions standards effectively limit annual potential emissions from the combustion turbine to: 174.5 tons/year of NO<sub>x</sub>, 34.5 tons/year of PM/PM<sub>10</sub>, and 37.1 tons/year of SO<sub>2</sub>.}*

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD and PSD Avoidance), F.A.C, and 40 CFR 60, Subpart KKKK]

11. **Nitrogen Oxides (NO<sub>x</sub>):** Emissions of NO<sub>x</sub> from the CT shall not exceed the following standards on a continuous basis and as measured by the required CEMS for the averaging period specified, and as measured during the required stack tests.

a. *While firing natural gas:*

9.0 ppmvd @ 15% O<sub>2</sub> on a 24-hour rolling average (as measured by the required CEMS and defined by this permit)

62.5 /lb/hr (3 1-hr run stack test)

b. *While firing fuel oil:*

42.0 ppmvd @ 15% O<sub>2</sub> on a 4-hr rolling average (as measured by the required CEMS and defined by subpart KKKK attached as an Appendix to this permit)

336.8 lb/hr (3 1-hr run stack test)

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD), F.A.C, and 40 CFR 60.4380]

12. **Sulfur Dioxide (SO<sub>2</sub>):**

a. *While firing natural gas:* The fuel sulfur specifications, established in condition 8 of this subsection, of 1.5 grains per 100 standard cubic feet effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing natural gas.

b. *While firing fuel oil:* The fuel sulfur specification, established in condition 8 of this subsection, of 0.05 % sulfur by weight effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing fuel oil.

[Rules 62-4.070(3), and 62-212.400 (PSD Avoidance), F.A.C]

13. **Particulate Matter (PM/PM<sub>10</sub>):** The fuel sulfur specifications, established in condition 8 of this subsection, combined with the efficient combustion, design, and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the fuel specifications and visible emissions standard shall serve as indicators of good combustion. Visible emissions shall not exceed 10 % opacity as observed during the required 30-minute visible emissions tests.

[Rules 62-4.070(3), 62-210.200 (BACT), 62-212.400(PSD), and 62-297.310(4)(a)2, F.A.C]

14. **Unconfined Particulate Emissions:** During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering, confining, or applying water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

15. **Test Methods:** Required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of NO <sub>x</sub> Emissions (Instrumental).
9	Visual Determination of Opacity
20	Determination of NO <sub>x</sub> , SO <sub>2</sub> , and Diluent Emissions from Stationary Gas Turbines

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C. [Rules 62-204.800, F.A.C.; 40 CFR 60, Appendix A]

16. **Testing Requirements:** Initial tests shall be conducted between 90% and 100% of permitted capacity; otherwise, this permit shall be modified to reflect the true maximum capacity as constructed. Subsequent annual tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. Tests shall be conducted for each pollutant while firing each fuel in the CT. For each run during tests for visible emissions, emissions of NO<sub>x</sub> recorded by the CEMS shall also be reported. Data collected from the reference method during the required CEMS quality assurance RATA tests may substitute for annual compliance tests for NO<sub>x</sub>, provided the owner or operator indicates this intent in the submitted test protocol, and obtains approval prior to testing. If the RATA is conducted at less than permitted capacity, and the data is used for annual compliance, the requirements of 62-297.310(2) (Operating Rate During Testing) still apply. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department. [Rule 62-297.310(2), and (7)(a), F.A.C.; and 40 CFR 60.8]
17. **Initial Compliance Demonstration:** Initial compliance stack tests while firing natural gas shall be conducted within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup. Initial testing on fuel oil shall be conducted within 60 days of any fuel oil firing in the CT. In accordance with the test methods specified in this permit, the combustion turbine shall be tested to demonstrate initial compliance with the emission standards for NO<sub>x</sub> and with the visible emissions standard. The permittee shall provide the Compliance Authority with any other initial emissions performance tests conducted to satisfy vendor guarantees including CO and particulate tests. [Rules 62-4.070, 62-297.310(7)(a), F.A.C. and 40 CFR 60.8]
18. **Subsequent Compliance Testing:** Annual compliance tests for NO<sub>x</sub>, and visible emissions shall be conducted during each federal fiscal year (October 1<sup>st</sup>, to September 30<sup>th</sup>). If normal operation on fuel oil is less than 400 hours per calendar year, then subsequent compliance testing on fuel oil is not required for that year. If normal operation on fuel oil exceeds 400 hours per year, the Department shall require compliance testing for NO<sub>x</sub> and visible emissions while firing fuel oil. [Rules 62-4.070, 62-210.200(BACT), and 62-297.310(7)(a)4, F.A.C.]
19. **Continuous Compliance:** Continuous compliance with the permit standard for emissions of NO<sub>x</sub> shall be demonstrated with data collected from the required continuous monitoring system. [Rules 62-4.070, and 62-210.200(BACT), F.A.C.]
20. **Special Compliance Tests:** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

#### EXCESS EMISSIONS

*{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Condition No 10 and 11 of this subsection. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, NESHAP, or Acid Rain programs.}*

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

#### 21. Definitions:

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose.
- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

*{Permitting Note: The applicant has described startup of this unit as the period from 0 to 50% load, and shutdown as the period beginning at 50 % load to no load operation.}*

[Rule 62-210.200(165, 242, and 258), F.A.C.]

22. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]

23. Data Exclusion Procedures for SIP Compliance: As per the procedures in this condition, limited amounts of CEMS emissions data, as specified in condition 24, may be excluded from the corresponding SIP-based compliance demonstration, provided that best operational practices to minimize emissions are adhered to, the duration of data excluded is minimized, and the procedures for data exclusion listed below are followed. As provided by the authority in Rule 62-210.700(5), F.A.C., these conditions replace the provisions in Rule 62-210.700(1), F.A.C.

- a. *Limiting Data Exclusion*. If the compliance calculation using all valid CEMS emission data indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
- b. *Event Driven Exclusion*. There must be an underlying event (startup, shutdown, malfunction, or fuel switching) in order to exclude data. If there is no underlying event, then no data may be excluded.
- c. *Continuous Exclusion*. Data shall be excluded on a continuous basis. Data from discontinuous periods shall not be excluded for the same underlying event.

[Rule 62-210.700 F.A.C.]

24. Allowable Data Exclusions: The following data may be excluded from the corresponding SIP-based compliance demonstration for each of the events listed below in accordance with the Data Exclusion Procedures of condition 23:

- a. *Startup*: Up to 30 minutes of CEMS data may be excluded for each combustion turbine startup. For startups of less than 30 minutes in duration, only those minutes attributable to startup may be excluded.
- b. *Shutdown*: Up to 30 minutes of CEMS data may be excluded for each combustion turbine shutdown. For shutdowns of less than 30 minutes in duration, only those minutes attributable to shutdown may be excluded.
- c. *Malfunction*: Up to two hours (in any operating day) of CEMS data may be excluded due to a documented malfunction. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic email.



## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- d. *DLN Tuning*: CEMS data collected during initial or other DLN tuning sessions may be excluded from the compliance demonstrations provided the tuning session is performed in accordance with the manufacturer's specifications or determined best practices. Prior to performing any tuning session, the permittee shall provide the Compliance Authority with an advance notice of at least one (1) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Design; Rule 62-4.070(3), F.A.C.]
- e. *Fuel Switching*: Up to 30 minutes of CEMS data may be excluded for each-oil-to-gas fuel switch. For fuel switches of less than 30 minutes in duration, only those minutes attributable to shutdown may be excluded.

All valid emissions data (including data collected during startup, shutdown, malfunction, DLN tuning, and fuel switching) shall be used to report emissions for the Annual Operating Report.

[Rules 62-210.200(BACT), 62-210.370, and 62-210.700, F.A.C.]

- 25. Notification Requirements: The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate non-compliance for a given averaging period. [Rule 62-4.070, F.A.C.]

#### CONTINUOUS MONITORING REQUIREMENTS

- 26. CEM Systems: Subject to the following, the permittee shall install, calibrate, operate, and maintain a continuous emission monitoring system (CEMS) to measure and record the emissions of NO<sub>x</sub> from the combustion turbine in terms of the applicable standards. The monitoring system shall be installed, and functioning within the required performance specifications by the time of the initial compliance demonstration.
  - a. *NO<sub>x</sub> Monitor*: Each NO<sub>x</sub> monitor shall be certified pursuant to the specifications of 40 CFR 75. Quality assurance procedures shall conform to the requirements of 40 CFR 75. The annual and required RATA tests required for the NO<sub>x</sub> monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.
  - b. *Diluent Monitor*: The oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) content of the flue gas shall be monitored at the location where NO<sub>x</sub> is monitored to correct the measured emissions rates to 15% oxygen. If a CO<sub>2</sub> monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

[Rules 62-4.070(3), 62-210.200(BACT), F.A.C., and 40 CFR 60, Subpart 75]

- 27. Moisture Correction: If necessary, the owner or operator shall determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). [Rules 62-4.070(3), 62-210.200(BACT), F.A.C.]

- 28. CEMS Data Requirements for BACT Standards:

*{Permitting Note: The following conditions apply only to the SIP-based NO<sub>x</sub> emissions standards specified in Condition Nos. 10-11 of this section. These requirements cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs. Additional reporting and monitoring may be required by the individual subparts.}*

- a. *Data Collection*: Except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments, emissions shall be monitored and recorded during all operation including startup, shutdown, and malfunction.

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- b. *Operating Hours and Operating Days:* An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
- c. *Valid Hour:* Each CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
- 1) Hours that are **not operating** hours are **not valid** hours.
  - 2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data and the 1-hour block average is not valid.
  - 3) During fuel switching an hour in which fuel oil is fired is attributed towards compliance with the permit standards for oil firing.
- d. *Rolling 24-Hour Average:* Compliance shall be determined after each valid hourly average is obtained by calculating the arithmetic average of that valid hourly average and the preceding 23 valid hourly averages.
- e. *Data Exclusion:* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, DLN tuning, and fuel switches. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of conditions 23 and 24 of this subsection.
- f. *Availability:* Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly excess emissions report shall be used to demonstrate monitor availability. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Compliance Authority.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

### CEMS REQUIREMENTS FOR ANNUAL EMISSIONS

29. CEMS Annual Emissions Requirement: The owner or operator shall use data from the NO<sub>x</sub> CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit. [Rules 62-210.200, and 62-210.370(3), F.A.C.]

### REPORTING AND RECORD KEEPING REQUIREMENTS

30. Monitoring of Capacity: The permittee shall monitor and record the operating rate of the combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction, DLN tuning, and fuel switching). Such monitoring shall be made by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

31. Monthly Operations Summary: By the 15th calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the combustion turbine for the previous month of operation: fuel consumption, hours of operation on each fuel, and the updated calendar year totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]
32. Fuel Sulfur Records: The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
- Natural Gas Sulfur Limit*: Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.
  - Distillate Fuel Oil Sulfur Limit*: Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91, D1552-90, D2622-94, or D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of the Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.
- The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]
33. Emissions Performance Test Reports: A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix SC of this permit. [Rule 62-297.310(8), F.A.C.]
34. Excess Emissions Reporting:
- Malfunction Notification*: If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
  - SIP Quarterly Report*: Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of NO<sub>x</sub> emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. A summary of data excluded from SIP compliance calculations should also be provided. In addition, the report shall summarize the NO<sub>x</sub> CEMS system monitor availability for the previous quarter.
  - NSPS Reporting*: Within 30 days following the calendar quarter, the permittee shall submit the written reports required by 40 CFR 60 Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) for the previous semi-annual period to the Compliance Authority.


**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

*{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}*

[Rules 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C., and 40 CFR 60.7 and 60.4375]

35. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating hours and emissions from this facility in accordance with 62-210.370. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]



SECTION IV - UNREGULATED EMISSIONS UNITS


A. Fuel Oil Storage Tank (EU 008)

ID	Emission Unit Description
008	Unit 8- One 900,000 gallon distillate fuel oil storage tank.

NSPS APPLICABILITY

NSPS Subpart Kb Applicability: The distillate fuel oil storage tank is not subject to Subpart Kb which applies to storage vessels with a capacity greater than or equal to 75 cubic meters that is used to store volatile organic liquids for which construction, reconstruction, or modification is commenced after July 23, 1984. Tanks with a capacity greater than or equal to 151 cubic meters (40,000 gallons) storing a liquid with a maximum true vapor pressure less than 3.5 kPa, are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb. The fuel oil storage tank (EU 008) has a capacity greater than 151 cubic meters and the vapor pressure of the low sulfur fuel oil is less than 3.5 kPa, therefore NSPS Kb, including the monitoring requirements, does not apply to this unit.

[40 CFR 60.110b(a) and (b), and 60.116b(c); Rule 62-204.800(7)(b), F.A.C.]



## SECTION IV. APPENDICES

---

### CONTENTS

Appendix A	NSPS Subpart A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

## SECTION IV. APPENDIX A

### NSPS SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

---

Emissions units subject to a New Source Performance Standard of 40 CFR 60 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

- § 60.1 Applicability.
- § 60.2 Definitions.
- § 60.3 Units and abbreviations.
- § 60.4 Address.
- § 60.5 Determination of construction or modification.
- § 60.6 Review of plans.
- § 60.7 Notification and Record Keeping.
- § 60.8 Performance Tests.
- § 60.9 Availability of information.
- § 60.10 State Authority.
- § 60.11 Compliance with Standards and Maintenance Requirements.
- § 60.12 Circumvention.
- § 60.13 Monitoring Requirements.
- § 60.14 Modification.
- § 60.15 Reconstruction.
- § 60.16 Priority List.
- § 60.17 Incorporations by Reference.
- § 60.18 General Control Device Requirements.
- § 60.19 General Notification and Reporting Requirements.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.

**SECTION IV. APPENDIX BD**

**FINAL BACT DETERMINATIONS AND EMISSIONS STANDARDS**

The Department establishes the following standards as the Best Available Control Technology for the simple cycle combustion turbine Unit 5 at the Oleander Power Project.

**BACT Determinations – Oleander Power Project Unit 5**

<b>Pollutant</b>	<b>Fuel</b>	<b>Emission Standard/Limit<sup>c</sup></b>	<b>Averaging Time</b>	<b>Compliance Method</b>	<b>Basis</b>
NO <sub>x</sub>	Gas	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr rolling	CEMS	BACT
		62.5 lb/hr	3-hr	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	Gas/Oil	10 % Opacity	6-minute block	STACK TEST	BACT
		1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	RECORD KEEPING	
SO <sub>2</sub> <sup>b</sup>	Gas/Oil	1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	BACT Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the gas turbine represents (BACT) for PM/PM10 emissions.
- b. The fuel sulfur specifications effectively limit the potential emissions of SO2 and sulfuric acid mist (SAM) from the gas.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.



## SECTION IV. APPENDIX GC

### GENERAL CONDITIONS

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
  - a. Have access to and copy and records that must be kept under the conditions of the permit;
  - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
  - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
  - a. A description of and cause of non-compliance; and
  - b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida

## SECTION IV. APPENDIX GC

### GENERAL CONDITIONS

Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
  - a. Determination of Best Available Control Technology (X);
  - b. Determination of Prevention of Significant Deterioration (X);
  - c. Compliance with National Emission Standards for Hazardous Air Pollutants (Not Applicable); and
  - d. Compliance with New Source Performance Standards (X).
14. The permittee shall comply with the following:
  - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - c. Records of monitoring information shall include:
    - 1) The date, exact place, and time of sampling or measurements;
    - 2) The person responsible for performing the sampling or measurements;
    - 3) The dates analyses were performed;
    - 4) The person responsible for performing the analyses;
    - 5) The analytical techniques or methods used; and
    - 6) The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

This subpart establishes emission standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification or reconstruction after February 18, 2005.

#### Applicability

##### § 60.4305 Does this subpart apply to my stationary combustion turbine?

(a) If you are the owner or operator of a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005, your turbine is subject to this subpart. Only heat input to the combustion turbine should be included when determining whether or not this subpart is applicable to your turbine. Any additional heat input to associated heat recovery steam generators (HRSG) or duct burners should not be included when determining your peak heat input. However, this subpart does apply to emissions from any associated HRSG and duct burners.

(b) Stationary combustion turbines regulated under this subpart are exempt from the requirements of subpart GG of this part. Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.

##### § 60.4310 What types of operations are exempt from these standards of performance?

- (a) Emergency combustion turbines, as defined in §60.4420(i), are exempt from the nitrogen oxides (NOX) emission limits in §60.4320.
- (b) Stationary combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements are exempt from the NOX emission limits in §60.4320 on a case-by-case basis as determined by the Administrator.
- (c) Stationary combustion turbines at integrated gasification combined cycle electric utility steam generating units that are subject to subpart Da of this part are exempt from this subpart.
- (d) Combustion turbine test cells/stands are exempt from this subpart.

#### Emission Limits

##### § 60.4315 What pollutants are regulated by this subpart?

The pollutants regulated by this subpart are nitrogen oxide (NOX) and sulfur dioxide (SO<sub>2</sub>).

##### § 60.4320 What emission limits must I meet for nitrogen oxides (NOX)?

- (a) You must meet the emission limits for NOX specified in Table 1 to this subpart.
- (b) If you have two or more turbines that are connected to a single generator, each turbine must meet the emission limits for NOX.

##### § 60.4325 What emission limits must I meet for NOX if my turbine burns both natural gas and distillate oil (or some other combination of fuels)?

You must meet the emission limits specified in Table 1 to this subpart. If your total heat input is greater than or equal to 50 percent natural gas, you must meet the corresponding limit for a natural gas-fired turbine when you are burning that fuel. Similarly, when your total heat input is greater than 50 percent distillate oil and fuels other than natural gas, you must meet the corresponding limit for distillate oil and fuels other than natural gas for the duration of the time that you burn that particular fuel.

##### § 60.4330 What emission limits must I meet for sulfur dioxide (SO<sub>2</sub>)?

(a) If your turbine is located in a continental area, you must comply with either paragraph (a)(1) or (a)(2) of this section. If your turbine is located in Alaska, you do not have to comply with the requirements in paragraph (a) of this section until January 1, 2008.

(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh)) gross output, or

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

(b) If your turbine is located in a noncontinental area or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit, you must comply with one or the other of the following conditions:

(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 780 ng/J (6.2 lb/MWh) gross output, or

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total sulfur with potential sulfur emissions in excess of 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

#### General Compliance Requirements

##### § 60.4333 What are my general requirements for complying with this subpart?

- (a) You must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.
- (b) When an affected unit with heat recovery utilizes a common steam header with one or more combustion turbines, the owner or operator shall either:
- (1) Determine compliance with the applicable NOX emissions limits by measuring the emissions combined with the emissions from the other unit(s) utilizing the common heat recovery unit; or
  - (2) Develop, demonstrate, and provide information satisfactory to the Administrator on methods for apportioning the combined gross energy output from the heat recovery unit for each of the affected combustion turbines. The Administrator may approve such demonstrated substitute methods for apportioning the combined gross energy output measured at the steam turbine whenever the demonstration ensures accurate estimation of emissions related under this part.

#### Monitoring

##### § 60.4335 How do I demonstrate compliance for NOX if I use water or steam injection?

- (a) If you are using water or steam injection to control NOX emissions, you must install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine when burning a fuel that requires water or steam injection for compliance.
- (b) Alternatively, you may use continuous emission monitoring, as follows:
- (1) Install, certify, maintain, and operate a continuous emission monitoring system (CEMS) consisting of a NOX monitor and a diluent gas (oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>)) monitor, to determine the hourly NOX emission rate in parts per million (ppm) or pounds per million British thermal units (lb/MMBtu); and
  - (2) For units complying with the output-based standard, install, calibrate, maintain, and operate a fuel flow meter (or flow meters) to continuously measure the heat input to the affected unit; and
  - (3) For units complying with the output-based standard, install, calibrate, maintain, and operate a watt meter (or meters) to continuously measure the gross electrical output of the unit in megawatt-hours; and
  - (4) For combined heat and power units complying with the output-based standard, install, calibrate, maintain, and operate meters for useful recovered energy flow rate, temperature, and pressure, to continuously measure the total thermal energy output in British thermal units per hour (Btu/h).

##### § 60.4340 How do I demonstrate continuous compliance for NOX if I do not use water or steam injection?

- (a) If you are not using water or steam injection to control NOX emissions, you must perform annual performance tests in accordance with §60.4400 to demonstrate continuous compliance. If the NOX emission result from the performance test is less than or equal to 75 percent of the NOX emission limit for the turbine, you may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NOX emission limit for the turbine, you must resume annual performance tests.
- (b) As an alternative, you may install, calibrate, maintain and operate one of the following continuous monitoring systems:
- (1) Continuous emission monitoring as described in §§60.4335(b) and 60.4345, or
  - (2) Continuous parameter monitoring as follows:
    - (i) For a diffusion flame turbine without add-on selective catalytic reduction (SCR) controls, you must define parameters indicative of the unit's NOX formation characteristics, and you must monitor these parameters continuously.
    - (ii) For any lean premix stationary combustion turbine, you must continuously monitor the appropriate parameters to determine whether the unit is operating in low-NOX mode.
    - (iii) For any turbine that uses SCR to reduce NOX emissions, you must continuously monitor appropriate parameters to verify the proper operation of the emission controls.

SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(iv) For affected units that are also regulated under part 75 of this chapter, with state approval you can monitor the NOX emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19, the requirements of this paragraph (b) may be met by performing the parametric monitoring described in section 2.3 of part 75 appendix E or in §75.19(c)(1)(iv)(H).

§ 60.4345 What are the requirements for the continuous emission monitoring system equipment, if I choose to use this option?

If the option to use a NOX CEMS is chosen:

(a) Each NOX diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NOX diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.

(b) As specified in §60.13(e)(2), during each full unit operating hour, both the NOX monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NOX emission rate for the hour.

(c) Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.

(d) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions.

(e) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section I of appendix B to part 75 of this chapter.

§ 60.4350 How do I use data from the continuous emission monitoring equipment to identify excess emissions?

For purposes of identifying excess emissions:

(a) All CEMS data must be reduced to hourly averages as specified in §60.13(h).

(b) For each unit operating hour in which a valid hourly average, as described in §60.4345(b), is obtained for both NOX and diluent monitors, the data acquisition and handling system must calculate and record the hourly NOX emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of this part. For any hour in which the hourly average O2 concentration exceeds 19.0 percent O2 (or the hourly average CO2 concentration is less than 1.0 percent CO2), a diluent cap value of 19.0 percent O2 or 1.0 percent CO2 (as applicable) may be used in the emission calculations.

(c) Correction of measured NOX concentrations to 15 percent O2 is not allowed.

(d) If you have installed and certified a NOX diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under §60.7(c).

(e) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages.

(f) Calculate the hourly average NOX emission rates, in units of the emission standards under §60.4320, using either ppm for units complying with the concentration limit or the following equation for units complying with the output based standard:

(1) For simple-cycle operation:

E = (NOx)h \* (HI)h / P (Eq. 1)

Where:

E = hourly NOX emission rate, in lb/MWh, (NOX)h = hourly NOX emission rate, in lb/MMBtu,

SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(HI)h = hourly heat input rate to the unit, in MMBtu/h, measured using the fuel flowmeter(s), e.g., calculated using Equation D-15a in appendix D to part 75 of this chapter, and

P = gross energy output of the combustion turbine in MW.

(2) For combined-cycle and combined heat and power complying with the output-based standard, use Equation 1 of this subpart, except that the gross energy output is calculated as the sum of the total electrical and mechanical energy generated by the combustion turbine, the additional electrical or mechanical energy (if any) generated by the steam turbine following the heat recovery steam generator, and 100 percent of the total useful thermal energy output that is not used to generate additional electricity or mechanical output, expressed in equivalent MW, as in the following equations:

P = (Pe)t + (Pe)c + Ps + Po (Eq. 2)

Where:

P = gross energy output of the stationary combustion turbine system in MW.

(Pe)t = electrical or mechanical energy output of the combustion turbine in MW,

(Pe)c = electrical or mechanical energy output (if any) of the steam turbine in MW, and

Ps = (Q \* H) / (3.413 \* 10^6 Btu/MWh) (Eq. 3)

Where:

Ps = useful thermal energy of the steam, measured relative to ISO conditions, not used to generate additional electric or mechanical output, in MW,

Q = measured steam flow rate in lb/h,

H = enthalpy of the steam at measured temperature and pressure relative to ISO conditions, in Btu/lb, and 3.413 x 10^6 = conversion from Btu/h to MW.

Po = other useful heat recovery, measured relative to ISO conditions, not used for steam generation or performance enhancement of the combustion turbine.

(3) For mechanical drive applications complying with the output-based standard, use the following equation:

E = ((NOx)m) / (BL \* AL) (Eq. 4)

Where:

E = NOX emission rate in lb/MWh,

(NOX)m = NOX emission rate in lb/h,

BL = manufacturer's base load rating of turbine, in MW, and

AL = actual load as a percentage of the base load.

(g) For simple cycle units without heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 4-hour rolling average basis, as described in §60.4380(b)(1).

(h) For combined cycle and combined heat and power units with heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 30 unit operating day rolling average basis, as described in §60.4380(b)(1).

§ 60.4355 How do I establish and document a proper parameter monitoring plan?

(a) The steam or water to fuel ratio or other parameters that are continuously monitored as described in §§60.4335 and 60.4340 must be monitored during the performance test required under §60.8, to establish acceptable values and ranges. You may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. You must develop and keep onsite a parameter monitoring plan which explains the procedures used to document proper operation of the NOX emission controls. The plan must:

- (1) Include the indicators to be monitored and show there is a significant relationship to emissions and proper operation of the NOX emission controls,

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

- (2) Pick ranges (or designated conditions) of the indicators, or describe the process by which such range (or designated condition) will be established,
- (3) Explain the process you will use to make certain that you obtain data that are representative of the emissions or parameters being monitored (such as detector location, installation specification if applicable),
- (4) Describe quality assurance and control practices that are adequate to ensure the continuing validity of the data,
- (5) Describe the frequency of monitoring and the data collection procedures which you will use (e.g., you are using a computerized data acquisition over a number of discrete data points with the average (or maximum value) being used for purposes of determining whether an exceedance has occurred), and
- (6) Submit justification for the proposed elements of the monitoring. If a proposed performance specification differs from manufacturer recommendation, you must explain the reasons for the differences. You must submit the data supporting the justification, but you may refer to generally available sources of information used to support the justification. You may rely on engineering assessments and other data, provided you demonstrate factors which assure compliance or explain why performance testing is unnecessary to establish indicator ranges. When establishing indicator ranges, you may choose to simplify the process by treating the parameters as if they were correlated. Using this assumption, testing can be divided into two cases:
  - (i) All indicators are significant only on one end of range (e.g., for a thermal incinerator controlling volatile organic compounds (VOC) it is only important to insure a minimum temperature, not a maximum). In this case, you may conduct your study so that each parameter is at the significant limit of its range while you conduct your emissions testing. If the emissions tests show that the source is in compliance at the significant limit of each parameter, then as long as each parameter is within its limit, you are presumed to be in compliance.
  - (ii) Some or all indicators are significant on both ends of the range. In this case, you may conduct your study so that each parameter that is significant at both ends of its range assumes its extreme values in all possible combinations of the extreme values (either single or double) of all of the other parameters. For example, if there were only two parameters, A and B, and A had a range of values while B had only a minimum value, the combinations would be A high with B minimum and A low with B minimum. If both A and B had a range, the combinations would be A high and B high, A low and B low, A high and B low, A low and B high. For the case of four parameters all having a range, there are 16 possible combinations.

(b) For affected units that are also subject to part 75 of this chapter and that have state approval to use the low mass emissions methodology in §75.19 or the NOX emission measurement methodology in appendix E to part 75, you may meet the requirements of this paragraph by developing and keeping onsite (or at a central location for unmanned facilities) a QA plan, as described in §75.19(e)(5) or in section 2.3 of appendix E to part 75 of this chapter and section 1.3.6 of appendix B to part 75 of this chapter.

#### § 60.4360 How do I determine the total sulfur content of the turbine's combustion fuel?

You must monitor the total sulfur content of the fuel being fired in the turbine, except as provided in §60.4365. The sulfur content of the fuel must be determined using total sulfur methods described in §60.4415. Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than half the applicable limit, ASTM D4084, D4810, D5504, or D6228, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17), which measure the major sulfur compounds, may be used.

#### § 60.4365 How can I be exempted from monitoring the total sulfur content of the fuel?

You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for units located in continental areas and 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for units located in noncontinental areas or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit. You must use one of the following sources of information to make the required demonstration:

- (a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for oil use in continental areas is 0.05 weight percent (500 ppmw) or less and 0.4 weight percent (4,000 ppmw) or less for noncontinental areas, the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet and 140 grains of sulfur or less per 100 standard cubic feet for noncontinental areas, has potential sulfur emissions of less than less than 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas and has potential sulfur emissions of less than less than 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas; or
- (b) Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas or 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

#### § 60.4370 How often must I determine the sulfur content of the fuel?

The frequency of determining the sulfur content of the fuel must be as follows:

(a) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (*i.e.*, flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank).

(b) *Gaseous fuel.* If you elect not to demonstrate sulfur content using options in §60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and recorded once per unit operating day.

(c) *Custom schedules.* Notwithstanding the requirements of paragraph (b) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (c)(1) and (c)(2) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.4330.

(1) The two custom sulfur monitoring schedules set forth in paragraphs (c)(1)(i) through (iv) and in paragraph (c)(2) of this section are acceptable, without prior Administrative approval:

(i) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (c)(1)(ii), (iii), or (iv) of this section, as applicable.

(ii) If none of the 30 daily measurements of the fuel's total sulfur content exceeds half the applicable standard, subsequent sulfur content monitoring may be performed at 12-month intervals. If any of the samples taken at 12-month intervals has a total sulfur content greater than half but less than the applicable limit, follow the procedures in paragraph (c)(1)(iii) of this section. If any measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section.

(iii) If at least one of the 30 daily measurements of the fuel's total sulfur content is greater than half but less than the applicable limit, but none exceeds the applicable limit, then:

(A) Collect and analyze a sample every 30 days for 3 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(B) of this section.

(B) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(C) of this section.

(C) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, continue to monitor at this frequency.

(iv) If a sulfur content measurement exceeds the applicable limit, immediately begin daily monitoring according to paragraph (c)(1)(i) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than the applicable limit, are obtained. At that point, the applicable procedures of paragraph (c)(1)(ii) or (iii) of this section shall be followed.

(2) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(i) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf, no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(ii) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds half the applicable limit, then the minimum required sampling frequency shall be one sample at 12 month intervals.

(iii) If any sample result exceeds half the applicable limit, but none exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iii) of this section.

(iv) If the sulfur content of any of the 720 hourly samples exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iv) of this section.



## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

#### Reporting

##### § 60.4375 What reports must I submit?

- (a) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.
- (b) For each affected unit that performs annual performance tests in accordance with §60.4340(a), you must submit a written report of the results of each performance test before the close of business on the 60th day following the completion of the performance test.

##### § 60.4380 How are excess emissions and monitor downtime defined for NOX?

For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that must be reported are defined as follows:

(a) For turbines using water or steam to fuel ratio monitoring:

- (1) An excess emission is any unit operating hour for which the 4-hour rolling average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.4320, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine when a fuel is being burned that requires water or steam injection for NOX control will also be considered an excess emission.
- (2) A period of monitor downtime is any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
- (3) Each report must include the average steam or water to fuel ratio, average fuel consumption, and the combustion turbine load during each excess emission.

(b) For turbines using continuous emission monitoring, as described in §§60.4335(b) and 60.4345:

- (1) An excess emissions is any unit operating period in which the 4-hour or 30-day rolling average NOX emission rate exceeds the applicable emission limit in §60.4320. For the purposes of this subpart, a "4- hour rolling average NOX emission rate" is the arithmetic average of the average NOX emission rate in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given hour and the three unit operating hour average NOX emission rates immediately preceding that unit operating hour. Calculate the rolling average if a valid NOX emission rate is obtained for at least 3 of the 4 hours. For the purposes of this subpart, a "30-day rolling average NOX emission rate" is the arithmetic average of all hourly NOX emission data in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given day and the twenty-nine unit operating days immediately preceding that unit operating day. A new 30-day average is calculated each unit operating day as the average of all hourly NOX emissions rates for the preceding 30 unit operating days if a valid NOX emission rate is obtained for at least 75 percent of all operating hours.
- (2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NOX concentration, CO2 or O2 concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if you will use this information for compliance purposes.
- (3) For operating periods during which multiple emissions standards apply, the applicable standard is the average of the applicable standards during each hour. For hours with multiple emissions standards, the applicable limit for that hour is determined based on the condition that corresponded to the highest emissions standard.

(c) For turbines required to monitor combustion parameters or parameters that document proper operation of the NOX emission controls:

- (1) An excess emission is a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
- (2) A period of monitor downtime is a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

##### § 60.4385 How are excess emissions and monitoring downtime defined for SO2?

If you choose the option to monitor the sulfur content of the fuel, excess emissions and monitoring downtime are defined as follows:

- (a) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the combustion turbine exceeds the applicable limit and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(b) If the option to sample each delivery of fuel oil has been selected, you must immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.05 weight percent. You must continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and you must evaluate excess emissions according to paragraph (a) of this section. When all of the fuel from the delivery has been burned, you may resume using the as-delivered sampling option.

(c) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

§ 60.4390 What are my reporting requirements if I operate an emergency combustion turbine or a research and development turbine?

(a) If you operate an emergency combustion turbine, you are exempt from the NOX limit and must submit an initial report to the Administrator stating your case.

(b) Combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements may be exempted from the NOX limit on a case-by-case basis as determined by the Administrator. You must petition for the exemption.

§ 60.4395 When must I submit my reports?

All reports required under §60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

Performance Tests

§ 60.4400 How do I conduct the initial and subsequent performance tests, regarding NOX?

(a) You must conduct an initial performance test, as required in §60.8. Subsequent NOX performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).

(1) There are two general methodologies that you may use to conduct the performance tests. For each test run:

(i) Measure the NOX concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NOX emission rate:

E = (1.194 x 10^-7 \* (NOx)c \* Qstd) / P (Eq. 5)

Where:

E = NOX emission rate, in lb/MWh

1.194 x 10^-7 = conversion constant, in lb/dscf-ppm

(NOX)c = average NOX concentration for the run, in ppm

Qstd = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(ii) Measure the NOX and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NOX emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the NOX emission rate in lb/MWh.

(2) Sampling traverse points for NOX and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multihole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NOX and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NOX concentrations is within  $\pm 10$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 5$  ppm or  $\pm 0.5$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average NOX concentration during the stratification test; or

(B) For turbines with a NOX standard greater than 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NOX concentrations is within  $\pm 5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 3$  ppm or  $\pm 0.3$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points; or

(C) For turbines with a NOX standard less than or equal to 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NOX concentrations is within  $\pm 2.5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 1$  ppm or  $\pm 0.15$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

(2) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), you must measure the total NOX emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test.

(3) If water or steam injection is used to control NOX with no additional post-combustion NOX control and you choose to monitor the steam or water to fuel ratio in accordance with §60.4335, then that monitoring system must be operated concurrently with each EPA Method 20 or EPA Method 7E run and must be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.4320 NOX emission limit.

(4) Compliance with the applicable emission limit in §60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NOX emission rate at each tested level meets the applicable emission limit in §60.4320.

(5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in §60.4405) as part of the initial performance test of the affected unit.

(6) The ambient temperature must be greater than 0 °F during the performance test.

#### § 60.4405 How do I perform the initial performance test if I have chosen to install a NOX-diluent CEMS?

If you elect to install and certify a NOX-diluent CEMS under §60.4345, then the initial performance test required under §60.8 may be performed in the following alternative manner:

(a) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs.

(b) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit.

(c) Use the test data both to demonstrate compliance with the applicable NOX emission limit under §60.4320 and to provide the required reference method data for the RATA of the CEMS described under §60.4335.

SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(d) Compliance with the applicable emission limit in §60.4320 is achieved if the arithmetic average of all of the NOX emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit.

§ 60.4410 How do I establish a valid parameter range if I have chosen to continuously monitor parameters?

If you have chosen to monitor combustion parameters or parameters indicative of proper operation of NOX emission controls in accordance with §60.4340, the appropriate parameters must be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.4355.

§ 60.4415 How do I conduct the initial and subsequent performance tests for sulfur?

(a) You must conduct an initial performance test, as required in §60.8. Subsequent SO2 performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). There are three methodologies that you may use to conduct the performance tests.

(1) If you choose to periodically determine the sulfur content of the fuel combusted in the turbine, a representative fuel sample would be collected following ASTM D5287 (incorporated by reference, see §60.17) for natural gas or ASTM D4177 (incorporated by reference, see §60.17) for oil. Alternatively, for oil, you may follow the procedures for manual pipeline sampling in section 14 of ASTM D4057 (incorporated by reference, see §60.17). The fuel analyses of this section may be performed either by you, a service contractor retained by you, the fuel vendor, or any other qualified agency. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129, or alternatively D1266, D1552, D2622, D4294, or D5453 (all of which are incorporated by reference, see §60.17); or

(ii) For gaseous fuels, ASTM D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17).

(2) Measure the SO2 concentration (in parts per million (ppm)), using EPA Methods 6, 6C, 8, or 20 in appendix A of this part. In addition, the American Society of Mechanical Engineers (ASME) standard, ASME PTC 19-10-1981-Part 10, "Flue and Exhaust Gas Analyses," manual methods for sulfur dioxide (incorporated by reference, see §60.17) can be used instead of EPA Methods 6 or 20. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then use the following equation to calculate the SO2 emission rate:

E = (1.664 x 10^-7 \* (SO2)c \* Qstd) / P (Eq. 6)

Where:

E = SO2 emission rate, in lb/MWh

1.664 x 10^-7 = conversion constant, in lb/dscf-ppm

(SO2)c = average SO2 concentration for the run, in ppm

Qstd = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(3) Measure the SO2 and diluent gas concentrations, using either EPA Methods 6, 6C, or 8 and 3A, or 20 in appendix A of this part. In addition, you may use the manual methods for sulfur dioxide ASME PTC 19-10-1981-Part 10 (incorporated by reference, see §60.17). Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the SO2 emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the SO2 emission rate in lb/MWh.

(b) [Reserved]

Definitions

§ 60.4420 What definitions apply to this subpart?

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

As used in this subpart, all terms not defined herein will have the meaning given them in the Clean Air Act and in subpart A (General Provisions) of this part.

*Combined cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to generate steam that is only used to create additional power output in a steam turbine.

*Combined heat and power combustion turbine* means any stationary combustion turbine which recovers heat from the exhaust gases to heat water or another medium, generate steam for useful purposes other than additional electric generation, or directly uses the heat in the exhaust gases for a useful purpose.

*Combustion turbine model* means a group of combustion turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

*Combustion turbine test cell/stand* means any apparatus used for testing uninstalled stationary or uninstalled mobile (motive) combustion turbines.

*Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary combustion turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

*Efficiency* means the combustion turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output—based on the higher heating value of the fuel.

*Emergency combustion turbine* means any stationary combustion turbine which operates in an emergency situation. Examples include stationary combustion turbines used to produce power for critical networks or equipment, including power supplied to portions of a facility, when electric power from the local utility is interrupted, or stationary combustion turbines used to pump water in the case of fire or flood, etc. Emergency stationary combustion turbines do not include stationary combustion turbines used as peaking units at electric utilities or stationary combustion turbines at industrial facilities that typically operate at low capacity factors. Emergency combustion turbines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are required by the manufacturer, the vendor, or the insurance company associated with the turbine. Required testing of such units should be minimized, but there is no time limit on the use of emergency combustion turbines.

*Excess emissions* means a specified averaging period over which either (1) the NOX emissions are higher than the applicable emission limit in §60.4320; (2) the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.4330; or (3) the recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

*Gross useful output* means the gross useful work performed by the stationary combustion turbine system. For units using the mechanical energy directly or generating only electricity, the gross useful work performed is the gross electrical or mechanical output from the turbine/generator set. For combined heat and power units, the gross useful work performed is the gross electrical or mechanical output plus the useful thermal output (i.e., thermal energy delivered to a process).

*Heat recovery steam generating unit* means a unit where the hot exhaust gases from the combustion turbine are routed in order to extract heat from the gases and generate steam, for use in a steam turbine or other device that utilizes steam. Heat recovery steam generating units can be used with or without duct burners.

*Integrated gasification combined cycle electric utility steam generating unit* means a coal-fired electric utility steam generating unit that burns a synthetic gas derived from coal in a combined-cycle gas turbine. No solid coal is directly burned in the unit during operation. *ISO conditions* means 288 Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

*Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture before delivery to the combustor. Mixing may occur before or in the combustion chamber. A lean premixed turbine may operate in diffusion flame mode during operating conditions such as startup and shutdown, extreme ambient temperature, or low or transient load.

*Natural gas* means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1,100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, the Northern Mariana Islands, or offshore platforms.

*Peak load* means 100 percent of the manufacturer's design capacity of the combustion turbine at ISO conditions.

*Regenerative cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine.

*Simple cycle combustion turbine* means any stationary combustion turbine which does not recover heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine, or which does not recover heat from the combustion turbine exhaust gases for purposes other than enhancing the performance of the combustion turbine itself.

*Stationary combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and sub-components comprising any simple cycle stationary combustion turbine, any regenerative/recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.

*Unit operating day* means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

*Useful thermal output* means the thermal energy made available for use in any industrial or commercial process, or used in any heating or cooling application, i.e., total thermal energy made available for processes and applications other than electrical or mechanical generation. Thermal output for this subpart means the energy in recovered thermal output measured against the energy in the thermal output at 15 degrees Celsius and 101.325 kilopascals of pressure.

**Table 1\_to Subpart KKKK of Part 60\_Nitrogen Oxide Emission Limits for New Stationary Combustion Turbines**

Combustion turbine type	Combustion turbine heat input at peak load (HHV)	NOX emission standard
New turbine firing natural gas, electric generating	[le] 50 MMBtu/h...	42 ppm at 15. percent O2 or 290 ng/J of useful output (2.3 lb/MWh).
New turbine firing natural gas, mechanical drive.	[le] 50 MMBtu/h...	100 ppm at 15 percent O2 or 690 ng/J of useful output (5.5 lb/MWh).
New turbine firing natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h	25 ppm at 15 percent O2 or 150 ng/J of useful output (1.2 lb/MWh).
New, modified, or reconstructed turbine firing natural gas.	> 850 MMBtu/h...	15 ppm at 15 percent O2 or 54 ng/J of useful output (0.43 lb/MWh)
New turbine firing fuels other than natural gas, electric generating	[le] 50 MMBtu/h...	96 ppm at 15 percent O2 or 700 ng/J of useful output (5.5 lb/MWh).
New turbine firing fuels other than natural gas, mechanical drive.	[le] 50 MMBtu/h...	150 ppm at 15 percent O2 or 1,100 ng/J of useful output (8.7 lb/MWh).
New turbine firing fuels other than natural gas	> 50 MMBtu/h and [le] 850 MMBtu/h	74 ppm at 15 percent O2 or 460 ng/J of useful output (3.6 lb/MWh).
New, modified, or reconstructed turbine firing fuels other than	> 850 MMBtu/h...	42 ppm at 15 percent O2 or 160 ng/J of useful output (1.3

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

natural gas.		lb/MWh).
Modified or reconstructed turbine.	[le] 50 MMBtu/h...	150 ppm at 15 percent O2 or 1,100 ng/J of useful output (8.7 lb/MWh).
Modified or reconstructed turbine firing natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h.	42 ppm at 15 percent O2 or 250 ng/J of useful output (2.0 lb/MWh).
Modified or reconstructed turbine firing fuels other than natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h	96 ppm at 15 percent O2 or 590 ng/J of useful output (4.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F.	[le] 30 MW output.	150 ppm at 15 percent O2 or 1,100 ng/J of useful output (8.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0°F.	> 30 MW output.	96 ppm at 15 percent O2 or 590 ng/J of useful 75 output (4.7 lb/MWh).
Heat recovery units operating independent of the combustion turbine.	All sizes.....	54 ppm at 15 percent O2 or 110 ng/J of useful output (0.86 lb/MWh).

## SECTION IV. APPENDIX SC

### STANDARD CONDITIONS

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at this facility.

#### EMISSIONS AND CONTROLS

1. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
2. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]
3. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
4. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]
5. Excess Emissions - Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]
6. VOC or OS Emissions: No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]
7. Objectionable Odor Prohibited: No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and 62-210.200(203), F.A.C.]
8. General Visible Emissions: No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20 percent opacity. [Rule 62-296.320(4)(b)1, F.A.C.]
9. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

#### TESTING REQUIREMENTS

10. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20% below the allowable emission limiting standard. [Rule 62-297.310(1), F.A.C.]



**SECTION IV. APPENDIX SC**

**STANDARD CONDITIONS**

11. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2), F.A.C.]
12. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
13. Test Procedures: Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.
  - a. Required Sampling Time. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.
  - b. Minimum Sample Volume. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.
  - c. Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.[Rule 62-297.310(4), F.A.C.]
14. Determination of Process Variables
  - a. Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
  - b. Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.[Rule 62-297.310(5), F.A.C.]
15. Sampling Facilities: The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C.
16. Test Notification: The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator. [Rule 62-297.310(7)(a)9, F.A.C.]
17. Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]
18. Test Reports: The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide

## SECTION IV. APPENDIX SC

### STANDARD CONDITIONS

sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

- 1) The type, location, and designation of the emissions unit tested.
- 2) The facility at which the emissions unit is located.
- 3) The owner or operator of the emissions unit.
- 4) The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
- 5) The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
- 6) The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
- 7) A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
- 8) The date, starting time and duration of each sampling run.
- 9) The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
- 10) The number of points sampled and configuration and location of the sampling plane.
- 11) For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
- 12) The type, manufacturer and configuration of the sampling equipment used.
- 13) Data related to the required calibration of the test equipment.
- 14) Data on the identification, processing and weights of all filters used.
- 15) Data on the types and amounts of any chemical solutions used.
- 16) Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
- 17) The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
- 18) All measured and calculated data required to be determined by each applicable test procedure for each run.
- 19) The detailed calculations for one run that relate the collected data to the calculated emission rate.
- 20) The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21) A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

#### RECORDS AND REPORTS

19. **Records Retention:** All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2, F.A.C.]
20. **Annual Operating Report:** The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

## Memorandum

# Florida Department of Environmental Protection

---

TO: Trina L. Vielhauer  
THROUGH A.A. Linero *AAL*  
FROM: Cindy Mulkey *CM*  
DATE: October 6, 2006  
SUBJECT: Oleander Power Project, L.P. – Simple Cycle Combustion Turbine  
DEP File No. 0090180-003-AC (PSD-FL-377)

Attached is the revised draft permit package for the 190 MW Unit 5 simple cycle combustion turbine project at the existing Oleander Power Project (OPP) owned and operated by affiliates of Southern Company (SC). The OPP facility is located in Cocoa, Brevard County.

This revised draft is being issued as a result of a number of comments from SC received by the Department on September 27, 2006. The cover letter to the applicant withdraws the previous intent to issue and allows OGC to close the case file that arose from the applicant's request for enlargement of time to file a petition.

The rating of 190 MW is the nominal low temperature rating. These units are typically rated at 170 MW at ISO conditions. The new construction also includes a 60-foot exhaust stack and a nominal 900,000 gallon fuel oil storage tank. The facility was originally permitted to construct five GE 7FA simple cycle CTs and two fuel oil storage tanks. However, only four of the CTs and the two authorized fuel oil storage tanks were actually constructed.

The new CT will be capable of firing either natural gas or low sulfur fuel oil (0.05 percent sulfur). Unit 5 will be permitted to operate a total of 3,390 hours per year with a maximum of 500 hours of fuel oil firing.

Unit 5 triggered PSD and a BACT determination for NO<sub>x</sub>, and PM/PM10. The BACT for NO<sub>x</sub> is 9 ppmvd. The actual control is by Dry Low NO<sub>x</sub> combustors and use of natural gas. A limit of 42 ppmvd applies while burning backup distillate fuel oil. Control will be achieved by wet injection.

The bulk of the applicant's comments relate to continuous emissions monitoring issues. We made some key changes such as providing for a 24-hour operating hour NO<sub>x</sub> averaging time. No changes were made in regards to the allowable fuel oil usage. Use of fuel oil is still limited to 500 hours.


None of the changes made to the draft permit are considered to be significant, nor do they contradict any previous determinations made in the technical evaluation. A list of changes is attached for your convenience.

They did not publish the original notice and the language in the attached notice is identical. We plan to work with the applicant regarding the present permit requirements to use more gas than fuel oil at the DeSoto facility, and possibly Oleander.

We recommend your approval of the attached package for public distribution.

AAL/cem

Attachments



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

## P.E. Certification Statement

**Permittee:**

**DEP File No.** 0090180-003-AC (PSD-FL-377)

Oleander Power Project, L.P.  
Brevard County

**Project type:**

Project is construction of a nominal 190-megawatt (MW) simple cycle combustion turbine-electrical generator (CT), a 60-ft stack, and a 990,000 gallon fuel oil storage tank. The unit will operate a maximum of 3,390 hours per year of which 500 hours per year may be low sulfur fuel oil (0.05 percent sulfur).

It has been determined that BACT for NO<sub>x</sub> is 9.0 parts per million by volume, dry corrected to 15 percent oxygen (ppmvd @15% O<sub>2</sub>). The limit will be achieved by use of inherently clean natural gas and use of Dry Low NO<sub>x</sub>/CO combustors. A limit of 42 ppmvd NO<sub>x</sub> @15% O<sub>2</sub> will apply while firing back-up fuel oil and will be achieved by water injection into the combustors for flame temperature control. Emissions of carbon monoxide (CO), PM/PM<sub>10</sub>, sulfuric acid mist (SAM), sulfur dioxide (SO<sub>2</sub>), volatile organic compounds (VOCs) and visible emissions (Opacity) will be minimized by the efficient, high-temperature combustion of clean fuels.

Maximum predicted air quality impacts due to worst case emissions from the proposed new project are less than the significant impact levels applicable to all PSD Class II areas. Therefore, multi-source (PSD Increment) modeling was not required. The impacts to the nearest Class I area (Chassahowitzka National Wildlife Refuge) will be negligible. The project will not cause or contribute to a violation of any state or federal ambient air quality standard. The Fish and Wildlife Service had no adverse comments regarding this project.


*I HEREBY CERTIFY that the engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).*

  
A. A. Linero, P.E.      10/6/06  
Date

Registration Number: 26032

Department of Environmental Protection

Bureau of Air Regulation

Permitting South Section  10/6

111 South Magnolia Drive, Suite 4

Tallahassee, Florida 32301

Phone (850) 921-9523

Fax (850) 922-6979

"More Protection, Less Process"

## Harvey, Mary

---

**From:** System Administrator  
**To:** Mulkey, Cindy  
**Sent:** Tuesday, October 10, 2006 4:23 PM  
**Subject:** Delivered:Oleander Power Project Unit 5 - #0090180-003-AC -D

Your message

**To:** jovick@southernco.com; kwhite@southernco.com; mblake@cocoaf1.org; helen.voltz@brevardcounty.us; worley.gregg@epa.gov; JOHN\_BUNYAK@NPS.GOV; Kozlov, Leonard; TDAVIS@ECTINC.COM  
**Cc:** Adams, Patty; Mulkey, Cindy; Gibson, Victoria  
**Subject:** Oleander Power Project Unit 5 - #0090180-003-AC -D  
**Sent:** 10/10/2006 4:22 PM

was delivered to the following recipient(s):

Mulkey, Cindy on 10/10/2006 4:22 PM

## Harvey, Mary

---

**From:** System Administrator  
**To:** Kozlov, Leonard; Adams, Patty; Gibson, Victoria  
**Sent:** Tuesday, October 10, 2006 4:23 PM  
**Subject:** Delivered:Oleander Power Project Unit 5 - #0090180-003-AC -D

### Your message

**To:** jovick@southernco.com; kwhite@southernco.com; mblake@cocoaf1.org; helen.voltz@brevardcounty.us; worley.gregg@epa.gov; JOHN\_BUNYAK@NPS.GOV; Kozlov, Leonard; TDAVIS@ECTINC.COM  
**Cc:** Adams, Patty; Mulkey, Cindy; Gibson, Victoria  
**Subject:** Oleander Power Project Unit 5 - #0090180-003-AC -D  
**Sent:** 10/10/2006 4:22 PM

was delivered to the following recipient(s):

Kozlov, Leonard on 10/10/2006 4:22 PM  
Adams, Patty on 10/10/2006 4:22 PM  
Gibson, Victoria on 10/10/2006 4:22 PM

## Harvey, Mary

---

**From:** Kozlov, Leonard  
**To:** Harvey, Mary  
**Sent:** Tuesday, October 10, 2006 4:37 PM  
**Subject:** Read: Oleander Power Project Unit 5 - #0090180-003-AC -D

### Your message

**To:** jovick@southernco.com; kwhite@southernco.com; mblake@cocoaf1.org; helen.voltz@brevardcounty.us; worley.gregg@epa.gov; JOHN\_BUNYAK@NPS.GOV; Kozlov, Leonard; TDAVIS@ECTINC.COM  
**Cc:** Adams, Patty; Mulkey, Cindy; Gibson, Victoria  
**Subject:** Oleander Power Project Unit 5 - #0090180-003-AC -D  
**Sent:** 10/10/2006 4:22 PM

was read on 10/10/2006 4:37 PM.

## Harvey, Mary

---

**From:** John\_Bunyak@nps.gov  
**Sent:** Tuesday, October 10, 2006 5:02 PM  
**To:** Harvey, Mary  
**Subject:** Re: Oleander Power Project Unit 5 - #0090180-003-AC -D

Got it. Thanks.



## Harvey, Mary

---

**From:** EPA Postmaster automated message [postmaster@epamail.epa.gov]  
**Sent:** Tuesday, October 10, 2006 4:23 PM  
**To:** Harvey, Mary  
**Subject:** Delivery Notification: Message successfully forwarded

**Attachments:** ATT173310.txt; ATT173310.txt



ATT173310.txt (796 B)    ATT173310.txt (2 KB)

This report relates to a message you sent with the following header fields:

Message-id: <19B6D66EAAA71D479AE9408FB93EDDD1C1B61@tlhexsmb1.floridadep.net>  
Date: Tue, 10 Oct 2006 16:22:12 -0400  
From: "Harvey, Mary" <Mary.Harvey@dep.state.fl.us>  
To: jovick@southernco.com, kwhite@southernco.com, mblake@cocoaf1.org, helen.voltz@brevardcounty.us, worley.gregg@epamail.epa.gov, JOHN\_BUNYAK@NPS.GOV, "Kozlov, Leonard" <Leonard.Kozlov@dep.state.fl.us>, TDAVIS@ECTINC.COM  
Subject: Oleander Power Project Unit 5 - #0090180-003-AC -D

Your message has been successfully relayed to the recipients

Recipient address: worley.gregg@mseive.epa.gov  
Original address: worley.gregg@epa.gov  
Reason: Message successfully relayed to a system that does not support receipts  
Diagnostic code: dns;mseive02.rtp.epa.gov (TCP|134.67.208.33|4857|134.67.221.150|25)  
(mseive02.rtp.epa.gov ESMTTP Postfix) smtp;250 Ok  
Remote system: dns;mseive02.rtp.epa.gov (TCP|134.67.208.33|4857|134.67.221.150|25)  
(mseive02.rtp.epa.gov ESMTTP Postfix)

on a remote system that does not support the generation of successful delivery receipts. This does NOT mean that your message has actually been placed in the recipients' mailboxes; merely that it has passed through a part of the message transport infrastructure. In the event of a nondelivery you should expect to receive a nondelivery notification; in the event of a successful delivery, however, you are unlikely to receive a positive confirmation of delivery.

**Harvey, Mary**

---

**From:** Exchange Administrator  
**Sent:** Tuesday, October 10, 2006 4:24 PM  
**To:** Harvey, Mary  
**Subject:** Delivery Status Notification (Relay)

**Attachments:** ATT173308.txt; Oleander Power Project Unit 5 - #0090180-003-AC -D



ATT173308.txt  
(481 B)



Oleander Power  
Project Unit 5 ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

[helen.voltz@brevardcounty.us](mailto:helen.voltz@brevardcounty.us)

## Harvey, Mary

---

**From:** Exchange Administrator  
**Sent:** Tuesday, October 10, 2006 4:23 PM  
**To:** Harvey, Mary  
**Subject:** Delivery Status Notification (Relay)

**Attachments:** ATT173307.txt; Oleander Power Project Unit 5 - #0090180-003-AC -D



ATT173307.txt  
(471 B)



Oleander Power  
Project Unit 5 ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

mblake@cocoaf1.org

**Harvey, Mary**

---

**From:** Exchange Administrator  
**Sent:** Tuesday, October 10, 2006 4:23 PM  
**To:** Harvey, Mary  
**Subject:** Delivery Status Notification (Relay)

**Attachments:** ATT173306.txt; Oleander Power Project Unit 5 - #0090180-003-AC -D



ATT173306.txt  
(472 B)



Oleander Power  
Project Unit 5 ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

JOHN\_BUNYAK@NPS.GOV

# Harvey, Mary

---

**From:** Exchange Administrator  
**Sent:** Tuesday, October 10, 2006 4:23 PM  
**To:** Harvey, Mary  
**Subject:** Delivery Status Notification (Relay)

**Attachments:** ATT173300.txt; Oleander Power Project Unit 5 - #0090180-003-AC -D



ATT173300.txt  
(470 B)



Oleander Power  
Project Unit 5 ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

TDAVIS@ECTINC.COM

## Harvey, Mary

---

**From:** Voltz, Helen P [Helen.Voltz@brevardcounty.us]  
**To:** Harvey, Mary  
**Sent:** Tuesday, October 10, 2006 6:00 PM  
**Subject:** Read: Oleander Power Project Unit 5 - #0090180-003-AC -D

Your message

**To:** Helen.Voltz@brevardcounty.us  
**Subject:**

was read on 10/10/2006 6:00 PM.

## Harvey, Mary

---

**From:** Tom Davis [tdavis@ectinc.com]  
**Sent:** Tuesday, October 10, 2006 5:10 PM  
**To:** Harvey, Mary  
**Subject:** RE: Oleander Power Project Unit 5 - #0090180-003-AC -D

---

**From:** Harvey, Mary [mailto:Mary.Harvey@dep.state.fl.us]  
**Sent:** Tuesday, October 10, 2006 4:22 PM  
**To:** jovick@southernco.com; kwhite@southernco.com; mblake@cocoaf1.org; helen.voltz@brevardcounty.us; worley.gregg@epa.gov; JOHN\_BUNYAK@NPS.GOV; Kozlov, Leonard; TDAVIS@ECTINC.COM  
**Cc:** Adams, Patty; Mulkey, Cindy; Gibson, Victoria  
**Subject:** Oleander Power Project Unit 5 - #0090180-003-AC -D

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

10/11/2006

## Harvey, Mary

---


**From:** Mailer-Daemon@ectinc.com  
**Sent:** Tuesday, October 10, 2006 4:26 PM  
**To:** Harvey, Mary  
**Subject:** Confirm: 'Oleander Power Project Unit 5 - #0090180-003-AC -D' received.

A message which requested delivery confirmation recently arrived at this server. This server honors all delivery confirmation requests whether generated from local mail traffic or from mail received via an outside source (such as SMTP/POP).

Message-ID: <19B6D66EAAA71D479AE9408FB93EDDDD1C1B61@tlhexsmb1.floridadep.net>  
To : tdavis@ectinc.com  
From : Mary.Harvey@dep.state.fl.us  
Subject : Oleander Power Project Unit 5 - #0090180-003-AC -D  
Date : Tue, 10 Oct 2006 16:22:12 -0400

Receiving Domain: ectinc.com





Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

September 12, 2006

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. James O. Vick, Director  
Environmental Affairs  
Gulf Power Company  
One Energy Place  
Pensacola, Florida 32520

Re: Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine  
DEP File No. 0090180-003-AC (PSD-FL-377)

Dear Mr. Vick:

Enclosed is the Department's preliminary determination to issue an Air Construction Permit pursuant to the rules for the Prevention of Significant Deterioration of Air Quality (PSD) to Oleander Power Project, L.P. to construct a 190 megawatt simple cycle combustion turbine unit, stack, and fuel oil storage tank at the Oleander Power Project in Brevard County. The documents include: the "Intent to Issue Air Construction Permit"; the "Public Notice of Intent to Issue Air Construction Permit"; the Department's "Technical Evaluation and Preliminary Determination"; and the Draft Permit.

The PUBLIC NOTICE must be published one time only in a newspaper of general circulation in the area affected, pursuant to Chapter 50, Florida Statutes. Proof of publication, i.e., newspaper affidavit, must be provided to the Department's Bureau of Air Regulation office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

Please submit any written comments you wish to have considered concerning the Department's proposed action to A. A. Linero at the above letterhead address. If you have any questions, please call Cindy Mulkey at 850/921-8968 (review engineer) or Debbie Nelson at 850/921-9537.

Sincerely,

Trina L. Vielhauer, Chief  
Bureau of Air Regulation

TLV/aal/cm

Enclosures

"More Protection, Less Process"

Printed on recycled paper.

SENDER: COMPLETE THIS SECTION		COMPLETE THIS SECTION ON DELIVERY	
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>		A. Signature <i>x B. Nichols</i> <input type="checkbox"/> Agent <input type="checkbox"/> Addressee	
1. Article Addressed to:  Mayor, City of Cocoa Beach Post Office Box 322430 Cocoa Beach, Florida 32932-2430		B. Received by (Printed Name) <i>B. Nichols</i>	C. Date of Delivery <i>9/14/06</i>
		D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No	
		3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.	
		4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes	
2. Article Number (Transfer from service label) <i>7000 1670 0013 3110 1229</i>			
PS Form 3811, February 2004		Domestic Return Receipt	

U.S. Postal Service CERTIFIED MAIL RECEIPT (Domestic Mail Only; No Insurance Coverage Provided)	
OFFICIAL USE	
Postage \$	Postmark Here
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Mayor, City of Cocoa Beach Post Office Box 322430 Cocoa Beach, Florida 32932-2430	
PS Form 3800, May 2000	

U.S. Postal Service CERTIFIED MAIL RECEIPT (Domestic Mail Only; No Insurance Coverage Provided)	
OFFICIAL USE	
Postage \$	Postmark Here
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Mr. James O. Vick, Director Environmental Affairs Gulf Power Company One Energy Place Pensacola, Florida 32520	
PS Form 3800, May 2000	

SENDER: COMPLETE THIS SECTION		COMPLETE THIS SECTION ON DELIVERY	
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>		A. Signature <i>x James Blakey</i> <input type="checkbox"/> Agent <input type="checkbox"/> Addressee	
1. Article Addressed to:  Mr. James O. Vick, Director Environmental Affairs Gulf Power Company One Energy Place Pensacola, Florida 32520		B. Received by (Printed Name) <i>James Blakey</i>	C. Date of Delivery <i>9-13</i>
		D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No	
		3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.	
		4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes	
2. Article Number (Transfer from service label) <i>7000 1670 0013 3110 1212</i>			
PS Form 3811, February 2004		Domestic Return Receipt	

In the Matter of an  
Application for Permit by:

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, Florida 32926

*Authorized Representative:*  
Mr. James O. Vick

DEP File No. 0090180-003-AC  
Draft Permit No. PSD-FL-377  
Oleander Power Project  
Unit 5 Simple Cycle Combustion Turbine  
Brevard County, Florida

### **INTENT TO ISSUE AIR CONSTRUCTION PERMIT**

The Department of Environmental Protection (Department) gives notice of its intent to issue an Air Construction Permit, copy of Draft Permit attached, for the proposed project as detailed in the application specified above and the attached Technical Evaluation and Preliminary Determination for the reasons stated below.

The applicant, Oleander Power Project, L.P., applied on May 4, 2006 to the Department for an Air Construction Permit to construct a 190 megawatt simple cycle combustion turbine, Unit 5, at the existing Oleander Power Project in the city of Cocoa, Brevard County.

The Department has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-212. The above actions are not exempt from permitting procedures. The Department has determined that an Air Construction Permit pursuant to the Rules for the Prevention of Significant Deterioration of Air Quality (PSD) is required.

The Department intends to issue this Air Construction Permit based on the belief that reasonable assurances have been provided to indicate that operation of these emissions units will not adversely impact air quality, and the emissions units will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C.

Pursuant to Section 403.815, F.S., and Rules 62-110.106(7)(a)1., and 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Construction Permit. The notice shall be published one time only in the legal advertisement section of a newspaper of general circulation in the area affected. Rule 62-110.106(7)(b), F.A.C., requires that the applicant cause the notice to be published as soon as possible after notification by the Department of its intended action. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Department at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-0114; Fax 850/921-9533). You must provide proof of publication within seven days of publication, pursuant to Rule 62-110.106(5), F.A.C. No permitting action for which published notice is required shall be granted until proof of publication of notice is made by furnishing a uniform affidavit in substantially the form prescribed in section 50.051, F.S. to the office of the Department issuing the permit. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rules 62-110.106(9) & (11), F.A.C.

The Department will issue the final permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for public meetings concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of the enclosed Public Notice of Intent to Issue Air Construction Permit. Written comments should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed

action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available in this proceeding.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief  
Bureau of Air Regulation

### CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Intent to Issue Air Construction Permit (including the Public Notice, Technical Evaluation and Preliminary Determination, and the DRAFT permit) was sent by certified mail (\*) and copies were mailed by U.S. Mail or by electronic mail before the close of business on 9/12/06 to the persons listed:

James O. Vick, Gulf Power Company\*  
Allison Little, Gulf Power Company  
Mayor, City of Cocoa\*  
Chair, Brevard County BCC

Gregg Worley, EPA Region 4  
John Bunyak, National Park Service  
Len Kozlov, DEP CD  
Thomas W. Davis, P.E., ECT, Inc.

Clerk Stamp

**FILING AND ACKNOWLEDGMENT**  
**FILED**, on this date, pursuant to §120.52,  
Florida Statutes, with the designated  
Department Clerk, receipt of which is  
hereby acknowledged.



(Clerk)

9/12/06  
(Date)

**PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT**

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DEP File No. 0090180-003-AC, PSD-FL-377

Oleander Power Project Unit 5  
Simple Cycle Combustion Turbine-Electrical Generator

Brevard County

The Department of Environmental Protection (Department) gives notice of its intent to issue an Air Construction Permit to Oleander Power Project, L.P. The permit is to construct a 190 megawatt (MW) simple cycle combustion turbine-electrical generator (CT) to be known as Unit 5 at the Oleander Power Project in the City of Cocoa, Brevard County. A review under the Rules for the Prevention of Significant Deterioration of Air Quality (PSD) and a Best Available Control Technology (BACT) determination were required for emissions of nitrogen oxides (NO<sub>x</sub>) and particulate matter (PM/PM<sub>10</sub>) pursuant to Rule 62-212.400, Florida Administrative Code (F.A.C.). The applicant's name and address are Oleander Power Project, L.P., 555 Townsend Road, Cocoa, Florida 32926.

The original Air Construction Permit issued in 1999 authorized construction of five General Electric 7FA simple cycle CTs with 60-foot stacks and two 1.8 million gallon fuel oil storage tanks. Only four CTs with stacks and the two fuel oil storage tanks were constructed. This draft permitting action re-authorizes construction of the fifth 190 MW CT, a 60-foot stack and a smaller fuel oil storage tank with a nominal capacity of 900,000 gallons.

Unit 5 will be an intermittent duty CT (typically known as a peaking unit) and will fire natural gas as the primary fuel and No. 2 low sulfur fuel oil as back-up fuel. Unit 5 will be permitted to operate a total of 3,390 hours per year with a maximum of 500 hours of fuel oil firing. The Department has determined that BACT for NO<sub>x</sub> is 9.0 parts per million by volume, dry corrected to 15 percent oxygen (ppmvd @15% O<sub>2</sub>). The limit will be achieved by use of inherently clean natural gas and use of Dry Low NO<sub>x</sub>/CO combustors.

A limit of 42 ppmvd NO<sub>x</sub> @15% O<sub>2</sub> will apply while firing back-up fuel oil and will be achieved by water injection into the combustors for flame temperature control. Emissions of carbon monoxide (CO), PM/PM<sub>10</sub>, sulfuric acid mist (SAM), sulfur dioxide (SO<sub>2</sub>), volatile organic compounds (VOCs) and visible emissions (Opacity) will be minimized by the efficient, high-temperature combustion of clean fuels.

Estimates of maximum potential annual emissions from CT Unit 5 are summarized in the following table.

<u>Pollutant</u>	<u>Maximum Tons Per Year</u>	<u>PSD Significant Emission Rate Tons Per Year</u>	<u>PSD Review Required?</u>
CO	77.0	100	No
NO <sub>x</sub>	174.5	40	Yes
PM/PM <sub>10</sub>	34.5/34.5	25/15	Yes
SO <sub>2</sub>	37.1	40	No
SAM	2.7	7	No
VOC	11.4	40	No
Mercury	0.0006	0.1	No
Pb	0.0495	0.6	No
Formaldehyde	0.655	Not Applicable	No

According to the applicant and as verified by the Department, maximum predicted air quality impacts due to worst case emissions from the proposed new project are less than the significant impact levels applicable to all PSD Class II areas. Therefore, multi-source (PSD Increment) modeling was not required. The impacts to the nearest Class I area (Chassahowitzka National Wildlife Refuge on the Gulf coast) will be negligible. Based on the required analyses, the Department has reasonable assurance that the proposed project will not cause or contribute to a violation of any state or federal ambient air quality standard.

The Department will issue the final permit, in accordance with the conditions of the draft permit, unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for a public meeting concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of this Public Notice of Intent to Issue Air Construction Permit. Written comments or requests for public meetings should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below. Mediation is not available in this proceeding.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen (14) days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen (14) days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C. Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Department of Environmental Protection  
Bureau of Air Regulation  
111 S. Magnolia Drive, Suite 4  
Tallahassee, Florida, 32301  
Telephone: 850/488-0114  
Fax: 850/921-9533

Department of Environmental Protection  
Central District Office  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767  
Telephone: 407/894-7555  
Fax: 407/897-2966

The complete project file includes the application, technical evaluations, Draft Permit, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Program Administrator, South Permitting Section at the Bureau of Air Regulation at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114 for additional information. Key documents related to this permitting action are available at: [www.dep.state.fl.us/Air/permitting/construction/oleander.htm](http://www.dep.state.fl.us/Air/permitting/construction/oleander.htm)

**TECHNICAL EVALUATION  
AND  
PRELIMINARY DETERMINATION**

Oleander Power Project, L.P.

190 MW Simple Cycle Gas Turbine

Cocoa, Brevard County

DEP File No. 0090180-003-AC (PSD-FL-377)



Florida Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation – Air Permitting South  
2600 Blair Stone Road, MS #5505  
Tallahassee, FL 32399-2400

September 12, 2006



**I. APPLICATION INFORMATION**

**A. APPLICANT**

Oleander Power Project, L.P.  
 555 Townsend Road  
 Cocoa, Florida 32926

**Authorized Representative**

James O. Vick, Director Environmental Affairs  
 Gulf Power Company  
 One Energy Place  
 Pensacola, Florida 32520

**B. PROCESSING SCHEDULE**

- Application for Air Construction Permit received on May 4, 2006;
- Department’s Request for Additional Information dated June 2, 2006;
- Applicant’s Response to Request for Additional Information Received July 13, 2006 (complete);
- Department’s Intent to Issue and Public Notice Package dated September 12, 2006.

**C. FACILITY LOCATION**

Oleander Power Project (OPP) is located in Cocoa just off Interstate 95 and State Road 520 in Brevard County. The site is 175 km from the nearest Federal Prevention of Significant Deterioration (PSD) Class I Area, the Chassahowitzka National Wildlife Refuge. The UTM coordinates for this site are Zone 17, 520.1 km East and 3,137.6 km North. The locations of Cocoa and OPP are shown in the following figures.



Figure 1. Location of Cocoa



Figure 2. OPP Location




Figure 3. Site Aerial Photograph

**D. FACILITY DESCRIPTION**

The regulated emissions units at the existing Oleander Power Project include four 190 megawatt (MW) General Electric 7FA simple cycle combustion turbine-electric generators (CT Units 001 through 004). The CTs have evaporative coolers, Dry Low NO<sub>x</sub>/CO (DLN) combustors and water injection equipment and can fire natural gas or No. 2 low sulfur (0.05 percent) fuel oil. The facility also includes four 60-foot stacks, two 1.8 million-gallon fuel oil storage tanks (Units 006 and 007) and water storage tanks. The original application included the construction of five combustion turbines (CTs), of which only four were constructed.

The facility’s Standard Industrial Classification Codes are listed in the following Table:

**Table 1. Oleander Power Project SIC Codes**

STANDARD INDUSTRIAL CLASSIFICATION CODES (SIC)		
Industry Group No.	49	Electric, Gas, and Sanitary Services
Industry No.	4911	Electric Services

**E. REGULATORY CATEGORIES**

*Title I, Part C, Clean Air Act (CAA):* The facility is located in an area that is designated as “attainment”, “maintenance”, or “unclassifiable” for each pollutant subject to a National Ambient Air Quality Standard. The facility does not fall into one of the 28 Prevention of Significant Deterioration (PSD) Major Facility Categories with the lower PSD applicability threshold therefore the 250 tons per year threshold is applicable. Potential emissions of at least one regulated pollutant exceed 250 tons per year, therefore the facility is classified as a “Major Stationary Source” of air pollution with respect to Rule 62-212.400 F.A.C., Prevention of Significant Deterioration of Air Quality.

*Title I, Section 111, CAA:* Unit 5 will be subject to 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines for Which Construction is Commenced After February 18, 2005).

*Title I, Section 112, CAA:* The facility is not a “Major Source” of hazardous air pollutants (HAPs). Unit 005 will not be subject to 40 CFR 63, Subpart YYYY, National Emissions Standard for Hazardous Air Pollutants for Stationary Combustion Gas Turbines.

*Title IV, CAA:* The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

*Title V, CAA:* The facility is a Title V or “Major Source of Air Pollution” in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), and volatile organic compounds (VOC).

**F. PROJECT DESCRIPTION AS PROPOSED BY APPLICANT**

The applicant proposes to install one 190 megawatt (MW) General Electric (GE) 7FA simple cycle combustion turbine-electrical generator (CT Unit 5, ID 005) equipped with evaporative cooling, DLN combustors and water injection equipment. OPP also plans to install a new 60-foot stack and a nominal 900,000 gallon distillate fuel oil storage tank.

Additional project details, as proposed, are described below:

*Fuel:* Operation of Unit 5 for a total of 3,390 hours per year using natural gas as the primary fuel. The use of low sulfur fuel oil (0.05 % sulfur) as a back up fuel has been requested for up to 1000 hours, included in the 3,390.

*Controls:* NO<sub>x</sub> emission will be reduced with DLN combustion technology while firing natural gas, and water injection while firing fuel oil. Advanced burner design with good combustion practices will be used to minimize incomplete combustion of CO, PM<sub>10</sub>, and VOC. The use of natural gas and restricted operation on fuel oil will minimize emissions of SO<sub>2</sub> and sulfuric acid mist (SAM).

*Continuous Monitors:* The combustion turbine is required to continuously monitor NO<sub>x</sub> emissions in accordance with the acid rain provisions. The same monitor will be employed for demonstration of continuous compliance with the Best Available Control Technology (BACT) determination. Flue gas oxygen content or carbon dioxide content will be monitored as a diluent gas.


*Stack parameters:* Unit 5 will have a stack that is 60 feet tall with an approximate exit diameter of 22 feet. The following table summarizes the exhaust characteristics of the unit. Values given are approximate for operation at 59 degrees Fahrenheit (°F) and the characteristics of the actual delivered unit may differ somewhat. At 59 °F, the nominal capacity is approximately 170 MW when firing natural gas whereas the capacity is greater (nominally 180 to 190 MW) at lower temperature or when firing fuel oil.

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

**Table 2. Approximate Exhaust Characteristics of Unit 5 at 100% Load and 59° F**

<u>Fuel</u>	<u>Total Heat Input (LHV)</u>	<u>Compressor Inlet Temp.</u>	<u>Turbine Exhaust Temp., °F</u>	<u>Stack Flow ACFM @ 15% O<sub>2</sub></u>
Gas	1722 mmBtu/hr	59° F	1,111 °F	2,882,847
Oil	1920 mmBtu/hr	59° F	1,095 °F	3,297,214

The key components, with a focus on fairly recent improvements, of the GE 7FA CT are shown in the “quarter section” internal diagram. The overall look can be appreciated by the “three-quarter” section graphic of the similar 7FB following the diagram.



**Figure 4. Quarter Section of GE 7FA (top). Three-Quarter Section of GE 7FB (bottom) (GE Reports)**

**G. PROCESS DESCRIPTION**

A gas turbine is an internal combustion engine that operates with rotary rather than reciprocating motion. Ambient air is drawn into the 18-stage compressor of the GE 7FA (Figure 4) where it is compressed by a pressure ratio of about 15.5 times atmospheric pressure. The compressed air is then directed to the combustor section, where fuel is introduced, ignited, and burned. The combustion section consists of 14 separate can-annular combustors.

In general, flame temperatures in a typical combustor section can reach 3600° F. Units such as the GE 7FA operate at lower flame temperatures, which minimize NO<sub>x</sub> formation. The hot combustion gases are then diluted with additional cool air and directed to the turbine section at temperatures of approximately 2500° F. Energy is recovered in the turbine section in the form of shaft horsepower, of which typically more than 50 percent is required to drive the internal compressor section. The balance of recovered shaft energy is available to drive the external load unit such as an electrical generator. Turbine exhaust gas is discharged at a temperature greater than 1000 °F and high excess oxygen and is available for additional energy recovery.

There are three basic operating cycles for gas turbines. These are simple, regenerative, and combined cycles. In the OPP project, the unit will operate in simple cycle mode only, meaning that the gas turbine drives an electric generator while the exhausted gases are directed through the stack with no additional heat recovery.

**II. RULE APPLICABILITY**

**A. STATE REGULATIONS**

The project is subject to the applicable environmental laws specified in Section 403 of the Florida Statutes (F.S.). The Florida Statutes authorize the Department of Environmental Protection to establish rules and regulations regarding air quality as part of the Florida Administrative Code (F.A.C.). This project is subject to the following rules in the F.A.C.

<b>Chapter</b>	<b>Description</b>
62-4	Permitting Requirements
62-204	Air Pollution Control (Includes Adoption of Federal Regulations)
62-210	Stationary Sources – General Requirements
62-212	Stationary Sources – Preconstruction Review (including PSD Requirements)
62-213	Operation Permits for Major Sources of Air Pollution
62-214	Acid Rain Program Requirements
62-296	Stationary Sources – Emission Limiting Standards
62-297	Stationary Sources – Emissions Monitoring

**B. FEDERAL REGULATIONS**

This project is also subject to certain applicable federal provisions regarding air quality as established by the EPA in the Code of Federal Regulations (CFR) and summarized below.

<b>Title 40</b>	<b>Description</b>
Part 60	Standards of Performance for New Stationary Sources (NSPS)
Part 72	Acid Rain – Permits Regulation
Part 73	Acid Rain – Sulfur Dioxide Allowance System
Part 75	Acid Rain – Continuous Emissions Monitoring
Part 76	Acid Rain – Nitrogen Oxides Emissions Reduction Program
Part 77	Acid Rain – Excess Emissions

*Note: Acid rain requirements will be included in the Title V air operation permit.*

**C. PSD PRECONSTRUCTION REVIEW REQUIREMENTS**

The Department regulates major air pollution sources in accordance with Florida’s Prevention of Significant Deterioration (PSD) program, as described in Rule 62-212.400, F.A.C. A PSD review is only required in areas that are currently in attainment with the National Ambient Air Quality Standard (AAQS) for a given pollutant or areas designated as “unclassifiable” for the pollutant. A new facility is considered “major” with respect to PSD if the facility emits or has the potential to emit:

- 250 tons per year or more of any regulated air pollutant; or
- 100 tons per year or more of any regulated air pollutant and the facility belongs to one of the 28 Major Facility Categories; or
- 5 tons per year of lead.

For new PSD-major facilities and modifications to existing PSD-major sources, each regulated pollutant is reviewed for PSD applicability based on emissions thresholds known as the Significant Emission Rates (SERs) identified in Rule 62-210.200(243), F.A.C. Each pollutant exceeding the respective SER is considered “significant” and the applicant must employ the Best Available Control Technology (BACT) to minimize emissions, and evaluate the air quality impacts. Although a facility may be considered a “major stationary source” with respect to PSD because of only one regulated pollutant, it is required to implement BACT for each “PSD-significant” pollutant. In accordance with Rule 62-212.400(4), F.A.C., for the construction of any new “major stationary source” or the major “modification” of any existing major stationary source, the applicant must provide the following information:

- (a) *A description of the nature, location, design capacity, and typical operating schedule of the source or modification, including specifications and drawings showing its design and plant layout;*
- (b) *A detailed schedule for construction of the source or modification;*
- (c) *A detailed description as to what system of continuous emission reduction is planned for the source or modification, emission estimates, and any other information necessary to determine best available control technology (BACT) including a proposed BACT;*
- (d) *The air quality impact of the source or modification, including meteorological and topographical data necessary to estimate such impact and an analysis of “good engineering practice” stack height; and*
- (e) *The air quality impacts, and the nature and extent of any or all general commercial, residential, industrial, and other growth which has occurred since August 7, 1977, in the area the source or modification would affect.*

## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

---

“Best Available Control Technology” or “BACT” as defined in Rule 62-210.200(38), F.A.C. is as follows:

- (a) *An emission limitation, including a visible emissions standard, based on the maximum degree of reduction of each pollutant emitted which the Department, on a case by case basis, taking into account:*
  1. *Energy, environmental and economic impacts, and other costs,*
  2. *All scientific, engineering, and technical material and other information available to the Department; and*
  3. *The emission limiting standards or BACT determinations of Florida and any other state; determines is achievable through application of production processes and available methods, systems and techniques (including fuel cleaning or treatment or innovative fuel combustion techniques) for control of each such pollutant.*
- (b) *If the Department determines that technological or economic limitations on the application of measurement methodology to a particular part of an emissions unit or facility would make the imposition of an emission standard infeasible, a design, equipment, work practice, operational standard or combination thereof, may be prescribed instead to satisfy the requirement for the application of BACT. Such standard shall, to the degree possible, set forth the emissions reductions achievable by implementation of such design, equipment, work practice or operation.*
- (c) *Each BACT determination shall include applicable test methods or shall provide for determining compliance with the standard(s) by means which achieve equivalent results.*
- (d) *In no event shall application of best available control technology result in emissions of any pollutant which would exceed the emissions allowed by any applicable standard under 40 CFR Parts 60, 61, and 63.*

The Department conducts its case-by-case BACT determinations in accordance with the requirements given above. Additionally the Department generally conducts its reviews in such a manner that the determinations are consistent with those conducted using the Top/Down Methodology described by EPA.<sup>1</sup>

In addition to a determination of BACT, PSD review also requires an Air Quality Analysis for each pollutant exceeding the SER. The Air Quality Analysis consists of: an air dispersion modeling analysis to estimate the resulting ambient air pollutant concentrations; a comparison of modeled concentrations from the project with National Ambient Air Quality Standards and PSD Increments; an analysis of the air quality impacts from the proposed project upon soils, vegetation, wildlife, and visibility (Air Quality Related Values – AQRVs); and an evaluation of the air quality impacts resulting from associated commercial, residential, and industrial growth related to the proposed project.

### **D. PSD APPLICABILITY FOR THE PROJECT**

The project will result in emissions of carbon monoxide, nitrogen oxides, sulfur dioxides, particulate matter, sulfuric acid mist (SAM), volatile organic compounds, lead (Pb), mercury (Hg), formaldehyde, and flourides. The following table summarizes the annual potential emissions in tons per year (TPY) from the project as proposed by the applicant.

Table 3. Estimate of Potential Annual Emissions as Proposed by Applicant.

Pollutant	Project Emissions TPY	PSD Significant Emission Rate TPY	PSD Review Required?
NO <sub>x</sub>	243.1	40	Yes
SO <sub>2</sub>	58.9	40	Yes
CO	83.7	100	No
PM	38.5	25	Yes
PM <sub>10</sub>	38.5	15	Yes
VOC	12.9	40	No
SAM	4.5	7	No
Mercury	0.0012	0.1	No
Lead	0.0489	0.6	No
Formaldehyde	0.672	Not Applicable	NAo
Total Fluorides	Negligible	3	No

As proposed by Applicant, the project is subject to PSD preconstruction review and BACT determinations for NO<sub>x</sub>, SO<sub>2</sub>, and PM/PM<sub>10</sub>.

III. BEST AVAILABLE CONTROL TECHNOLOGY (BACT) – Draft Determinations

A. NITROGEN OXIDES (NO<sub>x</sub>)

1. Discussion of NO<sub>x</sub> Formation

Nitrogen oxides form in the combustion turbine process as a result of the dissociation of molecular nitrogen and oxygen to their atomic forms and subsequent recombination into seven different oxides of nitrogen. Uncontrolled emissions range from about 100 to over 600 parts per million by volume, dry, corrected to 15 percent oxygen (ppmvd @15% O<sub>2</sub>). The Department estimates uncontrolled emissions at approximately 200 ppmvd @15% O<sub>2</sub> for a GE 7FA combustion turbine.<sup>2</sup>

Thermal NO<sub>x</sub> forms in the high temperature area of the combustor. Thermal NO<sub>x</sub> increases exponentially with increases in flame temperature and linearly with increases in residence time. Flame temperature is dependent upon the ratio of fuel burned in a flame to the amount of fuel that consumes all of the available oxygen, also known as the equivalence ratio. By maintaining a low fuel ratio (lean combustion), the flame temperature will be lower, thus reducing the potential for NO<sub>x</sub> formation. The changes in NO<sub>x</sub> production as flame temperatures vary due to increasing/decreasing equivalence ratios can be seen in Figure 5 below.





Figure 5. NO<sub>x</sub> vs. Temperature, Equivalence Ratio.<sup>3</sup> Figure 6. Hot Gas Path Parts, NO<sub>x</sub> Control

## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

In most combustor designs, the high temperature combustion gases are cooled to an acceptable temperature with dilution air prior to entering the turbine (expansion) section. The sooner this cooling occurs, the lower the thermal  $\text{NO}_x$  formation. The relationship between flame temperature, firing temperature, unit efficiency, and  $\text{NO}_x$  formation is depicted in Figure 6, which is from a General Electric discussion on these principles.

Prompt  $\text{NO}_x$  is formed in the proximity of the flame front as intermediate combustion products. The contribution of prompt to overall  $\text{NO}_x$  is relatively small in near-stoichiometric combustors and increases for leaner fuel mixtures. This provides a practical limit for  $\text{NO}_x$  control by lean combustion.

Fuel  $\text{NO}_x$  is formed when fuels containing bound nitrogen are burned. This phenomenon is not of great concern when combusting natural gas.

For the purpose of further discussion, concentrations expressed in terms of ppmvd presume correction to 15%  $\text{O}_2$  unless otherwise noted.

### 2. Descriptions of Available $\text{NO}_x$ Controls

Wet Injection. Fuel and air are mixed within traditional combustors and the combustion actually occurs on the boundaries of the flame. This is termed “diffusion flame” combustion. Injection of either water or steam directly into the combustor lowers the flame temperature and thereby reduces thermal  $\text{NO}_x$  formation. There is a physical limit to the amount of water or steam that may be injected before flame instability or cold spots in the combustion zone would cause adverse operating conditions for the combustion turbine. Carbon monoxide (CO) and hydrocarbon (HC) emissions are relatively low for most gas turbines. However steam and (more so) water injection may increase emissions of both of these pollutants.

Advanced dual fuel combustor designs can tolerate large amounts of steam or water without causing flame instability and can achieve  $\text{NO}_x$  emissions in the range of 30 to 42 ppmvd when employing wet injection for backup fuel oil firing. Wet injection results in control efficiencies on the order of 80 to 90% for oil firing. These values often form the basis, particularly in combined cycle turbines, for further reduction to BACT limits by other techniques as discussed below. During dry low- $\text{NO}_x$  combustion while gas firing, wet injection is not employed.

Dry Low  $\text{NO}_x$ /CO (DLN) Combustion. The excess air in lean combustion cools the flame and reduces the rate of thermal  $\text{NO}_x$  formation. Lean premixing of fuel and air prior to combustion can further reduce  $\text{NO}_x$  emissions. This is accomplished by minimizing localized fuel-rich pockets (and high temperatures) that can occur when trying to achieve lean mixing within the combustion zones. This principle is incorporated into the General Electric DLN-2.6 can-annular combustor shown in the following figure.




Figure 7. DLN-2.6 Fuel Nozzle Arrangement




**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

Each combustor includes six nozzles within which fuel and air have been fully pre-mixed. There are 16 small fuel passages around the circumference of each combustor can known as quaternary fuel pegs. The six nozzles are sequentially ignited as load increases in a manner that maintains lean pre-mixed combustion and flame stability.

Design NO<sub>x</sub>, CO, and VOC emission characteristics of the DLN-2.6 combustor while firing natural gas are given in Figure 8 below for a unit tuned to meet a limit of 9 ppmvd. The values for CO are “uncorrected” for O<sub>2</sub>. Values for VOC are uncorrected, “wet basis”, and do not include methane and ethane because they are not defined as VOC.

The combustor design is such that NO<sub>x</sub> concentrations equal 9 ppmvd at loads between 50 and 100 percent of capacity, but concentrations as high as 100 ppmvd may occur at less than 50 percent of capacity. This suggests the need to minimize operation at low load conditions.



**Figure 8. Design Emission Characteristics for DLN-2.6. Figure 9. NO<sub>x</sub> Performance of DLN-2.6**

Figure 9 is from a GE publication and is a plot of NO<sub>x</sub> data from actual installations or possibly a test facility. Actual NO<sub>x</sub> emissions are less than the design values. The Department has reviewed numerous reports and low load operation data from GE 7FA CTs in Florida and can confirm the accuracy of the graph on the right. Also actual emissions of CO and VOC have proven to be much less than suggested by the diagram.


Table 4 summarizes the results of the new and clean tests conducted on a dual-fuel GE 7FA CT with DLN 2.6 combustors operating in simple cycle mode and burning natural gas at the existing Tampa Electric Polk Power Station.<sup>4</sup> The test results confirm that NO<sub>x</sub>, CO, and VOC emissions are less than the design characteristics published by GE and given on the left hand side of the figure 8 above.

**Table 4. Actual Performance of DLN-2.6 Combustors at Tampa Electric Polk Power Station.**



Percent of Full Load	NO <sub>x</sub> (ppmvd @15% O <sub>2</sub> )	CO (ppmvd)	VOC (ppmvd)
50	5.3	1.6	0.5
70	6.3	0.5	0.4
85	6.2	0.4	0.2
100	7.6	0.3	0.1

Numerous simple cycle GE 7FA units with DLN technology for NO<sub>x</sub> control have been installed in Florida and throughout the United States with guarantees of 9 ppmvd. This represents a reduction of approximately 95 percent compared with uncontrolled emissions if assumed to equal 200 ppmvd.

Selective Catalytic Reduction (SCR). Selective catalytic reduction (SCR) is an add-on NO<sub>x</sub> control technology that is employed in the exhaust stream following the gas turbine. SCR reduces NO<sub>x</sub> emissions by injecting ammonia into the flue gas in the presence of a catalyst. Ammonia reacts with NO<sub>x</sub> in the presence of a catalyst and excess oxygen yielding molecular nitrogen and water according to the following simplified reaction:



The catalysts used in combined cycle, low temperature applications (conventional SCR), are usually vanadium (V) and titanium oxide (TiO<sub>2</sub>) formulations and account for most installations. At high temperatures, V can contribute to ammonia oxidation forming more NO<sub>x</sub> or forming nitrogen (N<sub>2</sub>) without reducing NO<sub>x</sub> according to:



For high temperature applications (hot SCR up to approximately 1100 °F), such as large frame simple cycle turbines, special formulations or strategies are required. SCR technology has progressed considerably over the last decade with Zeolite catalyst now being used for high temperature applications. SCR units are typically used in combination with wet injection or DLN combustion controls.

In the past, sulfur was found to poison the catalyst material. Sulfur-resistant catalyst materials are now available as evidenced by both hot and conventional installations at coal-fired plants. Such improvements have proven effective in resisting sulfur-induced performance degradation with fuel oil in Europe and Japan, where conventional SCR (low temperature) catalyst life in excess of 4 to 6 years has been achieved, while 8 to 10 years catalyst life has been reported with natural gas.

There are several examples of combined cycle SCR systems operating in Florida including:

- Kissimmee Utilities Authority Unit 3. 3.5 ppmvd NO<sub>x</sub> on gas, 12 ppmvd on fuel oil.
- Progress Energy Hines Block 2. 3.5 ppmvd on gas and 12 ppmvd on fuel oil.
- JEA Brandy Branch. 3.5 ppmvd on gas and 12 ppmvd on fuel oil.
- TEC Bayside – seven combustion turbines. 3.5 ppmvd on gas.
- FP&L Manatee Unit 3. 2.5 ppmvd on gas and 10 ppmvd on fuel oil
- FP&L Martin Unit 8. 2.5 ppmvd on gas and 10 ppmvd on fuel oil.

More recently, DEP issued permits for the Treasure Coast Energy Center Unit 1 and FP&L Turkey Point Unit 5 with NO<sub>x</sub> limits of 2.0 ppmvd on gas and 8.0 ppmvd on fuel oil. The Department also required SCR on two recently constructed GE LM6000 simple cycle units at the City of Tallahassee's Hopkins facility.

SCR is a commercially available, demonstrated control technology currently employed on numerous combustion turbine projects permitted with very low NO<sub>x</sub> emissions.

### 3. Applicant's NO<sub>x</sub> BACT Proposal

The applicant eliminated several NO<sub>x</sub> control strategies (including XONON<sup>TM</sup>, Selective Non-Catalytic Reduction, Non-Selective Catalytic Reduction, and SCONOX<sup>TM</sup>), based on either present technical infeasibility or unavailability for the size of CT under review. Therefore, the submitted BACT analysis was limited to DLN combustors for natural gas firing, wet injection for oil firing, and SCR as an add-on control.

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

Historically fuel oil usage at the Oleander site has actually been very low. The oil and gas usage from each of the four existing CTs as reported to FDEP is presented in Table 5. The percentage of allowable fuel use is based on total annual heat input and the 12-month allowable heat input adjusted for four units.

**Table 5. Historical Fuel Use, Oleander Units 1, 2, 3, and 4.**

YEAR	EU ID	Gas			Oil			Total Hrs. Operation
		Annual Rate (mm ft <sup>3</sup> )	Total Heat Input (mmBtu)	% of Allowable	Annual Rate (1000 Gallons)	Total Heat Input (mmBtu)	% of Allowable	
2002	1	1,395	1,295,955		795	105,002		976
	2	994	923,547		2,785	367,620		880
	3	643	597,078		522	68,950		509
	4	592	550,210		394	51,949		486
	All Units	3,624	3,366,789	14.42	4,496	593,521	7.73	2,851
2003	1	2,228	2,069,812		3,260	430,320		1,534
	2	2,267	2,106,043		1,784	235,488		1,697
	3	2,304	2,140,416		847	111,804		1,755
	4	2,065	1,918,385		1,282	169,224		1,600
	All Units	8,864	8,234,656	35.27	7,173	946,836	12.34	6,586
2004	1	1,357	1,261,099		1,545	203,990		1,106
	2	970	900,740		1,136	150,013		862
	3	817	759,337		954	125,941		681
	4	1,041	967,488		620	81,837		861
	All Units	4,186	3,888,664	16.65	4,256	561,781	7.32	3,510
2005	1	1,288	1,196,487		641	84,657		906
	2	607	564,070		1,798	237,337		576
	3	499	463,432		1,428	188,438		467
	4	236	219,309		1,457	192,327		270
	All Units	2,630	2,443,298	10.46	5,324	702,759	9.16	2,219

The column on the far right suggests that typically individual units run less than 1000 hours per year on both fuels combined. The greatest amount of fuel oil use on any unit was during 2003 on Unit 1. By proportioning the heat input for each fuel to total hours of operation, an estimate of approximately 400 hours of fuel oil firing is obtained. A similar calculation for Unit 4 during 2005 suggests approximately 130 hours of fuel oil firing. Overall, the historical use of fuel oil (even before completion of the gas expansion projects and during several hurricane seasons) at the existing units supports the adequacy of a 500 hour limit on fuel oil firing.

Typically distillate fuel oil prices are significantly greater than natural gas prices and the fuels do not typically compete within the power industry in Florida. Distillate fuel oil is only used during short-term supply interruptions and temporary natural gas price dislocations. Within the power industry, natural gas and the higher sulfur residual fuel oil (not allowed for the proposed project) do in fact compete for use in older conventional power plants.

According to a recent (July 2006) U.S. Department of Energy report, “changing market conditions in the United States over the past 7 months have led to dramatic decreases in natural gas prices from the historically high levels prevailing at the beginning of the year.”<sup>6</sup>

According to the same report, "in the near-term, natural gas prices are expected to not be constrained unduly by residual fuel oil prices. Although natural gas prices are projected again to exceed residual fuel oil prices by the 2006-2007 winter, this historical pattern is expected to be reversed by April 2007. However, while the current trend continues, natural gas will be an economically attractive choice for electric utilities, as well as other energy customers." Here the attractiveness is in relative terms.

A similar comparison (to the natural gas/residual fuel oil comparison) between distillate fuel oil and natural gas would be even more pronounced in favor of lower relative natural gas prices. It is reasonable to conclude that natural gas will continue to be more attractive for use in combustion turbines than distillate fuel oil on the basis of price. It is also more favorable on the basis of equipment maintenance.

BACT Determination:

Considering the above discussions, the Department has made the following determination for the control of NO<sub>x</sub> emissions from proposed Unit 5:

- NO<sub>x</sub> emissions while firing natural gas shall be limited to 9.0 ppmvd as BACT achievable by natural gas firing and use of Dry Low NO<sub>x</sub> combustion.
- The continuous limits for NO<sub>x</sub> shall be based on 24-hr block averages.

Incidental Back up Fuel Oil Limits:

Back-up fuel oil use shall be limited to 500 hours per year and NO<sub>x</sub> emissions shall be limited to 42.0 ppmvd (NSPS) achievable by injection of water into the combustors for flame cooling.

**B. SULFUR DIOXIDE (SO<sub>2</sub>)**

The Department determined that BACT for NO<sub>x</sub> is 9 ppmvd and limited the use of back-up low sulfur (0.05% sulfur) fuel oil to 500 hours per year. As a result, the potential emissions of SO<sub>2</sub> for the project decreased by 21.8 tons per year (TPY) from 58.9 to 37.1 TPY which is below the PSD significant threshold at which the BACT and Air Quality Analyses are required.

A BACT determination is not required for SO<sub>2</sub>. The Department will not require use of ultra low sulfur diesel for this project.

The Department will set the following emission limits to insure that emissions from the project will be less than 40 tons per year and not trigger PSD.

- Natural gas containing no more than 1.5 grains of sulfur per 100 standard cubic feet may be fired for up to 3,390 hours per year.
- Unit 5 may be fired using low sulfur diesel fuel oil (0.05 % sulfur) for up to 500 hours of the total 3,390 allowable operating hours.

**C. PARTICULATE MATTER (PM/PM<sub>10</sub>)**

Particulate matter (PM/PM<sub>10</sub>) is emitted from combustion turbines due to incomplete combustion of ash and sulfur present in the fuels. They are minimized by use of clean fuels, with low ash and sulfur contents, and good combustion practices. Clean fuels are a necessity in combustion turbines in order to avoid excessive maintenance due to damaged turbine blades and other components already exposed to very high temperatures and pressures.

The use of DLN combustor technology to maximize combustion efficiency, and the use of low ash, low sulfur fuels is proposed as BACT for PM/PM<sub>10</sub>. According to the applicant, combustion efficiency is projected to be greater than 99 percent with the DLN technology. Additionally, a visible emissions limit of 10 percent opacity has been proposed as a surrogate limit for PM/PM<sub>10</sub>. The Department agrees with the applicant, and the draft BACT standard for PM/PM<sub>10</sub> is the proposed fuel specifications and opacity limit.

**D. SUMMARY OF DEPARTMENT DRAFT BACT DETERMINATIONS**

The Department establishes the following standards as the Best Available Control Technology for the simple cycle combustion turbine Unit 5 at the Oleander Power Project.

**Table 6. Draft BACT Determinations – Oleander Power Project Unit 5**

Pollutant	Fuel	Emission Standard/Limit <sup>c</sup>	Averaging Time	Compliance Method	Basis
NO <sub>x</sub>	Gas	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr block	CEMS	BACT
		62.5 lb/hr	3-hr	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	Gas/Oil	10 % Opacity	6-minute block	Stack Test	BACT
		1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	Gas/Oil	1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	BACT Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the gas turbine represents (BACT) for PM/PM<sub>10</sub> emissions.
- b. The fuel sulfur specifications effectively limit the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from the gas turbine.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

In combination with the annual restriction of hours of operation on oil and gas, the above emissions standards effectively limit annual potential emissions from the combustion turbine to the amounts listed in the table below. The parenthetical numbers reflect the applicant's original proposal.

**Table 7. Project Potential Annual Emissions Estimates after BACT and (as Proposed)**

Pollutant	Project Emissions (TPY)	PSD Significant Emission Rate (TPY)	PSD Review Required?
NO <sub>x</sub>	174.5 (243.1)	40	Yes
SO <sub>2</sub>	37.1 (58.9)	40	No
CO	77 (83.7)	100	No
PM	34.5 (38.5)	25	Yes
PM <sub>10</sub>	34.5 (38.5)	15	Yes
VOC	11.4 (12.9)	40	No
SAM	2.7 (4.5)	7	No
Mercury	0.0006 (0.0012)	0.1	No
Lead	0.0495 (0.0489)	0.6	No
Total Fluorides	Negligible	3	No
Formaldehyde	0.655 (0.672)	NA	NA

**IV. NEW SOURCE PERFORMANCE STANDARDS**

**A. COMBUSTION TURBINES**

New stationary gas turbines are subject to the federal New Source Performance Standards in Subpart KKKK of 40 CFR 60. This federal regulation establishes the following emission standards for new combustion turbines with a heat input at peak load of > 850 mmBtu/hr.

- NO<sub>x</sub> (while firing natural gas) - 15 ppm @ 15 percent O<sub>2</sub> or 0.43 lb/ MWh
- NO<sub>x</sub> (while firing fuels other than natural gas) - 42 ppm at 15 percent O<sub>2</sub> or 1.3 lb/MWh
- SO<sub>2</sub> - 0.90 lb/MWh gross output, or 0.060 lb SO<sub>2</sub>/MMBtu heat input

The Department considers the draft BACT standards more stringent than the NSPS standards. However, the NSPS also has other specific requirements for notification, record keeping, performance testing, and monitoring of operations. An Appendix to the permit will summarize applicable federal requirements.

**V. PERIODS OF EXCESS EMISSIONS**

**A. EXCESS EMISSIONS PROHIBITED**

In accordance with Rule 62-210.700(4), F.A.C., “Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited.” All such preventable emissions shall be included in the compliance determinations for NO<sub>x</sub> emissions.

**B. ALLOWABLE DATA EXCLUSIONS**

In accordance with Rule 62-210.700, F.A.C., “Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.” In addition, the rule states that, “Considering operational variations in types of industrial equipment operations affected by this rule, the Department may adjust maximum and minimum factors to provide reasonable and practical regulatory controls consistent with the public interest.”

Operation of the General Electric Frame 7FA combustion turbine in lean pre-mix mode is achieved at least by 50% of base load conditions. Simple cycle gas turbines are designed for quick startup and operate at high load levels. Operation of the large frame gas turbines is generally automated and malfunctions have been infrequent.

Dry Low NO<sub>x</sub> combustion systems require initial and periodic “tuning” to account for changing ambient conditions, changes in fuels and normal wear and tear on the unit. Tuning involves optimizing NO<sub>x</sub> and CO emissions, and extends the life of the unit components. During tuning, it is possible to have elevated emissions while collecting emission data used in the tuning process. However, the duration of data collection is relatively short, and once tuned, the gas turbine emissions will be minimized. A major tuning session would typically occur after completion of initial construction, a combustor change-out, a major repair or maintenance to a combustor, or other similar event. Other minor tuning sessions are expected to occur periodically on an as needed basis between major tuning sessions.

Based on information from General Electric regarding startup and shutdown, and the information above regarding tuning, the Department establishes the following conditions for excess emissions for the combustion turbine for which a limited amount of data may be excluded from the NO<sub>x</sub> continuous compliance determinations.

- Excess emissions resulting from startup, shutdown, or malfunction shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized.

**TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION**

- For each startup, up to 30 consecutive minutes of excess emissions may be excluded from the continuous compliance determinations.
- For each shutdown, up to 30 consecutive minutes of excess emissions may be excluded from the continuous compliance determinations.
- No more than 2 hours of CEMS data in any 24-hour period shall be excluded from compliance demonstrations due to a malfunction.
- CEMS data collected during initial or other DLN tuning sessions may be excluded from the compliance demonstrations provided that tuning session is performed in accordance with the manufacturer's specifications. Prior to performing any tuning sessions, the permittee shall provide the Compliance Authority with an advance notice detailing the activity and proposed tuning schedule.

**VI. AIR QUALITY IMPACT ANALYSIS**

**A. INTRODUCTION**

The proposed project will increase emissions of two pollutants at levels in excess of PSD significant amounts: PM/PM<sub>10</sub> and NO<sub>x</sub>. PM<sub>10</sub> and NO<sub>x</sub> are criteria pollutants and have national and state ambient air quality standards (AAQS), PSD increments, significant impact levels and de minimis monitoring levels defined for them.

**B. MAJOR STATIONARY SOURCES IN BREVARD COUNTY**

The current largest stationary sources of air pollution in Brevard County are listed below. The information is from annual operating reports submitted to the Department from 2005.

**Table 8. Largest Sources of PM in Brevard County**


<u>Owner</u>	<u>Site Name</u>	<u>Tons per year</u>
Florida Power and Light	Cape Canaveral Plant	778
Reliant Energy Florida	Reliant Indian River Plant	207
<b>Oleander Power Project</b>	<b>Oleander Unit 5 (Applicant Proposal)</b>	<b>39</b>
R.A Connor Paving	R.A Connor Paving	28
Oleander Power Project	Oleander Power Project (Existing)	13

**Table 9. Largest Sources of NO<sub>x</sub> in Brevard County**

<u>Owner</u>	<u>Site Name</u>	<u>Tons per year</u>
Florida Power and Light	Cape Canaveral Plant	4566
Reliant Energy Florida	Reliant Indian River Plant	1295
<b>Oleander Power Project</b>	<b>Oleander Unit 5 (Applicant Proposal)</b>	<b>243</b>
Oleander Power Project	Oleander Power Project (Existing)	128
USAF/Cape Canaveral AFS	Cape Canaveral Air Force Station	60

**C. AIR QUALITY AND MONITORING IN BREVARD COUNTY**

The Florida Department of Environmental Protection Central District currently operates three monitors at two sites measuring PM<sub>2.5</sub> and ozone (O<sub>3</sub>). The 2005 monitoring network is shown in the figure below. Brevard County is expected to have three additional new monitoring sites in the near future. Those monitors will be located at Atlantis Elementary School and Fay Park.



**Figure 10. Brevard County Ambient Air Monitoring Network (Existing)**

The following table summarizes 2005 ambient air quality data from ambient monitoring stations near the OPP project site.

**Table 10. Ambient Air Quality Nearest to Project Site (2005)**

Pollutant	Location	Averaging Period	Ambient Concentration				
			High	2nd High	Mean	Standard	Units
PM <sub>10</sub>	Titusville	24-hour	60	48		150 <sup>a</sup>	ug/m <sup>3</sup>
		Annual			15.5*	50 <sup>b</sup>	ug/m <sup>3</sup>
SO <sub>2</sub>	Orlando	3-hour	11	9		500 <sup>a</sup>	ppb
		24-hour	4	3		100 <sup>a</sup>	ppb
		Annual			1	20 <sup>b</sup>	ppb
NO <sub>2</sub>	Orlando	Annual			9	53 <sup>b</sup>	ppb
CO	Orlando	1-hour	9	8		35 <sup>a</sup>	ppm
		8-hour	5	3		9 <sup>a</sup>	ppm
Ozone	Cocoa Beach	1-hour	0.082	0.081		0.12 <sup>c</sup>	ppm
		8-hour	0.078	0.075		0.08 <sup>c</sup>	ppm

\* The Mean does not satisfy summary criteria due to missing data.

a - Not to be exceeded more than once per year

b - Arithmetic mean

c - Not to be exceeded on more than an average of one day per year over a three-year period.



**D. AIR QUALITY IMPACT ANALYSIS**

**1. Significant Impact Analysis**

Significant Impact Levels (SILs) are defined for PM/PM<sub>10</sub> and NO<sub>x</sub>. A significant impact analysis is performed on each of these pollutants to determine if a project can cause an increase in ground level concentration greater than the SIL for each pollutant.

In order to conduct a significant impact analysis, the applicant uses the proposed project's emissions at worst load conditions as inputs to the model. The model used in this analysis and any required subsequent modeling analyses are described below. The highest predicted short-term concentrations and highest predicted annual averages predicted by this modeling are compared to the appropriate SILs for the PSD Class II Area (everywhere except the designated Class I areas such as the Chassahowitzka National Wildlife Refuge).

The Class II analysis includes a combination of fence line, near-field and far-field receptors chosen for predicting maximum concentrations in the vicinity of the project. The fence line receptors consisted of discrete Cartesian receptors spaced at 50-meter intervals around the facility fence line. The near-field receptor grid consisted of densely spaced Cartesian receptors at 100 meters apart starting at the property line and extending to 3 kilometers. Beyond 3 kilometers, Cartesian receptors with a spacing of 250 meters were used out to 6 kilometers from the facility. From 6 to 15 kilometers, Cartesian receptors with a spacing of 500 meters were used.

If this modeling at worst-load conditions shows ground-level increases less than the SILs, the applicant is exempt from conducting any further modeling. If the modeled concentrations from the project exceed the SILs, then additional modeling including emissions from all major facilities or projects in the region (multi-source modeling) is required to determine the proposed project's impacts compared to the AAQS or PSD increments.

The applicant's initial PM/PM<sub>10</sub> and NO<sub>x</sub> air quality impact analyses for this project indicated that maximum predicted impacts from all pollutants are less than the applicable SILs for the Class II area. These values are tabulated in the table below and compared with existing ambient air quality measurements from the local ambient monitoring network.

**Table 11. Maximum Projected Air Quality Impacts from Oleander Unit 5 for Comparison to the PSD Class II Significant Impact Levels**

Pollutant	Averaging Time	Max Predicted Impact (ug/m <sup>3</sup> )	Significant Impact Level (ug/m <sup>3</sup> )	Baseline Concentrations (ug/m <sup>3</sup> )	Ambient Air Standards (ug/m <sup>3</sup> )	Significant Impact?
PM <sub>10</sub>	Annual	0.1	1	~16	50	NO
	24-Hour	1	5	~60	150	NO
NO <sub>x</sub>	Annual	0.3	1	~17	100	NO

Maximum predicted impacts from the project are much less than the respective AAQS and the baseline concentrations in the area. PM<sub>10</sub> and NO<sub>x</sub> are also less than the respective significant impact levels that would otherwise require more detailed modeling efforts.

The nearest PSD Class I area is the Chassahowitzka National Wildlife Refuge located about 175 km to the west-northwest of the project site. According to the applicant, air quality impacts on this Class I area will be "negligible based on the distance from the project site." The Department provided this information to the U.S. Fish and Wildlife Service and they did not make any comments regarding the Class I Significant Impact Analysis specifically. However, they did state that the "Fish and Wildlife Service does not anticipate that this modification at Oleander will have significant impacts to visibility and Air Quality

Related Values at Chassahowitzka.” This conclusion was based on the use of control technologies, emission rates and distance to the Class I area. Therefore, no modeling was required for the Class I area.

**2. Preconstruction Ambient Monitoring Requirements**

A preconstruction monitoring analysis is done for those pollutants with listed de minimis impact levels. These are levels, which, if exceeded, would require pre-construction ambient monitoring. For this analysis, as was done for the significant impact analysis, the applicant uses the proposed project's emissions at worst load conditions as inputs to the models. As shown in the following table, the maximum predicted impacts for all pollutants with listed de minimis impact levels were less than these levels. Therefore, no pre-construction monitoring is required for those pollutants.

**Table 12. Maximum Air Quality Impacts for Comparison to the De Minimis Ambient Impact Levels.**

Pollutant	Averaging Time	Max Predicted Impact (ug/m <sup>3</sup> )	De Minimis Level (ug/m <sup>3</sup> )	Baseline Concentrations (ug/m <sup>3</sup> )	Impact Greater Than De Minimis?
PM <sub>10</sub>	24-hour	1	10	~60	NO
NOx	Annual	0.3	14	~17	NO

Based on the preceding discussions, the only additional detailed air quality analysis required by the PSD regulations for this project is an analysis of impacts on soils, vegetation, and of past growth-related air quality effects.

**3. Models and Meteorological Data Used in the Foregoing Air Quality Analysis**

**PSD Class II Area:** The AERMOD modeling system was used to evaluate the pollutant emissions from the proposed project in the surrounding Class II Area. AERMOD was approved by the EPA November 2005 and will officially replace the ISCST3 model November 2006. During this “transition” time period from November 2005 to November 2006, both the ISCST and AERMOD model may be used. This “transition” will allow applicants and the Department assimilate AERMOD guidance and procedures.

The AERMOD modeling system incorporates air dispersion based on planetary boundary layer turbulence structure and scaling concepts, including the treatment of both surface and elevated sources, and both simple and complex terrain. AERMOD contains two input data processors, AERMET and AERMAP. AERMAP is the terrain processor and AERMET is the meteorological data processor.

A series of specific model features, recommended by the EPA, are referred to as the regulatory options. The applicant and the Department used the EPA recommended regulatory options. Direction-specific downwash parameters were used for all sources for which downwash was considered. The stacks associated with this project all satisfied the good engineering practice (GEP) stack height criteria.

The modeling submitted with the application included an AERMET file created by the applicant. The meteorological data consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service at Orlando International Airport and Tampa/Ruskin respectively. The 5-year period of meteorological data was from 1996 through 2000. These airport stations were selected for use in the study because they are most representative of the project site.

Along with National Weather Service data, the AERMET processor requires an input of surface parameters based on land use. These characteristics include albedo, surface roughness and bowen ratio. The Department is currently creating a series of AERMET files for National Weather Service stations in Florida. Due to the variations in surface parameter values, by using uniform data sets created by one entity, the Department will ensure continuity from project to project. The data created by the Department for Orlando

International Airport and Tampa/Ruskin was completed after the application for Unit 5 was received. Therefore, the Department modeled Unit 5 with this data to verify the applicant's results.

The Department AERMET data consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service at Orlando International Airport and Tampa/Ruskin respectively. However, the 5-year period of meteorological data was from 1999-2003. The results of the Significant Impact Analysis listed above are indicative of the highest concentrations modeled with both data sets.

In reviewing this permit application, the Department has determined that the application complies with the applicable provisions of the stack height regulations as revised by EPA on July 8, 1985 (50 FR 27892). Portions of the regulations have been remanded by a panel of the U.S. Court of Appeals for the D.C. Circuit in *NRDC v. Thomas*, 838 F. 2d 1224 (D.C. Cir. 1988). Consequently, this permit may be subject to modification should EPA revise the regulation in response to the court decision. This may result in revised emission limitations or may affect other actions taken by the source owners or operators. A more detailed discussion of the required analyses follows.

## **E. ADDITIONAL IMPACTS ANALYSIS**

### **1. Impact on Soils, Vegetation, and Wildlife**

Very low emissions are expected from this natural gas-fired combustion turbine in comparison with conventional power plants generating equal power. Emissions of acid rain and ozone precursors will be very low. The maximum ground-level concentrations predicted to occur for PM<sub>10</sub> and NO<sub>x</sub> as a result of the proposed project, including background concentrations will be less than the respective ambient air quality standards (AAQS).

The project impacts are also less than the significant impact levels for PM<sub>10</sub> and NO<sub>x</sub>, which in-turn, are less than the applicable allowable increments for each pollutant. Because the AAQS are designed to protect both the public health and welfare, and the project impacts are less than significant, it is reasonable to assume the impacts on soils, vegetation, and wildlife will be minimal or insignificant.

### **2. Impact on Visibility and Air Quality Related Values (AQRV) in the Class I Area**

As mentioned previously, the Fish and Wildlife Service does not anticipate that this modification at Oleander will have significant impacts to visibility and Air Quality Related Values (rates of nitrogen deposition) at the Chassahowitzka based on the use of control technologies, emission rates and distance to the Class I area.

### **3. Growth-Related Impacts Due to the Proposed Project**

Increases in the labor force are not expected due to this project. Commercial and residential growth will not occur. Therefore, there will be no adverse air impacts due to growth from this project.

### **4. Growth-Related Air Quality Impacts since 1977**

According to the applicant, population growth in the area of the proposed project, Brevard County, has nearly doubled from 1980 to 2000, growing to 470,000 from approximately 275,000. Brevard growth corresponds with Florida growth. According to the City of Palm Bay, Palm Bay grew in excess of 200% in the 1980's and is the ninth fastest growing Florida city.

Despite the population growth and obvious increases in vehicular traffic, Brevard County has remained in attainment with the Ambient Air Quality Standards. For example, for the pollutant ozone, the Air Quality Index (which reports daily air quality) from 2000-2003 was "Good" for 96.4%, "Moderate" for 3.3% and "Unhealthy for Sensitive Groups" for 0.3% of the days over the 3-year period. There were no "Generally Unhealthy" or "Very Unhealthy" days.

**VII. PRELIMINARY DETERMINATION**

The Department makes a preliminary determination that the proposed project will comply with all applicable state and federal air pollution regulations as conditioned by the Draft Permit. This determination is based on a technical review of the complete PSD application, reasonable assurances provided by the applicant, the draft determinations of Best Available Control Technology (BACT), review of the air quality impact analysis, and the conditions specified in the draft permit.

Cindy Mulkey is the project review engineer and is responsible for preparing the draft permit. She may be contacted at [cindy.mulkey@dep.state.fl.us](mailto:cindy.mulkey@dep.state.fl.us) and 850-921-8968. Debbie Nelson is the project meteorologist responsible for reviewing and validating the air quality impact analysis. She may be contacted at [deborah.nelson@dep.state.fl.us](mailto:deborah.nelson@dep.state.fl.us) and 850-921-9537.

**REFERENCES**

---

- <sup>1</sup> Manual. EPA, Office of Air Quality Planning and Standards, "DRAFT New Source Review Workshop Manual", October 1990.
- <sup>2</sup> Technical Report GE 3695E. Badeer, G. H., General Electric. "GE Aero-derivative Gas Turbines – Design and Operating Features." 2000.
- <sup>3</sup> Technical Report GE Power Systems GER 3568G. Davis, L. B., and S.H. Black, General Electric. "Dry Low NO<sub>x</sub> Combustion Systems for GE Heavy-Duty Gas Turbines." 2000.
- <sup>4</sup> Report. Cubix Corporation. "Exhaust Emissions from a GE PG7241FA Simple Cycle Power Turbine at TEC Polk Power Station." September 2000.
- <sup>5</sup> Report to Legislature. California Environmental Protection Agency, Air Resources Board. Gas-Fired Power Plant NO<sub>x</sub> Emission Controls and Related Environmental Impacts. May 2004.
- <sup>6</sup> Energy Information Administration, Department of Energy, Natural Gas Weekly Update, July 7, 2006.



# Department of Environmental Protection

Jeb Bush  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

## PERMITTEE:

Oleander Power Project, L.P.  
555 Townsend Road  
Cocoa, Florida 32926

### *Authorized Representative:*

James O. Vick, Director Environmental Affairs

Oleander Power Project
Simple Cycle Unit 5
Permit No. PSD-FL-377
Project No. 0090180-003-AC
Expires: June 1, 2008

## PROJECT AND LOCATION

This permit authorizes the construction of a nominal 190 MW simple cycle combustion turbine electrical generator at the existing Oleander Power Project. The facility is located in Cocoa just off Interstate 95 and State Road 520 in Brevard County.

## STATEMENT OF BASIS

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The project was processed in accordance with the requirements of Rule 62-212.400, F.A.C., the preconstruction review program for the Prevention of Significant Deterioration (PSD) of Air Quality. The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

DRAFT

Joseph Kahn, P.E., Acting Director  
Division of Air Resource Management

"More Protection, Less Process"

Printed on recycled paper.

## SECTION I - GENERAL INFORMATION

### FACILITY DESCRIPTION

The regulated emissions units at the existing Oleander Power Project include four nominal 190 MW simple cycle combustion turbines (Units 001 through 004) capable of firing either natural gas or low-sulfur fuel oil (0.05 percent sulfur), and two 1.8 million-gallon fuel oil storage tanks (Units 006 and 007).

### PROJECT DESCRIPTION

The project is for the construction of one additional General Electric PG7241(FA) simple cycle combustion turbine electrical generator (Unit 5) equipped with evaporative cooling, capable of firing natural gas, with a nominal output of 190 megawatts. The project also includes the installation of one 900,000 gallon distillate fuel oil storage tank. Low sulfur fuel oil will be used as a backup fuel to the combustion turbine.

### NEW EMISSIONS UNITS

This permit authorizes construction and installation of the following new emissions units:

EU ID NO.	EMISSION UNIT DESCRIPTION
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.
008	Unit 8- One 900,000 gallon distillate fuel oil storage tank.

### REGULATORY CLASSIFICATION

*Title I, Part C, Clean Air Act (CAA):* The facility is a PSD-major facility pursuant to Rule 62-212, F.A.C.

*Title I, Section 111, CAA:* Unit 5 is subject to the New Source Performance Standards of 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines).

*Title I, Section 112, CAA:* The facility is not a "Major Source" of hazardous air pollutants (HAPs).

*Title IV, CAA:* The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

*Title V, CAA:* The facility is a Title V or "Major Source of air pollution" in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), sulfuric acid mist (SAM), and volatile organic compounds (VOC).

*CAIR:* As an electric generating unit, Unit B may be subject to the Clean Air Interstate Rule pending the finalization of DEP rules.

### PERMITTING AUTHORITY

All documents related to applications for permits to construct, operate or modify an emissions unit shall be submitted to the Bureau of Air Regulation of the Florida Department of Environmental Protection (DEP) at 2600 Blair Stone Road (MS #5505), Tallahassee, Florida 32399-2400. Copies of all such documents shall also be submitted to the Compliance Authority.

## SECTION I - GENERAL INFORMATION

---

### COMPLIANCE AUTHORITY

All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Department of Environmental Protection Central District, 3319 Maguire Boulevard, Suite 232, Orlando, Florida 32803-3767.

### APPENDICES

The following Appendices are attached as part of this permit.

Appendix A	NSPS Subparts A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

### RELEVANT DOCUMENTS:

The documents listed below are not a part of this permit, however they are specifically related to this permitting action and are on file with the Department.

- Application for Air Construction Permit received on May 4, 2006;
- Department's Request for Additional Information dated June 2, 2006;
- Applicant's Response to Request for Additional Information Received July 13, 2006 (complete);
- Department's Intent to Issue and Public Notice Package distributed September 12, 2006;
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.



## SECTION II. ADMINISTRATIVE REQUIREMENTS

1. General Conditions: The permittee shall operate under the attached General Conditions listed in Appendix GC of this permit. General Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
2. Applicable Regulations, Forms and Application Procedures: Unless otherwise indicated in this permit, the construction and operation of the subject emissions unit shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403 of the Florida Statutes (F.S.); Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.); and the Title 40, Parts 51, 52, 60, 63, 72, 73, and 75 of the Code of Federal Regulations (CFR), adopted by reference in Rule 62-204.800, F.A.C. The terms used in this permit have specific meanings as defined in the applicable chapters of the Florida Administrative Code. The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations. [Rules 62-204.800, 62-210.300 and 62-210.900, F.A.C.]
3. Construction and Expiration: Authorization to construct shall expire if construction is not commenced within 18 months after receipt of the permit, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. This provision does not apply to the time period between construction of the approved phases of a phased construction project except that each phase must commence construction within 18 months of the commencement date established by the Department in the permit. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. In conjunction with an extension of the 18-month period to commence or continue construction (or to construct the project in phases), the Department may require the permittee to demonstrate the adequacy of any previous determination of Best Available Control Technology (BACT) for emissions units regulated by the project. For good cause, the permittee may request that this PSD air construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation at least sixty (60) days prior to the expiration of this permit. [Rules 62-4.070(4), 62-4.080, 62-210.300(1), and 62-212.400(12), F.A.C.]
4. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
5. Source Obligation.
  - a. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.
  - b. At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by exceeding its projected actual emissions, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.

[Rule 62-212.400(12), F.A.C.]

## SECTION II. ADMINISTRATIVE REQUIREMENTS

6. Modifications: No emissions unit or facility subject to this permit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. This permit authorizes construction of the referenced facilities. [Chapters 62-210 and 62-212, F.A.C.]
7. Application for Title IV Permit: At least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW, the permittee shall submit an application for a Title IV Acid Rain Permit to the Department's Bureau of Air Regulation in Tallahassee and a copy to the Region 4 Office of the U.S. Environmental Protection Agency in Atlanta, Georgia. [40 CFR 72]
8. Title V Permit: This permit authorizes construction of the permitted emissions unit and initial operation to determine compliance with Department rules. A Title V operation permit is required for regular operation of the permitted emission units. The permittee shall apply for and obtain a Title V operation permit in accordance with Rule 62-213.420, F.A.C. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the Department's Bureau of Air Regulation and a copy to the Compliance Authority. [Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]

DRAFT

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

The specific conditions of this subsection apply to the following emissions unit after construction is complete.

E.U. ID	Emission Unit Description
005	Unit 5 - Consists of one General Electric PG7241 FA gas turbine electrical generator (nominal 190 MW) equipped with evaporative inlet air cooling.

#### APPLICABLE STANDARDS AND REGULATIONS

1. **BACT Determinations:** A determination of the Best Available Control Technology (BACT) was made for nitrogen oxides (NO<sub>x</sub>), and particulate matter (PM/PM<sub>10</sub>). [Rule 62-210.200 (BACT), F.A.C.]
2. **NSPS Requirements:** This unit shall comply with the applicable New Source Performance Standards (NSPS) in 40 CFR 60, including: Subpart A (General Provisions) and Subpart KKKK (Standards of Performance for Stationary Gas Turbines). See Appendix A and Appendix KKKK of this permit. The BACT emissions standards for NO<sub>x</sub> and the fuel sulfur specifications for PM/PM<sub>10</sub> are as stringent as, or more stringent than the NO<sub>x</sub> and SO<sub>2</sub> limits imposed by the applicable NSPS provisions. Some separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(7)(b), F.A.C.; 40 CFR 60, Subparts A and KKKK]

#### EQUIPMENT DESCRIPTION

3. **Combustion Turbine:** The permittee is authorized to install, tune, operate, and maintain one General Electric Model PG7241FA gas turbine-electrical generator set with a nominal generating capacity of 190 MW. The combustion turbine will be equipped with GE's DLN combustor, and an inlet air filtration system with evaporative coolers. The combustion turbine will be designed for operation in simple cycle mode and will have dual-fuel capability. [Application; Design]

#### CONTROL TECHNOLOGY

4. **DLN Combustion:** The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO<sub>x</sub> emissions from the combustion turbine when firing natural gas. Prior to the initial emissions performance tests required for the gas turbine, the DLN combustors and automated gas turbine control system shall be tuned to achieve the permitted levels for NO<sub>x</sub>. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations. [Design; Rule 62-212.400(10)(BACT), F.A.C.]
5. **Wet Injection:** The permittee shall install, operate, and maintain a water injection system to reduce NO<sub>x</sub> emissions from the combustion turbine when firing distillate fuel oil. Prior to the initial emissions performance tests, the water injection system shall be tuned to achieve sufficiently low NO<sub>x</sub> values to meet the NO<sub>x</sub> limits of this permit. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations. [Applicant request; Rule 62-212.400(10)(BACT), F.A.C.]

#### PERFORMANCE REQUIREMENTS

6. **Hours of Operation:** The combustion turbine may operate no more than 3,390 hours per calendar year. Restrictions on individual methods of operation are specified in separate conditions. [Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD), F.A.C.]
7. **Permitted Capacity:** The nominal heat input rate to the combustion turbine is 1,721.9 MMBtu per hour when firing natural gas and 1,919.5 MMBtu per hour when firing fuel oil (based on a compressor inlet air temperature of 59° F, the lower heating value (LHV) of each fuel, and 100% load). Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that

**SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS**

**A. Unit 5 Simple Cycle Combustion Turbine (EU 005)**

correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department.

[Rule 62-210.200(PTE), F.A.C.]

8. **Authorized Fuels:** The combustion turbine shall fire natural gas as the primary fuel, which shall contain no more than 1.5 grains of sulfur per 100 standard cubic feet of natural gas. As a restricted alternate fuel, the combustion turbine may fire low sulfur fuel oil containing no more than 0.05% sulfur by weight. The gas turbine shall fire no more than 500 hours of fuel oil, during any calendar year.  
[Rules 62-210.200(PTE, and BACT) and 62-212.400 (PSD, and PSD Avoidance), F.A.C.]
9. **Simple Cycle, Intermittent Operation:** The turbine shall operate only in simple cycle mode not to exceed the permitted hours of operation allowed by this permit. This restriction is based on the permittee's request, which formed the basis of the PSD applicability and BACT determination and resulted in the emission standards specified in this permit. For any request to convert this unit to combined cycle operation by installing/connecting to heat recovery steam generators, including changes to the fuel quality or quantity related to combined cycle conversion which may cause an increase in short or long-term emissions, the permittee may be required to submit a full PSD permit application complete with a new proposal of the best available control technology as if the unit had never been built.  
[Rules 62-212.400(12) and 62-212.400(BACT), F.A.C.]

**EMISSIONS AND TESTING REQUIREMENTS**

10. **Emission Standards:** Emissions from the combustion turbine shall not exceed the following standards.

Pollutant	Emission Standard <sup>c</sup>	Averaging Time	Compliance Method	Basis
NO <sub>x</sub> (Gas)	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr block	CEMS	BACT
	62.5 lb/hr	3 1-hr runs	Stack Test	
NO <sub>x</sub> (Oil)	42.0 ppmvd @ 15% O <sub>2</sub>	24-hr block	CEMS	NSPS
	336.8 lb/hr	3 1-hr runs	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	10 % Opacity	6-minute block	Visible Emissions Test	BACT
	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	
SO <sub>2</sub> <sup>b</sup>	1.5 gr S/100 SCF of gas/ 0.05 % S fuel oil	N/A	Record Keeping	PSD Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the visible emissions standard shall serve as an indicator of good combustion.
- b. The fuel sulfur specifications and limited hours of operation effectively limit the potential emissions of SO<sub>2</sub> and sulfuric acid mist (SAM) from the gas turbine.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

*{Permitting Note: In combination with the annual restriction on hours of operation, the above emissions standards effectively limit annual potential emissions from the combustion turbine to: 174.5 tons/year of NO<sub>x</sub>, 34.5 tons/year of PM/PM<sub>10</sub>, and 37.1 tons/year of SO<sub>2</sub>.}*

[Rules 62-4.070(3), 62-210.200 (BACT), and 62-212.400(PSD and PSD Avoidance), F.A.C]

11. **Nitrogen Oxides (NO<sub>x</sub>):** Emissions of NO<sub>x</sub> from the CT shall not exceed the following standards on a continuous basis and as measured by the required CEMS for the averaging period specified, and as measured during the required stack tests.

a. *While firing natural gas:*

9 ppmvd @ 15% O<sub>2</sub> on a 24-hr block average (CEMS)

62.5 /lb/hr (3 1-hr run stack test)

b. *While firing fuel oil:*

42.0 ppmvd @ 15% O<sub>2</sub> on a 24-hr block average (CEMS)

336.8 lb/hr (3 1-hr run stack test)

[Rules 62-4.070(3), 62-210.200 (BACT), and 62-212.400(PSD), F.A.C]

12. **Sulfur Dioxide (SO<sub>2</sub>):**

a. *While firing natural gas:* The fuel sulfur specifications, established in condition 8 of this subsection, of 1.5 grains per 100 standard cubic feet effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing natural gas.

b. *While firing fuel oil:* The fuel sulfur specification, established in condition 8 of this subsection, of 0.05 % sulfur by weight effectively limit the potential emissions of SO<sub>2</sub> from the combustion turbine while firing fuel oil.

[Rules 62-4.070(3), and 62-212.400 (PSD Avoidance), F.A.C]

13. **Particulate Matter (PM/PM<sub>10</sub>):** The fuel sulfur specifications, established in condition 8 of this subsection, combined with the efficient combustion, design, and operation of the combustion turbine represent BACT for PM/PM<sub>10</sub> emissions. Compliance with the fuel specifications and visible emissions standard shall serve as indicators of good combustion. Visible emissions shall not exceed 10 % opacity as observed during the required visible emissions tests.

[Rules 62-4.070(3), 62-210.200 (BACT), and 62-212.400(PSD), F.A.C]

14. **Unconfined Particulate Emissions:** During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering, confining, or applying water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

15. **Test Methods:** Required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of NO <sub>x</sub> Emissions (Instrumental).
9	Visual Determination of Opacity
20	Determination of NO <sub>x</sub> , SO <sub>2</sub> , and Diluent Emissions from Stationary Gas Turbines

The methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from

### SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

#### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C. [Rules 62-204.800, F.A.C.; 40 CFR 60, Appendix A]

16. **Testing Requirements:** Initial tests shall be conducted between 90% and 100% of permitted capacity; otherwise, this permit shall be modified to reflect the true maximum capacity as constructed. Subsequent annual tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. Tests shall be conducted for each pollutant while firing each fuel in the CT. For each run during tests for visible emissions, emissions of NO<sub>x</sub> recorded by the CEMS shall also be reported. Data collected from the reference method during the required CEMS quality assurance RATA tests may substitute for annual compliance tests for NO<sub>x</sub>, provided the owner or operator indicates this intent in the submitted test protocol, and obtains approval prior to testing. [Rule 62-297.310(7)(a), F.A.C.; 40 CFR 60.8]
17. **Initial Compliance Demonstration:** Initial compliance stack tests while firing natural gas shall be conducted within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup. Initial testing on fuel oil shall be conducted within 60 days of any fuel oil firing in the CT. In accordance with the test methods specified in this permit, the combustion turbine shall be tested to demonstrate initial compliance with the emission standards for NO<sub>x</sub> and with the visible emissions standard. The permittee shall provide the Compliance Authority with any other initial emissions performance tests conducted to satisfy vendor guarantees. [Rules 62-4.070, 62-297.310(7)(a), F.A.C. and 40 CFR 60.8]
18. **Subsequent Compliance Testing:** Annual compliance tests for NO<sub>x</sub>, and visible emissions shall be conducted during each federal fiscal year (October 1<sup>st</sup>, to September 30<sup>th</sup>). If normal operation on fuel oil is less than 400 hours per year, then subsequent compliance testing on fuel oil is not required for that year. If normal operation on fuel oil exceeds 400 hours per year, the Department shall require compliance testing for NO<sub>x</sub> and visible emissions while firing fuel oil. [Rules 62-4.070, 62-210.200(BACT), and 62-297.310(7)(a)4, F.A.C.]
19. **Continuous Compliance:** Continuous compliance with the permit standard for emissions of NO<sub>x</sub> shall be demonstrated with data collected from the required continuous monitoring system. [Rules 62-4.070, and 62-210.200(BACT), F.A.C.]
20. **Special Compliance Tests:** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

#### EXCESS EMISSIONS

*{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Condition No 10 and 11 of this subsection. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, NESHAP, or Acid Rain programs.}*

21. **Operating Procedures:** The Best Available Control Technology (BACT) determinations established by this permit rely on "good operating practices" to reduce emissions. Therefore, all operators and supervisors shall be properly trained to operate and ensure maintenance of the combustion turbine in accordance with the guidelines and procedures established by the manufacturer. The training shall include good operating practices as well as methods for minimizing excess emissions. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

#### 22. Definitions:

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose.
- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

[Rule 62-210.200(165, 242, and 258), F.A.C.]

23. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]
24. Data Exclusion Procedures for SIP Compliance: As per the procedures in this condition, limited amounts of CEMS emissions data, as specified in condition 25, may be excluded from the corresponding SIP-based compliance demonstration, provided that best operational practices to minimize emissions are adhered to, the duration of data excluded is minimized, and the procedures for data exclusion listed below are followed. As provided by the authority in Rule 62-210.700(5), F.A.C., these conditions replace the provisions in Rule 62-210.700(1), F.A.C.

- a. *Limiting Data Exclusion.* If the compliance calculation using all valid CEMS emission data indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
- b. *Event Driven Exclusion.* There must be an underlying event (startup, shutdown, or malfunction) in order to exclude data. If there is no underlying event, then no data may be excluded.
- c. *Continuous Exclusion.* Data shall be excluded on a continuous basis. Data from discontinuous periods shall not be excluded for the same underlying event.

[Rule 62-210.700 F.A.C.]

25. Allowable Data Exclusions: The following data may be excluded from the corresponding SIP-based compliance demonstration for each of the events listed below in accordance with the Data Exclusion Procedures of condition 24:
- a. *Startup:* Up to 30 minutes of CEMS data may be excluded for each combustion turbine startup. For startups of less than 30 minutes in duration, only those minutes attributable to startup may be excluded.
  - b. *Shutdown:* Up to 30 minutes of CEMS data may be excluded for each combustion turbine shutdown. For shutdowns of less than 30 minutes in duration, only those minutes attributable to shutdown may be excluded.
  - c. *Malfunction:* Up to two hours (in any calendar day) of CEMS data may be excluded due to a documented malfunction. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic email.
  - d. *DLN Tuning:* CEMS data collected during initial or other DLN tuning sessions shall be excluded from the compliance demonstrations provided the tuning session is performed in accordance with the manufacturer's specifications. Prior to performing any tuning session, the permittee shall provide the

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

Compliance Authority with an advance notice of at least one (1) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Design; Rule 62-4.070(3), F.A.C.]

All valid emissions data (including data collected during startup, shutdown, malfunction, and DLN tuning) shall be used to report emissions for the Annual Operating Report.

[Rules 62-210.200(BACT), 62-210.370, and 62-210.700, F.A.C.]

26. **Notification Requirements:** The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate non-compliance for a given averaging period. Within one working day of occurrence, the owner or operator shall notify the Compliance Authority of any malfunction resulting in the exclusion of CEMS data. [Rule 62-4.070, F.A.C.]

#### CONTINUOUS MONITORING REQUIREMENTS

27. **CEM Systems:** Subject to the following, the permittee shall install, calibrate, operate, and maintain a continuous emission monitoring system (CEMS) to measure and record the emissions of NO<sub>x</sub> from the combustion turbine in terms of the applicable standards. The monitoring system shall be installed, and functioning within the required performance specifications by the time of the initial compliance demonstration.

- a. **NO<sub>x</sub> Monitor:** Each NO<sub>x</sub> monitor shall be certified pursuant to the specifications of 40 CFR 75. Quality assurance procedures shall conform to the requirements of 40 CFR 75. The annual and required RATA tests required for the NO<sub>x</sub> monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.
- b. **Diluent Monitor:** The oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) content of the flue gas shall be monitored at the location where NO<sub>x</sub> is monitored to correct the measured emissions rates to 15% oxygen. If a CO<sub>2</sub> monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

[Rules 62-4.070(3), 62-210.200(BACT), F.A.C., and 40 CFR 60, Subpart 75]

28. **Moisture Correction:** If necessary, the owner or operator shall install a system to determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). [Rules 62-4.070(3), 62-210.200(BACT), F.A.C.]

29. **CEMS Data Requirements for BACT Standards:**

*{Permitting Note: The following conditions apply only to the SIP-based NO<sub>x</sub> emissions standards specified in Condition Nos. 10-11 of this section. These requirements cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs. Additional reporting and monitoring may be required by the individual subparts.}*

- a. **Data Collection:** Except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments, emissions shall be monitored and recorded during all operation including startup, shutdown, and malfunction.
- b. **Operating Hours and Operating Days:** An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.



## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

- c. *Valid Hour:* Each CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
- 1) Hours that are **not operating** hours are **not valid** hours.
  - 2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data and the 1-hour block average is not valid.
  - 3) During fuel switching an hour in which fuel oil is fired is attributed towards compliance with the permit standards for oil firing.
- d. *Block 24-Hour Average:* A 24-hour block shall begin at midnight of each operating day and compliance shall be determined by calculating the arithmetic average of all valid hourly averages occurring within that 24-hr block. If a unit operates less than 24 hours during the block, or there are less than 24 valid hourly averages available, the block average shall be the average of all available valid hourly average concentration values during that 24-hr block.
- e. *Missing Data/Bias Adjustments:* If the owner or operator has installed a CEMS to meet the requirements of Part 75, data reported to show compliance with any SIP-based limit shall not include data substituted using the missing data procedures in Subpart D of Part 75, nor shall the data have been bias adjusted according to the procedures of Part 75.
- f. *Data Exclusion:* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, DLN tuning, and fuel switches. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of conditions 24 and 25 of this subsection.
- g. *Availability:* Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly excess emissions report shall be used to demonstrate monitor availability. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Compliance Authority.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]

### CEMS REQUIREMENTS FOR ANNUAL EMISSIONS

30. CEMS Annual Emissions Requirement: The owner or operator shall use data from the NO<sub>x</sub> CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rules 62-210.370(3) and 62-212.300(1)(e), F.A.C.
31. CEMS Data Used for Annual Emissions Calculation: All valid data, as defined in Condition 29, shall be used when calculating annual emissions.
- a) Annual emissions shall include data collected during periods of startup, shutdown, malfunction, and DLN tuning.
  - b) Annual emissions shall not include data from periods of time where the monitor was functioning properly but was unable to collect data while conducting a mandated quality assurance/quality control

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

activity such as calibration error tests, RATAs, calibration gas audits, or RAAs. These periods of time shall be considered "missing data" for purposes of calculating annual emissions.

- c) Annual emissions shall not include data from periods of time when emissions are in excess of the calibrated span of the CEMS. These periods of time shall be considered "missing data" for purposes of calculating annual emissions.
32. Accounting for Missing Data: All valid measurements collected during each hour shall be used to calculate a 1-hr block average that begins at the top of each hour. For each hour, the 1-hr block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, the owner or operator shall account for emissions during that hour using site-specific data to generate a reasonable estimate of the 1-hr block average.
  33. Emissions Calculation: Hourly emissions shall be calculated for each hour as the product of the 1-hr block average and duration of pollutant emissions during that hour. Annual emissions shall be calculated as the sum of all hourly emissions occurring during the year.
  34. Acid Rain CEMS: For CEMS that are also subject to the Acid Rain Program, the data substitution and bias adjustment procedures from 40 CFR Part 75 shall only be applied to data submitted to the U.S. EPA. Annual emissions shall be determined using unadjusted data and using the calculation procedures of the preceding conditions of this permit.

### REPORTING AND RECORD KEEPING REQUIREMENTS

35. Monitoring of Capacity: The permittee shall monitor and record the operating rate of the combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction, and fuel switching). Such monitoring shall be made by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]
36. Monthly Operations Summary: By the fifth calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the combustion turbine for the previous month of operation: fuel consumption, hours of operation, and the updated 12-month rolling totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-210.200(BACT), F.A.C.]
37. Fuel Sulfur Records: The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
  - a. *Natural Gas Sulfur Limit*: Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.
  - b. *Distillate Fuel Oil Sulfur Limit*: Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91, D1552-90, D2622-94, or D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the

## SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

### A. Unit 5 Simple Cycle Combustion Turbine (EU 005)

certified fuel sulfur analysis from the fuel vendor. At the request of the Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]

38. Emissions Performance Test Reports: A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix SC of this permit. [Rule 62-297.310(8), F.A.C.]
39. Excess Emissions Reporting:
- Malfunction Notification*: If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
  - SIP Quarterly Report*: Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of NO<sub>x</sub> emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. A summary of data excluded from SIP compliance calculations should also be provided. In addition, the report shall summarize the NO<sub>x</sub> CEMS system monitor availability for the previous quarter.
  - NSPS Reporting*: Within 30 days following the calendar quarter, the permittee shall submit the written reports required by 40 CFR 60 Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) for the previous quarter or semi-annual period to the Compliance Authority.

*{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}*

[Rules 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C., and 40 CFR 60.7 and 60.4375]

40. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating hours and emissions from this facility in accordance with 62-210.370. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

B. Fuel Oil Storage Tank (EU 008)

ID	Emission Unit Description
008	Unit 8– One 900,000 gallon distillate fuel oil storage tank.

**NSPS APPLICABILITY**

1. NSPS Subpart Kb Applicability: The distillate fuel oil storage tank is not subject to Subpart Kb which applies to storage vessels with a capacity greater than or equal to 75 cubic meters that is used to store volatile organic liquids for which construction, reconstruction, or modification is commenced after July 23, 1984. Tanks with a capacity greater than or equal to 151 cubic meters (40,000 gallons) storing a liquid with a maximum true vapor pressure less than 3.5 kPa, are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb. The fuel oil storage tank (EU 008) has a capacity greater than 151 cubic meters and the vapor pressure of the low sulfur fuel oil is less than 3.5 kPa, therefore NSPS Kb, including the monitoring requirements, does not apply to this unit. [40 CFR 60.110b(a) and (b), and 60.116b(c); Rule 62-204.800(7)(b), F.A.C.]

**EQUIPMENT SPECIFICATIONS**

2. Equipment: The permittee is authorized to install, operate, and maintain one 900,000 gallon distillate fuel oil storage tank designed to provide low sulfur fuel oil to the Unit 5 gas turbine. [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

**PERFORMANCE REQUIREMENTS**

3. Hours of Operation: The hours of operation are not restricted (8760 hours per year). [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

**NOTIFICATION, REPORTING, AND RECORDS**

4. Oil Tank Records: The permittee shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage tank. Records shall be retained for the life of the facility. The permittee shall also keep records sufficient to determine the annual throughput of distillate fuel oil for use in the Annual Operating Report. [Rule 62-204.800(7)(b)16, F.A.C.]
5. Fuel Oil Records: The permittee shall keep readily accessible records showing the maximum true vapor pressure of the stored liquid. If the maximum true vapor pressure of the stored liquid exceeds 3.5 kPa, the Unit 8 storage tank shall be subject to the applicable requirements of Subpart Kb. [62-4.070(3) F.A.C.]

## SECTION IV. APPENDICES

---

### CONTENTS

Appendix A	NSPS Subpart A, Identification of General Provisions
Appendix BD	Final BACT Determinations and Emissions Standards
Appendix GC	General Conditions
Appendix KKKK	NSPS Subpart KKKK Requirements for Stationary Combustion Turbines
Appendix SC	Standard Conditions

## SECTION IV. APPENDIX A

### NSPS SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

---

Emissions units subject to a New Source Performance Standard of 40 CFR 60 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

- § 60.1 Applicability.
- § 60.2 Definitions.
- § 60.3 Units and abbreviations.
- § 60.4 Address.
- § 60.5 Determination of construction or modification.
- § 60.6 Review of plans.
- § 60.7 Notification and Record Keeping.
- § 60.8 Performance Tests.
- § 60.9 Availability of information.
- § 60.10 State Authority.
- § 60.11 Compliance with Standards and Maintenance Requirements.
- § 60.12 Circumvention.
- § 60.13 Monitoring Requirements.
- § 60.14 Modification.
- § 60.15 Reconstruction.
- § 60.16 Priority List.
- § 60.17 Incorporations by Reference.
- § 60.18 General Control Device Requirements.
- § 60.19 General Notification and Reporting Requirements.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.

**SECTION IV. APPENDIX BD**

**FINAL BACT DETERMINATIONS AND EMISSIONS STANDARDS**

The Department establishes the following standards as the Best Available Control Technology for the simple cycle combustion turbine Unit 5 at the Oleander Power Project.

**BACT Determinations – Oleander Power Project Unit 5**

<b>Pollutant</b>	<b>Fuel</b>	<b>Emission Standard/Limit<sup>c</sup></b>	<b>Averaging Time</b>	<b>Compliance Method</b>	<b>Basis</b>
NO <sub>x</sub>	Gas	9.0 ppmvd @ 15% O <sub>2</sub>	24-hr block	CEMS	BACT
		62.5 lb/hr	3-hr	Stack Test	
PM/PM <sub>10</sub> <sup>a</sup>	Gas/Oil	10 % Opacity	6-minute block	STACK TEST	BACT
		1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	RECORD KEEPING	
SO <sub>2</sub> <sup>b</sup>	Gas/Oil	1.5 gr S/100 SCF of gas/0.05 % S Oil	N/A	Record Keeping	BACT Avoidance

- a. The fuel sulfur specifications combined with the efficient combustion design and operation of the gas turbine represents (BACT) for PM/PM10 emissions.
- b. The fuel sulfur specifications effectively limit the potential emissions of SO2 and sulfuric acid mist (SAM) from the gas.
- c. The mass emission rate standards are based on a turbine inlet condition of 59°F and 100 percent full load operation. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

## SECTION IV. APPENDIX GC

### GENERAL CONDITIONS

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
  - a. Have access to and copy and records that must be kept under the conditions of the permit;
  - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
  - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
  - a. A description of and cause of non-compliance; and
  - b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida



## SECTION IV. APPENDIX GC

### GENERAL CONDITIONS

Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
  - a. Determination of Best Available Control Technology (X);
  - b. Determination of Prevention of Significant Deterioration (X);
  - c. Compliance with National Emission Standards for Hazardous Air Pollutants (Not Applicable); and
  - d. Compliance with New Source Performance Standards (X).
14. The permittee shall comply with the following:
  - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - c. Records of monitoring information shall include:
    - 1) The date, exact place, and time of sampling or measurements;
    - 2) The person responsible for performing the sampling or measurements;
    - 3) The dates analyses were performed;
    - 4) The person responsible for performing the analyses;
    - 5) The analytical techniques or methods used; and
    - 6) The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

This subpart establishes emission standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification or reconstruction after February 18, 2005.

#### Applicability

##### § 60.4305 Does this subpart apply to my stationary combustion turbine?

(a) If you are the owner or operator of a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005, your turbine is subject to this subpart. Only heat input to the combustion turbine should be included when determining whether or not this subpart is applicable to your turbine. Any additional heat input to associated heat recovery steam generators (HRSG) or duct burners should not be included when determining your peak heat input. However, this subpart does apply to emissions from any associated HRSG and duct burners.

(b) Stationary combustion turbines regulated under this subpart are exempt from the requirements of subpart GG of this part. Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.

##### § 60.4310 What types of operations are exempt from these standards of performance?

(a) Emergency combustion turbines, as defined in §60.4420(i), are exempt from the nitrogen oxides (NOX) emission limits in §60.4320.

(b) Stationary combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements are exempt from the NOX emission limits in §60.4320 on a case-by-case basis as determined by the Administrator.

(c) Stationary combustion turbines at integrated gasification combined cycle electric utility steam generating units that are subject to subpart Da of this part are exempt from this subpart.

(d) Combustion turbine test cells/stands are exempt from this subpart.

#### Emission Limits

##### § 60.4315 What pollutants are regulated by this subpart?

The pollutants regulated by this subpart are nitrogen oxide (NOX) and sulfur dioxide (SO<sub>2</sub>).

##### § 60.4320 What emission limits must I meet for nitrogen oxides (NOX)?

(a) You must meet the emission limits for NOX specified in Table 1 to this subpart.

(b) If you have two or more turbines that are connected to a single generator, each turbine must meet the emission limits for NOX.

##### § 60.4325 What emission limits must I meet for NOX if my turbine burns both natural gas and distillate oil (or some other combination of fuels)?

You must meet the emission limits specified in Table 1 to this subpart. If your total heat input is greater than or equal to 50 percent natural gas, you must meet the corresponding limit for a natural gas-fired turbine when you are burning that fuel. Similarly, when your total heat input is greater than 50 percent distillate oil and fuels other than natural gas, you must meet the corresponding limit for distillate oil and fuels other than natural gas for the duration of the time that you burn that particular fuel.

##### § 60.4330 What emission limits must I meet for sulfur dioxide (SO<sub>2</sub>)?

(a) If your turbine is located in a continental area, you must comply with either paragraph (a)(1) or (a)(2) of this section. If your turbine is located in Alaska, you do not have to comply with the requirements in paragraph (a) of this section until January 1, 2008.

(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh)) gross output, or

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

(b) If your turbine is located in a noncontinental area or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit, you must comply with one or the other of the following conditions:

(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 780 ng/J (6.2 lb/MWh) gross output, or

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total sulfur with potential sulfur emissions in excess of 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

#### General Compliance Requirements

##### § 60.4333 What are my general requirements for complying with this subpart?

- (a) You must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.
- (b) When an affected unit with heat recovery utilizes a common steam header with one or more combustion turbines, the owner or operator shall either:
- (1) Determine compliance with the applicable NOX emissions limits by measuring the emissions combined with the emissions from the other unit(s) utilizing the common heat recovery unit; or
  - (2) Develop, demonstrate, and provide information satisfactory to the Administrator on methods for apportioning the combined gross energy output from the heat recovery unit for each of the affected combustion turbines. The Administrator may approve such demonstrated substitute methods for apportioning the combined gross energy output measured at the steam turbine whenever the demonstration ensures accurate estimation of emissions related under this part.

#### Monitoring

##### § 60.4335 How do I demonstrate compliance for NOX if I use water or steam injection?

- (a) If you are using water or steam injection to control NOX emissions, you must install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine when burning a fuel that requires water or steam injection for compliance.
- (b) Alternatively, you may use continuous emission monitoring, as follows:
- (1) Install, certify, maintain, and operate a continuous emission monitoring system (CEMS) consisting of a NOX monitor and a diluent gas (oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>)) monitor, to determine the hourly NOX emission rate in parts per million (ppm) or pounds per million British thermal units (lb/MMBtu); and
  - (2) For units complying with the output-based standard, install, calibrate, maintain, and operate a fuel flow meter (or flow meters) to continuously measure the heat input to the affected unit; and
  - (3) For units complying with the output-based standard, install, calibrate, maintain, and operate a watt meter (or meters) to continuously measure the gross electrical output of the unit in megawatt-hours; and
  - (4) For combined heat and power units complying with the output-based standard, install, calibrate, maintain, and operate meters for useful recovered energy flow rate, temperature, and pressure, to continuously measure the total thermal energy output in British thermal units per hour (Btu/h).

##### § 60.4340 How do I demonstrate continuous compliance for NOX if I do not use water or steam injection?

- (a) If you are not using water or steam injection to control NOX emissions, you must perform annual performance tests in accordance with §60.4400 to demonstrate continuous compliance. If the NOX emission result from the performance test is less than or equal to 75 percent of the NOX emission limit for the turbine, you may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NOX emission limit for the turbine, you must resume annual performance tests.
- (b) As an alternative, you may install, calibrate, maintain and operate one of the following continuous monitoring systems:
- (1) Continuous emission monitoring as described in §§60.4335(b) and 60.4345, or
  - (2) Continuous parameter monitoring as follows:
    - (i) For a diffusion flame turbine without add-on selective catalytic reduction (SCR) controls, you must define parameters indicative of the unit's NOX formation characteristics, and you must monitor these parameters continuously.
    - (ii) For any lean premix stationary combustion turbine, you must continuously monitor the appropriate parameters to determine whether the unit is operating in low-NOX mode.
    - (iii) For any turbine that uses SCR to reduce NOX emissions, you must continuously monitor appropriate parameters to verify the proper operation of the emission controls.

SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(iv) For affected units that are also regulated under part 75 of this chapter, with state approval you can monitor the NOX emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19, the requirements of this paragraph (b) may be met by performing the parametric monitoring described in section 2.3 of part 75 appendix E or in §75.19(c)(1)(iv)(H).

§ 60.4345 What are the requirements for the continuous emission monitoring system equipment, if I choose to use this option?

If the option to use a NOX CEMS is chosen:

(a) Each NOX diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NOX diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.

(b) As specified in §60.13(e)(2), during each full unit operating hour, both the NOX monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NOX emission rate for the hour.

(c) Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.

(d) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions.

(e) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

§ 60.4350 How do I use data from the continuous emission monitoring equipment to identify excess emissions?

For purposes of identifying excess emissions:

(a) All CEMS data must be reduced to hourly averages as specified in §60.13(h).

(b) For each unit operating hour in which a valid hourly average, as described in §60.4345(b), is obtained for both NOX and diluent monitors, the data acquisition and handling system must calculate and record the hourly NOX emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of this part. For any hour in which the hourly average O2 concentration exceeds 19.0 percent O2 (or the hourly average CO2 concentration is less than 1.0 percent CO2), a diluent cap value of 19.0 percent O2 or 1.0 percent CO2 (as applicable) may be used in the emission calculations.

(c) Correction of measured NOX concentrations to 15 percent O2 is not allowed.

(d) If you have installed and certified a NOX diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under §60.7(c).

(e) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages.

(f) Calculate the hourly average NOX emission rates, in units of the emission standards under §60.4320, using either ppm for units complying with the concentration limit or the following equation for units complying with the output based standard:

(1) For simple-cycle operation:

E = (NOx)\_b \* (HI)\_b / P (Eq. 1)

Where:

E = hourly NOX emission rate, in lb/MWh, (NOX)h = hourly NOX emission rate, in lb/MMBtu,

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

(HI)<sub>h</sub> = hourly heat input rate to the unit, in MMBtu/h, measured using the fuel flowmeter(s), e.g., calculated using Equation D-15a in appendix D to part 75 of this chapter, and

P = gross energy output of the combustion turbine in MW.

(2) For combined-cycle and combined heat and power complying with the output-based standard, use Equation I of this subpart, except that the gross energy output is calculated as the sum of the total electrical and mechanical energy generated by the combustion turbine, the additional electrical or mechanical energy (if any) generated by the steam turbine following the heat recovery steam generator, and 100 percent of the total useful thermal energy output that is not used to generate additional electricity or mechanical output, expressed in equivalent MW, as in the following equations:

$$P = (Pe)_t + (Pe)_c + Ps + Po \quad (\text{Eq. 2})$$

Where:

P = gross energy output of the stationary combustion turbine system in MW.

(Pe)<sub>t</sub> = electrical or mechanical energy output of the combustion turbine in MW,

(Pe)<sub>c</sub> = electrical or mechanical energy output (if any) of the steam turbine in MW, and

$$Ps = \frac{Q * H}{3.413 \times 10^6 \text{ Btu/MWh}} \quad (\text{Eq. 3})$$

Where:

Ps = useful thermal energy of the steam, measured relative to ISO conditions, not used to generate additional electric or mechanical output, in MW,

Q = measured steam flow rate in lb/h,

H = enthalpy of the steam at measured temperature and pressure relative to ISO conditions, in Btu/lb, and 3.413 x 10<sup>6</sup> = conversion from Btu/h to MW.

Po = other useful heat recovery, measured relative to ISO conditions, not used for steam generation or performance enhancement of the combustion turbine.

(3) For mechanical drive applications complying with the output-based standard, use the following equation:

$$E = \frac{(\text{NO}_x)_m}{\text{BL} * \text{AL}} \quad (\text{Eq. 4})$$

Where:

E = NOX emission rate in lb/MWh,

(NOX)<sub>m</sub> = NOX emission rate in lb/h,

BL = manufacturer's base load rating of turbine, in MW, and

AL = actual load as a percentage of the base load.

(g) For simple cycle units without heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 4-hour rolling average basis, as described in §60.4380(b)(1).

(h) For combined cycle and combined heat and power units with heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 30 unit operating day rolling average basis, as described in §60.4380(b)(1).

**§ 60.4355 How do I establish and document a proper parameter monitoring plan?**

(a) The steam or water to fuel ratio or other parameters that are continuously monitored as described in §§60.4335 and 60.4340 must be monitored during the performance test required under §60.8, to establish acceptable values and ranges. You may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. You must develop and keep onsite a parameter monitoring plan which explains the procedures used to document proper operation of the NOX emission controls. The plan must:

(1) Include the indicators to be monitored and show there is a significant relationship to emissions and proper operation of the NOX emission controls,

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

- (2) Pick ranges (or designated conditions) of the indicators, or describe the process by which such range (or designated condition) will be established,
  - (3) Explain the process you will use to make certain that you obtain data that are representative of the emissions or parameters being monitored (such as detector location, installation specification if applicable),
  - (4) Describe quality assurance and control practices that are adequate to ensure the continuing validity of the data,
  - (5) Describe the frequency of monitoring and the data collection procedures which you will use (e.g., you are using a computerized data acquisition over a number of discrete data points with the average (or maximum value) being used for purposes of determining whether an exceedance has occurred), and
  - (6) Submit justification for the proposed elements of the monitoring. If a proposed performance specification differs from manufacturer recommendation, you must explain the reasons for the differences. You must submit the data supporting the justification, but you may refer to generally available sources of information used to support the justification. You may rely on engineering assessments and other data, provided you demonstrate factors which assure compliance or explain why performance testing is unnecessary to establish indicator ranges. When establishing indicator ranges, you may choose to simplify the process by treating the parameters as if they were correlated. Using this assumption, testing can be divided into two cases:
    - (i) All indicators are significant only on one end of range (e.g., for a thermal incinerator controlling volatile organic compounds (VOC) it is only important to insure a minimum temperature, not a maximum). In this case, you may conduct your study so that each parameter is at the significant limit of its range while you conduct your emissions testing. If the emissions tests show that the source is in compliance at the significant limit of each parameter, then as long as each parameter is within its limit, you are presumed to be in compliance.
    - (ii) Some or all indicators are significant on both ends of the range. In this case, you may conduct your study so that each parameter that is significant at both ends of its range assumes its extreme values in all possible combinations of the extreme values (either single or double) of all of the other parameters. For example, if there were only two parameters, A and B, and A had a range of values while B had only a minimum value, the combinations would be A high with B minimum and A low with B minimum. If both A and B had a range, the combinations would be A high and B high, A low and B low, A high and B low, A low and B high. For the case of four parameters all having a range, there are 16 possible combinations.
- (b) For affected units that are also subject to part 75 of this chapter and that have state approval to use the low mass emissions methodology in §75.19 or the NOX emission measurement methodology in appendix E to part 75, you may meet the requirements of this paragraph by developing and keeping onsite (or at a central location for unmanned facilities) a QA plan, as described in §75.19(e)(5) or in section 2.3 of appendix E to part 75 of this chapter and section 1.3.6 of appendix B to part 75 of this chapter.

#### § 60.4360 How do I determine the total sulfur content of the turbine's combustion fuel?

You must monitor the total sulfur content of the fuel being fired in the turbine, except as provided in §60.4365. The sulfur content of the fuel must be determined using total sulfur methods described in §60.4415. Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than half the applicable limit, ASTM D4084, D4810, D5504, or D6228, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17), which measure the major sulfur compounds, may be used.

#### § 60.4365 How can I be exempted from monitoring the total sulfur content of the fuel?

You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for units located in continental areas and 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for units located in noncontinental areas or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit. You must use one of the following sources of information to make the required demonstration:

- (a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for oil use in continental areas is 0.05 weight percent (500 ppmw) or less and 0.4 weight percent (4,000 ppmw) or less for noncontinental areas, the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet and 140 grains of sulfur or less per 100 standard cubic feet for noncontinental areas, has potential sulfur emissions of less than less than 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas and has potential sulfur emissions of less than less than 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas; or
- (b) Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas or 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

#### § 60.4370 How often must I determine the sulfur content of the fuel?

The frequency of determining the sulfur content of the fuel must be as follows:

(a) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (*i.e.*, flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank).

(b) *Gaseous fuel.* If you elect not to demonstrate sulfur content using options in §60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and recorded once per unit operating day.

(c) *Custom schedules.* Notwithstanding the requirements of paragraph (b) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (c)(1) and (c)(2) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.4330.

(1) The two custom sulfur monitoring schedules set forth in paragraphs (c)(1)(i) through (iv) and in paragraph (c)(2) of this section are acceptable, without prior Administrative approval:

(i) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (c)(1)(ii), (iii), or (iv) of this section, as applicable.

(ii) If none of the 30 daily measurements of the fuel's total sulfur content exceeds half the applicable standard, subsequent sulfur content monitoring may be performed at 12-month intervals. If any of the samples taken at 12-month intervals has a total sulfur content greater than half but less than the applicable limit, follow the procedures in paragraph (c)(1)(iii) of this section. If any measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section.

(iii) If at least one of the 30 daily measurements of the fuel's total sulfur content is greater than half but less than the applicable limit, but none exceeds the applicable limit, then:

(A) Collect and analyze a sample every 30 days for 3 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(B) of this section.

(B) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(C) of this section.

(C) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, continue to monitor at this frequency.

(iv) If a sulfur content measurement exceeds the applicable limit, immediately begin daily monitoring according to paragraph (c)(1)(i) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than the applicable limit, are obtained. At that point, the applicable procedures of paragraph (c)(1)(ii) or (iii) of this section shall be followed.

(2) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(i) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf, no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(ii) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds half the applicable limit, then the minimum required sampling frequency shall be one sample at 12 month intervals.

(iii) If any sample result exceeds half the applicable limit, but none exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iii) of this section.

(iv) If the sulfur content of any of the 720 hourly samples exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iv) of this section.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

#### Reporting

#### § 60.4375 What reports must I submit?

- (a) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.
- (b) For each affected unit that performs annual performance tests in accordance with §60.4340(a), you must submit a written report of the results of each performance test before the close of business on the 60th day following the completion of the performance test.

#### § 60.4380 How are excess emissions and monitor downtime defined for NOX?

For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that must be reported are defined as follows:

- (a) For turbines using water or steam to fuel ratio monitoring:

- (1) An excess emission is any unit operating hour for which the 4-hour rolling average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.4320, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine when a fuel is being burned that requires water or steam injection for NOX control will also be considered an excess emission.
- (2) A period of monitor downtime is any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
- (3) Each report must include the average steam or water to fuel ratio, average fuel consumption, and the combustion turbine load during each excess emission.

- (b) For turbines using continuous emission monitoring, as described in §§60.4335(b) and 60.4345:

- (1) An excess emissions is any unit operating period in which the 4-hour or 30-day rolling average NOX emission rate exceeds the applicable emission limit in §60.4320. For the purposes of this subpart, a "4-hour rolling average NOX emission rate" is the arithmetic average of the average NOX emission rate in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given hour and the three unit operating hour average NOX emission rates immediately preceding that unit operating hour. Calculate the rolling average if a valid NOX emission rate is obtained for at least 3 of the 4 hours. For the purposes of this subpart, a "30-day rolling average NOX emission rate" is the arithmetic average of all hourly NOX emission data in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given day and the twenty-nine unit operating days immediately preceding that unit operating day. A new 30-day average is calculated each unit operating day as the average of all hourly NOX emissions rates for the preceding 30 unit operating days if a valid NOX emission rate is obtained for at least 75 percent of all operating hours.
- (2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NOX concentration, CO<sub>2</sub> or O<sub>2</sub> concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if you will use this information for compliance purposes.
- (3) For operating periods during which multiple emissions standards apply, the applicable standard is the average of the applicable standards during each hour. For hours with multiple emissions standards, the applicable limit for that hour is determined based on the condition that corresponded to the highest emissions standard.

- (c) For turbines required to monitor combustion parameters or parameters that document proper operation of the NOX emission controls:

- (1) An excess emission is a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
- (2) A period of monitor downtime is a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

#### § 60.4385 How are excess emissions and monitoring downtime defined for SO<sub>2</sub>?

If you choose the option to monitor the sulfur content of the fuel, excess emissions and monitoring downtime are defined as follows:

- (a) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the combustion turbine exceeds the applicable limit and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.



SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(b) If the option to sample each delivery of fuel oil has been selected, you must immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.05 weight percent. You must continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and you must evaluate excess emissions according to paragraph (a) of this section. When all of the fuel from the delivery has been burned, you may resume using the as-delivered sampling option.

(c) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

§ 60.4390 What are my reporting requirements if I operate an emergency combustion turbine or a research and development turbine?

(a) If you operate an emergency combustion turbine, you are exempt from the NOX limit and must submit an initial report to the Administrator stating your case.

(b) Combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements may be exempted from the NOX limit on a case-by-case basis as determined by the Administrator. You must petition for the exemption.

§ 60.4395 When must I submit my reports?

All reports required under §60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

Performance Tests

§ 60.4400 How do I conduct the initial and subsequent performance tests, regarding NOX?

(a) You must conduct an initial performance test, as required in §60.8. Subsequent NOX performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).

(1) There are two general methodologies that you may use to conduct the performance tests. For each test run:

(i) Measure the NOX concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NOX emission rate:

E = (1.194 x 10^-7 \* (NOX)c \* Qstd) / P (Eq. 5)

Where:

E = NOX emission rate, in lb/MWh

1.194 x 10^-7 = conversion constant, in lb/dscf-ppm

(NOX)c = average NOX concentration for the run, in ppm

Qstd = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(ii) Measure the NOX and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NOX emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the NOX emission rate in lb/MWh.

(2) Sampling traverse points for NOX and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multihole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NOX and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NOX concentrations is within  $\pm 10$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 5$  ppm or  $\pm 0.5$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average NOX concentration during the stratification test; or

(B) For turbines with a NOX standard greater than 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NOX concentrations is within  $\pm 5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 3$  ppm or  $\pm 0.3$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points; or

(C) For turbines with a NOX standard less than or equal to 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NOX concentrations is within  $\pm 2.5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 1$  ppm or  $\pm 0.15$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

(2) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), you must measure the total NOX emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test.

(3) If water or steam injection is used to control NOX with no additional post-combustion NOX control and you choose to monitor the steam or water to fuel ratio in accordance with §60.4335, then that monitoring system must be operated concurrently with each EPA Method 20 or EPA Method 7E run and must be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.4320 NOX emission limit.

(4) Compliance with the applicable emission limit in §60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NOX emission rate at each tested level meets the applicable emission limit in §60.4320.

(5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in §60.4405) as part of the initial performance test of the affected unit.

(6) The ambient temperature must be greater than 0 °F during the performance test.

#### § 60.4405 How do I perform the initial performance test if I have chosen to install a NOX-diluent CEMS?

If you elect to install and certify a NOX-diluent CEMS under §60.4345, then the initial performance test required under §60.8 may be performed in the following alternative manner:

(a) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs.

(b) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit.

(c) Use the test data both to demonstrate compliance with the applicable NOX emission limit under §60.4320 and to provide the required reference method data for the RATA of the CEMS described under §60.4335.

SECTION IV. APPENDIX KKKK

NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

(d) Compliance with the applicable emission limit in §60.4320 is achieved if the arithmetic average of all of the NOX emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit.

§ 60.4410 How do I establish a valid parameter range if I have chosen to continuously monitor parameters?

If you have chosen to monitor combustion parameters or parameters indicative of proper operation of NOX emission controls in accordance with §60.4340, the appropriate parameters must be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.4355.

§ 60.4415 How do I conduct the initial and subsequent performance tests for sulfur?

(a) You must conduct an initial performance test, as required in §60.8. Subsequent SO2 performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). There are three methodologies that you may use to conduct the performance tests.

(1) If you choose to periodically determine the sulfur content of the fuel combusted in the turbine, a representative fuel sample would be collected following ASTM D5287 (incorporated by reference, see §60.17) for natural gas or ASTM D4177 (incorporated by reference, see §60.17) for oil. Alternatively, for oil, you may follow the procedures for manual pipeline sampling in section 14 of ASTM D4057 (incorporated by reference, see §60.17). The fuel analyses of this section may be performed either by you, a service contractor retained by you, the fuel vendor, or any other qualified agency. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129, or alternatively D1266, D1552, D2622, D4294, or D5453 (all of which are incorporated by reference, see §60.17); or

(ii) For gaseous fuels, ASTM D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17).

(2) Measure the SO2 concentration (in parts per million (ppm)), using EPA Methods 6, 6C, 8, or 20 in appendix A of this part. In addition, the American Society of Mechanical Engineers (ASME) standard, ASME PTC 19-10-1981-Part 10, "Flue and Exhaust Gas Analyses," manual methods for sulfur dioxide (incorporated by reference, see §60.17) can be used instead of EPA Methods 6 or 20. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then use the following equation to calculate the SO2 emission rate:

E = (1.664 x 10^-7 \* (SO2)c \* Qstd) / P (Eq. 6)

Where:

E = SO2 emission rate, in lb/MWh

1.664 x 10^-7 = conversion constant, in lb/dscf-ppm

(SO2)c = average SO2 concentration for the run, in ppm

Qstd = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(3) Measure the SO2 and diluent gas concentrations, using either EPA Methods 6, 6C, or 8 and 3A, or 20 in appendix A of this part. In addition, you may use the manual methods for sulfur dioxide ASME PTC 19-10-1981-Part 10 (incorporated by reference, see §60.17). Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the SO2 emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the SO2 emission rate in lb/MWh.

(b) [Reserved]

Definitions

§ 60.4420 What definitions apply to this subpart?

## SECTION IV. APPENDIX KKKK

### NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES

As used in this subpart, all terms not defined herein will have the meaning given them in the Clean Air Act and in subpart A (General Provisions) of this part.

*Combined cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to generate steam that is only used to create additional power output in a steam turbine.

*Combined heat and power combustion turbine* means any stationary combustion turbine which recovers heat from the exhaust gases to heat water or another medium, generate steam for useful purposes other than additional electric generation, or directly uses the heat in the exhaust gases for a useful purpose.

*Combustion turbine model* means a group of combustion turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

*Combustion turbine test cell/stand* means any apparatus used for testing uninstalled stationary or uninstalled mobile (motive) combustion turbines.

*Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary combustion turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

*Efficiency* means the combustion turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output—based on the higher heating value of the fuel.

*Emergency combustion turbine* means any stationary combustion turbine which operates in an emergency situation. Examples include stationary combustion turbines used to produce power for critical networks or equipment, including power supplied to portions of a facility, when electric power from the local utility is interrupted, or stationary combustion turbines used to pump water in the case of fire or flood, etc. Emergency stationary combustion turbines do not include stationary combustion turbines used as peaking units at electric utilities or stationary combustion turbines at industrial facilities that typically operate at low capacity factors. Emergency combustion turbines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are required by the manufacturer, the vendor, or the insurance company associated with the turbine. Required testing of such units should be minimized, but there is no time limit on the use of emergency combustion turbines.

*Excess emissions* means a specified averaging period over which either (1) the NOX emissions are higher than the applicable emission limit in §60.4320; (2) the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.4330; or (3) the recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

*Gross useful output* means the gross useful work performed by the stationary combustion turbine system. For units using the mechanical energy directly or generating only electricity, the gross useful work performed is the gross electrical or mechanical output from the turbine/generator set. For combined heat and power units, the gross useful work performed is the gross electrical or mechanical output plus the useful thermal output (i.e., thermal energy delivered to a process).

*Heat recovery steam generating unit* means a unit where the hot exhaust gases from the combustion turbine are routed in order to extract heat from the gases and generate steam, for use in a steam turbine or other device that utilizes steam. Heat recovery steam generating units can be used with or without duct burners.

*Integrated gasification combined cycle electric utility steam generating unit* means a coal-fired electric utility steam generating unit that burns a synthetic gas derived from coal in a combined-cycle gas turbine. No solid coal is directly burned in the unit during operation.

*ISO conditions* means 288 Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

*Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture before delivery to the combustor. Mixing may occur before or in the combustion chamber. A lean premixed turbine may operate in diffusion flame mode during operating conditions such as startup and shutdown, extreme ambient temperature, or low or transient load.

*Natural gas* means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1,100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, the Northern Mariana Islands, or offshore platforms.

*Peak load* means 100 percent of the manufacturer's design capacity of the combustion turbine at ISO conditions.

*Regenerative cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine.

*Simple cycle combustion turbine* means any stationary combustion turbine which does not recover heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine, or which does not recover heat from the combustion turbine exhaust gases for purposes other than enhancing the performance of the combustion turbine itself.

*Stationary combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and sub-components comprising any simple cycle stationary combustion turbine, any regenerative/recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.

*Unit operating day* means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

*Useful thermal output* means the thermal energy made available for use in any industrial or commercial process, or used in any heating or cooling application, i.e., total thermal energy made available for processes and applications other than electrical or mechanical generation. Thermal output for this subpart means the energy in recovered thermal output measured against the energy in the thermal output at 15 degrees Celsius and 101.325 kilopascals of pressure.

**Table 1 to Subpart KKKK of Part 60\_Nitrogen Oxide Emission Limits for New Stationary Combustion Turbines**

Combustion turbine type	Combustion turbine heat input at peak load (HHV)	NOX emission standard
New turbine firing natural gas, electric generating	[le] 50 MMBtu/h...	42 ppm at 15. percent O2 or 290 ng/J of useful output (2.3 lb/MWh).
New turbine firing natural gas, mechanical drive.	[le] 50 MMBtu/h...	100 ppm at 15 percent O2 or 690 ng/J of useful output (5.5 lb/MWh).
New turbine firing natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h	25 ppm at 15 percent O2 or 150 ng/J of useful output (1.2 lb/MWh).
New, modified, or reconstructed turbine firing natural gas.	> 850 MMBtu/h...	15 ppm at 15 percent O2 or 54 ng/J of useful output (0.43 lb/MWh)
New turbine firing fuels other than natural gas, electric generating	[le] 50 MMBtu/h...	96 ppm at 15 percent O2 or 700 ng/J of useful output (5.5 lb/MWh).
New turbine firing fuels other than natural gas, mechanical drive.	[le] 50 MMBtu/h...	150 ppm at 15 percent O2 or 1,100 ng/J of useful output (8.7 lb/MWh).
New turbine firing fuels other than natural gas	> 50 MMBtu/h and [le] 850 MMBtu/h	74 ppm at 15 percent O2 or 460 ng/J of useful output (3.6 lb/MWh).
New, modified, or reconstructed turbine firing fuels other than	> 850 MMBtu/h...	42 ppm at 15 percent O2 or 160 ng/J of useful output (1.3

**SECTION IV. APPENDIX KKKK**

**NSPS SUBPART KKKK REQUIREMENTS FOR STATIONARY COMBUSTION TURBINES**

natural gas.		lb/MWh).
Modified or reconstructed turbine.	[le] 50 MMBtu/h...	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
Modified or reconstructed turbine firing natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h.	42 ppm at 15 percent O <sub>2</sub> or 250 ng/J of useful output (2.0 lb/MWh).
Modified or reconstructed turbine firing fuels other than natural gas.	> 50 MMBtu/h and [le] 850 MMBtu/h	96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful output (4.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F.	[le] 30 MW output.	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0°F.	> 30 MW output.	96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful 75 output (4.7 lb/MWh).
Heat recovery units operating independent of the combustion turbine.	All sizes.....	54 ppm at 15 percent O <sub>2</sub> or 110 ng/J of useful output (0.86 lb/MWh).

## SECTION IV. APPENDIX SC

### STANDARD CONDITIONS

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at this facility.

#### EMISSIONS AND CONTROLS

1. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
2. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]
3. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
4. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]
5. Excess Emissions - Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]
6. VOC or OS Emissions: No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]
7. Objectionable Odor Prohibited: No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and 62-210.200(203), F.A.C.]
8. General Visible Emissions: No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20 percent opacity. [Rule 62-296.320(4)(b)1, F.A.C.]
9. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

#### TESTING REQUIREMENTS

10. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20% below the allowable emission limiting standard. [Rule 62-297.310(1), F.A.C.]

## SECTION IV. APPENDIX SC

### STANDARD CONDITIONS

11. **Operating Rate During Testing:** Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2), F.A.C.]
12. **Calculation of Emission Rate:** For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
13. **Test Procedures:** Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.
  - a. **Required Sampling Time.** Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.
  - b. **Minimum Sample Volume.** Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.
  - c. **Calibration of Sampling Equipment.** Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.[Rule 62-297.310(4), F.A.C.]
14. **Determination of Process Variables**
  - a. **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
  - b. **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.[Rule 62-297.310(5), F.A.C.]
15. **Sampling Facilities:** The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C.
16. **Test Notification:** The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator. [Rule 62-297.310(7)(a)9, F.A.C.]
17. **Special Compliance Tests:** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]
18. **Test Reports:** The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide



## SECTION IV. APPENDIX SC

### STANDARD CONDITIONS

sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

- 1) The type, location, and designation of the emissions unit tested.
- 2) The facility at which the emissions unit is located.
- 3) The owner or operator of the emissions unit.
- 4) The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
- 5) The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
- 6) The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
- 7) A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
- 8) The date, starting time and duration of each sampling run.
- 9) The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
- 10) The number of points sampled and configuration and location of the sampling plane.
- 11) For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
- 12) The type, manufacturer and configuration of the sampling equipment used.
- 13) Data related to the required calibration of the test equipment.
- 14) Data on the identification, processing and weights of all filters used.
- 15) Data on the types and amounts of any chemical solutions used.
- 16) Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
- 17) The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
- 18) All measured and calculated data required to be determined by each applicable test procedure for each run.
- 19) The detailed calculations for one run that relate the collected data to the calculated emission rate.
- 20) The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21) A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

#### RECORDS AND REPORTS

19. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2, F.A.C.]
20. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

# Memorandum

# Florida Department of Environmental Protection

---

TO: Trina L. Vielhauer  
THROUGH A.A. Linero *abs*  
FROM: Cindy Mulkey *cem*  
DATE: September 8, 2006  
SUBJECT: Oleander Power Project, L.P. – Simple Cycle Combustion Turbine  
DEP File No. 0090180-003-AC (PSD-FL-377)

Attached is the draft permit package for construction of a 190 megawatt GE 7FA simple cycle combustion turbine (Unit 5) at the existing Oleander Power Project (OPP) owned and operated by affiliates of Southern Company. The rating of 190 MW is the nominal low temperature rating. These units are typically rated at 170 MW at ISO conditions.

The OPP facility is located in Cocoa, Brevard County.

The new construction also includes a 60-foot exhaust stack and a nominal 900,000 gallon fuel oil storage tank. The facility was originally permitted to construct five GE 7FA simple cycle CTs and two fuel oil storage tanks. However, only four of the CTs and the two authorized fuel oil storage tanks were actually constructed.

The new CT will be capable of firing either natural gas or low sulfur fuel oil (0.05 percent sulfur). Unit 5 will be permitted to operate a total of 3,390 hours per year with a maximum of 500 hours of fuel oil firing.

Unit 5 triggered PSD and a BACT determination for NO<sub>x</sub>, and PM/PM10. The BACT for NO<sub>x</sub> is 9 ppmvd. The actual control is by Dry Low NO<sub>x</sub> combustors and use of natural gas. A limit of 42 ppmvd applies while burning backup distillate fuel oil. Control will be achieved by wet injection.

We recommend your approval of the attached package for public distribution.

AAL/cem

Attachments

**Southern Company Services, Inc.**

One Energy Place  
Pensacola, Florida 32520

850.444.6111



*Energy to Serve Your World<sup>SM</sup>*

July 11, 2006

RECEIVED

JUL 13 2006

BUREAU OF AIR REGULATION

Mr. A. Linero  
Program Administrator  
Florida Department of Environmental Protection  
New Source Review Section  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Re: Response to Request for Additional Information  
DEP File No. 0090180-003-AC (PSD-FL-377)  
Proposed Simple-Cycle Combustion Turbine at Oleander Power Project

Dear Mr. Linero:

Oleander Power Project, LP offers the following response to your letter dated June 2, 2006, requesting additional information in support of the referenced Prevention of Significant Deterioration (PSD) permit application. The questions are restated with the corresponding response following each.

- 1. The use of natural gas and low-sulfur distillate fuel oil ( $\leq 0.05$  % S by weight) has been proposed as BACT for  $SO_2$  for this project. What are the "actual" sulfur content values of the distillate fuel oil delivered for use in the existing combustion turbines? Please submit fuel records showing actual sulfur content of the fuel oil delivered to Oleander Power Project for use in Units 1, 2, 3, and 4 for the past four years.*

**Response**

Attached are records showing fuel oil sulfur content for the deliveries of oil that have occurred to Oleander Power Project since June 2005. For operations prior to this date, attached are sulfur content analyses determined during annual performance testing.

2. *Complete replacement of the standard specification (0.05% S) highway diesel fuel by ultra low sulfur (0.0015% sulfur) diesel is required by 2011. Will the now standard fuel (0.05 % S) be available for purchase for non-vehicular use after 2011? Or, is it expected that distillate fuel oil purchased for use in the combustion turbines at Oleander Power Project will eventually meet the ultra low sulfur diesel specification of 0.0015 percent?*

**Response**

It is the applicant's understanding that the currently available diesel fuel, which contains 0.05 percent sulfur by weight, is being phased out and may ultimately be replaced entirely by ultra low sulfur diesel (ULSD) fuel containing 0.0015 percent sulfur by weight. It is anticipated that Oleander Power Project would burn ULSD if it becomes exclusively available.

3. *Although this project is not PSD for VOC, the NO<sub>x</sub> emissions are above 100 TPY. NO<sub>x</sub> is a precursor for ozone formation. Please provide information regarding impacts from this project on the regional ozone. Will this project contribute to an Ambient Air Quality Standard violation for ozone?*

**Response**

The entire state of Florida is currently attainment for the 8-hour ozone standard. The ambient impact analysis results contained in Section 7.0 of our permit application shows that the worst-case nitrogen dioxide (NO<sub>2</sub>) impacts for the modeled years 1996 thru 2000 are significantly below the Significant Impact Level (SIL). This demonstrates that this project will not contribute to an ambient air quality standard violation for ozone.

4. *According to the application, the nearest Class I area is approximately 175 km away. A Class I analysis was not completed for this proposed modification due to this distance. However, the Federal Land Manager suggests that projects within 300 km of a Class I area be analyzed. The Department is awaiting comments regarding the Class I area from the US Fish and Wildlife Service. Please be aware that a Class I analysis may still be required for this application to be sufficient.*

**Response**

Based on an email originally sent to the Department from Catherine Collins with the U.S. Fish and Wildlife Service, it is anticipated that the addition of a 5<sup>th</sup> Unit at Oleander Power Project will not have significant impacts to the visibility and Air Quality Related Values at Chassahowitzka. Therefore, Class I Analysis for this project should not be necessary.

5. *The application states that this project will not have an adverse effect on all soils, vegetation and wildlife in the area since the predicted impacts will be below the Ambient Air Quality Standards. Are there any specifically sensitive or endangered species in the project area that may be particularly sensitive to the project emissions? If so, will these species be adversely impacted?*

**Response**

During April 1998, a listed species survey was conducted at the proposed Oleander Power Project site. Listed species are those plant or animal species currently listed by the U.S. Fish and Wildlife Service (USFWS) as endangered or threatened and by the Florida Department of Agriculture (FDA) as endangered, threatened, or of special concern. Animal species observed during this survey included gray tree squirrel, raccoon, nine-banded armadillo, Florida water snake, mourning dove, downy woodpecker, red-bellied woodpecker, blue jay, blue-gray gnatcatcher, gulf fritillary, silver-spotted skipper, and dragonflies.

None of these listed species were recently found onsite. Much of the wildlife found to use this site are typically well adapted to developed sites and are found throughout Brevard County in both urban and rural locations. Temporary displacement of some species may have occurred during construction activities, but they most likely resumed utilization of the undeveloped areas onsite, especially the enhanced wetlands, soon thereafter.

On March 22, 2006, listed species surveys were also conducted of the subject area under the existing transmission line adjacent to the power plant. No listed species of wildlife were found or expected. Due to the highly disturbed/developed condition of the area, the Florida Fish and Wildlife Conservation Commission (FWC) and USFWS were not directly contacted. No impacts to listed species of wildlife or plants are anticipated as a result of the proposed action. In addition, no significant long-term impacts to nonlisted wildlife species are expected to occur as a result of this project.

6. *Regarding the meteorological data, the modeling indicates that the base elevation of the Orlando International Airport station is at 0 m. Is this correct? Also, the AERMET surface parameters are based on the Orlando International Airport Station land use. While it is correct to use surface parameters for the meteorological site rather than the project site, the meteorological station used should be representative of the land use at the project site. Is the land use in the project area similar to the land use of the airport?*

**Response**

The base elevation listed in the AERMOD input files for the Orlando International Airport (OIA) should have been 28.7 meters in lieu of 0 meters. We have rerun AERMOD using 28.7 meters as the base elevation for OIA and noted no change in the modeling results. The updated AERMOD input and output files can be provided, if required. The AERMET surface parameters were based on the land use surrounding OIA. Comparison of land use maps for the project site with the land use maps used for OIA indicate that the land use surrounding Oleander Power Project is similar to the land use surrounding OIA.

7. *According to the application, the percent land use for the Orlando station is mostly Grassland and Deciduous Forest. For Spring/Summer, the AERMOD User's Guide suggests an Albedo of 0.12-0.18, a Bowen Ratio for Average Moisture of 0.3-0.8, and a Surface Roughness of 0.05-1.3 for Grasslands/ Deciduous Forest. The Albedo and Bowen Ratio surface parameters used in the AERMET file for this project are higher than the ranges given in the User's Guide. Also, the Surface Roughness parameters used in the model are more indicative of the "Forest" rather than "Grassland." Please explain how the surface parameters for this project were determined and please explain why the parameters are generally higher than what guidance suggests.*

**Response**

The surface parameters listed in Table 6-2 of our permit application were based on 12 sectors of land use surrounding OIA for all four seasons. Using the land use surrounding OIA for spring/summer seasons only may be more accurate for projects located in Florida and will result in lower numbers for several of these surface parameters. However, the modeling results presented in Tables 7-4, 7-5, and 7-6 are less than 50 percent of any SIL and are based on worst-case scenarios and conservative assumptions. Therefore, revising the surface parameters for the AERMET files will not result in any significant changes in the modeling results and will not change the modeling conclusions.

8. *Has Oleander Power or its affiliates had any violations (or warning letters) related to any Department or EPA regulations at any of their facilities in Florida and the United States? Have officers of Oleander Power also been officers of other companies that have had violations (or warning letters) of Department regulations at any facilities? Please provide all documentation in relation to any such violations.*


Mr. A. Linero  
Florida Department of Environmental Protection  
July 11, 2006  
Page 5

**Response**

Oleander Power Project, LP ("OPP") is a Florida limited partnership whose general partner is SP Oleander I LLC (a Delaware LLC) and whose limited partner is SP Oleander II LLC (a Delaware LLC). OPP's partners are wholly-owned by Southern Power - Oleander LLC (a Delaware LLC) which is wholly-owned by SPC. The Department should have on record all prior Title V annual statements of compliance for the Oleander Power Project as well as the certifications by the Responsible Official and Professional Engineer for this application. Considering the above mentioned certifications and the applicant's commitment to compliance, the applicant is/has provided reasonable assurance that the facility can and will be operated in accordance with all applicable laws.

Oleander Power Project trusts that this constitutes a timely response to your request for additional information and that your review and the permitting process can continue. If you have any further questions, please call Allison Little at 850-444-6537.

Sincerely,



James O. Vick  
Director Environmental Affairs

cc: Allison Little, Gulf Power  
Brian D. Toth, Southern Company (4 copies)  
Tom W. Davis, ECT

**Little, Allison N.**

**From:** Bill Karl [bkarl@ectinc.com]  
**Sent:** Thursday, June 29, 2006 12:14 PM  
**To:** Toth, Brian D.; Little, Allison N.  
**Subject:** FW: FW: Oleander Unit 5

**From:** Catherine\_Collins@fws.gov [mailto:Catherine\_Collins@fws.gov]  
**Sent:** Thursday, June 29, 2006 11:29 AM  
**To:** Nelson, Deborah  
**Cc:** Meredith\_Bond@fws.gov  
**Subject:** Re: Oleander Unit 5

Debbie --

Thank you for the opportunity to review the Oleander Unit 5 project. As stated in your message below the project is to add Unit 5 which is proposed to be a 190 MW simple cycle CT. The main fuel will be natural gas with low sulfur fuel as a backup. The project is PSD for NOx (243 TPY), PM/PM10 (38.5 TPY) and SO2 (59 TPY). The nearest Class I area is the Chassahowitzka National Wildlife Refuge (NWR), which is about 175km away from Oleander.

Based on the application package (use of control technologies, emission rates and distance to the Class I area), the U.S. Fish and Wildlife Service does not anticipate that this modification at Oleander will have significant impacts to the visibility and Air Quality Related Values at Chassahowitzka.

Should you have further questions or comments, please contact me. Again, thank you for allowing us to review the permit application.

Catherine Collins, Environmental Engineer  
U.S. Fish and Wildlife Service  
Air Quality Branch  
7333 W. Jefferson Ave., Suite 375  
Lakewood, CO 80235-2034  
303-914-3807  
(303) 969-5444 fax  
Catherine\_Collins@fws.gov

"Nelson, Deborah" <Deborah.Nelson@dep.state.fl.us>  
05/17/2006 10:02 AM

To <Catherine\_Collins@fws.gov>

cc

Subject Oleander Unit 5



06/08/2006 THU 14:37 FAX 1 321 783 3496 Coastal Terminals LLC

001/001

**COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA**

DESCRIPTION: STK 8 after "Overseas Philadelphia"  
 SAMPLE DATE: 5-18-06  
 REPORT DATE: 5-19-06  
 TM 0411 LOW SULFUR DIESEL

**CERTIFICATE OF ANALYSIS**

TEST	METHOD	RESULTS
API GRAVITY	D4052	35.2
DENSITY kg/m <sup>3</sup> @ 15 C.	D4052	847.9
SPECIFIC GRAVITY @ 15 C.	D4052	0.8487
FLASHPOINT, PMCC F.	D93	162
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT, F. *	D97	<0
NITROGEN, PPM WT.	D5762	
SULFUR, WT.% **	D4294	0.039
ASH, WT.% *	D482	<0.001
CLOUD POINT, F. *	D2600	17
BTU CALCULATED/GAL.	D4868	138507
CETANE INDEX, CALC.	D976	46.5
DISTILLATION, F.** IBP	D86	361
Recovered 10%	D86	413
Recovered 50%	D86	504
Recovered 90%	D86	613
Final Boiling Point	D86	664
CARBON 10% BTMS, WT. % *	D624	0.10
HAZE RATING	Colonial Pipeline	1
CONDUCTIVITY, pS/m	D2624	72

\*Load Port  
 \*Typicals

BY:  
 Marie F. Calhoon, Chemist

**COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA**

DESCRIPTION: STK 8 after "Overseas Philadelphia"  
SAMPLE DATE: 04-01-06  
REPORT DATE: 04-05-06  
TM 0405 LOW SULFUR DIESEL

*Invoice # 38874  
4/18/06*

**CERTIFICATE OF ANALYSIS**

TEST	METHOD	RESULTS
API GRAVITY	D4052	36.2
DENSITY kg/m3 @ 15 C.	D4052	843.3
SPECIFIC GRAVITY @ 15 C.	D4052	0.8438
FLASHPOINT, PMCC F.	D93	158
BS&W *	D2709	<0.005
VISCOSITY @ 50 C. cSt*	D445	2.40
POUR POINT, F. **	D97	<0
NITROGEN, PPM WT.	D5762	—
SULFUR, WT.% **	D4294	0.028
ASH, WT.% **	D482	<0.001
CLOUD POINT, F. **	D2500	14
BTU CALCULATED/GAL.*	D486B	139010
CETANE INDEX, CALC.**	D976	46.5
DISTILLATION, F.** IBP	D86	349
Recovered 10%	D86	408
Recovered 50%	D86	495
Recovered 90%	D86	605
Final Boiling Point	D86	842
CARBON 10% BTMS, WT.% *	D524	0.10
HAZE RATING	Colonial Pipeline	1

\*\*Load Port

\* Typical

BY:

Marie F. Calhoun, Chemist

BEST AVAILABLE COPY

**Intertek** Caleb Brett

### Report of Analysis

*Vessel / Tank*      **Sample X**      *For Olander / Seminole Power Plant.*  
*Lab Ref No.*      **PE2006 - 16604**  
*Terminal / Port*      **TPSI Cape Canaveral FL**  
*Submitted by*      **Personnel of Royal Petrobrum Florida**  
*Sample Designation*      **Dyed Low Sulphur Diesel**      *W/O Number*      **US4002006001**  
*Date Sampled*      **18-Apr-06**      *Customer Ref No:*  
*Date Submitted*      **26-Apr-06**      *Date Tested*      **26-Apr-06**  
*Samples Tested*      **Running**

<i>Method</i>	<i>Description</i>	<i>Results</i>	<i>Units</i>
D5762	Nitrogen	31	ppm



for Intertek Caleb Brett  
Peter Sicard

*The information contained herein is based on laboratory tests and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.*

Wednesday, April 26, 2006

1881 W State Rd 84, Box 105, Ft Lauderdale, Florida, 33315

Page 1 of 1

06/13/2006 16:34 FAX 321 952 0977  
06/13/2006 16:07 9544624946

ROYAL PETROLEUM  
INTERTEK CB


001  
PAGE 02/02

# Intertek Caleb Brett

## Report of Analysis

<i>Vessel / Tank</i>	<b>Sample B</b>	<b>For Oleander/Seminole</b>
<i>Lab Ref No.</i>	<b>PE2006 - 17250</b>	
<i>Terminal / Port</i>	<b>TPSI Cape Canaveral FL</b>	
<i>Submitted by</i>	<b>Personnel of Royal Petroleum Florida</b>	
<i>Sample Designation</i>	<b>Dyed Low Sulphur Diesel</b>	<i>WO Number</i> <b>US4002006001</b>
<i>Date Sampled</i>	<b>02-Jun-06</b>	<i>Customer Ref No:</i>
<i>Date Submitted</i>	<b>13-Jun-06</b>	<i>Date Tested</i> <b>13-Jun-06</b>
<i>Samples Tested</i>	<b>Running</b>	

<i>Method</i>	<i>Description</i>	<i>Results</i>	<i>Units</i>
D5762	Nitrogen	171	ppm



for Intertek Caleb Brett  
Donovan Yapp

The information contained herein is based on laboratory tests and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.

Tuesday, June 13, 2006

1881 W State Rd 84, Bay 105, Ft Lauderdale, Florida, 33315

Page 1 of 1

**Intertek** Caleb Brett

### Report of Analysis

<i>Vessel / Tank</i>	Sample A	For Oleander/Seminole
<i>Lab Ref No.</i>	PE2006 - 17249	
<i>Terminal / Port</i>	Taft Florida	
<i>Submitted by</i>	Personnel of Royal Petroleum Florida	
<i>Sample Designation</i>	Dyed Low Sulphur Diesel	WO Number US4002006001
<i>Date Sampled</i>	01-Jun-06	Customer Ref No:
<i>Date Submitted</i>	13-Jun-06	Date Tested 13-Jun-06
<i>Samples Tested</i>	Running	

Method	Description	Results	Units
D5762	Nitrogen	18	ppm

  
for Intertek Caleb Brett  
Donovan Yapp

The information contained herein is based on laboratory tests and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.

Tuesday, June 13, 2006

1881 W State Rd 84, Bay 105, Ft Lauderdale, Florida, 33315

Page 1 of 1

# Colonial Pipeline Company

## PRODUCT SPECIFICATIONS SPECIFICATIONS FOR FUNGIBLE LOW SULFUR DIESEL FUEL

3.26.1

Cancels Previous Issues of Grade 74

<u>PRODUCT PROPERTY</u>	<u>ASTM Test Method</u>	<u>Test Results</u>		<u>Note</u>
		<u>Minimum</u>	<u>Maximum</u>	
Gravity API	D287, D1298, D4052	30		
Flash Point, °F Pensky-Martin	D93	130		
Distillation, °F	D86		Report	
50%			640	
90%		540	690	
End Point			2.5	
Color ASTM	D1500, D6045			
Color Visual		Undyed		
Viscosity, cSt @ 40°C (104°F)	D445	1.9	3.4	
Pour Point	D97, D5949, D5950, D5985			2
Cloud Point	D2500, D5771, D5772, D5773			2
Corrosion, 3 hrs. @ 50°C (122°F)	D130		1	
Total Sulfur, wt.%	D1266, D2622, D4294		0.047	3
Cetane Number	D613	40		4
Aromatics (Volume %)	D1319		31.7	
or Aromatics by Cetane Index	D976	40		
Ash, wt.%	D482		0.01	
Carbon Residue: Ramsbottom on 10% Bottom	D524		0.35	
BS&W, vol.%	D2709 or equivalent		< 0.05	
Thermal stability, 90 minutes 150°C Pad rating, DuPont scale			7	
OR				
Oxidation stability, mg/100 ml	D2274		2.5	
Haze rating @ 25°C (77°F)	D4176 Procedure 2		2	
Nace Corrosion	TM0172-2001	B+ (Origin)		

March 2006

\* Denotes Change

74 Grade Page 1 of 2

# Colonial Pipeline Company

## PRODUCT SPECIFICATIONS

3.26.2

## SPECIFICATIONS FOR FUNGIBLE LOW SULFUR DIESEL FUEL

Cancels Previous Issues of Grade 74

### NOTES:

1. Concentration and type of additives permitted only as approved by Colonial.
2. This schedule denotes the fluidity of the distillate at the time and place of origin.

Pour Point – August 1st through March 14th

Maximum: -18°C (0°F)

Pour Point – March 15th through July 31st

Maximum: -12°C (+10°F)

Cloud Point – August 1st through March 14th

Maximum: -9°C (+15°F)

Cloud Point – March 15th through July 31st

Maximum: -7°C (+20°F)

The referee method will be Pour point D97 and Cloud point D2500

3. Test method D2622 or D4294 must be used to certify sulfur content at origin locations.
- \*4. Where cetane number by test method D613 is not available, test method D4737B can be used as an approximation.

March 2006

\* Denotes Change

74 Grade Page 2 of 2

**Intertek** Caleb Brett

Best Available Copy

*Report of Analysis*

<i>Vessel / Tank</i>	<b>Sample B</b>	<b>For Constellation Power</b>
<i>Lab Ref No.</i>	<b>PE2005 - 12510</b>	
<i>Terminal / Port</i>	<b>Taft Florida</b>	
<i>Submitted by</i>	<b>Personnel of Royal Petroleum Florida</b>	
<i>Sample Designation</i>	<b>Low Sulfur Diesel</b>	<b>WO Number B803302005000295</b>
<i>Date Sampled</i>	<b>02-May-05</b>	<b>Customer Ref No:</b>
<i>Date Submitted</i>	<b>06-May-05</b>	<b>Date Tested 06-May-05</b>
<i>Samples Tested</i>	<b>Running</b>	

<i>Method</i>	<i>Description</i>	<i>Results</i>	<i>Units</i>
D5762	Nitrogen	207	ppm



for Intertek  
Donovan Yapp

*The information contained herein is based on laboratory test and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.*



**Intertek**


**Caleb Brett**

**Best Available Copy**

### Report of Analysis

<i>Vessel / Tank</i>	Sample B	OVC Indian River
<i>Lab Ref No.</i>	PE2005 - 13369	
<i>Terminal / Port</i>	Taft Florida	
<i>Submitted by</i>	Personnel of Royal Petroleum Florida	
<i>Sample Designation</i>	Low Sulfur Diesel	WO Number US4002005001
<i>Date Sampled</i>	07-Jul-05	Customer Ref No:
<i>Date Submitted</i>	20-Jul-05	Date Tested 21-Jul-05
<i>Samples Tested</i>	Composite	

Method	Description	Results	Units
D5762	Nitrogen	141	ppm
D240	Heat of Combustion, Gross	19,482.5	BTU/lb
		136,786.6	BTU/gal
		5,745,038.4	BTU/bbl



for Intertek Caleb Brett  
Peter Sicard

*The information contained herein is based on laboratory test and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.*

**Intertek**

**Caleb Brett**

**Best Available Copy**

*Report of Analysis*

Vessel / Tank      **Sample B**  
 Lab Ref No.      **PE2005 - 13343**  
 Terminal / Port    **Coastal Cape Canaveral FL**  
 Submitted by      **Personnel of Royal Petroleum Florida**  
 Sample Designation **Low Sulfur Diesel**      **WO Number US4002005001**  
 Date Sampled      **09-Jul-05**      **Customer Ref No:**  
 Date Submitted    **19-Jul-05**      **Date Tested 19-Jul-05**  
 Samples Tested    **Composite**

Method	Description	Results	Units
D5762	Nitrogen	166	ppm

DY  
 for Intertek Caleb Brett  
 Donovan Yapp

*The information contained herein is based on laboratory test  
 and observations performed by Intertek Caleb Brett. The  
 sample was submitted solely for testing.*

**SGS**Client : FLORIDA POWER & LIGHT  
ROYAL PETROLEUM

File No. : 791319

**CERTIFICATE OF ANALYSIS**

Sample Marked : MARATHON ST 80-11  
Sample Description : LOW SULFUR DIESEL  
FP&L REF # :  
Sampling Location : SGS TAMPA  
In Association with :  
Sample Submitted By : ROYAL PETROLUEM  
Date of Sampling : 14-Jul-05

<u>METHOD</u>	<u>TEST NAME</u>	<u>RESULTS</u>
ASTM D-287	GRAVITY, API @ 60F	32.8
ASTM D-4294	SULFUR	0.0403
ASTM D-3228	NITROGEN	<0.015
ASTM D-240	BTU mmbtus/bbl	5.851

SGS North America Inc.

CHIP LEE  
OPERATIONS SUPERVISOR

SGS North America Inc. | Oil, Gas & Chemicals Services Division  
1212 N 39TH STREET SUITE 330 TAMPA FL 33605 (813)247-3984/(813) 248-6715/www.sgs.com  
Member of the SGS Group (Societe Generale de Surveillance)

COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA

DESCRIPTION: STK 8 AFTER "O.S. Philadelphia"  
SAMPLE DATE: 07-15-05  
REPORT DATE: 07-18-05  
LOW SULFUR DIESEL

CERTIFICATE OF ANALYSIS

TEST	METHOD	RESULTS
API GRAVITY	D4052	36.3
DENSITY kg/m3 @ 15 C.	D4052	842.8
SPECIFIC GRAVITY @ 15 C.	D4052	0.8436
FLASH POINT, PMCC F.	D93	161
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT, F. *	D97	0
NITROGEN, PPM WT.	D5762	—
SULFUR, WT.%**	D4294	0.044
ASH, WT.% *	D482	<0.001
CLOUD POINT, F. *	D2500	10
BTU CALCULATED / GAL.*	D4868	139010
CETANE INDEX, CALC. *	D976	48
DISTILLATION, F.* IBP	D86	354
Recovered 10%	D86	411
Recovered 50%	D86	510
Recovered 90%	D86	622
Final Boiling Point	D86	667
CARBON 10% BTMS, WT. % *	D524	<0.10
HAZE RATING	Colonial Pipeline	1

\*\*\*Load Port  
\*Typicals  
\*\*Calc.

BY:  
Marie F. Calhoun, Chemist

7.0341  
9

## Colonial Pipeline Company

## PRODUCT SPECIFICATIONS

3.31.1

## SPECIFICATIONS FOR FUNGIBLE LOW SULFUR DIESEL FUEL

Cancels Previous Issues of Grade 74

<u>PRODUCT PROPERTY</u>	<u>ASTM Test Method</u>	<u>Test Results</u>		<u>Note</u>
		<u>Minimum</u>	<u>Maximum</u>	
Gravity API	D287, D1298 D4052	30		
Flash Point, °F				
Pensky-Martin	D93	130		
Distillation, °F	D86			
50%			Report	
90%		540	640	
End Point			690	
Color ASTM	D1500, D6045		2.5	
Color Visual		Undyed		
Viscosity, cSt @ 40°C (104°F)	D445	1.9	3.4	
Pour Point	D97, D5949, D5950, D5985			2
Cloud Point	D2500, D5771 D5772, D5773			2
Corrosion, 3 hrs. @ 50°C (122°F)	D130		1	
Total Sulfur, wt. %	D1266, D2622 D4294		0.047	3
Cetane Number	D613	40		4
*Aromatics (Volume %)	D1319		31.7	
*or Cetane Index	D976	42		
Ash, wt. %	D482		0.01	
Carbon Residue: Ramsbottom on 10% Bottom	D524		0.35	
BS&W, vol. %	D2709 or equivalent		< 0.05	
Thermal stability, 90 minutes 150°C Pad rating, DuPont scale			7	
OR				
Oxidation stability, mg/100 ml	D2274		2.5	
Haze rating @ 25°C (77°F)	D4176 Procedure 2		2	
Nace Corrosion	TM0172-2001	B+	(Origin)	
BTU (per gallon)			137,000	
Specific Gravity			0.8762	

February 2004

\* Denotes Change

74 Grade Page 1 of 3



Caleb Brett

**Report of Analysis**

Lab Number: 2005-0475                      Customer Reference:  
Job Number: T5074309                      Our Reference: T507-4309  
Date Sampled: -  
Date Submitted: 07/05/05                      To: Royal Petroleum  
Date Tested: 07/05/05  
Product: **No. 2 Fuel Oil**                      By: Royal Petroleum  
Taken From: Submitted Sample  
Location: Royal Petroleum  
Sample Tested: Submitted Sample

<u>Test</u>	<u>Method</u>	<u>Result</u>	<u>Unit</u>
Nitrogen	ASTM D5762	221	ppm
Gross Heat of Combustion	ASTM D240	19,472	BTU/Lb
		139,381	BTU/Gal

Daniel Thompson  
Intertek Caleb Brett

**Intertek**


**Caleb Brett**

**BEST AVAILABLE COPY**

### Report of Analysis

<i>Vessel / Tank</i>	Sample B	OVC Indian River
<i>Lab Ref No.</i>	PE2005 - 13369	
<i>Terminal / Port</i>	Taft Florida	
<i>Submitted by</i>	Personnel of Royal Petroleum Florida	
<i>Sample Designation</i>	Low Sulfur Diesel	WO Number US4002005001
<i>Date Sampled</i>	07-Jul-05	Customer Ref No:
<i>Date Submitted</i>	20-Jul-05	Date Tested 21-Jul-05
<i>Samples Tested</i>	Composite	

Method	Description	Results	Units
D5762	Nitrogen	141	ppm
D240	Heat of Combustion, Gross	19,482.5	BTU/lb
		136,786.6	BTU/gal
		5,745,038.4	BTU/bbl

  
 for Intertek Caleb Brett  
 Peter Sicard


The information contained herein is based on laboratory test and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.

**Intertek** Caleb Brett

## Report of Analysis

<i>Vessel / Tank</i>	Sample B		
<i>Lab Ref No.</i>	PE2005 - 13343		
<i>Terminal / Port</i>	Coastal Cape Canaveral FL		
<i>Submitted by</i>	Personnel of Royal Petroleum Florida		
<i>Sample Designation</i>	Low Sulfur Diesel	<i>WO Number</i>	US400200S00446
<i>Date Sampled</i>	09-Jul-05	<i>Customer Ref No:</i>	
<i>Date Submitted</i>	19-Jul-05	<i>Date Tested</i>	19-Jul-05
<i>Samples Tested</i>	Composite		

Method	Description	Results	Units
DS762	Nitrogen	166	ppm



for Intertek Caleb Brett  
Peter Sicard

*The information contained herein is based on laboratory test  
and observations performed by Intertek Caleb Brett. The  
sample was submitted solely for testing.*

Saturday, July 23, 2005

2608 S. Federal Hwy, FL Lauderdale, Florida, 33316

Page 1 of 1



**SGS**Client : FLORIDA POWER & LIGHT  
ROYAL PETROLEUM

File No. : 791319

**CERTIFICATE OF ANALYSIS**

Sample Marked : MARATHON<sup>SM</sup> 80-11  
 Sample Description : LOW SULFUR DIESEL  
 FP&L REF # :  
 Sampling Location : SGS TAMPA  
 In Association with :  
 Sample Submitted By : ROYAL PETROLEUM  
 Date of Sampling : 14-Jul-05

<u>METHOD</u>	<u>TEST NAME</u>	<u>RESULTS</u>
ASTM D-287	GRAVITY, API @ 60F	32.8
ASTM D-4294	SULFUR	0.0403
ASTM D-3228	NITROGEN	<0.015
ASTM D-240	BTU mmbtus/bbl	5.851

SGS North America Inc.

CHIP LEE  
OPERATIONS SUPERVISOR

SGS North America Inc. | Oil, Gas & Chemicals Services Division  
 1212 N 38TH STREET SUITE 330 TAMPA FL 33605 t(813)247-3964 f(813) 248-6715 www.sgs.com  
 Member of the SGS Group (Societe Generale de Surveillance)

COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA

DESCRIPTION: STK B AFTER "O.S. Philadelphia"  
SAMPLE DATE: 07-15-05  
REPORT DATE: 07-18-05  
LOW SULFUR DIESEL

CERTIFICATE OF ANALYSIS

TEST	METHOD	RESULTS
API GRAVITY	D4052	36.3
DENSITY kg/m <sup>3</sup> @ 15 C.	D4052	842.8
SPECIFIC GRAVITY @ 15 C.	D4052	0.8435
FLASH POINT, PMCC F.	D93	161
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT, F. *	D97	0
NITROGEN, PPM WT.	D5762	
SULFUR, WT.%**	D4294	0.044
ASH, WT.% *	D482	<0.001
CLOUD POINT, F. *	D2500	10
BTU CALCULATED / GAL.*	D4868	139010
CETANE INDEX, CALC. *	D976	48
DISTILLATION, F.* IBP	D86	354
Recovered 10%	D86	411
Recovered 50%	D86	510
Recovered 90%	D86	622
Final Boiling Point	D86	667
CARBON 10% BTMS, WT. % *	D524	<0.10
HAZE RATING	Colonial Pipeline	1

\*\*\*Load Port

\*Typicals

\*\*Calc.

BY:

Marie F. Calhoon, Chemist

COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA

DESCRIPTION: STK 8 AFTER "O.S. Philadelphia"  
SAMPLE DATE: 07-30-05  
REPORT DATE: 08-01-05  
LOW SULFUR DIESEL

CERTIFICATE OF ANALYSIS

TEST	METHOD	RESULTS
API GRAVITY	D4052	33.8
DENSITY kg/m <sup>3</sup> @ 15 C.	D4052	855.1
SPECIFIC GRAVITY @ 15 C.	D4052	0.8558
FLASH POINT, PMCC F.	D93	151
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT, F. *	D97	0
NITROGEN, PPM WT.	D5762	
SULFUR, WT. % **	D4294	0.038
ASH, WT. % *	D482	<0.001
CLOUD POINT, F. *	D2500	10
BTU CALCULATED / GAL.*	D4868	139010
CETANE INDEX, CALC. **	D976	46
DISTILLATION, F.* IBP	D86	354
Recovered 10%	D86	411
Recovered 50%	D86	510
Recovered 90%	D86	622
Final Boiling Point	D86	667
CARBON 10% BTMS, WT. % *	D524	0.10
HAZE RATING	Colonial Pipeline	1

\*\*Load Port  
\*Typicals  
\*\*Calc.

BY:  
Marie F. Calhoun, Chemist

## Colonial Pipeline Company

PRODUCT SPECIFICATIONS

**SPECIFICATIONS FOR FUNGIBLE LOW SULFUR DIESEL FUEL**

3.27.1

Cancels Previous Issues of Grade 74

<u>PRODUCT PROPERTY</u>	<u>ASTM Test Method</u>	<u>Test Results</u>		<u>Note</u>
		<u>Minimum</u>	<u>Maximum</u>	
Gravity API	D287, D1298, D4052	30		
Flash Point, °F				
Pensky-Martin	D93	130		
Distillation, °F	D86			
50%			Report	
90%		540	640	
End Point			690	
Color ASTM	D1500, D6045		2.5	
Color Visual		Undyed		
Viscosity, cSt @ 40°C (104°F)	D445	1.9	3.4	
Pour Point	D97, D5949, D5950, D5985			2
Cloud Point	D2500, D5771, D5772, D5773			2
Corrosion, 3 hrs. @ 50°C (122°F)	D130		1	
Total Sulfur, wt. %	D1266, D2622, D4294		0.047	3
Cetane Number	D613	40		4
Aromatics (Volume %)	D1319		31.7	
or Aromatics by Cetane Index	D976	40		
Ash, wt. %	D482		0.01	
Carbon Residue: Ramsbottom				
on 10% Bottom	D524		0.35	
BS&W, vol. %	D2709			
	or equivalent		< 0.05	
Thermal stability, 90 minutes				
150°C Pad rating,				
DuPont scale			7	
OR				
Oxidation stability, mg/100 ml	D2274		2.5	
Haze rating @ 25°C (77°F)	D4176			
	Procedure 2		2	
Nace Corrosion	TM0172-2001	B+ (Origin)		

October 2005

\* Denotes Change

74 Grade Page 1 of 2

**Colonial Pipeline Company****PRODUCT SPECIFICATIONS**

3.27.2

**SPECIFICATIONS FOR FUNGIBLE LOW SULFUR DIESEL FUEL**

Cancels Previous Issues of Grade 74

**NOTES:**

1. Concentration and type of additives permitted only as approved by Colonial.

2. This schedule denotes the fluidity of the distillate at the time and place of origin.

Pour Point – August 1st through March 14th

Maximum: -18°C (0°F).

Pour Point – March 15th through July 31st

Maximum: -12°C (+10°F)

Cloud Point – August 1st through March 14th

Maximum: -9°C (+15°F)

Cloud Point – March 15th through July 31st

Maximum: -7°C (+20°F)

The referee method will be Pour point D97 and Cloud point D2500


3. Test method D2622 or D4294 must be used to certify sulfur content at origin locations.

4. Where cetane number by test method D613 is not available, test method D4737 can be used as an approximation.

**Intertek Caleb Brett****Report of Analysis**

<i>Vessel / Tank</i>	Sample A	Oleander Seminole
<i>Lab Ref No.</i>	PE2005 - 13982	
<i>Terminal / Port</i>	K M Orlando FL	
<i>Submitted by</i>	Personnel of Royal Petroleum Florida	
<i>Sample Designation</i>	Low Sulfur Diesel	WO Number US400200500560
<i>Date Sampled</i>	26-Aug-05	Customer Ref No:
<i>Date Submitted</i>	21-Sep-05	Date Tested 21-Sep-05
<i>Samples Tested</i>	Running	

<i>Method</i>	<i>Description</i>	<i>Results</i>	<i>Units</i>
D5762	Nitrogen	117	ppm



for Intertek Caleb Brett  
Peter Sicard

*The information contained herein is based on laboratory test  
and observations performed by Intertek Caleb Brett. The  
sample was submitted solely for testing.*

Wednesday, September 21, 2005

1881 W State Rd 84, Day 105, Ft Lauderdale, Florida, 33315

Page 1 of 1

**Intertek Caleb Brett****Report of Analysis**

Vessel / Tank      **Sample 1**  
 Lab Ref No.        **PE2005 - 13849**  
 Terminal / Port    **Stanton, Royal Petroleum**  
 Submitted by      **Personnel of Marathon Tampa**  
 Sample Designation **Low Sulfur Diesel**  
 Date Sampled      **31-Aug-05**  
 Date Submitted    **08-Sep-05**  
 Samples Tested    **Composite**

P/O Number **US4002005001**  
 Customer Ref No:  
 Date Tested    **08-Sep-05**

<u>Method</u>	<u>Description</u>	<u>Results</u>	<u>Units</u>
D5762	Nitrogen	178	ppm
D240	Heat of Combustion, Gross	19504.2	BTU/lb

for Intertek Caleb Brett

*The information contained herein is based on laboratory test and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.*

Wednesday, September 14, 2005

1881 W State Rd 84, Bay 105, Ft Lauderdale, Florida, 33315

Page 1 of 1



Certificate of Analysis

(Page 1 of 1)

Client : FLORIDA POWER AND LIGHT

Report No : 29879

Product : Low Sulfur Diesel

SGS File No : 791408

LIMS No : 29879 - 80513

Lab No : P340500397

Sample Description :



Sample Label : Low Sulfur Diesel,Rack/Riser #43,Received from TPSI - North on 09/01/05

Tested On : 9/1/2005

METHOD	TEST	RESULT	
ASTM D 287	API Gravity @ 60°F	36.8	°
ASTM D 5453	Total Sulfur by UV Fluorescence	0.0319	Wt-%
ASTM D 5762	Nitrogen by Chemiluminescence	0.01	Wt-%
ASTM D 240	Gross Heat of Combustion	20512	Btu/lb
ASTM D 240	Gross Heat of Combustion	143581	Btu/gal
ASTM D 240	Gross Heat of Combustion	6030381	Btu/bbl
ASTM D 240	Gross Heat of Combustion	6.030	Mbtu/bbl

Supervisor : \_\_\_\_\_

Date : 09/01/2005

David Radtke

IMPORTANT: No person shall accept, use or rely upon SGS-OGC documents or the information contained therein without understanding all of the details of the engagement under which they were issued.

SGS-OGC provides inspection, testing and quality control services pursuant to agreements with our clients (the "Services") in the course of performing such Services. SGS-OGC develops Information ("Information") and generates documents, such as reports and certificates ("Documents"), by its creating, using or relying upon such Information or Documents, the client for whom the Services are performed, and any person who relies upon the Information or Documents, agree to the following terms and conditions:

- 1) Any use after reliance upon the Information or Documents by the client is considered upon the timely payment of all fees. Client agrees to pay the charges of 1.5% per month on all invoices not paid within 30 days, plus collection costs including attorneys' fees.
- 2) SGS-OGC does not, by performing Services or by issuing Documents, contract, obligate, agree to or undertake to discharge any duty or responsibility of the client to any person or entity.
- 3) SGS-OGC is not liable for performing only the Services agreed upon between SGS-OGC and its client. Neither the title of a Document or the nature of a commodity tested nor any particular procedure have been followed or were performed other than as specified in the Documents(s).
- 4) SGS-OGC warrants that it has performed the Services agreed upon with its client in a workmanlike manner. SGS-OGC makes no further warranty of any kind, express or implied.
- 5) Any person accepting, using, or relying upon Information or Documents created in consideration for SGS-OGC performing the Services at the fee charged for the professional liability of SGS-OGC is limited to the extent of the fee paid for the Services or \$25,000, whichever is less.
- 6) SGS-OGC expressly disclaims liability as an insurer or guarantor. Any claim or other pending or future process proceeding from loss or damage from is provided for benefit should apply retroactively.
- 7) Acceptance, use or reliance upon Information or Documents from SGS-OGC shall be governed by the laws of the State where the Services were performed.
- 8) No person is authorized to waive or modify any of the foregoing terms and conditions orally. Any written waiver or modification must be signed by a senior officer of SGS-OGC Houston, TX.
- 9) SGS-OGC hereby objects to any conditions, terms contained in any order or acceptance returned by client.
- 10) All costs associated with compliance with any subpoena(s) for documents, testimony, or for any other purpose relating to work performed by SGS-OGC in accordance with work performed for that Client, shall be paid by Client. Client shall also pay SGS-OGC the hourly standard rates for consulting, development and trial testimony and all expenses related thereto.

Precision parameters apply to the determination of above test results. Also refer to ASTM D 3244-97A2, D 3679-04 and appendix E of D standard methods for analysis and testing for collection of test data to determine compliance with specifications.

Date printed: 09/01/2005

© Copyright SGS-OGC 2004

SGS North America Inc.

Oil, Gas & Chemicals Services 1100 South East 24th Street Fort Lauderdale FL 33316  
TEL: (954) 764-1580 FAX: (954) 764-1561



COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA

DESCRIPTION: STK 8 AFTER "O.S. Philadelphia"

SAMPLE DATE: 09-07-05

REPORT DATE: 09-13-05

LOW SULFUR DIESEL

CERTIFICATE OF ANALYSIS

TEST	METHOD	RESULTS
API GRAVITY	D4052	31.3
DENSITY kg/m3 @ 15 C.	D4052	868.3
SPECIFIC GRAVITY @ 15 C.	D4052	0.8691
FLASH POINT, PMCC F.	D93	162
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT, F. *	D97	0
NITROGEN, PPM WT.	D5762	
SULFUR, WT.%**	D4294	0.045
ASH, WT.% *	D482	<0.001
CLOUD POINT, F. *	D2500	10
BTU CALCULATED / GAL.*	D4868	139010
CETANE INDEX, CALC. *	D976	46
DISTILLATION, F.* IBP	D86	354
Recovered 10%	D86	411
Recovered 50%	D86	510
Recovered 90%	D86	622
Final Boiling Point	D86	667
CARBON 10% BTMS, WT. % *	D524	0.10
HAZE RATING	Colonial Pipeline	1

\*\*\*Load Port

\*Typicals

\*\*Calc.

BY:

Marie F. Calhoun, Chemist

**SGS**

File No. : 791435

**CERTIFICATE OF ANALYSIS**

Sample Marked : MARATHON, TAMPA S/T 80-11  
 Sample Description : LOW SULFUR DIESEL  
 FP&L REF # :  
 Sampling Location : SGS TAMPA  
 In Association with :  
 Sample Submitted By : SGS TAMPA  
 Date of Sampling : 14-Sep-05

<u>METHOD</u>	<u>TEST NAME</u>	<u>RESULTS</u>
ASTM D-287	GRAVITY, API @ 60F	35.5
ASTM D-4294	SULFUR	0.0408
ASTM D-3228	NITROGEN	0.017
ASTM D-240	BTU mmbtus/bbl	5.821

SGS North America Inc.

CHIP LEE  
 OPERATIONS SUPERVISOR

SGS North America Inc. | Oil, Gas & Chemicals Services Division  
 1212 N 39TH STREET SUITE 330 TAMPA FL 33605 (813)247-3984/(813) 248-6715/www.sgs.com  
 Member of the SGS Group (Societe Generale de Surveillance)

**COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA**

DESCRIPTION: STK 8 after "SARA VIKING"

SAMPLE DATE: 10-30-05

REPORT DATE: 10-31-05

TM 0375

LOW SULFUR DIESEL

**CERTIFICATE OF ANALYSIS**

TEST	METHOD	RESULTS
API GRAVITY	D4052	38.7
DENSITY kg/m3 @ 15 C.	D4052	830.4
SPECIFIC GRAVITY @ 15 C.	D4052	0.8312
FLASH POINT , PMCC F.	D93	145
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT , F. *	D97	0
NITROGEN , PPM WT.	D5762	-----
SULFUR , WT.%**	D4294	0.029
ASH , WT.% *	D482	<0.001
CLOUD POINT , F. *	D2500	10
BTU CALCULATED / GAL.*	D4868	139010
CETANE INDEX , CALC.	D976	54
DISTILLATION, F.** IBP	D86	354
Recovered 10%	D86	411
Recovered 50%	D86	514
Recovered 90%	D86	635
Final Boiling Point	D86	673
CARBON 10% BTMS, WT. % *	D524	0.10
HAZE RATING	Colonial Pipeline	1

\*Typicals

\*\*Calculated

BY:

Marie F. Calhoon , Chemist

**Intertek** Caleb Brett


### Report of Analysis

Vessel / Tank	Sample A	Oleander/Seminole Power Plant
Lab Ref No.	PE2005 - 14620	
Terminal / Port	TPSI Cape Canaveral FL	
Submitted by	Personnel of Royal Petroleum Florida	
Sample Designation	Dyed Low Sulphur Diesel	WO Number US400200500707
Date Sampled	03-Oct-05	Customer Ref No:
Date Submitted	22-Nov-05	Date Tested 22-Nov-05
Samples Tested	Composite	

Method	Description	Results	Units
D5762	Nitrogen	42	ppm

  
for Intertek Caleb Brett  
Peter Sicard

The information contained herein is based on laboratory test and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.

<b>SAYBOLT LP</b> <b>6531 Evergreen Ave.</b> <b>Jacksonville, FL 32208</b>  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05843  Job No.:  Sample Date: 07/09/05	  Email: saybolt.ftlauderdale@corelab.com
---	---	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** Unloading Station, Canaveral  
**TIME SAMPLED:** N/A  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:**  
**DATE TESTED:** 11/18-22/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	33.06
DENSITY @ 60 F, Kg/L	D-4052	0.8599
DENSITY @ 80 F, Kg/L	D-4052	0.8524
SULFUR, X RAY, WT PCT	D-4294	0.0404
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 12.73
CARBON, WT PCT	D-5291	** 87.40
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,521
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,360
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	139,675
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	131,368

**NOTES:**

- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.


This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

B. Tolaymat  
Saybolt LP.

\*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<b>SAYBOLT LP</b> <b>6531 Evergreen Ave.</b> <b>Jacksonville, FL 32208</b>  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05841  Job No.:  Sample Date: 07/06/05	 <b>Saybolt</b> <small>A CORE LABORATORIES COMPANY</small> <b>FAST TO THE POINT.</b>  Email: saybolt.ftlauderdale@corelab.com
---	---	---

<b>PRODUCT:</b>	<b># 2 FUEL OIL</b>
<b>SHORE TANK :</b>	<b>Unloading Station, TAFT</b>
<b>TIME SAMPLED:</b>	<b>N/A</b>
<b>TERMINAL:</b>	<b>OLEANDER POWER</b>
<b>SUBMITTED BY:</b>	<b>OLEANDER POWER</b>
<b>CLIENT:</b>	<b>OLEANDER POWER</b>
<b>REFERENCE NO.:</b>	
<b>DATE TESTED:</b>	<b>11/18-22/05</b>

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	32.9
DENSITY @ 60 F, Kg/L	D-4052	0.8606
DENSITY @ 80 F, Kg/L	D-4052	0.8532
SULFUR, X RAY, WT PCT	D-4294	0.0419
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 12.35
CARBON, WT PCT	D-5291	** 87.35
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,514
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,387
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	139,789
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	131,716

**NOTES:**

- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.


This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

B. Tolaymat  
Saybolt LP.

\*\* Carried out in third party laboratory.  
Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<b>SAYBOLT LP</b> <b>6531 Evergreen Ave.</b> <b>Jacksonville, FL 32208</b>  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>		 Email: saybolt.ftlauderdale@corelab.com
	Lab No.:	05842	
	Job No.:		
	Sample Date:	07/06/05	

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** Unloading Station, Tampa  
**TIME SAMPLED:** N/A  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:**  
**DATE TESTED:** 11/18-22/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	38.0
DENSITY @ 60 F, Kg/L	D-4052	0.8348
DENSITY @ 80 F, Kg/L	D-4052	0.8268
SULFUR, X RAY, WT PCT	D-4294	0.0310
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 13.17
CARBON, WT PCT	D-5291	** 87.46
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,681
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,480
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	136,756
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	128,411

**NOTES:**

- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

B. Tolaymat  
 Saybolt LP.

\*\* Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.


Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

**Report of Analysis**

<i>Vessel / Tank</i>	<b>Sample X</b>	<b>Oleander Seminole PowerPlant</b>
<i>Lab Ref No.</i>	<b>PE2005 - 14952</b>	
<i>Terminal / Port</i>	<b>Taft Florida</b>	
<i>Submitted by</i>	<b>Personnel of Royal Petroleum Florida</b>	
<i>Sample Designation</i>	<b>Dyed Low Sulphur Diesel</b>	<i>WO Number</i> <b>US400200500789</b>
<i>Date Sampled</i>	<b>18-Dec-05</b>	<i>Customer Ref No:</i>
<i>Date Submitted</i>	<b>22-Dec-05</b>	<i>Date Tested</i> <b>22-Dec-05</b>
<i>Samples Tested</i>	<b>Running</b>	

<i>Method</i>	<i>Description</i>	<i>Results</i>	<i>Units</i>
D5762	Nitrogen	158	ppm



for Intertek Caleb Brett  
Peter Sicard

*The information contained herein is based on laboratory test and observations performed by Intertek Caleb Brett. The sample was submitted solely for testing.*



COASTAL FUELS MARKETING, INC.  
CAPE CANAVERAL FLORIDA

DESCRIPTION: STK 8 after "Prodravine"

SAMPLE DATE: 12-25-05

REPORT DATE: 12-27-05

TM 0385

LOW SULFUR DIESEL

## CERTIFICATE OF ANALYSIS

TEST	METHOD	RESULTS
API GRAVITY	D4052	36.2
DENSITY kg/m3 @ 15 C.	D4052	842.8
SPECIFIC GRAVITY @ 15 C.	D4052	0.8437
FLASH POINT , PMCC F.	D93	149
BS&W *	D2709	<0.005
VISCOSITY @ 50 C, cSt*	D445	2.40
POUR POINT , F. ***	D97	-8
NITROGEN , PPM WT.	D5762	—
SULFUR , WT.%***	D4294	<u>0.034</u>
ASH , WT.% *	D482	<0.001
CLOUD POINT , F. *	D2500	13
BTU CALCULATED / GAL.*	D4868	<u>139010</u>
CETANE INDEX , CALC. **	D976	49
DISTILLATION, F.** IBP	D86	356
Recovered 10%	D86	427
Recovered 50%	D86	516
Recovered 90%	D86	619
Final Bolling Point	D88	668
CARBON 10% BTMS, WT. % *	D524	0.10
HAZE RATING	Colonial Pipeline	1

\*Typicals

\*\*Calculated

\*\*\*Load Port

BY:

Marie F. Calhoon , Chemist

**SAYBOLT LP**

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-15

CUSTOMER  
REF. NO(S):

**LABORATORY ANALYSIS REPORT**

DATE: 6/04/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIG SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 1  
SAMPLE TAKEN @ 11:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.


**ANALYSIS**

PAGE 1 OF 1

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8389
DENSITY @ 80°F, Kg/L	D-4052	0.8312
SULFUR, X-RAY, WT PCT	D-4294	0.0321
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.06
CARBON, WT PCT	D-5291	86.84
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19622
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18431
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137197

\*SAMPLING DATE:5/30/02

MEMBERS ASTM-API-SAE

  
**DREYFUS BROWN**  
SAYBOLT LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

JUN 05 2:00:21 PM '02 HR SHIBULLI 504 024 0011 IN J021000004 F.007.00

Best Available Copy

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-16

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 6/04/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIG SULFUR DIESEL
- Identifying Marks:  
UNIT # 1  
SAMPLE TAKEN @ 11:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
 DENSITY @ 60°F, Kg/L  
 DENSITY @ 80°F, Kg/L  
 SULFUR, X-RAY, WT PCT  
 SODIUM, PPM  
 VANADIUM, PPM  
 POTASSIUM, PPM  
 LEAD, PPM  
 CALCIUM, PPM  
 MAGNESIUM, PPM  
 HYDROGEN, WT PCT  
 CARBON, WT PCT  
 NITROGEN, WT PCT  
 HEAT OF COMBUSTION, GROSS, BTU/LB  
 HEAT OF COMBUSTION, NET, BTU/LB  
 HEAT OF COMBUSTION, GROSS, BTU/GAL

METHOD

D-4052  
 D-4052  
 D-4052  
 D-4294  
 SOL/DIL  
 SOL/DIL  
 SOL/DIL  
 SOL/DIL  
 SOL/DIL  
 D-5291  
 D-5291  
 D-5291  
 D-240  
 D-240  
 D-240

RESULT

37.0  
 0.8389  
 0.8312  
 0.0323  
 <0.1  
 <0.1  
 <0.1  
 <0.1  
 <0.1  
 <0.1  
 13.13  
 86.72  
 0.02  
 19608  
 18410  
 137099

\*SAMPLING DATE:5/30/02

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

DREYFUS BROWN  
SAYBOLT LP.

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-17

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 6/04/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIG SULFUR DIESEL
- Identifying Marks:  
UNIT # 1  
SAMPLE TAKEN @ 12:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.


ANALYSIS

PAGE 1 OF 1

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8390
DENSITY @ 80°F, Kg/L	D-4052	0.8313
SULFUR, X-RAY, WT PCT	D-4294	0.0326
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.10
CARBON, WT PCT	D-5291	86.63
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19612
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18417
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137127

\*SAMPLING DATE:5/30/02

MEMBERS ASTM-AP- SAE

  
DREYFUS BROWN  
SAYBOLT LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

JUN 05 2002 17:56 FR SHILALI  
554 524 2377 10 15210554054  
7.04.02

**SAYBOLT LP**

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-18

CUSTOMER  
REF. NO(S):

**LABORATORY ANALYSIS REPORT**

DATE: 6/04/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIG SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 1  
SAMPLE TAKEN @ 12:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

**ANALYSIS**

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

METHOD


D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

RESULT

37.0  
0.8389  
0.8311  
0.0318  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
13.30  
86.67  
0.02  
19576  
18363  
136875

\*SAMPLING DATE:5/30/02

MEMBERS ASTM-API-SAE

  
DREYFUS BROWN  
SAYBOLT LP.

**SAYBOLT LP**

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-19

CUSTOMER  
REF. NO(S):

**LABORATORY ANALYSIS REPORT**

DATE: 6/04/02

INVOICE NO:

JUN 05 2002 17:57 FR SAYBOLT  
954 524 2377 TO 13216394554  
P. 06/06

**DESCRIPTION**

- **Sample designated as:**  
HIG SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 1  
SAMPLE TAKEN @ 13:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
1457 DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

**ANALYSIS**

PAGE 1 OF 1

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8389
DENSITY @ 80°F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0324
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.05
CARBON, WT PCT	D-5291	86.85
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19594
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18403
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137001

\*SAMPLING DATE:5/30/02

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

**DREYFUS BROWN**  
SAYBOLT LP.

Best Available Copy

LABORATORY ANALYSIS REPORT

SAYBOLT LP  
6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-20

CUSTOMER  
REF. NO(S):

DATE: 6/04/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIG SULFUR DIESEL
- Identifying Marks:  
UNIT # 1  
SAMPLE TAKEN @ 13:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

PAGE 1 OF 1

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8389
DENSITY @ 80°F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0325
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.10
CARBON, WT PCT	D-5291	86.83
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19567
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18372
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	136812

\* SAMPLING DATE: 5/30/02

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

DREYFUS BROWN  
SAYBOLT LP.

Best Available Copy

SAYBOLT LP  
6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-21

LABORATORY ANALYSIS REPORT

CUSTOMER  
REF. NO(S):

DATE: 6/04/02

INVOICE NO:

**DESCRIPTION**

- ▣ Sample designated as:  
HIG SULFUR DIESEL
- ▣ Identifying Marks:  
UNIT # 1  
SAMPLE TAKEN @ 14:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- ▣ Submitted by:  
OLEANDER POWER PROJECT
- ▣ Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHER NOTICE IS REQUESTED IN WRITING.

**NOTES**

- ▣ This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- ▣ Results were based on analysis made at the time samples were received at the laboratory.
- ▣ Sample nomenclature is designated by the customer.

PAGE 1 OF 1

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8389
DENSITY @ 80°F, Kg/L	D-4052	0.8312
SULFUR, X-RAY, WT PCT	D-4294	0.0327
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.11
CARBON, WT PCT	D-5291	86.77
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19603
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18407
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137064

\*SAMPLING DATE:5/30/02

MEMBERS ASTM-API-SAE

DREYFUS BROWN  
SAYBOLT LP.

\*\* TOTAL PAGE.08 \*\*

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.



OLEANDER POWER PROJECT LTD  
 555 TOWNSEND ROAD  
 32926 COCOA FL  
 United States

SAYBOLT LP  
 2610 S. Federal Hwy  
 Ft. Lauderdale, FL 33316  
 Phone (954) 524-8772 Fax: (954) 524-2377  
 E-mail Saybolt.flauderdale@corelab.com



2006

All manual gauges, temperatures and samples in accordance with API/MPMS, Chapter 5.14, Chapter 9, Chapter 8.1, Chapter 8.2. Volume corrections for temperature are based on ASTM D1250 or tables supplied to us by the customer or the terminal. Saybolt can assume no responsibility for the accuracy of these tables

Reference  
 Report no. 13062/1535 .01.L/06  
 Report date 28/Apr/2006  
 Location Cocoa, Florida, Oleander Power Plant

CERTIFICATE OF ANALYSIS

Sample submitted as #2 Fuel Oil  
 Received Sampled by Saybolt Inspector  
 Marked UNIT#2 RUN#1 AT 1350 Hr  
 Date of sampling 13/Apr/2006  
 Testing completed 27/Apr/2006 Time: 1600  
 Sealed N/A  
 Lab number 06179

Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity	API Gravity at 60°F		ASTM D 4052		35.2
Density	Density at 60°F	Kg/l	ASTM D 4053		0.8483
Density	Density at 80°F	Kg/l	ASTM D 4054		0.8401
Sulfur content	Sulfur content, X-ray,	Wt%	ASTM D 4294		0.0331
Sodium	Sodium	ppm	SOL/DIL		< 0.1
Vanadium	Vanadium	ppm	SOL/DIL		< 0.1
Potassium	Potassium	ppm	SOL/DIL		< 0.1
Lead	Lead	ppm	SOL/DIL		< 0.1
Calcium	Calcium	ppm	SOL/DIL		< 0.1
Magnesium	Magnesium	ppm	SOL/DIL		< 0.1
Hydrogen **	Hydrogen	Wt%	ASTM D 5291		12.65
Carbon**	Carbon	Wt%	ASTM D 5291		87.03
Nitrogen**	Nitrogen	Wt%	ASTM D 5291		0.02
Heat of combustion	Heat of Combustion, Gross	BTU/lb	ASTM D 240		19,549
Heat of combustion	Heat of Combustion, Net	BTU/lb	ASTM D 240		18,395
Heat of combustion	Heat of Combustion, Gross	BTU/Gal	ASTM D 240		138,139
Heat of combustion	Heat of Combustion,Net	BTU/Gal	ASTM D 240		129,984

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt Saybolt LP - Ft. Lauderdale, FL and the recipient is deemed to have full knowledge thereof.

Remarks  
 \*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory.  
 \*\* Saybolt was not present whilst the analysis was carried out and has signed for receipt only  
 \*\*with no liability accepted.

*Ramon Acosta*  
 Sr. Ramon Acosta

OLEANDER POWER PROJECT LTD  
 555 TOWNSEND ROAD  
 32926 COCOA FL  
 United States

SAYBOLT LP  
 2610 S. Federal Hwy  
 Ft. Lauderdale, FL 33316  
 Phone (954) 524-8772 Fax (954) 524-2377  
 E-mail Saybolt.flauderdale@corelab.com



All manual gauges, temperatures and samples in accordance with API/MPMS Chapter 3.1A, Chapter 7, Chapter 8.1, Chapter 8.2. Volume corrections for temperature are based on ASTM D1250 or tables supplied to us by the customer or the terminal. Saybolt can assume no responsibility for the accuracy of these tables.

Reference  
 Report no. 13062/1535 .01.L/06  
 Report date 28/Apr/2006  
 Location Cocoa, Florida, Oleander Power Plant

CERTIFICATE OF ANALYSIS

Sample submitted as #2 Fuel Oil  
 Received Sampled by Saybolt Inspector  
 Marked UNIT#2 RUN#2 AT 1435 Hr  
 Date of sampling 13/Apr/2006  
 Testing completed 27/Apr/2006 Time: 1600  
 Sealed N/A  
 Lab number 06180

Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity	API Gravity at 60°F		ASTM D 4052		35.2
Density	Density at 60°F	Kg/l	ASTM D 4053		0.8484
Density	Density at 80°F	Kg/l	ASTM D 4054		0.8401
Sulfur content	Sulfur content, X-ray,	Wt%	ASTM D 4294		0.0339
Sodium	Sodium	ppm	SOL/DIL		< 0.1
Vanadium	Vanadium	ppm	SOL/DIL		< 0.1
Potassium	Potassium	ppm	SOL/DIL		< 0.1
Lead	Lead	ppm	SOL/DIL		< 0.1
Calcium	Calcium	ppm	SOL/DIL		< 0.1
Magnesium	Magnesium	ppm	SOL/DIL		< 0.1
Hydrogen **	Hydrogen	Wt%	ASTM D 5291		13.03
Carbon**	Carbon	Wt%	ASTM D 5291		86.62
Nitrogen**	Nitrogen	Wt%	ASTM D 5291		0.02
Heat of combustion	Heat of Combustion, Gross	BTU/lb	ASTM D 240		19,477
Heat of combustion	Heat of Combustion, Net	BTU/lb	ASTM D 240		18,288
Heat of combustion	Heat of Combustion, Gross	BTU/Gal	ASTM D 240		137,676
Heat of combustion	Heat of Combustion, Net	BTU/Gal	ASTM D 240		129,271

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt Saybolt LP - Ft. Lauderdale, FL and the recipient is deemed to have full knowledge thereof.

Remarks  
 \*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory.  
 \*\* Saybolt was not present whilst the analysis was carried out and has signed for receipt only  
 \*\*with no liability accepted.

*Ramon Acosta*  
 For Ramon Acosta

OLEANDER POWER PROJECT LTD  
 555 TOWNSEND ROAD  
 32926 COCOA FL  
 United States

SAYBOLT LP  
 2610 S. Federal Hwy  
 Ft. Lauderdale, FL 33316  
 Phone (954) 524-8772 Fax: (954) 524-2377  
 E-mail Saybolt.flauderdale@corelab.com



All manual gauges, temperatures and samples in accordance with API/MPMS, Chapter 3.1A, Chapter 7, Chapter 8.1, Chapter 8.2. Volume corrections for temperature are based on ASTM D1250 or tables supplied to us by the customer or the terminal. Saybolt can assume no responsibility for the accuracy of these tables.

Reference  
 Report no. 13062/1535 .01.L/06  
 Report date 28/Apr/2006  
 Location Cocoa, Florida, Oleander Power Plant

CERTIFICATE OF ANALYSIS

Sample submitted as #2 Fuel Oil  
 Received Sampled by Saybolt Inspector  
 Marked UNIT#2 RUN#3 AT 1530 Hr  
 Date of sampling 13/Apr/2006  
 Testing completed 27/Apr/2006 Time: 1600  
 Sealed N/A  
 Lab Number U0101


Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity	API Gravity at 60°F				35.2
Density	Density at 60°F	Kg/l			0.8484
Density	Density at 80°F	Kg/l			0.8401
Sulfur content	Sulfur content, X-ray,	Wt%			0.0329
Sodium	Sodium	ppm			< 0.1
Vanadium	Vanadium	ppm			< 0.1
Potassium	Potassium	ppm			< 0.1
Lead	Lead	ppm			< 0.1
Calcium	Calcium	ppm			< 0.1
Magnesium	Magnesium	ppm			< 0.1
Hydrogen **	Hydrogen	Wt%			12.15
Carbon**	Carbon	Wt%			87.44
Nitrogen**	Nitrogen	Wt%			0.02
Heat of combustion	Heat of Combustion, Gross	BTU/lb			19,344
Heat of combustion	Heat of Combustion, Net	BTU/lb			18,236
Heat of combustion	Heat of Combustion, Gross	BTU/Gal			136,738
Heat of combustion	Heat of Combustion, Net	BTU/Gal			128,906

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt Saybolt LP - Ft. Lauderdale, FL and the recipient is deemed to have full knowledge thereof.

Remarks  
 \*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory.  
 \*\* Saybolt was not present whilst the analysis was carried out and has signed for receipt only  
 \*\*with no liability accepted.

*Ramon Acosta*  
 For Ramon Acosta

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05304  Job No.:  Sample Date: 04/28/05	 <b>Saybolt</b> A TRUE LABORATORIES COMPANY FAST TO THE POINT.  Email: saybolt.ftlauderdale@corelab.com
---	---	---

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 2, Sample 1  
**TIME SAMPLED:** 12:00  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0424
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.84**
CARBON, WT PCT	D-5291	87.13**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19573
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18402
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138774
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130472

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\*\* Results were based on analysis made at the time samples were received at the laboratory.

3 Sample nomenclature is designated by the customer.

Use report to control stock. An the base of our customer and suppliers, they retain their responsibility

thereof. There may be other relevant information which has not been reported. Saybolt Inc. will not

be responsible to third parties for the contents of this report or for any omissions therefrom.

B. Tolaymat  
Saybolt LP.


\*\* Carried out in third party laboratory.

Analysis results are submitted by a third party laboratory.

Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05305  Job No.:  Sample Date: 04/28/05	 <b>Saybolt</b> 3 TEST LABORATORIES THROUGHOUT THE WORLD FAST TO THE POINT.  Email: saybolt.ftlauderdale@corclab.com
---	---	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 2, Sample 2  
**TIME SAMPLED:** 12:30  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0412
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.4
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.26**
CARBON, WT PCT	D-5291	86.70**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19572
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18362
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138765
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130186

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\*\* Results were based on analysis made at the time samples were received at the laboratory.

\* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information that is available to them.

These results are not to be used for any other purpose. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.


B. J. Olajmat  
Saybolt LP.

\*\* Carried out in third party laboratory.

Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05306  Job No.:  Sample Date: 04/28/05	 <b>Saybolt</b> <small>A TEST LABORATORY COMPANY</small> FAST TO THE POINT.  Email: saybolt.ftiauderdate@corelab.com
---	---	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 2. Sample 3  
**TIME SAMPLED:** 13:00  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0407
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.3
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.44**
CARBON, WT PCT	D-5291	87.51**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19570
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18435
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138752
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130705

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc

\* Results were based on analysis made at the time samples were received at the laboratory

\* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers, and specifically indicates they specifically requested. They are to understand all information that has been returned. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

B. J. Olajmat  
Saybolt LP.


\*\* Carried out in third party laboratory.

Analysis results are submitted by a third party laboratory.

Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05307  Job No.:  Sample Dat 04/28/05	 <b>Saybolt</b> A 2001 LABORATORY COMPANY FAST TO THE POINT.  Email: saybolt.ftlauderdale@corelab.com
---	---	---

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 2, Sample 4  
**TIME SAMPLED:** 13:30  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0413
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.4
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.93**
CARBON, WT PCT	D-5291	87.03**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19653
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18473
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138702
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130374

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\* Results were based on analysis made at the time samples were received at the laboratory.

\* Sample nomenclature is designated by the customer.

Keep records in original form, for the use of our customers and applicable state information they occasionally request. These records include reports and test results which have been prepared. Saybolt Inc. will not be responsible to third parties for the accuracy of this report or for any omissions therefrom.

Keep records in original form, for the use of our customers and applicable state information they occasionally request. These records include reports and test results which have been prepared. Saybolt Inc. will not be responsible to third parties for the accuracy of this report or for any omissions therefrom.

Keep records in original form, for the use of our customers and applicable state information they occasionally request. These records include reports and test results which have been prepared. Saybolt Inc. will not be responsible to third parties for the accuracy of this report or for any omissions therefrom.


B. Polymat  
Saybolt LP.

\*\* Carried out in third party laboratory.

Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208 Phone: (904) 354-0490/6090 Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05308 Job No.: Sample Date: 04/28/05	 Email: saybolt.ftlauderdale@corelab.com
---	---	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 2, Sample 5  
**TIME SAMPLED:** 14:00  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0405
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.2
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.38**
CARBON, WT PCT	D-5291	87.48**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19569
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18440
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138748
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130743

**NOTES:**

- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made of the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued only for the stated test methods and supplies only information they specifically requested. There may be other test information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.


B. I. Olajmat  
Saybolt LP.

\*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.



<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 05309  Job No.:  Sample Date: 04/28/05	 <b>Saybolt</b> A CERTIFIED ANALYSIS COMPANY FAST TO THE POINT.  Email: saybolt.ftlauderdale@corelab.com
---	---	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 2, Sample 6  
**TIME SAMPLED:** 14:30  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0422
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.4
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.16**
CARBON, WT PCT	D-5291	86.80**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19560
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18359
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138683
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130168

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\* Results were based on analysis made at the time samples were received at the laboratory.

\* Sample nomenclature is designated by the customer

The report is issued solely for the use of the customer and is not to be used for any other purpose.

It is requested that you notify the laboratory immediately if you have any questions or concerns.

The laboratory is not responsible for the contents of this report or for any omissions therefrom.

B. Polymat  
Saybolt LP.


\*\* Carried out in third party laboratory.

Analysis results are submitted by a third party laboratory.

Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208                  Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p align="center"><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 05310                  Job No.:                  Sample Date: 04/28/05</p>	 <p>Email: saybolt.ftlauderdale@corelab.com</p>
--	---	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 2, Sample76  
**TIME SAMPLED:** 15:00  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** N/A  
**DATE TESTED:** 05/03-05/05

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	34.6
DENSITY @ 60 F, Kg/L	D-1298	0.8519
DENSITY @ 80 F, Kg/L	D-1298	0.8444
SULFUR, X RAY, WT PCT	D-4294	0.0413
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.3
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.14**
CARBON, WT PCT	D-5291	86.80**
NITROGEN, WT PCT	D-5291	0.02**
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19564
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18365
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138712
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	130211

**NOTES:**

- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.


**B. Polaymat**  
 Saybolt LP.

\*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

This report is limited solely for the use of the end-user and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(B3), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 04283  Job No.:  Sample Date 04/01/04	 <b>Saybolt</b> A CHEMICAL ANALYSIS COMPANY FAST TO THE POINT.  Email: flauderdale@sayboltwh.com
---	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 2  
**TIME SAMPLED:** 16:00  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:**  
**DATE TESTED:** 04/08/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	34.90
DENSITY @ 60 F, Kg/L	D-4052	0.8499
DENSITY @ 80 F, Kg/L	D-4052	0.8483
SULFUR, X RAY, WT PCT	D-4294	0.0413
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.09
CARBON, WT PCT	D-5291	86.81
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,463
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,269
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,818

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\* Results were based on analysis made at the time samples were received at the laboratory.

\* Sample nomenclature is designated by the customer.


This report is issued only for the use of our customers and supplies only information they specifically requested.

There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

B. Tolaymat  
Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208</p> <p>Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p align="center"><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 04284                  Job No.:                  Sample Date 04/01/04</p>	 <p>Email: fflauderdale@sayboltwh.com</p>
--	--	--

PRODUCT: # 2 FUEL OIL  
 SHORE TANK: UNIT # 2  
 TIME SAMPLED: 16:30  
 TERMINAL: OLEANDER POWER  
 SUBMITTED BY: OLEANDER POWER  
 CLIENT: OLEANDER POWER  
 REFERENCE NO.:  
 DATE TESTED: 04/08/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	34.90
DENSITY @ 60 F, Kg/L	D-4052	0.8499
DENSITY @ 80 F, Kg/L	D-4052	0.8483
SULFUR, X RAY, WT PCT	D-4294	0.0417
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.87
CARBON, WT PCT	D-5291	87.09
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,486
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,312
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,818

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

*A. Tolaymat*  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208                  Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 04285                  Job No.:                  Sample Date 04/01/04</p>	 <p>Email: <a href="mailto:ftauderdale@sayboltrwh.com">ftauderdale@sayboltrwh.com</a></p>
--	---	--


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 2  
**TIME SAMPLED:** 17:00  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:**  
**DATE TESTED:** 04/08/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	34.90
DENSITY @ 60 F, Kg/L	D-4052	0.8499
DENSITY @ 80 F, Kg/L	D-4052	0.8483
SULFUR, X RAY, WT PCT	D-4294	0.0412
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.71
CARBON, WT PCT	D-5291	87.24
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,436
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,276
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,626

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued only for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208 Phone: (904) 354-0490/6090 Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b> Lab No.: 04286 Job No.: Sample Date 04/01/04	 <b>Saybolt</b> A CARE LABORATORY COMPANY FAST TO THE POINT. Email: ftlauderdale@sayboltwh.com
---	--	---


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 2  
**TIME SAMPLED:** 17:15  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:**  
**DATE TESTED:** 04/08/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	34.90
DENSITY @ 60 F, Kg/L	D-4052	0.8499
DENSITY @ 80 F, Kg/L	D-4052	0.8483
SULFUR, X RAY, WT PCT	D-4294	0.0415
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.43
CARBON, WT PCT	D-5291	87.49
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,511
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,377
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138,157
DRY VAPOR PRESSURE @ 100F, PSI	D-5191 MODIFIED	0.12

**NOTES:**

- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

LABORATORY WORKSHEET

\*\*\*\*\*  
**HIGH SULFUR DIESEL**  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 04-66  
 LAB DATE: 04/15/03  
 \*\*\*\*\*  
 JOB NO: FG-191  
 SAMPLING DATE: 04/11/03

DUCT : LOW SULFUR DIESEL  
 MARKED : UNIT # 2 @ 12:30, SUBMITTED  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	35.47
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8466
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8390
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0380
11111	SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	0.1
11114	LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
11115	CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.6
11116	MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>RH</u>	13.28
11118	CARBON, WT PCT	D-5291	<u>RH</u>	86.68
11119	NITROGEN, WT PCT	D-5291	<u>RH</u>	0.02
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19536
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>NJ</u>	18324
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137826

LABORATORY WORKSHEET

\*\*\*\*\*  
**LOW SULFUR DIESEL**  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 04-67  
 LAB DATE: 04/15/03  
 \*\*\*\*\*  
 JOB NO: FG-~~134~~  
 SAMPLING DATE: 04/11/03

PRODUCT : LOW SULFUR DIESEL  
 MARKED : UNIT # 2 @ 13:00, SUBMITTED  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	35.47
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8466
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8390
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0376
11111	SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>NS</u>	0.07
11114	LEAD, PPM	SOL/DIL	<u>NS</u>	<0.1
11115	CALCIUM, PPM	SOL/DIL	<u>NS</u>	0.4
11116	MAGNESIUM, PPM	SOL/DIL	<u>NS</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>RM</u>	13.43
11118	CARBON, WT PCT	D-5291	<u>RM</u>	86.55
11119	NITROGEN, WT PCT	D-5291	<u>RM</u>	0.02
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NS</u>	19554
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>NS</u>	18329
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NS</u>	137953



## LABORATORY WORKSHEET

\*\*\*\*\*

HIGH SULFUR DIESEL

\*\*\*\*\*

PRODUCT : LOW SULFUR DIESEL  
 MARKED : UNIT # 2 @ 13:30, SUBMITTED  
 LOCATION : COCOA, FL

\*\*\*\*\*

LAB NUMBER: 04-68

LAB DATE: 04/15/03

\*\*\*\*\*

JOB NO: FG-~~131~~

SAMPLING DATE: 04/11/03

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	35.47
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8466
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8390
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0378
11111	SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>NS</u>	0.07
11114	LEAD, PPM	SOL/DIL	<u>NS</u>	<0.1
11115	CALCIUM, PPM	SOL/DIL	<u>NS</u>	0.5
11116	MAGNESIUM, PPM	SOL/DIL	<u>NS</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>RM</u>	13.49
11118	CARBON, WT PCT	D-5291	<u>RM</u>	86.47
11119	NITROGEN, WT PCT	D-5291	<u>RM</u>	0.02
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NS</u>	19563
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>NS</u>	18332
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NS</u>	138017

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



Best Available Copy

LABORATORY NO.: 06-76

LABORATORY ANALYSIS REPORT

CUSTOMER  
REF. NO(S):

DATE: 06/11/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT #2  
TAKEN @ 10:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.


NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	37.0
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8387
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0330
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.9
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.24
CARBON, WT PCT	D-5291	86.50
NITROGEN, WT PCT	D-5291	0.20
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19668
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18460
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137519

MEMBERS ASTM-API-SAE

  
SAYBOLT

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-75

LABORATORY ANALYSIS REPORT

CUSTOMER  
REF. NO(S):

DATE: 06/11/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT #2  
TAKEN @ 10:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
(45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.


NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	37.0
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8387
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0320
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.9
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.09
CARBON, WT PCT	D-5291	86.65
NITROGEN, WT PCT	D-5291	0.24
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19646
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18452
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137365

MEMBERS ASTM-API-SAE

  
SAYBOLT

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO... 5-74

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 06/11/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
  
- **Identifying Marks:**  
UNIT #2  
TAKEN @ 09:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
  
- **Submitted by:**  
OLEANDER POWER PROJECT
  
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.


**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  
- Results were based on analysis made at the time samples were received at the laboratory.
  
- Sample nomenclature is designated by the customer.

**ANALYSIS**

<u>TEST</u>	<u>METHOD</u>	<u>RESULT</u>
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	37.0
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8387
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0321
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.7
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.08
CARBON, WT PCT	D-5291	86.52
NITROGEN, WT PCT	D-5291	0.25
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19645
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18452
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137358

MEMBERS ASTM-API-SAE



SAYBOLT

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-73

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 06/11/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT #2  
TAKEN @ 09:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST

SPECIFIC GRAVITY, API @ 60 DEG F  
DENSITY @ 60 DEG F, Kg/L  
DENSITY @ 80 DEG F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

METHOD

D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

RESULT

37.0  
0.8388  
0.8311  
0.0342  
<0.1  
<0.1  
<0.1  
0.6  
<0.1  
<0.1  
13.36  
86.69  
0.14  
19581  
18236  
136910

MEMBERS ASTM-API-SAE

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO. 06-72

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 06/11/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT #2  
TAKEN @ 08:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	37.0
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8387
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0326
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.5
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.19
CARBON, WT PCT	D-5291	86.76
NITROGEN, WT PCT	D-5291	0.14
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19623
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18420
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137204

MEMBERS ASTM-API-SAE

  
SAYBOLT

**SAYBOLT LP**

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO. 06-71

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 06/11/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
  
- **Identifying Marks:**  
UNIT #2  
TAKEN @ 08:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
  
- **Submitted by:**  
OLEANDER POWER PROJECT
  
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  
- Results were based on analysis made at the time samples were received at the laboratory.
  
- Sample nomenclature is designated by the customer.

**ANALYSIS**

<u>TEST</u>	<u>METHOD</u>	<u>RESULT</u>
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	37.0
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8387
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0327
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.9
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.05
CARBON, WT PCT	D-5291	86.59
NITROGEN, WT PCT	D-5291	0.10
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19683
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18492
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137624

MEMBERS ASTM-API-SAE

  
SAYBOLT

SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 06-70

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 06/11/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT #2  
TAKEN @ 07:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.


NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	37.0
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8387
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8311
SULFUR, X-RAY, WT PCT	D-4294	0.0328
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.5
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.03
CARBON, WT PCT	D-5291	86.73
NITROGEN, WT PCT	D-5291	0.14
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19683
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18494
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137624

MEMBERS ASTM-API-SAE

  
SAYBOLT



LABORATORY WORKSHEET

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*  
 PRODUCT : HIGH SULFUR DIESEL  
 SAMPLE : UNIT # 2 TAKEN AT 07:30  
 LOCATION : COCOA, FL

\*\*\*\*\*  
 LAB NUMBER: 06-70  
 LAB DATE: 06/14/02  
 \*\*\*\*\*  
 JOB NO: FG-131  
 SAMPLING DATE: 06/11/02

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

TEST ID / TEST DESCRIPTION	ASTM	BY	RESULTS
00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	B.T	37.0
00000 DENSITY AT 60 F, Kg/L	D-4052	B.T	0.8387
00000 DENSITY AT 80 F, Kg/L	D-4052	B.T	0.8311
00237 SULFUR, X-RAY, WT PCT	D-4294	B.T	0.0328
11111 SODIUM, PPM	SOL/DIL	B.T	<0.1
11112 VANADIUM, PPM	SOL/DIL	B.T	<0.1
11113 POTASSIUM, PPM	SOL/DIL	NJ	<0.1
11114 LEAD, PPM	SOL/DIL	NJ	0.5
11115 CALCIUM, PPM	SOL/DIL	NJ	<0.1
11116 MAGNESIUM, PPM	SOL/DIL	NJ	<0.1
11117 HYDROGEN, WT PCT	D-5291	NJR	13.03
11118 CARBON, WT PCT	D-5291	NJR	86.73
11119 NITROGEN, WT PCT	D-5291	NJR	0.14
11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	NJ	19683
11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	B.T	18494
11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	NJ	137624

JUN 14 2002 10:10 AM

\*\*\*\*\*  
HIGH SULFUR DIESEL  
\*\*\*\*\*

LABORATORY WORKSHEET

\*\*\*\*\*  
LAB NUMBER: 06-71  
LAB DATE: 06/14/02  
\*\*\*\*\*  
JOB NO: FG-124  
SAMPLING DATE: 06/11/02

PROJECT : HIGH SULFUR DIESEL  
LABORATORY : UNIT # 2 TAKEN AT 08:00  
LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
	00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	37.0
	00000 DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8387
	00000 DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8311
	00237 SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0327
	11111 SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
	11112 VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
	11113 POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11114 LEAD, PPM	SOL/DIL	<u>NJ</u>	0.9
	11115 CALCIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11116 MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11117 HYDROGEN, WT PCT	D-5291	<u>NIR</u>	13.05
	11118 CARBON, WT PCT	D-5291	<u>NIR</u>	86.59
	11119 NITROGEN, WT PCT	D-5291	<u>NIR</u>	0.10
	11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19683
	11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>BT</u>	18492
	11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137624

LABORATORY WORKSHEET

\*\*\*\*\*

\*\*\*\*\*

HIGH SULFUR DIESEL

LAB NUMBER: 06-72

\*\*\*\*\*

LAB DATE: 06/14/02

PRODUCT : HIGH SULFUR DIESEL  
 ANALYZED : UNIT # 2 TAKEN AT 08:30  
 LOCATION : COCOA, FL

\*\*\*\*\*  
 JOB NO: FG-134  
 SAMPLING DATE: 06/11/02

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

TEST ID	TEST DESCRIPTION	ASTM	BY	RESULTS
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	BT	37.0
00000	DENSITY AT 60 F, Kg/L	D-4052	BT	0.8387
00000	DENSITY AT 80 F, Kg/L	D-4052	BT	0.8311
00237	SULFUR, X-RAY, WT PCT	D-4294	BT	0.0326
11111	SODIUM, PPM	SOL/DIL	BT	<0.1
11112	VANADIUM, PPM	SOL/DIL	BT	<0.1
11113	POTASSIUM, PPM	SOL/DIL	NT	<0.1
11114	LEAD, PPM	SOL/DIL	NT	0.5
11115	CALCIUM, PPM	SOL/DIL	NT	<0.1
11116	MAGNESIUM, PPM	SOL/DIL	NT	<0.1
11117	HYDROGEN, WT PCT	D-5291	NT/R	13.19
11118	CARBON, WT PCT	D-5291	NT/R	86.76
11119	NITROGEN, WT PCT	D-5291	NT/R	0.14
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	NT	19623
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	BT	18420
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	NT	137204

LABORATORY WORKSHEET

\*\*\*\*\*  
HIGH SULFUR DIESEL  
\*\*\*\*\*

\*\*\*\*\*  
LAB NUMBER: 06-73  
LAB DATE: 06/14/02  
\*\*\*\*\*  
JOB NO: PG-131  
SAMPLING DATE: 06/11/02

PRODUCT : HIGH SULFUR DIESEL  
UNIT : UNIT # 2 TAKEN AT 09:00  
LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

REF	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	37.0
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8388
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8311
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0342
11111	SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11114	LEAD, PPM	SOL/DIL	<u>NT</u>	0.6
11115	CALCIUM, PPM	SOL/DIL	<u>NS</u>	<0.1
11116	MAGNESIUM, PPM	SOL/DIL	<u>NS</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>NS/R</u>	13.36
11118	CARBON, WT PCT	D-5291	<u>NS/R</u>	86.69
11119	NITROGEN, WT PCT	D-5291	<u>NS/R</u>	0.14
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NT</u>	19581
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>BT</u>	18236
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NS</u>	136910

LABORATORY WORKSHEET

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 06-74  
 LAB DATE: 06/14/02  
 \*\*\*\*\*  
 JOB NO: FG-121  
 SAMPLING DATE: 06/11/02

PRODUCT : HIGH SULFUR DIESEL  
 UNIT : UNIT # 2 TAKEN AT 09:30  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	37.0
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8387
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8311
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0321
11111	SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11114	LEAD, PPM	SOL/DIL	<u>NJ</u>	0.7
11115	CALCIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11116	MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.08
11118	CARBON, WT PCT	D-5291	<u>NJR</u>	86.52
11119	NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.25
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19645
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>BT</u>	18452
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137358

LABORATORY WORKSHEET

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 06-75  
 LAB DATE: 06/14/02  
 \*\*\*\*\*  
 JOB NO: FG-131  
 SAMPLING DATE: 06/11/02

PRODUCT : HIGH SULFUR DIESEL  
 SAMPLED : UNIT # 2 TAKEN AT 10:00  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

TEST ID / TEST DESCRIPTION	ASTM	BY	RESULTS
00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	BT	37.0
00000 DENSITY AT 60 F, Kg/L	D-4052	BT	0.8387
00000 DENSITY AT 80 F, Kg/L	D-4052	BT	0.8311
00237 SULFUR, X-RAY, WT PCT	D-4294	BT	0.0320
11111 SODIUM, PPM	SOL/DIL	BT	<0.1
11112 VANADIUM, PPM	SOL/DIL	BT	<0.1
11113 POTASSIUM, PPM	SOL/DIL	NJ	<0.1
11114 LEAD, PPM	SOL/DIL	NJ	0.9
11115 CALCIUM, PPM	SOL/DIL	NJ	<0.1
11116 MAGNESIUM, PPM	SOL/DIL	NJ	<0.1
11117 HYDROGEN, WT PCT	D-5291	NJR	13.09
11118 CARBON, WT PCT	D-5291	NJR	86.65
11119 NITROGEN, WT PCT	D-5291	NJR	0.24
11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	NJ	19646
11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	BT	18452
11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	NJ	137365

To Whom it may concern



Report no. 13062/1340 .00.L/05  
 Report date 30/Nov/2005  
 Object Submitted Samples - Lab Analysis  
 Product No.2 Fuel Oil  
 Location Cocoa , Florida, Oleander Power Project  
 B/L Date


**CERTIFICATE OF ANALYSIS**

Sample submitted as No.2 Fuel Oil  
 Received Sampled by Oleander Power Project  
 Marked UNIT # 3 @ 13:35  
 Date of sampling 11-Nov-05  
 Testing completed 22-Nov-05 Time  
 Sealed N/A  
 Lab number 05844

Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity at 60 °F			ASTM D 4052		34.06
DENSITY @ 60°F, Kg/L			ASTM D 4052		0.8542
DENSITY @ 80°F, Kg/L			ASTM D 4052		0.8465
SULFUR, X-RAY, WT PCT			ASTM D 4294		0.0383
SODIUM, PPM			SOL/DIL		<0.1
VANADIUM, PPM			SOL/DIL		<0.1
POTASSIUM, PPM			SOL/DIL		<0.1
LEAD, PPM			SOL/DIL		<0.1
CALCIUM, PPM			SOL/DIL		<0.1
MAGNESSIUM, PPM			SOL/DIL		<0.1
HYDROGEN, WT PCT			ASTM D 5291		**12.50
CARBON, WT PCT			ASTM D 5291		**87.20
NITROGEN, WT PCT			ASTM D 5291		**0.02
HEAT OF COMBUSTION, Gross, BTU/Lb			ASTM D 240		19,552
HEAT OF COMBUSTION, NET, BTU/LB			ASTM D 240		18,412
HEAT OF COMBUSTION, Gross, BTU/Gal			ASTM D 240		139,050
HEAT OF COMBUSTION, NET, BTU/GAL			ASTM D 240		130,943

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt SAYBOLT LP - Ft Lauderdale, Fl and the recipient is deemed to have full knowledge thereof.



Dreyfus Brown  
Saybolt LP.

Remarks  
 \*\*Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory.  
 Saybolt was not present whilst the analysis was carried out and has signed for receipt only with no liability accepted

To Whom it may concern



Report no. 13062/1340 .00.L/05  
 Report date 30/Nov/2005  
 Object Submitted Samples - Lab Analysis  
 Product No.2 Fuel Oil  
 Location Cocoa , Florida, Oleander Power Project  
 B/L Date

**CERTIFICATE OF ANALYSIS**

Sample submitted as No.2 Fuel Oil  
 Received Sampled by Oleander Power Project  
 Marked UNIT # 3 @ 14:05  
 Date of sampling 11-Nov-05  
 Testing completed 22-Nov-05 Time  
 Sealed N/A  
 Lab number 05845

Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity at 60 *F			ASTM D 4052		34.06
DENSITY @ 60°F, Kg/L			ASTM D 4052		0.8542
DENSITY @ 80°F, Kg/L			ASTM D 4052		0.8465
SULFUR, X-RAY, WT PCT			ASTM D 4294		0.0393
SODIUM, PPM			SOL/DIL		<0.1
VANADIUM, PPM			SOL/DIL		<0.1
POTASSIUM, PPM			SOL/DIL		<0.1
LEAD, PPM			SOL/DIL		<0.1
CALCIUM, PPM			SOL/DIL		<0.1
MAGNESSIUM, PPM			SOL/DIL		<0.1
HYDROGEN, WT PCT			ASTM D 5291		**12.49
CARBON, WT PCT			ASTM D 5291		**87.13
NITROGEN, WT PCT			ASTM D 5291		**0.02
HEAT OF COMBUSTION, Gross, BTU/Lb			ASTM D 240		19,554
HEAT OF COMBUSTION, NET, BTU/LB			ASTM D 240		18,415
HEAT OF COMBUSTION, Gross, BTU/Gal			ASTM D 240		139,067
HEAT OF COMBUSTION, NET, BTU/GAL			ASTM D 240		130,966

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt SAYBOLT LP - Ft Lauderdale, FL and the recipient is deemed to have full knowledge thereof.

Remarks  
 \*\*Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory.  
 Saybolt was not present whilst the analysis was carried out and has signed for receipt only with no liability accepted

*Jon Dreyfus*  
 Dreyfus Brown  
 Saybolt LP.



To Whom it may concern



Report no. 13062/1340 .00.L/05  
 Report date 30/Nov/2005  
 Object Submitted Samples - Lab Analysis  
 Product No.2 Fuel Oil  
 Location Cocoa , Florida, Oleander Power Project  
 B/L Date

**CERTIFICATE OF ANALYSIS**


Sample submitted as No.2 Fuel Oil  
 Received Sampled by Oleander Power Project  
 Marked UNIT # 3 @ 14:35  
 Date of sampling 11-Nov-05  
 Testing completed 22-Nov-05 Time  
 Sealed N/A  
 Lab number 05846

Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity at 60 °F			ASTM D 4052		34.06
DENSITY @ 60°F, Kg/L			ASTM D 4052		0.8542
DENSITY @ 80°F, Kg/L			ASTM D 4052		0.8465
SULFUR, X-RAY, WT PCT			ASTM D 4294		0.0384
SODIUM, PPM			SOL/DIL		<0.1
VANADIUM, PPM			SOL/DIL		<0.1
POTASSIUM, PPM			SOL/DIL		<0.1
LEAD, PPM			SOL/DIL		<0.1
CALCIUM, PPM			SOL/DIL		<0.1
MAGNESSIUM, PPM			SOL/DIL		<0.1
HYDROGEN, WT PCT			ASTM D 5291		**12.84
CARBON, WT PCT			ASTM D 5291		**86.80
NITROGEN, WT PCT			ASTM D 5291		**0.02
HEAT OF COMBUSTION, Gross, BTU/Lb			ASTM D 240		19,555
HEAT OF COMBUSTION, NET, BTU/LB			ASTM D 240		18,384
HEAT OF COMBUSTION, Gross, BTU/Gal			ASTM D 240		139,068
HEAT OF COMBUSTION, NET, BTU/GAL			ASTM D 240		130,740


Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt SAYBOLT LP - Ft Lauderdale, Fl and the recipient is deemed to have full knowledge thereof.

Remarks  
 \*\*Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory.  
 Saybolt was not present whilst the analysis was carried out and has signed for receipt only with no liability accepted



Dreyfus Brown  
Saybolt LP.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-19  Job No.: 13062-0301792/00  Sample Date: 12/02/03	  Email: ftlauderdale@sayboltwh.com
---	--	--


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 16:35  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #7  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.45
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8391
SULFUR, X RAY, WT PCT	D-4294	0.0370
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIAM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.70
CARBON, WT PCT	D-5291	86.97
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,559
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,400
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,989

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208 Phone: (904) 354-0490/6090 Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-18 Job No.: 13062-0301792/00 Sample Date: 12/02/03	 Email: ftlauderdale@sayboltwh.com
---	--	--


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 16:05  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #6  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.45
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8391
SULFUR, X RAY, WT PCT	D-4294	0.0371
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.57
CARBON, WT PCT	D-5291	87.08
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,510
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,363
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,643

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-17  Job No.: 13062-0301792/00  Sample Date: 12/02/03	 <b>Saybolt</b> <small>A CERT. LABORATORIES COMPANY</small> <b>FAST TO THE POINT.</b>  Email: ftlauderdale@sayboltwh.com
---	--	--


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 15:35  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #5  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.44
DENSITY @ 60 F, Kg/L	D-4052	0.8472
DENSITY @ 80 F, Kg/L	D-4052	0.8391
SULFUR, X RAY, WT PCT	D-4294	0.0344
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASium, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.98
CARBON, WT PCT	D-5291	86.72
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,538
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,354
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,919

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Jon Luebke  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*


<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-16  Job No.: 13062-0301792/00  Sample Date: 12/02/03	 <b>Saybolt</b> A CHEM. LABORATORIES COMPANY FAST TO THE POINT.  Email: ftlauderdale@sayboltwh.com
---	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 15:05  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #4  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.44
DENSITY @ 60 F, Kg/L	D-4052	0.8472
DENSITY @ 80 F, Kg/L	D-4052	0.8391
SULFUR, X RAY, WT PCT	D-4294	0.0370
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.74
CARBON, WT PCT	D-5291	86.79
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,527
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,365
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,841

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

  
 Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.


<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-15  Job No.: 13062-0301792/00  Sample Date: 12/02/03	 <b>Saybolt</b> <small>A CORE LABORATORIES COMPANY</small> <b>FAST TO THE POINT.</b>  Email: ftlauderdale@sayboltwh.com
---	--	---

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 14:35  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #3  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.44
DENSITY @ 60 F, Kg/L	D-4052	0.8472
DENSITY @ 80 F, Kg/L	D-4052	0.8391
SULFUR, X RAY, WT PCT	D-4294	0.0365
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.18
CARBON, WT PCT	D-5291	86054
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,517
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,315
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,771

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

  
 Jon L. Luster  
 Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-14  Job No.: 13062-0301792/00  Sample Date: 12/02/03	 <b>Saybolt</b> <small>A CHEM LABORATORIES COMPANY</small> <b>FAST TO THE POINT.</b>  Email: ftlauderdale@sayboltwh.com
---	--	---


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 14:05  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #2  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.43
DENSITY @ 60 F, Kg/L	D-4052	0.8472
DENSITY @ 80 F, Kg/L	D-4052	0.8392
SULFUR, X RAY, WT PCT	D-4294	0.0370
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.40
CARBON, WT PCT	D-5291	86.49
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,506
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,284
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,692

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  <b>Lab No.:</b> 12-13  <b>Job No.:</b> 13062-0301792/00  <b>Sample Date:</b> 12/02/03	 <b>Saybolt</b> <small>A LABS LABORATORIES COMPANY</small> <b>FAST TO THE POINT.</b>  <b>Email:</b> ftlauderdale@sayboltwh.com
---	---	--


**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3  
**TIME SAMPLED:** 13:35  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** Sample #1  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.42
DENSITY @ 60 F, Kg/L	D-4052	0.8473
DENSITY @ 80 F, Kg/L	D-4052	0.8392
SULFUR, X RAY, WT PCT	D-4294	0.0364
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIAM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.23
CARBON, WT PCT	D-5291	86.45
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,522
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,315
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,805

**NOTES:**

- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.


  
 Saybolt LP

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*





<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208                  Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p align="center"><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 041126                  Job No.:                  Sample Dat 11/10/04</p>	 <p>Email: saybolt.fl@clauderdale@corclab.com</p>
--	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 3, Sample 1  
**TIME SAMPLED:** 15:50  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** 17293  
**DATE TESTED:** 11/12-16/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	35.2
DENSITY @ 60 F, Kg/L	D-1298	0.8488
DENSITY @ 80 F, Kg/L	D-1298	0.8413
SULFUR, X RAY, WT PCT	D-1298	0.0435
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.2
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 13.17
CARBON, WT PCT	D-5291	** 86.80
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19412
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18210
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137204
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	128708

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  - \* Results were based on analysis made at the time samples were received at the laboratory.
  - \* Sample nomenclature is designated by the customer.
- This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

**B. Tolaymat**  
 Saybolt LP.

\*\* Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208                  Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p align="center"><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 041127                  Job No.:                  Sample Dat 11/10/04</p>	 <p>Email: saybolt.flauderdale@corelab.com</p>
--	--	---

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 3, Sample 2  
**TIME SAMPLED:** 16:15  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** 17293  
**DATE TESTED:** 11/12-16/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	35.2
DENSITY @ 60 F, Kg/L	D-1298	0.8488
DENSITY @ 80 F, Kg/L	D-1298	0.8413
SULFUR, X RAY, WT PCT	D-1298	0.0436
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.2
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 12.95
CARBON, WT PCT	D-5291	** 87.02
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19267
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18086
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	136179
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	127832

**NOTES:**  
 \* This laboratory report may not be published or used except in full.  
 It shall not be used in connection with any form of advertising  
 unless written consent is received from all offices of Saybolt Inc.

D. Tolaymat  
 Saybolt LP.


\* Results were based on analysis made at the time samples were received at the laboratory.  
 \* Sample nomenclature is designated by the customer.

\*\* Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory.  
 Saybolt was not present whilst the analysis was carried out,  
 and has signed for receipt only with no liability accepted.

This report is issued only for the use of our customer and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions thereon.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208 Phone: (904) 354-0490/6090 Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b> Lab No.: 041128 Job No.: Sample Dat 11/10/04	 Email: saybolt.ftlauderdale@corelab.com
---	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 3, Sample 3  
**TIME SAMPLED:** 16:45  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** 17293  
**DATE TESTED:** 11/12-16/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	35.2
DENSITY @ 60 F, Kg/L	D-1298	0.8488
DENSITY @ 80 F, Kg/L	D-1298	0.8413
SULFUR, X RAY, WT PCT	D-1298	0.0426
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 12.97
CARBON, WT PCT	D-5291	** 86.99
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19128
HEAT OF COMBUSTION, NET, BTU/LB	D-240	17947
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	135197
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	126849

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\* Results were based on analysis made at the time samples were received at the laboratory.

\* Sample nomenclature is designated by the customer.

This report is limited only to the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.


B. Tolaymat  
Saybolt LP.

\*\* Carried out in third party laboratory.

Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208                  Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p align="center"><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 041129                  Job No.:                  Sample Dat 11/10/04</p>	 <p>Email: saybolt.ftlauderdale@corelab.com</p>
--	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 3, Sample 4  
**TIME SAMPLED:** 17:15  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** 17293  
**DATE TESTED:** 11/12-16/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	35.2
DENSITY @ 60 F, Kg/L	D-1298	0.8488
DENSITY @ 80 F, Kg/L	D-1298	0.8413
SULFUR, X RAY, WT PCT	D-1298	0.0446
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 12.70
CARBON, WT PCT	D-5291	** 87.25
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19391
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18232
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137056
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	128864

**NOTES:**


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  - \* Results were based on analysis made at the time samples were received at the laboratory.
  - \* Sample nomenclature is designated by the customer.
- This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

B. Tolaymat  
 Saybolt LP.

\*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

<p><b>SAYBOLT LP</b>                  6531 Evergreen Ave.                  Jacksonville, FL 32208                  Phone: (904) 354-0490/6090                  Fax: (904) 354-2090</p>	<p align="center"><b>CERTIFICATE OF ANALYSIS</b></p> <p>Lab No.: 041130                  Job No.:                  Sample Dat 11/10/04</p>	 <p>Email: saybolt.ftlauderdale@corelab.com</p>
--	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK:** UNIT # 3, Sample 5  
**TIME SAMPLED:** 17:45  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** 17293  
**DATE TESTED:** 11/12-16/04

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-1298	35.2
DENSITY @ 60 F, Kg/L	D-1298	0.8488
DENSITY @ 80 F, Kg/L	D-1298	0.8413
SULFUR, X RAY, WT PCT	D-1298	0.0425
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	0.2
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	** 12.85
CARBON, WT PCT	D-5291	** 87.11
NITROGEN, WT PCT	D-5291	** 0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19408
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18236
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137176
HEAT OF COMBUSTION, NET, BTU/GAL	D-240	128892

**NOTES:**

\* This laboratory report may not be published or used except in full.

It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.

\* Results were based on analysis made at the time samples were received at the laboratory.

\* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.


B. Tolymat  
 Saybolt LP.

\*\* Carried out in third party laboratory. Analysis results are submitted by a third party laboratory. Saybolt was not present whilst the analysis was carried out, and has signed for receipt only with no liability accepted.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

**SAYBOLT LP.**  
 6531 Evergreen Av.,  
 Jacksonville, Florida  
 32208



LABORATORY NO. 1-31

CUSTOMER  
 REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 11/12/02  
 INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT 3 & 4 - SAMPLE  
TAKEN @ 16:30 ON 11/07/02  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
 DENSITY @ 60°F, Kg/L  
 DENSITY @ 80°F, Kg/L  
 SULFUR, X-RAY, WT PCT  
 SODIUM, PPM  
 VANADIUM, PPM  
 POTASSIUM, PPM  
 LEAD, PPM  
 CALCIUM, PPM  
 MAGNESIUM, PPM  
 HYDROGEN, WT PCT  
 CARBON, WT PCT  
 NITROGEN, WT PCT  
 HEAT OF COMBUSTION, GROSS, BTU/LB  
 HEAT OF COMBUSTION, NET, BTU/LB  
 HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:11/07/02

**ANALYSIS**

<u>METHOD</u>	<u>RESULT</u>
D-4052	35.75
D-4052	0.8452
D-4052	0.8377
D-4294	0.0266
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	12.77
D-5291	86.80
D-5291	0.02
D-240	19300
D-240	18135
D-240	135911

MEMBERS ASTM-API-SAE

*Tom Kusaka*  
 SAYBOLT

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

**SAYBOLT LP.**  
 6531 Evergreen Av  
 Jacksonville, Florida  
 32208



LABORATORY NO. 1-30

CUSTOMER  
 REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 11/12/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
  
- **Identifying Marks:**  
UNIT 3 & 4 - SAMPLE  
TAKEN @ 16:00 ON 11/07/02  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
  
- **Submitted by:**  
OLEANDER POWER PROJECT
  
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  
- Results were based on analysis made at the time samples were received at the laboratory.
  
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
 DENSITY @ 60°F, Kg/L  
 DENSITY @ 80°F, Kg/L  
 SULFUR, X-RAY, WT PCT  
 SODIUM, PPM  
 VANADIUM, PPM  
 POTASSIUM, PPM  
 LEAD, PPM  
 CALCIUM, PPM  
 MAGNESIUM, PPM  
 HYDROGEN, WT PCT  
 CARBON, WT PCT  
 NITROGEN, WT PCT  
 HEAT OF COMBUSTION, GROSS, BTU/LB  
 HEAT OF COMBUSTION, NET, BTU/LB  
 HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:11/07/02

**ANALYSIS**

<u>METHOD</u>	<u>RESULT</u>
D-4052	35.75
D-4052	0.8452
D-4052	0.8377
D-4294	0.0260
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	12.80
D-5291	86.60
D-5291	0.02
D-240	19479
D-240	18311
D-240	137171

MEMBERS ASTM-API-SAE

*Jon Kaseke*  
 SAYBOLT

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.



SAYBOLT LP.  
6531 Evergreen Av.  
Jacksonville, Florida  
32208



LABORATORY NO.: 1-29

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 11/12/02

INVOICE NO:

DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT 3 & 4 - SAMPLE  
TAKEN @ 15:30 ON 11/07/02  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

METHOD

RESULT

D-4052	35.75
D-4052	0.8452
D-4052	0.8377
D-4294	0.0258
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	12.88
D-5291	86.62
D-5291	0.02
D-240	19600
D-240	18425
D-240	138023

\*SAMPLING DATE: 11/07/02

MEMBERS ASTM-API-SAE

LABORATORY WORKSHEET

\*\*\*\*\*  
HIGH SULFUR DIESEL  
\*\*\*\*\*

\*\*\*\*\*  
LAB NUMBER: 07-41  
LAB DATE: 07/15/02  
\*\*\*\*\*  
JOB NO: FG-~~351~~  
SAMPLING DATE: 07/10/02

DUCT : HIGH SULFUR DIESEL  
MARKED : UNIT # 3 TAKEN AT 15:15  
LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>B.T</u>	37.0
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>B.T</u>	0.8388
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>B.T</u>	0.8318
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>B.T</u>	0.0275
11111	SODIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11114	LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
11115	CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.2
11116	MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.19
11118	CARBON, WT PCT	D-5291	<u>NJR</u>	86.55
11119	NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.02
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19729
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>B.T</u>	18526
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137945

LABORATORY WORKSHEET

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 07-42  
 LAB DATE: 07/15/02  
 \*\*\*\*\*  
 JOB NO: FG-122  
 SAMPLING DATE: 07/10/02

UCT : HIGH SULFUR DIESEL  
 MARKED : UNIT # 3 TAKEN AT 15:45  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

TEST ID / TEST DESCRIPTION	ASTM	BY	RESULTS
00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>B.T</u>	37.0
00000 DENSITY AT 60 F, Kg/L	D-4052	<u>B.T</u>	0.8388
00000 DENSITY AT 80 F, Kg/L	D-4052	<u>B.T</u>	0.8318
00237 SULFUR, X-RAY, WT PCT	D-4294	<u>B.T</u>	0.0283
11111 SODIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11112 VANADIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11113 POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11114 LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
11115 CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.1
11116 MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117 HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.36
11118 CARBON, WT PCT	D-5291	<u>NJR</u>	86.60
11119 NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.02
11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19725
11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>B.T</u>	18506
11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137917

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*

LABORATORY WORKSHEET

\*\*\*\*\*  
 LAB NUMBER: 07-43  
 LAB DATE: 07/15/02  
 \*\*\*\*\*  
 JOB NO: FG-134  
 SAMPLING DATE: 07/10/02

UCT : HIGH SULFUR DIESEL  
 Rked : UNIT # 3 TAKEN AT 16:15  
 OCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

TEST ID / TEST DESCRIPTION	[ASTM]	[BY]	[RESULTS]
00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	37.0
00000 DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8387
00000 DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8318
00237 SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0293
11111 SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11112 VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
11113 POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11114 LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
11115 CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.1
11116 MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117 HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.32
11118 CARBON, WT PCT	D-5291	<u>NJR</u>	86.29
11119 NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.02
11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19710
11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>BT</u>	18495
11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137812

LABORATORY WORKSHEET

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 07-44  
 LAB DATE: 07/15/02  
 \*\*\*\*\*  
 JOB NO: FG-~~121~~  
 SAMPLING DATE: 07/10/02

DUCT : HIGH SULFUR DIESEL  
 WORKED : UNIT # 3 TAKEN AT 16:45  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
	00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>B.T</u>	37.0
	00000 DENSITY AT 60 F, Kg/L	D-4052	<u>B.T</u>	0.8388
	00000 DENSITY AT 80 F, Kg/L	D-4052	<u>B.T</u>	0.8318
	00237 SULFUR, X-RAY, WT PCT	D-4294	<u>B.T</u>	0.0294
	11111 SODIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
	11112 VANADIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
	11113 POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11114 LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11115 CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.1
	11116 MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11117 HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.37
	11118 CARBON, WT PCT	D-5291	<u>NJR</u>	86.60
	11119 NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.02
	11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19704
	11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>B.T</u>	18484
	11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	137770

LABORATORY WORKSHEET

\*\*\*\*\*  
 HIGH SULFUR DIESEL  
 \*\*\*\*\*

\*\*\*\*\*  
 LAB NUMBER: 07-45  
 LAB DATE: 07/15/02  
 \*\*\*\*\*  
 JOB NO: FG-~~122~~  
 SAMPLING DATE: 07/10/02

DUCT : HIGH SULFUR DIESEL  
 MARKED : UNIT # 3 TAKEN AT 17:15  
 LOCATION : COCOA, FL

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
00000	SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>B.T</u>	37.0
00000	DENSITY AT 60 F, Kg/L	D-4052	<u>B.T</u>	0.8387
00000	DENSITY AT 80 F, Kg/L	D-4052	<u>B.T</u>	0.8318
00237	SULFUR, X-RAY, WT PCT	D-4294	<u>B.T</u>	0.0276
11111	SODIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11112	VANADIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11113	POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11114	LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
11115	CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.2
11116	MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117	HYDROGEN, WT PCT	D-5291	<u>NJ/R</u>	13.24
11118	CARBON, WT PCT	D-5291	<u>NJ/R</u>	86.35
11119	NITROGEN, WT PCT	D-5291	<u>NJ/R</u>	0.02
11120	HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19742
11121	HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>B.T</u>	18534
11122	HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	138036

\*\*\*\*\*

LABORATORY WORKSHEET

\*\*\*\*\*

HIGH SULFUR DIESEL

LAB NUMBER: 07-46

\*\*\*\*\*

LAB DATE: 07/15/02

DUCT : HIGH SULFUR DIESEL  
MARKED : UNIT # 3 TAKEN AT 17:45  
LOCATION : COCOA, FL

\*\*\*\*\*  
JOB NO: FG-1  
SAMPLING DATE: 07/10/02

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

TEST ID / TEST DESCRIPTION	[ASTM]	[BY]	[RESULTS]
00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>B.T</u>	37.0
00000 DENSITY AT 60 F, Kg/L	D-4052	<u>B.T</u>	0.8387
00000 DENSITY AT 80 F, Kg/L	D-4052	<u>B.T</u>	0.8318
00237 SULFUR, X-RAY, WT PCT	D-4294	<u>B.T</u>	0.0273
11111 SODIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11112 VANADIUM, PPM	SOL/DIL	<u>B.T</u>	<0.1
11113 POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11114 LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
11115 CALCIUM, PPM	SOL/DIL	<u>NT</u>	0.1
11116 MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
11117 HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.47
11118 CARBON, WT PCT	D-5291	<u>NJR</u>	86.48
11119 NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.02
11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19753
11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>B.T</u>	18524
11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	138113

LABORATORY WORKSHEET

\*\*\*\*\*

\*\*\*\*\*

HIGH SULFUR DIESEL

LAB NUMBER: 07-47

\*\*\*\*\*

LAB DATE: 07/15/02

DUCT : HIGH SULFUR DIESEL  
 MARKED : UNIT # 3 TAKEN AT 18:15  
 LOCATION : COCOA, FL

\*\*\*\*\*  
 JOB NO: PG-~~121~~  
 SAMPLING DATE: 07/10/02

TERMINAL : OLEANDER POWER PROJECT PAGE 1

CUSTOMER SPECS:

[RE]	[TEST_ID / TEST DESCRIPTION]	[ASTM]	[BY]	[RESULTS]
	00000 SPECIFIC GRAVITY, API AT 60 F	D-4052	<u>BT</u>	37.0
	00000 DENSITY AT 60 F, Kg/L	D-4052	<u>BT</u>	0.8387
	00000 DENSITY AT 80 F, Kg/L	D-4052	<u>BT</u>	0.8318
	00237 SULFUR, X-RAY, WT PCT	D-4294	<u>BT</u>	0.0278
	11111 SODIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
	11112 VANADIUM, PPM	SOL/DIL	<u>BT</u>	<0.1
	11113 POTASSIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11114 LEAD, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11115 CALCIUM, PPM	SOL/DIL	<u>NJ</u>	0.1
	11116 MAGNESIUM, PPM	SOL/DIL	<u>NJ</u>	<0.1
	11117 HYDROGEN, WT PCT	D-5291	<u>NJR</u>	13.34
	11118 CARBON, WT PCT	D-5291	<u>NJR</u>	86.58
	11119 NITROGEN, WT PCT	D-5291	<u>NJR</u>	0.02
	11120 HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	<u>NJ</u>	19744
	11121 HEAT OF COMBUSTION, NET, BTU/LB	D-240	<u>BT</u>	18527
	11122 HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	<u>NJ</u>	138050



# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-41

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 7/15/02

INVOICE NO:

### DESCRIPTION

■ Sample designated as:  
HIGH SULFUR DIESEL

■ Identifying Marks:  
UNIT # 3  
SAMPLE TAKEN @ 15:15  
OLEANDER POWER PROJECT  
COCOA, FLORIDA

■ Submitted by:  
OLEANDER POWER PROJECT

■ Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
(45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.


### ANALYSIS

PAGE 1 OF 1

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8388
DENSITY @ 80°F, Kg/L	D-4052	0.8318
SULFUR, X-RAY, WT PCT	D-4294	0.0275
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	0.2
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.19
CARBON, WT PCT	D-5291	86.55
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19729
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18526
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137945

\*SAMPLING DATE: 7/10/02

MEMBERS ASTM-API-SAE

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-42

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 7/15/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 3  
SAMPLE TAKEN @ 15:45  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
(46) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.


### ANALYSIS

PAGE 1 OF 1

<u>TEST</u>	<u>METHOD</u>	<u>RESULT</u>
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8388
DENSITY @ 80°F, Kg/L	D-4052	0.8318
SULFUR, X-RAY, WT PCT	D-4294	0.0283
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.36
CARBON, WT PCT	D-5291	86.60
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19725
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18506
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137917

\*SAMPLING DATE: 7/10/02

MEMBERS ASTM-API-SAE

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-43

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 7/15/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
  
- **Identifying Marks:**  
UNIT # 3  
SAMPLE TAKEN @ 16:15  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
  
- **Submitted by:**  
OLEANDER POWER PROJECT
  
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
(45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  
- Results were based on analysis made at the time samples were received at the laboratory.
  
- Sample nomenclature is designated by the customer.


### ANALYSIS

PAGE 1 OF 1

<u>TEST</u>	<u>METHOD</u>	<u>RESULT</u>
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8387
DENSITY @ 80°F, Kg/L	D-4052	0.8318
SULFUR, X-RAY, WT PCT	D-4294	0.0293
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.32
CARBON, WT PCT	D-5291	86.29
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19710
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18495
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137812

\*SAMPLING DATE:7/10/02

MEMBERS ASTM-API-SAE

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-44

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 7/15/02

INVOICE NO:

### DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT # 3  
SAMPLE TAKEN @ 16:45  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
(45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

### ANALYSIS

PAGE 1 OF 1

#### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT.  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

#### METHOD


D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

#### RESULT

37.0  
0.8388  
0.8318  
0.0294  
<0.1  
<0.1  
<0.1  
<0.1  
0.1  
<0.1  
13.37  
86.60  
0.02  
19704  
18484  
137770

\*SAMPLING DATE: 7/10/02

MEMBERS ASTM-API-SAE

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-45

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 7/15/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 3  
SAMPLE TAKEN @ 17:15  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

### ANALYSIS

PAGE 1 OF 1

#### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

#### METHOD


D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

#### RESULT

37.0  
0.8387  
0.8318  
0.0276  
<0.1  
<0.1  
<0.1  
<0.1  
0.2  
<0.1  
13.24  
86.35  
0.02  
19742  
18534  
138036

\*SAMPLING DATE:7/10/02

MEMBERS ASTM-API-SAE

  
SAYBOLT

**SAYBOLT LP**

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-46

CUSTOMER  
REF. NO(S):

**LABORATORY ANALYSIS REPORT:**

DATE: 7/15/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
  
- **Identifying Marks:**  
UNIT # 3  
SAMPLE TAKEN @ 17:45  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
  
- **Submitted by:**  
OLEANDER POWER PROJECT
  
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  
- Results were based on analysis made at the time samples were received at the laboratory.
  
- Sample nomenclature is designated by the customer.

**ANALYSIS**

PAGE 1 OF 1

<u>TEST</u>	<u>METHOD</u>	<u>RESULT</u>
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8387
DENSITY @ 80°F, Kg/L	D-4052	0.8318
SULFUR, X-RAY, WT PCT	D-4294	0.0273
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.47
CARBON, WT PCT	D-5291	86.48
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19753
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18524
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138113

\*SAMPLING DATE:7/10/02

MEMBERS ASTM-API-SAE

SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 07-47

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 7/15/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 3  
SAMPLE TAKEN @ 18:15  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

### ANALYSIS

PAGE 1 OF 1

<u>TEST</u>	<u>METHOD</u>	<u>RESULT</u>
SPECIFIC GRAVITY, API @ 60°F	D-4052	37.0
DENSITY @ 60°F, Kg/L	D-4052	0.8387
DENSITY @ 80°F, Kg/L	D-4052	0.8318
SULFUR, X-RAY, WT PCT	D-4294	0.0278
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.34
CARBON, WT PCT	D-5291	86.58
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19744
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18527
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138050

\*SAMPLING DATE:7/10/02

MEMBERS ASTM-API-SAE

SAYBOLT

To Whom it may concern



Report no. 13062/1340 .00.L/05  
 Report date 30/Nov/2005  
 Object Submitted Samples - Lab Analysis  
 Product No.2 Fuel Oil  
 Location Cocoa , Florida, Oleander Power Project  
 B/L Date

CERTIFICATE OF ANALYSIS


Sample submitted as No.2 Fuel Oil  
 Received Sampled by Oleander Power Project  
 Marked UNIT # 4 @ 18:05  
 Date of sampling 11-Nov-05  
 Testing completed 22-Nov-05 Time  
 Sealed N/A  
 Lab number 05847

Test	Analyte	Unit	Method	Result	
				Prefix	Figure
API Gravity at 60 °F			ASTM D 4052		34.06
DENSITY @ 60°F, Kg/L			ASTM D 4052		0.8542
DENSITY @ 80°F, Kg/L			ASTM D 4052		0.8466
SULFUR, X-RAY, WT PCT			ASTM D 4294		0.0391
SODIUM, PPM			SOL/DIL		<0.1
VANADIUM, PPM			SOL/DIL		<0.1
POTASSIUM, PPM			SOL/DIL		<0.1
LEAD, PPM			SOL/DIL		<0.1
CALCIUM, PPM			SOL/DIL		<0.1
MAGNESSIUM, PPM			SOL/DIL		<0.1
HYDROGEN, WT PCT			ASTM D 5291		**12.44
CARBON, WT PCT			ASTM D 5291		**87.04
NITROGEN, WT PCT			ASTM D 5291		**0.02
HEAT OF COMBUSTION, Gross, BTU/Lb			ASTM D 240		19,553
HEAT OF COMBUSTION, NET, BTU/LB			ASTM D 240		18,418
HEAT OF COMBUSTION, Gross, BTU/Gal			ASTM D 240		139,055
HEAT OF COMBUSTION, NET, BTU/GAL			ASTM D 240		130,983

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt SAYBOLT LP - Ft Lauderdale, FL and the recipient is deemed to have full knowledge thereof.

Remarks  
 \*\*Carried out in third party laboratory.  
 Analysis results are submitted by a third party laboratory.  
 Saybolt was not present whilst the analysis was carried out and has signed for receipt only with no liability accepted

  
 Dreyfus Brown  
 Saybolt LP.





To Whom it may concern



Report no. 13062/1340 .00.L/05  
Report date 30/Nov/2005  
Object Submitted Samples - Lab Analysis  
Product No.2 Fuel Oil  
Location Cocoa , Florida, Oleander Power Project  
B/L Date

CERTIFICATE OF ANALYSIS

Sample submitted as No.2 Fuel Oil  
Received Sampled by Oleander Power Project  
Marked UNIT # 4 @ 19:15  
Date of sampling 11-Nov-05  
Testing completed 22-Nov-05 Time  
Sealed N/A  
Lab number 05849

Table with 5 columns: Test, Analyte, Unit, Method, Result (Prefix, Figure). Rows include API Gravity, Density, Sulfur, Vanadium, Potassium, Lead, Calcium, Magnesium, Hydrogen, Carbon, Nitrogen, and Heat of Combustion.

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG), IP367 and appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with specifications.

This report is issued in accordance with the General Terms and Conditions of Saybolt SAYBOLT LP - Ft Lauderdale, Fl and the recipient is deemed to have full knowledge thereof.

Remarks

\*\*Carried out in third party laboratory.  
Analysis results are submitted by a third party laboratory.  
Saybolt was not present whilst the analysis was carried out and has signed for receipt only with no liability accepted

Signature of Jon Dreyfus Brown, Dreyfus Brown Saybolt LP.

SAYBOLT LP  
6531 Evergreen Ave.  
Jacksonville, FL 32208

Phone: (904) 354-0490/6090

Fax: (904) 354-2090

### CERTIFICATE OF ANALYSIS

Lab No.: 12-06

Job No.: 13062-0301793/00

Sample Date: 12/01/03



**Saybolt**  
A CHEM LABORATORIES COMPANY  
FAST TO THE POINT.


Email: [ftlauderdale@sayboltwh.com](mailto:ftlauderdale@sayboltwh.com)

PRODUCT: # 2 FUEL OIL  
SHORE TANK : UNIT # 4  
TIME SAMPLED: 11:50  
TERMINAL: OLEANDER POWER  
SUBMITTED BY: OLEANDER POWER  
CLIENT: OLEANDER POWER  
REFERENCE NO.: SAMPLE #1  
DATE TESTED: 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.45
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0358
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIAM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.68
CARBON, WT PCT	D-5291	86.90
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,746
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,589
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	139,308
READ VAPOR PRESSURE @ 100 F, PSI	D-5191 MODIFIED	0.13

#### NOTES:


- \* This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.

  
Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*


<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-07  Job No.: 13062-0301793/00  Sample Date: 12/01/03	 <b>Saybolt</b> <small>A LORE LABORATORIES COMPANY</small> <small>FAST TO THE POINT.</small>  Email: ftlauderdale@sayboltwh.com
---	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 4  
**TIME SAMPLED:** 12:20  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** SAMPLE #2  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.45
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0371
SODIUM, PPM	SOL/DIL	0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.42
CARBON, WT PCT	D-5291	87.32
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,470
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,337
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,361

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

  
 Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*


<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-08  Job No.: 13062-0301793/00  Sample Date: 12/01/03	  Email: ftlauderdale@sayboltwh.com
---	--	---

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 4  
**TIME SAMPLED:** 12:50  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** SAMPLE #3  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.46
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0360
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	13.00
CARBON, WT PCT	D-5291	86.61
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,516
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,330
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,685

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

  
 Saybolt LP.

This report is issued solely for the use of our customers and supplies only in formation they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.


<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-09  Job No.: 13062-0301793/00  Sample Date: 12/01/03	 <b>Saybolt</b> A LABC LABORATORIES COMPANY FAST TO THE POINT.  Email: <a href="mailto:ftlauderdale@sayboltwh.com">ftlauderdale@sayboltwh.com</a>
---	--	--

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 4  
**TIME SAMPLED:** 13:20  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** SAMPLE #4  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.45
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0371
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.94
CARBON, WT PCT	D-5291	86.71
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,536
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,355
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,826

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

  
 Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*


<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208  Phone: (904) 354-0490/6090  Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-10  Job No.: 13062-0301793/00  Sample Date: 12/01/03	 <b>Saybolt</b> <small>A LABS LABORATORIES COMPANY</small> <small>FAST TO THE POINT.</small>  Email: ftlauderdale@sayboltwh.com
---	--	--

<b>PRODUCT:</b>	<b># 2 FUEL OIL</b>
<b>SHORE TANK :</b>	<b>UNIT # 4</b>
<b>TIME SAMPLED:</b>	<b>13:50</b>
<b>TERMINAL:</b>	<b>OLEANDER POWER</b>
<b>SUBMITTED BY:</b>	<b>OLEANDER POWER</b>
<b>CLIENT:</b>	<b>OLEANDER POWER</b>
<b>REFERENCE NO.:</b>	<b>SAMPLE #5</b>
<b>DATE TESTED:</b>	<b>12/08/03</b>

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.46
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0372
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.80
CARBON, WT PCT	D-5291	86.84
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,216
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,048
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	135,568

**NOTES:**


- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

  
 Jon Eusebe  
 Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

*precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.*

<b>SAYBOLT LP</b> 6531 Evergreen Ave. Jacksonville, FL 32208 Phone: (904) 354-0490/6090 Fax: (904) 354-2090	<b>CERTIFICATE OF ANALYSIS</b>  Lab No.: 12-11 Job No.: 13062-0301793/00 Sample Date: 12/01/03	 <b>Saybolt</b> <small>A LABORATORY COMPANY</small> <small>FAST TO THE POINT.</small> Email: ftlauderdale@sayboltwh.com
---	--	---


<b>PRODUCT:</b>	# 2 FUEL OIL
<b>SHORE TANK :</b>	UNIT # 4
<b>TIME SAMPLED:</b>	14:20
<b>TERMINAL:</b>	OLEANDER POWER
<b>SUBMITTED BY:</b>	OLEANDER POWER
<b>CLIENT:</b>	OLEANDER POWER
<b>REFERENCE NO.:</b>	SAMPLE #6
<b>DATE TESTED:</b>	12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.45
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0358
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.82
CARBON, WT PCT	D-5291	86.74
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,527
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,357
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,762

**NOTES:**

- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

  
 Saybolt LP.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

recision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.



SAYBOLT LP  
6531 Evergreen Ave.  
Jacksonville, FL 32208

Phone: (904) 354-0490/6090

Fax: (904) 354-2090

### CERTIFICATE OF ANALYSIS

Lab No.: 12-12

Job No.: 13062-0301793/00

Sample Date: 12/01/03



**Saybolt**

A CORP. LABORATORIES COMPANY

FAST TO THE POINT.


Email: ftlauderdale@sayboltwh.com

**PRODUCT:** # 2 FUEL OIL  
**SHORE TANK :** UNIT # 4  
**TIME SAMPLED:** 14:50  
**TERMINAL:** OLEANDER POWER  
**SUBMITTED BY:** OLEANDER POWER  
**CLIENT:** OLEANDER POWER  
**REFERENCE NO.:** SAMPLE #7  
**DATE TESTED:** 12/08/03

TEST	METHOD	RESULTS
API Gravity @ 60 F	D-4052	35.46
DENSITY @ 60 F, Kg/L	D-4052	0.8471
DENSITY @ 80 F, Kg/L	D-4052	0.8390
SULFUR, X RAY, WT PCT	D-4294	0.0366
SODIUM, PPM	SOL/DIL	0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	<0.1
MAGNESSIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.50
CARBON, WT PCT	D-5291	87.12
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19,517
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18,377
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	137,692

#### NOTES:

- \* This laboratory report may not be published or used except in full.
- It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- \* Results were based on analysis made at the time samples were received at the laboratory.
- \* Sample nomenclature is designated by the customer.


  
Saybolt LP.

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omissions therefrom.

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of the inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions. Any data or results included in this message or an attachment contain original information that may not be modified or altered in any way that would change the content of the original information.

Precision parameters apply in the determination of the test results specified above. Please refer to ASTM D3244-77(83), IP 367 and Appendix E of IP standard methods for analysis and testing with respect to the utilization of test data to determine conformance with the relevant ASTM or IP specifications.

**SAYBOLT LP.**  
 6531 Evergreen Av.,  
 Jacksonville, Florida  
 32208



LABORATORY NO. 1-31

CUSTOMER  
 REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 11/12/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT 3 & 4 - SAMPLE  
TAKEN @ 16:30 ON 11/07/02  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
 DENSITY @ 60°F, Kg/L  
 DENSITY @ 80°F, Kg/L  
 SULFUR, X-RAY, WT PCT  
 SODIUM, PPM  
 VANADIUM, PPM  
 POTASSIUM, PPM  
 LEAD, PPM  
 CALCIUM, PPM  
 MAGNESIUM, PPM  
 HYDROGEN, WT PCT  
 CARBON, WT PCT  
 NITROGEN, WT PCT  
 HEAT OF COMBUSTION, GROSS, BTU/LB  
 HEAT OF COMBUSTION, NET, BTU/LB  
 HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:11/07/02

**ANALYSIS**


<u>METHOD</u>	<u>RESULT</u>
D-4052	35.75
D-4052	0.8452
D-4052	0.8377
D-4294	0.0266
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	12.77
D-5291	86.80
D-5291	0.02
D-240	19300
D-240	18135
D-240	135911

MEMBERS ASTM-API-SAE

*Tom Lusaka*  
 SAYBOLT

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

SAYBOLT LP.  
6531 Evergreen Av  
Jacksonville, Florida  
32208



LABORATORY NO.: 1-30

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 11/12/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
  
- **Identifying Marks:**  
UNIT 3 & 4 - SAMPLE  
TAKEN @ 16:00 ON 11/07/02  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
  
- **Submitted by:**  
OLEANDER POWER PROJECT
  
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
  
- Results were based on analysis made at the time samples were received at the laboratory.
  
- Sample nomenclature is designated by the customer.

**ANALYSIS**

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE: 11/07/02

METHOD

D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

RESULT


35.75  
0.8452  
0.8377  
0.0260  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
12.80  
86.60  
0.02  
19479  
18311  
137171

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

*Jon Kaseke*  
SAYBOLT

**SAYBOLT LP.**  
 6531 Evergreen Av.  
 Jacksonville, Florida  
 32208



LABORATORY NO.: 11-29

**Best Available Copy**

LABORATORY ANALYSIS REPORT

CUSTOMER  
 REF. NO(S):

DATE: 11/12/02

INVOICE NO:

**DESCRIPTION**

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT 3 & 4 - SAMPLE  
TAKEN @ 15:30 ON 11/07/02  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

**NOTES**

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

TEST

SPECIFIC GRAVITY, API @ 60°F  
 DENSITY @ 60°F, Kg/L  
 DENSITY @ 80°F, Kg/L  
 SULFUR, X-RAY, WT PCT  
 SODIUM, PPM  
 VANADIUM, PPM  
 POTASSIUM, PPM  
 LEAD, PPM  
 CALCIUM, PPM  
 MAGNESIUM, PPM  
 HYDROGEN, WT PCT  
 CARBON, WT PCT  
 NITROGEN, WT PCT  
 HEAT OF COMBUSTION, GROSS, BTU/LB  
 HEAT OF COMBUSTION, NET, BTU/LB  
 HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE: 11/07/02

**ANALYSIS**

<u>METHOD</u>	<u>RESULT</u>
D-4052	35.75
D-4052	0.8452
D-4052	0.8377
D-4294	0.0258
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	12.88
D-5291	86.62
D-5291	0.02
D-240	19600
D-240	18425
D-240	138023

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

*Jim Lawrence*  
 SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 08-63

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 8/19/02

INVOICE NO:

### DESCRIPTION

- Sample designated as:  
HIGH SULFUR DIESEL
- Identifying Marks:  
UNIT # 4  
SAMPLE TAKEN @ 12:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- Submitted by:  
OLEANDER POWER PROJECT
- Client:  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

### ANALYSIS

PAGE 1 OF 1

#### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:8/15/02

METHOD	RESULT
D-4052	37.03
D-4052	0.8388
D-4052	0.8312
D-4294	0.0282
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	13.34
D-5291	86.43
D-5291	0.02
D-240	19548
D-240	18331
D-240	136680

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 08-64

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 8/19/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 4  
SAMPLE TAKEN @ 13:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

### ANALYSIS

PAGE 1 OF 1

#### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:8/15/02

#### METHOD


D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

#### RESULT

37.04  
0.8387  
0.8311  
0.0279  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
13.32  
86.61  
0.02  
19656  
18441  
137435

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 08-65

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 8/19/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 4  
SAMPLE TAKEN @ 13:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

#### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:8/15/02

### ANALYSIS

METHOD	RESULT
D-4052	37.04
D-4052	0.8387
D-4052	0.8311
D-4294	0.0272
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	13.42
D-5291	86.55
D-5291	0.02
D-240	19614
D-240	18390
D-240	137141

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 08-66

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 8/19/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 4  
SAMPLE TAKEN @ 14:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE  
(45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:8/15/02

### ANALYSIS

<u>METHOD</u>	<u>RESULT</u>
D-4052	37.04
D-4052	0.8387
D-4052	0.8311
D-4294	0.0274
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	13.54
D-5291	86.37
D-5291	0.02
D-240	19642
D-240	18407
D-240	137337

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

SAYBOLT



# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 08-67

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 8/19/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 4  
SAMPLE TAKEN @ 14:30  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

### ANALYSIS

PAGE 1 OF 1

#### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL

\*SAMPLING DATE:8/15/02

#### METHOD

D-4052  
D-4052  
D-4052  
D-4294  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
SOL/DIL  
D-5291  
D-5291  
D-5291  
D-240  
D-240  
D-240

#### RESULT

37.05  
0.8387  
0.8311  
0.0275  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
<0.1  
13.55  
86.31  
0.02  
19678  
18442  
137510

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 08-68

CUSTOMER  
REF. NO(S):

## LABORATORY ANALYSIS REPORT

DATE: 8/19/02

INVOICE NO:

### DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
UNIT # 4  
SAMPLE TAKEN @ 15:00  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

### NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

PAGE 1 OF 1

### TEST

SPECIFIC GRAVITY, API @ 60°F  
DENSITY @ 60°F, Kg/L  
DENSITY @ 80°F, Kg/L  
SULFUR, X-RAY, WT PCT  
SODIUM, PPM  
VANADIUM, PPM  
POTASSIUM, PPM  
LEAD, PPM  
CALCIUM, PPM  
MAGNESIUM, PPM  
HYDROGEN, WT PCT  
CARBON, WT PCT  
NITROGEN, WT PCT  
HEAT OF COMBUSTION, GROSS, BTU/LB  
HEAT OF COMBUSTION, NET, BTU/LB  
HEAT OF COMBUSTION, GROSS, BTU/GAL


\*SAMPLING DATE:8/15/02

### ANALYSIS

METHOD	RESULT
D-4052	37.05
D-4052	0.8387
D-4052	0.8311
D-4294	0.0266
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
SOL/DIL	<0.1
D-5291	13.24
D-5291	86.73
D-5291	0.02
D-240	19631
D-240	18423
D-240	137181

MEMBERS ASTM-API-SAE

This report is issued solely for the use of our customers and supplies only information they specifically requested. There may be other relevant information which has not been reported. Saybolt Inc. will not be responsible to third parties for the contents of this report or for any omission therefrom.

  
SAYBOLT

# SAYBOLT LP

6531 Evergreen Avenue  
Jacksonville, Florida 32208



LABORATORY NO.: 11-05

CUSTOMER  
REF. NO(S):

LABORATORY ANALYSIS REPORT

DATE: 11/05/02

INVOICE NO:

## DESCRIPTION

- **Sample designated as:**  
HIGH SULFUR DIESEL
- **Identifying Marks:**  
TANK 3A FILL  
SUBMITTED SAMPLE  
OLEANDER POWER PROJECT  
COCOA, FLORIDA
- **Submitted by:**  
OLEANDER POWER PROJECT
- **Client:**  
OLEANDER POWER PROJECT

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.


## NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

## ANALYSIS

TEST	METHOD	RESULT
SPECIFIC GRAVITY, API @ 60 DEG F	D-4052	35.53
DENSITY @ 60 DEG F, Kg/L	D-4052	0.8463
DENSITY @ 80 DEG F, Kg/L	D-4052	0.8387
SULFUR, X-RAY, WT PCT	D-4294	0.0266
SODIUM, PPM	SOL/DIL	<0.1
VANADIUM, PPM	SOL/DIL	<0.1
POTASSIUM, PPM	SOL/DIL	<0.1
LEAD, PPM	SOL/DIL	<0.1
CALCIUM, PPM	SOL/DIL	0.1
MAGNESIUM, PPM	SOL/DIL	<0.1
HYDROGEN, WT PCT	D-5291	12.71
CARBON, WT PCT	D-5291	86.88
NITROGEN, WT PCT	D-5291	0.02
HEAT OF COMBUSTION, GROSS, BTU/LB	D-240	19569
HEAT OF COMBUSTION, NET, BTU/LB	D-240	18409
HEAT OF COMBUSTION, GROSS, BTU/GAL	D-240	138059

MEMBERS ASTM-API-SAE

  
SAYBOLT

		<b>EXP+</b>		Pieces: <b>1/1</b>
<b>FM: DEP AIR RESOURCE MGMT</b> P. Adams DIRECTOR OFFICE STE 23 111 S MAGNOLIADR TALLAHASSEE, FL 32301 UNITED STATES Phone: 850-921-9505		37550201000 A7 AP255 Sender's ref <b>TLH</b>		<b>ORIGIN:</b> <b>TLH</b>
<b>To: NATIONAL PARK SERVICE</b> MRS. JOHN BUNYAK 12795 W. ALAMEDA PARKWAY AIR DIVISION LAKEWOOD, CO 80228 UNITED STATES		<b>80228</b> POSTCODE:		TEL: 303-966-2818
Description: PSD-FL-377 7/11/06 letter		Weight: 1 lbs for 1 pcs Date: 2006-07-25		Time <b>10:30</b>
DHL standard terms and conditions apply.				
		<b>EGEH 9E</b>		
(ZLUS80228)				
				
WAYBILL: 17127466753		(Non-Negotiable)		



Please fold or cut in half  
**DO NOT PHOTOCOPY**

Using a photocopy could delay the delivery of your package and will result in additional shipping charge

<b>SENDER'S RECEIPT</b> Waybill #: 17127466753		Rate Estimate: 13.73 Protection: Not Required Description: PSD-FL-377 7/11/06 letter
To(Company): National Park Service Air Division 12795 W. Alameda Parkway Lakewood, CO 80228 UNITED STATES		Weight (lbs.): 1 Dimensions: 0 x 0 x 0
Attention To: Mr. John Bunyak Phone#: 303-966-2818		Ship Ref: 37550201000 A7 AP255 Service Level: Next Day 10:30 (Next business day by 10:30 A.M.)
Sent By: P. Adams Phone#: 850-921-9505		Special Svc:
		Date Printed: 7/25/2006 Bill Shipment To: Sender Bill To Acct: 778941286

DHL Signature (optional) \_\_\_\_\_ Route \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

For Tracking, please go to [www.dhl-usa.com](http://www.dhl-usa.com) or call 1-800-225-5345  
 Thank you for shipping with DHL

Create new shipment    
  View pending shipments    
  Print waybill



		<b>Pieces:</b> <b>1/1</b>	
<b>FM: DEP AIR RESOURCE MGMT</b> P. Adams DIRECTOR OFFICE STE 23 111 SMAGNOLIA DR TALLAHASSEE, FL 32301 UNITED STATES Phone: 850-921-9505		<b>ORIGINE:</b> TLH Sender's ref 37550201000 A7 AP255	
<b>To: DEP CENTRAL DISTRICT</b> MR. ALAN ZAHM 3319 MAGUIRE BLVD. 225 ORLANDO, FL 32803 UNITED STATES		<b>POSTCODE:</b> <b>32803</b> TEL: 407-893-3334	
Description: PSD-FL-377 7/11/06 letter		Weight: 1 lbs for 1 pcs Date: 2006-07-25	
DHL standard terms and conditions apply.			
 (2L)JUS32803		<b>MCOX 5H</b> <b>FSC</b>	
 WAYBILL: 17127376755 (Non-Negotiable)		<b>26WE</b> Day	



Please fold or cut in half  
**DO NOT PHOTOCOPY**

Using a photocopy could delay the delivery of your package and will result in additional shipping charge

**SENDER'S RECEIPT**

Waybill #: 17127376755

To(Company):  
 DEP Central District  
 225  
 3319 Maguire Blvd.

Orlando, FL 32803  
 UNITED STATES

Attention To: Mr. Alan Zahm  
 Phone#: 407-893-3334

Sent By: P. Adams  
 Phone#: 850-921-9505

Rate Estimate: 3.1  
 Protection: Not Required  
 Description: PSD-FL-377 7/11/06 letter

Weight (lbs.): 1  
 Dimensions: 0 x 0 x 0

Ship Ref: 37550201000 A7 AP255  
 Service Level: Ground (Est.  
 delivery in 1 business day(s))


Special Svc:

Date Printed: 7/25/2006  
 Bill Shipment To: Sender  
 Bill To Acct: 778941286


DHL Signature (optional) \_\_\_\_\_ Route \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

For Tracking, please go to [www.dhl-usa.com](http://www.dhl-usa.com) or call 1-800-225-5345

Thank you for shipping with DHL

Create new shipment 

View pending shipments

Print waybill 



		<b>GND</b>		Pieces: <b>1/1</b>
<b>FM: DEP AIR RESOURCE MGMT</b> P. Adams DIRECTOR OFFICE STE 23 111 S MAGNOLIA DR TALLAHASSEE, FL 32301 UNITED STATES Phone: 850-921-9505		ORIGIN: <b>TLH</b> Sender's ref 37550201000 A7 AP255		
<b>To: U.S. EPA REGION 4</b> MR. GREGG M. WORLEY 61 FORSYTH STREET AIR PERMITS SECTION ATLANTA, GA 30303 UNITED STATES		POSTCODE: <b>30303</b> TEL: 404-562-9141		
Description: PSD-FL-380 app; PSD-FL-379 app; PSD-FL-377 response Weight: 13 lbs for 1 pcs Date: 2006-07-19 DHL standard terms and conditions apply.				
			20TH Day	
		<b>HARB 6V</b> <b>ATT</b>		
(ZLU)S30303				
				
MAYBILL: 17050352454 (Non-Negotiable)				

▲ PEEL HERE PEEL HERE ▲

Please fold or cut in half  
**DO NOT PHOTOCOPY**

Using a photocopy could delay the delivery of your package and will result in additional shipping charge

<b>SENDER'S RECEIPT</b> Waybill #: 17050352454		Rate Estimate: 3.3 Protection: Not Required Description: PSD-FL-380 app; PSD-FL-379 app; PSD-FL-377 response
To (Company): U.S. EPA Region 4 Air Permits Section 61 Forsyth Street  Atlanta, GA 30303 UNITED STATES		Weight (lbs.): 13 Dimensions: 0 x 0 x 0
Attention To: Mr. Gregg M. Worley Phone#: 404-562-9141		Ship Ref: 37550201000 A7 AP255 Service Level: Ground (Est. delivery in 1 business day(s))
Sent By: P. Adams Phone#: 850-921-9505		Special Svc:  Date Printed: 7/19/2006 Bill Shipment To: Sender Bill To Acct: 778941286

DHL Signature (optional) \_\_\_\_\_ Route \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

For Tracking, please go to [www.dhl-usa.com](http://www.dhl-usa.com) or call 1-800-225-5345  
 Thank you for shipping with DHL

[Create new shipment](#) ▶
 [View pending shipments](#)
[Print waybill](#) ▶



**Southern Company Services, Inc.**

One Energy Place  
Pensacola, Florida 32520

850.444.6111

RECEIVED

MAY 04 2006

BUREAU OF AIR REGULATION



May 2, 2006

Al Linero  
Florida Department of Environmental Protection  
Division of Air Resource Management  
2600 Blair Stone Road, M.S. #5500  
Tallahassee, FL 32399-2400

RE: Oleander Power Project  
Unit 5 PSD Construction Permit

Dear Mr. Linero,

As we have discussed, Southern Company is planning to build a 5<sup>th</sup> unit at the Oleander Power Project facility. As you know 5 units were originally permitted for construction at the facility, but only 4 were built. Please find enclosed 4 copies of the Oleander Unit 5 PSD construction permit application. Also enclosed is a check for the application fee. The application has been signed by the authorized representative.

Please call Allison Little at (850) 444-6537 regarding any additional questions or concerns.

Sincerely,

A handwritten signature in black ink that reads "Jim Vick". The signature is written in a cursive style.

Jim Vick  
Gulf Power Company  
Director of Environmental Affairs



# Department of Environmental Protection

Jeb Bush  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400  
Telephone: (850) 488-0114 FAX: (850) 922-6979

Colleen M. Castille  
Secretary

June 2, 2006

## CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. James O. Vick, Director Environmental Affairs  
Gulf Power Company  
One Energy Place  
Pensacola, Florida 32520

Re: Request for Additional Information  
DEP File No. 0090180-003-AC (PSD-FL-377)  
Proposed Simple Cycle Combustion Turbine at the Oleander Power Project

Dear Mr. Vick:

On May 4, 2006 we received your application for an air construction permit for an additional simple cycle (SC) combustion turbine at the existing Oleander Power Project in Brevard County.

Pursuant to Rules 62-4.055, and 62-4.070 F.A.C., Permit Processing, the Department requests submittal of the additional information prior to processing the application. Should your response to any of the below items require new calculations, please submit the new calculations, assumptions, reference material and appropriate revised pages of the application form.

1. The use of natural gas and low-sulfur distillate fuel oil ( $\leq 0.05\%$  S by weight) has been proposed as BACT for  $\text{SO}_2$  for this project. What are the "actual" sulfur content values of the distillate fuel oil delivered for use in the existing combustion turbines? Please submit fuel records showing actual sulfur content of the fuel oil delivered to Oleander Power Project for use in Units 1, 2, 3, and 4 for the past four years.
2. Complete replacement of the standard specification (0.05% S) highway diesel fuel by ultra low sulfur (0.0015 % sulfur) diesel is required by 2011. Will the now standard fuel (0.05 % S) be available for purchase for non-vehicular use after 2011? Or, is it expected that distillate fuel oil purchased for use in the combustion turbines at Oleander Power Project will eventually meet the ultra low sulfur diesel specification of 0.0015 percent?
3. Although this project is not PSD for VOC, the  $\text{NO}_x$  emissions are above 100 TPY.  $\text{NO}_x$  is a precursor for ozone formation. Please provide information regarding impacts from this project on the regional ozone. Will this project contribute to an Ambient Air Quality Standard violation for ozone?
4. According to the application, the nearest Class I area is approximately 175 km away. A Class I analysis was not completed for this proposed modification due to this distance. However, the Federal Land Manager suggests that projects within 300 km of a Class I area be analyzed. The Department is awaiting comments regarding the Class I area from the US Fish and Wildlife Service. Please be aware that a Class I analysis may still be required for this application to be sufficient.



5. The application states that this project will not have an adverse effect on all soils, vegetation and wildlife in the area since the predicted impacts will be below the Ambient Air Quality Standards. Are there any specifically sensitive or endangered species in the project area that may be particularly sensitive to the project emissions? If so, will these species be adversely impacted?
6. Regarding the meteorological data, the modeling indicates that the base elevation of the Orlando International Airport station is at 0m. Is this correct? Also, the AERMET surface parameters are based on the Orlando International Airport Station land use. While it is correct to use surface parameters for the meteorological site rather than the project site, the meteorological station used should be representative of the land use at the project site. Is the land use in the project area similar to the land use of the airport?
7. According to the application, the percent land use for the Orlando station is mostly Grassland and Deciduous Forest. For Spring/Summer, the AERMOD User's Guide suggests an Albedo of 0.12-0.18, a Bowen Ratio for Average Moisture of 0.3-0.8, and a Surface Roughness of 0.05-1.3 for Grasslands/Deciduous Forest. The Albedo and Bowen Ratio surface parameters used in the AERMET file for this project are higher than the ranges given in the User's Guide. Also, the Surface Roughness parameters used in the model are more indicative of the "Forest" rather than "Grassland." Please explain how the surface parameters for this project were determined and please explain why the parameters are generally higher than what guidance suggests.
8. Has Oleander Power or its affiliates had any violations (or warning letters) related to any Department or EPA regulations at any of their facilities in Florida and the United States? Have officers of Oleander Power also been officers of other companies that have had violations (or warning letters) of Department regulations at any facilities? Please provide all documentation in relation to any such violations.

We will forward any comments received from other agencies as soon as we receive them. Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. Please advise the professional engineer to make sure he/she uses the correct seal in compliance with the applicable requirements of the Florida Board of Professional Engineers.

Permit applicants are advised that Rule 62-4.055(1), F.A.C. requires applicants to respond to requests for information within 90 days. If there are any questions, please call Cindy Mulkey at 850/921-8968. Matters regarding modeling issues should be directed to Debbie Nelson at 850/921-9537.

Sincerely,



A.A. Linero, Program Administrator  
Bureau of Air Regulation  
New Source Review Section

AAL/cm

cc: Allison Little, Southern Co.  
Thomas Davis, ECT  
Jim Little, EPA  
John Bunyak, NPS  
Len Kozlov, DEP CD  
Chair, Brevard County Commission  
Administrator, Brevard County

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	A. Signature <input checked="" type="checkbox"/> <i>[Signature]</i> <div style="float: right;"> <input type="checkbox"/> Agent  <input type="checkbox"/> Addressee         </div>
1. Article Addressed to:  James O. Vick, Director Environmental Affairs Gulf Power Company One Energy Place Pensacola, FL 32520	B. Received by ( <i>Printed Name</i> ) <i>[Signature]</i>
2. <u>7005 1820 0007 9819 8436</u>	C. Date of Delivery <i>10/5/00</i>  D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input checked="" type="checkbox"/> No <i>Misson Little</i>
PS Form 3811, February 2004	3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.
Domestic Return Receipt	4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes

**U.S. Postal Service™**

**CERTIFIED MAIL™ RECEIPT**

*(Domestic Mail Only; No Insurance Coverage Provided)*

For delivery information visit our website at [www.usps.com](http://www.usps.com)

OFFICIAL USE

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

*Sent To* James O. Vick

*Street, Apt. No., or PO Box* One Energy Place

*City, State, ZIP+4* Pensacola, FL 32520

PS Form 3800, June 2002 See Reverse for Instructions

7005 1820 0007 9819 8436