From:	Kennedy, Susan Butler
To:	Svec, Ed
Cc:	Terry, Greg N.
Subject:	Oleander
Date:	Friday, April 19, 2013 12:31:03 PM
Attachments:	image012.png image013.png image014.png

Good Morning Ed,
Per our conversation yesterday, Southern Power would like to change the following language from the "Proposed Air Permit Revisions" for application number 3493-1. We request that "regardless of hours of operation" be removed from Specific Condition 29 and Specific Condition 18. See below:

Specific Condition 29. If data collected from the reference method during the required CEMS quality assurance RATA test are substituted for annual and renewal compliance tests for NOx, then no separate annual or renewal compliance testing while firing fuel oil shall be required. ~~regardless of hours of operation~~.

Specific Condition 18. If data collected from the reference method during the required CEMS quality assurance RATA test are substituted for annual and renewal compliance tests for NOx, then no separate annual or renewal compliance testing while firing fuel oil shall be required for Nox. ~~regardless of hours of operation~~.

Please confirm receipt of this email and feel free to call me with any questions or comments regarding our request.
Thanks so much,
Susan.

Susan B. Kennedy, QEP
Senior Environmental Affairs Specialist
Gulf Power Company
One Energy Place, Pensacola, FL 32520
850-444-6153 cell 850-336-6153

Stay connected with Gulf Power