From: Kennedy, Susan Butler
To: Svec, Ed
Cc: Terry, Greg N.
Subject: RE: Oleander
Date: Wednesday, May 01, 2013 5:47:58 PM
Attachments: image002.png
image003.png
image004.png

Hi Ed,
We discussed your suggested language for Specific Condition 29 and 18 listed below and Southern Power finds it acceptable.
Feel free to call me with any questions.
Have a good night,
Susan.

Susan B. Kennedy, QEP
Senior Environmental Affairs Specialist
Gulf Power Company
One Energy Place, Pensacola, FL 32520
850-444-6153 cell 850-336-6153

From: Svec, Ed [mailto:Ed.Svec@dep.state.fl.us]
Sent: Wednesday, May 01, 2013 1:20 PM
To: Kennedy, Susan Butler
Subject: RE: Oleander

Susan:

Sorry I am so long getting back to you. Here is my suggestion for the two conditions:

If data collected from the reference method during the required CEMS quality assurance RATA test are substituted for annual or renewal compliance tests for NO_X, then no separate annual or renewal compliance testing for the fuel fired while conducting the CEMS quality assurance RATA test shall be required.

The way it was written, if you operated over 400 hrs on oil and you did the RATA on gas, you would not have to do the oil compliance test.

Ed Svec

Please take a few minutes to share your comments on the service you received from the department by clicking on this link. DEP Customer Survey.
From: Kennedy, Susan Butler [mailto:SKENNEDY@southernco.com]
Sent: Friday, April 19, 2013 12:31 PM
To: Svec, Ed
Cc: Terry, Greg N.
Subject: Oleander

Good Morning Ed,
Per our conversation yesterday, Southern Power would like to change the following language

from the “Proposed Air Permit Revisions” for application number 3493-1. We request that “regardless of hours of operation” be removed from Specific Condition 29 and Specific Condition 18. See below:

Specific Condition 29. If data collected from the reference method during the required CEMS quality assurance RATA test are substituted for annual and renewal compliance tests for NOx, then no separate annual or renewal compliance testing while firing fuel oil shall be required. ~~regardless of hours of operation~~.

Specific Condition 18. If data collected from the reference method during the required CEMS quality assurance RATA test are substituted for annual and renewal compliance tests for NOx, then no separate annual or renewal compliance testing while firing fuel oil shall be required for Nox. ~~regardless of hours of operation~~.

Please confirm receipt of this email and feel free to call me with any questions or comments regarding our request.
Thanks so much,
Susan.

Susan B. Kennedy, QEP
Senior Environmental Affairs Specialist
Gulf Power Company
One Energy Place, Pensacola, FL 32520
850-444-6153 cell 850-336-6153

Stay connected with Gulf Power