

Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

## NOTICE OF ADMINISTRATIVE PERMIT CORRECTION

2/19/02

In the Matter of an Application for Administrative Permit Correction

Mr. W. Fred McGuire, P.E.  
Vice President Environment, Safety & Health  
Reliant Energy, Inc.  
P.O. Box 4567  
Houston, Texas 77251-4567

FINAL Permit No. 0090196-001-AV  
Indian River Plant

Based on information provided by the Department's Central District Office, the Department has determined that a minor correction to information contained in FINAL Permit Number 0090196-001-AV is required. The change corrects the language of two specific conditions to remove errors that were inadvertently included in the permit. This Administrative Permit Correction was processed as project number 0090196-002-AV, pursuant to Rule 62-210.360, F.A.C. The correction is as noted below.

- Specific Conditions A.25. and A.26. are changed as follows:

**A.25.** The Permittee shall conduct a compliance test on an *annual basis* for the following pollutant. The compliance test shall be conducted in accordance with 40 CFR 60, Appendix A, using the methods indicated.

Particulate Matter (PM/PM<sub>10</sub>) - EPA Method 5 or 17 (see Specific Condition A.18.).

An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours. [Rule 62-297.310(7)(a)4. & 5., F.A.C.]

**A.26.** The Permittee shall conduct a compliance test for each of the following pollutants *prior to obtaining a renewed operation permit*. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy this requirement. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of compliance test results for any emissions unit that, during the year prior to renewal: a) did not operate; or b) in the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours. Each compliance test shall be conducted in accordance with 40 CFR 60 Appendix A, using the method indicated.


a) Sulfur Dioxide (SO<sub>2</sub>) - EPA Method 6 or ASTM D 2880-71 for sulfur in oil.

b) Particulate Matter (PM/PM<sub>10</sub>) - EPA Method 5 or 17 (see Specific Condition A.18.).

[Rule 62-297.310(7)(a)3., F.A.C.]

This permit correction corrects and is a part of FINAL Permit Number 0090196-001-AV. This permit correction is issued pursuant to Chapter 403, Florida Statutes.

Executed in Tallahassee, Florida.

  
C.H. Fancy, P.E., Chief  
Bureau of Air Regulation

"More Protection, Less Process"

Printed on recycled paper.

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
*(Domestic Mail Only; No Insurance Coverage Provided)*

7000 0520 0020 9371 2707

Mr. W. Fred McGuire, P.E.

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
<b>Total Postage &amp; Fees</b>	<b>\$</b>

Postmark  
Here

**Recipient's Name (Please Print Clearly) (To be completed by mailer)**

Mr. W. Fred McGuire, P.E.

**Street, Apt. No.; or PO Box No.**

P.O. Box 4567

**City, State, ZIP+4**

Houston, Texas 77251-4567

PS Form 3800, February 2000

See Reverse for Instructions

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. W. Fred McGuire, P.E.  
 Vice President Environment,  
 Safety & Health  
 Reliant Energy, Inc.  
 P.O. Box 4567  
 Houston, Texas 77251-4567

2. Article Number (Copy from service label)

7000 0520 0020 9371 2707

**COMPLETE THIS SECTION ON DELIVERY**

A. Received by (Please Print Clearly) B. Date of Delivery  
 FEB 22 2002

C. Signature  
 X GEE  Agent  
 Addressee

D. Is delivery address different from item 1?  Yes  
 If YES, enter delivery address below:  No

3. Service Type  
 Certified Mail  Express Mail  
 Registered  Return Receipt for Merchandise  
 Insured Mail  C.O.D.

4. Restricted Delivery? (Extra Fee)  Yes

NOTICE OF ADMINISTRATIVE PERMIT CORRECTION  
FINAL PERMIT NUMBER 0090196-001-AV

Page 2 of 2

**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVE PERMIT CORRECTION was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 2/19/02 to the person(s) listed or as otherwise noted:

Mr. W. Fred McGuire, P.E.\*

Ms. Amy Deese, Reliant Energy Indian River Plant, US 1 and Kings Highway, Titusville, Florida 32780

Mr. Len Kozlov, P.E., Central District Office

U.S.EPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Barbara J. Friday 2/19/02  
(Clerk) (Date)