

MEMORANDUM


10/3/00

TO: Scott M. Sheplak, P.E. *smg*
FROM: Tom Cascio *10/3/00*
THROUGH: Bruce Mitchell
DATE: September 20, 2000
Re: Intent package for DRAFT Title V Air Operation Permit
No.: 0090196-001-AV
Reliant Energy, Inc.
Indian River Plant

Permit Clock: Today is ARMS Day 58
Default Date (Day 90): October 22, 2000

This permit is for an initial Title V Air Operation Permit for the subject facility that reflects the purchase of the three boilers and the lime storage silo from the Orlando Utilities Commission.

I recommend that this Intent to Issue be sent out as attached.



Jeb Bush
Governor

File / Barbara

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Signed
10/3/00
David B. Struhs
Secretary

September 19, 2000

Mr. W. Fred McGuire, P.E.
Vice President Environment, Safety & Health
Reliant Energy, Inc.
P.O. Box 4567
Houston, Texas 77251-4567

Re: DRAFT Title V Permit No.: 0090196-001-AV
Reliant Energy Indian River, L.L.C.

Dear Mr. McGuire:

One copy of the DRAFT Title V Air Operation Permit for the Indian River Plant (the three boilers and the lime storage silo), located at US 1 and Kings Highway, Titusville, Brevard County, is enclosed. The permitting authority's "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" and the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" are also included.

The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" must be published as soon as possible upon receipt of this letter. Proof of publication, i.e., newspaper affidavit, must be provided to the permitting authority's office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

Please submit any written comments you wish to have considered concerning the permitting authority's proposed action to Scott M. Sheplak, P.E., at the above letterhead address. If you have any other questions, please contact Tom Cascio at 850/921-9526.

Sincerely,

C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/tbc

Enclosures

cc: Mr. Gregg Worley, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)
Ms. Elizabeth Bartlett, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)

"More Protection, Less Process"

Printed on recycled paper.

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Fred McGuire, P.E.
Vice President
Reliant Energy, Inc.
Environment, Safety & Health
P. O. Box 4567
Houston, TX 77251-4567

2. Article Number (Copy from service label)

3 210 660 444

PS Form 3811, July 1999

Domestic Return Receipt

102595-99-M-1789

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) | B. Date of Delivery

001 - 9. 2000

C. Signature

X

GEE

Agent

Addressee

D. Is delivery address different from item 1? Yes

If YES, enter delivery address below: No

3. Service Type

Certified Mail Express Mail

Registered Return Receipt for Merchandise

Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes

Z 210 660 444

US Postal Service

Receipt for Certified Mail

No Insurance Coverage Provided.

Do not use for International Mail (See reverse)

Mr. Fred McGuire, P.E.
Vice President
Reliant Energy, Inc.
Environment, Safety & Health
P. O. Box 4567
Houston, TX 77251-4567

PS Form 3800, April 1995

Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	10-03-00 <i>SJK</i>

In the Matter of an
Application for Permit by:

Reliant Energy Indian River, L.L.C.
P.O. Box 4567
Houston, Texas 77251-4567

DRAFT Permit No.: 0090196-001-AV
Indian River Plant
Brevard County

INTENT TO ISSUE TITLE V AIR OPERATION PERMIT

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit (copy of DRAFT Permit enclosed) for the Title V source detailed in the application specified above, for the reasons stated below.

The applicant, Reliant Energy Indian River, L.L.C., applied on July 3, 2000, to the permitting authority for a Title V air operation permit for selected units of the Indian River Plant, located at US 1 and Kings Highway, Titusville, Brevard County. The application reflects the purchase of three boilers and a lime storage silo from the Orlando Utilities Commission.

The permitting authority has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-213, and 62-214, F.A.C. This source is not exempt from Title V permitting procedures. The permitting authority has determined that a Title V air operation permit is required to commence or continue operations at the described facility.

The permitting authority intends to issue this Title V air operation permit based on the belief that reasonable assurances have been provided to indicate that operation of the source will not adversely impact air quality, and the source will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C.

Pursuant to Sections 403.815 and 403.087, F.S., and Rules 62-110.106 and 62-210.350(3), F.A.C., you (the applicant) are required to publish at your own expense the enclosed "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT." The notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. Where there is more than one newspaper of general circulation in the county, the newspaper used must be one with significant circulation in the area that may be affected by the permit. If you are uncertain that a newspaper meets these requirements, please contact the permitting authority at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-1344; Fax: 850/922-6979),

within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit pursuant to Rule 62-110.106, F.A.C.

The permitting authority will issue the Title V PROPOSED Permit, and subsequent Title V FINAL Permit, in accordance with the conditions of the attached Title V DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT." Written comments should be provided to the permitting authority office. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Permit, the permitting authority shall issue another DRAFT Permit and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/488-9730; Fax: 850/487-4938). Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination;

(c) A statement of how and when each petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief;

(f) A demand for relief.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation will not be available in this proceeding.

In addition to the above, a person subject to regulation has a right to apply to the Department of Environmental Protection for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542, F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

(a) The name, address, and telephone number of the petitioner;

(b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;

(c) Each rule or portion of a rule from which a variance or waiver is requested;

(d) The citation to the statute underlying (implemented by) the rule identified in (c) above;

(e) The type of action requested;

(f) The specific facts that would justify a variance or waiver for the petitioner;

(g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and,

(h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as


each of those terms is defined in Section 120.542(2), F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the United States Environmental Protection Agency and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

Executed in Tallahassee, Florida.

**STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION**



C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT (including the PUBLIC NOTICE and the DRAFT permit) and all copies were sent by certified mail before the close of business on 10-03-00 to the person(s) listed:

Mr. W. Fred McGuire, P.E., Reliant Energy, Inc.

In addition, the undersigned duly designated deputy agency clerk hereby certifies that copies of this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT (including the PUBLIC NOTICE and the DRAFT permit) were sent by U.S. mail on the same date to the person(s) listed:

Mr. Frederick F. Haddad, Jr., Orlando Utilities Commission
Mr. Jason M. Goodwin, P.E., Reliant Energy, Inc.
Mr. Len Kozlov, P.E., Central District Office

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

Sandra G. Knight
(Clerk)

10-03-00
(Date)

PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Title V DRAFT Permit No.: 0090196-001-AV

Indian River Plant
Brevard County

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue an initial DRAFT Title V air operation permit for selected emission units (the three existing boilers and a lime storage silo) of the Indian River Plant located at US 1 and Kings Highway, Titusville, Brevard County. The application reflects the purchase of these units from the Orlando Utilities Commission. The applicant's name and address are: Mr. W. Fred McGuire, P.E., Vice President Environment, Safety & Health, Reliant Energy, Inc., P.O. Box 4567, Houston, Texas 77251-4567.

The permitting authority will issue the Title V PROPOSED Permit, and subsequent Title V FINAL Permit, in accordance with the conditions of the Title V DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions. The permitting authority will accept written comments concerning the proposed Title V DRAFT Permit issuance action for a period of 30 (thirty) days from the date of publication of this Notice. Written comments should be provided to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Permit, the permitting authority shall issue another DRAFT Permit and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57 of the Florida Statutes (F.S.). The petition must contain the information set forth below and must be filed (received) in Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/488-9730; Fax: 850/487-4938). Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of the notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the applicable time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address and telephone number of the petitioner; name address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how petitioner's substantial rights will be affected by the agency determination;

(c) A statement of how and when the petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so state;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle petitioner to relief; and

(f) A demand for relief.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available for this proceeding.

In addition to the above, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Permitting Authority:

Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 850/488-1344
Fax: 850/922-6979

Affected District Program:

Department of Environmental Protection
Central District Office
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767
Telephone: 407/894-7555
Fax: 407/897-2966

The complete project file includes the DRAFT Permit, the application, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact Scott M. Sheplak, P.E., at the above address, or call 850/921-9532, for additional information.



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary


P.E. Certification Statement

Permittee:
Reliant Energy, Inc.
Indian River Plant

DRAFT Permit Revision No.: 0090196-001-AV
Facility ID No.: 0090196

Project type: Title V Air Operation Permit Revision

I HEREBY CERTIFY that the engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).



Scott M. Sheplak, P.E.
Registration Number: 48866

09/21/00
date

Permitting Authority:
Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 850/921-9532
Fax: 850/922-6979

STATEMENT OF BASIS

Reliant Energy Indian River, L.L.C.
Indian River Plant
Facility ID No.: 0090196
Brevard County

DRAFT Title V Air Operation Permit Permit No.: 0090196-001-AV

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility described in the application, approved drawings, plans, and other documents attached hereto or on file with the Department, in accordance with the terms and conditions of this permit.

This facility consists of selected units (three boilers, and a lime storage silo) of the Indian River Plant recently purchased from the Orlando Utilities Commission.

Emissions units -001, -002, and -003 consist of three Combustion Engineering Steam Generators. The boilers may burn a variable combination of natural gas, propane, No. 6 and No. 2 fuel oils, and on-specification used oil from facility operations. Emissions units -001 and -002 share a common stack, with a height of 300 feet. Emissions unit -003 has a separate 300 foot stack. Unit -001 began operation February 1, 1960; Unit -002 September 1, 1964, and Unit -003 February 1, 1974.

The Department has determined that the appropriate particulate matter testing frequency for the fossil fuel steam generators is annually whenever fuel oil is used for more than 400 hours in the preceding year. This frequency is justified because the units 001, 002, and 003 are uncontrolled and have documented low emissions in previous emissions tests while firing fuel oil. The applicant has presented historical PM test results which show that the steady-state and soot blowing average results are well below the applicable standards of 0.1 lb/mmBtu and 0.3 lb/mmBtu, respectively. The five-year average test results for 1994-1998 for these units are as follows:

	Steady State (lb/mmBTU)	Soot-Blow (lb/mmBTU)
Unit 001	0.058	0.080
Unit 002	0.061	0.131
Unit 003	0.056	0.103

Emissions unit -008 is a lime storage silo filling system. The silo is equipped with a fabric filter baghouse made by General Resource Corporation, Model 13204.8. The baghouse is approximately 99 percent efficient to control particulate emissions. This source is located at the water treatment building. The silo began operation February 25, 1993.

Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities. Based on the initial Title V permit application received July 3, 2000, this facility is a major source of hazardous air pollutants (HAPs).

Reliant Energy Indian River, L.L.C.
Indian River Plant
Facility ID No. **0090196**
Brevard County

Initial Title V Air Operation Permit
DRAFT Permit No. **0090196-001-AV**

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section

Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
Telephone: 850/488-0114
Fax: 850/922-6979

Compliance Authority:

Department of Environmental Protection
Central District Office
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767
Telephone: 407/894-7555
Fax: 407/897-2996

TABLE OF CONTENTS

Section	Page
Placard Page.....	1
I. Facility Information.....	2
A. Facility Description	
B. Summary of Emissions Unit ID Nos. and Brief Description	
C. Relevant Documents	
II. Facility-wide Conditions.....	3
III. Emissions Unit Conditions	
A. Fossil Fuel Steam Boilers.....	5
B. Lime Storage Silo.....	16
IV. Acid Rain Part, Phase II.....	19



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

Permittee:

Reliant Energy Indian River L.L.C.
P.O. Box 4567
Houston, Texas 77251-4567

DRAFT Permit No. 0090196-001-AV

SIC Nos. 49, 4911

Project: Initial Title V Air Operation Permit

This permit is for the operation of selected units (three boilers, and a lime storage silo) of the Indian River Plant. This facility is located at US 1 and Kings Highway, Titusville, Brevard County, 32780; UTM Coordinates: Zone 17, 521.5 km East and 3151.6 km North; Latitude: 28° 29' 32" North and Longitude: 80° 46' 59" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.) and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named Permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawings, plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix U-1, List of Unregulated Emissions Units and Activities

Appendix I-1, List of Insignificant Emissions Units and Activities

APPENDIX TV-3, TITLE V CONDITIONS (version dated 4/30/99)

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)

TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)

Figure 1 - SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM REPORT (version dated 7/96)

Phase II Acid Rain Permit Application dated July 19, 2000

Alternate Sampling Procedures: ASP Number 97-B-01 and ASP 92-0-01

Effective Date: January 1, 2000

Renewal Application Due Date: July 5, 2004

Effective Date:

Expiration Date: December 31, 2004

Howard L. Rhodes, Director
Division of Air Resources
Management

HLR/tbc

"More Protection, Less Process"

Printed on recycled paper.

Section I. Facility Information

Subsection A. Facility Description

This facility (selected units of an original Orlando Utilities Commission power plant) consists of three boilers, and a lime storage silo. Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities.

Based on the initial Title V permit application received July 3, 2000, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions

E.U. ID No.	Brief Description
001	87 MW Unit No.1 Boiler
002	188 MW Unit No.2 Boiler
003	328 MW Unit No.3 Boiler
008	Lime Storage Silo
009	Unregulated Emissions Units and Activities

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit ID Nos. on all test report submittals, applications, and other correspondence.

Subsection C. Relevant Documents

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the Permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Transfers

These documents are on file with the permitting authority:

Initial Title V Permit Application received July 3, 2000

Section II. Facility-wide Conditions

The following conditions apply facility-wide:

1. APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99), is a part of this permit. {Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the Permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}

2. Not Federally Enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.

[Rule 62-296.320(2), F.A.C.]

3. General Particulate Emission Limiting Standards. General Visible Emissions Standard.

Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1. & 4., F.A.C.]

{Permitting Note: Although the Permittee is not required to perform a visible emissions compliance test to demonstrate compliance with the facility-wide limitations annually or before renewal, if the Department believes that the general visible emissions standard is being violated, the Department may require that the owner or operator perform a visible emissions compliance test per Chapter 62-297.310(7)(b), Special Compliance Tests. In addition, Department personnel who are certified to perform visible emissions tests may determine compliance with the general visible emissions standard.}

4. Prevention of Accidental Releases (Section 112(r) of CAA).

a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable ; and

b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

[40 CFR 68]

5. Unregulated Emissions Units and Activities. Appendix U-1, List of Unregulated Emissions Units and Activities, is a part of this permit.

[Rule 62-213.440(1), F.A.C.]

6. Insignificant Emissions Units and Activities. Appendix I-1, List of Insignificant Emissions Units and Activities, is a part of this permit.

[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]

7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.

[Rule 62-296.320(1)(a), F.A.C.]

8. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.
[Rule 62-213.440, F.A.C.]

9. **Not federally enforceable.** The Permittee shall take reasonable precautions to prevent emissions of unconfined particulate matter at this facility. These precautions include receiving delivery of fuel oil by barge rather than trucks, and using paved roads for the fuel trucks which deliver vehicle fuel. Additionally, watering will be used as needed to prevent emissions from unpaved areas.
[Rule 62-296.320(4)(c)2., F.A.C.]

10. The Permittee shall submit all compliance, annual operating reports and other correspondence required of this permit to:

Department of Environmental Protection
Central District Office
3319 Maguire Boulevard
Suite 232
Orlando, Florida 32803-3767
Telephone: 407/894-7555
Fax: 407/897-2996

11. Any reports, data, notification, certifications, and requests required to be sent to the United States Environmental Protection Agency should be sent to:

United States Environmental Protection Agency
Region 4
Air, Pesticides, & Toxics Management Division
Air and EPCRA Enforcement Branch, Air Enforcement Section
61 Forsyth Street
Atlanta, Georgia 30303
Telephone: 404/562-9155
Fax: 404/562-9163

{Permitting note: Condition no. 51 of Appendix TV-3, lists the necessary elements of a compliance certification required under 40 C.F.R. 70.6(c)(5)(iii).}

Section III. Emissions Unit Conditions

Subsection A. Fossil Fuel Steam Boilers

E.U. ID No.	Brief Description
001	87 MW Unit No.1 Boiler
002	188 MW Unit No. 2 Boiler
003	328 MW Unit No.3 Boiler

Emissions units 001, 002, and 003 consist of three Combustion Engineering Steam Generators. The boilers may burn a variable combination of natural gas, propane, No. 6 and No. 2 fuel oils, and on-specification used oil. Emissions units 001 and 002 share a common stack, with a height of 300 feet. Emissions unit 003 has a separate 300 foot stack. Unit 001 began operation on February 1, 1960; Unit 002 on September 1, 1964, and Unit 003 on February 1, 1974.

{Permitting note: The emissions units are regulated under Acid Rain-Phase II, and Fossil Fuel Steam Generators with more than 250 million Btu per Hour Heat Input - Rule 62-296.405, F.A.C. and AO05-183384}

The following conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operating heat input rate is as follows:

<u>Unit No.</u>	<u>Fuel Type</u>	<u>MMBtu/Hour</u>
1	Natural Gas	865.5
1	Oil	832.2
2	Natural Gas	2248.7
2	Oil	2016.5
3	Natural Gas	3208.5
3	Oil	3048.8

Additionally, on-specification used oil may be fired at the rate of the lesser of :

- a. Up to 1.5 million gallons per year; or
- b. the equivalent heat input of 10 percent or less of the permitted heat input of No. 6 Fuel Oil while combusting either No. 6 Fuel Oil or Natural Gas.

{Permitting note: See Specific Condition A.38.}

[Rules 62-4.160(2), 62-210.200 (PTE), and 62-296.405, F.A.C.]

A.2. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition A.21.

[Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation - Fuels. The only fuels allowed to be burned are No. 2 fuel oil, No. 6 residual oil, natural gas, propane, and on-specification used oil. The used oil shall comply with the limits given in Specific Condition A.38. Off-specification used oil shall not be burned.

[Rules 62-4.160(2), 62-210.200, 62-213.440(1), F.A.C., and AO05-183384]

A.4. Hours of Operation. These emissions units may operate 8,400 hours per year. The facility is required to keep daily records of the operating hours and associated fuel use.

[Rules 62-210.200 and 62-213.440(1)(b)1.b., F.A.C., (PTE)]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.5. Visible Emissions - Steady State. Visible emissions shall not exceed 40 percent opacity. Emissions units governed by this visible emissions standard shall compliance test for particulate matter emissions annually.

[Rule 62-296.405(1)(a), F.A.C. and Order OGC File Nos. 88-1257, 88-1258, and 88-1259 dated March 13, 1989.]

A.6. Visible Emissions - Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3 hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.

Visible emissions above 60 percent opacity shall be allowed for not more than four, six-minute periods, during the three-hour period of excess emissions allowed by this subparagraph, for boiler cleaning and load changes, at units which have installed and are operating, or have committed to install or operate, continuous opacity monitors.

[Rule 62-210.700(3), F.A.C.]

A.7. Particulate Matter - Steady State. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods. {Permitting note: The averaging time shall correspond to the cumulative sample time, as specified in the reference test method.}

[Rule 62-296.405(1)(b), F.A.C.]

A.8. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change. {Permitting note: The averaging time shall correspond to the cumulative sample time, as specified in the reference test method.}

[Rule 62-210.700(3), F.A.C.]

A.9. Sulfur Dioxide. Sulfur dioxide emissions when burning liquid fuel shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods.

[Rule 62-296.405(1)(c)1.j., F.A.C.]

A.10. Sulfur Dioxide - Sulfur Content. The as-fired sulfur content of the fuel(s) shall not exceed 2.5 percent, by weight. See Specific Conditions A.14., A.19., and A.20.

[Rule 62-296.405(1)(e)3., F.A.C.]

Excess Emissions

A.11. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be

minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

A.12. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

A.13. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

Monitoring Requirements

A.14. Sulfur Dioxide. The permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit. Reliant Energy Indian River L.L.C. (Reliant Energy) will perform a daily sulfur content analysis of the as-fired fuel. See Specific Condition **A.33.** for recordkeeping requirements. This protocol is allowed since the emissions unit has no operating flue gas desulfurization device. See Specific Conditions **A.19.**, and **A.20.**

[Rule 62-296.405(1)(f)1.b., F.A.C.]

A.15. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.16. Visible Emissions. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. See Specific Condition **A.17.**

[Rule 62-296.405(1)(e)1., F.A.C.]

A.17. DEP Method 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.

2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:

- a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
- b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.

[Rule 62-297.401, F.A.C.]

A.18. Particulate Matter. The test method for particulate emissions shall be EPA Method 17 incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. Reliant Energy may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 17.

[Rule 62-296.405(1)(e)2., F.A.C.]

A.19. Sulfur Dioxide. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C. Fuel sampling and analysis may be used as an alternate sampling procedure if such a procedure is incorporated into the operation permit for the emissions unit. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedances of the sulfur dioxide emissions limiting standard are occurring. Results of an approved fuel sampling and analysis program shall have the same effect as EPA Method 6 test results for purposes of demonstrating compliance or noncompliance with sulfur dioxide standards. The permittee may use the EPA test methods referenced above to demonstrate compliance; **however, the permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit. Reliant Energy will perform a daily analysis of the as-fired fuel.** See Specific Condition A.20.

[Rules 62-296.405(1)(e)3., 62-297.620, F.A.C.]

A.20. The following fuel sampling and analysis protocol shall be used as an alternate sampling procedure:

- a. Determine and record the **as-fired** fuel sulfur content, percent by weight, for liquid fuels using either ASTM D2622-94, ASTM D4294-90 (95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 (or latest editions).

- b. Record daily the amount of each fuel fired, the density of each fuel, and the percent sulfur content by weight of the as-fired fuel.
- c. Utilize the information in a. and b., above, to calculate the SO₂ emission rate to ensure compliance at all times.

[Rules 62-297.440, and 62-297.620(2)(d), F.A.C.]

A.21. Operating Rate During Testing. Testing of emissions shall be conducted with each emissions unit operating at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.
[Rules 62-297.310(2) & (2)(b), F.A.C.]

A.22. The particulate matter and visible emissions test shall be conducted concurrently.
[Rule 62-4.070(3), F.A.C., and AO05-183384]

A.23. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities. (See attachment.)
[Rule 62-297.310(6), F.A.C.]

A.24. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

1. (Not applicable)

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid fuel for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), a formal compliance test shall be conducted for:

a. Visible emissions;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.

6. (Not applicable)

7. (Not applicable)

8. (Not applicable)

9. (See Specific Condition A.37.)

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

[Rule 62-297.310(7)(a)2., 3., 4., 5., 9., 10., F.A.C.; SIP approved]

A.25. The Permittee shall conduct a compliance test on an *annual basis* for each of the following pollutants. Each compliance test shall be conducted in accordance with 40 CFR 60, Appendix A, using the method indicated.

a) Oxides of Nitrogen (NO_x) - EPA Method 20.

b) Carbon Monoxide (CO) - EPA Method 10.

c) Beryllium (Be) - EPA Method 104.

d) Particulate Matter (PM/PM₁₀) - EPA Method 5.

An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

[Rule 62-297.310(7)(a)4. & 5., F.A.C.]

A.26. The Permittee shall conduct a compliance test for each of the following pollutants *prior to obtaining a renewed operation permit*. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy this requirement. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of compliance test results for any emissions unit that, during the year prior to renewal: a) did not operate; or b) in the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours. Each compliance test shall be conducted in accordance with 40 CFR 60 Appendix A, using the method indicated.

a) Sulfur Dioxide (SO₂) - EPA Method 6 or ASTM D 2880-71 for sulfur in oil.

b) Particulate Matter (PM/PM₁₀) - EPA Method 5.

c) Volatile Organic Compounds (VOC) - EPA Method 25.

[Rule 62-297.310(7)(a)3., F.A.C.]

A.27. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of Reliant Energy, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.28. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.
[Rule 62-297.310(3), F.A.C.]

A.29. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. **Opacity Compliance Tests.** When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

a. (not applicable)

b. (not applicable)

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1. (See attachment.)

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

A.30. Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require Reliant Energy to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7)(b), F.A.C., SIP approved]

A.31. Waiver of Compliance Test Requirements. If Reliant Energy is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate

means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7)(c), F.A.C., SIP approved]

A.32. COMS for Periodic Monitoring. Reliant Energy shall install continuous opacity monitoring systems (COMS) pursuant to 40 CFR Part 75. Reliant Energy shall maintain and operate the COMS and shall make and maintain records of opacity measured by the COMS, for purposes of periodic monitoring.

[Rule 62-213.440, F.A.C., and applicant requested]

Reporting and Recordkeeping Requirements

A.33. On a quarterly basis, Reliant Energy shall submit a report showing the types of fuels burned. Also, state the sulfur content of the as-fired fuel, recorded from the daily analysis required of Specific Condition **A.19**. The records shall be maintained for a minimum of five years and shall be made available to the Department upon request. The permittee shall submit a copy of the fuel oil analysis for the fuel oil burned during each compliance test with the results from the test.

[Rule 62-4.070(3), F.A.C., and AO05-183384]

A.34. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, the permittee shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

A.35. Quarterly Excess Emissions Reporting Requirements. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the permittee of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.

[Rule 62-296.405(1)(g), F.A.C.]

A.36. Test Reports - General Requirements.

(a) The owner or operator an emissions unit for which a compliance test is required shall file a report with the Department's Central District Office on the results of each such test.

(b) The required test report shall be filed with the Department's Central District Office as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.

7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.
[Rule 62-297.310(8), F.A.C.]

A.37. Notification. Reliant Energy shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted.
[Rule 62-297.310(7)(a)9., F.A.C.]

Miscellaneous Conditions

A.38. Used Oil. Burning of on-specification used oil is allowed by these emissions units in accordance with all other conditions of this permit and the following conditions:

- a. **On-specification Used Oil Emissions Limitations:** This emissions unit is permitted to burn only on-specification used oil, which contains a PCB concentration of less than 50 ppm. "On-specification" used oil is defined as used oil that meets the specifications of 40 CFR 279.11, Table 1, Standards for the Management of Used Oil, as listed below. **"Off-specification" used oil shall not be burned.** Used oil which exceeds any of the allowable levels of the constituents and properties in the following table is considered off-specification used oil.

CONSTITUENT/PROPERTY	ALLOWABLE LEVEL
Arsenic	5 ppm maximum
Cadmium	2 ppm maximum
Chromium	10 ppm maximum
Lead	100 ppm maximum
Total Halogens	1000 ppm maximum
Flash point	100 degrees F minimum

- b. Quantity Limitation: No more than 1.5 million gallons of on-specification used oil may be burned during any federal fiscal year.
- c. PCB Limitation: Used oil containing a PCB concentration of 50 or more ppm shall not be burned at this facility. Used oil shall not be blended to meet this requirement.
- d. Operational Requirements: On-specification used oil with a PCB concentration of greater than or equal to 2, and less than 50 ppm shall be burned only at normal source operating temperatures. Used oil with a PCB concentration of greater than or equal to 2 ppm shall not be burned during periods of startup or shutdown.
- e. Testing Requirements: For used oil generated on-site, Reliant Energy shall sample and analyze each batch of used oil to be burned for the following parameters:
 Arsenic, cadmium, chromium, lead, total halogens, flash point and PCBs.
 Testing (sampling, extraction and analysis) shall be performed using approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods).
 For used oil obtained off-site, Reliant Energy shall receive from the marketer, for each load of used oil received, a *certification* that the used oil meets the criteria for on-specification used oil and contains a PCB concentration of no greater than 49 ppm. This certification shall also describe the basis for the certification, such as analytical results. Any claim that used oil does not contain quantifiable levels of PCBs (that is, the used oil contains less than 2 ppm of PCBs) must be documented by testing or other information. The first person making that claim is responsible for furnishing the documentation. The documentation can be tests, personal or special knowledge of the source and composition of the used oil, or a certification from the person generating the used oil claiming that it contains no detectable PCBs. If Reliant Energy does not receive certification from the marketer as described above, they must sample and test each load of used oil as outlined above for on-site testing. If Reliant Energy relies on the certification from the marketer, Reliant Energy shall, at a minimum, each calendar quarter, test one load of the used oil received, selected at random, for the above parameters. If the analytical results show that the used oil does not meet the “on-specification” criteria, or that it contains PCB’s of 50 ppm or greater, Reliant Energy shall immediately notify and provide these results to the Department’s Central District Office and immediately stop burning the used oil.
- f. Record Keeping Requirements: Reliant Energy shall obtain, make, and keep the following records for used oil in a form suitable for inspection by the Department:
 - (1) The gallons of on-specification used oil generated and burned each month. (This record shall be completed no later than the fifteenth day of the succeeding month.)
 - (2) The total gallons of on-specification used oil burned in the preceding consecutive 12-month period. (This record shall be completed no later than the fifteenth day of the succeeding month.)
 - (3) The name and address of all marketers delivering used oil to the facility.

- (4) Copies of the marketer certifications and any supporting information.
 - (5) Documentation that the used oil contains less than 2 ppm PCBs, if claimed, including the name and address of the person making the claim.
 - (6) Results of the analyses required above.
 - (7) A copy of the notice to EPA and a copy of the one-time written notice provided to each marketer.
 - (8) Total lead emissions as a result of burning on-specification used oil on a monthly basis.
- g. Reporting Requirements: Reliant Energy shall submit to the Department, within thirty days of the end of each calendar quarter, the analytical results and the total amount of on-specification used oil generated and burned during the quarter.
- Reliant Energy shall submit, with the Annual Operation Report form, the analytical results and the total amount of on-specification used oil burned during the previous calendar year.

[Rule 62-4.070(3), F.A.C., and 40 CFR 279 and 40 CFR 761]

Subsection B. Lime Storage Silo

E.U. ID No.	Brief Description
008	Lime Storage Silo

Emissions unit 008 is a lime storage silo filling system. The silo is equipped with a fabric filter baghouse made by General Resource Corporation, Model 13204.8. The baghouse is approximately 99 percent efficient to control particulate emissions. This source is located at the water treatment building. The silo began operation February 25, 1993.

Essential Potential to Emit (PTE) Parameters

B.1. Capacity.

- (a) This silo is permitted to be loaded 14 hours per week.
 - (b) The maximum permitted loading rate is ten (10) tons per hour.
 - (c) The facility is required to keep records of the operating hours and loading rate.
- [Rules 62-4.160(2), 62-210.200 (PTE), 62-213.440(1)(b)1.b., F.A.C., and AO05-229996]

Emission Limitations and Standards

B.2. (a) No owner or operator of an emissions unit source governed by Rule 62-296.711, F.A.C., shall cause, permit, or allow any visible emissions (five percent opacity) from such emissions unit.

(b) If, in order to comply with the requirements of paragraph (a) above, it is necessary to totally or partially enclose an operation and exhaust particulate laden gases through a vent or stack, emissions of particulate from such vent or stack shall not exceed 0.03 gr/dscf.

(c) An owner or operator may request the Department to determine that the emission standards of Rule 62-296.711(2)(a) and (b), F.A.C., do not constitute RACT for a facility. If the Department finds that the emission standards do not represent RACT, the Department shall make a determination of RACT for that facility.

[Rule 62-296.711, F.A.C.]

B.3. Unconfined Emissions. Particulate matter emissions from plant grounds, including the transfer point at which materials are loaded into trucks shall be subject to the following:

- a) Area must be watered down should unconfined emissions occur.
- b) The loading operation shall be maintained and properly operated.

[Rule 62-296.320(4)(c), F.A.C., and AO05-229996]

Test Methods and Procedures

B.4. (a) An annual test method for visible emissions shall be performed. The test method shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C.

(b) A visible emissions test indicating no visible emissions (5 percent opacity) may be submitted in lieu of a particulate stack test for materials handling emissions units subject to this rule, where the emissions unit is equipped with a baghouse.

(c) The permittee must perform and record the results of a qualitative observation of opacity (40 C.F.R. Part 60, Method 22) at least once on each day while the loading operations are taking place. The records of these observations should indicate whether or not any abnormal visible emissions are detected and include color, duration, and density of the plume, as well as the cause and corrective action taken for any abnormal visible emissions. If an abnormal visible emission is detected, a Method 9 survey shall be conducted during lime loading operations, within 24 hours of the

qualitative survey. If lime filling does not occur within 24 hours of the detected visible emission, a Method 9 survey shall occur at the next time the silo is loaded.

(d) Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.
[Rules 62-213.440(1)(b)1.b. and 62-297, F.A.C.]

B.5. DEP Method 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.

2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:

- a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
- b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.

[Rule 62-297.401, F.A.C.]

B.6. Operating Rate During Testing. Unless otherwise stated in the applicable emission limiting standard rule, testing of emissions shall be conducted with the emissions unit operating at 90 to 100 percent of the maximum operation rate allowed by permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rule 62-297.310(2), F.A.C.]

B.7. Required Sampling Time.

Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows: For batch, cyclical processes, or other operations which are normally completed within

less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.

[Rule 62-297.310(4)(a)(2)a., F.A.C.]

B.8. During compliance testing, the silo must be operated at the highest pressure and filling rate ever intended to be used. The process rate achieved during the compliance test must be recorded on the visible emission test report.

[Rule 62-4.070(3), F.A.C., and AO05-229996]

Reporting and Recordkeeping

B.9. Reliant Energy shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for Reliant Energy.

[Rule 62-297.310(7)(a)9., F.A.C.,]

B.10. The required test report shall be filed with this office as soon as practical but no later than 45 days after the last sampling run of each test is completed.

Each calendar year on or before March 1, submit an Annual Operations Report DEP Form 62-210.900(4) for the preceding calendar year.

[Rule 62-297.310(8)(b), F.A.C, and AO05-229996]

B.11. Reliant Energy shall keep records of the operating hours and process loading rate of the lime storage silo to ensure continuous compliance with the limits in Specific Condition **B.1.**

[Rules 62-4.160(2), 62-210.200 (PTE), and 62-4.070(3), F.A.C.]

Qualitative Opacity Monitoring

B.12. Reliant Energy shall perform and record the results of a qualitative observation of opacity (40 CFR 60, Method 22) at least once on each day while the loading operations are taking place. The records of these observations should indicate whether or not any visible emissions are detected and include color, duration and density of the plume, as well as the cause and corrective action taken for any visible emissions. If a visible emission is detected, corrective action should be taken and a Method 9 observation shall be conducted during lime loading operations, within 24 hours of the qualitative survey. If lime loading does not occur within 24 hours of the detected visible emission a Method 9 observation shall be conducted the next time the silo is loaded. {Permitting note: It is presumed that the threshold of visibility for opacity is equal to 5%.}

[Rules 62-213.440 and 62-4.070(3), F.A.C.]

IV. Acid Rain Part

Indian River Plant

Operated by: Orlando Utilities Commission

ORIS code: 55318

The emissions units listed below are regulated under Acid Rain Part, Phase II.

E.U. ID No.	Description
001	87 MW Unit No.1 Boiler
002	188 MW Unit No.2 Boiler
003	328 MW Unit No.3 Boiler

1. The Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

a. DEP Form No.62-210.900(1)(a), version 07/01/95, received July 24, 2000.

[Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit are:

E.U. ID No.	EPA ID #	Year	2000	2001	2002	2003	2004
001	1 IRP1	SO ₂ allowances, under Table 2 of 40 CFR 73	1192*	1192*	1192*	1192*	1192*
002	2 IRP2	SO ₂ allowances, under Table 2 of 40 CFR 73	1569*	1569*	1569*	1569*	1569*
003	3 IRP3	SO ₂ allowances, under Table 2 of 40 CFR 73	3646*	3646*	3646*	3646*	3646*

*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the US EPA under Table 2 of 40 CFR 73.

3. Comments, notes, and justifications: Phase II Permit Application received July 24, 2000.

4. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

c. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

5. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.
{See condition No.51., Appendix TV-3, Title V Conditions.}
[Rule 62-214.420(11), F.A.C.]

6. Where an applicable requirement of the Act is more stringent than applicable regulations promulgated under Title IV of the Act, both provisions shall be incorporated into the permit and shall be enforceable by the Administrator.
[40 CFR 70.6(a)(1)(ii); and, Rule 62-210.200, F.A.C., Definitions – Applicable Requirements.]

Appendix U-1, List of Unregulated Emissions Units and Activities

Reliant Energy Indian River L.L.C.
Indian River Plant

DRAFT Permit No. 0090196-001-AV

Unregulated Emissions Units and Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and activities are neither ‘regulated emissions units’ nor ‘exempt emissions units’.

E.U. ID No.	Brief Description of Emissions Units and Activities
009	Three No. 6 Fuel Oil Storage Tanks (two with 3.67 million gallon capacity, one with 7.5 million gallon capacity)
	No. 2 Fuel Oil Storage Tank (34,500 gallon capacity)
	One Gasoline Fuel Storage “day” Tank (500 gallon capacity)
	Fuel loading and unloading activities

Appendix I-1, List of Insignificant Emissions Units and Activities

Reliant Energy Indian River L.L.C.
Indian River Plant

DRAFT Permit No. 0090196-001-AV

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62-210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and Activities

1. Internal combustion engines in boats, aircraft and vehicles used for transportation of passengers or freight.
2. Cold storage refrigeration equipment, except for any such equipment located at a Title V source using an ozone-depleting substance regulated under 40 CFR Part 82.
3. Vacuum pumps in laboratory operations.
4. Equipment used for steam cleaning.
5. Belt or drum sanders having a total sanding surface of five square feet or less and other equipment used exclusively on wood or plastics or their products having a density of 20 pounds per cubic foot or more.
6. Equipment used exclusively for space heating, other than boilers.
7. Laboratory equipment used exclusively for chemical or physical analyses.
8. Brazing, soldering or welding equipment.
9. One or more emergency generators located within a single facility provided:
 - a. None of the emergency generators is subject to the Federal Acid Rain Program; and
 - b. Total fuel consumption by all such emergency generators within the facility is limited to 32,000 gallons per year of diesel fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
10. One or more heating units and general purpose internal combustion engines located within a single facility provided:
 - a. None of the heating units or general purpose internal combustion engines is subject to the Federal Acid Rain Program; and
 - b. Total fuel consumption by all such heating units and general purpose internal combustion engines within the facility is limited to 32,000 gallons per year of diesel

fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

11. Fire and safety equipment.

12. Surface coating operations within a single facility if the total quantity of coatings containing greater than 5.0 percent VOCs, by volume, used is 6.0 gallons per day or less, averaged monthly, provided:

a. Such operations are not subject to a volatile organic compound Reasonably Available Control Technology (RACT) requirement of Chapter 62-296, F.A.C.; and

b. The amount of coatings used shall include any solvents and thinners used in the process including those used for cleanup.

13. Surface coating operations utilizing only coatings containing 5.0 percent or less VOCs, by volume.

14. Degreasing units using heavier-than-air vapors exclusively, except any such unit using or emitting any substance classified as a hazardous air pollutant.

Note: No exemption shall be granted to any emissions unit or activity if:

1. Such unit or activity would be subject to any unit-specific applicable requirement;

2. Such unit or activity, in combination with other units and activities proposed for exemption, would cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); or

3. Such unit or activity would emit or have the potential to emit:

a. 500 pounds per year or more of lead and lead compounds expressed as lead;

b. 1,000 pounds per year or more of any hazardous air pollutant;

c. 2,500 pounds per year or more of total hazardous air pollutants; or

d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

Appendix H-1, Permit History/ID Number Changes

Reliant Energy Indian River L.L.C.
Indian River Plant

DRAFT Permit No. 0090196-001-AV
Facility ID No. 0090196

Permit History:

E.U. ID No	Description	Permit No.	Issue Date	Expiration Date	Extended Date¹	Revised Dates
001, 002, & 003	Boiler Units No. 1, 2, & 3	OGC FILE NO. 88-1257, 88-1258, & 88-1259 AO05-183384 0090008-001-AV	03/13/89 04/26/91 01/01/00	 04/15/96	 08/14/96	
008	Lime Storage Silo	AO05-229996 0090008-001-AV	06/03/93 01/01/00	05/30/98		

ID Number Changes:

From: Facility ID No. 30ORL050008
To: Facility ID No. 0090008

Notes: 1 - AO permits automatic extensions in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

{Rule 62-213.420(1)(b)2., F.A.C., allows Title V Sources to operate under existing valid permits that were in effect at the time of application until the Title V permit becomes effective.}

Table 1-1, Summary of Air Pollutant Standards and Terms

Reliant Energy Indian River, L.L.C.
 Indian River Plant

Permit # 0090196-001-AV
 Facility ID # 0090196

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 001, 002, 003 Boilers 1, 2, and 3

Pollutant/Parameter	Fuel	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citations	See Permit Condition
			Standards	lbs./hour	TPY	lbs./hour	TPY		
SO2	All	8,400	2.75 lbs/MMBtu					Rule 62-296.405(1)(c)1.j	III. A.9
PM	All		0.1 lbs/MMBtu 0.3 lbs/MMBtu for 3hr. per 24 hours (sootblowing)					Rule 62-296.405(1)(b) Rule 62-210.700(3)	III. A.7 III. A.8
VE	All		20%; 40%@ 2min/hr. 60% for 3hr./24 hours (sootblowing)				n/a	Rule 62-296.405(1)(a) Rule 62-210.700(3)	III. A.5 III. A.6

Notes: * -- Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1lb/MMBtu.
 * -- Equivalent Emissions provided for information only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Reliant Energy Indian River, L.L.C.
 Indian River Plant

Permit # 0090196-001-AV
Facility ID # 0090196

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 008

Lime Storage Silo

Pollutant	Process Rate	Allowable Emissions	Equivalent Emissions		Regulatory Citations	See Permit Condition
			lbs./hour	TPY		
Particulate Matter	10 tons per hour	0.03 gr/dscf.	n/a	n/a	Rule 62-296.711	III.B.2.
Visible Emissions	10 tons per hour	5% Opacity	n/a	n/a	Rule 62-296.711	III.B.2.

Notes:

Table 2-1, Summary of Compliance Requirements

Reliant Energy Indian River, L.L.C.
Indian River Plant

Permit # 0090196-001-AV
Facility ID # 0090196

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 001, 002, 003 Boilers 1, 2, and 3

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS**	Permit Condition
SO2	All Fuels	Fuel sampling & analysis	Daily sampling of as-fired fuel	1-Oct			III. A.19
PM	All Fuels	EPA Method 5 or 17	annual	001: 1-Oct 002 & -003: -23-Aug			III. A.18
VE	All Fuels	DEP Method 9	annual	001: 1-Oct 002 & -003: -23-Aug	1 hour		III. A.16

Notes:

*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

**CMS = continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Reliant Energy Indian River, L.L.C.
Indian River Plant

Permit # 0090196-001-AV
Facility ID # 0090196

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 008 **Lime Storage Silo**

Pollutant/ Parameter	Material	Compliance Method	Frequency of Sampling	Frequency Base Date*	Min. Compliance Test Duration	CMS**	Permit Condition
PM	Lime	VE Test in lieu of PM test since source has baghouse	annual	1-Mar	30 minutes or one batch cycle	n/a	III.B.4.
VE	Lime	DEP Method 9	annual	1-Mar	30 minutes or one batch cycle	n/a	III.B.4.

Notes:

*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

**CMS = continuous monitoring system

4. Professional Engineer Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [X], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

[Handwritten Signature]

Signature

10/26/00

Date

(seal)

* Attach any exception to certification statement.

