



Wheelabrator South Broward, Inc.
4400 South State Road 7
Ft. Lauderdale, FL 33314

REPORT ON COMPLIANCE TESTING

Performed for:
WHEELABRATOR SOUTH BROWARD, INC.
UNITS 1, 2 AND 3 SDA INLETS, FF OUTLETS, ASH HANDLING
SYSTEM AND LIME SILO VENT
FT. LAUDERDALE, FL
VOLUME I OF II

CleanAir Project No: 10955-4
Revision 0: May 5, 2010


To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program.

Submitted by,



Scott Brown
Project Manager
sbrown@cleanair.com
(800) 627-0033 ext. 4544

Reviewed by,



Mark Roach, P.E.
Engineering Group Technical Leader
mroach@cleanair.com
(800) 627-0033 ext. 4599



Wheelabrator South Broward Inc.

A Waste Management Company

4400 South State Road 7
Ft. Lauderdale, FL 33314
(954) 581-6606
(954) 581-6705 Fax

May 6, 2010

UPS#7007268000087713974

Mr. Lennon Anderson
Air Program Administrator
Florida Department of Environmental Protection
Southeast District
400 North Congress Ave., Suite 200
West Palm Beach, FL 33401

RECEIVED

MAY 07 2010

**BUREAU OF
AIR REGULATION**

Re: Wheelabrator South Broward
2010 Annual Compliance Stack Test and RATA Reports

Dear Mr. Anderson:

Please find enclosed a copy of the final compliance stack test report and the continuous emissions monitoring system certification RATA report for testing conducted on March 22-24 of this year by Clean Air Engineering, Inc.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 581-6606.

Sincerely,


Ganeesh Siewrattan
Operations Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement
Branch, Air Enforcement Section (with) UPS#7007268000087713981
FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section,
(with) UPS#7007268000087713998
Broward County Department of Planning and Environmental Protection, Air Quality Division
(with) UPS#7007268000087714001
Chuck Faller (with)
Ram Tewari - BCWRS (without)
Tim Porter (without)
Rob French - MPI (with) UPS#7007268000087714018



WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

REVISION HISTORY

REPORT ON COMPLIANCE TESTING

DRAFT REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
D0a	04/23/10	All	Draft version of original document.

FINAL REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
0	05/05/10	All	Final version of original document.

CONTENTS

1 PROJECT OVERVIEW 1-1

INTRODUCTION 1-1

 Key Project Participants 1-1

 Test Program Parameters 1-2

TEST PROGRAM SYNOPSIS 1-3

 Test Schedule 1-3

 Table 1-1: Schedule of Activities 1-3

 Results Summary 1-4

 Table 1-2: Summary of Test Results 1-4

 Table 1-3: Subpart Cb Required Operating Data 1-5

 Table 1-4: Opacity and Fugitive Emission Test Results 1-5

 Discussion of Test Program 1-6

2 RESULTS 2-1

 Table 2-1: Unit 1 FF Outlet – Particulate and Metals 2-1

 Table 2-2: Unit 1 SDA Inlet and FF Outlet – Mercury 2-2

 Table 2-3: Unit 1 FF Outlet - Fluorides 2-3

 Table 2-4: Unit 1 FF Outlet and SDA Inlet - Hydrogen Chloride 2-4

 Table 2-5: Unit 2 FF Outlet – Particulate and Metals 2-5

 Table 2-6: Unit 2 SDA Inlet and FF Outlet – Mercury 2-6

 Table 2-7: Unit 2 FF Outlet - Fluorides 2-7

 Table 2-8: Unit 2 FF Outlet - PCDDs/PCDFs 2-8

 Table 2-9: Unit 2 FF Outlet and SDA Inlet - Hydrogen Chloride 2-9

 Table 2-10: Unit 3 FF Outlet – Particulate and Metals 2-10

 Table 2-11: Unit 3 SDA Inlet and FF Outlet – Mercury 2-11

 Table 2-12: Unit 3 FF Outlet - Fluorides 2-12

 Table 2-13: Unit 3 FF Outlet and SDA Inlet - Hydrogen Chloride 2-13

 Table 2-14: Units 1, 2 and 3 FF Outlets – Opacity by COMS 2-14

 Table 2-15: Ash Handling System - Fugitive Emissions 2-15

 Table 2-16: Lime Silo Fabric Filter Outlet - Visible Emissions 2-15

 Table 2-17: Air Flow Summary 2-16

 Table 2-18: Quality Control and Quality Assurance PCDD/PCDF - Extraction Standard
Percent Recoveries 2-17

 Table 2-19: Quality Control and Quality Assurance PCDD/PCDF – CS/SS Percent
Recoveries 2-17

 Table 2-20: Quality Control and Quality Assurance - Metals 2-18

 Table 2-22: Quality Control and Quality Assurance – Method and Field Blanks 2-20

 Table 2-23: Quality Control and Quality Assurance - Miscellaneous 2-21

CONTENTS

3 DESCRIPTION OF INSTALLATION..... 3-1
PROCESS DESCRIPTION..... 3-1
 Figure 3-1: General Process Schematic..... 3-1
 Figure 3-2: Process Schematic..... 3-2
 Table 3-1: Unit 1 Compliance Test Process Data 3-3
 Table 3-2: Unit 2 Compliance Test Process Data 3-4
 Table 3-3: Unit 3 Compliance Test Process Data 3-5
DESCRIPTION OF SAMPLING LOCATIONS..... 3-6
 Table 3-4: Sampling Points 3-6
 Figure 3-3: SDA Inlets - Sampling Point Determination (HCl Sampling) (Units 1, 2 and 3 are identical)..... 3-7
 Figure 3-4: SDA Inlets - Sampling Point Determination (Hg Sampling) (Units 1, 2 and 3 are identical)..... 3-8
 Figure 3-5: FF Outlets - Sampling Point Determination (Units 1, 2 and 3 are identical) 3-9

4 METHODOLOGY 4-1
 Table 4-1: Summary of Sampling Procedures 4-1

5 APPENDIX..... 5-1
TEST METHOD SPECIFICATIONS A
SAMPLE CALCULATIONS..... B
PLANT DATA..... C
PARAMETERS D
QA/QC DATA..... E
ASTM D 6866-08 AND 7459-08 CO₂ SAMPLING/ANALYSIS RESULTS..... F
FIELD DATA G
FIELD DATA PRINTOUTS H
LABORATORY DATA..... I
PERTINENT CERTIFICATIONS J
CORRESPONDENCE AND CLARIFICATIONS K

PROJECT OVERVIEW

1-1

INTRODUCTION

Wheelabrator South Broward, Inc. operates a Refuse-to-Energy facility, located in Ft. Lauderdale, Florida. The facility's emission levels are regulated by the Florida Department of Environmental Protection (FDEP). Clean Air Engineering (CleanAir) was contracted to perform a compliance test program at its municipal waste combustor (MWC) facility, located in Ft. Lauderdale, Florida.

The visual emissions were determined by the facility's continuous opacity monitor system (COMS) data, as allowed under Title V Conditions B.53(6), B.76 and B.81. The lime silo fabric filter vent was observed for visual emissions (VEs) and the ash handling system was observed for fugitive emissions. Testing was conducted in accordance with the Wheelabrator North and South Broward Protocol on Compliance, dated February 8, 2010, 40 CFR 60 Subpart Cb, and applicable sections of the facility's Title V Permit No. 0112119-009-AV.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (EPA) and the FDEP.

Key Project Participants

Individuals responsible for coordinating and conducting the test program were:

- C. Faller – Wheelabrator South Broward, Inc.
- S. Brown – CleanAir

Lee Hoefert of the FDEP was present for portions of the test program.

The CleanAir test crew consisted of the following individuals:

- B. Wiltse
- R. Vicere
- P. Bihun
- N. Hitchins
- A. Obuchowski
- B. Arnold
- D. Luckhard
- A. Karony

PROJECT OVERVIEW

1-2

Test Program Parameters

The sampling conducted at the Units 1, 2 and 3 Spray Dry Absorption (SDA) Inlet, Fabric Filter (FF) Outlets, Ash Handling System and Lime Silo Vent from March 22 through 24, 2010, included the following emissions measurements:

- beryllium (Be);
- cadmium (Cd);
- lead (Pb);
- mercury (Hg);
- polychlorinated dibenzo-p-dioxins and polychlorinated dibenzofurans (PCDD/PCDF), Unit 2 only;
- total filterable particulate (TFP);
- hydrogen chloride (HCl);
- total fluoride;
- fugitive emissions (FE);
- visual emissions (VE).

PROJECT OVERVIEW

TEST PROGRAM SYNOPSIS

Test Schedule

The on-site-schedule-followed during the test program is outlined in Table 1-1.

**Table 1-1:
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Unit 1 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/22/10	08:31	09:31
1	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/22/10	08:47	11:05
1	Unit 3 SDA Inlet	USEPA Method 29	Mercury	03/22/10	08:47	11:05
2	Unit 1 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/22/10	09:58	10:58
1	Unit 2 FF Outlet	USEPA Method 23	PCDD/F	03/22/10	10:04	14:44
3	Unit 1 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/22/10	11:30	12:47
2	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/22/10	11:43	13:57
2	Unit 3 SDA Inlet	USEPA Method 29	Mercury	03/22/10	11:43	13:57
1	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/22/10	13:19	14:34
3	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/22/10	14:24	16:39
3	Unit 3 SDA Inlet	USEPA Method 29	Mercury	03/22/10	14:27	16:39
2	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/22/10	15:07	16:21
3	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/22/10	16:30	17:41
2	Unit 2 FF Outlet	USEPA Method 23	PCDD/F	03/23/10	07:36	12:10
1	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/23/10	07:43	09:58
1	Unit 1 SDA Inlet	USEPA Method 29	Mercury	03/23/10	07:43	09:58
1	Unit 2 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/23/10	07:55	08:55
2	Unit 2 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/23/10	09:30	10:31
2	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/23/10	10:31	12:45
2	Unit 1 SDA Inlet	USEPA Method 29	Mercury	03/23/10	10:31	12:45
3	Unit 2 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/23/10	10:55	12:06
3	Unit 2 FF Outlet	USEPA Method 23	PCDD/F	03/23/10	12:32	17:02
1	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/23/10	12:41	13:54
3	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/23/10	13:32	15:46
3	Unit 1 SDA Inlet	USEPA Method 29	Mercury	03/23/10	13:32	15:46
2	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/23/10	14:31	15:39
3	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/23/10	15:54	17:02
1	Unit 3 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/24/10	07:45	08:45
1	Ash Handling System	USEPA Method 22	Fugitive Emissions		07:52	14:05
1	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/24/10	07:53	09:11
1	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/24/10	07:53	10:06
1	Unit 2 SDA Inlet	USEPA Method 29	Mercury	03/24/10	07:53	10:06
2	Unit 3 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/24/10	09:16	10:16
2	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/24/10	09:37	10:54
1	Lime Silo	USEPA Method 9	Opacity	03/24/10	10:32	11:51
3	Unit 3 FF Outlet/SDA Inlet	USEPA Method 26A	HCl	03/24/10	10:54	11:54
2	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/24/10	11:03	13:35
2	Unit 2 SDA Inlet	USEPA Method 29	Mercury	03/24/10	11:03	13:35
3	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/24/10	11:24	12:46
3	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/24/10	14:12	16:22
3	Unit 2 SDA Inlet	USEPA Method 29	Mercury	03/24/10	14:12	16:22

PROJECT OVERVIEW

TEST PROGRAM SYNOPSIS (CONTINUED)

Results Summary

Table 1-2 summarizes the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown in Tables 2-1 through 2-23 on pages 2-1 through 2-21. Subpart Cb required operating data is summarized in Table 1-3 and opacity and fugitive emission results are presented in Table 1-4, both on page 1-5.

**Table 1-2:
Summary of Test Results**

<u>Source</u>	<u>Average Unit 1</u>	<u>Average Unit 2</u>	<u>Average Unit 3</u>	<u>Permit Limit¹</u>
Constituent				
Particulate (mg/dscm @7% O ₂)	1.0	1.4	2.1	25
Visual Emissions (% by COMS) ²	1	0	0	10
Fluoride (lb/MMBtu as HF) ³	<0.000039	<0.000039	<0.000043	0.0040
Total PCCD/PCDF (ng/dscm @ 7% O ₂)	NA	4.0	NA	30
Hydrogen Chloride (ppmdv @ 7% O ₂) <u>or</u>	8.7	13	20	29
Hydrogen Chloride Removal (%) ⁴	98%	97%	96%	>95
Beryllium (mg/dscm @ 7% O ₂)	<0.00003	<0.00003	<0.00003	0.001
Cadmium (mg/dscm @ 7% O ₂)	<0.00011	0.00048	0.00045	0.035
Lead (mg/dscm @ 7% O ₂)	0.00030	0.0034	0.0036	0.40
Mercury (µg/dscm @ 7% O ₂)	2.7	1.9	2.1	50
Mercury Removal (%) ⁴	95%	96%	96%	>85
Carbon Feed Rate (lbs/hr) ⁵	6	6	6	NA
Average Steam Flow (Klbs/hr) ⁶	184.0	184.0	184.1	192
Average FF Inlet Temperature (°F) ⁶	315	317	315	NA

¹ Limits obtained from facilities Title V Permit 0112119-009-AV. If a second limit is shown that limit is being implemented by the EPA as of April 28, 2009.

² Visual Emissions (opacity) was obtained from the facilities COMS data as allowed under Title V Conditions B.53(6), B.76 and B.81.

³ lb/MMBtu calculations used Fd of 9,570 for MSW as per Method 19.

⁴ Removal for mercury and hydrogen chloride calculated in the unit of its standard (ppmdv @ 7% O₂). The hydrogen chloride limit is 29 ppmdv @ 7% O₂ or 95% removal and the mercury limit is 70/50 µg/dscm @ 7% O₂ or 85% removal, whichever is less stringent.

⁵ From 40CFR60.58b (m)(1)(i) an average mass carbon rate during mercury or dioxin testing. The minimum carbon feed rate is established as the lower of the average carbon feed rates measured during the mercury or dioxin testing.

⁶ From all compliance test runs.

PROJECT OVERVIEW
TEST PROGRAM SYNOPSIS (CONTINUED)

1-5

Table 1-3:
Subpart Cb Required Operating Data

Process Condition

Unit 1 Maximum Demonstrated Combustor Load (Klbs/hr) ¹	184.2 ²
Unit 2 Maximum Demonstrated Combustor Load (Klbs/hr) ¹	183.9
Unit 3 Maximum Demonstrated Combustor Load (Klbs/hr) ¹	184.1 ³
Unit 1 Maximum Particulate Control Device Inlet Temperature (°F) ⁴	320 ²
Unit 2 Maximum Particulate Control Device Inlet Temperature (°F) ⁴	315
Unit 3 Maximum Particulate Control Device Inlet Temperature (°F) ⁴	319 ³
Unit 1 Carbon Feed Rate (lbs/hr) ⁵	6
Unit 2 Carbon Feed Rate (lbs/hr) ⁵	6
Unit 3 Carbon Feed rate (Klbs/hr) ⁵	6

¹ From 40CFR60.58b (i) (8) the maximum demonstrated load during PCDD/PCDF testing, four hour average.

² From CleanAir Cb test report dated April 28, 2009.

³ From CleanAir Cb test report dated April 24, 2008.

⁴ From 40CFR60.58b (i) (9) the highest four hour average during PCDD/PCDF testing.

⁵ From 40CFR60.58b (m)(1)(i) an average mass carbon rate during mercury or dioxin testing. The minimum carbon feed rate is established as the lower of the average carbon feed rates measured during the mercury or dioxin testing.

Table 1-4:
Opacity and Fugitive Emission Test Results

<u>Source</u>	<u>Constituent</u>	<u>Sampling Method</u>	<u>Results</u>	<u>Permit Limit¹</u>
<u>Ash Handling System²</u>				
	Fugitive Emissions (%)	EPA M22	0	5% of observation time
	Fugitive Emissions (minutes)		0	9 minutes
<u>Lime Silo³</u>				
	Visual Emissions (%)	EPA M9	0	5%

¹ Limits obtained from 40 Code of Federal Register part 60 Subpart Cb - Emission Guidelines and Compliance Times for Large Municipal Waste Combustors That Are Constructed on or Before September 20, 1994 published in Federal Register as 62 FR 45123 on December 19, 1995 as modified on August 25, 1997, Florida's Rule 62-296.416, F.A.C. and PSD-FL-105.

² The Ash Handling System was observed at various locations for a total of 3 hours.

³ The Lime Silo was observed for one complete truck unloading.

PROJECT OVERVIEW

1-6

TEST PROGRAM SYNOPSIS (CONTINUED)

Discussion of Test Program

All test methods were done in triplicate. All data that is reported in the units of lb/MMBTU utilized the Fd of 9,570 as per EPA Method 19.

All equipment utilized for compliance testing was manufactured by Clean Air Engineering, except for the Servomex O₂/CO₂ analyzer utilized for all of the integrated gas sample bag analysis.

During compliance testing, all three (3) boilers were operated within 10% of the 192,000 lb/hr maximum steam flow rating. The results tables present each boiler's steam output for every test run.

Raina Vicere performed the fugitive emission readings (per EPA Method 22) on the ash handling system and the VE readings (per EPA Method 9) on the Lime Silo during one (1) entire truck unloading. Ms. Vicere's VE evaluation certificate is presented in Appendix J.

Any fractions of the mercury analysis that were reported as not detected were summed as zero if there was at least one (1) fraction detected in that run. The beryllium, cadmium and lead front- and back-half fractions were combined proportionately for analysis, per EPA Method 29, Section 5.4.

Field blanks were collected for the Method 23 and 29 testing by assembling a used set of glassware, taking the complete train to the outlet location and performing a leak-check. These samples were treated exactly as the other samples. The results for the method field blanks are presented in Table 2-22 on page 2-20, as well as Appendix I. The results of the Method 29 reagent blank analysis were used to correct any data, as outlined in Method 29.

All Method 23 samples were analyzed with the DB-5S column with modified calibration and additional quality assurance procedures as a direct substitute for the DB-5 and DB-225 columns. Confirmation of the 2,3,7,8 TCDF and TCDD 2,3,7,8 isomers was performed on the DB-5S column. The DB-5S column and modified calibration procedures meets the column separation requirement and can be used as a direct substitute for the DB-5 and DB-225 columns, in accordance with Method 23 as approved by the EPA. All QA/QC data (spikes and recoveries) for Method 23, as well as the EPA Audit Sample results, are presented in Appendix I.

PROJECT OVERVIEW

1-7

TEST PROGRAM SYNOPSIS (CONTINUED)

The Method 23 results for all three (3) runs contained at least one (1) estimated maximum possible concentration (EMPC) value. EMPC results do not meet all the identification criteria required by Method 23 to be positively identified as a dioxin or furan. Specifically, the integrated ion abundance ratios were not within 15% of the theoretical value limits specified in Method 23 Section 5.3.2.5, Table 4. The laboratory reports EMPC results as zero and, for this reason, all EMPC results are enclosed in brackets and are considered zero when calculating total dioxin/furans.

For analytical results that are below the detection limit, values are reported as ND, with the detection limit in parenthesis and are considered zero for calculating total catch weights per Method 23, Section 9.9.

Chuck Faller of Wheelabrator South Broward Inc. provided the process (operating) data. This data is presented in its entirety in Appendix C. All process data and CleanAir run times are based on facility CEM time.

Integrated gas samples (IGS) were collected in a vinyl sample bag from every sample train. The contents of the bag were then analyzed for O₂ and CO₂ concentrations using an O₂/CO₂ continuous monitoring analyzer calibrated with EPA Protocol gases. A linearity and bias check was performed on the analyzers before each set of bags was analyzed, and then a post bias check was performed after each set of bags was analyzed. All data was recorded using CleanAir's data acquisition system. The results of the IGS bag analyses are presented in Appendix H.

Metals and particulate matter sampling were combined during this test program, per the Method 29 Section 1.2 Principle, "This method may be used to determine particulate emissions in addition to the metals emissions if the prescribed procedures and precautions are followed".

Additionally, 120-minute mercury measurements were conducted, using EPA Method 29 at the SDA Inlets simultaneously with the Method 5/29. The carbon injection rate is set for the following year based on the results of these tests. The carbon rates established are presented in Table 1-3 on page 1-5.

Sixty-minute Method 26A sample trains at the SDA Inlets and FF Outlets were utilized to exhibit compliance with each unit's HCl limit(s). The Method 26A was modified to a single-point constant sampling rate at all test locations.

The FDEP supplied audit samples for PCDD/PCDF, metals and HCl to CleanAir. The analytical results of these samples are presented in Appendix I, along with each respective lab report.

RESULTS

2-1

**Table 2-1:
Unit 1 FF Outlet – Particulate and Metals**

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		07:43	10:31	13:32	
Stop Time (approx.)		09:58	12:45	15:46	
Process Conditions					
R _p	Steam Production Rate (Klbs/hr)	183.5	183.9	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.6	9.4	9.7	9.6
CO ₂	Carbon dioxide (dry volume %)	9.7	9.9	9.8	9.8
T _s	Sample temperature (°F)	295	295	296	296
B _w	Actual water vapor in gas (% by volume)	22.0	22.3	21.8	22.0
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _{std}	Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	77.17	77.39	77.61	77.39
%I	Isokinetic sampling (%)	105.2	104.2	102.9	104.1
Particulate Laboratory Data					
m _n	Net matter collected (g)	0.0011	0.0022	0.0022	
Filterable Particulate Results					
C _{sd}	Particulate Concentration (mg/dscm)	0.50	1.0	1.0	0.84
C _{sd7}	Particulate Concentration @7% O ₂ (mg/dscm)	0.62	1.2	1.2	1.0
Beryllium Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total					
C _{sd}	Concentration (mg/dscm)	<0.000023	<0.000023	<0.000023	<0.000023
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<0.000028	<0.000028	<0.000028	<0.000028
Cadmium Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.2000	<0.2000	<0.2000	
Cadmium Results - Total					
C _{sd}	Concentration (mg/dscm)	<0.000092	<0.000091	<0.000091	<0.000091
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<0.00011	<0.00011	<0.00011	<0.00011
Lead Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	0.3815	0.7111	0.5419	
Lead Results - Total					
C _{sd}	Concentration (mg/dscm)	0.00017	0.00032	0.00025	0.00025
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	0.00021	0.00039	0.00031	0.00030

RESULTS**Table 2-2:
Unit 1 SDA Inlet and FF Outlet – Mercury**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:43	10:31	13:32	
Stop Time (approx.)	09:58	12:45	15:46	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	183.5	183.9	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	6	6	6	6
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	8.1	8.3	8.5	8.3
CO ₂ Carbon dioxide (dry volume %)	11.0	10.9	11.0	10.9
T _s Sample temperature (°F)	499	505	507	504
B _w Actual water vapor in gas (% by volume)	18.2	18.6	18.1	18.3
SDA Inlet Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	192,331	188,096	188,581	189,669
Q _{std} Volumetric flow rate, dry standard (dscfm)	86,810	84,006	84,525	85,114
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	68.54	65.65	65.80	66.66
%I Isokinetic sampling (%)	99.6	98.6	98.2	98.8
SDA Inlet Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	78.0752	95.4417	86.1483	
SDA Inlet Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	40	51	46	46
C _{sd7} Concentration @7% O ₂ (µg/dscm)	44	57	52	51
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	9.6	9.4	9.7	9.6
CO ₂ Carbon dioxide (dry volume %)	9.7	9.9	9.8	9.8
T _s Sample temperature (°F)	295	295	296	296
B _w Actual water vapor in gas (% by volume)	22.0	22.3	21.8	22.0
FF Outlet Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _{std} Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	77.17	77.39	77.61	77.39
%I Isokinetic sampling (%)	105.2	104.2	102.9	104.1
FF Outlet Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	4.8386	4.5386	5.0072	
FF Outlet Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	2.2	2.1	2.3	2.2
C _{sd7} Concentration @7% O ₂ (µg/dscm)	2.7	2.5	2.8	2.7
RE Removal Efficiency (µg/dscm @ 7% O ₂ based)	94%	96%	95%	95%

RESULTS

2-3

**Table 2-3:
Unit 1 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	13:19	15:07	16:30	
Stop Time (approx.)	14:34	16:21	17:41	
Process Conditions				
R _P Steam Production Rate (Klbs/hr)	183.9	184.2	184.8	184.3
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.2	9.3	9.2	9.2
CO ₂ Carbon dioxide (dry volume %)	10.3	10.0	10.3	10.2
T _s Sample temperature (°F)	293	293	293	293
B _w Actual water vapor in gas (% by volume)	21.8	21.7	22.1	21.9
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	175,956	176,099	169,528	173,861
Q _{std} Volumetric flow rate, dry standard (dscfm)	94,620	94,737	90,888	93,415
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	36.94	37.95	36.29	37.06
%I Isokinetic sampling (%)	102.1	104.8	104.4	103.8
Laboratory Data				
m _n Total HF collected (mg)	<0.03892	<0.03744	<0.03782	
Hydrogen Fluoride (HF) Results				
C _{sd} HF Concentration (ppmdv)	<0.045	<0.042	<0.044	<0.044
C _{std} HF Concentration @7% O ₂ (ppmdv)	<0.053	<0.050	<0.052	<0.052
C _{sd} HF Concentration (mg/dscm)	<0.037	<0.035	<0.037	<0.036
C _{std} HF Concentration @7% O ₂ (mg/dscm)	<0.044	<0.042	<0.044	<0.043
E _{lb/hr} HF Rate (lb/hr)	<0.013	<0.012	<0.013	<0.013
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000040	<0.000038	<0.000039	<0.000039

RESULTS**Table 2-4:
Unit 1 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:31	09:58	11:30	
Stop Time (approx.)	09:31	10:58	12:47	
Process Conditions				
R _P Steam Production Rate (Klbs/hr)	183.3	184.8	184.6	184.2
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	316	315
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	8.5	8.6	7.9	8.3
CO ₂ Carbon dioxide (dry volume %)	10.9	10.8	11.4	11.0
T _s Sample temperature (°F)	495	497	494	495
B _w Actual water vapor in gas (% by volume)	17.6	17.2	19.1	17.9
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	35.19	36.04	35.52	35.58
SDA Inlet Laboratory Data				
m _n Total HCl collected (mg)	592.5061	671.5237	1044.3603	
SDA Inlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	393	434	685	504
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	438	490	734	554
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	10.0	9.5	9.2	9.6
CO ₂ Carbon dioxide (dry volume %)	9.2	10.0	10.2	9.8
T _s Sample temperature (°F)	295	295	296	295
B _w Actual water vapor in gas (% by volume)	21.8	21.1	21.9	21.6
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	41.76	41.69	41.49	41.64
FF Outlet Laboratory Data				
m _n Total HCl collected (mg)	11.0981	11.4642	15.4584	
FF Outlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	6.2	6.4	8.7	7.1
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	7.9	7.8	10.3	8.7
RE Reduction Efficiency (% Removal)	98%	98%	99%	98%

RESULTS

2-5

**Table 2-5:
Unit 2 FF Outlet – Particulate and Metals**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:35	16:22	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	183.9	183.7	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	6	6	6	6
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.5	9.4	9.8	9.5
CO ₂ Carbon dioxide (dry volume %)	9.9	10.2	9.9	10.0
T _s Sample temperature (°F)	295	298	297	297
B _w Actual water vapor in gas (% by volume)	22.1	22.6	22.0	22.2
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.89	73.20	73.71	72.93
%I Isokinetic sampling (%)	100.1	100.0	99.0	99.7
Particulate Laboratory Data				
m _n Net matter collected (g)	0.0025	0.0030	0.0015	
Filterable Particulate Results				
C _{sd} Particulate Concentration (mg/dscm)	1.2	1.4	0.72	1.1
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	1.5	1.7	0.90	1.4
Beryllium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{sd} Concentration (mg/dscm)	<0.000025	<0.000024	<0.000024	<0.000024
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<0.000030	<0.000029	<0.000030	<0.000030
Cadmium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.5113	0.9717	0.9525	
Cadmium Results - Total				
C _{sd} Concentration (mg/dscm)	0.00025	0.00047	0.00046	0.00039
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.00030	0.00057	0.00057	0.00048
Lead Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	5.3271	5.6541	6.3189	
Lead Results - Total				
C _{sd} Concentration (mg/dscm)	0.0026	0.0027	0.0030	0.0028
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.0032	0.0033	0.0038	0.0034

RESULTS**Table 2-6:
Unit 2 SDA Inlet and FF Outlet – Mercury**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:35	16:22	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	183.9	183.7	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Process data - (units)	6	6	6	6
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	7.8	8.0	8.2	8.0
CO ₂ Carbon dioxide (dry volume %)	11.4	11.4	11.4	11.4
T _s Sample temperature (°F)	483	488	495	489
B _w Actual water vapor in gas (% by volume)	19.3	18.7	18.7	18.9
SDA Inlet Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	180,110	178,599	187,722	182,144
Q _{std} Volumetric flow rate, dry standard (dscfm)	81,557	81,021	84,568	82,382
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	65.53	63.19	66.87	65.20
%I Isokinetic sampling (%)	101.3	98.4	99.7	99.8
SDA Inlet Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	59.4137	114.4267	80.9101	
SDA Inlet Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	32	64	43	46
C _{sd7} Concentration @7% O ₂ (µg/dscm)	34	69	47	50
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	9.5	9.4	9.8	9.5
CO ₂ Carbon dioxide (dry volume %)	9.9	10.2	9.9	10.0
T _s Sample temperature (°F)	295	298	297	297
B _w Actual water vapor in gas (% by volume)	22.1	22.6	22.0	22.2
FF Outlet Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.89	73.20	73.71	72.93
%I Isokinetic sampling (%)	100.1	100.0	99.0	99.7
FF Outlet Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	2.8801	3.2488	3.4006	
FF Outlet Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	1.4	1.6	1.6	1.5
C _{sd7} Concentration @7% O ₂ (µg/dscm)	1.7	1.9	2.0	1.9
RE Removal Efficiency (µg/dscm @ 7% O ₂ based)	95%	97%	96%	96%

WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

RESULTS

2-7

Table 2-7:
Unit 2 FF Outlet - Fluorides

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	09:37	11:24	
Stop Time (approx.)	09:11	10:54	12:46	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.3	183.8	183.6	183.9
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.4	9.3	9.4	9.4
CO ₂ Carbon dioxide (dry volume %)	10.0	10.0	10.1	10.0
T _s Sample temperature (°F)	292	292	293	292
B _w Actual water vapor in gas (% by volume)	22.0	22.2	22.1	22.1
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	175,045	174,991	170,950	173,662
Q _{std} Volumetric flow rate, dry standard (dscfm)	93,851	93,628	91,463	92,981
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	36.24	35.99	34.97	35.74
%I Isokinetic sampling (%)	101.0	100.6	100.0	100.5
Laboratory Data				
m _n Total HF collected (mg)	<0.03273	<0.03622	<0.03921	
Hydrogen Fluoride (HF) Results				
C _{sd} HF Concentration (ppmdv)	<0.038	<0.043	<0.048	<0.043
C _{sd7} HF Concentration @7% O ₂ (ppmdv)	<0.046	<0.051	<0.057	<0.052
C _{sd} HF Concentration (mg/dscm)	<0.032	<0.036	<0.040	<0.036
C _{sd7} HF Concentration @7% O ₂ (mg/dscm)	<0.038	<0.043	<0.048	<0.043
E _{lb/hr} HF Rate (lb/hr)	<0.011	<0.012	<0.014	<0.012
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000035	<0.000038	<0.000043	<0.000039

RESULTS

**Table 2-8:
Unit 2 FF Outlet - PCDDs/PCDFs**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 23	Mar 23	
Start Time (approx.)		10:04	07:36	12:32	
Stop Time (approx.)		14:44	12:10	17:02	
Process Conditions					
R _p	Steam Production Rate (Klbs/hr)	184.2	184.2	183.9	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	318	320	320	319
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.2	9.6	9.3	9.4
CO ₂	Carbon dioxide (dry volume %)	10.2	9.7	10.2	10.0
T _s	Sample temperature (°F)	293	297	299	296
B _w	Actual water vapor in gas (% by volume)	21.6	21.5	22.4	21.8
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	173,437	178,662	177,895	176,665
Q _{std}	Volumetric flow rate, dry standard (dscfm)	93,381	95,811	94,124	94,438
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	139.50	142.83	141.78	141.37
%I	Isokinetic sampling (%)	100.7	100.5	101.5	100.9
Results (ND and EMPC = 0)					
Laboratory Data from USEPA Method 23					
m _n	Total PCDDs & PCDFs (ng)	12.1000	13.3000	14.4000	
m _{n,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.0907	0.0880	0.1110	
Total PCDD/F Results (TEF=1)					
C _{sd}	PCDD/F Concentration (ng/dscm)	3.1	3.3	3.6	3.3
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	3.6	4.0	4.3	4.0
E _{lb/hr}	PCDD/F Rate (lb/hr)	1.07E-06	1.18E-06	1.26E-06	1.17E-06
E _{Fd}	PCDD/F Rate - F _d -based (lb/MMBtu)	3.27E-09	3.62E-09	3.85E-09	3.58E-09
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)					
C _{sdTEQ}	TEQ Concentration (ng/dscm)	0.023	0.022	0.028	0.024
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	0.027	0.027	0.033	0.029
E _{lb/hrTEQ}	TEQ Rate (lb/hr)	8.03E-09	7.81E-09	9.75E-09	8.53E-09
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	2.45E-11	2.40E-11	2.97E-11	2.61E-11
Results (ND and EMPC = actual value)					
Laboratory Data from USEPA Method 23, including NDs and EMPCs					
m _n	Total PCDDs & PCDFs (ng)	12.1000	13.4000	14.6000	
m _{n,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.0960	0.1100	0.1210	
Total PCDD/F Results (TEF=1)					
C _{sd}	PCDD/F Concentration (ng/dscm)	3.1	3.3	3.6	3.3
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	3.6	4.1	4.3	4.0
E _{lb/hr}	PCDD/F Rate (lb/hr)	1.07E-06	1.19E-06	1.28E-06	1.18E-06
E _{Fd}	PCDD/F Rate - F _d -based (lb/MMBtu)	3.27E-09	3.65E-09	3.91E-09	3.61E-09
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)					
C _{sdTEQ}	TEQ Concentration (ng/dscm)	0.024	0.027	0.030	0.027
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	0.029	0.033	0.036	0.033
E _{lb/hrTEQ}	TEQ Rate (lb/hr)	8.50E-09	9.76E-09	1.06E-08	9.63E-09
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	2.60E-11	3.00E-11	3.24E-11	2.94E-11

RESULTS

2-9

**Table 2-9:
Unit 2 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:55	09:30	10:55	
Stop Time (approx.)	08:55	10:31	12:06	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	185.2	183.2	185.3	184.6
P ₁ Fabric Filter Inlet Temperature (°F)	320	320	320	320
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	8.1	8.7	7.6	8.1
CO ₂ Carbon dioxide (dry volume %)	10.9	10.5	11.6	11.0
T _s Sample temperature (°F)	490	495	494	493
B _w Actual water vapor in gas (% by volume)	17.6	17.8	19.6	18.3
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	34.60	34.43	34.04	34.36
SDA Inlet Laboratory Data				
m _n Total HCl collected (mg)	542.6130	510.8841	606.2813	
SDA Inlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	366	346	415	376
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	398	394	434	409
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	9.5	10.1	9.3	9.6
CO ₂ Carbon dioxide (dry volume %)	9.7	9.3	10.1	9.7
T _s Sample temperature (°F)	301	301	300	301
B _w Actual water vapor in gas (% by volume)	21.4	21.6	22.2	21.7
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	40.08	39.97	40.83	40.29
FF Outlet Laboratory Data				
m _n Total HCl collected (mg)	21.2629	16.6326	16.8368	
FF Outlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	12	10	10	11
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	15	12	11	13
RE Reduction Efficiency (% Removal)	96%	97%	97%	97%

RESULTS**Table 2-10:
Unit 3 FF Outlet – Particulate and Metals**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:47	11:43	14:24	
Stop Time (approx.)		11:05	13:57	16:39	
Process Conditions					
R _p	Steam Production Rate (Klbs/hr)	184.1	184.0	184.2	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
Gas Conditions					
O ₂	Oxygen (dry volume %)	10.0	9.7	9.5	9.7
CO ₂	Carbon dioxide (dry volume %)	9.4	9.8	10.0	9.7
T _s	Sample temperature (°F)	297	296	295	296
B _w	Actual water vapor in gas (% by volume)	21.1	20.7	20.6	20.8
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _{std}	Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	77.68	72.10	73.91	74.56
%I	Isokinetic sampling (%)	100.2	100.2	100.8	100.4
Particulate Laboratory Data					
m _n	Net matter collected (g)	0.0039	0.0034	0.0033	
Filterable Particulate Results					
C _{sd}	Particulate Concentration (mg/dscm)	1.77	1.67	1.58	1.67
C _{sd7}	Particulate Concentration @7% O ₂ (mg/dscm)	2.26	2.07	1.92	2.08
Beryllium Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total					
C _{sd}	Concentration (mg/dscm)	<0.000023	<0.000024	<0.000024	<0.000024
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<0.000029	<0.000030	<0.000029	<0.000030
Cadmium Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	0.7733	0.7704	0.7331	
Cadmium Results - Total					
C _{sd}	Concentration (mg/dscm)	0.00035	0.00038	0.00035	0.00036
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	0.00045	0.00047	0.00043	0.00045
Lead Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	6.8716	5.5360	5.9671	
Lead Results - Total					
C _{sd}	Concentration (mg/dscm)	0.0031	0.0027	0.0029	0.0029
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	0.0040	0.0034	0.0035	0.0036

RESULTS**Table 2-11:
Unit 3 SDA Inlet and FF Outlet – Mercury**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:47	11:43	14:24	
Stop Time (approx.)		11:05	13:57	16:39	
Process Conditions					
R _p	Steam Production Rate (Klbs/hr)	184.1	184.0	184.2	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
SDA Inlet Gas Conditions					
O ₂	Oxygen (dry volume %)	9.2	8.2	8.1	8.5
CO ₂	Carbon dioxide (dry volume %)	10.5	11.1	11.2	10.9
T _s	Sample temperature (°F)	473	469	471	471
B _w	Actual water vapor in gas (% by volume)	18.2	18.2	17.7	18.0
SDA Inlet Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	181,887	175,008	174,895	177,264
Q _{std}	Volumetric flow rate, dry standard (dscfm)	84,459	81,568	81,829	82,619
SDA Inlet Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	67.57	65.07	64.93	65.85
%I	Isokinetic sampling (%)	100.9	100.6	100.1	100.5
SDA Inlet Mercury Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	69.7807	118.2850	100.6553	
SDA Inlet Mercury Results - Total					
C _{sd}	Concentration (µg/dscm)	36	64	55	52
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	43	70	60	58
FF Outlet Gas Conditions					
O ₂	Oxygen (dry volume %)	10.0	9.7	9.5	9.7
CO ₂	Carbon dioxide (dry volume %)	9.4	9.8	10.0	9.7
T _s	Sample temperature (°F)	297	296	295	296
B _w	Actual water vapor in gas (% by volume)	21.1	20.7	20.6	20.8
FF Outlet Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _{std}	Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
FF Outlet Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	77.68	72.10	73.91	74.56
%I	Isokinetic sampling (%)	100.2	100.2	100.8	100.4
FF Outlet Mercury Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	3.6560	3.5329	3.2883	
FF Outlet Mercury Results - Total					
C _{sd}	Concentration (µg/dscm)	1.7	1.7	1.6	1.7
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	2.1	2.1	1.9	2.1
RE	Removal Efficiency (µg/dscm @ 7% O ₂ based)	95%	97%	97%	96%

RESULTS**Table 2-12:
Unit 3 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	12:41	14:31	15:54	
Stop Time (approx.)	13:54	15:39	17:02	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	183.8	184.4	183.9	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.8	9.9	9.4	9.7
CO ₂ Carbon dioxide (dry volume %)	9.6	9.6	10.2	9.8
T _s Sample temperature (°F)	297	296	296	297
B _w Actual water vapor in gas (% by volume)	22.3	21.5	21.8	21.9
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	174,143	179,138	166,090	173,124
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,603	96,238	88,943	92,595
Sampling Data				
V _{metd} Volume metered, standard (dscf)	35.65	37.18	35.41	36.08
%I Isokinetic sampling (%)	100.7	101.0	104.1	102.0
Laboratory Data				
m _n Total HF collected (mg)	<0.03972	<0.03985	<0.03778	
Hydrogen Fluoride (HF) Results				
C _{std} HF Concentration (ppmdv)	<0.047	<0.046	<0.045	<0.046
C _{std7} HF Concentration @7% O ₂ (ppmdv)	<0.059	<0.058	<0.055	<0.057
C _{std} HF Concentration (mg/dscm)	<0.039	<0.038	<0.038	<0.038
C _{std7} HF Concentration @7% O ₂ (mg/dscm)	<0.049	<0.048	<0.046	<0.048
E _{lb/hr} HF Rate (lb/hr)	<0.014	<0.014	<0.013	<0.013
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000044	<0.000043	<0.000041	<0.000043

RESULTS

2-13

**Table 2-13:
Unit 3 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:45	09:16	10:54	
Stop Time (approx.)	08:45	10:16	11:54	
Process Conditions				
R _P Steam Production Rate (Klbs/hr)	184.1	184.2	184.1	184.1
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	9.0	8.1	8.0	8.4
CO ₂ Carbon dioxide (dry volume %)	10.4	11.2	11.3	10.9
T _s Sample temperature (°F)	465	464	468	466
B _w Actual water vapor in gas (% by volume)	17.8	18.2	18.7	18.2
SDA Inlet Sampling Data				
V _{metd} Volume metered, standard (dscf)	36.06	36.23	36.49	36.26
SDA Inlet Laboratory Data				
m _n Total HCl collected (mg)	607.2973	714.3158	701.1579	
SDA Inlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	393	460	448	433
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	458	498	484	480
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	9.6	9.1	9.1	9.3
CO ₂ Carbon dioxide (dry volume %)	9.8	10.3	10.3	10.1
T _s Sample temperature (°F)	295	296	295	295
B _w Actual water vapor in gas (% by volume)	21.7	21.5	22.4	21.9
FF Outlet Sampling Data				
V _{metd} Volume metered, standard (dscf)	40.21	40.73	39.98	40.30
FF Outlet Laboratory Data				
m _n Total HCl collected (mg)	30.1359	28.8286	29.3329	
FF Outlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	17	17	17	17
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	22	19	20	20
RE Reduction Efficiency (% Removal)	95%	96%	96%	96%

RESULTS

**Table 2-14:
 Units 1, 2 and 3 FF Outlets – Opacity by COMS**

Run No.	1	2	3	Average
<u>Unit 1</u>				
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:43	10:31	13:32	
Stop Time (approx.)	09:58	12:45	15:46	
Visible Emissions (%)¹				
Average Opacity	1	1	1	1
Maximum Reading	1	1	1	1
Minimum Reading	1	1	1	1
<u>Unit 2</u>				
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:35	16:22	
Visible Emissions (%)¹				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0
<u>Unit 3</u>				
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:47	11:43	14:24	
Stop Time (approx.)	11:05	13:57	16:39	
Visible Emissions (%)¹				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0

¹ Reading obtained from facility's continuous opacity monitoring system (COMS) as provided under 40 CFR 60.11(e) and Title V Conditions A.36(6), A.53 and A.54 and coincide with Method 5/29 test runs.

RESULTS

2-15

**Table 2-15:
Ash Handling System - Fugitive Emissions**

<u>Source</u> Constituent	<u>Date</u> (2010)	<u>Start Time</u> (approx.)	<u>Stop Time</u> (approx.)	<u>Observation</u> Duration (minutes)	<u>Accumulated</u> Emission Duration (seconds)	
<u>Ash Unloading/Conveyor</u>						
Visual Opacity (%)	March 24	7:52	9:02	60	0	
<u>Ash Conveyor/Doors to Baghouse</u>						
Visual Opacity (%)	March 24	9:07	10:17	60	0	
<u>Rolling Door/Door to Baghouse</u>						
Visual Opacity (%)	March 24	12:55	14:05	60	0	<u>Permit Limit</u>
Total (% of observation time) = 0					< 5% of observation Time	
Total (minutes) = 0					< 9 minutes	

**Table 2-16:
Lime Silo Fabric Filter Outlet - Visible Emissions**

Run No.	1
Date (2010)	Mar 24
Start Time (approx.)	10:32
Stop Time (approx.)	11:51
<u>Process Conditions</u>	
Total lime unloaded (tons)	25.63
Rate of unloading (tons/hr)	19.5
<u>Visible Emissions</u>	
Average (percent opacity)	0
Maximum reading (percent opacity)	0

RESULTS

**Table 2-17:
Air Flow Summary**

Run Number	Run Date	Run Time	Steam Flow Klbs/hour	Flue Gas Temp Deg F	Air Flow ACFM	O ₂ %	CO ₂ %	CO ₂ Sample Rate (lpm) ¹	Stack Flow 2RSD (%)	Air Flow, DSCFM	Air Flow, DSCFM@ 7%O ₂
1-O-M5/29-1	3/23/2010	07:43-09:58	183.5	295	177.014	9.6	9.7	0.2	11.6%	94,473	77,005
1-O-M5/29-2	3/23/2010	10:31-12:45	183.9	295	179.820	9.4	9.9	0.2	12.2%	95,658	79,279
1-O-M5/29-3	3/23/2010	13:32-15:46	183.3	296	181.627	9.7	9.8	0.2	13.1%	97,155	78,073
1-O-M13B-1	3/22/2010	13:19-14:34	183.9	293	175.956	9.2	10.3	0.4	9.1%	94,620	79,848
1-O-M13B-2	3/22/2010	15:07-16:21	184.2	293	176.099	9.3	10.0	0.4	13.9%	94,737	78,993
1-O-M13B-3	3/22/2010	16:30-17:41	184.8	293	169.528	9.2	10.3	0.4	11.1%	90,888	76,829
		Average	183.9	294	176,674	9.4	10.0	NA	11.6%	94,588	78,338
2-O-M5/29-1	3/24/2010	07:53-10:06	183.9	295	173.477	9.5	9.9	0.2	9.3%	92,545	76,233
2-O-M5/29-2	3/24/2010	11:03-13:35	183.7	298	178.750	9.4	10.2	0.2	6.4%	94,353	78,130
2-O-M5/29-3	3/24/2010	14:12-16:22	183.3	297	180.224	9.8	9.9	0.2	10.0%	95,903	76,653
2-O-M13B-1	3/24/2010	07:53-09:11	184.3	292	175.045	9.4	10.0	0.4	6.9%	93,851	77,782
2-O-M13B-2	3/24/2010	09:37-10:54	183.8	292	174.991	9.3	10.0	0.4	9.6%	93,628	78,001
2-O-M13B-3	3/24/2010	11:24-12:46	183.6	293	170.950	9.4	10.1	0.4	11.0%	91,463	75,934
2-O-M23-1	3/22/2010	10:04-14:44	184.2	293	173.437	9.2	10.2	0.1	6.9%	93,381	78,534
2-O-M23-2	3/23/2010	07:36-12:10	184.2	297	178.662	9.6	9.7	0.1	8.9%	95,811	78,096
2-O-M23-3	3/23/2010	12:32-17:02	183.9	299	177.895	9.3	10.2	0.1	10.8%	94,124	78,685
		Average	183.9	295	175,937	9.4	10.0	NA	8.9%	93,895	77,561
3-O-M5/29-1	3/22/2010	08:47-11:05	184.1	297	184.927	10.0	9.4	0.2	11.7%	99,875	78,176
3-O-M5/29-2	3/22/2010	11:43-13:57	184.0	296	170.489	9.7	9.8	0.2	9.0%	92,737	74,723
3-O-M5/29-3	3/22/2010	14:24-16:39	184.2	295	173.572	9.5	10.0	0.2	9.1%	94,492	77,497
3-O-M13B-1	3/23/2010	12:41-13:54	183.8	297	174.143	9.8	9.6	0.4	10.7%	92,603	74,282
3-O-M13B-2	3/23/2010	14:31-15:39	184.4	296	179.138	9.9	9.6	0.4	12.3%	96,238	75,952
3-O-M13B-3	3/23/2010	15:54-17:02	183.9	296	166.090	9.4	10.2	0.4	6.5%	88,943	73,586
		Average	184.1	296	174,727	9.7	9.8	NA	9.9%	94,148	75,703
		Facility Average	184.0	295	175,779	9.5	9.9	NA	10.2%	94,211	77,201

¹ CO₂ gas sample flow rate was within 10% of initial flow rate throughout all test runs.

RESULTS

2-17

**Table 2-18:
Quality Control and Quality Assurance
PCDD/PCDF - Extraction Standard Percent Recoveries**

Sample Number	Extraction Standard Percent Recoveries, %							
	¹³ C- TCDD	¹³ C- PeCDD	¹³ C- HxCDD	¹³ C- HxCDD	¹³ C- HxCDD	¹³ C- HpCDD	¹³ C- OCDD	¹³ C- TCDF
0_7660_MB001	94.3	87.2	86.2	86.2	87.9	86.9	85.9	101
Field Blank	91.6	96	84.8	79.7	81.2	80.7	79.1	95.2
Unit 2 FF Outlet Run 1	88.9	85.6	85.3	85.7	90.8	87.2	84.6	90.9
Unit 2 FF Outlet Run 2	94.9	86.5	84.3	83.6	83.9	85.1	81.7	95.5
Unit 2 FF Outlet Run 3	79.8	84.9	79.6	79	80.7	83	82.4	84.1

Average	90	88	84	83	85	85	83	93
SD	6	5	3	3	4	3	3	6
Min	79.8	84.9	79.6	79	80.7	80.7	79.1	84.1
Max	94.9	96	86.2	86.2	90.8	87.2	85.9	101
Within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE

Sample Number	Extraction Standard Percent Recoveries, %								
	¹³ C- PeCDF	¹³ C- PeCDF	¹³ C- HxCDF	¹³ C- HxCDF	¹³ C- HxCDF	¹³ C- HxCDF	¹³ C- HpCDF	¹³ C- HpCDF	¹³ C- OCDF
0_7660_MB001	93.7	97.5	85.1	86.7	90.1	83.5	83.8	86.1	82
Field Blank	97.4	98.6	81.4	82.3	83.5	78.4	78.6	82.6	77
Unit 2 FF Outlet Run 1	90.1	89.4	87.3	87.7	88.5	82.9	84.4	85.7	80.9
Unit 2 FF Outlet Run 2	92.7	91.4	85.9	85.8	85.7	80.6	81.7	82.4	77.7
Unit 2 FF Outlet Run 3	87.8	87.8	80.6	79.6	81.9	75.8	78.5	80.4	77

Average	92	93	84	84	86	80	81	83	79
SD	4	5	3	3	3	3	3	2	2
Min	87.8	87.8	80.6	79.6	81.9	75.8	78.5	80.4	77
Max	97.4	98.6	87.3	87.7	90.1	83.5	84.4	86.1	82
Within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE

**Table 2-19:
Quality Control and Quality Assurance
PCDD/PCDF - CS/SS Percent Recoveries**

Sample Number	CS/SS Percent Recoveries, %				
	³⁷ Cl- TCDD	¹³ C- PeCDD	¹³ C- PeCDF	¹³ C- HxCDF	¹³ C- HpCDF
0_7660_MB001	99.1	104	102	100	103
Field Blank	97.5	99.1	98.3	98.7	102
Unit 2 FF Outlet Run 1	99	104	99.3	99.6	101
Unit 2 FF Outlet Run 2	97.2	106	98.6	99.9	104
Unit 2 FF Outlet Run 3	99.1	106	95.3	98.9	103

Average	98	104	99	99	103
SD	1	3	2	1	1
Min	97.2	99.1	95.3	98.7	101
Max	99.1	106	102	100	104
Min within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE

RESULTS

**Table 2-20:
Quality Control and Quality Assurance - Metals**

Run Number	RPD RESULTS				
	FH Front Half	BH H ₂ O ₂ /HNO ₄	A Empty Impinger	B KMnO ₄	C HCl
U1-SDA-I-R1	0.1%	1.4%	NA	NA	0.9%
U1-SDA-I-R2	1.4%	1.4%	NA	NA	1.6%
U1-SDA-I-R3	1.6%	1.2%	NA	3.4%	1.8%
U1-FF-O-R1	NA	1.0%	NA	NA	NA
U1-FF-O-R2	NA	1.3%	NA	NA	NA
U1-FF-O-R3	NA	1.1%	NA	NA	NA
U2-SDA-I-R1	0.7%	9.6%	NA	NA	1.7%
U2-SDA-I-R2	1.2%	1.5%	NA	NA	1.9%
U2-SDA-I-R3	1.0%	5.7%	NA	NA	1.8%
U2-FF-O-R1	NA	0.9%	NA	NA	NA
U2-FF-O-R2	NA	0.2%	NA	NA	NA
U2-FF-O-R3	NA	0.1%	NA	NA	NA
U3-SDA-I-R1	1.1%	0.8%	NA	NA	0.1%
U3-SDA-I-R2	1.2%	3.2%	NA	NA	0.3%
U3-SDA-I-R3	1.1%	0.3%	NA	NA	1.3%
U3-FF-O-R1	NA	5.6%	NA	NA	NA
U3-FF-O-R2	NA	1.3%	NA	NA	NA
U3-FF-O-R3	NA	2.7%	NA	NA	NA
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA
Reagent Blank 3/23/10				NA	
		U1-FF-O-R2	U2-FF-O-R2	U3-FF-O-R2	
Element		RPD	RPD	RPD	
Beryllium		NA	NA	NA	
Cadmium		NA	1.6%	13.5%	
Lead		0.5%	0.3%	12.4%	

RESULTS

**Table 2-21:
Quality Control and Quality Assurance – Metals (Continued)**

Sample Spike and Recovery						
Run Number		FH Front Half	BH H ₂ O ₂ /HNO ₄	A Empty Impinger	B KMnO ₄	C HCl
U1-SDA-I-R3	#1	122%	104%	100%	86%	99%
	#2	118%	106%	101%	84%	97%
U1-FF-O-R3	#1	116%	104%	81%	82%	100%
	#2	113%	103%	83%	84%	98%
U2-SDA-I-R3	#1	106%	107%	99%	88%	103%
	#2	102%	107%	97%	85%	102%
U2-FF-O-R3	#1	123%	96%	102%	81%	104%
	#2	122%	96%	99%	76%	103%
U3-SDA-I-R3	#1	124%	116%	87%	100%	101%
	#2	122%	110%	87%	102%	101%
U3-FF-O-R3	#1	90%	99%	100%	91%	98%
	#2	93%	101%	102%	90%	97%

Element	U1-FF-O-R3 Recovery	U2-FF-O-R3 Recovery	U3-FF-O-R3 Recovery
Beryllium	86%	89%	87%
Cadmium	91%	89%	85%
Lead	98%	97%	97%

Second Source Calibration Verification					
Element	.25 ppb	1 ppb	50 ppb	100 ppb	250 ppb
	QC Std 8	QC Std 2	QC Std 5	QC Std 4	QC Std 3
Beryllium	124%	100%	97%	99%	95%
Cadmium		100%	96%	100%	94%
Lead		92%	96%	99%	95%

RESULTS

**Table 2-22:
Quality Control and Quality Assurance – Method and Field Blanks**

	Average Total Catch ug	FH Front Half	BH H ₂ O ₂ /HNO ₄	A Empty Impinger	B KMnO ₄	C HCl
Mercury						
Field Blank	#1 < 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank	#1 < 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
Reagent Blank 3/23/10	#1 < 0.5				< 0.5	

Element	Field Blank Total µg	Reagent Blank Total µg
Beryllium	< 0.05	< 0.05
Cadmium	< 0.2	< 0.2
Lead	0.308	0.207

Method 23	0_7660_MB001 pg	Field Blank pg
Totals		
TCDDs	2.27	3.98
PeCDDs	0	0
HxCDDs	0	7.15
HpCDDs	3.61	4.94
OCDD	7.89	16.8
TCDFs	0	0
PeCDFs	0	0
HxCDFs	0	4.2
HpCDFs	0	4.27
OCDF	0	0
Total PCDD/Fs (ND=0; EMPC=0)	5.88	24.5
Total PCDD/Fs (ND=0; EMPC=EMPC)	17.5	48.1
Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)	50.5	64.4
Total 2378s (ND=0; EMPC=0)	0.00	9.65
Total 2378s (ND=0.5; EMPC=0)	20.4	20.2
Total 2378s (ND=1; EMPC=0)	40.7	30.7
Total 2378s (ND=0; EMPC=1)	11.6	37.1
Total 2378s (ND=0.5; EMPC=1)	28.1	35.6
Total 2378s (ND=1; EMPC=1)	44.6	43.7

RESULTS

2-21

**Table 2-23:
 Quality Control and Quality Assurance - Miscellaneous**

Blanks	Result	
Acetone (g)	<0.0001	
HCl DI H ₂ O (mg/l)	<0.099	
HCl 0.1 N H ₂ SO ₄ (mg/l)	<0.099	
HF DI H ₂ O (mg/l)	<0.040	
Meters - Post Cal	Result	Limit
61-6	-0.6%	≤ ± 5%
61-8	-0.4%	≤ ± 5%
66-11	-0.2%	≤ ± 5%
66-14	0.3%	≤ ± 5%
66-22	-0.5%	≤ ± 5%
66-24	-0.4%	≤ ± 5%
85-2	1.2%	≤ ± 5%
85-4	-0.2%	≤ ± 5%

End of Section 2 – Results

DESCRIPTION OF INSTALLATION

3-1

PROCESS DESCRIPTION

The South Broward Resource Recovery facility operates three (3) 750-tons-per-day municipal refuse-fired, water-wall boiler trains. The trains were manufactured by Babcock and Wilcox to produce electricity for sale to a local utility company. The boilers are rated at a maximum steam flow of 192,000 lbs/hr. Each boiler is equipped with an SDA for acid gas removal, followed by an FF baghouse for the control of particulate emissions and selective non-catalytic reduction for NO_x control. The control equipment is manufactured by Wheelabrator Air Pollution Control, Inc.

A carbon injection system was recently installed at South Broward for mercury control. All pertinent equipment for the carbon injection system was supplied by Chemco Systems of Monongahela, Pennsylvania, with the carbon rate scales being supplied by Merrick Industries of Lynn Haven, Florida. Each FF baghouse is followed by an induced draft fan that directs the flue gas to a dedicated flue in a common stack.

Figure 3-1 shows a general schematic of the facility. The general sampling locations for the Units 1, 2 and 3 SDA Inlets and FF Outlets are shown in Figure 3-2 on page 3-2.




Figure 3-1: General Process Schematic

DESCRIPTION OF INSTALLATION
PROCESS DESCRIPTION (CONTINUED)

3-2




Figure 3-2: Process Schematic

DESCRIPTION OF INSTALLATION

3-3

CleanAir

**Table 3-1:
 Unit 1 Compliance Test Process Data**

PLANT NAME: SOUTH BROWARD 2010				Data from DCS Printouts								Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												Test Run Comments
M-26A HCl	1	1	3/22/2010	08:31	09:31	183.3	315.0	6.5	507.4	37.1	27.7	9.5	25.7	1.071	0.738	418.4	All times based on CEMS time
		2	3/22/2010	09:58	10:58	184.8	314.9	6.5	508.3	36.7	30.2	6.5	17.6	1.096	1.002	390.8	
		3	3/22/2010	11:30	12:36	184.6	316.5	6.3	505.4	35.8	18.5	17.3	20.4	1.093	0.970	1009.2	
		Avg				184.2	315.4	6.5	507.0	36.6	25.5	11.1	21.2	1.087	0.903	606.1	
M-29/5 Metals PM	1	1	3/23/2010	07:43	09:58	183.5	315.0	6.5	505.5	35.9	25.2	10.7	28.7	1.064	0.671	432.4	All times based on CEMS time
		2	3/23/2010	10:31	12:45	183.9	315.1	6.6	512.1	37.9	28.5	9.4	28.7	1.060	0.624	350.8	
		3	3/23/2010	13:32	15:46	183.3	315.0	6.6	514.7	38.0	30.4	7.6	19.6	1.088	0.915	416.7	
		Avg				183.6	315.0	6.6	510.8	37.3	28.0	9.2	25.7	1.071	0.737	400.0	
M-13B HF	1	1	3/22/2010	13:19	14:34	183.9	315.0	6.5	503.2	34.8	23.2	11.6	19.8	1.092	0.966	669.4	All times based on CEMS time
		2	3/22/2010	15:07	16:21	184.2	314.9	6.4	508.3	35.9	28.7	7.2	17.0	1.090	0.942	406.9	
		3	3/22/2010	16:30	17:41	184.8	314.9	6.5	505.8	34.8	24.8	10.0	27.1	1.072	0.749	448.1	
		Avg				184.3	314.9	6.5	505.8	35.2	25.6	9.6	21.3	1.085	0.886	508.1	

DESCRIPTION OF INSTALLATION

3-4

CleanAir

**Table 3-2:
Unit 2 Compliance Test Process Data**

PLANT NAME: SOUTH BROWARD 2010				Data From DCS Printouts								Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow	FF Inlet Temp	Fabric Filter Delta	SDA Inlet Temp	Total SDA Flow	Diluton H2O flow	Slurry Flow	Slurry Conc.	Slurry Specific Gravity	Slurry CaO Density	CaO Flow	
				Start	Stop	klbs/hr	deg F	In. H2O	deg F	gpm	gpm	gpm	%	lb/gal	lbs/hr		
M-26A HCI	2	1	3/23/2010	07:55	08:55	185.2	319.8	6.5	492.3	31.0	19.3	11.7	33.2	1.064	0.673	472.0	All times based on CEMS time
		2	3/23/2010	09:30	10:30	183.2	320.2	6.7	496.5	32.5	22.1	10.5	32.2	1.063	0.659	413.6	
		3	3/23/2010	10:55	12:06	185.3	319.9	6.6	495.5	31.6	20.8	10.8	34.3	1.060	0.624	402.5	
		Avg				184.6	319.9	6.6	494.7	31.7	20.7	11.0	33.2	1.062	0.652	429.4	
M-29/5 Metals PM	2	1	3/24/2010	07:53	10:06	183.9	315.1	6.6	486.9	30.3	21.6	8.7	26.8	1.082	0.858	448.4	All times based on CEMS time
		2	3/24/2010	11:03	13:35	183.7	315.2	6.6	492.0	31.4	22.4	9.0	25.5	1.084	0.880	476.8	
		3	3/24/2010	14:12	16:22	183.3	315.1	6.7	498.9	33.6	24.2	9.5	18.1	1.099	1.044	591.9	
		Avg				183.6	315.1	6.6	492.6	31.8	22.7	9.1	23.5	1.088	0.927	505.7	
M-23 dioxins	2	1	3/22/2010	10:04	14:44	184.2	318.0	6.6	491.0	31.2	19.8	11.3	22.1	1.093	0.978	665.4	All times based on CEMS time
		2	3/23/2010	07:36	12:12	184.2	319.8	6.6	494.7	31.7	20.9	10.8	33.1	1.063	0.655	424.4	
		3	3/23/2010	12:32	17:02	183.9	320.0	6.7	503.2	33.8	23.1	10.7	23.3	1.084	0.881	565.6	
		Avg				184.1	319.3	6.6	496.3	32.2	21.3	10.9	26.1	1.080	0.838	551.8	
M-13B HF	2	1	3/24/2010	07:53	09:11	184.3	315.1	6.6	485.8	29.9	21.9	8.0	26.7	1.083	0.871	418.6	All times based on CEMS time
		2	3/24/2010	09:37	10:54	183.8	315.0	6.5	489.5	31.0	21.3	9.6	27.2	1.080	0.832	480.2	
		3	3/24/2010	11:24	12:46	183.6	315.1	6.6	490.5	30.9	21.9	9.0	29.0	1.076	0.789	425.6	
		Avg				183.9	315.0	6.6	488.6	30.6	21.7	8.9	27.6	1.080	0.831	441.5	

DESCRIPTION OF INSTALLATION

3-5

CleanAir:

**Table 3-3:
 Unit 3 Compliance Test Process Data**

PLANT NAME: SOUTH BROWARD 2010					Data From DCS Printouts							Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow kilbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	3	1	3/24/2010	07:45	08:45	184.1	315.0	6.8	464.8	31.7	22.5	9.2	25.8	1.084	0.879	483.6	All times based on CEMS time
		2	3/24/2010	09:16	10:16	184.2	315.1	6.7	462.8	30.8	19.4	11.4	27.6	1.081	0.840	573.0	
		3	3/24/2010	10:54	11:54	184.1	314.8	6.7	466.9	31.4	21.5	10.0	28.8	1.076	0.792	472.8	
		Avg				184.1	315.0	6.7	464.8	31.3	21.1	10.2	27.4	1.080	0.837	509.8	
M-29/5 Metals PM	3	1	3/22/2010	8:47	11:05	184.1	315.0	6.9	471.8	35.4	25.3	10.1	23.5	1.084	0.874	531.2	All times based on CEMS time
		2	3/22/2010	11:43	13:57	184.0	315.2	6.8	467.5	32.4	19.9	12.5	23.4	1.092	0.967	722.9	
		3	3/22/2010	14:24	16:39	184.2	314.9	6.7	470.4	33.0	21.4	11.5	23.6	1.089	0.927	641.3	
		Avg				184.1	315.0	6.8	469.9	33.6	22.2	11.4	23.5	1.088	0.923	631.8	
M-13B HF	3	1	3/23/2010	12:41	13:54	183.8	315.1	7.0	481.9	38.1	27.3	10.8	22.5	1.082	0.850	551.8	All times based on CEMS time
		2	3/23/2010	14:31	15:39	184.4	314.9	7.0	487.0	39.8	29.8	10.0	20.0	1.087	0.906	541.4	
		3	3/23/2010	15:54	17:02	183.9	315.0	6.9	479.5	36.7	25.6	11.1	21.9	1.086	0.898	598.1	
		Avg				184.0	315.0	7.0	482.8	38.2	27.6	10.6	21.4	1.085	0.885	563.8	

DESCRIPTION OF INSTALLATION

DESCRIPTION OF SAMPLING LOCATIONS

Sampling point locations were determined according to EPA Method 1.

Table 3-4 outlines the sampling point configurations. Figures 3-3 through 3-5, on pages 3-7 through 3-9, illustrate the sampling points and orientation of sampling ports for each of the sources that were tested in the program.

**Table 3-4:
Sampling Points**


Location	Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>Units 1, 2 and 3 SDA Inlets</u>								
	Hydrogen Chloride	26A ¹	1-3	1	1	60	60	3-3
	Mercury	29	1-3	1	1	5	120	3-4
<u>Units 1, 2 and 3 FF Outlets</u>								
	Particulate, Be, Cd, Pb and Hg	5/29 ²	1-3	5	5	5	125	3-5
	Hydrogen Chloride	26A ¹	1-3	1	1	60	60	NA
	Fluorides	13B	1-3	5	5	2.5	62.5	3-5
	PCDDs/PCDFs (Unit 1 only)	23	1-3	5	5	10	250	3-5

¹ Hydrogen chloride Inlet testing utilized a modification of EPA Method 26A (single point constant sampling rate).

² FF Outlet metals testing was done in conjunction with EPA Method 5 particulate sampling.

DESCRIPTION OF INSTALLATION
DESCRIPTION OF SAMPLING LOCATIONS (CONTINUED)

3-7




<u>Sampling Point</u> 1	<u>Port to Point Distance (in.)</u> approximate center
----------------------------	---

Equivalent diameters to upstream disturbance: 2.0	Limit: 2.0
Equivalent diameters to downstream disturbance: 0.5	Limit: 0.5

Figure 3-3: SDA Inlets - Sampling Point Determination (HCl Sampling)
(Units 1, 2 and 3 are identical)

DESCRIPTION OF INSTALLATION
SAMPLING POINT DETERMINATION (CONTINUED)

3-8




<u>Sampling Point</u>	<u>Port to Point Distance (in.)</u>
1	102.8
2	98.0
3	92.6
4	86.4
5	78.9
6	67.7
7	37.3
8	26.3
9	18.6
10	12.4
11	7.0
12	2.2

Diameters to upstream disturbance: >2.0
 Diameters to downstream disturbance: >0.5

Limit: 2.0
 Limit: 0.5

Figure 3-4: SDA Inlets - Sampling Point Determination (Hg Sampling)
 (Units 1, 2 and 3 are identical)

DESCRIPTION OF INSTALLATION
DESCRIPTION OF SAMPLING LOCATIONS (CONTINUED)



<u>Sampling Point</u>	<u>Port to Point Distance (in.)</u>
1	86.4
2	67.2
3	48.0
4	28.8
5	9.6

Equivalent diameters to upstream disturbance: 2.0 Limit: 2.0
Equivalent diameters to downstream disturbance: 0.5 Limit: 0.5

**Figure 3-5: FF Outlets - Sampling Point Determination
(Units 1, 2 and 3 are identical)**

End of Section 3 – Description of Installation

METHODOLOGY

Clean Air Engineering followed procedures as detailed in EPA Methods 1, 2, 3, 3A, 3B, 4, 5, 9, 13B, 22, 23, mod. 26A and 29. The following table summarizes the methods and their respective sources.

**Table 4-1:
Summary of Sampling Procedures**

Title 40 CFR Part 60 Appendix A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 3B	"Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air"
Method 5	"Determination of Particulate Matter Emissions from Stationary Sources"
Method 9	"Visual Determination of the Opacity of Emissions from Stationary Sources"
Method 13B	"Determination of Total Fluoride Emissions from Stationary Sources (Specific Ion Electrode Method)"
Method 23	"Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Municipal Waste Conductors"
Method 22	"Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Flares"
Mod.Method 26A ¹	"Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources Isokinetic Method"
Method 29	"Determination of Metals Emissions from Stationary Sources"

¹ Hydrogen chloride testing utilized a modification of EPA Method 26A (single point constant sampling rate) at the inlet and outlet sampling locations.

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and on the World Wide Web at <http://www.cleanair.com>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and in EPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods", EPA/600/R-94/038C. Additional QA/QC methods, as prescribed in CleanAir's internal Quality Manual, were also followed. Results of all QA/QC activities performed by CleanAir are summarized in Appendix E.

End of Section 4 – Methodology

APPENDIX	
TEST METHOD SPECIFICATIONS.....	A
SAMPLE CALCULATIONS.....	B
PLANT DATA.....	C
PARAMETERS.....	D
QA/QC DATA.....	E
ASTM D 6866-08 AND 7459-08 CO ₂ SAMPLING/ANALYSIS RESULTS.....	F
FIELD DATA.....	G
FIELD DATA PRINTOUTS.....	H
LABORATORY DATA.....	I
PERTINENT CERTIFICATIONS.....	J
CORRESPONDENCE AND CLARIFICATIONS.....	K

WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

TEST METHOD SPECIFICATIONS

A

This Page Intentionally Left Blank

Specification Sheet for EPA Method 5/29

Source Location Name(s) Units 1, 2 and 3 FF Outlets
 Pollutant(s) to be Determined Particulate Matter (PM) and Trace Metals (including Mercury)
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate

	Standard Method Specification	Actual Specification Used
Pollutant Sampling Information		
Duration of Run	N/A	125 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
Sampling Probe		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.805
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic material)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Fiberglass Fiber	Quartz Fiber
Other Components		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 5/29

Impinger Train Description

Type of Glassware Connections

Connection to Probe or Filter by

Number of Impingers

Impinger Stem Types

Impinger 1

Impinger 2

Impinger 3

Impinger 4

Impinger 5

Impinger 6

Impinger 7

Impinger 8

Gas Density Determination

Sample Collection

Sample Collection Medium

Sample Analysis

Sample Recovery Information

Probe Brush Material

Probe Rinse Reagent

Probe Rinse Wash Bottle Material

Probe Rinse Storage Container

Filter Recovered?

Filter Storage Container

Impinger Contents Recovered?

Impinger Rinse Reagent

Impinger Wash Bottle

Impinger Storage Container

Analytical Information

Method 4 H₂O Determination by

Filter Preparation Conditions

Front-Half Rinse Preparation

Back-Half Analysis

Additional Analysis

Standard Method Specification

Ground Glass or Equivalent

Direct Glass Connection

7

Modified Greenburg-Smith

Modified Greenburg-Smith

Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Multi-point integrated

Flexible Gas Bag

Orsat or Fyrite Analyzer

Non-metallic swab or bristle

Acetone/0.1N Nitric Acid

Glass or Teflon

See Method 29 Recovery Flow Chart

Yes

Petri Dish - Glass or Polystyrene

Yes

See Method 29 Recovery Flow Chart

Glass or Teflon

See Recovery Flow Chart

Volumetric or Gravimetric

See Method 29 Analytical Flow Chart

See Method 29 Analytical Flow Chart

See Method 29 Analytical Flow Chart

Gravimetric (EPA Method 5)

Actual Specification Used

Screw Joint with Silicone Gasket

Direct Glass Connection

7

Modified Greenburg-Smith

Modified Greenburg-Smith

Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Multi-Point Integrated

Vinyl Bag

CEM

Teflon Mat

Acetone/0.1N. Nitric Acid

Teflon

See Recovery Flow Chart

Yes

Glass

Yes

See Recovery Flow Chart

Teflon

See Recovery Flow Chart

Gravimetric and Volumetric


For Metals Analysis

See Analytical Flow Chart

See Analytical Flow Chart

Gravimetric (EPA Method 5)


EPA Method 5/29 Sampling Train Configuration



Impinger Contents

Impinger 1	Empty
Impinger 2	100 ml 5% HNO ₃ / 10% H ₂ O ₂
Impinger 3	100 ml 5% HNO ₃ / 10% H ₂ O ₂
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO ₄ / 10% H ₂ SO ₄
Impinger 6	100 ml 4% KMnO ₄ / 10% H ₂ SO ₄
Impinger 7	Silica Gel


EPA Method 29 Glassware Preparation Procedures




EPA Method 29 Sample Recovery Flowchart (includes Mercury and Particulate Matter)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)
- Collect one complete blank set per field test

A-7



EPA Method 29
Analytical Flowchart
 (includes Mercury and Particulate Matter)



Specification Sheet for

EPA Method 29

Source Location Name(s) Units 1,2 and 3 SDA Inlets
 Pollutant(s) to be Determined Trace Metals (including Mercury)
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate


	Standard Method Specification	Actual Specification Used
Pollutant Sampling Information		
Duration of Run	N/A	120 minutes
No. of Sample Traverse Points	N/A	24
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
Sampling Probe		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	10'
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.825
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Glass Fiber	Quartz Fiber
Other Components		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 29

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Impinger Train Description		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	7	7
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 7	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 8	Modified Greenburg-Smith	Modified Greenburg-Smith
Gas Density Determination		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
Sample Recovery Information		
Probe Brush Material	Non-metallic swab or bristle	Teflon Mat
Probe Rinse Reagent	0.1N Nitric Acid	0.1 N Nitric Acid
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Polyethylene or glass	Polyethylene
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Polyethylene
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Impinger Wash Bottle	Glass or Teflon	Teflon
Impinger Storage Container	See Recovery Flow Chart	See Recovery Flow Chart
Analytical Information		
Method 4 H ₂ O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See Method 29 Analytical Flow Chart	For Metals Analysis
Front-Half Rinse Preparation	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Back-Half Analysis	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Additional Analysis	None	None


EPA Method 29 SDA Inlet Sampling Train Configuration



Impinger Contents


Impinger 1	Empty
Impinger 2	100 ml 5% HNO ₃ / 10% H ₂ O ₂
Impinger 3	100 ml 5% HNO ₃ / 10% H ₂ O ₂
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO ₄ / 10% H ₂ SO ₄
Impinger 6	100 ml 4% KMnO ₄ / 10% H ₂ SO ₄
Impinger 7	Silica Gel

EPA Method 29 Glassware Preparation Procedures




EPA Method 29 Sample Recovery Flowchart (includes Mercury)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)
- Collect one complete blank set per field test



**EPA Method 29
Analytical Flowchart
(includes Mercury)**



Specification Sheet for EPA Method 13B

Source Location Name(s) Units 1 ,2 and 3 FF Outlets
 Pollutant(s) to be Determined Total Fluoride (F)
 Other Parameters to be Determined from Trai Gas Density, Moisture, Flow Rate

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Pollutant Sampling Information		
Duration of Run	N/A	62.5 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	2.5 minutes
Sampling Rate	Isokinetic (90-110%) 1 cfm maximum	Isokinetic (90-110%) 1 cfm maximum
Sampling Probe		
Nozzle Material	Stainless Steel or Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Stainless Steel or Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F (optional)	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.812
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	Exit of Probe or Between 3rd and 4th impingers	Exit of Probe
Filter Holder Material	Borosilicate Glass or Stainless Steel	Borosilicate Glass
Filter Support Material	Stainless Steel if filter at probe exit; Glass Frit if filter after 3rd impinger	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F if after probe, unheated if after 3rd imp.	248°F±25°F
Filter Material	Low F Quartz or Fiberglass if after probe, Whatman No. 1 if after 3rd impinger	Whatman No. 1 (Ashless)
Other Components		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 13B

Impinger Train Description

Type of Glassware Connections
 Connection to Probe or Filter by
 Number of Impingers
 Impinger Stem Types

- Impinger 1
- Impinger 2
- Impinger 3
- Impinger 4
- Impinger 5
- Impinger 6
- Impinger 7
- Impinger 8

Gas Density Determination

Sample Collection
 Sample Collection Medium
 Sample Analysis

Sample Recovery Information

Probe Brush Material
 Probe Rinse Reagent
 Probe Rinse Wash Bottle Material
 Probe Rinse Storage Container
 Filter Recovered?
 Filter Storage Container
 Impinger Contents Recovered?
 Impinger Rinse Reagent
 Impinger Wash Bottle
 Impinger Storage Container

Analytical Information

Method 4 H₂O Determination by
 Filter Preparation Conditions
 Front-Half Rinse Preparation
 Back-Half Analysis
 Additional Analysis

Standard Method Specification

Ground Glass or Equivalent
 Direct Glass Connection
 4

Modified Greenburg-Smith
 Greenburg-Smith
 Modified Greenburg-Smith
 Modified Greenburg-Smith

Multi-point integrated
 Flexible Gas Bag
 Orsat or Fyrite Analyzer

Nylon Bristle
 Deionized distilled water
 Glass or Polyethylene
 Polyethylene
 Yes
 Polyethylene
 Yes
 Deionized Distilled Water
 Glass or Polyethylene
 Polyethylene

Volumetric or Gravimetric
 See analytical flow chart
 See analytical flow chart
 Ion Specific Electrode
 N/A

Actual Specification Used

Screw Joint with Silicone Gasket
 Direct Glass Connection
 4


Modified Greenburg-Smith
 Greenburg-Smith
 Modified Greenburg-Smith
 Modified Greenburg-Smith

Multi-Point Integrated
 Vinyl Bag
 CEM

Nylon Bristle
 Deionized Distilled Water
 Teflon
 Polyethylene
 Yes
 Polyethylene
 Yes
 Deionized Distilled Water
 Teflon
 Polyethylene


Gravimetric and Volumetric
 See Analytical Flow Chart
 See Analytical Flow Chart
 Ion Chromatography
 None

EPA Method 13B Glassware Preparation Procedures




EPA Method 13B Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



EPA Method 13B Analytical Flowchart



Specification Sheet for

EPA Method 23

Source Location Name(s) Unit 2 FF Outlet
 Pollutant(s) to be Determined Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans (PCDD/PCDF)
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate


	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Pollutant Sampling Information		
Duration of Run	N/A	250 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	10 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
Sampling Probe		
Nozzle Material	Nickel, Quartz, Stainless Steel or Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.834
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Glass Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Glass Fiber - Toluene Extracted	Glass Fiber - Toluene Extracted
Other Components		
Adsorbent Module	XAD-2 Trap	XAD-II Adsorbent Trap
Location	After filter and condenser	After filter and condenser
Operating Temperature	< 68°F	<68°F

Specification Sheet for

EPA Method 23

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Impinger Train Description		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	5	5
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Shortened Stem (open tip)
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6		
Impinger 7		
Impinger 8		
Gas Density Determination		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
Sample Recovery Information		
Probe Brush Material	Inert Bristle	Teflon Mat
Probe Rinse Reagent	Acetone/Methylene Chloride/Toluene	Acetone/Toluene (see Appendix J)
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Glass	Glass
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Glass
Impinger Contents Recovered?	No	Archived
Impinger Rinse Reagent	N/A	HPLC Water
Impinger Wash Bottle	N/A	Teflon
Impinger Storage Container	N/A	Polyethylene
Analytical Information		
Method 4 H ₂ O Determination by	Volumetric or Gravimetric	Gravimetric
Filter Preparation Conditions	See Method 23 Analytical Flow Chart	For Organic Analysis
Front-Half Rinse Preparation	See Method 23 Analytical Flow Chart	Organic Analysis
Back-Half Analysis	N/A	Archive
Additional Analysis	None	None

EPA Method 23 Glassware Preparation Procedures




EPA Method 23 Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



EPA Method 23 Analytical Flowchart

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition
- All samples must be extracted within 30 days of collection
- All samples must be analyzed within 45 days of extraction
- All laboratory glassware must be cleaned as described in Section 3A of the "Manual of Analytical Methods for the Analysis of Pesticides"



Specification Sheet for

EPA Method 26A (modified)

Note: Modification includes the use of full-size impingers instead of midjet impingers.

Source Location Name(s) Units 1-3 SDA Inlets and Units 1-3 FF Outlets
 Pollutant(s) to be Determined Hydrogen Chloride (HCl)
 Other Parameters to be Determined from Train Gas Density, Moisture

	Standard Method Specification	Actual Specification Used
Pollutant Sampling Information		
Duration of Run	N/A	60 minutes
No. of Sample Traverse Points	N/A	1
Sample Time per Point	N/A	60 minutes
Sampling Rate	Constant Rate (±10%)	Constant Rate (±10%)
Sampling Probe		
Nozzle Material	N/A	None
Nozzle Design	N/A	N/A
Probe Liner Material	Borosilicate Glass	Borosilicate Glass
Effective Probe Length	N/A	4 feet
Probe Temperature Set-Point	>248°F	350°F @ Inlet, Stack Temp @ FF Outlet
Velocity Measuring Equipment		
Pitot Tube Design	None	None
Pitot Tube Coefficient	N/A	N/A
Pitot Tube Calibration by	N/A	N/A
Pitot Tube Attachment	N/A	N/A
Metering System Console		
Meter Type	Dry Gas Meter or Critical Orifice	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	2 liters/minute	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter	Wet Test Meter
Pump Type	Diaphragm or equivalent	Rotary Vane
Temperature Measurements	Dial Thermometer or equivalent	Type K Thermocouple/Pyrometer
Temperature Resolution	2°F-5.4°F	1.0°F
ΔP Differential Pressure Gauge	N/A	N/A
ΔH Differential Pressure Gauge	N/A	Inclined Manometer
Barometer	Mercury, aneroid or other.	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Teflon or Quartz	Borosilicate Glass
Filter Support Material	Teflon Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	>248°F	350°F @ Inlet, Stack Temp @ FF Outlet
Filter Material	Teflon/Glass Mat (Quartz, Optional High Temp>410F)	Quartz Fiber @ Inlet, Teflon on Glass @ Outlet
Other Components		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 26A (modified)

Impinger Train Description

Type of Glassware Connections

Connection to Probe or Filter by

Number of Impingers

Impinger Stem Types

Impinger 1

Impinger 2

Impinger 3

Impinger 4

Impinger 5

Impinger 6

Impinger 7

Impinger 8

Standard Method Specification

Ground Glass or Equivalent

Direct Glass Connection

5 or 6 (Midget Impingers)

Midget Shortened Stem

Midget Bubbler

Midget Bubbler

Midget Bubbler

Midget Bubbler

Mae West

Actual Specification Used

Screw Joint with Silicone Gasket

Direct Glass Connection

5

Shortened Stem (open tip)

Greenburg-Smith

Greenburg-Smith

Modified Greenburg-Smith

Modified Greenburg-Smith

Gas Density Determination

Sample Collection

Sample Collection Medium

Sample Analysis

N/A

N/A

N/A

Single Point Integrated

Vinyl Bag

CEM

Sample Recovery Information

Probe Brush Material

Probe Rinse Reagent

Probe Rinse Wash Bottle Material

Probe Rinse Storage Container

Filter Recovered?

Filter Storage Container

Impinger Contents Recovered?

Impinger Rinse Reagent

Impinger Wash Bottle

Impinger Storage Container

N/A

N/A

N/A

N/A

No

N/A

Yes

Deionized Distilled Water

Polyethylene or glass

Polyethylene

N/A

N/A

N/A

N/A

No

N/A

Yes

Deionized Distilled Water

Polyethylene

Polyethylene

Analytical Information

Method 4 H₂O Determination by

Filter Preparation Conditions

Front-Half Rinse Preparation

Back-Half Analysis

Additional Analysis

N/A

N/A

N/A

Ion Chromatography

None

Gravimetric


N/A

N/A

Ion Chromatography


None

EPA Method 26A Glassware Preparation Procedures




EPA Method 26
Sample Recovery Flowchart
(without Cl2)
(Modified)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



**EPA Method 26
Analytical Flowchart
(without Cl₂)
(Modified)**

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition



This Page Intentionally Left Blank

SAMPLE CALCULATIONS

B

This Page Intentionally Left Blank

**USEPA Method 5/29 (Particulate/Metals)
 Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 103649
 J

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	463.2	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	21.80	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
T_m	= average dry gas meter temperature (°F)	=	68.46	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	76.55	dcf
Y_d	= gas meter correction factor (dimensionless)	=	1.0005	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.19	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	77.169	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-11.00	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
P_s	= absolute sample gas pressure (in. Hg)	=	29.29	in. Hg

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	295.20	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.29	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.29	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.29	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	77.169	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	21.80	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2203	
		=	22.03	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.29	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.29	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2203	
B_w	= actual water vapor in gas	=	0.2203	
		=	22.03	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.74	%

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2+CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.7	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	29.93	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2203	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	29.93	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.30	lb/lb-mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left(\sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

K_p	= velocity pressure constant	=	85.49	
C_p	= pitot tube coefficient	=	0.81	
M_s	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.30	lb/lb-mole
P_s	= absolute sample gas pressure (in. Hg)	=	29.29	in. Hg
T_s	= average sample gas temperature (°F)	=	295.20	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H ₂ O)	=	0.689	$\sqrt{\text{in. H}_2\text{O}}$
460	= °F to °R conversion constant	=	460	
V_s	= sample gas velocity (ft/sec)	=	46.10	ft/sec

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

A_s	= cross sectional area of sampling location (ft ²)	=	64.00	ft ²
V_s	= sample gas velocity (ft/sec)	=	46.10	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
Q_a	= volumetric flow rate at actual conditions (acfm)	=	177,014	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left(\frac{P_s}{29.92} \right) \left(\frac{68 + 460}{T_s + 460} \right)$$

Where:

Q_a	= volumetric flow rate at actual conditions (acfm)	=	177,014	acfm
P_s	= absolute sample gas pressure (in. Hg)	=	29.29	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
T_s	= average sample gas temperature (°F)	=	295.2	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	121,159	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2203	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	121,159	scfm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm

16. Dry flow of sample gas corrected to 7%O₂ (dscfm)

$$Q_{std7} = (Q_{std}) \left(\frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q_{std7}	= volumetric flow rate at STP and 7%O ₂ , dry basis (dscfm)	=	77,005	dscfm

17. Hourly time basis conversion of volumetric flow rate (Q_{std} example)

$$Q_{std-hr} = (Q_{std-min}) (60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft ³ /min)	=	94,473	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Q_{std-hr}	= volumetric flow rate, hourly basis (dscf/hr)	=	5,668,358	dscf/hr

18. Metric Conversion of Gas Volumes (Q_{std} example)

$$Q_{std-metric} = (Q_{std-english}) \left(\frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft ³ /min)	=	94,473	dscfm
35.31	= conversion factor (ft ³ /m ³)	=	35.31	ft ³ /m ³
60	= conversion factor (min/hr)	=	60	min/hr
$Q_{std-metric}$	= volumetric flow rate, metric units (m ³ /hr)	=	160,531	dry std m ³ /hr

19. Standard to Normal Conversion of Gas Volumes (Q_{std} example)

$$Q_{Normal} = (Q_{std-metric}) \left(\frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m ³ /hr)	=	160,531	dry std m ³ /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	
Q_{Normal}	= volumetric flow rate, metric units (dry Nm ³ /hr)	=	149,586	dry Nm ³ /hr

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\bar{T}_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{144(4)}\right)(\Theta)(1 - B_w)}$$

Where:

D_n	= diameter of nozzle (in)	=	0.270	in.
B_w	= proportion of water vapor in the gas stream by volume	=	0.2203	
P_s	= absolute sample gas pressure (in. Hg)	=	29.29	in. Hg
T_s	= average sample gas temperature (°F)	=	295.2	°F
V_{mstd}	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	77.169	dscf
V_s	= sample gas velocity (ft/sec)	=	46.10	ft/sec
θ	= total sampling time (min)	=	125	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
I	= percent of isokinetic sampling (%)	=	105.25	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\Theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{@})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

θ	= total sampling time (min)	=	125	min
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	76.55	dcf
T_m	= average dry gas meter temperature (°F)	=	68.46	°F
$\Delta H_{@}$	= dry gas meter orifice coefficient	=	1.8097	
P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.185	in. H ₂ O
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	29.93	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.085	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
Y_{qa}	= alternative Method 5 post-test meter calibration factor	=	0.9679	

**USEPA Method 5/29
 Filterable Particulate Gravimetric Analysis Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 103649
 N

1. Total residue from gravimetric analysis of filters (g)

$$m_{fr} = \sum_{i=1}^n m_{fi}$$

Where:

m_{f1}	= residual mass of filter "1" from gravimetric analysis (g)	= 0.00050 g
m_{f2}	= residual mass of filter "2" from gravimetric analysis (g)	= 0.00000 g
m_{f3}	= residual mass of filter "3" from gravimetric analysis (g)	= 0.00000 g
m_{f4}	= residual mass of filter "4" from gravimetric analysis (g)	= 0.00000 g
m_{fr}	= total filter residue from gravimetric analysis (g)	= 0.00050 g

2. Total particulate collected on filters (g)

$$m_{filter} = m_{fr} \text{ if } m_{fr} \geq 0$$

$$m_{filter} = 0 \text{ if } m_{fr} < 0$$

Where:

m_{fr}	= total filter residue from gravimetric analysis (g)	= 0.00050 g
m_{filter}	= total particulate collected on filters (g)	= 0.00050 g

3. Solvent rinse - sample residue mass (g)

$$r_{si} = r_{ai} \left(\frac{v_{si}}{v_{ai}} \right)$$

Where:

r_{ai}	= aliquot residue mass for solvent "i" (g)	Acetone	= 0.00060 g
v_{si}	= sample liquid volume for solvent rinse "i" (ml)		= 76.0 ml
v_{ai}	= aliquot liquid volume for solvent rinse "i" (ml)		= 76.0 ml
r_{si}	= solvent rinse "i" - sample residue mass (g)		= 0.00060 g

4. Solvent rinse - blank residue (g)

$$m_{i-blank} = r_{ai-blank} \text{ if } r_{ai-blank} \geq 0$$

$$m_{i-blank} = 0 \text{ if } r_{ai-blank} < 0$$

Where:

$r_{ai-blank}$	= blank residue for solvent "i" from gravimetric analysis (g)	Acetone	= 0.00010 g
$m_{i-blank}$	= solvent rinse - blank residue (g)		= 0.00000 g

5. Solvent rinse - maximum allowable blank correction (g)

$$m_{bi} = \text{MINIMUM} \left[\left(\frac{(m_{i-blank})(v_{si})}{v_{ai-blank}} \right) \text{ or } (0.00001)(\rho_i)(v_{si}) \text{ or } (r_{si}) \right] \text{ if } r_{si} \geq 0$$

$$m_{bi} = 0 \quad \text{if } r_{si} < 0$$

Where:

		Acetone	
$m_{i-blank}$	= solvent rinse - blank residue (g)	= 0.00000	g
v_{si}	= sample liquid volume for solvent rinse "i" (ml)	= 76.0	ml
$v_{ai-blank}$	= blank liquid volume for solvent rinse "i" (ml)	= 146.0	ml
0.00001	= EPA M5 fraction of total rinse that can be subtracted (g)	= 0.00001	g
ρ_i	= density of solvent rinse "i" (g/ml)	= 0.7845	g/ml
r_{si}	= solvent rinse "i" - sample residue mass (g)	= 0.00060	g
m_{bi}	= solvent rinse "i" - maximum allowable blank correction (g)	= 0.00000	g

6. Solvent rinse - net residue (g)

$$m_i = (r_{si} - m_{bi}) \text{ if } r_{si} \geq m_{bi}$$

$$m_i = 0 \quad \text{if } r_{si} < m_{bi}$$

Where:

		Acetone	
r_{si}	= solvent rinse "i" - sample residue mass (g)	= 0.00060	g
m_{bi}	= solvent rinse "i" - maximum allowable blank correction (g)	= 0.00000	g
m_i	= solvent rinse "i" - net residue (g)	= 0.00060	g

7. Total solvent residue - (g)

$$m_s = \sum_{i=1}^n m_i$$

Where:

m_1	= solvent rinse "1" - net residue (g)	= 0.00060	g
m_2	= solvent rinse "2" - net residue (g)	= N/A	g
m_3	= solvent rinse "3" - net residue (g)	= N/A	g
m_s	= total solvent residue (g)	= 0.00060	g

8. Total gravimetric result (g)

$$m_T = m_{filter} + m_s$$

Where:

m_{filter}	= total particulate collected on filters (g)	= 0.00050	g
m_s	= total solvent residue (g)	= 0.00060	g
m_T	= total gravimetric result (g)	= 0.00110	g

9. Total gravimetric detection limit (g)

$$m_D = (MDL_{filter})(n_f) + (MDL_{rinse})(n_r)$$

Where:

MDL_{filter}	= minimum detection limit for single filter analysis (g)	= 0.00050 g
n_f	= number of filters in analysis	= 1
MDL_{rinse}	= minimum detection limit for single rinse analysis (g)	= 0.00050 g
n_r	= number of rinses in analysis	= 1
m_D	= total gravimetric detection limit (g)	= 0.00020 g

10. Total particulate matter (g)

$$m_n = \text{MAXIMUM}[m_T \text{ or } < m_D]$$

Where:

m_T	= total gravimetric result (g)	= 0.00110 g
m_D	= total gravimetric detection limit (g)	= 0.00020 g
m_n	= total particulate matter (g)	= 0.00110 g

**USEPA Method 5/29
 Filterable Particulate Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 163801
 J_N

1. Particulate concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3})$$

Where:

m_n	= total particulate matter (g)	= 0.00110	g
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
C_{sd}	= particulate concentration (lb/dscf)	= 3.1431E-08	lb/dscf

2. Particulate concentration (gr/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (15.43)$$

Where:

m_n	= total particulate matter (g)	= 0.00110	g
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
15.43	= conversion factor (gr/g)	= 15.43	gr/g
C_{sd}	= particulate concentration (gr/dscf)	= 0.00022	gr/dscf

3. Particulate concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (1000)(35.31)$$

Where:

m_n	= total particulate matter (g)	= 0.00110	g
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
1,000	= conversion factor (mg/g)	= 1,000	mg/g
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
C_{sd}	= particulate concentration (mg/dscm)	= 0.50332	mg/dscm

4. Particulate concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (1000)(35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00110	g
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
1,000	= conversion factor (mg/g)	=	1,000	mg/g
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
C_{sd}	= particulate concentration (mg/Nm ³ dry)	=	0.54015	mg/Nm ³ dry

5. Particulate concentration corrected to x% O₂ (gr/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= particulate concentration (gr/dscf)	=	0.00022	gr/dscf
x	= oxygen content of corrected gas (%)	=	7.0	%
O ₂	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
C_{sdx}	= particulate concentration corrected to x%O ₂ (gr/dscf)	=	0.00027	gr/dscf @ x%O ₂

6. Particulate concentration corrected to y% CO₂ (gr/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= particulate concentration (gr/dscf)	=	0.00022	gr/dscf
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO ₂	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.7	%
C_{sdy}	= particulate concentration corrected to y%CO ₂ (gr/dscf)	=	0.00027	gr/dscf @ y%CO ₂

7. Particulate concentration at actual gas conditions (gr/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= particulate concentration (gr/dscf)	=	0.00022	gr/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	=	177,014	acfm
C_a	= particulate concentration at actual gas conditions (gr/acf)	=	0.00012	gr/acf

8. Particulate rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) (60)$$

Where:

m_n	= total particulate matter (g)	=	0.00110	g
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= particulate rate (lb/hr)	=	0.1782	lb/hr

9. Particulate rate (kg/hr)

$$E_{kg/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{(Q_{std})(60)}{1000} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00110	g
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
1,000	= conversion factor (g/kg)	=	1,000	g/kg
$E_{kg/hr}$	= particulate rate (kg/hr)	=	0.0808	kg/hr

10. Particulate rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00110	g
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2,000	= conversion factor (lb/Ton)	=	2,000	lb/Ton
$E_{T/yr}$	= particulate rate (Ton/yr)	=	0.7804	Ton/yr

11. Particulate rate - F_d -based (lb/MMBtu)

$$E_{F_d} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00110	g
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
E_{F_d}	= particulate rate - F_d - based (lb/MMBtu)	=	0.00055	lb/MMBtu

12. Particulate rate - F_c -based (lb/MMBtu)

$$E_{F_c} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00110	g
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	=	9.7	%
100	= conversion factor	=	100	
E_{F_c}	= particulate rate - F_c - based (lb/MMBtu)	=	0.00059	lb/MMBtu

LOGIC FOR TREATING DETECTION LIMITS

(mercury only)

1. Logic for Determining Total Blank ($m_{\text{Total-B}}$) from 5 Fractions

	CASE 1 All 5 fractions are D.	CASE 2 1 to 4 fractions are ND	CASE 3 All 5 fractions are ND
Rule			
$ND = 0$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < \text{Sum ND}$
$ND = 1x$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < \text{Sum ND}$
$ND = 0.5x$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < 0.5 \text{ Sum ND}$

2. Logic for Determining Total Sample ($m_{\text{Total-S}}$) from 5 Fractions

	CASE 1 All 5 fractions are D.	CASE 2 1 to 4 fractions are ND	CASE 3 All 5 fractions are ND
Rule			
$ND = 0$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = \text{Sum D}$	$m_{\text{Total-S}} = < \text{Sum ND}$
$ND = 1x$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = < [\text{Sum D} + \text{Sum ND}]$	$m_{\text{Total-S}} = < \text{Sum ND}$
$ND = 0.5x$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = < [\text{Sum D} + 0.5 \text{ Sum ND}]$	$m_{\text{Total-S}} = < 0.5 \text{ Sum ND}$

3. Logic for Determining Maximum Allowable Blank Correction ($m_{\text{T-B-allow}}$)

	CASE 1 All 5 fractions are D. $m_{\text{Total-B}} = D$	CASE 2 1 to 4 sample fractions are ND $m_{\text{Total-B}} = D$	CASE 3 All 5 fractions are ND $m_{\text{Total-B}} = D$	CASE 4 Any type of fractions $m_{\text{Total-B}} = \text{ND}$
Rule				
$ND = 0$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$
$ND = 1x$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$
$ND = 0.5x$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$

* M29 rule using only detected sample quantities for logical comparisons.

4. Logic for Determining Blank-Corrected Sample Amount (m_n)

	CASE 1 All 5 fractions are D. $m_{\text{Total-S}} - m_{\text{T-B-allow}} \geq \text{MIN}(\text{MDL})$	CASE 2 1 to 4 sample fractions are ND $m_{\text{Total-S}} - m_{\text{T-B-allow}} \geq \text{MIN}(\text{MDL})$	CASE 3 All 5 fractions are ND $m_{\text{Total-S}}$ and $m_{\text{T-B-allow}}$ anything	CASE 4 Any type of fractions $m_{\text{Total-S}} - m_{\text{T-B-allow}} < \text{MIN}(\text{MDL})$
Rule				
$ND = 0$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN}[\text{MDL}]$
$ND = 1x$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < [m_{\text{Total-S}} - m_{\text{T-B-allow}}]$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN}[\text{MDL}]$
$ND = 0.5x$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < [m_{\text{Total-S}} - m_{\text{T-B-allow}}]$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN}[\text{MDL}]$

Laboratory Data

m_n

Net matter collected (g)

Filterable Particulate Results

C_{sd}

Particulate Concentration (mg/dscm)

C_{sd7}

Particulate Concentration @7% O₂ (mg/dscm)

Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

MIN[MDL] = lowest quantity of all detection limits for 5 fractions.

**USEPA Method 5/29
 Mercury Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

042010 103801
 0

1. Total blank amount (µg)

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

m_{1b-B}	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
m_{2b-B}	= mercury amount in blank for Fraction 2b	=	<0.2000	µg
m_{3a-B}	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
m_{3b-B}	= mercury amount in blank for Fraction 3b	=	<0.5000	µg
m_{3c-B}	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg

2. Total sample amount (µg)

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

m_{1b-S}	= mercury amount in sample for Fraction 1b	=	<0.1000	µg
m_{2b-S}	= mercury amount in sample for Fraction 2b	=	4.8386	µg
m_{3a-S}	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
m_{3b-S}	= mercury amount in sample for Fraction 3b	=	<0.5000	µg
m_{3c-S}	= mercury amount in sample for Fraction 3c	=	<0.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	4.8386	µg

3. Allowable blank correction (µg)

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = MAX [0.6, MIN (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Laboratory Data

m Net matter collected (g)

Filterable Particulate Results

C Particulate Concentration (mg/dscm)

C Particulate Concentration @7% O₂ (mg/dscm)

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	4.8386	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	0.2419	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total (μg)

$$m_n = m_{\text{total-S}} - m_{\text{T-B-allow}}$$

Where:

$m_{\text{total-S}}$	= total amount of mercury in sample	=	4.8386	μg
$m_{\text{T-B-allow}}$	= total allowable blank correction	=	0.0000	μg
m_n	= total mercury in sample corrected for allowable blank	=	4.8386	μg

5. Sample corrected for allowable blank - Prorated for each fraction (μg)

$$m_{n-i} = \left(\frac{m_{i-S}}{m_{\text{total-S}}} \right) (m_n)$$

Where:

m_n	= total mercury in sample corrected for allowable blank	=	4.8386	μg
m_{1b-S}	= mercury amount in sample for Fraction 1b	=	<0.1000	μg
m_{2b-S}	= mercury amount in sample for Fraction 2b	=	4.8386	μg
m_{3a-S}	= mercury amount in sample for Fraction 3a	=	<0.2000	μg
m_{3b-S}	= mercury amount in sample for Fraction 3b	=	<0.5000	μg
m_{3c-S}	= mercury amount in sample for Fraction 3c	=	<0.4000	μg
$m_{\text{total-S}}$	= total amount of mercury in sample	=	4.8386	μg
m_{n-1b}	= mercury corrected for blank - prorated for Fraction 1b	=	<0.1000	μg
m_{n-2b}	= mercury corrected for blank - prorated for Fraction 2b	=	4.8386	μg
m_{n-3a}	= mercury corrected for blank - prorated for Fraction 3a	=	<0.2000	μg
m_{n-3b}	= mercury corrected for blank - prorated for Fraction 3b	=	<0.5000	μg
m_{n-3c}	= mercury corrected for blank - prorated for Fraction 3c	=	<0.4000	μg

**USEPA Method 5/29
 Mercury Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 103905
 J_0

1. Mercury concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
C_{sd}	= mercury concentration (lb/dscf)	= 1.3826E-10	lb/dscf

2. Mercury concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
C_{sd}	= mercury concentration ($\mu\text{g/dscm}$)	= 2.2140E+00	$\mu\text{g/dscm}$

3. Mercury concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf

Laboratory Data

m Net matter collected (g)

Filterable Particulate Results

C Particulate Concentration (mg/dscm)

C Particulate Concentration @7% O₂ (mg/dscm)

35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	= 1000	$\mu\text{g/mg}$
C_{sd}	= mercury concentration (mg/dscm)	= 2.2140E-03	mg/dscm

4. Mercury concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	= 68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	
C_{sd}	= mercury concentration ($\mu\text{g}/\text{Nm}^3$ dry)	= 2.3760E+00	$\mu\text{g}/\text{Nm}^3$ dry

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= mercury concentration (lb/dscf)	= 1.3826E-10	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
C_{sdx}	= mercury concentration corrected to x% oxygen (lb/dscf)	= 1.6962E-10	lb/dscf @ x% O_2

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= mercury concentration (lb/dscf)	= 1.3826E-10	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 9.7	%
C_{sdy}	= mercury conc. corrected to y% carbon dioxide (lb/dscf)	= 1.7122E-10	lb/dscf @ y% CO_2

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= mercury concentration (lb/dscf)	= 1.3826E-10	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 177,014	acfm
C_a	= mercury concentration at actual gas conditions (lb/acf)	= 7.3788E-11	lb/acf

8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= mercury emission rate (lb/hr)	= 7.8369E-04	lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= mercury emission rate (g/s)	= 9.8727E-05	g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{T/yr}$	= mercury emission rate (Ton/yr)	= 3.4326E-03	Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= mercury emission rate - Fd-based (lb/MMBtu)	= 2.4407E-06	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 4.8386	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 9.7	%
100	= conversion factor	= 100	
E_{Fc}	= mercury emission rate - Fc-based (lb/MMBtu)	= 2.5968E-06	lb/MMBtu

LOGIC FOR TREATING DETECTION LIMITS

(all metals except mercury)

1. Logic for Determining Maximum Allowable Front-Half Blank Correction ($m_{FB-allow}$)

	CASE 1 $m_{FB} = D$	CASE 2 $m_{FB} = ND$
Rule		
$ND = 0$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$
$ND = 1x$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$
$ND = 0.5x$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$

2. Logic for Determining Blank-Corrected Front-Half Sample Amount (m_F)

	CASE 1 $m_{FS} - m_{FB-allow} \geq MDL$	CASE 2 $m_{FS} - m_{FB-allow} < MDL$
Rule		
$ND = 0$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$
$ND = 1x$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$
$ND = 0.5x$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$

3. Logic for Determining Maximum Allowable Back-Half Blank Correction ($m_{BB-allow}$)

	CASE 1 $m_{BB} = D$	CASE 2 $m_{BB} = ND$
Rule		
$ND = 0$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$
$ND = 1x$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$
$ND = 0.5x$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$

4. Logic for Determining Blank-Corrected Back-Half Sample Amount (m_B)

	CASE 1 $m_{BS} - m_{BB-allow} \geq MDL$	CASE 2 $m_{BS} - m_{BB-allow} < MDL$
Rule		
$ND = 0$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$
$ND = 1x$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$
$ND = 0.5x$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$

5. Logic for Adding Front and Back-Half Corrected Samples (m_n)

Laboratory Data

m_n Net matter collected (g)

Filterable Particulate Results

C_{ed} Particulate Concentration (mg/dscm)
 C_{ed7} Particulate Concentration @7% O₂ (mg/dscm)

CASE 1	CASE 2	CASE 3
Both are D	One is D, other is ND	Both are ND

Rule

$ND = 0$	$m_n = m_F + m_B$	$m_n = D$	$m_n = < \text{Sum ND}$
$ND = 1x$	$m_n = m_F + m_B$	$m_n = < [D + ND]$	$m_n = < \text{Sum ND}$
$ND = 0.5x$	$m_n = m_F + m_B$	$m_n = < [D + 0.5ND]$	$m_n = < 0.5 \text{ Sum ND}$

Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

If Front and Back-Half fractions are combined, then only Items 1 and 2 are used.

**USEPA Method 5/29
 Beryllium Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

042010 103923
 P

1. Maximum front-half blank correction criteria (µg)

$$A = (1.4) \left(\frac{3.141593}{4} \right) \left(\frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	µg/in ²
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	µg

2. Allowable blank correction - combined front and back-half sample fractions (µg)

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m _{FB}	= beryllium amount in combined front- and back-half blank	=	<0.0500	µg
m _{FS}	= beryllium amount in combined front- and back-half sample	=	<0.0500	µg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	µg
0.05 x m _{FS}	= 5% of combined front- and back-half sample amount	=	<0.0025	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
m _{FB-allow}	= allowable combined Beryllium blank correction	=	0.0000	µg

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank (µg)

Laboratory Data

m Net matter collected (g)

Filterable Particulate Results

C, Particulate Concentration (mg/dscm)

C, Particulate Concentration @7% O₂ (mg/dscm)

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m _{FS}	= beryllium amount in combined front- and back-half sample	=	<0.0500	µg
m _{FB-allow}	= allowable combined beryllium blank correction	=	0.0000	µg
m _n	= blank-corrected beryllium in combined sample	=	<0.0500	µg

**USEPA Method 5/29
 Beryllium Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 103947
 J_P

1. Beryllium concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
C_{sd}	= beryllium concentration (lb/dscf)	=	<1.4287E-12	lb/dscf

2. Beryllium concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= beryllium concentration ($\mu\text{g/dscm}$)	=	<2.2878E-02	$\mu\text{g/dscm}$

3. Beryllium concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	=	1000	$\mu\text{g/mg}$
C_{sd}	= beryllium concentration (mg/dscm)	=	<2.2878E-05	mg/dscm

4. Beryllium concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	= 68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

C_{sd} = beryllium concentration ($\mu\text{g}/\text{Nm}^3$ dry) = <2.4552E-02 $\mu\text{g}/\text{Nm}^3$ dry

5. Beryllium concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= beryllium concentration (lb/dscf)	= <1.4287E-12	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

C_{sdx} = beryllium concentration corrected to x% oxygen (lb/dscf) = <1.7528E-12 lb/dscf @ x% O_2

6. Beryllium concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= beryllium concentration (lb/dscf)	= <1.4287E-12	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 9.7	%

C_{sdy} = beryllium conc. corrected to y% carbon dioxide (lb/dscf) = <1.7693E-12 lb/dscf @ y% CO_2

7. Beryllium concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= beryllium concentration (lb/dscf)	= <1.4287E-12	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 177,014	acfm

C_a = beryllium concentration at actual gas conditions (lb/acf) = <7.6249E-13 lb/acf

8. Beryllium emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= beryllium emission rate (lb/hr)	=	<8.0983E-06	lb/hr

9. Beryllium emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	=	60	sec/min
$E_{g/s}$	= beryllium emission rate (g/s)	=	<1.0202E-06	g/s

10. Beryllium emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2000	= conversion factor (lb/Ton)	=	2000	lb/Ton
$E_{Ton/yr}$	= beryllium emission rate (Ton/yr)	=	<3.5471E-05	Ton/yr

11. Beryllium emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= beryllium emission rate - Fd-based (lb/MMBtu)	= <2.5221E-08	lb/MMBtu

12. Beryllium emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 9.7	%
100	= conversion factor	= 100	.
E_{Fc}	= beryllium emission rate - Fc-based (lb/MMBtu)	= <2.6834E-08	lb/MMBtu

**USEPA Method 5/29
 Cadmium Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

042010 104144
 P

1. Maximum front-half blank correction criteria (μg)

$$A = (1.4) \left(\frac{3.141593}{4} \right) \left(\frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	$\mu\text{g}/\text{in}^2$
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	μg

2. Allowable blank correction - combined front and back-half sample fractions (μg)

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m_{FB}	= cadmium amount in combined front- and back-half blank	=	<0.2000	μg
m_{FS}	= cadmium amount in combined front- and back-half sample	=	<0.2000	μg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	μg
$0.05 \times m_{FS}$	= 5% of combined front- and back-half sample amount	=	<0.0100	μg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{FB-allow}$	= allowable combined Cadmium blank correction	=	0.0000	μg

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank (μg)

Laboratory Data

m Net matter collected (g)

Filterable Particulate Results

C Particulate Concentration (mg/dscm)

C Particulate Concentration @7% O₂ (mg/dscm)

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m_{FS}	= cadmium amount in combined front- and back-half sample	=	<0.2000	μg
$m_{FB-allow}$	= allowable combined cadmium blank correction	=	0.0000	μg
m_n	= blank-corrected cadmium in combined sample	=	<0.2000	μg

**USEPA Method 5/29
 Cadmium Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104156
 J_P

1. Cadmium concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	<0.2000	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
C_{sd}	= cadmium concentration (lb/dscf)	=	<5.7147E-12	lb/dscf

2. Cadmium concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	<0.2000	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= cadmium concentration ($\mu\text{g/dscm}$)	=	<9.1514E-02	$\mu\text{g/dscm}$

3. Cadmium concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	<0.2000	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	=	1000	$\mu\text{g/mg}$
C_{sd}	= cadmium concentration (mg/dscm)	=	<9.1514E-05	mg/dscm

4. Cadmium concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	<0.2000	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	=	68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	=	32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	=	460	

C_{sd} = cadmium concentration ($\mu\text{g}/\text{Nm}^3$ dry) = <9.8210E-02 $\mu\text{g}/\text{Nm}^3$ dry

5. Cadmium concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= cadmium concentration (lb/dscf)	=	<5.7147E-12	lb/dscf
x	= oxygen content of corrected gas (%)	=	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%

C_{sdx} = cadmium concentration corrected to x% oxygen (lb/dscf) = <7.0110E-12 lb/dscf @ x% O_2

6. Cadmium concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= cadmium concentration (lb/dscf)	=	<5.7147E-12	lb/dscf
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.7	%

C_{sdy} = cadmium conc. corrected to y% carbon dioxide (lb/dscf) = <7.0771E-12 lb/dscf @ y% CO_2

7. Cadmium concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= cadmium concentration (lb/dscf)	=	<5.7147E-12	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,473	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	=	177,014	acfm

C_a = cadmium concentration at actual gas conditions (lb/acf) = <3.0500E-12 lb/acf

8. Cadmium emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

m_n	= cadmium collected in sample (total μg)	= <0.2000 μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
$E_{lb/hr}$	= cadmium emission rate (lb/hr)	= <3.2393E-05 lb/hr

9. Cadmium emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= <0.2000 μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689 dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473 dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60 sec/min
$E_{g/s}$	= cadmium emission rate (g/s)	= <4.0808E-06 g/s

10. Cadmium emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= <0.2000 μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760 hours/yr
2000	= conversion factor (lb/Ton)	= 2000 lb/Ton
$E_{Ton/yr}$	= cadmium emission rate (Ton/yr)	= <1.4188E-04 Ton/yr

11. Cadmium emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	<0.2000	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
E_{Fd}	= cadmium emission rate - Fd-based (lb/MMBtu)	=	<1.0088E-07	lb/MMBtu

12. Cadmium emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	<0.2000	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	=	9.7	%
100	= conversion factor	=	100	
E_{Fc}	= cadmium emission rate - Fc-based (lb/MMBtu)	=	<1.0734E-07	lb/MMBtu

**USEPA Method 5/29
 Lead Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

042010 104230
 P

1. Maximum front-half blank correction criteria (µg)

$$A = (1.4) \left(\frac{3.141593}{4} \right) \left(\frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	µg/in ²
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	µg

2. Allowable blank correction - combined front and back-half sample fractions (µg)

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m _{FB}	= lead amount in combined front- and back-half blank	=	0.2067	µg
m _{FS}	= lead amount in combined front- and back-half sample	=	0.5882	µg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	µg
0.05 x m _{FS}	= 5% of combined front- and back-half sample amount	=	0.0294	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
m _{FB-allow}	= allowable combined Lead blank correction	=	0.2067	µg

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank (µg)

Laboratory Data

m Net matter collected (g)

Filterable Particulate Results

C Particulate Concentration (mg/dscm)

C Particulate Concentration @7% O₂ (mg/dscm)

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m _{FS}	= lead amount in combined front- and back-half sample	=	0.5882	µg
m _{FB-allow}	= allowable combined lead blank correction	=	0.2067	µg
m _n	= blank-corrected lead in combined sample	=	0.3815	µg

**USEPA Method 5/29
 Lead Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104240
 J_P

1. Lead concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= lead collected in sample (total μg)	=	0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
C_{sd}	= lead concentration (lb/dscf)	=	1.0901E-11	lb/dscf

2. Lead concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= lead collected in sample (total μg)	=	0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= lead concentration ($\mu\text{g/dscm}$)	=	1.7457E-01	$\mu\text{g/dscm}$

3. Lead concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= lead collected in sample (total μg)	=	0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	=	77.1689	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	=	1000	$\mu\text{g/mg}$
C_{sd}	= lead concentration (mg/dscm)	=	1.7457E-04	mg/dscm

4. Lead concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	= 68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

C_{sd} = lead concentration ($\mu\text{g}/\text{Nm}^3$ dry) = 1.8734E-01 $\mu\text{g}/\text{Nm}^3$ dry

5. Lead concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= lead concentration (lb/dscf)	= 1.0901E-11	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

C_{sdx} = lead concentration corrected to x% oxygen (lb/dscf) = 1.3374E-11 lb/dscf @ x% O_2

6. Lead concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= lead concentration (lb/dscf)	= 1.0901E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 9.7	%

C_{sdy} = lead conc. corrected to y% carbon dioxide (lb/dscf) = 1.3500E-11 lb/dscf @ y% CO_2

7. Lead concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= lead concentration (lb/dscf)	= 1.0901E-11	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 177,014	acfm

C_a = lead concentration at actual gas conditions (lb/acf) = 5.8181E-12 lb/acf

8. Lead emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= lead emission rate (lb/hr)	= 6.1793E-05	lb/hr

9. Lead emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= lead emission rate (g/s)	= 7.7845E-06	g/s

10. Lead emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,473	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{Ton/yr}$	= lead emission rate (Ton/yr)	= 2.7065E-04	Ton/yr

11. Lead emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= lead emission rate - Fd-based (lb/MMBtu)	= 1.9245E-07	lb/MMBtu

12. Lead emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.3815	μg
V_{mstd}	= volume metered, standard (dscf)	= 77.1689	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 9.7	%
100	= conversion factor	= 100	
E_{Fc}	= lead emission rate - Fc-based (lb/MMBtu)	= 2.0475E-07	lb/MMBtu

**USEPA Method 13B (Total Fluorides)
 Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104529
 O

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	218.9	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	10.30	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
T_m	= average dry gas meter temperature (°F)	=	69.60	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	36.72	dcf
Y_d	= gas meter correction factor (dimensionless)	=	1.0005	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.14	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in.H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	36.936	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-10.20	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
P_s	= absolute sample gas pressure (in. Hg)	=	29.35	in. Hg

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	293.12	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.35	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.35	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.35	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	36.936	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	10.30	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2181	
		=	21.81	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.35	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.35	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2181	
B_w	= actual water vapor in gas	=	0.2181	
		=	21.81	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.3	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.51	%

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.3	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.5	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.02	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2181	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.02	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.40	lb/lb-mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left(\sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

K_p	= velocity pressure constant	=	85.49	
C_p	= pitot tube coefficient	=	0.81	
M_s	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.40	lb/lb-mole
P_s	= absolute sample gas pressure (in. Hg)	=	29.35	in. Hg
T_s	= average sample gas temperature (°F)	=	293.12	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H ₂ O)	=	0.682	√in. H ₂ O
460	= °F to °R conversion constant	=	460	
V_s	= sample gas velocity (ft/sec)	=	45.82	ft/sec

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

A_s	= cross sectional area of sampling location (ft ²)	=	64.00	ft ²
V_s	= sample gas velocity (ft/sec)	=	45.82	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
Q_a	= volumetric flow rate at actual conditions (acfm)	=	175,956	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left(\frac{P_s}{29.92} \right) \left(\frac{68 + 460}{T_s + 460} \right)$$

Where:

Q_a	= volumetric flow rate at actual conditions (acfm)	=	175,956	acfm
P_s	= absolute sample gas pressure (in. Hg)	=	29.35	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
T_s	= average sample gas temperature (°F)	=	293.1	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	121,010	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2181	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	121,010	scfm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,620	dscfm

16. Dry flow of sample gas corrected to 7%O₂ (dscfm)

$$Q_{std7} = (Q_{std}) \left(\frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,620	dscfm
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q_{std7}	= volumetric flow rate at STP and 7%O ₂ , dry basis (dscfm)	=	79,848	dscfm

17. Hourly time basis conversion of volumetric flow rate (Q_{std} example)

$$Q_{std-hr} = (Q_{std-min}) (60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft ³ /min)	=	94,620	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Q_{std-hr}	= volumetric flow rate, hourly basis (dscf/hr)	=	5,677,207	dscf/hr

18. Metric Conversion of Gas Volumes (Q_{std} example)

$$Q_{std-metric} = (Q_{std-english}) \left(\frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft ³ /min)	=	94,620	dscfm
35.31	= conversion factor (ft ³ /m ³)	=	35.31	ft ³ /m ³
60	= conversion factor (min/hr)	=	60	min/hr
$Q_{std-metric}$	= volumetric flow rate, metric units (m ³ /hr)	=	160,782	dry std m ³ /hr

19. Standard to Normal Conversion of Gas Volumes (Q_{std} example)

$$Q_{Normal} = (Q_{std-metric}) \left(\frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m ³ /hr)	=	160,782	dry std m ³ /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	
Q_{Normal}	= volumetric flow rate, metric units (dry Nm ³ /hr)	=	149,819	dry Nm ³ /hr

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\bar{T}_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(144)(4)}\right)(\theta)(1 - B_w)}$$

Where:

D_n	= diameter of nozzle (in)	=	0.268	in.
B_w	= proportion of water vapor in the gas stream by volume	=	0.2181	
P_s	= absolute sample gas pressure (in. Hg)	=	29.35	in. Hg
T_s	= average sample gas temperature (°F)	=	293.1	°F
V_{mstd}	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	36.936	dscf
V_s	= sample gas velocity (ft/sec)	=	45.82	ft/sec
θ	= total sampling time (min)	=	63	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
I	= percent of isokinetic sampling (%)	=	102.10	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\ominus}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\ominus})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

θ	= total sampling time (min)	=	63	min
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	36.72	dcf
T_m	= average dry gas meter temperature (°F)	=	69.60	°F
ΔH_{\ominus}	= dry gas meter orifice coefficient	=	1.8097	
P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.144	in. H ₂ O
M_d	= dry molecular weight of sample gas (lb/lb·mole)	=	30.02	lb/lb·mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.067	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb·mole)	=	28.96	lb/lb·mole
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in.H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
Y_{qa}	= alternative Method 5 post-test meter calibration factor	=	0.9921	

**USEPA Method 13B
 HF Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104315
 K

1. Fluoride to HF conversion factor

$$K_{HF} = \frac{MW_{HF}}{n \times MW_{F^-}}$$

Where:

MW _{HF}	= molecular weight of HF (mg/mg-mole)	=	20.006	mg/mg-mole
MW _{F⁻}	= molecular weight of fluoride ion (mg/mg-mole)	=	18.998	mg/mg-mole
n	= molar ratio of fluoride to HF	=	1.0	mole F/mole HF
K _{HF}	= conversion factor to convert mass F to mass HF	=	1.053	

2. Total HF collected (mg)

$$m_{HF} = K_{HF} \times \frac{(S_{F-1}v_1 + S_{F-2}v_2)}{1000}$$

Where:

K _{HF}	= conversion factor to convert mass F to mass HF	=	1.053	
S _{F-1}	= fluoride concentration of sample fraction 1 (mg/liter)	=	<0.0400	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	924.0	ml
S _{F-2}	= fluoride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v ₂	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m _{HF}	= total HF collected in sample (mg)	=	<0.0389	mg

Note: Non-detects are treated as zero in summations.

DEFINITION

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HF} \times B_F \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_F < MDL$$

Where:

K _{HF}	= conversion factor to convert mass F to mass HF	=	1.053	
B _F	= fluoride concentration of blank (mg/liter)	=	<0.0400	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	924.0	ml
v ₂	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m _b	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HF collected, corrected for blank (mg)

$$m_{nb} = m_{HF} - m_b$$

Where:

m_{HF}	= total HF collected in sample (mg)	=	<0.0389	mg
m_b	= allowable blank subtraction (mg)	=	0.0000	mg
m_{nb}	= total HF collected, corrected for blank (mg)	=	<0.0389	mg

5. Minimum detectable HF (mg)

$$m_{MDL} = K_{HF} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

K_{HF}	= conversion factor to convert mass F to mass HF	=	1.053	
MDL	= minimum detectable fluoride concentration	=	0.008	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	=	924.0	ml
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m_{MDL}	= minimum detectable HF (mg)	=	0.0078	mg

6. Total HF value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

m_{nb}	= total HF collected, corrected for blank (mg)	=	<0.0389	mg
m_{MDL}	= minimum detectable HF (mg)	=	0.0078	mg
m_n	= total HF value used in emission calculations (mg)	=	<0.0389	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HF} \times S_{F-2} \times \frac{v_2}{1000}}{m_{HF}}$$

Where:

K_{HF}	= conversion factor to convert mass F to mass HF	=	1.053	
S_{F-2}	= fluoride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
m_{HF}	= total HF collected in sample (mg)	=	<0.0389	mg
1000	= conversion factor (ml/liter)	=	1000	ml/liter
100	= conversion factor	=	100	%
EFF	= Collection QC check (% mass collected in second fraction)	=	0.00	%

**USEPA Method 13B
 HF Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104328
 O_K

1. HF concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0389	mg
V_{mstd}	= volume metered, standard (dscf)	=	36.9359	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
C_{sd}	= HF concentration (lb/dscf)	=	<2.3234E-09	lb/dscf

2. HF concentration (ppmdv)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{0.850}{1000} \right) \left(\frac{10^6}{MW} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0389	mg
V_{mstd}	= volume metered, standard (dscf)	=	36.9359	dscf
MW	= molecular weight of HF (g/g-mole)	=	20.006	g/g-mole
0.850	= conversion factor (dscf/g-mole)	=	0.850	dscf/g-mole
1000	= conversion factor (mg/g)	=	1,000	mg/g
10^6	= conversion factor (ppm)	=	10^6	ppm
C_{sd}	= HF concentration (ppmdv)	=	<0.0448	ppmdv

3. HF concentration (ppmwv)

$$C_w = C_{sd} \left(1 - \frac{B_w}{100} \right)$$

Where:

C_{sd}	= HF concentration (ppmdv)	=	<0.0448	ppmdv
B_w	= actual water vapor in gas (% v/v)	=	21.8078	% v/v
100	= conversion factor (%)	=	100	%
C_w	= HF concentration (ppmwv)	=	<0.0350	ppmwv

4. HF concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0389	mg
V_{mstd}	= volume metered, standard (dscf)	=	36.9359	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= HF concentration (mg/dscm)	=	<0.0372	mg/dscm

5. HF concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0389	mg
V_{mstd}	= volume metered, standard (dscf)	=	36.9359	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
C_{sd}	= HF concentration (mg/Nm ³ dry)	=	<0.0399	mg/Nm ³ dry

6. HF concentration corrected to x% O₂ (ppmdv example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= HF concentration (ppmdv)	=	<0.0448	ppmdv
x	= oxygen content of corrected gas (%)	=	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
C_{sdx}	= HF concentration corrected to x%O ₂ (ppmdv)	=	<0.0531	ppmdv @ x%O ₂

7. HF concentration corrected to y% CO₂ (ppmdv example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= HF concentration (ppmdv)	=	<0.0448	ppmdv
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.3	%
C_{sdy}	= HF concentration corrected to y%CO ₂ (ppmdv)	=	<0.0521	ppmdv @ y%CO ₂

8. HF concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= HF concentration (lb/dscf)	= <2.3234E-09 lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,620 dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 175,956 acfm
C_a	= HF concentration at actual gas conditions (lb/acf)	= <1.2494E-09 lb/acf

9. HF rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (Q_{std})(60)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	= <0.0389 mg
V_{mstd}	= volume metered, standard (dscf)	= 36.9359 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
1000	= conversion factor (mg/g)	= 1,000 mg/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,620 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
$E_{lb/hr}$	= HF rate (lb/hr)	= <0.0132 lb/hr

10. HF rate (kg/hr)

$$E_{kg/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{10^6} \right) (60)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	= <0.0389 mg
V_{mstd}	= volume metered, standard (dscf)	= 36.9359 dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,620 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
10^6	= conversion factor (mg/kg)	= 10^6 g/kg
$E_{kg/hr}$	= HF rate (kg/hr)	= <0.0060 kg/hr

11. HF rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	= <0.0389 mg
V_{mstd}	= volume metered, standard (dscf)	= 36.9359 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
1000	= conversion factor (mg/g)	= 1,000 mg/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,620 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760 hours/yr
2000	= conversion factor (lb/Ton)	= 2,000 lb/Ton
$E_{T/yr}$	= HF rate (Ton/yr)	= <0.0578 Ton/yr

12. HF rate - F_d -based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0389	mg
V_{mstd}	= volume metered, standard (dscf)	=	36.9359	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
E_{Fd}	= HF rate (lb/MMBtu)	=	<3.9617E-05	lb/MMBtu

13. HF rate - F_c -based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0389	mg
V_{mstd}	= volume metered, standard (dscf)	=	36.9359	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	=	10.3	%
100	= conversion factor	=	100	
E_{Fc}	= HF rate (lb/MMBtu)	=	<4.0974E-05	lb/MMBtu

**USEPA Method 23 (PCDD/F)
 Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104529
 H

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	815.5	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	38.38	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
T_m	= average dry gas meter temperature (°F)	=	72.58	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	140.94	dcf
Y_d	= gas meter correction factor (dimensionless)	=	0.9904	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.00	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in.H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	139.505	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-10.80	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
P_s	= absolute sample gas pressure (in. Hg)	=	29.31	in. Hg

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	293.30	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.31	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.31	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.31	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	139.505	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	38.38	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2157	
		=	21.57	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.31	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.31	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{w0}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{w0}	= proportion of water measured in the gas stream by volume	=	0.2157	
B_w	= actual water vapor in gas	=	0.2157	
		=	21.57	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.63	%

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2+CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.6	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	29.99	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2157	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	29.99	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.41	lb/lb-mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left(\frac{\sqrt{(T_s + 460)}}{(M_s)(P_s)} \right)$$

Where:

K_p	= velocity pressure constant	=	85.49	
C_p	= pitot tube coefficient	=	0.83	
M_s	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.41	lb/lb-mole
P_s	= absolute sample gas pressure (in. Hg)	=	29.31	in. Hg
T_s	= average sample gas temperature (°F)	=	293.30	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H ₂ O)	=	0.654	√in. H ₂ O
460	= °F to °R conversion constant	=	460	
V_s	= sample gas velocity (ft/sec)	=	45.17	ft/sec

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

A_s	= cross sectional area of sampling location (ft ²)	=	64.00	ft ²
V_s	= sample gas velocity (ft/sec)	=	45.17	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
Q_a	= volumetric flow rate at actual conditions (acfm)	=	173,437	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left(\frac{P_s}{29.92} \right) \left(\frac{68 + 460}{T_s + 460} \right)$$

Where:

Q_a	= volumetric flow rate at actual conditions (acfm)	=	173,437	acfm
P_s	= absolute sample gas pressure (in. Hg)	=	29.31	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
T_s	= average sample gas temperature (°F)	=	293.3	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	119,070	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2157	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	119,070	scfm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	93,381	dscfm

16. Dry flow of sample gas corrected to 7% O₂ (dscfm)

$$Q_{std7} = (Q_{std}) \left(\frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	93,381	dscfm
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q_{std7}	= volumetric flow rate at STP and 7% O ₂ , dry basis (dscfm)	=	78,534	dscfm

17. Hourly time basis conversion of volumetric flow rate (Q_{std} example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft ³ /min)	=	93,381	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Q_{std-hr}	= volumetric flow rate, hourly basis (dscf/hr)	=	5,602,843	dscf/hr

18. Metric Conversion of Gas Volumes (Q_{std} example)

$$Q_{std-metric} = (Q_{std-english}) \left(\frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft ³ /min)	=	93,381	dscfm
35.31	= conversion factor (ft ³ /m ³)	=	35.31	ft ³ /m ³
60	= conversion factor (min/hr)	=	60	min/hr
$Q_{std-metric}$	= volumetric flow rate, metric units (m ³ /hr)	=	158,676	dry std m ³ /hr

19. Standard to Normal Conversion of Gas Volumes (Q_{std} example)

$$Q_{Normal} = (Q_{std-metric}) \left(\frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m ³ /hr)	=	158,676	dry std m ³ /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	
Q_{Normal}	= volumetric flow rate, metric units (dry Nm ³ /hr)	=	147,857	dry Nm ³ /hr

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T_s} + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(144)(4)}\right)(\Theta)(1 - B_w)}$$

Where:

D_n	= diameter of nozzle (in)	=	0.264	in.
B_w	= proportion of water vapor in the gas stream by volume	=	0.2157	
P_s	= absolute sample gas pressure (in. Hg)	=	29.31	in. Hg
T_s	= average sample gas temperature (°F)	=	293.3	°F
V_{mstd}	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	139.505	dscf
V_s	= sample gas velocity (ft/sec)	=	45.17	ft/sec
Θ	= total sampling time (min)	=	250	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
I	= percent of isokinetic sampling (%)	=	100.67	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\Theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\Theta})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

Θ	= total sampling time (min)	=	250	min
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	140.94	dcf
T_m	= average dry gas meter temperature (°F)	=	72.58	°F
ΔH_{Θ}	= dry gas meter orifice coefficient	=	1.7516	
P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.004	in. H ₂ O
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	29.99	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.001	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
Y_{qa}	= alternative Method 5 post-test meter calibration factor	=	0.9887	

**USEPA Method 23
 PCDD/PCDF Emissions Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: PCDD/F results may be presented in two formats - normally expected levels and the maximum possible levels. In the normal case, data classified as ND (non-detect) or EMPC (estimated maximum possible concentration) are not counted. In the maximum possible emissions case, NDs and EMPCs are fully counted.

042010 104529
 H_P

		Normal Case (ND & EMPC = 0)	Maximum Case (ND & EMPC fully counted)
1. TEQ concentration (ng/dscm)			
C_{sd}	$= \left(\frac{m_{n-TEQ}}{V_{mstd}} \right) \times 35.31$		
Where:			
m_{n-TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 9.0700E-02 ng	9.6000E-02 ng
V_{mstd}	= volume metered, standard (dscf)	= 139.5047 dscf	139.5047 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm	35.31 dscf/dscm
C_{sd}	= PCDD/F TEQ concentration (ng/dscm)	= 2.2957E-02 ng/dscm	2.4299E-02 ng/dscm
2. TEQ concentration (ng/Nm³ dry)			
C_{sd}	$= \left(\frac{m_{n-TEQ}}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$		
Where:			
m_{n-TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 9.0700E-02 ng	9.6000E-02 ng
V_{mstd}	= volume metered, standard (dscf)	= 139.5047 dscf	139.5047 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm	35.31 dscf/dscm
68	= standard temperature (°F)	= 68 °F	68 °F
32	= normal temperature (°F)	= 32 °F	32 °F
460	= °F to °R conversion constant	= 460	460
C_{sd}	= PCDD/F TEQ concentration (ng/Nm ³ dry)	= 2.4637E-02 ng/Nm ³ dry	2.6076E-02 ng/Nm ³ dry
3. TEQ concentration at actual gas conditions (ng/acm example)			
C_a	$= C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$		
Where:			
C_{sd}	= PCDD/F TEQ concentration (ng/dscm)	= 2.2957E-02 ng/dscm	2.4299E-02 ng/dscm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscm/h)	= 158,676 dry std m ³ /hr	158,676 dry std m ³ /hr
Q_a	= volumetric flow rate at actual conditions (acm/h)	= 294,710 actual m ³ /hr	294,710 actual m ³ /hr
C_a	= PCDD/F TEQ concentration at actual gas conditions (ng/acm)	= 1.2360E-02 ng/acm	1.3083E-02 ng/acm

4. TEQ concentration corrected to x% O2 (ng/dscm example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= PCDD/F TEQ concentration (ng/dscm)	=	2.2957E-02	ng/dscm	2.4299E-02	ng/dscm
x	= oxygen content of corrected gas (%)	=	7.0	%	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%	9.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%	20.9	%
C_{sdx}	= PCDD/F TEQ concentration (ng/dscm corrected to x% O ₂)	=	2.7297E-02	ng/dscm @ x% O ₂	2.8892E-02	ng/dscm @ x% O ₂

5. TEQ concentration corrected to y% CO2 (ng/dscm example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= PCDD/F TEQ concentration (ng/dscm)	=	2.2957E-02	ng/dscm	2.4299E-02	ng/dscm
y	= carbon dioxide content of corrected gas (%)	=	12.0	%	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%	10.2	%
C_{sdy}	= PCDD/F TEQ concentration (ng/dscm corrected to y% CO ₂)	=	2.7115E-02	ng/dscm @ y% CO ₂	2.8699E-02	ng/dscm @ y% CO ₂

6. TEQ Emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_{n-TEQ}}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) \left(\frac{60}{10^9} \right)$$

Where:

m_{n-TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	=	9.0700E-02	ng	9.6000E-02	ng
V_{mstd}	= volume metered, standard (dscf)	=	139.5047	dscf	139.5047	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	93,381	dscfm	93,381	dscfm
60	= conversion factor (min/hr)	=	60	min/hr	60	min/hr
10^9	= conversion factor to convert from ng to grams	=	1.0E+09	ng/g	1.0E+09	ng/g
$E_{lb/hr}$	= PCDDF TEQ Emission rate (lb/hr)	=	8.0322E-09	lb/hr	8.5016E-09	lb/hr

7. TEQ Emission rate (g/sec)

$$E_{g/sec} = \left(\frac{m_{n-TEQ}}{V_{mstd}} \right) \left(\frac{Q_{std}}{60 \times 10^9} \right)$$

Where:

m_{n-TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	=	9.0700E-02	ng	9.6000E-02	ng
V_{mstd}	= volume metered, standard (dscf)	=	139.5047	dscf	139.5047	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	93,381	dscfm	93,381	dscfm
60	= conversion factor (sec/min)	=	60	sec/min	60	sec/min
10^9	= conversion factor to convert from ng to grams	=	1.0E+09	ng/g	1.0E+09	ng/g
$E_{g/sec}$	= PCDDF TEQ Emission rate (g/sec)	=	1.0119E-09	g/sec	1.0710E-09	g/sec

$$8. \text{ TEQ emission rate (Ton/yr)} \\ E_{T/yr} = \left(\frac{m_{n_TEQ}}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^9} \right) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_{n_TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 9.0700E-02	ng	9.6000E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 139.5047	dscf	139.5047	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 93,381	dscfm	93,381	dscfm
60	= conversion factor (min/hr)	= 60	min/hr	60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr	8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2,000	lb/Ton	2,000	lb/Ton
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
$E_{T/yr}$	= PCDDF TEQ Emission rate (Ton/yr)	= 3.5181E-08	Ton/yr	3.7237E-08	Ton/yr

9. TEQ emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_{n_TEQ}}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^9} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_{n_TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 9.0700E-02	ng	9.6000E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 139.5047	dscf	139.5047	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 9.2	%	9.2	%
20.9	= oxygen content of ambient air (%)	= 20.9	%	20.9	%
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
E_{Fd}	= PCDDF TEQ Emission rate (lb/MMBtu)	= 2.4528E-11	lb/MMBtu	2.5962E-11	lb/MMBtu

10. TEQ emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_{n_TEQ}}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^9} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_{n_TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 9.0700E-02	ng	9.6000E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 139.5047	dscf	139.5047	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu	1,820	dscf/MMBtu
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.2	%	10.2	%
100	= conversion factor	= 100		100	
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
E_{Fc}	= PCDDF TEQ Emission rate (lb/MMBtu)	= 2.5681E-11	lb/MMBtu	2.7181E-11	lb/MMBtu

**USEPA Method 26A (HCl)
 Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104735
0

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	247.6	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	11.65	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
T_m	= average dry gas meter temperature (°F)	=	67.58	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	41.32	dcf
Y_d	= gas meter correction factor (dimensionless)	=	1.0005	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.50	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	41.758	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.10	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-10.60	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
P_s	= absolute sample gas pressure (in. Hg)	=	29.32	in. Hg

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	294.67	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F

P_v	= vapor pressure, actual (in. Hg)	=	29.32	in. Hg
-------	-----------------------------------	---	-------	--------

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.32	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.32	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	41.758	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	11.65	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2182	
		=	21.82	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.32	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.32	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2182	
B_w	= actual water vapor in gas	=	0.2182	
		=	21.82	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.2	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	10.0	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.74	%

10. Molecular weight of dry gas stream (lb/lb·mole)

$$M_d = (M_{CO_2}) \left(\frac{CO_2}{100} \right) + (M_{O_2}) \left(\frac{O_2}{100} \right) + (M_{N_2+CO}) \left(\frac{N_2 + CO}{100} \right)$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb·mole)	=	44.00	lb/lb·mole
M_{O_2}	= molecular weight of oxygen (lb/lb·mole)	=	32.00	lb/lb·mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb·mole)	=	28.00	lb/lb·mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.2	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	10.0	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.7	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb·mole)	=	29.88	lb/lb·mole

11. Molecular weight of sample gas (lb/lb·mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2182	
M_d	= dry molecular weight of sample gas (lb/lb·mole)	=	29.88	lb/lb·mole
M_{H_2O}	= molecular weight of water (lb/lb·mole)	=	18.00	lb/lb·mole
M_s	= molecular weight of sample gas, wet basis (lb/lb·mole)	=	27.29	lb/lb·mole

**USEPA Method 26A
 HCl Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104735
 ©

1. Chloride to HCl conversion factor

$$K_{HCl} = \frac{MW_{HCl}}{n \times MW_{Cl^-}}$$

Where:

MW _{HCl}	= molecular weight of HCl (mg/mg-mole)	=	36.461	mg/mg-mole
MW _{Cl⁻}	= molecular weight of chloride ion (mg/mg-mole)	=	35.453	mg/mg-mole
n	= molar ratio of chloride to HCl	=	1.0	mole Cl ⁻ /mole HCl
K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.028	

2. Total HCl collected (mg)

$$m_{HCl} = K_{HCl} \times \frac{(S_{Cl-1}v_1 + S_{Cl-2}v_2)}{1000}$$

Where:

K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.028	
S _{Cl-1}	= chloride concentration of sample fraction 1 (mg/liter)	=	13.0700	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	826.0	ml
S _{Cl-2}	= chloride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v ₂	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m _{HCl}	= total HCl collected in sample (mg)	=	11.0981	mg

Note: Non-detects are treated as zero in summations.

DEFINITION

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HCl} \times B_{Cl} \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_{Cl} < MDL$$

Where:

K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.0280	
B _{Cl}	= chloride concentration of blank (mg/liter)	=	<0.1	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	826.0	ml
v ₂	= liquid volume of sample fraction 2 (ml)	=	0	ml
1000	= conversion factor (ml/liter)	=	1000.0000	ml/liter
m _b	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HCl collected, corrected for blank (mg)

$$m_{nb} = m_{HCl} - m_b$$

Where:

m_{HCl}	= total HCl collected in sample (mg)	= 11.0981	mg
m_b	= allowable blank subtraction (mg)	= 0.0000	mg
m_{nb}	= total HCl collected, corrected for blank (mg)	= 11.09810296	mg

5. Minimum detectable HCl (mg)

$$m_{MDL} = K_{HCl} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

K_{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	= 1.028	
MDL	= minimum detectable chloride concentration	= 0.0	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	= 826.0	ml
v_2	= liquid volume of sample fraction 2 (ml)	= 0	ml
1000	= conversion factor (ml/liter)	= 1000	ml/liter
m_{MDL}	= minimum detectable HCl (mg)	= 0.01698256	mg

6. Total HCl value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

m_{nb}	= total HCl collected, corrected for blank (mg)	= 11.0981	mg
m_{MDL}	= minimum detectable HCl (mg)	= 0.01698256	mg
m_n	= total HCl value used in emission calculations (mg)	= 11.09810296	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HCl} \times S_{Cl-2} \times \frac{v_2}{1000}}{m_{HCl}}$$

Where:

K_{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	= 1.0280	
S_{Cl-2}	= chloride concentration of sample fraction 2 (mg/liter)	= 0.0	mg/liter
v_2	= liquid volume of sample fraction 2 (ml)	= 0.0000	ml
m_{HCl}	= total HCl collected in sample (mg)	= 11	mg
1000	= conversion factor (ml/liter)	= 1000	ml/liter
100	= conversion factor	= 100	%
EFF	= Collection QC check (% mass collected in second fraction)	= 0	%

**USEPA Method 26A
 HCl Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042010 104735
 O_@

1. HCl concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	11.0981	mg
V_{mstd}	= volume metered, standard (dscf)	=	41.7580	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g

C_{sd}	= HCl concentration (lb/dscf)	=	5.8603E-07	lb/dscf
----------	-------------------------------	---	------------	---------

2. HCl concentration (ppmdv)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{0.850}{1000} \right) \left(\frac{10^6}{MW} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	11.0981	mg
V_{mstd}	= volume metered, standard (dscf)	=	41.7580	dscf
MW	= molecular weight of HCl (g/g-mole)	=	36.461	g/g-mole
0.850	= conversion factor (dscf/g-mole)	=	0.850	dscf/g-mole
1000	= conversion factor (mg/g)	=	1,000	mg/g
10^6	= conversion factor (ppm)	=	10^6	ppm

C_{sd}	= HCl concentration (ppmdv)	=	6.1958	ppmdv
----------	-----------------------------	---	--------	-------

3. HCl concentration (ppmwv)

$$C_w = C_{sd} \left(1 - \frac{B_w}{100} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	=	6.1958	ppmdv
B_w	= actual water vapor in gas (% v/v)	=	21.8162	% v/v
100	= conversion factor (%)	=	100	%

C_w	= HCl concentration (ppmwv)	=	4.8441	ppmwv
-------	-----------------------------	---	--------	-------

4. HCl concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	11.0981	mg
V_{mstd}	= volume metered, standard (dscf)	=	41.7580	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= HCl concentration (mg/dscm)	=	9.3844	mg/dscm

5. HCl concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	11.0981	mg
V_{mstd}	= volume metered, standard (dscf)	=	41.7580	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
C_{sd}	= HCl concentration (mg/Nm ³ dry)	=	10.0711	mg/Nm ³ dry

6. HCl concentration corrected to x% O₂ (ppmdv example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	=	6.1958	ppmdv
x	= oxygen content of corrected gas (%)	=	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	10.0	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
C_{sdx}	= HCl concentration corrected to x%O ₂ (ppmdv)	=	7.9156	ppmdv @ x%O ₂

7. HCl concentration corrected to y% CO₂ (ppmdv example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	=	6.1958	ppmdv
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	9.2	%
C_{sdy}	= HCl concentration corrected to y%CO ₂ (ppmdv)	=	8.0465	ppmdv @ y%CO ₂

8. HCl rate - F_d -based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	11.0981	mg
V_{mstd}	= volume metered, standard (dscf)	=	41.7580	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	=	10.0	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
E_{Fd}	= HCl rate (lb/MMBtu)	=	1.0773E-02	lb/MMBtu

9. HCl rate - F_c -based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	11.0981	mg
V_{mstd}	= volume metered, standard (dscf)	=	41.7580	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
100	= conversion factor	=	100	
E_{Fc}	= HCl rate (lb/MMBtu)	=	1.1543E-02	lb/MMBtu

This Page Intentionally Left Blank

WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

PLANT DATA

C

This Page Intentionally Left Blank

**WHEELABRATOR SOUTH BROWARD
TONS OF REFUSE PROCESSED PER STACK TEST RUN LOG (2010)**

UNIT #1						
Date	Res	Method #	Run #	Steam (klb/hr)	Run Length (hr)	Trash Processed (tons)
3/22/2010	HCl	26A	1	183.3	1.00	32.2
3/22/2010	HCl	26A	2	184.8	1.00	32.4
3/22/2010	HCl	26A	3	184.6	1.10	35.6
3/23/2010	Particulate/Metals	5/29	1	183.5	2.25	72.5
3/23/2010	Particulate/Metals	5/29	2	183.9	2.23	72.0
3/23/2010	Particulate/Metals	5/29	3	183.3	2.23	71.7
3/22/2010	Fluorides	13B	1	183.9	1.25	40.3
3/22/2010	Fluorides	13B	2	184.2	1.23	39.7
3/22/2010	Fluorides	13B	3	184.8	1.18	38.2
n/a	Dioxins/Furans	23	1	n/a	n/a	n/a
n/a	Dioxins/Furans	23	2	n/a	n/a	n/a
n/a	Dioxins/Furans	23	3	n/a	n/a	n/a

UNIT #2						
Date	Res	Method #	Run #	Steam (klb/hr)	Run Length (hr)	Trash Processed (tons)
3/23/2010	HCl	26A	1	185.2	1.00	32.5
3/23/2010	HCl	26A	2	183.2	1.00	32.1
3/23/2010	HCl	26A	3	185.3	1.18	38.4
3/24/2010	Particulate/Metals	5/29	1	183.9	2.22	71.6
3/24/2010	Particulate/Metals	5/29	2	183.7	2.53	81.5
3/24/2010	Particulate/Metals	5/29	3	183.3	2.17	69.8
3/24/2010	Fluorides	13B	1	184.3	1.30	42.0
3/24/2010	Fluorides	13B	2	183.8	1.28	41.3
3/24/2010	Fluorides	13B	3	183.6	1.30	41.9
3/22/2010	Dioxins/Furans	23	1	184.2	4.67	150.9
3/23/2010	Dioxins/Furans	23	2	184.2	4.60	148.6
3/23/2010	Dioxins/Furans	23	3	183.9	4.50	145.2

UNIT #3						
Date	Res	Method #	Run #	Steam (klb/hr)	Run Length (hr)	Trash Processed (tons)
3/24/2010	HCl	26A	1	184.1	1.00	32.3
3/24/2010	HCl	26A	2	184.2	1.00	32.3
3/24/2010	HCl	26A	3	184.1	1.00	32.3
3/22/2010	Particulate/Metals	5/29	1	184.1	2.30	74.3
3/22/2010	Particulate/Metals	5/29	2	184.0	2.23	72.0
3/22/2010	Particulate/Metals	5/29	3	184.2	2.25	72.7
3/23/2010	Fluorides	13B	1	183.8	1.22	39.3
3/23/2010	Fluorides	13B	2	184.4	1.13	36.5
3/23/2010	Fluorides	13B	3	183.9	1.13	36.5
n/a	Dioxins/Furans	23	1	n/a	n/a	n/a
n/a	Dioxins/Furans	23	2	n/a	n/a	n/a
n/a	Dioxins/Furans	23	3	n/a	n/a	n/a

Metals: Cd (cadmium) Hg (mercury) Be (beryllium) Pb (lead)

Stack Test Process Data

PLANT NAME: SOUTH BROWARD 2010						Data from DCS Printouts						Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	1	1	3/22/2010	08:31	09:31	183.3	315.0	6.5	507.4	37.1	27.7	9.5	25.7	1.071	0.738	418.4	All times based on CEMS time
		2	3/22/2010	09:58	10:58	184.8	314.9	6.5	508.3	36.7	30.2	6.5	17.6	1.096	1.002	390.8	
		3	3/22/2010	11:30	12:36	184.6	316.5	6.3	505.4	35.8	18.5	17.3	20.4	1.093	0.970	1009.2	
		Avg				184.2	315.4	6.5	507.0	36.6	25.5	11.1	21.2	1.087	0.903	606.1	
M-29/5 Metals PM	1	1	3/23/2010	07:43	09:58	183.5	315.0	6.5	505.5	35.9	25.2	10.7	28.7	1.064	0.671	432.4	All times based on CEMS time
		2	3/23/2010	10:31	12:45	183.9	315.1	6.6	512.1	37.9	28.5	9.4	28.7	1.060	0.624	350.8	
		3	3/23/2010	13:32	15:46	183.3	315.0	6.6	514.7	38.0	30.4	7.6	19.6	1.088	0.915	416.7	
		Avg				183.6	315.0	6.6	510.8	37.3	28.0	9.2	25.7	1.071	0.737	400.0	
M-13B HF	1	1	3/22/2010	13:19	14:34	183.9	315.0	6.5	503.2	34.8	23.2	11.6	19.8	1.092	0.966	669.4	All times based on CEMS time
		2	3/22/2010	15:07	16:21	184.2	314.9	6.4	508.3	35.9	28.7	7.2	17.0	1.090	0.942	406.9	
		3	3/22/2010	16:30	17:41	184.8	314.9	6.5	505.8	34.8	24.8	10.0	27.1	1.072	0.749	448.1	
		Avg				184.3	314.9	6.5	505.8	35.2	25.6	9.6	21.3	1.085	0.886	508.1	

C-4

Stack Test Process Data

PLANT NAME: SOUTH BROWARD 2010					Data From DCS Printouts							Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow kibs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	2	1	3/23/2010	07:55	08:55	185.2	319.8	6.5	492.3	31.0	19.3	11.7	33.2	1.064	0.673	472.0	All times based on CEMS time
		2	3/23/2010	09:30	10:30	183.2	320.2	6.7	496.5	32.5	22.1	10.5	32.2	1.063	0.659	413.6	
		3	3/23/2010	10:55	12:06	185.3	319.9	6.6	495.5	31.6	20.8	10.8	34.3	1.060	0.624	402.5	
		Avg				184.6	319.9	6.6	494.7	31.7	20.7	11.0	33.2	1.062	0.652	429.4	
M-29/5 Metals PM	2	1	3/24/2010	07:53	10:06	183.9	315.1	6.6	486.9	30.3	21.6	8.7	26.8	1.082	0.858	448.4	All times based on CEMS time
		2	3/24/2010	11:03	13:35	183.7	315.2	6.6	492.0	31.4	22.4	9.0	25.5	1.084	0.880	476.8	
		3	3/24/2010	14:12	16:22	183.3	315.1	6.7	498.9	33.6	24.2	9.5	18.1	1.099	1.044	591.9	
		Avg				183.6	315.1	6.6	492.6	31.8	22.7	9.1	23.5	1.088	0.927	505.7	
M-23 dioxins	2	1	3/22/2010	10:04	14:44	184.2	318.0	6.6	491.0	31.2	19.8	11.3	22.1	1.093	0.978	665.4	All times based on CEMS time
		2	3/23/2010	07:36	12:12	184.2	319.8	6.6	494.7	31.7	20.9	10.8	33.1	1.063	0.655	424.4	
		3	3/23/2010	12:32	17:02	183.9	320.0	6.7	503.2	33.8	23.1	10.7	23.3	1.084	0.881	565.6	
		Avg				184.1	319.3	6.6	496.3	32.2	21.3	10.9	26.1	1.080	0.838	551.8	
M-13B HF	2	1	3/24/2010	07:53	09:11	184.3	315.1	6.6	485.8	29.9	21.9	8.0	26.7	1.083	0.871	418.6	All times based on CEMS time
		2	3/24/2010	09:37	10:54	183.8	315.0	6.5	489.5	31.0	21.3	9.6	27.2	1.080	0.832	480.2	
		3	3/24/2010	11:24	12:46	183.6	315.1	6.6	490.5	30.9	21.9	9.0	29.0	1.076	0.789	425.6	
		Avg				183.9	315.0	6.6	488.6	30.6	21.7	8.9	27.6	1.080	0.831	441.5	

C-5

Stack Test Process Data

PLANT NAME: SOUTH BROWARD 2010						Data From DCS Printouts						Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	3	1	3/24/2010	07:45	08:45	184.1	315.0	6.8	464.8	31.7	22.5	9.2	25.8	1.084	0.879	483.6	All times based on CEMS time
		2	3/24/2010	09:16	10:16	184.2	315.1	6.7	462.8	30.8	19.4	11.4	27.6	1.081	0.840	573.0	
		3	3/24/2010	10:54	11:54	184.1	314.8	6.7	466.9	31.4	21.5	10.0	28.8	1.076	0.792	472.8	
		Avg				184.1	315.0	6.7	464.8	31.3	21.1	10.2	27.4	1.080	0.837	509.8	
M-29/5 Metals PM	3	1	3/22/2010	8:47	11:05	184.1	315.0	6.9	471.8	35.4	25.3	10.1	23.5	1.084	0.874	531.2	All times based on CEMS time
		2	3/22/2010	11:43	13:57	184.0	315.2	6.8	467.5	32.4	19.9	12.5	23.4	1.092	0.967	722.9	
		3	3/22/2010	14:24	16:39	184.2	314.9	6.7	470.4	33.0	21.4	11.5	23.6	1.089	0.927	641.3	
		Avg				184.1	315.0	6.8	469.9	33.6	22.2	11.4	23.5	1.088	0.923	631.8	
M-13B HF	3	1	3/23/2010	12:41	13:54	183.8	315.1	7.0	481.9	38.1	27.3	10.8	22.5	1.082	0.850	551.8	All times based on CEMS time
		2	3/23/2010	14:31	15:39	184.4	314.9	7.0	487.0	39.8	29.8	10.0	20.0	1.087	0.906	541.4	
		3	3/23/2010	15:54	17:02	183.9	315.0	6.9	479.5	36.7	25.6	11.1	21.9	1.086	0.898	598.1	
		Avg				184.0	315.0	7.0	482.8	38.2	27.6	10.6	21.4	1.085	0.885	563.8	

C-6

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 8:31:00
 End Time: 9:31:00
 TEST 26A run 1

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
507.44	314.96	37.14	27.69	9.45	293.15	6.53	-11.00	183.28	418.24

Unit 1

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.20	902.68	825.39	85.21	-0.09	434.77	1081.16	7.26	6.98	9.49

Lime Slurry 3/22/2010
 S.G. 1.071
 Lb/gal 0.738

Specific Gravity	CaO lb/gal	Lime Conc %
1.071	0.738	25.745

C-7

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 9:58:00
 End Time: 10:58:00
 TEST 26A run 2

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
508.27	314.88	36.74	30.24	6.51	294.01	6.53	-10.97	184.79	391.28

Unit 1

FEED H2O FLOW	SH OUT STIM PRESS	FINAL STIM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.54	903.14	826.20	85.72	-0.10	434.69	1094.28	8.10	6.78	9.28

Lime Slurry 3/22/2010
 S.G. 1.096
 Lb/gal 1.002

Specific Gravity	CaO lb/gal	Lime Conc %
1.096	1.002	17.616

C-8

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 11:30:00
 End Time: 12:36:00
 TEST 26A run 3

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	EFF OUT TEMP	EFF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
505.43	316.46	35.79	18.45	17.34	294.57	6.34	-10.66	184.61	1008.47

Unit 1

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.91	902.98	826.43	82.57	-0.11	431.13	1101.43	7.53	6.58	8.96

Lime Slurry 3/22/2010
 S.G. 1.093
 Lb/gal 0.970

Specific Gravity	CaO lb/gal	Lime Conc %
1.093	0.970	20.382

C-9

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 7:43:00
 End Time: 9:58:00
 TEST 5/29 run 1

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
505.46	315.02	35.90	25.16	10.74	295.15	6.49	-10.77	183.54	432.47

Unit 1

FEED H2O FLOW	SH OUT STIM PRESS	FINAL STIM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
185.66	904.87	826.07	85.77	-0.10	431.80	1105.81	7.65	6.49	8.97

Lime Slurry 3/23/2010
 S.G. 1.064
 Lb/gal 0.671

Specific Gravity	CaO lb/gal	Lime Conc %
1.064	0.671	28.676

C - 10

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 10:31:00
 End Time: 12:45:00
 TEST 5/29 run 2

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
512.09	315.08	37.89	28.52	9.36	295.77	6.55	-10.93	183.94	350.67

Unit 1

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
185.48	906.92	824.13	86.96	-0.10	434.58	1100.30	10.34	6.52	9.08

Lime Slurry 3/23/2010
 S.G. 1.060
 Lb/gal 0.624

Specific Gravity	CaO lb/gal	Lime Conc %
1.060	0.624	28.714

C-11

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 13:32:00
 End Time: 15:46:00
 TEST 5/29 run 3

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
514.70	314.98	38.01	30.42	7.59	296.30	6.62	-11.01	183.31	416.61

Unit 1

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SHROL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
185.39	907.78	824.60	86.34	-0.09	434.89	1099.50	9.79	6.71	9.24

Lime Slurry 3/23/2010
 S.G. 1.088
 Lb/gal 0.915

Specific Gravity	CaO lb/gal	Lime Conc %
1.088	0.915	19.626

C - 12

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 13:19:00
 End Time: 14:34:00
 TEST 13B run 1

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
503.21	314.97	34.76	23.21	11.55	293.88	6.50	-10.68	183.85	669.46

Unit 1

FEED H2O FLOW	SH OUT STMPRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.02	903.36	826.21	81.72	-0.10	429.30	1110.32	4.54	6.75	9.08

Lime Slurry 3/22/2010
 S.G. 1.092
 Lb/gal 0.966

Specific Gravity	CaO lb/gal	Lime Conc %
1.092	0.966	19.817

C-13

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 15:07:00
 End Time: 16:21:00
 TEST 13B run 2

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
508.28	314.94	35.92	28.72	7.20	293.36	6.38	-10.65	184.16	407.06

Unit 1

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.55	904.19	825.99	83.01	-0.09	431.26	1121.11	5.67	6.75	9.18

Lime Slurry 3/22/2010
 S.G. 1.090
 Lb/gal 0.942

Specific Gravity	CaO lb/gal	Lime Conc %
1.090	0.942	19.965

C - 14

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 16:30:00
 End Time: 17:41:00
 TEST 13B run 3

Unit 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
505.83	314.89	34.77	24.80	9.97	292.60	6.47	-10.66	184.75	448.06

Unit 1

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.65	905.17	824.72	81.44	-0.10	429.77	1106.66	5.52	6.45	8.95

Lime Slurry 3/22/2010
 S.G. 1.072
 Lb/gal 0.749

Specific Gravity	CaO lb/gal	Lime Conc %
1.072	0.749	27.069

C - 15

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 7:55:00
 End Time: 8:55
 TEST 26A run 1

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	SD INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
492.29	319.78	31.03	19.34	11.6935	301.82	6.48	-10.94	185.24	472.27

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.23	898.05	825.29	85.52	-0.10	413.31	1073.17	2.47	6.41	8.92

Lime Slurry 3/23/2010
 S.G. 1.064
 Lb/gal 0.673

Specific Gravity	Gao lb/gal	Lime Conc %
1.064	0.673	33.238

C - 16

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 9:30:00
 End Time: 10:30
 TEST 26A run 2

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
496.47	320.19	32.51	22.05	10.4573	301.22	6.71	-11.32	183.16	413.46

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
185.85	898.03	822.57	87.68	-0.09	414.69	1083.09	3.77	6.77	9.51

Lime Slurry 3/23/2010
 S.G. 1.063
 Lb/gal 0.659

Specific Gravity	CaO lb/gal	Lime Conc
1.063	0.659	32.184

C-17

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 10:55:00
 End Time: 12:06
 TEST 26A run 3

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIE WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
495.48	319.85	31.56	20.81	10.7450	298.62	6.62	-11.07	185.26	402.44

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.67	899.45	824.05	85.84	-0.09	412.33	1098.27	2.53	6.22	8.93

Lime Slurry 3/23/2010
 S.G. 1.060
 Lb/gal 0.624

Specific Gravity	CaO lb/gal	Lime Conc %
1.060	0.624	34.259

C - 18

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 7:53:00
 End Time: 10:06
 TEST 5/29 run 1

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
486.88	315.06	30.26	21.55	8.7102	294.58	6.55	-11.04	183.87	448.37

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.31	898.34	825.04	81.80	-0.10	411.17	1062.56	2.44	6.11	8.95

Lime Slurry 3/24/2010
 S.G. 1.082
 Lb/gal 0.858

Specific Gravity	CaO lb/gal	Lime Conc lb/gal
1.082	0.858	26.822

C-19

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 11:03:00
 End Time: 13:35
 TEST 5/29 run 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
492.03	315.15	31.39	22.36	9.0368	295.45	6.58	-11.16	183.71	477.25

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.96	899.54	825.04	82.80	-0.10	411.56	1071.47	2.40	6.17	9.00

Unit 2

Lime Slurry 3/24/2010
 S.G. 1.084
 Lb/gal 0.880

Specific Gravity	CaO lb/gal	Lime Conc
1.084	0.880	25.466

C - 20

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 14:12:00
 End Time: 16:22
 TEST 5/29 run 3

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
498.93	315.08	33.64	24.19	9.4444	296.18	6.68	-11.44	183.28	591.54

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	TECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.44	899.61	824.82	85.12	-0.10	413.97	1075.67	2.06	6.55	9.32

Lime Slurry 3/24/2010
 S.G. 1.099
 Lb/gal 1.044

Specific Gravity	Gao lb/gal	Lime Conc %
1.099	1.044	18.096

C-21

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 10:04:00
 End Time: 14:44
 TEST 23 run 1

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIE WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
491.00	318.04	31.17	19.83	11.3333	297.13	6.57	-10.65	184.20	665.02

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SHIROI AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.57	897.43	825.38	83.45	-0.10	411.95	1072.08	2.19	6.26	9.08

Lime Slurry 3/22/2010
 S.G. 1.093
 Lb/gal 0.978

Specific Gravity	S.G. lb/gal	Lime Conc %
1.093	0.978	22.054

C - 22

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 7:36:00
 End Time: 12:12
 TEST 23 run 2

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
494.72	319.79	31.74	20.94	10.7944	300.59	6.61	-11.14	184.19	424.08

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.49	898.33	824.78	86.57	-0.10	413.58	1087.40	2.84	6.57	9.19

Lime Slurry 3/23/2010
 S.G. 1.063
 Lb/gal 0.655

Specific Gravity	CaO lb/gal	Lime Conc
1.063	0.655	33.104

C-23

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 12:32:00
 End Time: 17:02
 TEST 23 run 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
503.15	320.03	33.81	23.11	10.7049	301.91	6.67	-11.34	183.94	565.69

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.78	900.28	823.88	85.99	-0.10	414.96	1094.18	3.86	6.41	9.12

Unit 2

Lime Slurry 3/23/2010
 S.G. 1.084
 Lb/gal . 0.881

Specific Gravity	S.G. lb/gal	Lime Conc %
1.084	0.881	23.272

C - 24

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 7:53:00
 End Time: 9:11
 TEST 13B run 1

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
485.81	315.05	29.87	21.86	8.0074	294.34	6.55	-11.02	184.26	418.27

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.43	898.08	823.57	81.40	-0.10	410.77	1064.59	2.48	6.07	8.90

Lime Slurry 3/24/2010
 S.G. 1.083
 Lb/gal 0.871

Specific Gravity	CaO lb/gal	Lime Conc %
1.083	0.871	26.725

C - 25

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 9:37:00
 End Time: 10:54
 TEST 13B run 2

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
489.47	314.99	30.96	21.34	9.6187	295.88	6.52	-11.03	183.82	479.93

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
187.16	898.98	825.31	82.93	-0.10	411.77	1063.29	2.25	6.19	9.05

Lime Slurry 3/24/2010
 S.G. 1.080
 Lb/gal 0.832

Specific Gravity	CaO lb/gal	Lime Conc %
1.080	0.832	27.225

C - 26

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 11:24:00
 End Time: 12:46
 TEST 13B run 3

Unit 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
490.53	315.08	30.93	21.94	8.9854	294.55	6.59	-11.11	183.55	425.23

Unit 2

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
186.98	899.49	825.49	82.35	-0.11	410.80	1071.68	2.08	6.12	8.97

Lime Slurry 3/24/2010
 S.G. 1.076
 Lb/gal 0.789

Specific Gravity	Gao lb/gal	Lime Conc %
1.076	0.789	28.972

C-27

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 7:45:00
 End Time: 8:45:00
 TEST 26A run 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
464.75	314.96	31.70	22.53	9.17	296.99	6.75	-9.51	184.05	484.09

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SHRO AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.89	891.35	820.01	80.18	-0.11	390.23	1057.32	7.67	6.15	9.26

Unit 3

Lime Slurry 3/24/2010
 S.G. 1.084
 Lb/gal 0.879

Specific Gravity	CaO lb/gal	Lime Conc %
1.084	0.879	25.787

C - 28

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 9:16:00
 End Time: 10:16:00
 TEST 26A run 2

Unit 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
462.78	315.08	30.75	19.38	11.37	298.35	6.68	-9.46	184.18	572.74

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
189.60	891.92	827.04	77.61	-0.11	385.80	1057.86	9.85	5.64	8.88

Lime Slurry 3/24/2010
 S.G. 1.081
 Lb/gal 0.840

Specific Gravity	CaO lb/gal	Lime Conc %
1.081	0.840	27.649

C-29

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/24/2010
 Start Time: 10:54:00
 End Time: 11:54:00
 TEST 26A run 3

Unit 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBs/hr	lb/hr
466.94	314.81	31.40	21.45	9.95	297.21	6.70	-9.69	184.14	472.72

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH RO AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
189.40	892.49	824.18	77.80	-0.11	386.76	1073.00	11.62	5.62	8.90

Lime Slurry 3/24/2010
 S.G. 1.076
 Lb/gal 0.792

Specific Gravity	CaO lb/gal	Lime Conc %
1.076	0.792	28.815

C - 30

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 8:47:00
 End Time: 11:05:00
 TEST 5/29 run 1

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
471.76	314.97	35.38	25.25	10.12	297.81	6.93	-10.00	184.13	531.04

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.78	894.95	824.83	85.00	-0.10	393.82	1031.07	12.17	6.70	9.78

Unit 3

Lime Slurry 3/22/2010
 S.G. 1.084
 Lb/gal 0.874

Specific Gravity	CaO lb/gal	Lime Conc %
1.084	0.874	23.479

C-31

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 11:43:00
 End Time: 13:57:00
 TEST 5/29 run 2

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
467.49	315.15	32.40	19.94	12.46	297.02	6.75	-9.64	184.00	722.81

Unit 3

FEED H2O FLOW	SHI OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.69	894.87	825.65	80.33	-0.11	387.32	1042.54	10.07	6.26	9.39

Unit 3

Lime Slurry 3/22/2010
 S.G. 1.092
 Lb/gal 0.967

Specific Gravity	CaO lb/gal	Lime Conc
1.092	0.967	23.428

C - 32

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/22/2010
 Start Time: 14:24:00
 End Time: 16:39:00
 TEST 5/29 run 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
470.38	314.92	32.95	21.42	11.52	296.46	6.70	-9.64	184.16	640.91

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.52	894.82	822.72	81.01	-0.10	387.01	1059.52	9.28	6.28	9.45

Unit 3

Lime Slurry 3/22/2010
 S.G. 1.089
 Lb/gal 0.927

Specific Gravity	CaO lb/gal	Lime Conc %
1.089	0.927	23.579

C-33

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 12:41:00
 End Time: 13:54:00
 TEST 13B run 1

Unit 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
481.92	315.06	38.14	27.32	10.83	299.74	6.97	-10.33	183.84	552.14

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROIL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.94	891.61	824.07	85.03	-0.11	393.63	1054.76	9.45	6.58	9.60

Lime Slurry 3/23/2010
 S.G. 1.082
 Lb/gal 0.850

Specific Gravity	CaO lb/gal	Lime Conc %
1.082	0.850	22.460

C - 34

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 14:31:00
 End Time: 15:39:00
 TEST 13B run 2

Unit 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLbs/hr	lb/hr
486.97	314.87	39.77	29.81	9.96	299.22	7.02	-10.44	184.35	541.47

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAET	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
KLbs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
189.85	891.81	825.70	86.40	-0.11	396.16	1061.48	11.40	6.68	9.66

Lime Slurry 3/23/2010
 S.G. 1.087
 Lb/gal 0.906

Specific Gravity	CaO lb/gal	Lime Conc %
1.087	0.906	19.978

C - 35

**Wheelabrator
SOUTH BROWARD
Emission Test Log**

Date: 3/23/2010
 Start Time: 15:54:00
 End Time: 17:02:00
 TEST 13B run 3

Unit 3

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME SLURRY	EFF OUT TEMP	EFF DP	ID INLET PRESS	STEAM FLOW	Lime Feed Rate
DEG F	DEG F	GPM	GPM	GPM	DEG F	" H2O	" H2O	KLBS/hr	lb/hr
479.47	314.98	36.68	25.58	11.10	298.34	6.87	-9.99	183.87	598.15

Unit 3

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
188.91	891.17	820.85	81.70	-0.11	391.08	1074.39	9.31	6.37	9.21

Lime Slurry 3/23/2010
 S.G. 1.086
 Lb/gal 0.898

Specific Gravity	CaO lb/gal	Lime Conc %
1.086	0.898	21.866

C - 36

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT1
Data Averaging Type: 6m

Time of Report: 03/24/10 07:22
Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT)
03/23/10	07:48	1
	07:54	1
	08:00	1
	08:06	1
	08:12	1
	08:18	1
	08:24	1
	08:30	1
	08:36	1
	08:42	1
	08:48	1
	08:54	1
	09:00	1
	09:06	1
	09:12	1
	09:18	1
	09:24	1
	09:30	1
	09:36	1
	09:42	1
	09:48	1
	09:54	1

Average = 1
Geometric Avg. = 1
Maximum = 1
Minimum = 1
Possible Values = 22
Included Values = 22
Total = 29

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Plant Name: SBWD
General Average Report
Reporting Period: 03/23/2010 to 03/23/2010

Page: 1

Site Name: UNIT1
Data Averaging Type: 6m

Time of Report: 03/24/10 07:22
Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT)
03/23/10	10:36	1
	10:42	1
	10:48	1
	10:54	1
	11:00	1
	11:06	1
	11:12	1
	11:18	1
	11:24	1
	11:30	1
	11:36	1
	11:42	1
	11:48	1
	11:54	1
	12:00	1
	12:06	1
	12:12	1
	12:18	1
	12:24	1
	12:30	1
	12:36	1
	12:42	1

Average =	1
Geometric Avg. =	1
Maximum =	1
Minimum =	1
Possible Values =	22
Included Values =	22
Total =	31

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT1
Data Averaging Type: 6m

Time of Report: 03/24/10 07:22
Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT)
03/23/10	13:36	1
	13:42	1
	13:48	1
	13:54	1
	14:00	1
	14:06	1
	14:12	1
	14:18	1
	14:24	1
	14:30	1
	14:36	1
	14:42	1
	14:48	1
	14:54	1
	15:00	1
	15:06	1
	15:12	1
	15:18	1
	15:24	1
	15:30	2
	15:36	2
	15:42	1

Average = 1
Geometric Avg. = 1
Maximum = 2
Minimum = 1
Possible Values = 22
Included Values = 22
Total = 31

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/24/2010 to 03/24/2010

Site Name: UNIT2

Time of Report: 03/24/10 16:32

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT)
03/24/10	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0
	08:42	0
	08:48	0
	08:54	0
	09:00	0
	09:06	0
	09:12	0
	09:18	0
	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0

	Average =	0
	Geometric Avg. =	
	Maximum =	0
	Minimum =	0
	Possible Values =	23
	Included Values =	23
	Total =	0

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

Reporting Period: 03/24/2010 to 03/24/2010

Site Name: UNIT2
Data Averaging Type: 6m

Time of Report: 03/24/10 16:32
Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT)
03/24/10	11:06	0
	11:12	0
	11:18	0
	11:24	0
	11:30	0
	11:36	0
	11:42	0
	11:48	0
	11:54	0
	12:00	0
	12:06	0
	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	25
Included Values =	25
Total =	0

* - excluded values (missing, OOC, invalid, suspect)
< - missing
T - out-of-control
I - invalid
S - suspect
H - exceedance
F - stack not operating
B - invalid (PADER)
U - missing data substituted
-999 - missing value
-888 - value could not be calculated

General Average Report

Reporting Period: 03/24/2010 to 03/24/2010

Site Name: UNIT2

Time of Report: 03/24/10 16:32

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT)
03/24/10	14:12	0
	14:18	0
	14:24	0
	14:30	0
	14:36	0
	14:42	0
	14:48	0
	14:54	0
	15:00	0
	15:06	0
	15:12	0
	15:18	0
	15:24	0
	15:30	0
	15:36	0
	15:42	0
	15:48	0
	15:54	0
	16:00	0
	16:06	0
	16:12	0
	16:18	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT3
Data Averaging Type: 6m

Time of Report: 03/23/10 07:06
Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT)
03/22/10	08:48	0
	08:54	0
	09:00	0
	09:06	0
	09:12	0
	09:18	0
	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	23
Included Values =	23
Total =	0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT3

Time of Report: 03/23/10 07:06

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT)
03/22/10	11:48	0
	11:54	0
	12:00	0
	12:06	0
	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0
	13:54	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

General Average Report

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT3

Time of Report: 03/23/10 07:07

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT)
03/22/10	14:24	0
	14:30	0
	14:36	0
	14:42	0
	14:48	0
	14:54	0
	15:00	0
	15:06	0
	15:12	0
	15:18	0
	15:24	0
	15:30	0
	15:36	0
	15:42	0
	15:48	0
	15:54	0
	16:00	0
	16:06	0
	16:12	0
	16:18	0
	16:24	0
	16:30	0
	16:36	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	23
Included Values =	23
Total =	0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT1
Data Averaging Type: 15m

Time of Report: 03/24/10 07:23
Rolling Average Interval: 1

Date	Time	CARFEED1 (LBS/HR)
03/23/10	07:45	6
	08:00	7
	08:15	6
	08:30	6
	08:45	6
	09:00	6
	09:15	6
	09:30	6
	09:45	6

Average = 6
Geometric Avg. = 6
Maximum = 7
Minimum = 6
Possible Values = 9
Included Values = 9
Total = 54

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- i - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Plant Name: SBWD
General Average Report

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT1
Data Averaging Type: 15m

Time of Report: 03/24/10 07:23
Rolling Average Interval: 1

Date	Time	CARFEED1 (LBS/HR)
03/23/10	10:45	6
	11:00	6
	11:15	6
	11:30	6
	11:45	6
	12:00	6
	12:15	6
	12:30	6
	12:45	6

Average = 6
Geometric Avg. = 6
Maximum = 6
Minimum = 6
Possible Values = 9
Included Values = 9
Total = 54

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT1

Time of Report: 03/24/10 07:23

Data Averaging Type: 15m

Rolling Average Interval: 1

CARFED1		
Date	Time	(LBS/HR)
03/23/10	13:45	6
	14:00	6
	14:15	6
	14:30	6
	14:45	6
	15:00	6
	15:15	6
	15:30	6
	15:45	6

Average =	6
Geometric Avg. =	6
Maximum =	6
Minimum =	6
Possible Values =	9
Included Values =	9
Total =	54

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

General Average Report

Reporting Period: 03/24/2010 to 03/24/2010

Site Name: UNIT2

Time of Report: 03/24/10 16:33

Data Averaging Type: 15m

Rolling Average Interval: 1

Date	Time	CARFBED2 (LBS/HR)
03/24/10	08:00	6
	08:15	6
	08:30	7
	08:45	6
	09:00	6
	09:15	7
	09:30	6
	09:45	5
	10:00	7

Average =	6
Geometric Avg. =	6
Maximum =	7
Minimum =	5
Possible Values =	9
Included Values =	9
Total =	56

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

General Average Report

Reporting Period: 03/24/2010 to 03/24/2010

Site Name: UNIT2

Time of Report: 03/24/10 16:33

Data Averaging Type: 15m

Rolling Average Interval: 1

Date	Time	CARFEED2 (LBS/HR)
03/24/10	11:15	6
	11:30	6
	11:45	6
	12:00	6
	12:15	6
	12:30	6
	12:45	6
	13:00	6
	13:15	8
	13:30	6

Average =	6
Geometric Avg. =	6
Maximum =	8
Minimum =	6
Possible Values =	10
Included Values =	10
Total =	62

* - excluded values (missing, OOC, invalid, suspect)
< - missing
T - out-of-control
I - invalid
S - suspect
H - exceedance
F - stack not operating
B - invalid (PADER)
U - missing data substituted
-999 - missing value
-888 - value could not be calculated

Plant Name: SBWD
General Average Report

Reporting Period: 03/24/2010 to 03/24/2010

Site Name: UNIT2
Data Averaging Type: 15m

Time of Report: 03/24/10 16:32
Rolling Average Interval: 1

Date	Time	CARFEED2 (LBS/HR)
03/24/10	14:15	6
	14:30	6
	14:45	6
	15:00	6
	15:15	6
	15:30	6
	15:45	6
	16:00	6
	16:15	6

Average = 6
Geometric Avg. = 6
Maximum = 6
Minimum = 6
Possible Values = 9
Included Values = 9
Total = 52

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT2

Time of Report: 03/23/10 07:04

Data Averaging Type: 15m

Rolling Average Interval: 1

Date	Time	CARFED2 (LBS/HR)
03/22/10	10:15	6
	10:30	7
	10:45	7
	11:00	7
	11:15	7
	11:30	7
	11:45	6
	12:00	6
	12:15	7
	12:30	6
	12:45	6
	13:00	6
	13:15	7
	13:30	6
	13:45	5
	14:00	8
	14:15	7
	14:30	8

Average =	7
Geometric Avg. =	7
Maximum =	8
Minimum =	5
Possible Values =	18
Included Values =	18
Total =	119

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

General Average Report

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT2

Time of Report: 03/24/10 07:24

Data Averaging Type: 15m

Rolling Average Interval: 1

CARFEE2		
Date	Time	(LBS/HR)
03/23/10	07:45	5
	08:00	6
	08:15	6
	08:30	6
	08:45	6
	09:00	6
	09:15	7
	09:30	6
	09:45	7
	10:00	5
	10:15	6
	10:30	6
	10:45	6
	11:00	6
	11:15	6
	11:30	5
	11:45	6
	12:00	6

Average =	6
Geometric Avg. =	6
Maximum =	7
Minimum =	5
Possible Values =	18
Included Values =	18
Total =	105

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/23/2010 to 03/23/2010

Site Name: UNIT2

Time of Report: 03/24/10 07:24

Data Averaging Type: 15m

Rolling Average Interval: 1

Date	Time	CARFED2 (LBS/HR)
03/23/10	12:45	6
	13:00	6
	13:15	6
	13:30	6
	13:45	6
	14:00	6
	14:15	6
	14:30	6
	14:45	6
	15:00	6
	15:15	6
	15:30	6
	15:45	6
	16:00	6
	16:15	5
	16:30	6
	16:45	6
	17:00	7

Average =	6
Geometric Avg. =	6
Maximum =	7
Minimum =	5
Possible Values =	18
Included Values =	18
Total =	104

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

General Average Report

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT3

Time of Report: 03/23/10 07:05

Data Averaging Type: 15m

Rolling Average Interval: 1

CARFEED3		
Date	Time	(LBS/HR)
03/22/10	09:00	6
	09:15	6
	09:30	7
	09:45	6
	10:00	6
	10:15	6
	10:30	6
	10:45	6
	11:00	6

Average =	6
Geometric Avg. =	6
Maximum =	7
Minimum =	6
Possible Values =	9
Included Values =	9
Total =	55

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT3

Time of Report: 03/23/10 07:05

Data Averaging Type: 15m

Rolling Average Interval: 1

CARFRED3		
Date	Time	(LBS/HR)
03/22/10	11:45	6
	12:00	6
	12:15	6
	12:30	6
	12:45	7
	13:00	6
	13:15	6
	13:30	6
	13:45	6

Average =	6
Geometric Avg. =	6
Maximum =	7
Minimum =	6
Possible Values =	9
Included Values =	9
Total =	55

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

Reporting Period: 03/22/2010 to 03/22/2010

Site Name: UNIT3
Data Averaging Type: 15m

Time of Report: 03/23/10 07:05
Rolling Average Interval: 1

CARFEED3		
Date	Time	(LBS/HR)
03/22/10	14:30	6
	14:45	6
	15:00	6
	15:15	7
	15:30	6
	15:45	6
	16:00	6
	16:15	6
	16:30	6

Average =	6
Geometric Avg. =	6
Maximum =	7
Minimum =	6
Possible Values =	9
Included Values =	9
Total =	56

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

WHEELABRATOR SOUTH BROWARD INC.

4400 South State Road 7
 Fort Lauderdale, FL 33314
 Tel: (954) 581-6606 Fax: (954) 581-6705

829438

3/24/2010 IN: 10:13:44 AM OUT: 12:00:45 PM OPERATOR: JWS MAINTENA

ACCOUNT: 623030 CHE001
 CUSTOMER: Chemical Lime
 Chemical Lime
 PO Box 7247-8945
 Philadelphia, PA 19170-8945

DECAL #: LIME1
 VEHICLE#: LIME1
 AUTOID #: 0
 TYPE: Tractor/Trailer

OTHER: 2539721

PRODUCT: 90204 Lime

QTY: 25.63 Ton

ORIGIN: Wheelabrator So

	LB	TON
GROSS	79520	39.76
TARE	28260	14.13
NET	51260	25.63

PRICE/TON:	0.00
FEES:	0.00
OTHER:	0.00
TOTAL: \$	0.00

Wheelabrator South Broward (2010)

Carbon Feeder Calibration				
----------------------------------	--	--	--	--

Feeder	A	B	C	D
---------------	---	---	---	---

Boiler #	n/a	2	n/a	n/a
-----------------	-----	---	-----	-----

Time		05:37		
-------------	--	-------	--	--

Old Zero		201.11		
-----------------	--	--------	--	--

New Zero		201.70		
-----------------	--	--------	--	--

Difference %		0.3		
---------------------	--	-----	--	--

Calibration Weight		49.26		
---------------------------	--	-------	--	--

Scale Factor Old		4056.8777		
-------------------------	--	-----------	--	--

Scale Factor New		4070.2871		
-------------------------	--	-----------	--	--

Difference %		0.3		
---------------------	--	-----	--	--

Calibrated by:	Steve Voigt			
-----------------------	-------------	--	--	--

Date	3/24/2010			
-------------	-----------	--	--	--

Wheelabrator South Broward

Carbon Feeder Calibration				
----------------------------------	--	--	--	--

Feeder	A	B	C	D
---------------	---	---	---	---

Boiler #	3	2	n/a	1
-----------------	---	---	-----	---

Time	07:39	07:32		07:48
-------------	-------	-------	--	-------

Old Zero	196.42	195.29		131.05
-----------------	--------	--------	--	--------

New Zero	196.68	195.56		134.71
-----------------	--------	--------	--	--------

Difference %	0.1	0.1		2.8
---------------------	-----	-----	--	-----

Calibration Weight	49.26	49.26		49.26
---------------------------	-------	-------	--	-------

Scale Factor Old	4196.6802	4172.0815		4159.2573
-------------------------	-----------	-----------	--	-----------

Scale Factor New	4196.0298	4056.8777		4175.7764
-------------------------	-----------	-----------	--	-----------

Difference %	0.0	-2.8		0.4
---------------------	-----	------	--	-----

Calibrated by:	Luis Romero & Steve Voigt
-----------------------	---------------------------

Date	3/23/2010
-------------	-----------

Wheelabrator South Broward (2010)

Carbon Feeder Calibration				
----------------------------------	--	--	--	--

Feeder	A	B	C	D
---------------	---	---	---	---

Boiler #	3	2	n/a	1
-----------------	---	---	-----	---

Time	21:35	20:40		20:30
-------------	-------	-------	--	-------

Old Zero	191.67	193.88		118.75
-----------------	--------	--------	--	--------

New Zero	197.57	199.51		131.57
-----------------	--------	--------	--	--------

Difference %	3.1	2.9		10.8
---------------------	-----	-----	--	------

Calibration Weight	49.26	49.26		49.26
---------------------------	-------	-------	--	-------

Scale Factor Old	4172.2002	4083.9648		4142.8062
-------------------------	-----------	-----------	--	-----------

Scale Factor New	4196.6802	4172.0815		4159.2573
-------------------------	-----------	-----------	--	-----------

Difference %	0.6	2.2		0.4
---------------------	-----	-----	--	-----

Calibrated by:	Luis Romero
-----------------------	-------------

Date	3/22/2010
-------------	-----------

This Page Intentionally Left Blank

WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

PARAMETERS

D

This Page Intentionally Left Blank

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average	
Date (2010)	Mar 23	Mar 23	Mar 23		
Start Time (approx.)	07:43	10:31	13:32		
Stop Time (approx.)	09:58	12:45	15:46		
Sampling Conditions					
Y _d	Dry gas meter correction factor	1.0005	1.0005	1.0005	
C _p	Pitot tube coefficient	0.8050	0.8050	0.8050	
P _g	Static pressure (in. H ₂ O)	-11.0000	-10.8000	-10.9000	
A _s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar}	Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n	Nozzle diameter (in.)	0.2700	0.2700	0.2700	
O ₂	Oxygen (dry volume %)	9.5700	9.3800	9.7300	9.5600
CO ₂	Carbon dioxide (dry volume %)	9.6900	9.9400	9.8400	9.8233
N ₂ +CO	Nitrogen plus carbon monoxide (dry volume %)	80.7400	80.6800	80.4300	80.6167
V _{lc}	Total Liquid collected (ml)	463.20	472.70	458.70	
V _m	Volume metered, meter conditions (ft ³)	76.5450	77.7000	78.1800	
T _m	Dry gas meter temperature (°F)	68.4600	74.9400	76.7200	
T _s	Sample temperature (°F)	295.2000	295.1200	296.2400	295.5200
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.1852	1.2108	1.2280	
θ	Total sampling time (min)	125.0	125.0	125.0	
Flow Results					
V _{wetd}	Volume of water collected (ft ³)	21.7982	22.2453	21.5864	21.8766
V _{mstd}	Volume metered, standard (dscf)	77.1689	77.3893	77.6124	77.3902
P _g	Sample gas pressure, absolute (in. Hg)	29.2912	29.3059	29.2985	29.2985
P _v	Vapor pressure, actual (in. Hg)	29.2912	29.3059	29.2985	29.2985
B _{wo}	Moisture measured in sample (% by volume)	22.0257	22.3269	21.7608	22.0378
B _{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w	Actual water vapor in gas (% by volume)	22.0257	22.3269	21.7608	22.0378
√ΔP	Velocity head (√in. H ₂ O)	0.6893	0.7003	0.7076	0.6991
M _d	MW of sample gas, dry (lb/lb-mole)	29.9332	29.9656	29.9636	29.9541
M _w	MW of sample gas, wet (lb/lb-mole)	27.3048	27.2941	27.3602	27.3197
V _s	Velocity of sample (ft/sec)	46.0974	46.8282	47.2988	46.7415
%I	Isokinetic sampling (%)	105.2463	104.2391	102.9288	104.1381
Q _a	Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _s	Volumetric flow rate, standard (scfm)	121,159	123,154	124,177	122,830
Q _{std}	Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,005	79,279	78,073	78,119
Q _a	Volumetric flow rate, actual (acf/hr)	10,620,832	10,789,216	10,897,644	10,769,231
Q _s	Volumetric flow rate, standard (scf/hr)	7,269,519	7,389,262	7,450,598	7,369,793
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,668,358	5,739,472	5,829,290	5,745,707
Q _a	Volumetric flow rate, actual (m ³ /hr)	300,788	305,557	308,628	304,991
Q _s	Volumetric flow rate, standard (m ³ /hr)	205,877	209,268	211,005	208,717
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	160,531	162,545	165,089	162,722
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,850	134,714	132,665	132,743
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	191,840	195,000	196,619	194,486
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	149,586	151,463	153,833	151,627
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,929	125,529	123,620	123,692

Comments:

Average includes 3 runs.

042010 111410
 J.L.L.®

**USEPA Method 5/29
 Filterable Particulate Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:43	10:31	13:32	
Stop Time (approx.)	09:58	12:45	15:46	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	183.5	183.9	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.5700	9.3800	9.7300	9.5600
CO ₂ Carbon dioxide (dry volume %)	9.6900	9.9400	9.8400	9.8233
T _a Sample temperature (°F)	295.2000	295.1200	296.2400	295.5200
B _w Actual water vapor in gas (% by volume)	22.0257	22.3269	21.7608	22.0378
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _s Volumetric flow rate, standard (scfm)	121,159	123,154	124,177	122,830
Q _{std} Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,005	79,279	78,073	78,119
Q _a Volumetric flow rate, actual (act/hr)	10,620,832	10,789,216	10,897,644	10,769,231
Q _s Volumetric flow rate, standard (scf/hr)	7,269,519	7,389,262	7,450,598	7,369,793
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,668,358	5,739,472	5,829,290	5,745,707
Q _a Volumetric flow rate, actual (m ³ /hr)	300,788	305,557	308,628	304,991
Q _s Volumetric flow rate, standard (m ³ /hr)	205,877	209,268	211,005	208,717
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	160,531	162,545	165,089	162,722
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,850	134,714	132,665	132,743
Q _s Volumetric flow rate, normal (Nm ³ /hr)	191,840	195,000	196,619	194,486
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	149,586	151,463	153,833	151,627
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,929	125,529	123,620	123,692
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	77.1689	77.3893	77.6124	77.3902
%I Isokinetic sampling (%)	105.2463	104.2391	102.9288	104.1381
Laboratory Data				
m _{finer} Matter collected on filter(s) (g)	0.00050	0.00010	0.00070	
m _s Matter collected in solvent rinse(s) (g)	0.00060	0.00210	0.00150	
m _n Total particulate matter collected (g)	0.00110	0.00220	0.00220	
Filterable Particulate Results				
C _{sd} Particulate Concentration (lb/dscf)	3.1431E-08	6.2683E-08	6.2503E-08	5.2206E-08
C _{sd7} Particulate Concentration @7% O ₂ (lb/dscf)	3.8561E-08	7.5633E-08	7.7779E-08	6.3991E-08
C _{sd12} Particulate Concentration @12% CO ₂ (lb/dscf)	3.8924E-08	7.5674E-08	7.6223E-08	6.3607E-08
C _a Particulate Concentration (lb/acf)	1.6775E-08	3.3345E-08	3.3434E-08	2.7851E-08
C _{sd} Particulate Concentration (gr/dscf)	0.0002	0.0004	0.0004	0.0004
C _{sd7} Particulate Concentration @7% O ₂ (gr/dscf)	0.0003	0.0005	0.0005	0.0004
C _{sd12} Particulate Concentration @12% CO ₂ (gr/dscf)	0.0003	0.0005	0.0005	0.0004
C _a Particulate Concentration (gr/acf)	0.0001	0.0002	0.0002	0.0002
C _{sd} Particulate Concentration (mg/dscm)	0.5033	1.0038	1.0009	0.8360
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	0.6175	1.2112	1.2455	1.0247
C _{sd12} Particulate Concentration @12% CO ₂ (mg/dscm)	0.6233	1.2118	1.2206	1.0186
C _a Particulate Concentration (mg/m ³ (actual,wet))	0.2686	0.5340	0.5354	0.4460
C _{sd} Particulate Concentration (mg/Nm ³ dry)	0.5402	1.0772	1.0741	0.8972
C _{sd7} Particulate Concentration @7% O ₂ (mg/Nm ³ dry)	0.6627	1.2998	1.3367	1.0997
C _{sd12} Particulate Concentration @12% CO ₂ (mg/Nm ³ dry)	0.6689	1.3005	1.3099	1.0931
E _{lb/hr} Particulate Rate (lb/hr)	0.1782	0.3598	0.3643	0.3008
E _{kg/hr} Particulate Rate (kg/hr)	0.0808	0.1632	0.1652	0.1364
E _{T/yr} Particulate Rate (Ton/yr)	0.7804	1.5758	1.5958	1.3173
E _{Fd} Particulate Rate - F _d -based (lb/MMBtu)	0.0006	0.0011	0.0011	0.0009
E _{Fc} Particulate Rate - F _c -based (lb/MMBtu)	0.0006	0.0011	0.0012	0.0010

Comments:
 Average includes 3 runs.

042010 111410
 JLL@_N

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		07:43	10:31	13:32	
Stop Time (approx.)		09:58	12:45	15:46	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.5	183.9	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.5700	9.3800	9.7300	9.5600
CO ₂	Carbon dioxide (dry volume %)	9.6900	9.9400	9.8400	9.8233
T _s	Sample temperature (°F)	295.2000	295.1200	296.2400	295.5200
B _w	Actual water vapor in gas (% by volume)	22.0257	22.3269	21.7608	22.0378
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _s	Volumetric flow rate, standard (scfm)	121,159	123,154	124,177	122,830
Q _{std}	Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,005	79,279	78,073	78,119
Q _a	Volumetric flow rate, actual (acf/hr)	10,620,832	10,789,216	10,897,644	10,769,231
Q _s	Volumetric flow rate, standard (scf/hr)	7,269,519	7,389,262	7,450,598	7,369,793
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,668,358	5,739,472	5,829,290	5,745,707
Q _a	Volumetric flow rate, actual (m ³ /hr)	300,788	305,557	308,628	304,991
Q _s	Volumetric flow rate, standard (m ³ /hr)	205,877	209,268	211,005	208,717
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	160,531	162,545	165,089	162,722
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,850	134,714	132,665	132,743
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	191,840	195,000	196,619	194,486
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	149,586	151,463	153,833	151,627
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,929	125,529	123,620	123,692
Sampling Data					
V _{std}	Volume metered, standard (dscf)	77.1689	77.3893	77.6124	77.3902
%I	Isokinetic sampling (%)	105.2463	104.2391	102.9288	104.1381
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m _{n-2b}	Fraction 2B (µg)	4.8386	4.5386	5.0072	
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m _n	Total matter corrected for allowable blanks (µg)	4.8386	4.5386	5.0072	
Mercury Results - Total					
C _{sd}	Concentration (lb/dscf)	1.3826E-10	1.2932E-10	1.4226E-10	1.3661E-10
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	1.6962E-10	1.5603E-10	1.7703E-10	1.6756E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	1.7122E-10	1.5612E-10	1.7348E-10	1.6694E-10
C _a	Concentration (lb/acf)	7.3788E-11	6.8792E-11	7.6095E-11	7.2692E-11
C _{sd}	Concentration (µg/dscm)	2.2140E+00	2.0708E+00	2.2780E+00	2.1876E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	2.7162E+00	2.4987E+00	2.8348E+00	2.6832E+00
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	2.7418E+00	2.5000E+00	2.7781E+00	2.6733E+00
C _{sd}	Concentration (mg/dscm)	2.2140E-03	2.0708E-03	2.2780E-03	2.1876E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	2.7162E-03	2.4987E-03	2.8348E-03	2.6832E-03
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	2.7418E-03	2.5000E-03	2.7781E-03	2.6733E-03
C _a	Concentration (µg/m ³ actual,wet)	1.1816E+00	1.1016E+00	1.2186E+00	1.1673E+00
C _{sd}	Concentration (µg/Nm ³ dry)	2.3760E+00	2.2223E+00	2.4447E+00	2.3477E+00
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	2.9150E+00	2.6815E+00	3.0422E+00	2.8796E+00
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	2.9424E+00	2.6829E+00	2.9814E+00	2.8689E+00
E _{lb/hr}	Rate (lb/hr)	7.8369E-04	7.4221E-04	8.2926E-04	7.8505E-04
E _{g/s}	Rate (g/s)	9.8727E-05	9.3501E-05	1.0447E-04	9.8898E-05
E _{T/yr}	Rate (Ton/yr)	3.4326E-03	3.2509E-03	3.6321E-03	3.4385E-03
E _{Fd}	Rate - Fd-based (lb/MMBtu)	2.4407E-06	2.2452E-06	2.5473E-06	2.4111E-06
E _{Fc}	Rate - Fc-based (lb/MMBtu)	2.5968E-06	2.3678E-06	2.6312E-06	2.5319E-06

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		07:43	10:31	13:32	
Stop Time (approx.)		09:58	12:45	15:46	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.5	183.9	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.5700	9.3800	9.7300	9.5600
CO ₂	Carbon dioxide (dry volume %)	9.6900	9.9400	9.8400	9.8233
T _s	Sample temperature (°F)	295.2000	295.1200	296.2400	295.5200
B _w	Actual water vapor in gas (% by volume)	22.0257	22.3269	21.7608	22.0378
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _s	Volumetric flow rate, standard (scfm)	121,159	123,154	124,177	122,830
Q _{std}	Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,005	79,279	78,073	78,119
Q _a	Volumetric flow rate, actual (acf/hr)	10,620,832	10,789,216	10,897,644	10,769,231
Q _s	Volumetric flow rate, standard (scf/hr)	7,269,519	7,389,262	7,450,598	7,369,793
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,668,358	5,739,472	5,829,290	5,745,707
Q _a	Volumetric flow rate, actual (m ³ /hr)	300,788	305,557	308,628	304,991
Q _s	Volumetric flow rate, standard (m ³ /hr)	205,877	209,268	211,005	208,717
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	160,531	162,545	165,089	162,722
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,850	134,714	132,665	132,743
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	191,840	195,000	196,619	194,486
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	149,586	151,463	153,833	151,627
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,929	125,529	123,620	123,692
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	77.1689	77.3893	77.6124	77.3902
%I	Isokinetic sampling (%)	105.2463	104.2391	102.9288	104.1381
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total					
C _{sd}	Concentration (lb/dscf)	<1.4287E-12	<1.4246E-12	<1.4205E-12	<1.4246E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.7528E-12	<1.7189E-12	<1.7677E-12	<1.7465E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.7693E-12	<1.7199E-12	<1.7323E-12	<1.7405E-12
C _a	Concentration (lb/acf)	<7.6249E-13	<7.5784E-13	<7.5986E-13	<7.6006E-13
C _{sd}	Concentration (µg/dscm)	<2.2878E-02	<2.2813E-02	<2.2748E-02	<2.2813E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.8068E-02	<2.7526E-02	<2.8307E-02	<2.7967E-02
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.8332E-02	<2.7541E-02	<2.7741E-02	<2.7872E-02
C _{sd}	Concentration (mg/dscm)	<2.2878E-05	<2.2813E-05	<2.2748E-05	<2.2813E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.8068E-05	<2.7526E-05	<2.8307E-05	<2.7967E-05
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.8332E-05	<2.7541E-05	<2.7741E-05	<2.7872E-05
C _a	Concentration (µg/m ³ (actual,wet))	<1.2210E-02	<1.2136E-02	<1.2168E-02	<1.2171E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<2.4552E-02	<2.4483E-02	<2.4412E-02	<2.4482E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0122E-02	<2.9541E-02	<3.0379E-02	<3.0014E-02
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<3.0405E-02	<2.9556E-02	<2.9771E-02	<2.9911E-02
E _{lb/hr}	Rate (lb/hr)	<8.0983E-06	<8.1765E-06	<8.2806E-06	<8.1852E-06
E _{g/s}	Rate (g/s)	<1.0202E-06	<1.0301E-06	<1.0432E-06	<1.0311E-06
E _{T/yr}	Rate (Ton/yr)	<3.5471E-05	<3.5813E-05	<3.6269E-05	<3.5851E-05
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.5221E-08	<2.4735E-08	<2.5436E-08	<2.5131E-08
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.6834E-08	<2.6085E-08	<2.6274E-08	<2.6397E-08

042010 111503
 JLL@P

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		07:43	10:31	13:32	
Stop Time (approx.)		09:58	12:45	15:46	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.5	183.9	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.5700	9.3800	9.7300	9.5600
CO ₂	Carbon dioxide (dry volume %)	9.6900	9.9400	9.8400	9.8233
T _s	Sample temperature (°F)	295.2000	295.1200	296.2400	295.5200
B _w	Actual water vapor in gas (% by volume)	22.0257	22.3269	21.7608	22.0378
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _s	Volumetric flow rate, standard (scfm)	121,159	123,154	124,177	122,830
Q _{std}	Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,005	79,279	78,073	78,119
Q _a	Volumetric flow rate, actual (acf/hr)	10,620,832	10,789,216	10,897,644	10,769,231
Q _s	Volumetric flow rate, standard (scf/hr)	7,269,519	7,389,262	7,450,598	7,369,793
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,668,358	5,739,472	5,829,290	5,745,707
Q _a	Volumetric flow rate, actual (m ³ /hr)	300,788	305,557	308,628	304,991
Q _s	Volumetric flow rate, standard (m ³ /hr)	205,877	209,268	211,005	208,717
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	160,531	162,545	165,089	162,722
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,850	134,714	132,665	132,743
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	191,840	195,000	196,619	194,486
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	149,586	151,463	153,833	151,627
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,929	125,529	123,620	123,692
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	77.1689	77.3893	77.6124	77.3902
%I	Isokinetic sampling (%)	105.2463	104.2391	102.9288	104.1381
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.2000	<0.2000	<0.2000	
Cadmium Results - Total					
C _{sd}	Concentration (lb/dscf)	<5.7147E-12	<5.6985E-12	<5.6821E-12	<5.6984E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<7.0110E-12	<6.8758E-12	<7.0708E-12	<6.9859E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<7.0771E-12	<6.8794E-12	<6.9294E-12	<6.9620E-12
C _a	Concentration (lb/acf)	<3.0500E-12	<3.0314E-12	<3.0394E-12	<3.0403E-12
C _{sd}	Concentration (µg/dscm)	<9.1514E-02	<9.1253E-02	<9.0991E-02	<9.1252E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<1.1227E-01	<1.1011E-01	<1.1323E-01	<1.1187E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<1.1333E-01	<1.1016E-01	<1.1096E-01	<1.1149E-01
C _{sd}	Concentration (mg/dscm)	<9.1514E-05	<9.1253E-05	<9.0991E-05	<9.1252E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<1.1227E-04	<1.1011E-04	<1.1323E-04	<1.1187E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<1.1333E-04	<1.1016E-04	<1.1096E-04	<1.1149E-04
C _a	Concentration (µg/m ³ (actual,wet))	<4.8841E-02	<4.8543E-02	<4.8672E-02	<4.8685E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<9.8210E-02	<9.7930E-02	<9.7649E-02	<9.7929E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<1.2049E-01	<1.1816E-01	<1.2151E-01	<1.2005E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<1.2162E-01	<1.1823E-01	<1.1908E-01	<1.1964E-01
E _{lb/hr}	Rate (lb/hr)	<3.2393E-05	<3.2706E-05	<3.3123E-05	<3.2741E-05
E _{g/s}	Rate (g/s)	<4.0808E-06	<4.1202E-06	<4.1727E-06	<4.1245E-06
E _{T/yr}	Rate (Ton/yr)	<1.4188E-04	<1.4325E-04	<1.4508E-04	<1.4340E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<1.0088E-07	<9.8938E-08	<1.0174E-07	<1.0052E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<1.0734E-07	<1.0434E-07	<1.0510E-07	<1.0559E-07

042010 111503
 J.L.L._P

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

USEPA Method 5/29 Lead (Pb) Emission Parameters

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:43	10:31	13:32	
Stop Time (approx.)	09:58	12:45	15:46	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	183.5	183.9	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	6	6	6	6
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.5700	9.3800	9.7300	9.5600
CO ₂ Carbon dioxide (dry volume %)	9.6900	9.9400	9.8400	9.8233
T _s Sample temperature (°F)	295.2000	295.1200	296.2400	295.5200
B _w Actual water vapor in gas (% by volume)	22.0257	22.3269	21.7608	22.0378
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	177,014	179,820	181,627	179,487
Q _s Volumetric flow rate, standard (scfm)	121,159	123,154	124,177	122,830
Q _{std} Volumetric flow rate, dry standard (dscfm)	94,473	95,658	97,155	95,762
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,005	79,279	78,073	78,119
Q _a Volumetric flow rate, actual (acf/hr)	10,620,832	10,789,216	10,897,644	10,769,231
Q _s Volumetric flow rate, standard (scf/hr)	7,269,519	7,389,262	7,450,598	7,369,793
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,668,358	5,739,472	5,829,290	5,745,707
Q _a Volumetric flow rate, actual (m ³ /hr)	300,788	305,557	308,628	304,991
Q _s Volumetric flow rate, standard (m ³ /hr)	205,877	209,268	211,005	208,717
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	160,531	162,545	165,089	162,722
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,850	134,714	132,665	132,743
Q _s Volumetric flow rate, normal (Nm ³ /hr)	191,840	195,000	196,619	194,486
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	149,586	151,463	153,833	151,627
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,929	125,529	123,620	123,692
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	77.1689	77.3893	77.6124	77.3902
%I Isokinetic sampling (%)	105.2463	104.2391	102.9288	104.1381
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.3815	0.7111	0.5419	
Lead Results - Total				
C _{sd} Concentration (lb/dscf)	1.0901E-11	2.0261E-11	1.5395E-11	1.5519E-11
C _{sd7} Concentration @7% O ₂ (lb/dscf)	1.3374E-11	2.4447E-11	1.9157E-11	1.8993E-11
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	1.3500E-11	2.4460E-11	1.8774E-11	1.8911E-11
C _a Concentration (lb/acf)	5.8181E-12	1.0778E-11	8.2348E-12	8.2770E-12
C _{sd} Concentration (µg/dscm)	1.7457E-01	3.2445E-01	2.4652E-01	2.4852E-01
C _{sd7} Concentration @7% O ₂ (µg/dscm)	2.1417E-01	3.9148E-01	3.0678E-01	3.0414E-01
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	2.1619E-01	3.9169E-01	3.0064E-01	3.0284E-01
C _{sd} Concentration (mg/dscm)	1.7457E-04	3.2445E-04	2.4652E-04	2.4852E-04
C _{sd7} Concentration @7% O ₂ (mg/dscm)	2.1417E-04	3.9148E-04	3.0678E-04	3.0414E-04
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	2.1619E-04	3.9169E-04	3.0064E-04	3.0284E-04
C _a Concentration (µg/m ³ (actual,wet))	9.3169E-02	1.7260E-01	1.3187E-01	1.3254E-01
C _{sd} Concentration (µg/Nm ³ dry)	1.8734E-01	3.4819E-01	2.6456E-01	2.6670E-01
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	2.2984E-01	4.2013E-01	3.2922E-01	3.2640E-01
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	2.3201E-01	4.2035E-01	3.2264E-01	3.2500E-01
E _{lb/hr} Rate (lb/hr)	6.1793E-05	1.1629E-04	8.9740E-05	8.9274E-05
E _{g/s} Rate (g/s)	7.7845E-06	1.4649E-05	1.1305E-05	1.1246E-05
E _{T/yr} Rate (Ton/yr)	2.7065E-04	5.0934E-04	3.9306E-04	3.9102E-04
E _{Fd} Rate - Fd-based (lb/MMBtu)	1.9245E-07	3.5178E-07	2.7566E-07	2.7329E-07
E _{Fc} Rate - Fc-based (lb/MMBtu)	2.0475E-07	3.7098E-07	2.8474E-07	2.8682E-07

042010 11:503
 JLL@_P

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 SDA Inlet

**USEPA Method 29 (Trace Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:43	10:31	13:32	
Stop Time (approx.)	09:58	12:45	15:46	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9916	0.9916	0.9916	
C _p Pitot tube coefficient	0.8250	0.8250	0.8250	
P _g Static pressure (in. H ₂ O)	-1.4000	-1.4000	-1.5000	
A _s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n Nozzle diameter (in.)	0.2700	0.2700	0.2700	
O ₂ Oxygen (dry volume %)	8.0900	8.3300	8.4900	8.3033
CO ₂ Carbon dioxide (dry volume %)	10.9500	10.9400	10.9500	10.9467
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.9600	80.7300	80.5600	80.7500
V _{lc} Total Liquid collected (ml)	324.10	318.30	308.90	
V _m Volume metered, meter conditions (ft ³)	70.1450	68.2850	68.8600	
T _m Dry gas meter temperature (°F)	80.2708	89.0208	92.4375	
T _s Sample temperature (°F)	499.3333	505.0833	507.0833	503.8333
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.0925	1.0479	1.0542	
θ Total sampling time (min)	120.0	120.0	120.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	15.2521	14.9792	14.5368	14.9227
V _{mstd} Volume metered, standard (dscf)	68.5400	65.6521	65.7964	66.6628
P _s Sample gas pressure, absolute (in. Hg)	29.9971	29.9971	29.9897	29.9946
P _v Vapor pressure, actual (in. Hg)	29.9971	29.9971	29.9897	29.9946
B _{wo} Moisture measured in sample (% by volume)	18.2024	18.5774	18.0957	18.2918
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	18.2024	18.5774	18.0957	18.2918
√ΔP Velocity head (√in. H ₂ O)	0.7057	0.6876	0.6894	0.6942
M _d MW of sample gas, dry (lb/lb-mole)	30.0756	30.0836	30.0916	30.0836
M _w MW of sample gas, wet (lb/lb-mole)	27.8776	27.8388	27.9035	27.8733
V _s Velocity of sample (ft/sec)	53.3078	52.1341	52.2685	52.5702
%i Isokinetic sampling (%)	99.5632	98.5515	98.1618	98.7588
Q _a Volumetric flow rate, actual (acfm)	192,331	188,096	188,581	189,669
Q _s Volumetric flow rate, standard (scfm)	106,128	103,173	103,200	104,167
Q _{std} Volumetric flow rate, dry standard (dscfm)	86,810	84,006	84,525	85,114
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,003	75,968	75,464	77,145
Q _a Volumetric flow rate, actual (acf/hr)	11,539,835	11,285,753	11,314,844	11,380,144
Q _s Volumetric flow rate, standard (scf/hr)	6,367,678	6,190,372	6,191,975	6,250,008
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,208,611	5,040,361	5,071,497	5,106,823
Q _a Volumetric flow rate, actual (m ³ /hr)	326,815	319,619	320,443	322,292
Q _s Volumetric flow rate, standard (m ³ /hr)	180,336	175,315	175,360	177,004
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	147,511	142,746	143,628	144,628
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,944	129,088	128,232	131,088
Q _a Volumetric flow rate, normal (Nm ³ /hr)	168,041	163,362	163,404	164,935
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	137,453	133,013	133,835	134,767
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	126,675	120,286	119,489	122,150

Comments:

Average includes 3 runs.

042010 111626
 JNK@

**USEPA Method 29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		07:43	10:31	13:32	
Stop Time (approx.)		09:58	12:45	15:46	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.5	183.9	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.0900	8.3300	8.4900	8.3033
CO ₂	Carbon dioxide (dry volume %)	10.9500	10.9400	10.9500	10.9467
T _s	Sample temperature (°F)	499.3333	505.0833	507.0833	503.8333
B _w	Actual water vapor in gas (% by volume)	18.2024	18.5774	18.0957	18.2918
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	192,331	188,096	188,581	189,669
Q _s	Volumetric flow rate, standard (scfm)	106,128	103,173	103,200	104,167
Q _{std}	Volumetric flow rate, dry standard (dscfm)	86,810	84,006	84,525	85,114
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,003	75,968	75,464	77,145
Q _a	Volumetric flow rate, actual (acf/hr)	11,539,835	11,285,753	11,314,844	11,380,144
Q _s	Volumetric flow rate, standard (scf/hr)	6,367,678	6,190,372	6,191,975	6,250,008
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,208,611	5,040,361	5,071,497	5,106,823
Q _a	Volumetric flow rate, actual (m ³ /hr)	326,815	319,619	320,443	322,292
Q _s	Volumetric flow rate, standard (m ³ /hr)	180,336	175,315	175,360	177,004
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	147,511	142,746	143,628	144,628
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,944	129,088	128,232	131,088
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	168,041	163,362	163,404	164,935
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	137,453	133,013	133,835	134,767
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	126,675	120,286	119,489	122,150
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	68.5400	65.6521	65.7964	66.6628
%I	Isokinetic sampling (%)	99.5632	98.5515	98.1618	98.7588
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	22.5792	69.6536	55.4324	
m _{n-2b}	Fraction 2B (µg)	50.8761	24.7029	27.0182	
m _{n-3a}	Fraction 3A (µg)	0.0000	0.0000	0.0000	
m _{n-3b}	Fraction 3B (µg)	0.0000	0.0000	0.7870	
m _{n-3c}	Fraction 3C (µg)	4.6198	1.0851	2.9106	
m _n	Total matter corrected for allowable blanks (µg)	78.0752	95.4417	86.1483	
Mercury Results - Total					
C _{std}	Concentration (lb/dscf)	2.5118E-09	3.2055E-09	2.8870E-09	2.8681E-09
C _{std7}	Concentration @7% O ₂ (lb/dscf)	2.7255E-09	3.5447E-09	3.2337E-09	3.1679E-09
C _{std12}	Concentration @12% CO ₂ (lb/dscf)	2.7526E-09	3.5161E-09	3.1639E-09	3.1442E-09
C _a	Concentration (lb/acf)	1.1337E-09	1.4316E-09	1.2940E-09	1.2864E-09
C _{std}	Concentration (µg/dscm)	4.0222E+01	5.1332E+01	4.6232E+01	4.5929E+01
C _{std7}	Concentration @7% O ₂ (µg/dscm)	4.3645E+01	5.6763E+01	5.1783E+01	5.0730E+01
C _{std12}	Concentration @12% CO ₂ (µg/dscm)	4.4079E+01	5.6306E+01	5.0665E+01	5.0350E+01
C _{sd}	Concentration (mg/dscm)	4.0222E-02	5.1332E-02	4.6232E-02	4.5929E-02
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	4.3645E-02	5.6763E-02	5.1783E-02	5.0730E-02
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	4.4079E-02	5.6306E-02	5.0665E-02	5.0350E-02
C _a	Concentration (µg/m ³ (actual,wet))	1.8155E+01	2.2925E+01	2.0722E+01	2.0801E+01
C _{sd}	Concentration (µg/Nm ³ dry)	4.3165E+01	5.5088E+01	4.9615E+01	4.9289E+01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	4.6838E+01	6.0917E+01	5.5572E+01	5.4442E+01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	4.7304E+01	6.0425E+01	5.4372E+01	5.4034E+01
E _{lb/hr}	Rate (lb/hr)	1.3083E-02	1.6157E-02	1.4642E-02	1.4627E-02
E _{g/s}	Rate (g/s)	1.6481E-03	2.0354E-03	1.8445E-03	1.8427E-03
E _{T/yr}	Rate (Ton/yr)	5.7302E-02	7.0768E-02	6.4130E-02	6.4067E-02
E _{Fd}	Rate - Fd-based (lb/MMBtu)	3.9218E-05	5.1006E-05	4.6531E-05	4.5585E-05
E _{Fc}	Rate - Fc-based (lb/MMBtu)	4.1748E-05	5.3328E-05	4.7986E-05	4.7687E-05

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		13:19	15:07	16:30	
Stop Time (approx.)		14:34	16:21	17:41	
Sampling Conditions					
Y_d	Dry gas meter correction factor	1.0005	1.0005	1.0005	
C_p	Pilot tube coefficient	0.8120	0.8120	0.8120	
P_g	Static pressure (in. H ₂ O)	-10.2000	-10.2000	-10.2000	
A_s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P_{bar}	Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D_n	Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O_2	Oxygen (dry volume %)	9.1700	9.3100	9.1500	9.2100
CO_2	Carbon dioxide (dry volume %)	10.3200	10.0400	10.3100	10.2233
N_2+CO	Nitrogen plus carbon monoxide (dry volume %)	80.5100	80.6500	80.5400	80.5667
V_{lc}	Total Liquid collected (ml)	218.90	224.00	218.30	
V_m	Volume metered, meter conditions (ft ³)	36.7200	38.0000	36.4950	
T_m	Dry gas meter temperature (°F)	69.6000	73.3800	75.5600	
T_s	Sample temperature (°F)	293.1200	293.4800	292.9600	293.1867
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.1440	1.1544	1.0652	
θ	Total sampling time (min)	62.5	62.5	62.5	
Flow Results					
V_{wstd}	Volume of water collected (ft ³)	10.3014	10.5414	10.2732	10.3720
V_{mstd}	Volume metered, standard (dscf)	36.9359	37.9535	36.2941	37.0612
P_a	Sample gas pressure, absolute (in. Hg)	29.3500	29.3500	29.3500	29.3500
P_v	Vapor pressure, actual (in. Hg)	29.3500	29.3500	29.3500	29.3500
B_{wo}	Moisture measured in sample (% by volume)	21.8078	21.7372	22.0610	21.8687
B_{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w	Actual water vapor in gas (% by volume)	21.8078	21.7372	22.0610	21.8687
$\sqrt{\Delta P}$	Velocity head (in. H ₂ O)	0.6821	0.6822	0.6568	0.6737
M_d	MW of sample gas, dry (lb/lb-mole)	30.0180	29.9788	30.0156	30.0041
M_w	MW of sample gas, wet (lb/lb-mole)	27.3971	27.3749	27.3648	27.3790
V_s	Velocity of sample (ft/sec)	45.8219	45.8590	44.1479	45.2762
%I	Isokinetic sampling (%)	102.0995	104.7829	104.4456	103.7760
Q_a	Volumetric flow rate, actual (acfm)	175,956	176,099	169,528	173,861
Q_s	Volumetric flow rate, standard (scfm)	121,010	121,050	116,614	119,558
Q_{std}	Volumetric flow rate, dry standard (dscfm)	94,620	94,737	90,888	93,415
Q_{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,848	78,993	76,829	78,557
Q_a	Volumetric flow rate, actual (acf/hr)	10,557,355	10,565,919	10,171,667	10,431,647
Q_s	Volumetric flow rate, standard (scf/hr)	7,260,581	7,262,999	6,996,820	7,173,466
Q_{std}	Volumetric flow rate, dry standard (dscf/hr)	5,677,207	5,684,227	5,453,253	5,604,896
Q_a	Volumetric flow rate, actual (m ³ /hr)	298,990	299,233	288,068	295,430
Q_s	Volumetric flow rate, standard (m ³ /hr)	205,624	205,692	198,154	203,157
Q_{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	160,782	160,981	154,439	158,734
Q_{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,681	134,228	130,551	133,487
Q_s	Volumetric flow rate, normal (Nm ³ /hr)	191,604	191,668	184,644	189,305
Q_{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	149,819	150,005	143,909	147,911
Q_{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	126,430	125,076	121,650	124,385

Comments:

Average includes 3 runs.

042010 111711
 O K P @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 13B
 HF Parameters**

Run No.	1	2	3	Average	
Date (2010)	Mar 22	Mar 22	Mar 22		
Start Time (approx.)	13:19	15:07	16:30		
Stop Time (approx.)	14:34	16:21	17:41		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.9	184.2	184.8	184.3
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.1700	9.3100	9.1500	9.2100
CO ₂	Carbon dioxide (dry volume %)	10.3200	10.0400	10.3100	10.2233
T _s	Sample temperature (°F)	293.1200	293.4800	292.9600	293.1867
B _w	Actual water vapor in gas (% by volume)	21.8078	21.7372	22.0610	21.8687
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	175,956	176,099	169,528	173,861
Q _s	Volumetric flow rate, standard (scfm)	121,010	121,050	116,614	119,558
Q _{std}	Volumetric flow rate, dry standard (dscfm)	94,620	94,737	90,888	93,415
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,848	78,993	76,829	78,557
Q _a	Volumetric flow rate, actual (act/hr)	10,557,355	10,565,919	10,171,667	10,431,647
Q _s	Volumetric flow rate, standard (scf/hr)	7,260,581	7,262,999	6,996,820	7,173,466
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,677,207	5,684,227	5,453,253	5,604,896
Q _a	Volumetric flow rate, actual (m ³ /hr)	298,990	299,233	288,068	295,430
Q _s	Volumetric flow rate, standard (m ³ /hr)	205,624	205,692	198,154	203,157
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	160,782	160,981	154,439	158,734
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,681	134,228	130,551	133,487
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	191,604	191,668	184,644	189,305
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	149,819	150,005	143,909	147,911
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	126,430	125,076	121,650	124,385
Sampling Data					
V _{std}	Volume metered, standard (dscf)	36.9359	37.9535	36.2941	37.0612
%I	Isokinetic sampling (%)	102.0995	104.7829	104.4456	103.7760
Laboratory Data					
m _n	Total HF collected (mg)	<0.0389	<0.0374	<0.0378	
Hydrogen Fluoride (HF) Results					
C _{std}	HF Concentration (lb/dscf)	<2.3234E-09	<2.1754E-09	<2.2979E-09	<2.2656E-09
C _{std7}	HF Concentration @7% O ₂ (lb/dscf)	<2.7532E-09	<2.6090E-09	<2.7184E-09	<2.6935E-09
C _{std12}	HF Concentration @12% CO ₂ (lb/dscf)	<2.7016E-09	<2.6001E-09	<2.6746E-09	<2.6588E-09
C _a	HF Concentration (lb/acf)	<1.2494E-09	<1.1703E-09	<1.2320E-09	<1.2172E-09
C _{std}	HF Concentration (ppmdv)	<0.0448	<0.0419	<0.0443	<0.0437
C _{std7}	HF Concentration @7% O ₂ (ppmdv)	<0.0531	<0.0503	<0.0524	<0.0519
C _{std12}	HF Concentration @12% CO ₂ (ppmdv)	<0.0521	<0.0501	<0.0515	<0.0512
C _w	HF Concentration (ppmwv)	<0.0350	<0.0328	<0.0345	<0.0341
C _{std}	HF Concentration (mg/dscm)	<0.0372	<0.0348	<0.0368	<0.0363
C _{std7}	HF Concentration @7% O ₂ (mg/dscm)	<0.0441	<0.0418	<0.0435	<0.0431
C _{std12}	HF Concentration @12% CO ₂ (mg/dscm)	<0.0433	<0.0416	<0.0428	<0.0426
C _a	HF Concentration (mg/m ³ (actual,wet))	<0.0200	<0.0187	<0.0197	<0.0195
C _{std}	HF Concentration (mg/Nm ³ dry)	<0.0399	<0.0374	<0.0395	<0.0389
C _{std7}	HF Concentration @7% O ₂ (mg/Nm ³ dry)	<0.0473	<0.0448	<0.0467	<0.0463
C _{std12}	HF Concentration @12% CO ₂ (mg/Nm ³ dry)	<0.0464	<0.0447	<0.0460	<0.0457
E _{lb/hr}	HF Rate (lb/hr)	<0.0132	<0.0124	<0.0125	<0.0127
E _{kg/hr}	HF Rate (kg/hr)	<0.0060	<0.0056	<0.0057	<0.0058
E _{T/yr}	HF Rate (Ton/yr)	<0.0578	<0.0542	<0.0549	<0.0556
E _{Fd}	HF Rate - Fd-based (lb/MMBtu)	<0.000040	<0.000038	<0.000039	<0.000039
E _{Fc}	HF Rate - Fc-based (lb/MMBtu)	<0.000041	<0.000039	<0.000041	<0.000040

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 26A (HCl)
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:31	09:58	11:30	
Stop Time (approx.)		09:31	10:58	12:47	
Sampling Conditions					
Y _d	Dry gas meter correction factor	1.0005	1.0005	1.0005	
C _p	Pitot tube coefficient	0.8400	0.8400	0.8400	
P _g	Static pressure (in. H ₂ O)	-10.6000	-10.6000	-10.6000	
A _s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar}	Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
O ₂	Oxygen (dry volume %)	10.0200	9.5200	9.1900	9.5767
CO ₂	Carbon dioxide (dry volume %)	9.2400	9.9600	10.2400	9.8133
N ₂ +CO	Nitrogen plus carbon monoxide (dry volume %)	80.7400	80.5200	80.5700	80.6100
V _{lc}	Total Liquid collected (ml)	247.60	236.90	247.90	
V _m	Volume metered, meter conditions (ft ³)	41.3200	41.2350	40.9900	
T _m	Dry gas meter temperature (°F)	67.5833	67.3750	66.7917	
T _s	Sample temperature (°F)	294.6667	294.9167	296.2500	295.2778
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.5000	1.5000	1.5000	
θ	Total sampling time (min)	60.0	60.0	60.0	
Flow Results					
V _{wstd}	Volume of water collected (ft ³)	11.6521	11.1485	11.6662	11.4889
V _{mstd}	Volume metered, standard (dscf)	41.7580	41.6886	41.4868	41.6445
P _s	Sample gas pressure, absolute (in. Hg)	29.3206	29.3206	29.3206	29.3206
P _v	Vapor pressure, actual (in. Hg)	29.3206	29.3206	29.3206	29.3206
B _{wo}	Moisture measured in sample (% by volume)	21.8162	21.0998	21.9483	21.6214
B _{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w	Actual water vapor in gas (% by volume)	21.8162	21.0998	21.9483	21.6214
M _d	MW of sample gas, dry (lb/lb-mole)	29.8792	29.9744	30.0060	29.9532
M _s	MW of sample gas, wet (lb/lb-mole)	27.2876	27.4478	27.3709	27.3688

Comments:

Average includes 3 runs.

042010 111804
 ONK@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:31	09:58	11:30	
Stop Time (approx.)		09:31	10:58	12:47	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.3	184.8	184.6	184.2
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	316	315
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	10.0200	9.5200	9.1900	9.5767
CO ₂	Carbon dioxide (dry volume %)	9.2400	9.9600	10.2400	9.8133
T _s	Sample temperature (°F)	294.6667	294.9167	296.2500	295.2778
B _w	Actual water vapor in gas (% by volume)	21.8162	21.0998	21.9483	21.6214
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	41.7580	41.6886	41.4868	41.6445
Laboratory Data					
m _n	Total HCl collected (mg)	11.0981	11.4642	15.4584	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	5.8603E-07	6.0637E-07	8.2161E-07	6.7133E-07
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	7.4869E-07	7.4064E-07	9.7527E-07	8.2153E-07
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	7.6107E-07	7.3056E-07	9.6282E-07	8.1815E-07
C _{sd}	HCl Concentration (ppmdv)	6.1958	6.4109	8.6865	7.0977
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	7.9156	7.8305	10.3111	8.6857
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	8.0465	7.7240	10.1795	8.6500
C _w	HCl Concentration (ppmwv)	4.8441	5.0582	6.7800	5.5608
C _{sd}	HCl Concentration (mg/dscm)	9.3844	9.7101	13.1569	10.7505
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	11.9893	11.8603	15.6175	13.1557
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	12.1875	11.6989	15.4183	13.1016
C _{sd}	HCl Concentration (mg/Nm ³ dry)	10.0711	10.4206	14.1196	11.5371
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	12.8665	12.7282	16.7603	14.1183
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	13.0793	12.5550	16.5464	14.0602
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.0108	0.0107	0.0140	0.0118
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.0115	0.0111	0.0146	0.0124

042010 111804
 ONK@@@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 SDA Inlet

**USEPA Method 26A (HCI)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:31	09:58	11:30	
Stop Time (approx.)	09:31	10:58	12:46	
Sampling Conditions				
Y_d Dry gas meter correction factor	0.9916	0.9916	0.9916	
C_p Pitot tube coefficient	0.8400	0.8400	0.8400	
P_g Static pressure (in. H ₂ O)	-1.6000	-1.8000	-1.7000	
A_s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P_{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
O_2 Oxygen (dry volume %)	8.4500	8.5900	7.9200	8.3200
CO_2 Carbon dioxide (dry volume %)	10.8700	10.8200	11.3900	11.0267
N_2+CO Nitrogen plus carbon monoxide (dry volume %)	80.6800	80.5900	80.6900	80.6533
V_{lc} Total Liquid collected (ml)	159.30	159.10	177.80	
V_m Volume metered, meter conditions (ft ³)	35.0250	36.1650	35.7300	
T_m Dry gas meter temperature (°F)	65.5417	69.8750	71.1667	
T_s Sample temperature (°F)	494.9167	496.9167	493.7500	495.1944
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.1258	1.1917	1.2000	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V_{wstd} Volume of water collected (ft ³)	7.4967	7.4872	8.3673	7.7837
V_{mstd} Volume metered, standard (dscf)	35.1856	36.0395	35.5202	35.5818
P_s Sample gas pressure, absolute (in. Hg)	29.9824	29.9676	29.9750	29.9750
P_v Vapor pressure, actual (in. Hg)	29.9824	29.9676	29.9750	29.9750
B_{wo} Moisture measured in sample (% by volume)	17.5639	17.2015	19.0653	17.9435
B_{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w Actual water vapor in gas (% by volume)	17.5639	17.2015	19.0653	17.9435
M_d MW of sample gas, dry (lb/lb-mole)	30.0772	30.0748	30.1392	30.0971
M_s MW of sample gas, wet (lb/lb-mole)	27.9560	27.9978	27.8248	27.9262

Comments:

Average includes 3 runs.

042010 111818
 J Q J @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 SDA Inlet

USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:31	09:58	11:30	
Stop Time (approx.)		09:31	10:58	12:46	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	183.3	184.8	184.6	184.2
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	316	315
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.4500	8.5900	7.9200	8.3200
CO ₂	Carbon dioxide (dry volume %)	10.8700	10.8200	11.3900	11.0267
T _s	Sample temperature (°F)	494.9167	496.9167	493.7500	495.1944
B _w	Actual water vapor in gas (% by volume)	17.5639	17.2015	19.0653	17.9435
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	35.1856	36.0395	35.5202	35.5818
Laboratory Data					
m _n	Total HCl collected (mg)	592.5061	671.5237	1044.3603	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	3.7131E-05	4.1086E-05	6.4831E-05	4.7683E-05
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	4.1455E-05	4.6392E-05	6.9426E-05	5.2425E-05
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	4.0991E-05	4.5566E-05	6.8303E-05	5.1620E-05
C _{sd}	HCl Concentration (ppmdv)	392.5707	434.3828	685.4341	504.1292
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	438.2917	490.4891	734.0165	554.2658
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	433.3807	481.7554	722.1430	545.7597
C _w	HCl Concentration (ppmwv)	323.6201	359.6626	554.7541	412.6789
C _{sd}	HCl Concentration (mg/dscm)	594.6004	657.9305	1038.1810	763.5706
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	663.8511	742.9109	1111.7654	839.5091
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	656.4126	729.6826	1093.7815	826.6256
C _{sd}	HCl Concentration (mg/Nm ³ dry)	638.1078	706.0717	1114.1454	819.4416
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	712.4255	797.2703	1193.1141	900.9366
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	704.4428	783.0740	1173.8143	887.1104
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.5965	0.6676	0.9990	0.7544
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.6217	0.6911	1.0359	0.7829

042010 111818
 J Q J @ @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 24	Mar 24	Mar 24	
Start Time (approx.)		07:53	11:03	14:12	
Stop Time (approx.)		10:06	13:35	16:22	
Sampling Conditions					
Y _d	Dry gas meter correction factor	1.0066	1.0066	1.0066	
C _p	Pitot tube coefficient	0.8050	0.8050	0.8050	
P _g	Static pressure (in. H ₂ O)	-11.0000	-11.0000	-11.1000	
A _s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar}	Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n	Nozzle diameter (in.)	0.2700	0.2700	0.2700	
O ₂	Oxygen (dry volume %)	9.4500	9.3900	9.7900	9.5433
CO ₂	Carbon dioxide (dry volume %)	9.9100	10.1500	9.8600	9.9733
N ₂ +CO	Nitrogen plus carbon monoxide (dry volume %)	80.6400	80.4600	80.3500	80.4833
V _{lc}	Total Liquid collected (ml)	432.50	455.00	442.20	
V _m	Volume metered, meter conditions (ft ³)	70.8050	73.8600	74.5150	
T _m	Dry gas meter temperature (°F)	67.7600	80.8000	81.9000	
T _s	Sample temperature (°F)	295.1600	297.6400	297.3200	296.7067
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.0812	1.1520	1.1828	
θ	Total sampling time (min)	125.0	125.0	125.0	
Flow Results					
V _{wstd}	Volume of water collected (ft ³)	20.3535	21.4123	20.8099	20.8586
V _{mstd}	Volume metered, standard (dscf)	71.8944	73.2007	73.7054	72.9335
P _s	Sample gas pressure, absolute (in. Hg)	29.2912	29.2912	29.2838	29.2887
P _v	Vapor pressure, actual (in. Hg)	29.2912	29.2912	29.2838	29.2887
B _{wo}	Moisture measured in sample (% by volume)	22.0639	22.6315	22.0175	22.2376
B _{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w	Actual water vapor in gas (% by volume)	22.0639	22.6315	22.0175	22.2376
√ΔP	Velocity head (√in. H ₂ O)	0.6758	0.6947	0.7011	0.6905
M _d	MW of sample gas, dry (lb/lb-mole)	29.9636	29.9996	29.9692	29.9775
M _s	MW of sample gas, wet (lb/lb-mole)	27.3240	27.2839	27.3339	27.3139
V _s	Velocity of sample (ft/sec)	45.1764	46.5496	46.9334	46.2198
%I	Isokinetic sampling (%)	100.0953	99.9603	99.0236	99.6931
Q _a	Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _s	Volumetric flow rate, standard (scfm)	118,744	121,953	122,980	121,226
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,233	78,130	76,653	77,005
Q _a	Volumetric flow rate, actual (acf/hr)	10,408,646	10,725,027	10,813,459	10,649,044
Q _s	Volumetric flow rate, standard (scf/hr)	7,124,664	7,317,195	7,378,793	7,273,551
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,552,687	5,661,207	5,754,167	5,656,020
Q _a	Volumetric flow rate, actual (m ³ /hr)	294,779	303,739	306,244	301,587
Q _s	Volumetric flow rate, standard (m ³ /hr)	201,775	207,227	208,972	205,991
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,255	160,329	162,961	160,182
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	129,538	132,761	130,252	130,850
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	188,017	193,098	194,724	191,946
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,533	149,397	151,850	149,260
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	120,706	123,709	121,371	121,929

Comments:

Average includes 3 runs.

042010 111911
 KKN@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Filterable Particulate Parameters**

Run No.	1	2	3	Average	
Date (2010)	Mar 24	Mar 24	Mar 24		
Start Time (approx.)	07:53	11:03	14:12		
Stop Time (approx.)	10:06	13:35	16:22		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.9	183.7	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.4500	9.3900	9.7900	9.5433
CO ₂	Carbon dioxide (dry volume %)	9.9100	10.1500	9.8600	9.9733
T _s	Sample temperature (°F)	295.1600	297.6400	297.3200	296.7067
B _w	Actual water vapor in gas (% by volume)	22.0639	22.6315	22.0175	22.2376
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _s	Volumetric flow rate, standard (scfm)	118,744	121,953	122,980	121,226
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,233	78,130	76,653	77,005
Q _a	Volumetric flow rate, actual (acf/hr)	10,408,646	10,725,027	10,813,459	10,649,044
Q _s	Volumetric flow rate, standard (scf/hr)	7,124,664	7,317,195	7,378,793	7,273,551
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,552,687	5,661,207	5,754,167	5,656,020
Q _a	Volumetric flow rate, actual (m ³ /hr)	294,779	303,739	306,244	301,587
Q _s	Volumetric flow rate, standard (m ³ /hr)	201,775	207,227	208,972	205,991
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,255	160,329	162,961	160,182
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	129,538	132,761	130,252	130,850
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	188,017	193,098	194,724	191,946
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,533	149,397	151,850	149,260
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	120,706	123,709	121,371	121,929
Sampling Data					
V _{std}	Volume metered, standard (dscf)	71.8944	73.2007	73.7054	72.9335
%I	Isokinetic sampling (%)	100.0953	99.9603	99.0236	99.6931
Laboratory Data					
m _{filter}	Matter collected on filter(s) (g)	0.00110	0.00060	0.00030	
m _s	Matter collected in solvent rinse(s) (g)	0.00140	0.00240	0.00120	
m _n	Total particulate matter collected (g)	0.00250	0.00300	0.00150	
Filterable Particulate Results					
C _{std}	Particulate Concentration (lb/dscf)	7.6675E-08	9.0368E-08	4.4875E-08	7.0639E-08
C _{std7}	Particulate Concentration @7% O ₂ (lb/dscf)	9.3081E-08	1.0913E-07	5.6144E-08	8.6119E-08
C _{std12}	Particulate Concentration @12% CO ₂ (lb/dscf)	9.2846E-08	1.0684E-07	5.4614E-08	8.4766E-08
C _a	Particulate Concentration (lb/acf)	4.0904E-08	4.7701E-08	2.3879E-08	3.7495E-08
C _{std}	Particulate Concentration (gr/dscf)	0.0005	0.0006	0.0003	0.0005
C _{std7}	Particulate Concentration @7% O ₂ (gr/dscf)	0.0007	0.0008	0.0004	0.0006
C _{std12}	Particulate Concentration @12% CO ₂ (gr/dscf)	0.0006	0.0007	0.0004	0.0006
C _a	Particulate Concentration (gr/acf)	0.0003	0.0003	0.0002	0.0003
C _{std}	Particulate Concentration (mg/dscm)	1.2278	1.4471	0.7186	1.1312
C _{std7}	Particulate Concentration @7% O ₂ (mg/dscm)	1.4906	1.7476	0.8991	1.3791
C _{std12}	Particulate Concentration @12% CO ₂ (mg/dscm)	1.4868	1.7109	0.8746	1.3574
C _a	Particulate Concentration (mg/m ³ (actual,wet))	0.6550	0.7639	0.3824	0.6004
C _{std}	Particulate Concentration (mg/Nm ³ dry)	1.3177	1.5530	0.7712	1.2140
C _{std7}	Particulate Concentration @7% O ₂ (mg/Nm ³ dry)	1.5996	1.8755	0.9648	1.4800
C _{std12}	Particulate Concentration @12% CO ₂ (mg/Nm ³ dry)	1.5956	1.8361	0.9386	1.4567
E _{lb/hr}	Particulate Rate (lb/hr)	0.4258	0.5116	0.2582	0.3985
E _{kg/hr}	Particulate Rate (kg/hr)	0.1931	0.2320	0.1171	0.1807
E _{T/yr}	Particulate Rate (Ton/yr)	1.8648	2.2408	1.1310	1.7455
E _{rd}	Particulate Rate - F _d -based (lb/MMBtu)	0.0013	0.0016	0.0008	0.0012
E _{rc}	Particulate Rate - F _c -based (lb/MMBtu)	0.0014	0.0016	0.0008	0.0013

Comments:

Average includes 3 runs.

042010 111911
 KKN@_M

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 24	Mar 24	Mar 24	
Start Time (approx.)		07:53	11:03	14:12	
Stop Time (approx.)		10:06	13:35	16:22	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.9	183.7	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.4500	9.3900	9.7900	9.5433
CO ₂	Carbon dioxide (dry volume %)	9.9100	10.1500	9.8600	9.9733
T _a	Sample temperature (°F)	295.1600	297.6400	297.3200	296.7067
B _w	Actual water vapor in gas (% by volume)	22.0639	22.6315	22.0175	22.2376
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _s	Volumetric flow rate, standard (scfm)	118,744	121,953	122,980	121,226
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,233	78,130	76,653	77,005
Q _a	Volumetric flow rate, actual (acf/hr)	10,408,646	10,725,027	10,813,459	10,649,044
Q _s	Volumetric flow rate, standard (scf/hr)	7,124,664	7,317,195	7,378,793	7,273,551
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,552,687	5,661,207	5,754,167	5,656,020
Q _a	Volumetric flow rate, actual (m ³ /hr)	294,779	303,739	306,244	301,587
Q _s	Volumetric flow rate, standard (m ³ /hr)	201,775	207,227	208,972	205,991
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,255	160,329	162,961	160,182
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	129,538	132,761	130,252	130,850
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	188,017	193,098	194,724	191,946
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,533	149,397	151,850	149,260
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	120,706	123,709	121,371	121,929
Sampling Data					
V _{std}	Volume metered, standard (dscf)	71.8944	73.2007	73.7054	72.9335
%I	Isokinetic sampling (%)	100.0953	99.9603	99.0236	99.6931
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m _{n-2b}	Fraction 2B (µg)	2.8801	3.2488	3.4006	
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m _n	Total matter corrected for allowable blanks (µg)	2.8801	3.2488	3.4006	
Mercury Results - Total					
C _{sd}	Concentration (lb/dscf)	8.8333E-11	9.7864E-11	1.0173E-10	9.5976E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	1.0723E-10	1.1818E-10	1.2728E-10	1.1757E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	1.0696E-10	1.1570E-10	1.2381E-10	1.1549E-10
C _a	Concentration (lb/acf)	4.7123E-11	5.1657E-11	5.4135E-11	5.0972E-11
C _{sd}	Concentration (µg/dscm)	1.4145E+00	1.5672E+00	1.6291E+00	1.5369E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	1.7172E+00	1.8926E+00	2.0382E+00	1.8827E+00
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	1.7129E+00	1.8528E+00	1.9827E+00	1.8494E+00
C _{sd}	Concentration (mg/dscm)	1.4145E-03	1.5672E-03	1.6291E-03	1.5369E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	1.7172E-03	1.8926E-03	2.0382E-03	1.8827E-03
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	1.7129E-03	1.8528E-03	1.9827E-03	1.8494E-03
C _a	Concentration (µg/m ³ (actual,wet))	7.5461E-01	8.2722E-01	8.6689E-01	8.1624E-01
C _{sd}	Concentration (µg/Nm ³ dry)	1.5180E+00	1.6818E+00	1.7483E+00	1.6494E+00
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	1.8429E+00	2.0310E+00	2.1873E+00	2.0204E+00
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	1.8382E+00	1.9884E+00	2.1278E+00	1.9848E+00
E _{lb/hr}	Rate (lb/hr)	4.9049E-04	5.5403E-04	5.8538E-04	5.4330E-04
E _{g/s}	Rate (g/s)	6.1790E-05	6.9794E-05	7.3745E-05	6.8443E-05
E _{T/yr}	Rate (Ton/yr)	2.1483E-03	2.4266E-03	2.5640E-03	2.3796E-03
E _{Td}	Rate - Fd-based (lb/MMBtu)	1.5430E-06	1.7006E-06	1.8315E-06	1.6917E-06
E _{Fc}	Rate - Fc-based (lb/MMBtu)	1.6223E-06	1.7548E-06	1.8778E-06	1.7516E-06

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Emission Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:35	16:22	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	183.9	183.7	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	6	6	6	6
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.4500	9.3900	9.7900	9.5433
CO ₂ Carbon dioxide (dry volume %)	9.9100	10.1500	9.8600	9.9733
T _s Sample temperature (°F)	295.1600	297.6400	297.3200	296.7067
B _w Actual water vapor in gas (% by volume)	22.0639	22.6315	22.0175	22.2376
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _s Volumetric flow rate, standard (scfm)	118,744	121,953	122,980	121,226
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,233	78,130	76,653	77,005
Q _a Volumetric flow rate, actual (acf/hr)	10,408,646	10,725,027	10,813,459	10,649,044
Q _s Volumetric flow rate, standard (scf/hr)	7,124,664	7,317,195	7,378,793	7,273,551
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,552,687	5,661,207	5,754,167	5,656,020
Q _a Volumetric flow rate, actual (m ³ /hr)	294,779	303,739	306,244	301,587
Q _s Volumetric flow rate, standard (m ³ /hr)	201,775	207,227	208,972	205,991
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,255	160,329	162,961	160,182
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	129,538	132,761	130,252	130,850
Q _s Volumetric flow rate, normal (Nm ³ /hr)	188,017	193,098	194,724	191,946
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,533	149,397	151,850	149,260
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	120,706	123,709	121,371	121,929
Sampling Data				
V _{msid} Volume metered, standard (dscf)	71.8944	73.2007	73.7054	72.9335
%I Isokinetic sampling (%)	100.0953	99.9603	99.0236	99.6931
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{ed} Concentration (lb/dscf)	<1.5335E-12	<1.5061E-12	<1.4958E-12	<1.5118E-12
C _{ed7} Concentration @7% O ₂ (lb/dscf)	<1.8616E-12	<1.8189E-12	<1.8715E-12	<1.8507E-12
C _{ed12} Concentration @12% CO ₂ (lb/dscf)	<1.8569E-12	<1.7807E-12	<1.8205E-12	<1.8193E-12
C _a Concentration (lb/acf)	<8.1807E-13	<7.9501E-13	<7.9597E-13	<8.0302E-13
C _{ed} Concentration (µg/dscm)	<2.4557E-02	<2.4119E-02	<2.3953E-02	<2.4210E-02
C _{ed7} Concentration @7% O ₂ (µg/dscm)	<2.9811E-02	<2.9127E-02	<2.9969E-02	<2.9636E-02
C _{ed12} Concentration @12% CO ₂ (µg/dscm)	<2.9736E-02	<2.8515E-02	<2.9152E-02	<2.9134E-02
C _{sd} Concentration (mg/dscm)	<2.4557E-05	<2.4119E-05	<2.3953E-05	<2.4210E-05
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<2.9811E-05	<2.9127E-05	<2.9969E-05	<2.9636E-05
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	<2.9736E-05	<2.8515E-05	<2.9152E-05	<2.9134E-05
C _a Concentration (µg/m ³ (actual,wet))	<1.3100E-02	<1.2731E-02	<1.2746E-02	<1.2859E-02
C _{sd} Concentration (µg/Nm ³ dry)	<2.6354E-02	<2.5883E-02	<2.5706E-02	<2.5981E-02
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	<3.1993E-02	<3.1258E-02	<3.2162E-02	<3.1804E-02
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	<3.1912E-02	<3.0601E-02	<3.1285E-02	<3.1266E-02
E _{lb/hr} Rate (lb/hr)	<8.5150E-08	<8.5265E-08	<8.6072E-08	<8.5496E-08
E _{g/s} Rate (g/s)	<1.0727E-06	<1.0741E-06	<1.0843E-06	<1.0770E-06
E _{T/yr} Rate (Ton/yr)	<3.7296E-05	<3.7346E-05	<3.7699E-05	<3.7447E-05
E _{Fd} Rate - Fd-based (lb/MMBtu)	<2.6788E-08	<2.6173E-08	<2.6929E-08	<2.6630E-08
E _{Fc} Rate - Fc-based (lb/MMBtu)	<2.8163E-08	<2.7007E-08	<2.7610E-08	<2.7593E-08

042010 112729
 KKN@_K

**USEPA Method 5/29
 Cadmium (Cd) Emission Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:35	16:22	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	183.9	183.7	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	6	6	6	6
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.4500	9.3900	9.7900	9.5433
CO ₂ Carbon dioxide (dry volume %)	9.9100	10.1500	9.8600	9.9733
T _s Sample temperature (°F)	295.1600	297.6400	297.3200	296.7067
B _w Actual water vapor in gas (% by volume)	22.0639	22.6315	22.0175	22.2376
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _s Volumetric flow rate, standard (scfm)	118,744	121,953	122,980	121,226
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,233	78,130	76,653	77,005
Q _a Volumetric flow rate, actual (acf/hr)	10,408,646	10,725,027	10,813,459	10,649,044
Q _s Volumetric flow rate, standard (scf/hr)	7,124,664	7,317,195	7,378,793	7,273,551
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,552,687	5,661,207	5,754,167	5,656,020
Q _a Volumetric flow rate, actual (m ³ /hr)	294,779	303,739	306,244	301,587
Q _s Volumetric flow rate, standard (m ³ /hr)	201,775	207,227	208,972	205,991
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,255	160,329	162,961	160,182
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	129,538	132,761	130,252	130,850
Q _s Volumetric flow rate, normal (Nm ³ /hr)	188,017	193,098	194,724	191,946
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,533	149,397	151,850	149,260
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	120,706	123,709	121,371	121,929
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.8944	73.2007	73.7054	72.9335
%I Isokinetic sampling (%)	100.0953	99.9603	99.0236	99.6931
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.5113	0.9717	0.9525	
Cadmium Results - Total				
C _{sd} Concentration (lb/dscf)	1.5682E-11	2.9271E-11	2.8496E-11	2.4483E-11
C _{sd7} Concentration @7% O ₂ (lb/dscf)	1.9037E-11	3.5349E-11	3.5652E-11	3.0013E-11
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	1.8989E-11	3.4606E-11	3.4681E-11	2.9425E-11
C _a Concentration (lb/acf)	8.3657E-12	1.5451E-11	1.5164E-11	1.2993E-11
C _{sd} Concentration (µg/dscm)	2.5112E-01	4.6874E-01	4.5632E-01	3.9206E-01
C _{sd7} Concentration @7% O ₂ (µg/dscm)	3.0485E-01	5.6607E-01	5.7092E-01	4.8061E-01
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	3.0408E-01	5.5417E-01	5.5536E-01	4.7121E-01
C _{sd} Concentration (mg/dscm)	2.5112E-04	4.6874E-04	4.5632E-04	3.9206E-04
C _{sd7} Concentration @7% O ₂ (mg/dscm)	3.0485E-04	5.6607E-04	5.7092E-04	4.8061E-04
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	3.0408E-04	5.5417E-04	5.5536E-04	4.7121E-04
C _a Concentration (µg/m ³ (actual,wet))	1.3396E-01	2.4742E-01	2.4282E-01	2.0807E-01
C _{sd} Concentration (µg/Nm ³ dry)	2.6950E-01	5.0303E-01	4.8971E-01	4.2075E-01
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	3.2716E-01	6.0749E-01	6.1269E-01	5.1578E-01
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	3.2633E-01	5.9472E-01	5.9600E-01	5.0568E-01
E _{lb/hr} Rate (lb/hr)	8.7076E-05	1.6571E-04	1.6397E-04	1.3892E-04
E _{g/s} Rate (g/s)	1.0969E-05	2.0876E-05	2.0656E-05	1.7500E-05
E _{T/yr} Rate (Ton/yr)	3.8139E-04	7.2581E-04	7.1819E-04	6.0846E-04
E _{Fd} Rate - Fd-based (lb/MMBtu)	2.7393E-07	5.0865E-07	5.1301E-07	4.3187E-07
E _{Fc} Rate - Fc-based (lb/MMBtu)	2.8800E-07	5.2486E-07	5.2599E-07	4.4628E-07

042010 112729
 K.K.N.@_K

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29
 Lead (Pb) Emission Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:35	16:22	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	183.9	183.7	183.3	183.6
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	6	6	6	6
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.4500	9.3900	9.7900	9.5433
CO ₂ Carbon dioxide (dry volume %)	9.9100	10.1500	9.8600	9.9733
T _s Sample temperature (°F)	295.1600	297.6400	297.3200	296.7067
B _w Actual water vapor in gas (% by volume)	22.0639	22.6315	22.0175	22.2376
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	173,477	178,750	180,224	177,484
Q _s Volumetric flow rate, standard (scfm)	118,744	121,953	122,980	121,226
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,545	94,353	95,903	94,267
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,233	78,130	76,653	77,005
Q _a Volumetric flow rate, actual (acf/hr)	10,408,646	10,725,027	10,813,459	10,649,044
Q _s Volumetric flow rate, standard (scf/hr)	7,124,664	7,317,195	7,378,793	7,273,551
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,552,687	5,661,207	5,754,167	5,656,020
Q _a Volumetric flow rate, actual (m ³ /hr)	294,779	303,739	306,244	301,587
Q _s Volumetric flow rate, standard (m ³ /hr)	201,775	207,227	208,972	205,991
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,255	160,329	162,961	160,182
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	129,538	132,761	130,252	130,850
Q _s Volumetric flow rate, normal (Nm ³ /hr)	188,017	193,098	194,724	191,946
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,533	149,397	151,850	149,260
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	120,706	123,709	121,371	121,929
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.8944	73.2007	73.7054	72.9335
%I Isokinetic sampling (%)	100.0953	99.9603	99.0236	99.6931
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	5.3271	5.6541	6.3189	
Lead Results - Total				
C _{sd} Concentration (lb/dscf)	1.6338E-10	1.7032E-10	1.8904E-10	1.7425E-10
C _{sd7} Concentration @7% O ₂ (lb/dscf)	1.9834E-10	2.0568E-10	2.3651E-10	2.1351E-10
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	1.9784E-10	2.0136E-10	2.3007E-10	2.0975E-10
C _a Concentration (lb/acf)	8.7159E-11	8.9901E-11	1.0059E-10	9.2551E-11
C _{sd} Concentration (µg/dscm)	2.6163E+00	2.7274E+00	3.0272E+00	2.7903E+00
C _{sd7} Concentration @7% O ₂ (µg/dscm)	3.1762E+00	3.2937E+00	3.7874E+00	3.4191E+00
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	3.1681E+00	3.2245E+00	3.6842E+00	3.3589E+00
C _{sd} Concentration (mg/dscm)	2.6163E-03	2.7274E-03	3.0272E-03	2.7903E-03
C _{sd7} Concentration @7% O ₂ (mg/dscm)	3.1762E-03	3.2937E-03	3.7874E-03	3.4191E-03
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	3.1681E-03	3.2245E-03	3.6842E-03	3.3589E-03
C _a Concentration (µg/m ³ (actual,wet))	1.3957E+00	1.4396E+00	1.6109E+00	1.4821E+00
C _{sd} Concentration (µg/Nm ³ dry)	2.8078E+00	2.9269E+00	3.2487E+00	2.9945E+00
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	3.4086E+00	3.5347E+00	4.0645E+00	3.6693E+00
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	3.3999E+00	3.4604E+00	3.9538E+00	3.6047E+00
E _{lb/hr} Rate (lb/hr)	9.0721E-04	9.6419E-04	1.0878E-03	9.8639E-04
E _{g/s} Rate (g/s)	1.1429E-04	1.2147E-04	1.3703E-04	1.2426E-04
E _{T/yr} Rate (Ton/yr)	3.9736E-03	4.2232E-03	4.7644E-03	4.3204E-03
E _{Fd} Rate - Fd-based (lb/MMBtu)	2.8540E-06	2.9596E-06	3.4033E-06	3.0723E-06
E _{Fc} Rate - Fc-based (lb/MMBtu)	3.0005E-06	3.0539E-06	3.4894E-06	3.1813E-06

042010 112729
 K.K.N@K

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

**USEPA Method 29 (Trace Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	11:03	14:12	
Stop Time (approx.)	10:06	13:32	16:19	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9933	0.9933	0.9933	
C _p Pitot tube coefficient	0.8250	0.8250	0.8250	
P _g Static pressure (in. H ₂ O)	-1.4000	-1.6000	-1.6000	
A _s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n Nozzle diameter (in.)	0.2700	0.2700	0.2700	
O ₂ Oxygen (dry volume %)	7.7900	8.0300	8.1900	8.0033
CO ₂ Carbon dioxide (dry volume %)	11.4100	11.3900	11.3700	11.3900
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.8000	80.5800	80.4400	80.6067
V _{lc} Total Liquid collected (ml)	333.40	309.10	326.90	
V _m Volume metered, meter conditions (ft ³)	65.5450	64.5350	68.1250	
T _m Dry gas meter temperature (°F)	68.8333	79.9375	78.7292	
T _s Sample temperature (°F)	483.2083	488.0833	494.8333	488.7083
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.0283	0.9975	1.1117	
θ Total sampling time (min)	120.0	120.0	120.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	15.6898	14.5462	15.3839	15.2067
V _{mstd} Volume metered, standard (dscf)	65.5324	63.1909	66.8743	65.1992
P _a Sample gas pressure, absolute (in. Hg)	29.9971	29.9824	29.9824	29.9873
P _v Vapor pressure, actual (in. Hg)	29.9971	29.9824	29.9824	29.9873
B _{wo} Moisture measured in sample (% by volume)	19.3171	18.7121	18.7020	18.9104
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	19.3171	18.7121	18.7020	18.9104
√ΔP Velocity head (√in. H ₂ O)	0.6654	0.6589	0.6902	0.6715
M _d MW of sample gas, dry (lb/lb-mole)	30.1372	30.1436	30.1468	30.1425
M _w MW of sample gas, wet (lb/lb-mole)	27.7926	27.8713	27.8751	27.8463
V _s Velocity of sample (ft/sec)	49.9206	49.5018	52.0306	50.4843
%I Isokinetic sampling (%)	101.3257	98.3521	99.7190	99.7989
Q _a Volumetric flow rate, actual (acfm)	180,110	178,599	187,722	182,144
Q _s Volumetric flow rate, standard (scfm)	101,084	99,671	104,022	101,592
Q _{std} Volumetric flow rate, dry standard (dscfm)	81,557	81,021	84,568	82,382
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,922	75,017	77,328	76,422
Q _a Volumetric flow rate, actual (acf/hr)	10,806,580	10,715,920	11,263,346	10,928,615
Q _s Volumetric flow rate, standard (scf/hr)	6,065,012	5,980,273	6,241,341	6,095,542
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	4,893,425	4,861,238	5,074,087	4,942,917
Q _s Volumetric flow rate, actual (m ³ /hr)	306,049	303,481	318,985	309,505
Q _s Volumetric flow rate, standard (m ³ /hr)	171,765	169,365	176,758	172,629
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	138,585	137,673	143,701	139,986
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,708	127,471	131,399	129,859
Q _s Volumetric flow rate, normal (Nm ³ /hr)	160,053	157,817	164,707	160,859
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	129,136	128,286	133,903	130,442
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,796	118,780	122,440	121,005

Comments:

Average includes 3 runs.

042010 112815
 HJK @

**USEPA Method 29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 24	Mar 24	Mar 24	
Start Time (approx.)		07:53	11:03	14:12	
Stop Time (approx.)		10:06	13:32	16:19	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	183.9	183.7	183.3	183.6
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	6	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.7900	8.0300	8.1900	8.0033
CO ₂	Carbon dioxide (dry volume %)	11.4100	11.3900	11.3700	11.3900
T _a	Sample temperature (°F)	483.2083	488.0833	494.8333	488.7083
B _w	Actual water vapor in gas (% by volume)	19.3171	18.7121	18.7020	18.9104
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	180,110	178,599	187,722	182,144
Q _s	Volumetric flow rate, standard (scfm)	101,084	99,671	104,022	101,592
Q _{std}	Volumetric flow rate, dry standard (dscfm)	81,557	81,021	84,568	82,382
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	76,922	75,017	77,328	76,422
Q _a	Volumetric flow rate, actual (aci/hr)	10,806,580	10,715,920	11,263,346	10,928,615
Q _s	Volumetric flow rate, standard (scf/hr)	6,065,012	5,980,273	6,241,341	6,095,542
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	4,893,425	4,861,238	5,074,087	4,942,917
Q _a	Volumetric flow rate, actual (m ³ /hr)	306,049	303,481	318,985	309,505
Q _s	Volumetric flow rate, standard (m ³ /hr)	171,765	169,365	176,758	172,629
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	138,585	137,673	143,701	139,986
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	130,708	127,471	131,399	129,859
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	160,053	157,817	164,707	160,859
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	129,136	128,286	133,903	130,442
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	121,796	118,780	122,440	121,005
Sampling Data					
V _{metd}	Volume metered, standard (dscf)	65.5324	63.1909	66.8743	65.1992
%I	Isokinetic sampling (%)	101.3257	98.3521	99.7190	99.7989
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	32.2231	63.8393	28.8006	
m _{n-2b}	Fraction 2B (µg)	26.7448	50.0603	50.0603	
m _{n-3a}	Fraction 3A (µg)	0.0000	0.0000	0.0000	
m _{n-3b}	Fraction 3B (µg)	0.0000	0.0000	0.0000	
m _{n-3c}	Fraction 3C (µg)	0.4458	0.5270	2.0492	
m _n	Total matter corrected for allowable blanks (µg)	59.4137	114.4267	80.9101	
Mercury Results - Total					
C _{ed}	Concentration (lb/dscf)	1.9991E-09	3.9928E-09	2.6678E-09	2.8866E-09
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	2.1196E-09	4.3124E-09	2.9176E-09	3.1165E-09
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	2.1025E-09	4.2067E-09	2.8156E-09	3.0416E-09
C _a	Concentration (lb/acf)	9.0524E-10	1.8113E-09	1.2018E-09	1.3061E-09
C _{sd}	Concentration (µg/dscm)	3.2013E+01	6.3940E+01	4.2721E+01	4.6225E+01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	3.3942E+01	6.9057E+01	4.6721E+01	4.9907E+01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	3.3669E+01	6.7364E+01	4.5088E+01	4.8707E+01
C _{ed}	Concentration (mg/dscm)	3.2013E-02	6.3940E-02	4.2721E-02	4.6225E-02
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	3.3942E-02	6.9057E-02	4.6721E-02	4.9907E-02
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	3.3669E-02	6.7364E-02	4.5088E-02	4.8707E-02
C _a	Concentration (µg/m ³ (actual, wet))	1.4496E+01	2.9006E+01	1.9246E+01	2.0916E+01
C _{sd}	Concentration (µg/Nm ³ dry)	3.4356E+01	6.8618E+01	4.5847E+01	4.9607E+01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	3.6426E+01	7.4110E+01	5.0139E+01	5.3558E+01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	3.6132E+01	7.2293E+01	4.8387E+01	5.2271E+01
E _{lb/hr}	Rate (lb/hr)	9.7826E-03	1.9410E-02	1.3537E-02	1.4243E-02
E _{g/s}	Rate (g/s)	1.2324E-03	2.4452E-03	1.7053E-03	1.7943E-03
E _{T/yr}	Rate (Ton/yr)	4.2848E-02	8.5016E-02	5.9290E-02	6.2385E-02
E _{Fd}	Rate - Fd-based (lb/MMBtu)	3.0500E-05	6.2053E-05	4.1982E-05	4.4845E-05
E _{Fc}	Rate - Fc-based (lb/MMBtu)	3.1888E-05	6.3801E-05	4.2703E-05	4.6131E-05

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

USEPA Method 13B (Total Fluorides) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:53	09:37	11:24	
Stop Time (approx.)	09:11	10:54	12:46	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9904	0.9904	0.9904	
C _p Pitot tube coefficient	0.8120	0.8120	0.8120	
P _g Static pressure (in. H ₂ O)	-11.0000	-11.0000	-11.0000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O ₂ Oxygen (dry volume %)	9.3800	9.3200	9.3600	9.3533
CO ₂ Carbon dioxide (dry volume %)	10.0000	10.0000	10.1100	10.0367
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.6200	80.6800	80.5300	80.6100
V _{lc} Total Liquid collected (ml)	217.30	217.70	210.30	
V _m Volume metered, meter conditions (ft ³)	35.9350	36.3750	35.7900	
T _m Dry gas meter temperature (°F)	62.7800	72.8200	79.4800	
T _s Sample temperature (°F)	291.9200	292.0400	293.0400	292.3333
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.0596	1.0672	1.0264	
θ Total sampling time (min)	62.5	62.5	62.5	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	10.2261	10.2450	9.8967	10.1226
V _{mstd} Volume metered, standard (dscf)	36.2407	35.9939	34.9743	35.7363
P _a Sample gas pressure, absolute (in. Hg)	29.2912	29.2912	29.2912	29.2912
P _v Vapor pressure, actual (in. Hg)	29.2912	29.2912	29.2912	29.2912
B _{wo} Moisture measured in sample (% by volume)	22.0074	22.1566	22.0559	22.0733
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	22.0074	22.1566	22.0559	22.0733
√ΔP Velocity head (√in. H ₂ O)	0.6777	0.6772	0.6614	0.6721
M _d MW of sample gas, dry (lb/lb-mole)	29.9752	29.9728	29.9920	29.9800
M _s MW of sample gas, wet (lb/lb-mole)	27.3398	27.3200	27.3471	27.3356
V _s Velocity of sample (ft/sec)	45.5847	45.5705	44.5182	45.2245
%I Isokinetic sampling (%)	100.9984	100.5500	100.0149	100.5211
Q _a Volumetric flow rate, actual (acfm)	175,045	174,991	170,950	173,662
Q _s Volumetric flow rate, standard (scfm)	120,334	120,277	117,344	119,318
Q _{std} Volumetric flow rate, dry standard (dscfm)	93,851	93,628	91,463	92,981
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,782	78,001	75,934	77,239
Q _a Volumetric flow rate, actual (acf/hr)	10,502,705	10,499,447	10,256,995	10,419,715
Q _s Volumetric flow rate, standard (scf/hr)	7,220,024	7,216,633	7,040,625	7,159,094
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,631,087	5,617,672	5,487,752	5,578,837
Q _a Volumetric flow rate, actual (m ³ /hr)	297,443	297,351	290,484	295,092
Q _s Volumetric flow rate, standard (m ³ /hr)	204,475	204,379	199,395	202,750
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	159,476	159,096	155,416	157,996
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,170	132,542	129,029	131,247
Q _s Volumetric flow rate, normal (Nm ³ /hr)	190,534	190,444	185,800	188,926
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	148,602	148,248	144,820	147,224
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,158	123,505	120,232	122,298

Comments:

Average includes 3 runs.

042010 112850
 LPI@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 13B
 HF Parameters**

Run No.	1	2	3	Average	
Date (2010)	Mar 24	Mar 24	Mar 24		
Start Time (approx.)	07:53	09:37	11:24		
Stop Time (approx.)	09:11	10:54	12:46		
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.3	183.8	183.6	183.9
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.3800	9.3200	9.3600	9.3533
CO ₂	Carbon dioxide (dry volume %)	10.0000	10.0000	10.1100	10.0367
T _a	Sample temperature (°F)	291.9200	292.0400	293.0400	292.3333
B _w	Actual water vapor in gas (% by volume)	22.0074	22.1566	22.0559	22.0733
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	175,045	174,991	170,950	173,662
Q _s	Volumetric flow rate, standard (scfm)	120,334	120,277	117,344	119,318
Q _{std}	Volumetric flow rate, dry standard (dscfm)	93,851	93,628	91,463	92,981
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	77,782	78,001	75,934	77,239
Q _a	Volumetric flow rate, actual (acf/hr)	10,502,705	10,499,447	10,256,995	10,419,715
Q _s	Volumetric flow rate, standard (scf/hr)	7,220,024	7,216,633	7,040,625	7,159,094
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,631,087	5,617,672	5,487,752	5,578,837
Q _a	Volumetric flow rate, actual (m ³ /hr)	297,443	297,351	290,484	295,092
Q _s	Volumetric flow rate, standard (m ³ /hr)	204,475	204,379	199,395	202,750
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	159,476	159,096	155,416	157,998
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,170	132,542	129,029	131,247
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	190,534	190,444	185,800	188,926
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	148,602	148,248	144,820	147,224
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,158	123,505	120,232	122,298
Sampling Data					
V _{msld}	Volume metered, standard (dscf)	36.2407	35.9939	34.9743	35.7363
%I	Isokinetic sampling (%)	100.9984	100.5500	100.0149	100.5211
Laboratory Data					
m _n	Total HF collected (mg)	<0.0327	<0.0362	<0.0392	
Hydrogen Fluoride (HF) Results					
C _{sd}	HF Concentration (lb/dscf)	<1.9912E-09	<2.2190E-09	<2.4723E-09	<2.2275E-09
C _{sd7}	HF Concentration @7% O ₂ (lb/dscf)	<2.4026E-09	<2.6636E-09	<2.9779E-09	<2.6814E-09
C _{sd12}	HF Concentration @12% CO ₂ (lb/dscf)	<2.3895E-09	<2.6629E-09	<2.9345E-09	<2.6623E-09
C _a	HF Concentration (lb/acf)	<1.0676E-09	<1.1873E-09	<1.3227E-09	<1.1925E-09
C _{sd}	HF Concentration (ppmdv)	<0.0384	<0.0428	<0.0476	<0.0429
C _{sd7}	HF Concentration @7% O ₂ (ppmdv)	<0.0463	<0.0513	<0.0574	<0.0517
C _{sd12}	HF Concentration @12% CO ₂ (ppmdv)	<0.0460	<0.0513	<0.0565	<0.0513
C _w	HF Concentration (ppmwv)	<0.0299	<0.0333	<0.0371	<0.0334
C _{sd}	HF Concentration (mg/dscm)	<0.0319	<0.0355	<0.0396	<0.0357
C _{sd7}	HF Concentration @7% O ₂ (mg/dscm)	<0.0385	<0.0427	<0.0477	<0.0429
C _{sd12}	HF Concentration @12% CO ₂ (mg/dscm)	<0.0383	<0.0426	<0.0470	<0.0426
C _a	HF Concentration (mg/m ³ (actual,wet))	<0.0171	<0.0190	<0.0212	<0.0191
C _{sd}	HF Concentration (mg/Nm ³ dry)	<0.0342	<0.0381	<0.0425	<0.0383
C _{sd7}	HF Concentration @7% O ₂ (mg/Nm ³ dry)	<0.0413	<0.0458	<0.0512	<0.0461
C _{sd12}	HF Concentration @12% CO ₂ (mg/Nm ³ dry)	<0.0411	<0.0458	<0.0504	<0.0458
E _{lb/hr}	HF Rate (lb/hr)	<0.0112	<0.0125	<0.0136	<0.0124
E _{kg/hr}	HF Rate (kg/hr)	<0.0051	<0.0057	<0.0062	<0.0056
E _{T/yr}	HF Rate (Ton/yr)	<0.0491	<0.0546	<0.0594	<0.0544
E _{Fd}	HF Rate - F _d -based (lb/MMBtu)	<0.000035	<0.000038	<0.000043	<0.000039
E _{Fc}	HF Rate - F _c -based (lb/MMBtu)	<0.000036	<0.000040	<0.000045	<0.000040

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 23 (PCDD/F)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 23	Mar 23	
Start Time (approx.)	10:04	07:36	12:32	
Stop Time (approx.)	14:44	12:10	17:02	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9904	0.9904	0.9904	
C _p Pitot tube coefficient	0.8340	0.8340	0.8340	
P _g Static pressure (in. H ₂ O)	-10.8000	-11.0000	-11.0000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n Nozzle diameter (in.)	0.2640	0.2640	0.2640	
O ₂ Oxygen (dry volume %)	9.2100	9.5700	9.2800	9.3533
CO ₂ Carbon dioxide (dry volume %)	10.1600	9.6900	10.2000	10.0167
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.6300	80.7400	80.5200	80.6300
V _{lc} Total Liquid collected (ml)	815.50	830.00	867.60	
V _m Volume metered, meter conditions (ft ³)	140.9400	145.9200	146.0200	
T _m Dry gas meter temperature (°F)	72.5800	78.6300	82.9900	
T _s Sample temperature (°F)	293.3000	296.9000	298.5200	296.2400
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.0038	1.0594	1.0590	
θ Total sampling time (min)	250.0	250.0	250.0	
Flow Results				
V _{wetd} Volume of water collected (ft ³)	38.3774	39.0598	40.8293	39.4222
V _{metd} Volume metered, standard (dscf)	139.5047	142.8310	141.7811	141.3722
P _s Sample gas pressure, absolute (in. Hg)	29.3059	29.2912	29.2912	29.2961
P _v Vapor pressure, actual (in. Hg)	29.3059	29.2912	29.2912	29.2961
B _{wo} Moisture measured in sample (% by volume)	21.5746	21.4743	22.3587	21.8025
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	21.5746	21.4743	22.3587	21.8025
√ΔP Velocity head (√in. H ₂ O)	0.6541	0.6716	0.6674	0.6644
M _d MW of sample gas, dry (lb/lb-mole)	29.9940	29.9332	30.0032	29.9768
M _s MW of sample gas, wet (lb/lb-mole)	27.4063	27.3706	27.3194	27.3655
V _s Velocity of sample (ft/sec)	45.1659	46.5267	46.3268	46.0065
%I Isokinetic sampling (%)	100.6681	100.4539	101.5032	100.8750
Q _a Volumetric flow rate, actual (acfm)	173,437	178,662	177,895	176,665
Q _s Volumetric flow rate, standard (scfm)	119,070	122,012	121,229	120,770
Q _{std} Volumetric flow rate, dry standard (dscfm)	93,381	95,811	94,124	94,438
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,534	78,096	78,685	78,438
Q _a Volumetric flow rate, actual (acf/hr)	10,406,215	10,719,745	10,673,702	10,599,887
Q _s Volumetric flow rate, standard (scf/hr)	7,144,173	7,320,742	7,273,730	7,246,215
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,602,843	5,748,663	5,647,420	5,666,309
Q _a Volumetric flow rate, actual (m ³ /hr)	294,710	303,589	302,286	300,195
Q _s Volumetric flow rate, standard (m ³ /hr)	202,327	207,328	205,996	205,217
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	158,676	162,808	159,938	160,473
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	133,448	132,704	133,704	133,285
Q _s Volumetric flow rate, normal (Nm ³ /hr)	188,532	193,192	191,951	191,225
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	147,857	151,705	149,033	149,532
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	124,349	123,656	124,588	124,197

Comments:

Average includes 3 runs.

042010 112912
 HNP@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 23 Parameters (NDs & EMPCs counted as Zero)
 Total Tetra- through Octa-PCDD/F Results (using USEPA/INTL 1989 TEFs)**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 23	Mar 23	
Start Time (approx.)		10:04	07:36	12:32	
Stop Time (approx.)		14:44	12:10	17:02	
Process Conditions					
R _p	Steam Production Rate (Kibs/hour)	184.2	184.2	183.9	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	318	320	320	319
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _o	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.2100	9.5700	9.2800	9.3533
CO ₂	Carbon dioxide (dry volume %)	10.1600	9.6900	10.2000	10.0167
T _s	Sample temperature (°F)	293.3	296.9	298.5	296.2
B _w	Actual water vapor in gas (% by volume)	21.5746	21.4743	22.3587	21.8025
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	173,437	178,662	177,895	176,665
Q _s	Volumetric flow rate, standard (scfm)	119,070	122,012	121,229	120,770
Q _{std}	Volumetric flow rate, dry standard (dscfm)	93,381	95,811	94,124	94,438
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,534	78,096	78,685	78,438
Q _a	Volumetric flow rate, actual (act/hr)	10,406,215	10,719,745	10,673,702	10,599,887
Q _s	Volumetric flow rate, standard (scf/hr)	7,144,173	7,320,742	7,273,730	7,246,215
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,602,843	5,748,663	5,647,420	5,666,309
Q _a	Volumetric flow rate, actual (m ³ /hr)	294,710	303,589	302,286	300,195
Q _s	Volumetric flow rate, standard (m ³ /hr)	202,327	207,328	205,996	205,217
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	158,676	162,806	159,938	160,473
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	133,448	132,704	133,704	133,285
Q _n	Volumetric flow rate, normal (Nm ³ /hr)	188,532	193,192	191,951	191,225
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	147,857	151,705	149,033	149,532
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	124,349	123,856	124,588	124,197
Sampling Data					
V _{std}	Volume metered, standard (dscf)	139.5047	142.8310	141.7811	141.3722
%I	Isokinetic sampling (%)	100.6681	100.4539	101.5032	100.8750
Laboratory Data from USEPA Method 23					
	Total PCDDs (ng)	9.65000	10.67000	11.61000	
	Total PCDFs (ng)	2.41080	2.57500	2.80840	
m _n	Total PCDDs & PCDFs (ng)	12.10000	13.30000	14.40000	
m _{n,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.09070	0.08800	0.11100	
Total PCDD/F Results (TEF=1)					
C _{sd}	PCDD/F Concentration (ng/dscm)	3.0626E+00	3.2880E+00	3.5863E+00	3.3123E+00
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	3.6416E+00	4.0338E+00	4.2899E+00	3.9884E+00
C _{sd12}	PCDD/F Concentration @12% CO ₂ (ng/dscm)	3.6173E+00	4.0718E+00	4.2191E+00	3.9694E+00
C _{sd}	PCDD/F Concentration (ng/Nm ³ dry)	3.2867E+00	3.5285E+00	3.8487E+00	3.5546E+00
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/Nm ³ dry)	3.9081E+00	4.3289E+00	4.6038E+00	4.2803E+00
C _{sd12}	PCDD/F Concentration @12% CO ₂ (ng/Nm ³ dry)	3.8820E+00	4.3697E+00	4.5278E+00	4.2598E+00
E _{sd/hr}	PCDD/F Rate (lb/hr)	1.0716E-06	1.1803E-06	1.2647E-06	1.1722E-06
E _{g/s}	PCDD/F Rate (g/s)	1.3499E-07	1.4869E-07	1.5933E-07	1.4767E-07
E _{T/yr}	PCDD/F Rate (Ton/yr)	4.6934E-06	5.1699E-06	5.5396E-06	5.1343E-06
E _{Fd}	PCDD/F Rate - F _d -based (lb/MMBtu)	3.2723E-09	3.6247E-09	3.8548E-09	3.5839E-09
E _{Fo}	PCDD/F Rate - F _o -based (lb/MMBtu)	3.4260E-09	3.8564E-09	3.9960E-09	3.7595E-09
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)					
C _{sdTEQ}	TEQ Concentration (ng/dscm)	2.2957E-02	2.1755E-02	2.7644E-02	2.4119E-02
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	2.7297E-02	2.6690E-02	3.3068E-02	2.9018E-02
C _{sd12TEQ}	TEQ Concentration @12% CO ₂ (ng/dscm)	2.7115E-02	2.6941E-02	3.2522E-02	2.8859E-02
C _{sdTEQ}	TEQ Concentration (ng/Nm ³ dry)	2.4637E-02	2.3347E-02	2.9667E-02	2.5883E-02
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/Nm ³ dry)	2.9294E-02	2.8643E-02	3.5488E-02	3.1142E-02
C _{sd12TEQ}	TEQ Concentration @12% CO ₂ (ng/Nm ³ dry)	2.9099E-02	2.8912E-02	3.4902E-02	3.0971E-02
E _{sd/hrTEQ}	TEQ Rate (lb/hr)	8.0322E-09	7.8097E-09	9.7491E-09	8.5303E-09
E _{g/sTEQ}	TEQ Rate (g/sec)	1.0110E-09	9.8384E-10	1.2282E-09	1.0746E-09
E _{T/yrTEQ}	TEQ Rate (Ton/yr)	3.5181E-08	3.4207E-08	4.2701E-08	3.7363E-08
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	2.4528E-11	2.3983E-11	2.9714E-11	2.6075E-11
E _{FoTEQ}	TEQ Rate - F _o -based (lb/MMBtu)	2.5681E-11	2.5516E-11	3.0802E-11	2.7333E-11

042010 112912
 H N P @ P

**USEPA Method 23 Maximum Emissions Parameters (NDs & EMPCs included)
 Total Tetra- through Octa-PCDD/F Results (TEQ based on USEPA/INTL 1989 TEFs)**

Run No.	1	2	3	Average	
Date (2010)	Mar 22	Mar 23	Mar 23		
Start Time (approx.)	10:04	07:36	12:32		
Stop Time (approx.)	14:44	12:10	17:02		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184	184	184	184
P ₁	Fabric Filter Inlet Temperature (°F)	318	320	320	319
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.2100	9.5700	9.2800	9.3533
CO ₂	Carbon dioxide (dry volume %)	10.1600	9.6900	10.2000	10.0187
T _s	Sample temperature (°F)	293.3	296.9	298.5	296.2
B _w	Actual water vapor in gas (% by volume)	21.5746	21.4743	22.3587	21.8025
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	173,437	178,662	177,895	176,665
Q _s	Volumetric flow rate, standard (scfm)	119,070	122,012	121,229	120,770
Q _{std}	Volumetric flow rate, dry standard (dscfm)	93,381	95,811	94,124	94,438
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,534	78,096	78,685	78,438
Q _a	Volumetric flow rate, actual (acf/hr)	10,406,215	10,719,745	10,673,702	10,599,887
Q _s	Volumetric flow rate, standard (scf/hr)	7,144,173	7,320,742	7,273,730	7,246,215
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,602,843	5,748,663	5,647,420	5,666,309
Q _a	Volumetric flow rate, actual (m ³ /hr)	294,710	303,589	302,286	300,195
Q _s	Volumetric flow rate, standard (m ³ /hr)	202,327	207,328	205,996	205,217
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	158,676	162,806	159,938	160,473
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	133,448	132,704	133,704	133,285
Q _n	Volumetric flow rate, normal (Nm ³ /hr)	188,532	193,192	191,951	191,225
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	147,857	151,705	149,033	149,532
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	124,349	123,656	124,588	124,197
Sampling Data					
V _{std}	Volume metered, standard (dscf)	139.5047	142.8310	141.7811	141.3722
%I	Isokinetic sampling (%)	100.6681	100.4539	101.5032	100.8750
Laboratory Data from USEPA Method 23, including NDs and EMPCs					
m _n	Total PCDDs & PCDFs (ng)	12.10000	13.40000	14.60000	
m _{n,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.09600	0.11000	0.12100	
Total PCDD/F Results (TEF=1)					
C _{od}	PCDD/F Concentration (ng/dscm)	3.0626E+00	3.3127E+00	3.6361E+00	3.3371E+00
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	3.6416E+00	4.0641E+00	4.3495E+00	4.0184E+00
C _{sd12}	PCDD/F Concentration @12% CO ₂ (ng/dscm)	3.6173E+00	4.1024E+00	4.2777E+00	3.9991E+00
C _{sd}	PCDD/F Concentration (ng/Nm ³ dry)	3.2867E+00	3.5551E+00	3.9021E+00	3.5813E+00
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/Nm ³ dry)	3.9081E+00	4.3615E+00	4.6678E+00	4.3124E+00
C _{sd12}	PCDD/F Concentration @12% CO ₂ (ng/Nm ³ dry)	3.8820E+00	4.4026E+00	4.5907E+00	4.2918E+00
E _{lb/hr}	PCDD/F Rate (lb/hr)	1.0716E-06	1.1892E-06	1.2823E-06	1.1810E-06
E _{g/s}	PCDD/F Rate (g/s)	1.3499E-07	1.4981E-07	1.6154E-07	1.4878E-07
E _{T/yr}	PCDD/F Rate (Ton/yr)	4.6934E-06	5.2087E-06	5.6165E-06	5.1729E-06
E _{Fd}	PCDD/F - F _d -based (lb/MMBtu)	3.2723E-09	3.6519E-09	3.9084E-09	3.6108E-09
E _{Fc}	PCDD/F Rate - F _c -based (lb/MMBtu)	3.4260E-09	3.8854E-09	4.0515E-09	3.7876E-09
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)					
C _{sdTEQ}	TEQ Concentration (ng/dscm)	2.4299E-02	2.7194E-02	3.0135E-02	2.7209E-02
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	2.8892E-02	3.3362E-02	3.6047E-02	3.2767E-02
C _{sd12TEQ}	TEQ Concentration @12% CO ₂ (ng/dscm)	2.8699E-02	3.3676E-02	3.5452E-02	3.2609E-02
C _{sdTEQ}	TEQ Concentration (ng/Nm ³ dry)	2.6076E-02	2.9183E-02	3.2340E-02	2.9200E-02
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/Nm ³ dry)	3.1006E-02	3.5803E-02	3.8685E-02	3.5165E-02
C _{sd12TEQ}	TEQ Concentration @12% CO ₂ (ng/Nm ³ dry)	3.0799E-02	3.6141E-02	3.8046E-02	3.4995E-02
E _{lb/hrTEQ}	TEQ Rate (lb/hr)	8.5016E-09	9.7622E-09	1.0627E-08	9.8304E-09
E _{g/sTEQ}	TEQ Rate (g/sec)	1.0710E-09	1.2298E-09	1.3388E-09	1.2132E-09
E _{T/yrTEQ}	TEQ Rate (Ton/yr)	3.7237E-08	4.2758E-08	4.6548E-08	4.2181E-08
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	2.5962E-11	2.9978E-11	3.2391E-11	2.9444E-11
E _{FcTEQ}	TEQ Rate - F _c -based (lb/MMBtu)	2.7181E-11	3.1895E-11	3.3577E-11	3.0885E-11

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 26A (HCI)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:55	09:30	10:55	
Stop Time (approx.)	08:55	10:31	12:06	
Sampling Conditions				
Y _d Dry gas meter correction factor	1.0066	1.0066	1.0066	
C _p Pitot tube coefficient	0.8400	0.8400	0.8400	
P _g Static pressure (in. H ₂ O)	-11.0000	-11.0000	-11.0000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
O ₂ Oxygen (dry volume %)	9.5400	10.1000	9.2600	9.6333
CO ₂ Carbon dioxide (dry volume %)	9.6600	9.2700	10.1300	9.6867
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.8000	80.6300	80.6100	80.6800
V _{lc} Total Liquid collected (ml)	231.70	233.50	247.10	
V _m Volume metered, meter conditions (ft ³)	40.0400	40.5300	41.1750	
T _m Dry gas meter temperature (°F)	75.8750	83.9583	81.0000	
T _s Sample temperature (°F)	300.9167	301.2500	300.0833	300.7500
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.5000	1.5000	1.5000	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	10.9038	10.9885	11.6285	11.1736
V _{mstd} Volume metered, standard (dscf)	40.0812	39.9688	40.8269	40.2923
P _s Sample gas pressure, absolute (in. Hg)	29.2912	29.2912	29.2912	29.2912
P _v Vapor pressure, actual (in. Hg)	29.2912	29.2912	29.2912	29.2912
B _{wo} Moisture measured in sample (% by volume)	21.3863	21.5641	22.1684	21.7063
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	21.3863	21.5641	22.1684	21.7063
M _d MW of sample gas, dry (lb/lb-mole)	29.9272	29.8872	29.9912	29.9352
M _s MW of sample gas, wet (lb/lb-mole)	27.3764	27.3238	27.3329	27.3444

Comments:

Average includes 3 runs.

042010 112942
 O K Q @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		07:55	09:30	10:55	
Stop Time (approx.)		08:55	10:31	12:06	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	185.2	183.2	185.3	184.6
P ₁	Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.5400	10.1000	9.2600	9.6333
CO ₂	Carbon dioxide (dry volume %)	9.6600	9.2700	10.1300	9.6867
T _s	Sample temperature (°F)	300.9167	301.2500	300.0833	300.7500
B _w	Actual water vapor in gas (% by volume)	21.3863	21.5641	22.1684	21.7063
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	40.0812	39.9688	40.8269	40.2923
Laboratory Data					
m _n	Total HCl collected (mg)	21.2629	16.6326	16.8368	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	1.1697E-06	9.1759E-07	9.0933E-07	9.9889E-07
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	1.4313E-06	1.1810E-06	1.0859E-06	1.2327E-06
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	1.4531E-06	1.1878E-06	1.0772E-06	1.2394E-06
C _{sd}	HCl Concentration (ppmdv)	12.3672	9.7013	9.6140	10.5608
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	15.1324	12.4859	11.4806	13.0330
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	15.3630	12.5583	11.3887	13.1033
C _w	HCl Concentration (ppmwv)	9.7223	7.6093	7.4827	8.2714
C _{sd}	HCl Concentration (mg/dscm)	18.7318	14.6939	14.5616	15.9958
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	22.9200	18.9116	17.3889	19.7402
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	23.2693	19.0212	17.2497	19.8467
C _{sd}	HCl Concentration (mg/Nm ³ dry)	20.1024	15.7691	15.6271	17.1662
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	24.5971	20.2954	18.6613	21.1846
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	24.9719	20.4130	18.5119	21.2989
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.0206	0.0170	0.0156	0.0177
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.0220	0.0180	0.0163	0.0188

042010 112942
 OKQ@_@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

**USEPA Method 26A (HCl)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:55	09:30	10:55	
Stop Time (approx.)	08:55	10:30	12:06	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9933	0.9933	0.9933	
C _p Pitot tube coefficient	0.8400	0.8400	0.8400	
P _g Static pressure (in. H ₂ O)	-1.4000	-1.4000	-1.5000	
A _s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
O ₂ Oxygen (dry volume %)	8.1400	8.7100	7.5900	8.1467
CO ₂ Carbon dioxide (dry volume %)	10.8900	10.4900	11.5900	10.9900
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.9700	80.8000	80.8200	80.8633
V _{lc} Total Liquid collected (ml)	156.80	158.10	176.10	
V _m Volume metered, meter conditions (ft ³)	34.9050	35.3500	35.1100	
T _m Dry gas meter temperature (°F)	73.6667	83.0417	85.5833	
T _s Sample temperature (°F)	489.9167	494.5833	493.8333	492.7778
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.1917	1.2000	1.2000	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	7.3790	7.4402	8.2873	7.7022
V _{mstd} Volume metered, standard (dscf)	34.5960	34.4329	34.0398	34.3562
P _s Sample gas pressure, absolute (in. Hg)	29.9971	29.9971	29.9897	29.9946
P _v Vapor pressure, actual (in. Hg)	29.9971	29.9971	29.9897	29.9946
B _{w0} Moisture measured in sample (% by volume)	17.5795	17.7684	19.5791	18.3090
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	17.5795	17.7684	19.5791	18.3090
M _d MW of sample gas, dry (lb/lb-mole)	30.0680	30.0268	30.1580	30.0843
M _s MW of sample gas, wet (lb/lb-mole)	27.9465	27.8898	27.7776	27.8713

Comments:

Average includes 3 runs.

042010 112955
 KOH@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

USEPA Method 26A HCl Parameters

Run No.	1	2	3	Average
Date (2010) _____	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	07:55	09:30	10:55	
Stop Time (approx.)	08:55	10:30	12:06	
Process Conditions				
R _P Steam Production Rate (Klbs/hour)	185.2	183.2	185.3	184.6
P ₁ Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.1400	8.7100	7.5900	8.1467
CO ₂ Carbon dioxide (dry volume %)	10.8900	10.4900	11.5900	10.9900
T _s Sample temperature (°F)	489.9167	494.5833	493.8333	492.7778
B _w Actual water vapor in gas (% by volume)	17.5795	17.7684	19.5791	18.3090
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	34.5960	34.4329	34.0398	34.3562
Laboratory Data				
m _n Total HCl collected (mg)	542.6130	510.8841	606.2813	
Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (lb/dscf)	3.4584E-05	3.2716E-05	3.9273E-05	3.5524E-05
C _{sd7} HCl Concentration @7% O ₂ (lb/dscf)	3.7674E-05	3.7305E-05	4.1014E-05	3.8664E-05
C _{sd12} HCl Concentration @12% CO ₂ (lb/dscf)	3.8109E-05	3.7425E-05	4.0663E-05	3.8732E-05
C _{sd} HCl Concentration (ppmdv)	365.6412	345.8914	415.2198	375.5841
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	398.3082	394.4126	433.6255	408.7821
C _{sd12} HCl Concentration @12% CO ₂ (ppmdv)	402.9104	395.6812	429.9083	409.5000
C _w HCl Concentration (ppmwv)	301.3631	284.4319	333.9233	306.5728
C _{sd} HCl Concentration (mg/dscm)	553.8121	523.8984	628.9055	568.8720
C _{sd7} HCl Concentration @7% O ₂ (mg/dscm)	603.2906	597.3903	656.7834	619.1548
C _{sd12} HCl Concentration @12% CO ₂ (mg/dscm)	610.2613	599.3118	651.1532	620.2421
C _{sd} HCl Concentration (mg/Nm ³ dry)	594.3349	562.2324	674.9230	610.4968
C _{sd7} HCl Concentration @7% O ₂ (mg/Nm ³ dry)	647.4338	641.1018	704.8407	664.4588
C _{sd12} HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	654.9145	643.1639	698.7986	665.6257
E _{Fd} HCl Rate - Fd-based (lb/MMBtu)	0.5421	0.5368	0.5902	0.5564
E _{Fc} HCl Rate - Fc-based (lb/MMBtu)	0.5780	0.5676	0.6167	0.5874

042010 112955
 KOH@_@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:47	11:43	14:24	
Stop Time (approx.)	11:05	13:57	16:39	
Sampling Conditions				
Y _d Dry gas meter correction factor	1.0085	1.0085	1.0085	
C _p Pitot tube coefficient	0.8050	0.8050	0.8050	
P _g Static pressure (in. H ₂ O)	-10.3000	-10.0000	-10.1000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n Nozzle diameter (in.)	0.2700	0.2700	0.2700	
O ₂ Oxygen (dry volume %)	10.0200	9.7000	9.5000	9.7400
CO ₂ Carbon dioxide (dry volume %)	9.4200	9.7800	9.9800	9.7267
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.5600	80.5200	80.5200	80.5333
V _{lc} Total Liquid collected (ml)	441.20	399.40	408.30	
V _m Volume metered, meter conditions (ft ³)	77.9900	72.4500	75.0500	
T _m Dry gas meter temperature (°F)	79.2600	79.5000	85.2800	
T _s Sample temperature (°F)	296.5600	295.6800	295.2800	295.8400
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.2684	1.0928	1.1404	
θ Total sampling time (min)	125.0	125.0	125.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	20.7629	18.7958	19.2146	19.5911
V _{mstd} Volume metered, standard (dscf)	77.6829	72.1017	73.9061	74.5636
P _s Sample gas pressure, absolute (in. Hg)	29.3426	29.3647	29.3574	29.3549
P _v Vapor pressure, actual (in. Hg)	29.3426	29.3647	29.3574	29.3549
B _{wo} Moisture measured in sample (% by volume)	21.0907	20.6780	20.6341	20.8009
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	21.0907	20.6780	20.6341	20.8009
√ΔP Velocity head (√in. H ₂ O)	0.7213	0.6667	0.6791	0.6890
M _d MW of sample gas, dry (lb/lb-mole)	29.9080	29.9528	29.9768	29.9459
M _s MW of sample gas, wet (lb/lb-mole)	27.3965	27.4812	27.5055	27.4611
V _s Velocity of sample (ft/sec)	48.1582	44.3982	45.2011	45.9192
%I Isokinetic sampling (%)	100.2162	100.1764	100.7755	100.3894
Q _a Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _s Volumetric flow rate, standard (scfm)	126,570	116,911	119,059	120,847
Q _{std} Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,176	74,723	77,497	76,799
Q _a Volumetric flow rate, actual (acf/hr)	11,095,639	10,229,354	10,414,338	10,579,777
Q _s Volumetric flow rate, standard (scf/hr)	7,594,174	7,014,687	7,143,530	7,250,797
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,992,512	5,564,191	5,669,529	5,742,077
Q _a Volumetric flow rate, actual (m ³ /hr)	314,235	289,701	294,940	299,626
Q _s Volumetric flow rate, standard (m ³ /hr)	215,071	198,660	202,309	205,347
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	169,711	157,581	160,564	162,619
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,839	126,972	131,686	130,499
Q _s Volumetric flow rate, normal (Nm ³ /hr)	200,408	185,115	188,515	191,346
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	158,140	146,837	149,617	151,531
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,782	118,315	122,707	121,601

Comments:

Average includes 3 runs.

042010 113035
 I P J @

**USEPA Method 5/29
 Filterable Particulate Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:47	11:43	14:24	
Stop Time (approx.)	11:05	13:57	16:39	
Process Conditions				
R _p	184.1	184.0	184.2	184.1
P ₁	315	315	315	315
F _d	9,570	9,570	9,570	9,570
F _c	1,820	1,820	1,820	1,820
Cap	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂	10.0200	9.7000	9.5000	9.7400
CO ₂	9.4200	9.7800	9.9800	9.7267
T _s	296.5600	295.6800	295.2800	295.8400
B _w	21.0907	20.6780	20.6341	20.8009
Gas Flow Rate				
Q _a	184,927	170,489	173,572	176,330
Q _s	126,570	116,911	119,059	120,847
Q _{std}	99,875	92,737	94,492	95,701
Q _{std7}	78,176	74,723	77,497	76,799
Q _a	11,095,639	10,229,354	10,414,338	10,579,777
Q _s	7,594,174	7,014,687	7,143,530	7,250,797
Q _{std}	5,992,512	5,564,191	5,669,529	5,742,077
Q _a	314,235	289,701	294,940	299,626
Q _s	215,071	198,660	202,309	205,347
Q _{std}	169,711	157,581	160,564	162,619
Q _{std7}	132,839	126,972	131,686	130,499
Q _e	200,408	185,115	188,515	191,346
Q _{std}	158,140	146,837	149,617	151,531
Q _{std7}	123,782	118,315	122,707	121,601
Sampling Data				
V _{metd}	77.6829	72.1017	73.9061	74.5636
%I	100.2162	100.1764	100.7755	100.3894
Laboratory Data				
m _{filter}	0.00290	0.00110	0.00160	
m _s	0.00100	0.00230	0.00170	
m _n	0.00390	0.00340	0.00330	
Filterable Particulate Results				
C _{sd}	1.1070E-07	1.0398E-07	9.8456E-08	1.0438E-07
C _{sd7}	1.4143E-07	1.2904E-07	1.2005E-07	1.3017E-07
C _{sd12}	1.4102E-07	1.2758E-07	1.1838E-07	1.2899E-07
C _a	5.9787E-08	5.6558E-08	5.3599E-08	5.6648E-08
C _{sd}	0.0008	0.0007	0.0007	0.0007
C _{sd7}	0.0010	0.0009	0.0008	0.0009
C _{sd12}	0.0010	0.0009	0.0008	0.0009
C _a	0.0004	0.0004	0.0004	0.0004
C _{sd}	1.7727	1.6651	1.5766	1.6715
C _{sd7}	2.2648	2.0665	1.9224	2.0845
C _{sd12}	2.2582	2.0430	1.8958	2.0657
C _a	0.9574	0.9057	0.8583	0.9071
C _{sd}	1.9024	1.7869	1.6920	1.7938
C _{sd7}	2.4305	2.2177	2.0631	2.2371
C _{sd12}	2.4235	2.1925	2.0345	2.2168
E _{lb/hr}	0.6634	0.5786	0.5582	0.6000
E _{kg/hr}	0.3008	0.2624	0.2532	0.2721
E _{T/yr}	2.9056	2.5341	2.4449	2.6282
E _{Fd}	0.0020	0.0019	0.0017	0.0019
E _{Fc}	0.0021	0.0019	0.0018	0.0020

Comments:

Average includes 3 runs.

042010 113052
 I P J @ _ P

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:47	11:43	14:24	
Stop Time (approx.)		11:05	13:57	16:39	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.1	184.0	184.2	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	10.0200	9.7000	9.5000	9.7400
CO ₂	Carbon dioxide (dry volume %)	9.4200	9.7800	9.9800	9.7267
T _s	Sample temperature (°F)	296.5600	295.6800	295.2800	295.8400
B _w	Actual water vapor in gas (% by volume)	21.0907	20.6780	20.6341	20.8009
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _s	Volumetric flow rate, standard (scfm)	126,570	116,911	119,059	120,847
Q _{std}	Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,176	74,723	77,497	76,799
Q _a	Volumetric flow rate, actual (acf/hr)	11,095,639	10,229,354	10,414,338	10,579,777
Q _s	Volumetric flow rate, standard (scf/hr)	7,594,174	7,014,687	7,143,530	7,250,797
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,992,512	5,564,191	5,669,529	5,742,077
Q _a	Volumetric flow rate, actual (m ³ /hr)	314,235	289,701	294,940	299,626
Q _s	Volumetric flow rate, standard (m ³ /hr)	215,071	198,660	202,309	205,347
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	169,711	157,581	160,564	162,619
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,839	126,972	131,686	130,499
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	200,408	185,115	188,515	191,346
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	158,140	146,837	149,617	151,531
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,782	118,315	122,707	121,601
Sampling Data					
V _{std}	Volume metered, standard (dscf)	77.6829	72.1017	73.9061	74.5636
%I	Isokinetic sampling (%)	100.2162	100.1764	100.7755	100.3894
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m _{n-2b}	Fraction 2B (µg)	3.6560	3.5329	3.2883	
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m _n	Total matter corrected for allowable blanks (µg)	3.6560	3.5329	3.2883	
Mercury Results - Total					
C _{sd}	Concentration (lb/dscf)	1.0377E-10	1.0804E-10	9.8106E-11	1.0331E-10
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	1.3258E-10	1.3409E-10	1.1962E-10	1.2878E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	1.3220E-10	1.3257E-10	1.1796E-10	1.2758E-10
C _a	Concentration (lb/acf)	5.6046E-11	5.8770E-11	5.3408E-11	5.6075E-11
C _{sd}	Concentration (µg/dscm)	1.6618E+00	1.7302E+00	1.5710E+00	1.6543E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	2.1231E+00	2.1473E+00	1.9156E+00	2.0620E+00
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	2.1169E+00	2.1229E+00	1.8890E+00	2.0430E+00
C _{sd}	Concentration (mg/dscm)	1.6618E-03	1.7302E-03	1.5710E-03	1.6543E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	2.1231E-03	2.1473E-03	1.9156E-03	2.0620E-03
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	2.1169E-03	2.1229E-03	1.8890E-03	2.0430E-03
C _a	Concentration (µg/m ³ (actual,wet))	8.9750E-01	9.4112E-01	8.5526E-01	8.9796E-01
C _{sd}	Concentration (µg/Nm ³ dry)	1.7834E+00	1.8568E+00	1.6860E+00	1.7754E+00
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	2.2784E+00	2.3044E+00	2.0557E+00	2.2128E+00
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	2.2718E+00	2.2782E+00	2.0272E+00	2.1924E+00
E _{lb/hr}	Rate (lb/hr)	6.2186E-04	6.0118E-04	5.5621E-04	5.9308E-04
E _{g/s}	Rate (g/s)	7.8340E-05	7.5734E-05	7.0070E-05	7.4715E-05
E _{ton/yr}	Rate (Ton/yr)	2.7238E-03	2.6332E-03	2.4362E-03	2.5977E-03
E _{Fd}	Rate - Fd-based (lb/MMBtu)	1.9077E-06	1.9295E-06	1.7213E-06	1.8528E-06
E _{Fc}	Rate - Fc-based (lb/MMBtu)	2.0050E-06	2.0106E-06	1.7891E-06	1.9349E-06

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Emission Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:47	11:43	14:24	
Stop Time (approx.)	11:05	13:57	16:39	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.1	184.0	184.2	184.1
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂ Carbon Feed Rate (lb/hr)	7	6	6	6
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	10.0200	9.7000	9.5000	9.7400
CO ₂ Carbon dioxide (dry volume %)	9.4200	9.7800	9.9800	9.7267
T _s Sample temperature (°F)	296.5600	295.6800	295.2800	295.8400
B _w Actual water vapor in gas (% by volume)	21.0907	20.6780	20.6341	20.8009
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _s Volumetric flow rate, standard (scfm)	126,570	116,911	119,059	120,847
Q _{std} Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,176	74,723	77,497	76,799
Q _a Volumetric flow rate, actual (acf/hr)	11,095,639	10,229,354	10,414,338	10,579,777
Q _s Volumetric flow rate, standard (scf/hr)	7,594,174	7,014,687	7,143,530	7,250,797
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,992,512	5,564,191	5,669,529	5,742,077
Q _a Volumetric flow rate, actual (m ³ /hr)	314,235	289,701	294,940	299,626
Q _s Volumetric flow rate, standard (m ³ /hr)	215,071	198,660	202,309	205,347
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	169,711	157,581	160,564	162,619
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,839	126,972	131,686	130,499
Q _s Volumetric flow rate, normal (Nm ³ /hr)	200,408	185,115	188,515	191,346
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	158,140	146,837	149,617	151,531
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,782	118,315	122,707	121,601
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	77.6829	72.1017	73.9061	74.5636
%I Isokinetic sampling (%)	100.2162	100.1764	100.7755	100.3894
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{std} Concentration (lb/dscf)	<1.4192E-12	<1.5291E-12	<1.4918E-12	<1.4800E-12
C _{std7} Concentration @7% O ₂ (lb/dscf)	<1.8132E-12	<1.8977E-12	<1.8189E-12	<1.8433E-12
C _{std12} Concentration @12% CO ₂ (lb/dscf)	<1.8079E-12	<1.8762E-12	<1.7937E-12	<1.8259E-12
C _a Concentration (lb/acf)	<7.6650E-13	<8.3174E-13	<8.1211E-13	<8.0345E-13
C _{std} Concentration (µg/dscm)	<2.2727E-02	<2.4486E-02	<2.3888E-02	<2.3701E-02
C _{std7} Concentration @7% O ₂ (µg/dscm)	<2.9035E-02	<3.0389E-02	<2.9127E-02	<2.9517E-02
C _{std12} Concentration @12% CO ₂ (µg/dscm)	<2.8952E-02	<3.0044E-02	<2.8724E-02	<2.9240E-02
C _{sd} Concentration (mg/dscm)	<2.2727E-05	<2.4486E-05	<2.3888E-05	<2.3701E-05
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<2.9035E-05	<3.0389E-05	<2.9127E-05	<2.9517E-05
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	<2.8952E-05	<3.0044E-05	<2.8724E-05	<2.9240E-05
C _a Concentration (µg/m ³ (actual, wet))	<1.2274E-02	<1.3319E-02	<1.3005E-02	<1.2866E-02
C _{sd} Concentration (µg/Nm ³ dry)	<2.4390E-02	<2.6278E-02	<2.5636E-02	<2.5435E-02
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	<3.1160E-02	<3.2613E-02	<3.1258E-02	<3.1677E-02
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	<3.1070E-02	<3.2243E-02	<3.0825E-02	<3.1378E-02
E _{lb/hr} Rate (lb/hr)	<8.5048E-06	<8.5081E-06	<8.4576E-06	<8.4902E-06
E _{g/s} Rate (g/s)	<1.0714E-06	<1.0718E-06	<1.0655E-06	<1.0696E-06
E _{T/yr} Rate (Ton/yr)	<3.7251E-05	<3.7266E-05	<3.7044E-05	<3.7187E-05
E _{Fd} Rate - Fd-based (lb/MMBtu)	<2.6091E-08	<2.7307E-08	<2.6173E-08	<2.6523E-08
E _{Fc} Rate - Fc-based (lb/MMBtu)	<2.7420E-08	<2.8455E-08	<2.7204E-08	<2.7693E-08

042010 113052
 I P J @ _ O

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Emission Parameters**

Run No.	1	2	3	Average	
Date (2010)	Mar 22	Mar 22	Mar 22		
Start Time (approx.)	08:47	11:43	14:24		
Stop Time (approx.)	11:05	13:57	16:39		
Process Conditions					
R _p	Steam Production Rate (Kibs/hour)	184.1	184.0	184.2	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	10.0200	9.7000	9.5000	9.7400
CO ₂	Carbon dioxide (dry volume %)	9.4200	9.7800	9.9800	9.7267
T _s	Sample temperature (°F)	296.5600	295.6800	295.2800	295.8400
B _w	Actual water vapor in gas (% by volume)	21.0907	20.6780	20.6341	20.8009
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _s	Volumetric flow rate, standard (scfm)	126,570	116,911	119,059	120,847
Q _{std}	Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,176	74,723	77,497	76,799
Q _a	Volumetric flow rate, actual (acf/hr)	11,095,639	10,229,354	10,414,338	10,579,777
Q _s	Volumetric flow rate, standard (scf/hr)	7,594,174	7,014,687	7,143,530	7,250,797
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,992,512	5,564,191	5,669,529	5,742,077
Q _a	Volumetric flow rate, actual (m ³ /hr)	314,235	289,701	294,940	299,626
Q _s	Volumetric flow rate, standard (m ³ /hr)	215,071	198,660	202,309	205,347
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	169,711	157,581	160,564	162,619
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,839	126,972	131,686	130,499
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	200,408	185,115	188,515	191,346
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	158,140	146,837	149,617	151,531
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,782	118,315	122,707	121,601
Sampling Data					
V _{std}	Volume metered, standard (dscf)	77.6829	72.1017	73.9061	74.5636
%I	Isokinetic sampling (%)	100.2162	100.1764	100.7755	100.3894
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	0.7733	0.7704	0.7331	
Cadmium Results - Total					
C _{std}	Concentration (lb/dscf)	2.1951E-11	2.3560E-11	2.1873E-11	2.2461E-11
C _{std7}	Concentration @7% O ₂ (lb/dscf)	2.8044E-11	2.9239E-11	2.6669E-11	2.7984E-11
C _{std12}	Concentration @12% CO ₂ (lb/dscf)	2.7963E-11	2.8908E-11	2.6300E-11	2.7723E-11
C _a	Concentration (lb/acf)	1.1855E-11	1.2815E-11	1.1907E-11	1.2193E-11
C _{std}	Concentration (µg/dscm)	3.5152E-01	3.7728E-01	3.5026E-01	3.5968E-01
C _{std7}	Concentration @7% O ₂ (µg/dscm)	4.4909E-01	4.6823E-01	4.2707E-01	4.4813E-01
C _{std12}	Concentration @12% CO ₂ (µg/dscm)	4.4779E-01	4.6291E-01	4.2115E-01	4.4395E-01
C _{std}	Concentration (mg/dscm)	3.5152E-04	3.7728E-04	3.5026E-04	3.5968E-04
C _{std7}	Concentration @7% O ₂ (mg/dscm)	4.4909E-04	4.6823E-04	4.2707E-04	4.4813E-04
C _{std12}	Concentration @12% CO ₂ (mg/dscm)	4.4779E-04	4.6291E-04	4.2115E-04	4.4395E-04
C _a	Concentration (µg/m ³ (actual,wet))	1.8985E-01	2.0522E-01	1.9068E-01	1.9525E-01
C _{std}	Concentration (µg/Nm ³ dry)	3.7724E-01	4.0488E-01	3.7589E-01	3.8600E-01
C _{std7}	Concentration @7% O ₂ (µg/Nm ³ dry)	4.8195E-01	5.0249E-01	4.5832E-01	4.8092E-01
C _{std12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	4.8056E-01	4.9679E-01	4.5197E-01	4.7644E-01
E _{lb/hr}	Rate (lb/hr)	1.3154E-04	1.3109E-04	1.2401E-04	1.2888E-04
E _{g/s}	Rate (g/s)	1.6571E-05	1.6514E-05	1.5622E-05	1.6236E-05
E _{T/yr}	Rate (Ton/yr)	5.7615E-04	5.7418E-04	5.4315E-04	5.6449E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	4.0354E-07	4.2074E-07	3.8375E-07	4.0268E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	4.2411E-07	4.3843E-07	3.9888E-07	4.2047E-07

042010 113052
 I P J @ _ O

**USEPA Method 5/29
 Lead (Pb) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:47	11:43	14:24	
Stop Time (approx.)		11:05	13:57	16:39	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.1	184.0	184.2	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Carbon Feed Rate (lb/hr)	7	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	10.0200	9.7000	9.5000	9.7400
CO ₂	Carbon dioxide (dry volume %)	9.4200	9.7800	9.9800	9.7267
T _s	Sample temperature (°F)	296.5600	295.6800	295.2800	295.8400
B _w	Actual water vapor in gas (% by volume)	21.0907	20.6780	20.6341	20.8009
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	184,927	170,489	173,572	176,330
Q _s	Volumetric flow rate, standard (scfm)	126,570	116,911	119,059	120,847
Q _{std}	Volumetric flow rate, dry standard (dscfm)	99,875	92,737	94,492	95,701
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	78,176	74,723	77,497	76,799
Q _a	Volumetric flow rate, actual (acf/hr)	11,095,639	10,229,354	10,414,338	10,579,777
Q _s	Volumetric flow rate, standard (scf/hr)	7,594,174	7,014,687	7,143,530	7,250,797
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,992,512	5,564,191	5,669,529	5,742,077
Q _a	Volumetric flow rate, actual (m ³ /hr)	314,235	289,701	294,940	299,626
Q _s	Volumetric flow rate, standard (m ³ /hr)	215,071	198,660	202,309	205,347
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	169,711	157,581	160,564	162,619
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	132,839	126,972	131,686	130,499
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	200,408	185,115	188,515	191,346
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	158,140	146,837	149,617	151,531
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	123,782	118,315	122,707	121,601
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	77.6829	72.1017	73.9061	74.5636
%I	Isokinetic sampling (%)	100.2162	100.1764	100.7755	100.3894
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	6.8716	5.5360	5.9671	
Lead Results - Total					
C _{sd}	Concentration (lb/dscf)	1.9505E-10	1.6930E-10	1.7803E-10	1.8079E-10
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	2.4919E-10	2.1012E-10	2.1707E-10	2.2546E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	2.4847E-10	2.0773E-10	2.1406E-10	2.2342E-10
C _a	Concentration (lb/acf)	1.0534E-10	9.2091E-11	9.6918E-11	9.8117E-11
C _{sd}	Concentration (µg/dscfm)	3.1234E+00	2.7111E+00	2.8509E+00	2.8951E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscfm)	3.9904E+00	3.3647E+00	3.4761E+00	3.6104E+00
C _{sd12}	Concentration @12% CO ₂ (µg/dscfm)	3.9789E+00	3.3265E+00	3.4279E+00	3.5778E+00
C _{sd}	Concentration (mg/dscm)	3.1234E-03	2.7111E-03	2.8509E-03	2.8951E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	3.9904E-03	3.3647E-03	3.4761E-03	3.6104E-03
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	3.9789E-03	3.3265E-03	3.4279E-03	3.5778E-03
C _a	Concentration (µg/m ³ (actual,wet))	1.6869E+00	1.4747E+00	1.5520E+00	1.5712E+00
C _{sd}	Concentration (µg/Nm ³ dry)	3.3520E+00	2.9095E+00	3.0595E+00	3.1070E+00
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	4.2824E+00	3.6109E+00	3.7304E+00	3.8746E+00
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	4.2700E+00	3.5699E+00	3.6787E+00	3.8396E+00
E _{h/hr}	Rate (lb/hr)	1.1688E-03	9.4203E-04	1.0093E-03	1.0401E-03
E _{g/s}	Rate (g/s)	1.4724E-04	1.1867E-04	1.2715E-04	1.3102E-04
E _{t/yr}	Rate (Ton/yr)	5.1195E-03	4.1261E-03	4.4209E-03	4.5555E-03
E _{fd}	Rate - Fd-based (lb/MMBtu)	3.5857E-06	3.0234E-06	3.1235E-06	3.2442E-06
E _{fc}	Rate - Fc-based (lb/MMBtu)	3.7684E-06	3.1506E-06	3.2466E-06	3.3886E-06

042010 113052
 IPJ @_O

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 SDA Inlet

**USEPA Method 29 (Trace Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 22	Mar 22	Mar 22	
Start Time (approx.)	08:47	11:43	14:27	
Stop Time (approx.)	11:05	13:57	16:39	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9900	0.9900	0.9900	
C _p Pitot tube coefficient	0.8250	0.8250	0.8250	
P _g Static pressure (in. H ₂ O)	-1.3000	-1.3000	-1.3000	
A _s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n Nozzle diameter (in.)	0.2700	0.2700	0.2700	
O ₂ Oxygen (dry volume %)	9.1900	8.1900	8.1400	8.5067
CO ₂ Carbon dioxide (dry volume %)	10.4700	11.1000	11.1900	10.9200
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.3400	80.7100	80.6700	80.5733
V _{lc} Total Liquid collected (ml)	318.60	308.00	297.10	
V _m Volume metered, meter conditions (ft ³)	67.9800	65.7850	66.6100	
T _m Dry gas meter temperature (°F)	70.1250	72.6458	80.5000	
T _s Sample temperature (°F)	473.2083	469.0833	471.1667	471.1528
ΔH Meter box orifice pressure drop (in. H ₂ O)	0.9754	0.9167	0.9196	
θ Total sampling time (min)	120.0	120.0	120.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	14.9933	14.4945	13.9815	14.4898
V _{mstd} Volume metered, standard (dscf)	67.5673	65.0669	64.9260	65.8534
P _s Sample gas pressure, absolute (in. Hg)	30.0044	30.0044	30.0044	30.0044
P _v Vapor pressure, actual (in. Hg)	30.0044	30.0044	30.0044	30.0044
B _{wc} Moisture measured in sample (% by volume)	18.1604	18.2180	17.7189	18.0324
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	18.1604	18.2180	17.7189	18.0324
√ΔP Velocity head (√in. H ₂ O)	0.6765	0.6528	0.6525	0.6606
M _d MW of sample gas, dry (lb/lb-mole)	30.0428	30.1036	30.1160	30.0875
M _w MW of sample gas, wet (lb/lb-mole)	27.8558	27.8986	27.9692	27.9078
V _a Velocity of sample (ft/sec)	50.4133	48.5065	48.4754	49.1317
%I Isokinetic sampling (%)	100.8827	100.5929	100.0541	100.5099
Q _a Volumetric flow rate, actual (acfm)	181,887	175,008	174,895	177,264
Q _s Volumetric flow rate, standard (scfm)	103,200	99,738	99,451	100,796
Q _{std} Volumetric flow rate, dry standard (dscfm)	84,459	81,568	81,829	82,619
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	71,152	74,585	75,118	73,618
Q _a Volumetric flow rate, actual (acf/hr)	10,913,243	10,500,470	10,493,727	10,635,813
Q _s Volumetric flow rate, standard (scf/hr)	6,192,025	5,984,275	5,967,051	6,047,784
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,067,530	4,894,060	4,909,757	4,957,116
Q _a Volumetric flow rate, actual (m ³ /hr)	309,069	297,379	297,189	301,212
Q _s Volumetric flow rate, standard (m ³ /hr)	175,362	169,478	168,990	171,277
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	143,515	138,603	139,047	140,388
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	120,904	126,737	127,643	125,095
Q _s Volumetric flow rate, normal (Nm ³ /hr)	163,405	157,923	157,468	159,599
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	133,730	129,152	129,567	130,816
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	112,661	118,096	118,940	116,565

Comments:

Average includes 3 runs.

042010 113220
 N O Q @

**USEPA Method 29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 22	Mar 22	Mar 22	
Start Time (approx.)		08:47	11:43	14:27	
Stop Time (approx.)		11:05	13:57	16:39	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.1	184.0	184.2	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P ₂	Coal Feed Rate (lb/hr)	7	6	6	6
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.1900	8.1900	8.1400	8.5067
CO ₂	Carbon dioxide (dry volume %)	10.4700	11.1000	11.1900	10.9200
T _s	Sample temperature (°F)	473.2083	469.0833	471.1667	471.1528
B _w	Actual water vapor in gas (% by volume)	18.1604	18.2180	17.7189	18.0324
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	181,887	175,008	174,895	177,264
Q _s	Volumetric flow rate, standard (scfm)	103,200	99,738	99,451	100,796
Q _{std}	Volumetric flow rate, dry standard (dscfm)	84,459	81,568	81,829	82,619
Q _{std7}	Volumetric flow rate, dry std@7% O ₂ (dscfm)	71,152	74,585	75,118	73,618
Q _a	Volumetric flow rate, actual (acf/hr)	10,913,243	10,500,470	10,493,727	10,635,813
Q _s	Volumetric flow rate, standard (scf/hr)	6,192,025	5,984,275	5,967,051	6,047,784
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,067,530	4,894,060	4,909,757	4,957,116
Q _a	Volumetric flow rate, actual (m ³ /hr)	309,069	297,379	297,189	301,212
Q _s	Volumetric flow rate, standard (m ³ /hr)	175,362	169,478	168,990	171,277
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	143,515	138,603	139,047	140,388
Q _{std7}	Volumetric flow rate, dry std@7% O ₂ (dry m ³ /hr)	120,904	126,737	127,643	125,095
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	163,405	157,923	157,468	159,599
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	133,730	129,152	129,567	130,816
Q _{std7}	Volumetric flow rate, dry normal @7% O ₂ (Nm ³ /hr)	112,661	118,096	118,940	116,565
Sampling Data					
V _{std}	Volume metered, standard (dscf)	67.5673	65.0669	64.9260	65.8534
%I	Isokinetic sampling (%)	100.8827	100.5929	100.0541	100.5099
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	46.7982	94.5017	74.2463	
m _{n-2b}	Fraction 2B (µg)	21.1531	22.0588	25.4675	
m _{n-3a}	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c}	Fraction 3C (µg)	1.8293	1.7245	0.9416	
m _n	Total matter corrected for allowable blanks (µg)	69.7807	118.2850	100.6553	
Mercury Results - Total					
C _{sd}	Concentration (lb/dscf)	2.2772E-09	4.0085E-09	3.4184E-09	3.2347E-09
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	2.7031E-09	4.3838E-09	3.7238E-09	3.6036E-09
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	2.6100E-09	4.3335E-09	3.6659E-09	3.5365E-09
C _a	Concentration (lb/acf)	1.0574E-09	1.8683E-09	1.5994E-09	1.5084E-09
C _{sd}	Concentration (µg/dscm)	3.6467E+01	6.4190E+01	5.4741E+01	5.1799E+01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	4.3287E+01	7.0200E+01	5.9632E+01	5.7706E+01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	4.1796E+01	6.9395E+01	5.8704E+01	5.6631E+01
C _{sd}	Concentration (mg/dscm)	3.6467E-02	6.4190E-02	5.4741E-02	5.1799E-02
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	4.3287E-02	7.0200E-02	5.9632E-02	5.7706E-02
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	4.1796E-02	6.9395E-02	5.8704E-02	5.6631E-02
C _a	Concentration (µg/m ³ (actual, wet))	1.6933E+01	2.9918E+01	2.5612E+01	2.4154E+01
C _{sd}	Concentration (µg/Nm ³ dry)	3.9135E+01	6.8887E+01	5.8747E+01	5.5590E+01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	4.6454E+01	7.5337E+01	6.3995E+01	6.1929E+01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	4.4854E+01	7.4472E+01	6.2999E+01	6.0775E+01
E _{lb/hr}	Rate (lb/hr)	1.1540E-02	1.9618E-02	1.6784E-02	1.5980E-02
E _{g/s}	Rate (g/s)	1.4538E-03	2.4714E-03	2.1143E-03	2.0132E-03
E _{T/yr}	Rate (Ton/yr)	5.0545E-02	8.5925E-02	7.3512E-02	8.9994E-02
E _{Fd}	Rate - Fd-based (lb/MMBtu)	3.8896E-05	6.3080E-05	5.3584E-05	5.1853E-05
E _{Fc}	Rate - Fc-based (lb/MMBtu)	3.9585E-05	6.5724E-05	5.5599E-05	5.3636E-05

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 13B (Total Fluorides)
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	Average
Date (2010)		Mar 23	Mar 23	Mar 23	
Start Time (approx.)		12:41	14:31	15:54	
Stop Time (approx.)		13:54	15:39	17:02	
Sampling Conditions					
Y _d	Dry gas meter correction factor	1.0085	1.0085	1.0085	
C _p	Pitot tube coefficient	0.8120	0.8120	0.8120	
P _g	Static pressure (in. H ₂ O)	-10.2000	-10.2000	-10.2000	
A _s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar}	Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
D _n	Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O ₂	Oxygen (dry volume %)	9.7500	9.9300	9.4000	9.6933
CO ₂	Carbon dioxide (dry volume %)	9.5800	9.6200	10.1900	9.7967
N ₂ +CO	Nitrogen plus carbon monoxide (dry volume %)	80.6700	80.4500	80.4100	80.5100
V _{lc}	Total Liquid collected (ml)	217.50	217.00	209.70	
V _m	Volume metered, meter conditions (ft ³)	36.2600	37.8500	35.9900	
T _m	Dry gas meter temperature (°F)	86.0600	86.6800	85.5600	
T _s	Sample temperature (°F)	296.7600	296.3600	296.4000	296.5067
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.1160	1.1812	1.0072	
θ	Total sampling time (min)	62.5	62.5	62.5	
Flow Results					
V _{wstd}	Volume of water collected (ft ³)	10.2356	10.2120	9.8685	10.1054
V _{mstd}	Volume metered, standard (dscf)	35.6542	37.1813	35.4118	36.0824
P _a	Sample gas pressure, absolute (in. Hg)	29.3500	29.3500	29.3500	29.3500
P _v	Vapor pressure, actual (in. Hg)	29.3500	29.3500	29.3500	29.3500
B _{wo}	Moisture measured in sample (% by volume)	22.3047	21.5474	21.7942	21.8821
B _{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w	Actual water vapor in gas (% by volume)	22.3047	21.5474	21.7942	21.8821
√ΔP	Velocity head (√in. H ₂ O)	0.6718	0.6925	0.6423	0.6689
M _d	MW of sample gas, dry (lb/lb-mole)	29.9228	29.9364	30.0064	29.9552
M _w	MW of sample gas, wet (lb/lb-mole)	27.2635	27.3644	27.3897	27.3392
V _s	Velocity of sample (ft/sec)	45.3498	46.6506	43.2527	45.0844
%I	Isokinetic sampling (%)	100.7037	101.0498	104.1344	101.9626
Q _a	Volumetric flow rate, actual (acfm)	174,143	179,138	166,090	173,124
Q _s	Volumetric flow rate, standard (scfm)	119,187	122,671	113,729	118,529
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,603	96,238	88,943	92,595
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	74,282	75,952	73,586	74,607
Q _a	Volumetric flow rate, actual (acf/hr)	10,448,592	10,748,298	9,965,413	10,387,434
Q _s	Volumetric flow rate, standard (scf/hr)	7,151,219	7,360,233	6,823,767	7,111,740
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,556,164	5,774,297	5,336,580	5,555,680
Q _a	Volumetric flow rate, actual (m ³ /hr)	295,910	304,398	282,226	294,178
Q _s	Volumetric flow rate, standard (m ³ /hr)	202,527	208,446	193,253	201,409
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,354	163,531	151,135	157,340
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	126,223	129,060	125,040	126,774
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	188,718	194,234	180,077	187,676
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,625	152,382	140,830	146,612
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	117,617	120,261	116,514	118,131

Comments:

Average includes 3 runs.

042010 113253
 R K L @

**USEPA Method 13B
 HF Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 23	Mar 23	Mar 23	
Start Time (approx.)	12:41	14:31	15:54	
Stop Time (approx.)	13:54	15:39	17:02	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	183.8	184.4	183.9	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.7500	9.9300	9.4000	9.6933
CO ₂ Carbon dioxide (dry volume %)	9.5800	9.6200	10.1900	9.7967
T _s Sample temperature (°F)	296.7600	296.3600	296.4000	296.5067
B _w Actual water vapor in gas (% by volume)	22.3047	21.5474	21.7942	21.8821
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	174,143	179,138	166,090	173,124
Q _s Volumetric flow rate, standard (scfm)	119,187	122,671	113,729	118,529
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,603	96,238	88,943	92,595
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	74,282	75,952	73,586	74,607
Q _a Volumetric flow rate, actual (acf/hr)	10,448,592	10,748,298	9,965,413	10,387,434
Q _s Volumetric flow rate, standard (scf/hr)	7,151,219	7,360,233	6,823,767	7,111,740
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,556,164	5,774,297	5,336,580	5,555,680
Q _a Volumetric flow rate, actual (m ³ /hr)	295,910	304,398	282,226	294,178
Q _s Volumetric flow rate, standard (m ³ /hr)	202,527	208,446	193,253	201,409
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,354	163,531	151,135	157,340
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	126,223	129,060	125,040	126,774
Q _s Volumetric flow rate, normal (Nm ³ /hr)	188,718	194,234	180,077	187,676
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,625	152,382	140,830	146,812
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	117,617	120,261	116,514	118,131
Sampling Data				
V _{std} Volume metered, standard (dscf)	35.6542	37.1813	35.4118	36.0824
%I Isokinetic sampling (%)	100.7037	101.0498	104.1344	101.9626
Laboratory Data				
m _n Total HF collected (mg)	<0.0397	<0.0398	<0.0378	
Hydrogen Fluoride (HF) Results				
C _{sd} HF Concentration (lb/dscf)	<2.4564E-09	<2.3630E-09	<2.3526E-09	<2.3907E-09
C _{sd7} HF Concentration @7% O ₂ (lb/dscf)	<3.0622E-09	<2.9941E-09	<2.8435E-09	<2.9666E-09
C _{sd12} HF Concentration @12% CO ₂ (lb/dscf)	<3.0769E-09	<2.9476E-09	<2.7704E-09	<2.9316E-09
C _a HF Concentration (lb/acf)	<1.3062E-09	<1.2695E-09	<1.2598E-09	<1.2785E-09
C _{sd} HF Concentration (ppmdv)	<0.0473	<0.0455	<0.0453	<0.0461
C _{sd7} HF Concentration @7% O ₂ (ppmdv)	<0.0590	<0.0577	<0.0548	<0.0572
C _{sd12} HF Concentration @12% CO ₂ (ppmdv)	<0.0593	<0.0568	<0.0534	<0.0565
C _w HF Concentration (ppmwv)	<0.0368	<0.0357	<0.0355	<0.0360
C _{sd} HF Concentration (mg/dscm)	<0.0393	<0.0378	<0.0377	<0.0383
C _{sd7} HF Concentration @7% O ₂ (mg/dscm)	<0.0490	<0.0479	<0.0455	<0.0475
C _{sd12} HF Concentration @12% CO ₂ (mg/dscm)	<0.0493	<0.0472	<0.0444	<0.0469
C _a HF Concentration (mg/m ³ (actual,wet))	<0.0209	<0.0203	<0.0202	<0.0205
C _{sd} HF Concentration (mg/Nm ³ dry)	<0.0422	<0.0406	<0.0404	<0.0411
C _{sd7} HF Concentration @7% O ₂ (mg/Nm ³ dry)	<0.0526	<0.0515	<0.0489	<0.0510
C _{sd12} HF Concentration @12% CO ₂ (mg/Nm ³ dry)	<0.0529	<0.0507	<0.0476	<0.0504
E _{lb/hr} HF Rate (lb/hr)	<0.0136	<0.0136	<0.0126	<0.0133
E _{kg/hr} HF Rate (kg/hr)	<0.0062	<0.0062	<0.0057	<0.0060
E _{T/yr} HF Rate (Ton/yr)	<0.0598	<0.0598	<0.0550	<0.0582
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000044	<0.000043	<0.000041	<0.000043
E _{Fc} HF Rate - Fc-based (lb/MMBtu)	<0.000047	<0.000045	<0.000042	<0.000044

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

USEPA Method 26A (HCI) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:45	09:16	10:54	
Stop Time (approx.)	08:45	10:16	11:54	
Sampling Conditions				
Y_d Dry gas meter correction factor	0.9898	0.9898	0.9898	
C_p Pitot tube coefficient	0.8400	0.8400	0.8400	
P_g Static pressure (in. H ₂ O)	-10.0000	-10.0000	-10.0000	
A_s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P_{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
O_2 Oxygen (dry volume %)	9.6100	9.0700	9.0800	9.2533
CO_2 Carbon dioxide (dry volume %)	9.7500	10.2900	10.3000	10.1133
N_2+CO Nitrogen plus carbon monoxide (dry volume %)	80.6400	80.6400	80.6200	80.6333
V_{lc} Total Liquid collected (ml)	236.90	236.80	244.70	
V_m Volume metered, meter conditions (ft ³)	40.2150	41.5700	41.4850	
T_m Dry gas meter temperature (°F)	67.5833	78.3333	87.3750	
T_s Sample temperature (°F)	294.9167	295.5000	295.3333	295.2500
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.5000	1.5000	1.5000	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V_{wstd} Volume of water collected (ft ³)	11.1485	11.1438	11.5156	11.2693
V_{mstd} Volume metered, standard (dscf)	40.2067	40.7314	39.9767	40.3049
P_s Sample gas pressure, absolute (in. Hg)	29.3647	29.3647	29.3647	29.3647
P_v Vapor pressure, actual (in. Hg)	29.3647	29.3647	29.3647	29.3647
B_{wo} Moisture measured in sample (% by volume)	21.7086	21.4819	22.3637	21.8514
B_{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w Actual water vapor in gas (% by volume)	21.7086	21.4819	22.3637	21.8514
M_d MW of sample gas, dry (lb/lb-mole)	29.9444	30.0092	30.0112	29.9883
M_s MW of sample gas, wet (lb/lb-mole)	27.3514	27.4294	27.3251	27.3686

Comments:

Average includes 3 runs.

042010 113310
 Q L K @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

USEPA Method 26A HCl Parameters

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:45	09:16	10:54	
Stop Time (approx.)	08:45	10:16	11:54	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.1	184.2	184.1	184.1
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.6100	9.0700	9.0800	9.2533
CO ₂ Carbon dioxide (dry volume %)	9.7500	10.2900	10.3000	10.1133
T _s Sample temperature (°F)	294.9167	295.5000	295.3333	295.2500
B _w Actual water vapor in gas (% by volume)	21.7086	21.4819	22.3637	21.8514
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	40.2067	40.7314	39.9767	40.3049
Laboratory Data				
m _n Total HCl collected (mg)	30.1359	28.8286	29.3329	
Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (lb/dscf)	1.6527E-06	1.5606E-06	1.6179E-06	1.6104E-06
C _{sd7} HCl Concentration @7% O ₂ (lb/dscf)	2.0348E-06	1.8337E-06	1.9026E-06	1.9237E-06
C _{sd12} HCl Concentration @12% CO ₂ (lb/dscf)	2.0341E-06	1.8200E-06	1.8850E-06	1.9130E-06
C _{sd} HCl Concentration (ppmdv)	17.4733	16.5000	17.1056	17.0263
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	21.5128	19.3872	20.1157	20.3386
C _{sd12} HCl Concentration @12% CO ₂ (ppmdv)	21.5057	19.2420	19.9289	20.2255
C _w HCl Concentration (ppmwv)	13.6801	12.9555	13.2802	13.3053
C _{sd} HCl Concentration (mg/dscm)	26.4657	24.9915	25.9087	25.7886
C _{sd7} HCl Concentration @7% O ₂ (mg/dscm)	32.5840	29.3644	30.4679	30.8055
C _{sd12} HCl Concentration @12% CO ₂ (mg/dscm)	32.5732	29.1446	30.1849	30.6342
C _{sd} HCl Concentration (mg/Nm ³ dry)	28.4022	26.8201	27.8045	27.6756
C _{sd7} HCl Concentration @7% O ₂ (mg/Nm ³ dry)	34.9682	31.5131	32.6973	33.0595
C _{sd12} HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	34.9566	31.2771	32.3936	32.8757
E _{Fd} HCl Rate - Fd-based (lb/MMBtu)	0.0293	0.0264	0.0274	0.0277
E _{Fc} HCl Rate - Fc-based (lb/MMBtu)	0.0309	0.0276	0.0286	0.0290

042010 113310
 Q.L.K.@_@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 SDA Inlet

**USEPA Method 26A (HCI)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:45	09:16	10:54	
Stop Time (approx.)	08:45	10:16	11:54	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9900	0.9900	0.9900	
C _p Pitot tube coefficient	0.8400	0.8400	0.8400	
P _g Static pressure (in. H ₂ O)	-1.1000	-1.1000	-1.2000	
A _s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P _{bar} Barometric pressure (in. Hg)	30.10	30.10	30.10	30.1000
O ₂ Oxygen (dry volume %)	8.9800	8.0700	8.0300	8.3600
CO ₂ Carbon dioxide (dry volume %)	10.3600	11.1600	11.2600	10.9267
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.6600	80.7700	80.7100	80.7133
V _{lc} Total Liquid collected (ml)	166.40	171.40	178.00	
V _m Volume metered, meter conditions (ft ³)	35.9400	36.5250	37.0400	
T _m Dry gas meter temperature (°F)	65.4167	71.5417	75.1667	
T _s Sample temperature (°F)	465.1667	464.1667	468.0000	465.7778
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.2000	1.1917	1.2000	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	7.8308	8.0661	8.3767	8.0912
V _{mstd} Volume metered, standard (dscf)	36.0617	36.2256	36.4883	36.2585
P _s Sample gas pressure, absolute (in. Hg)	30.0191	30.0191	30.0118	30.0167
P _v Vapor pressure, actual (in. Hg)	30.0191	30.0191	30.0118	30.0167
B _{wo} Moisture measured in sample (% by volume)	17.8408	18.2113	18.6709	18.2410
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	17.8408	18.2113	18.6709	18.2410
M _d MW of sample gas, dry (lb/lb-mole)	30.0168	30.1084	30.1228	30.0827
M _s MW of sample gas, wet (lb/lb-mole)	27.8729	27.9033	27.8594	27.8785

Comments:

Average includes 3 runs.

042010 113320
 MJK @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 SDA Inlet

USEPA Method 26A HCl Parameters

Run No.	1	2	3	Average
Date (2010)	Mar 24	Mar 24	Mar 24	
Start Time (approx.)	07:45	09:16	10:54	
Stop Time (approx.)	08:45	10:16	11:54	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.1	184.2	184.1	184.1
P ₁ Fabric Filter Inlet Temperature (°F)	315	315	315	315
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.9800	8.0700	8.0300	8.3600
CO ₂ Carbon dioxide (dry volume %)	10.3600	11.1600	11.2600	10.9267
T _s Sample temperature (°F)	465.1667	464.1667	468.0000	465.7778
B _w Actual water vapor in gas (% by volume)	17.8408	18.2113	18.6709	18.2410
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	36.0617	36.2256	36.4883	36.2585
Laboratory Data				
m _n Total HCl collected (mg)	607.2973	714.3158	701.1579	
Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (lb/dscf)	3.7133E-05	4.3479E-05	4.2371E-05	4.0995E-05
C _{sd7} HCl Concentration @7% O ₂ (lb/dscf)	4.3301E-05	4.7105E-05	4.5762E-05	4.5390E-05
C _{sd12} HCl Concentration @12% CO ₂ (lb/dscf)	4.3012E-05	4.6752E-05	4.5156E-05	4.4973E-05
C _{sd} HCl Concentration (ppmdv)	392.5961	459.6899	447.9739	433.4200
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	457.8092	498.0273	483.8258	479.8874
C _{sd12} HCl Concentration @12% CO ₂ (ppmdv)	454.7445	494.2902	477.4145	475.4831
C _w HCl Concentration (ppmwv)	322.5536	375.9745	364.3333	354.2871
C _{sd} HCl Concentration (mg/dscm)	594.6390	696.2614	678.5160	656.4721
C _{sd7} HCl Concentration @7% O ₂ (mg/dscm)	693.4129	754.3285	732.8184	726.8532
C _{sd12} HCl Concentration @12% CO ₂ (mg/dscm)	688.7710	748.6682	723.1076	720.1823
C _{sd} HCl Concentration (mg/Nm ³ dry)	638.1491	747.2074	728.1635	704.5067
C _{sd7} HCl Concentration @7% O ₂ (mg/Nm ³ dry)	744.1504	809.5232	786.4392	780.0376
C _{sd12} HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	739.1689	803.4488	776.0180	772.8786
E _{Fd} HCl Rate - Fd-based (lb/MMBtu)	0.6231	0.6778	0.6585	0.6531
E _{Fc} HCl Rate - Fc-based (lb/MMBtu)	0.6523	0.7091	0.6849	0.6821

042010 113320
 M J K @ _ @

Wheelabrator North Broward, Inc.
 CleanAir Project No. 10955
 Lime Silo

Visible Emission Parameters

Run	1	Time (min)	Time (sec)				Time (min)	Time (sec)			
			15	30	45	60		15	30	45	60
Date (2010)	Mar 24	0	0	0	0	0	0	0	0	0	0
Start Time	10:32	1	0	0	0	0	1	0	0	0	0
		2	0	0	0	0	2	0	0	0	0
		3	0	0	0	0	3	0	0	0	0
		4	0	0	0	0	4	0	0	0	0
		5	0	0	0	0	5	0	0	0	0
		6	0	0	0	0	6	0	0	0	0
		7	0	0	0	0	7	0	0	0	0
		8	0	0	0	0	8	0	0	0	0
		9	0	0	0	0	9	0	0	0	0
		10	0	0	0	0	10	0	0	0	0
		11	0	0	0	0	11	0	0	0	0
		12	0	0	0	0	12	0	0	0	0
		13	0	0	0	0	13	0	0	0	0
		14	0	0	0	0	14	0	0	0	0
		15	0	0	0	0	15	0	0	0	0
		16	0	0	0	0	16	0	0	0	0
		17	0	0	0	0	17	0	0	0	0
		18	0	0	0	0	18	0	0	0	0
		19	0	0	0	0	19	0	0	0	0
		20	0	0	0	0	20				
		21	0	0	0	0	21				
		22	0	0	0	0	22				
		23	0	0	0	0	23				
		24	0	0	0	0	24				
		25	0	0	0	0	25				
		26	0	0	0	0	26				
		27	0	0	0	0	27				
		28	0	0	0	0	28				
		29	0	0	0	0	29				
		30	0	0	0	0	30				
		31	0	0	0	0	31				
		32	0	0	0	0	32				
		33	0	0	0	0	33				
		34	0	0	0	0	34				
		35	0	0	0	0	35				
		36	0	0	0	0	36				
		37	0	0	0	0	37				
		38	0	0	0	0	38				
		39	0	0	0	0	39				
		40	0	0	0	0	40				
		41	0	0	0	0	41				
		42	0	0	0	0	42				
		43	0	0	0	0	43				
		44	0	0	0	0	44				
		45	0	0	0	0	45				
		46	0	0	0	0	46				
		47	0	0	0	0	47				
		48	0	0	0	0	48				
		49	0	0	0	0	49				
		50	0	0	0	0	50				
		51	0	0	0	0	51				
		52	0	0	0	0	52				
		53	0	0	0	0	53				
		54	0	0	0	0	54				
		55	0	0	0	0	55				
		56	0	0	0	0	56				
		57	0	0	0	0	57				
		58	0	0	0	0	58				
		59	0	0	0	0	59				

Average Opacity 0
 Minimum Reading 0
 Maximum Reading 0
 No. of Readings >5% 0

WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

QA/QC DATA

E

This Page Intentionally Left Blank

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 23	Mar 23	Mar 23
Start Time (approx.)	07:43	10:31	13:32
Stop Time (approx.)	09:58	12:45	15:46
Total Duration of Test Run (min.)	135	134	134
Net Sampling Time (min.)	125	125	125

Sampling System Calibration Summary

D _n	Nozzle ID No:	270-1	270-1	270-1
	Nozzle Diameter (in):	0.270	0.270	0.270
C _p	Probe ID No:	67-8-4	67-8-4	67-8-4
	Pitot Coefficient:	0.8050	0.8050	0.8050
Y _d	Meter Box ID. No:	66-22	66-22	66-22
	Meter Box Yd - Field Sheet	1.0005	1.0005	1.0005
	Meter Box Yd - Database	1.0005	1.0005	1.0005
	Meter Box ΔH@ - Field Sheet	1.8097	1.8097	1.8097
	Meter Box ΔH@ - Database	1.8097	1.8097	1.8097

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0245	0.0249	0.0250
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0020	0.0010	0.0030

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	77.169	77.389	77.612

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0847	1.0964	1.1041
Y _{qa}	Alternative Meter Calibration Factor	0.9679	0.9691	0.9716
	Variation from full-test Y _d (average ≤ ±5%)	-3.3%	-3.1%	-2.9%

**Average
-3.1%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	105.25	104.24	102.93

Point-by-Point Isokinetic Variation

	Number of points <90%	1	0	0
	Number of points >110%	1	0	0
	Number of points <80%	1	0	0
	Number of points >120%	1	0	0

042010 114448
 J.L.L.@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 SDA Inlet

USEPA Method 29 (Trace Metals) QA/QC Results

Run No.	1	2	3
Date (2010)	Mar 23	Mar 23	Mar 23
Start Time (approx.)	07:43	10:31	13:32
Stop Time (approx.)	09:58	12:45	15:46
Total Duration of Test Run (min.)	135	134	134
Net Sampling Time (min.)	120	120	120

Sampling System Calibration Summary

	Nozzle ID No:	270-2	270-2	270-2
D _n	Nozzle Diameter (in):	0.270	0.270	0.270
	Probe ID No:	67-10-3	67-10-3	67-10-3
C _p	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	61-8	61-8	61-8
Y _d	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box ΔH@ - Field Sheet	1.7580	1.7580	1.7580
	Meter Box ΔH@ - Database	1.7580	1.7580	1.7580

QA/QC

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0234	0.0228	0.0230
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0070	0.0030	0.0030
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{msid}	Actual Sample Volume (dscf)	68.540	65.652	65.796
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0404	1.0174	1.0223
Y _{qa}	Alternative Meter Calibration Factor	0.9954	1.0079	1.0073
	Variation from full-test Y _d (average ≤ ±5%)	0.4%	1.6%	1.6%
	<u>Mean Isokinetic Sampling Rate Variation</u>			
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	99.56	98.55	98.16
	<u>Point-by-Point Isokinetic Variation</u>			
	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042010 114448
 JNK@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 24	Mar 24	Mar 24
Start Time (approx.)	07:53	11:03	14:12
Stop Time (approx.)	10:06	13:35	16:22
Total Duration of Test Run (min.)	133	152	130
Net Sampling Time (min.)	125	125	125

Sampling System Calibration Summary

D _n	Nozzle ID No:	270-1	270-1	270-1
	Nozzle Diameter (in):	0.270	0.270	0.270
C _p	Probe ID No:	67-8-4	67-8-4	67-8-4
	Pitot Coefficient:	0.8050	0.8050	0.8050
Y _d	Meter Box ID. No:	85-2	85-2	85-2
	Meter Box Yd - Field Sheet	1.0066	1.0066	1.0066
	Meter Box Yd - Database	1.0066	1.0066	1.0066
	Meter Box ΔH@ - Field Sheet	1.7759	1.7759	1.7759
	Meter Box ΔH@ - Database	1.7759	1.7759	1.7759

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0227	0.0236	0.0238
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0020

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	71.894	73.201	73.705

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0373	1.0721	1.0849
Y _{qa}	Alternative Meter Calibration Factor	1.0090	1.0113	1.0159
	Variation from full-test Y _d (average ≤ ±5%)	0.2%	0.5%	0.9%

**Average
0.5%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	100.10	99.96	99.02

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042010 114448
 KKN @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

USEPA Method 29 (Trace Metals) QA/QC Results

Run No.	1	2	3
Date (2010)	Mar 24	Mar 24	Mar 24
Start Time (approx.)	07:53	11:03	14:12
Stop Time (approx.)	10:06	13:32	16:19
Total Duration of Test Run (min.)	133	149	127
Net Sampling Time (min.)	120	120	120

Sampling System Calibration Summary

D _n	Nozzle ID No:	270-2	270-2	270-2
	Nozzle Diameter (in):	0.270	0.270	0.270
C _p	Probe ID No:	67-10-3	67-10-3	67-10-3
	Pitot Coefficient:	0.8250	0.8250	0.8250
Y _d	Meter Box ID. No:	66-11	66-11	66-11
	Meter Box Yd - Field Sheet	0.9933	0.9933	0.9933
	Meter Box Yd - Database	0.9933	0.9933	0.9933
	Meter Box ΔH@ - Field Sheet	1.8619	1.8619	1.8619
	Meter Box ΔH@ - Database	1.8619	1.8619	1.8619

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0218	0.0215	0.0227
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0040	0.0030	0.0040

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	65.532	63.191	66.874

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0106	0.9956	1.0515
Y _{qa}	Alternative Meter Calibration Factor	0.9939	1.0048	1.0039
	Variation from full-test Y _d (average ≤ ±5%)	0.1%	1.2%	1.1%

**Average
0.8%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	101.33	98.35	99.72

Point-by-Point Isokinetic Variation

	Number of points <90%	0	1	0
	Number of points >110%	0	1	0
	Number of points <80%	0	1	0
	Number of points >120%	0	1	0

042010 114448
H J K @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 22	Mar 22	Mar 22
Start Time (approx.)	08:47	11:43	14:24
Stop Time (approx.)	11:05	13:57	16:39
Total Duration of Test Run (min.)	138	134	135
Net Sampling Time (min.)	125	125	125

Sampling System Calibration Summary

D _n	Nozzle ID No:	270-1	270-1	270-1
	Nozzle Diameter (in):	0.270	0.270	0.270
C _p	Probe ID No:	67-8-4	67-8-4	67-8-4
	Pitot Coefficient:	0.8050	0.8050	0.8050
Y _d	Meter Box ID. No:	85-4	85-4	85-4
	Meter Box Yd - Field Sheet	1.0085	1.0085	1.0085
	Meter Box Yd - Database	1.0085	1.0085	1.0085
	Meter Box ΔH@ - Field Sheet	1.7723	1.7723	1.7723
	Meter Box ΔH@ - Database	1.7723	1.7723	1.7723

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0250	0.0232	0.0240
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0030	0.0010	0.0010

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	77.683	72.102	73.906

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.1226	1.0432	1.0657
Y _{qa}	Alternative Meter Calibration Factor	1.0038	1.0039	0.9948
	Variation from full-test Y _d (average ≤ ±5%)	-0.5%	-0.5%	-1.4%

**Average
-0.8%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	100.22	100.18	100.78

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042010 114448
IPJ@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 SDA Inlet

USEPA Method 29 (Trace Metals) QA/QC Results

Run No.	1	2	3
Date (2010)	Mar 22	Mar 22	Mar 22
Start Time (approx.)	08:47	11:43	14:27
Stop Time (approx.)	11:05	13:57	16:39
Total Duration of Test Run (min.)	138	134	132
Net Sampling Time (min.)	120	120	120

Sampling System Calibration Summary

	Nozzle ID No:	270-2	270-2	270-2
D _n	Nozzle Diameter (in):	0.270	0.270	0.270
	Probe ID No:	67-10-3	67-10-3	67-10-3
C _p	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	61-6	61-6	61-6
Y _d	Meter Box Yd - Field Sheet	0.9900	0.9900	0.9900
	Meter Box Yd - Database	0.9900	0.9900	0.9900
	Meter Box ΔH@ - Field Sheet	1.6820	1.6820	1.6820
	Meter Box ΔH@ - Database	1.6820	1.6820	1.6820

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0227	0.0219	0.0222
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0060	0.0060	0.0050

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	67.567	65.067	64.926

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	0.9851	0.9531	0.9541
Y _{qa}	Alternative Meter Calibration Factor	0.9856	0.9867	0.9826
	Variation from full-test Y _d (average ≤ ±5%)	-0.4%	-0.3%	-0.8%

**Average
-0.5%**

Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.88	100.59	100.05

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042010 114448
 N O Q @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 22	Mar 22	Mar 22
Start Time (approx.)	13:19	15:07	16:30
Stop Time (approx.)	14:34	16:21	17:41
Total Duration of Test Run (min.)	75	74	71
Net Sampling Time (min.)	63	63	63

Sampling System Calibration Summary

D _n	Nozzle ID No:	0.268-1	0.268-1	0.268-1
	Nozzle Diameter (in):	0.268	0.268	0.268
C _p	Probe ID No:	67-8-14	67-8-14	67-8-14
	Pitot Coefficient:	0.8120	0.8120	0.8120
Y _d	Meter Box ID. No:	66-22	66-22	66-22
	Meter Box Y _d - Field Sheet	1.0005	1.0005	1.0005
	Meter Box Y _d - Database	1.0005	1.0005	1.0005
	Meter Box ΔH@ - Field Sheet	1.8097	1.8097	1.8097
	Meter Box ΔH@ - Database	1.8097	1.8097	1.8097

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0235	0.0243	0.0234
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0010

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	36.936	37.954	36.294

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0670	1.0698	1.0284
Y _{qa}	Alternative Meter Calibration Factor	0.9921	0.9652	0.9676
	Variation from full-test Y _d (average ≤ ±5%)	-0.8%	-3.5%	-3.3%

**Average
-2.6%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	102.10	104.78	104.45

Point-by-Point Isokinetic Variation

Number of points <90%	1	1	2
Number of points >110%	2	9	7
Number of points <80%	1	0	0
Number of points >120%	0	0	0

042010 114800
OKP@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

USEPA Method 13B (Total Fluorides) QA/QC Results

Run No.	1	2	3
Date (2010)	Mar 24	Mar 24	Mar 24
Start Time (approx.)	07:53	09:37	11:24
Stop Time (approx.)	09:11	10:54	12:46
Total Duration of Test Run (min.)	78	77	82
Net Sampling Time (min.)	63	63	63

Sampling System Calibration Summary

D _n	Nozzle ID No:	0.268-1	0.268-1	0.268-1
	Nozzle Diameter (in):	0.268	0.268	0.268
C _p	Probe ID No:	67-8-14	67-8-14	67-8-14
	Pitot Coefficient:	0.8120	0.8120	0.8120
Y _d	Meter Box ID. No:	66-24	66-24	66-24
	Meter Box Yd - Field Sheet	0.9904	0.9904	0.9904
	Meter Box Yd - Database	0.9904	0.9904	0.9904
	Meter Box ΔH@ - Field Sheet	1.7516	1.7516	1.7516
	Meter Box ΔH@ - Database	1.7516	1.7516	1.7516

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0230	0.0233	0.0229
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0010	0.0040	0.0020

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	36.241	35.994	34.974

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0278	1.0303	1.0096
Y _{qa}	Alternative Meter Calibration Factor	0.9869	0.9867	0.9886
	Variation from full-test Y _d (average ≤ ±5%)	-0.3%	-0.4%	-0.2%

**Average
-0.3%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	101.00	100.55	100.01

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042010 114800
LPI@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 13B (Total Fluorides)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 23	Mar 23	Mar 23
Start Time (approx.)	12:41	14:31	15:54
Stop Time (approx.)	13:54	15:39	17:02
Total Duration of Test Run (min.)	73	68	68
Net Sampling Time (min.)	63	63	63

Sampling System Calibration Summary

D _n	Nozzle ID No:	0.268-1	0.268-1	0.268-1
	Nozzle Diameter (in):	0.268	0.268	0.268
C _p	Probe ID No:	67-8-14	67-8-14	67-8-14
	Pitot Coefficient:	0.8120	0.8120	0.8120
Y _d	Meter Box ID. No:	85-4	85-4	85-4
	Meter Box Yd - Field Sheet	1.0085	1.0085	1.0085
	Meter Box Yd - Database	1.0085	1.0085	1.0085
	Meter Box ΔH@ - Field Sheet	1.7723	1.7723	1.7723
	Meter Box ΔH@ - Database	1.7723	1.7723	1.7723

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0232	0.0242	0.0230
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0030	0.0010	0.0020

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	35.654	37.181	35.412

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0531	1.0826	1.0023
Y _{qa}	Alternative Meter Calibration Factor	1.0191	1.0039	0.9755
	Variation from full-test Y _d (average ≤ ±5%)	1.0%	-0.5%	-3.3%

**Average
-0.9%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	100.70	101.05	104.13

Point-by-Point Isokinetic Variation

	Number of points <90%	1	2	0
	Number of points >110%	1	1	3
	Number of points <80%	1	0	0
	Number of points >120%	0	0	1

042010 114600
 RKL@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 23 (PCDD/F)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 22	Mar 23	Mar 23
Start Time (approx.)	10:04	07:36	12:32
Stop Time (approx.)	14:44	12:10	17:02
Total Duration of Test Run (min.)	280	274	270
Net Sampling Time (min.)	250	250	250

Sampling System Calibration Summary

	Nozzle ID No:	264-1	264-1	264-1
D _n	Nozzle Diameter (in):	0.264	0.264	0.264
	Probe ID No:	67-8-17	67-8-17	67-8-17
C _p	Pitot Coefficient:	0.8340	0.8340	0.8340
	Meter Box ID. No:	66-24	66-24	66-24
Y _d	Meter Box Yd - Field Sheet	0.9904	0.9904	0.9904
	Meter Box Yd - Database	0.9904	0.9904	0.9904
	Meter Box ΔH@ - Field Sheet	1.7516	1.7516	1.7516
	Meter Box ΔH@ - Database	1.7516	1.7516	1.7516

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0226	0.0233	0.0234
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0040	0.0030	0.0030

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	139.505	142.831	141.781

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0005	1.0269	1.0257
Y _{qa}	Alternative Meter Calibration Factor	0.9887	0.9866	0.9876
	Variation from full-test Y _d (average ≤ ±5%)	-0.2%	-0.4%	-0.3%

**Average
-0.3%**

Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	100.67	100.45	101.50

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042010 114630
 HNP@

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 FF Outlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 22	Mar 22	Mar 22
Start Time (approx.)	08:31	09:58	11:30
Stop Time (approx.)	09:31	10:58	12:47
Total Duration of Test Run (min.)	60	60	77
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

D _n	Nozzle ID No:	NA	NA	NA
	Nozzle Diameter (in):	NA	NA	NA
C _p	Probe ID No:	67-4-3	67-4-3	67-4-3
	Pitot Coefficient:	0.8400	0.8400	0.8400
Y _d	Meter Box ID. No:	66-22	66-22	66-22
	Meter Box Yd - Field Sheet	1.0005	1.0005	1.0005
	Meter Box Yd - Database	1.0005	1.0005	1.0005
	Meter Box ΔH@ - Field Sheet	1.8097	1.8097	1.8097
	Meter Box ΔH@ - Database	1.8097	1.8097	1.8097

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0275	0.0275	0.0273
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0010	0.0010	0.0014

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	41.758	41.689	41.487

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.2247	1.2247	1.2247
Y _{qa}	Alternative Meter Calibration Factor	0.9714	0.9717	0.9764
	Variation from full-test Y _d (average ≤ ±5%)	-2.9%	-2.9%	-2.4%

042010 114859
 ONK @

**Average
 -2.7%**

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 1 SDA Inlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 22	Mar 22	Mar 22
Start Time (approx.)	08:31	09:58	11:30
Stop Time (approx.)	09:31	10:58	12:46
Total Duration of Test Run (min.)	60	60	76
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	67-4-1	67-4-1	67-4-5
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	61-8	61-8	61-8
Y _d	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box ΔH@ - Field Sheet	1.7580	1.7580	1.7580
	Meter Box ΔH@ - Database	1.7580	1.7580	1.7580

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0234	0.0241	0.0238
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0040	0.0080	0.0050

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	35.186	36.040	35.520

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0595	1.0916	1.0954
Y _{qa}	Alternative Meter Calibration Factor	1.0011	1.0029	1.0189
	Variation from full-test Y _d (average ≤ ±5%)	1.0%	1.1%	2.8%

**Average
1.6%**

042010 114709
 J Q J @

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 FF Outlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 23	Mar 23	Mar 23
Start Time (approx.)	07:55	09:30	10:55
Stop Time (approx.)	08:55	10:31	12:06
Total Duration of Test Run (min.)	60	61	71
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	67-4-3	67-4-3	67-4-3
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	85-2	85-2	85-2
Y _d	Meter Box Yd - Field Sheet	1.0066	1.0066	1.0066
	Meter Box Yd - Database	1.0066	1.0066	1.0066
	Meter Box ΔH@ - Field Sheet	1.7759	1.7759	1.7759
	Meter Box ΔH@ - Database	1.7759	1.7759	1.7759

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0267	0.0270	0.0275
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0050	0.0010	0.0020

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	40.081	39.969	40.827

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.2247	1.2247	1.2247
Y _{qa}	Alternative Meter Calibration Factor	1.0191	1.0150	0.9947
	Variation from full-test Y _d (average ≤ ±5%)	1.2%	0.8%	-1.2%

042010 114717
 O X Q @

**Average
 0.3%**

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 2 SDA Inlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 23	Mar 23	Mar 23
Start Time (approx.)	07:55	09:30	10:55
Stop Time (approx.)	08:55	10:30	12:06
Total Duration of Test Run (min.)	60	60	71
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	67-4-5	67-4-5	67-4-5
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	66-11	66-11	66-11
Y _d	Meter Box Yd - Field Sheet	0.9933	0.9933	0.9933
	Meter Box Yd - Database	0.9933	0.9933	0.9933
	Meter Box ΔH@ - Field Sheet	1.8619	1.8619	1.8619
	Meter Box ΔH@ - Database	1.8619	1.8619	1.8619

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0233	0.0236	0.0234
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0050	0.0040	0.0040

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	34.596	34.433	34.040

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0916	1.0954	1.0954
Y _{qa}	Alternative Meter Calibration Factor	1.0134	1.0137	1.0208
	Variation from full-test Y _d (average ≤ ±5%)	2.0%	2.1%	2.8%

042010 114725
 KOH@

**Average
 2.3%**

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 FF Outlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 24	Mar 24	Mar 24
Start Time (approx.)	07:45	09:16	10:54
Stop Time (approx.)	08:45	10:16	11:54
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

D _n	Nozzle ID No:	NA	NA	NA
	Nozzle Diameter (in):	NA	NA	NA
C _p	Probe ID No:	67-4-3	67-4-3	67-4-3
	Pitot Coefficient:	0.8400	0.8400	0.8400
Y _d	Meter Box ID. No:	66-14	66-14	66-14
	Meter Box Yd - Field Sheet	0.9898	0.9898	0.9898
	Meter Box Yd - Database	0.9898	0.9898	0.9898
	Meter Box ΔH@ - Field Sheet	1.7643	1.7643	1.7643
	Meter Box ΔH@ - Database	1.7643	1.7643	1.7643

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0268	0.0277	0.0277
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0020	0.0010	0.0020

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	40.207	40.731	39.977

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.2247	1.2247	1.2247
Y _{qa}	Alternative Meter Calibration Factor	1.0098	0.9857	0.9959
	Variation from full-test Y _d (average ≤ ±5%)	2.0%	-0.4%	0.6%

D42010 114734
 DLK@

**Average
 0.7%**

Wheelabrator South Broward, Inc.
 Clean Air Project No: 10955
 Unit 3 SDA Inlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2010)	Mar 24	Mar 24	Mar 24
Start Time (approx.)	07:45	09:16	10:54
Stop Time (approx.)	08:45	10:16	11:54
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

D _n	Nozzle ID No:	NA	NA	NA
	Nozzle Diameter (in):	NA	NA	NA
C _p	Probe ID No:	67-4-5	67-4-5	67-4-5
	Pitot Coefficient:	0.8400	0.8400	0.8400
Y _d	Meter Box ID. No:	61-6	61-6	61-6
	Meter Box Yd - Field Sheet	0.9900	0.9900	0.9900
	Meter Box Yd - Database	0.9900	0.9900	0.9900
	Meter Box ΔH@ - Field Sheet	1.6820	1.6820	1.6820
	Meter Box ΔH@ - Database	1.6820	1.6820	1.6820

QA/QC

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0240	0.0244	0.0247
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0040	0.0030	0.0040

Sample Volume

V _{mstd}	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	36.062	36.226	36.488

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0954	1.0916	1.0954
Y _{qa}	Alternative Meter Calibration Factor	1.0320	1.0162	1.0089
	Variation from full-test Y _d (average ≤ ±5%)	4.2%	2.7%	1.9%

042010 114745
 MJK@

**Average
 2.9%**

Nozzle Calibration Sheet


Client: <u>Wheelabrator North Boward</u>	Project Number: <u>0955</u>
Calibrated by: <u>S. Brown</u>	Unit: <u>1-3 (Both Plants)</u>
Date: <u>3/15/10</u>	Runs: <u>-3</u>

	Nozzle Identification	D ₁ (inches)	D ₂ (inches)	D ₃ (inches)	ΔD (inches)	D _{ave} (inches)
5/29	0.270-1	0.270	0.270	0.271	0.001	0.270
m23	0.264-1	0.265	0.264	0.263	0.002	0.264
m13B	0.268-1	0.269	0.268	0.268	0.001	0.268
inlet	0.270-2	0.271	0.270	0.270	0.001	0.270
	0.270-3	0.270	0.270	0.270	0.000	0.270

D₁, D₂, D₃ = three nozzle diameter measurements

ΔD = maximum difference between any two diameters
ΔD = 0.004 inches*

D_{ave} = average of D₁, D₂, D₃



* (40 CFR 60, Appendix A, Method 5, Section 5.1)

Meter Box Full Test Calibration

Meter Box No: 61-6

Date of Calibration: 7/17/2009

Meter Box Y_d : 0.9900

Calibration conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.6820

Barometric Pressure: 29.04

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	In	Out	T_{ds} Avg.	In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.965	3.00	-1.70	1.0000	0.000	10.000	10.000	209.181	219.284	10.103	77.0	77.0	77.00	85.0	77.0	81.00	9.89	0.9854	1.7309
0.971	3.00	-1.70	1.0000	0.000	10.000	10.000	219.284	229.389	10.105	77.0	77.0	77.00	86.0	78.0	82.00	9.82	0.9870	1.7034
0.401	0.50	-1.00	1.0000	0.000	5.000	5.000	234.378	239.419	5.041	77.0	77.0	77.00	81.0	78.0	79.50	11.88	0.9927	1.6620
0.401	0.50	-1.00	1.0000	0.000	5.000	5.000	239.419	244.459	5.040	77.0	77.0	77.00	81.0	78.0	79.50	11.90	0.9929	1.6676
0.695	1.50	-1.50	1.0000	0.000	10.000	10.000	253.277	263.387	10.110	76.0	76.0	76.00	84.0	79.0	81.50	13.76	0.9917	1.6629
0.694	1.50	-1.50	1.0000	0.000	10.000	10.000	263.387	273.514	10.127	76.0	76.0	76.00	84.0	79.0	81.50	13.77	0.9900	1.6653
Averages																0.98996	1.68200	

E - 20

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_1 \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_1 \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
5.6	5.0
10.7	10.0
15.4	15.0
20.4	20.0
24.8	24.7

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-6

Office: _____

Calibrated by: OLEG LAVROV

Client: _____

Date: 1/18/08

Job No: _____

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	51	50				
100	98	100	99				
150	148	150	150				
200	199	200	200				
250	249	250	250				
300	299	300	300				
350	349	350	350				
400	399	400	399				
450	449	450	450				
500	499	500	500				
550	548	550	550				
600	599	600	599				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp date : <u>6/22/2010</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 61-6 Orifice B-5
 Location warehouse Meter Yd 0.9900 Orifice K' 0.5463
 Test Date 03/30/10 Meter ΔH@ 1.6820 Orifice Cal. Date 01/28/10
 Operator E. Dieter Full Test Cal. Date 07/17/09

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute
 Positive Pressure Pass
No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp (F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time (minutes)	Net Meter Volume for Run (dcf)	Avg. Meter Temp. for Run (F)	DGM Calibration Factor (Y _i)	Percent Variation (ΔY)
			Inlet (F)	Outlet (F)								
	0.0	773.90	68	66								
1	5.0	777.48	68	66	71	1.50	19	5.0	3.58	67.0	0.9855	0.2%
2	10.0	781.07	70	66	71	1.50	19	5.0	3.59	67.5	0.9837	0.0%
3	15.0	784.66	71	67	74	1.50	19	5.0	3.59	68.5	0.9828	-0.1%
Average Y_i											0.9840	
Cal. Error											-0.6%	

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}}{Y_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y} - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

Meter Box Full Test Calibration

Meter Box No: 61-8

Date of Calibration: 5/11/2009

Meter Box Y_d : 0.9916

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.7580

Barometric Pressure: 29.39

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i in	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.984	3.00	-1.70	1.0000	0.000	10.000	10.000	62.712	72.772	10.060	68.0	68.0	68.00	73.0	69.0	71.00	9.98	0.9880	1.7092
0.972	3.00	-1.70	1.0000	0.000	10.000	10.000	72.772	82.872	10.100	68.0	68.0	68.00	76.0	70.0	73.00	10.10	0.9878	1.7472
0.387	0.50	-1.10	1.0000	0.000	5.000	5.000	86.333	91.393	5.060	68.0	68.0	68.00	75.0	72.0	73.50	12.68	0.9944	1.8290
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	91.393	96.466	5.073	68.0	68.0	68.00	75.0	73.0	74.00	12.76	0.9928	1.8487
0.692	1.50	-1.30	1.0000	0.000	10.000	10.000	98.815	108.963	10.148	68.0	68.0	68.00	78.0	73.0	75.50	14.19	0.9924	1.7147
0.694	1.50	-1.30	1.0000	0.000	10.000	10.000	108.963	119.111	10.148	68.0	68.0	68.00	79.0	74.0	76.50	14.14	0.9943	1.6994
Averages																0.99164	1.75804	

E - 23

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge

Standard (in.Hg)	Gauge (in.Hg)
4.7	5.0
9.6	10.0
14.6	15.0
19.5	20.0
23.3	24.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-8 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 5/11/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	49	48				
100	99	99	98				
150	149	149	149				
200	199	199	199				
250	250	249	249				
300	300	299	299				
350	350	349	350				
400	400	399	399				
450	450	449	449				
500	500	499	499				
550	549	549	549				
600	599	599	599				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 61-8 Orifice B-5
 Location warehouse Meter Yd 0.9916 Orifice K' 0.5463
 Test Date 03/30/10 Meter ΔH@ 1.7580 Orifice Cal. Date 01/28/10
 Operator E. Dieter Full Test Cal. Date 05/11/09

Leak Checks

Negative Pressure

No movement of manometer in one-minute Pass

Positive Pressure

No movement of manometer in one-minute Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp. (F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time (minutes)	Net Meter Volume for Run - V (scf)	Avg Meter Temp. for Run (F)	DGM Calibration Factor - Y _i	Percent Variation ΔY _i
			Inlet (F)	Outlet (F)								
	0.0	535.20	71	68								
1	5.0	538.80	72	69	71	1.50	15	5.0	3.60	70.0	0.9856	-0.2%
2	10.0	542.40	73	69	73	1.50	15	5.0	3.60	70.8	0.9851	-0.2%
3	15.0	545.99	74	70	71	1.50	15	5.0	3.59	71.5	0.9911	0.4%

Average Y _i	0.9873
Cal. Error	-0.4%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

Meter Box Full Test Calibration

Meter Box No: 66-11

Date of Calibration: 10/14/2009

Meter Box Y_d : 0.9933

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.8619

Barometric Pressure: 29.45

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.942	3.00	-1.90	1.0000	0.000	10.000	10.000	527.575	537.612	10.037	69.5	69.5	69.50	78.0	70.0	74.00	10.42	0.9926	1.8665
0.943	3.00	-1.90	1.0000	0.000	10.000	10.000	537.612	547.871	10.059	69.5	69.5	69.50	80.0	72.0	76.00	10.40	0.9941	1.8523
0.374	0.50	-1.30	1.0000	0.000	5.000	5.000	551.323	556.370	5.047	69.5	69.5	69.50	76.0	73.0	74.50	13.12	0.9956	1.9616
0.376	0.50	-1.30	1.0000	0.000	5.500	5.500	556.370	561.927	5.557	69.5	69.5	69.50	76.0	74.0	75.00	14.37	0.9955	1.9411
0.679	1.50	-1.50	1.0000	0.000	10.000	10.000	565.835	576.002	10.167	69.5	69.5	69.50	81.0	75.0	78.00	14.44	0.9919	1.7755
0.679	1.50	-1.50	1.0000	0.000	10.000	10.000	576.002	586.200	10.198	69.5	69.5	69.50	81.0	76.0	78.50	14.45	0.9898	1.7746
Averages																0.99325	1.86192	

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_g Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
4.7	5.0
9.7	10.0
14.9	15.0
20.5	20.0
24.9	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 68-11 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 10/14/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	50	52	51				
100	100	101	101				
150	150	151	151				
200	200	201	201				
250	250	251	251				
300	300	301	301				
350	349	351	351				
400	399	401	400				
450	449	451	450				
500	499	501	500				
550	549	551	550				
600	599	601	600				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp Date : <u>10/7/2010</u>
Calibration Report No: <u>R044701</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 66-11 Orifice B-5
 Location warehouse Meter Yd 0.9933 Orifice K' 0.5463
 Test Date 03/29/10 Meter ΔH@ 1.8619 Orifice Cal. Date 01/28/10
 Operator E. Dieter Full Test Cal. Date 10/14/09

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute
 Positive Pressure Pass
No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (ccf)	Note: Temperature		Ambient Temp. T _{amb} (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V _m (ccf)	Avg Meter Temp. for Run - T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation - ΔY _i
			Init (°F)	Outlet (°F)								
	0.0	916.90	67	59								
1	5.0	920.43	67	59	72	1.60	20	5.0	3.53	63.0	0.9907	0.0%
2	10.0	923.97	68	61	71	1.60	20	5.0	3.54	63.8	0.9902	-0.1%
3	15.0	927.51	70	62	72	1.60	20	5.0	3.54	65.3	0.9921	0.1%

Average Y _i	0.9910
Cal. Error	-0.2%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}}{Y_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y} - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

Meter Box Full Test Calibration

Meter Box No: 66-14

Date of Calibration: 8/17/2009

Meter Box Y_d : 0.9898

Calibration Conducted by: O. Lavrov

Meter Box $\Delta H@$: 1.7643

Barometric Pressure: 29.21

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.943	3.00	-1.80	1.0000	0.000	10.000	10.000	473.148	483.260	10.112	77.0	77.0	77.00	86.0	79.0	82.50	10.18	0.9871	1.8165
0.938	3.00	-1.80	1.0000	0.000	10.000	10.000	483.260	493.403	10.143	77.0	77.0	77.00	88.0	81.0	84.50	10.23	0.9877	1.8276
0.392	0.50	-1.20	1.0000	0.000	5.000	5.000	502.282	507.357	5.075	77.0	77.0	77.00	85.0	82.0	83.50	12.24	0.9929	1.7410
0.392	0.50	-1.20	1.0000	0.000	5.000	5.000	507.357	512.444	5.087	77.0	77.0	77.00	85.0	82.0	83.50	12.25	0.9905	1.7439
0.680	1.50	-1.40	1.0000	0.000	10.000	10.000	521.145	531.347	10.202	77.5	77.5	77.50	89.0	84.0	86.50	14.09	0.9894	1.7272
0.680	1.50	-1.40	1.0000	0.000	10.000	10.000	531.347	541.532	10.185	77.5	77.5	77.50	89.0	84.0	86.50	14.10	0.9910	1.7296
Averages																0.98976	1.76429	

E - 29

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_1 \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_1 \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
5.6	5.0
10.5	10.0
15.8	15.0
20.6	20.0
25.2	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-14 Office: _____
 Calibrated by: O. Lavrov Client: _____
 Date: 8/17/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	51	52				
100	99	101	102				
150	149	151	151				
200	199	201	202				
250	249	251	252				
300	299	301	302				
350	349	351	351				
400	399	401	402				
450	449	451	452				
500	499	501	502				
550	549	551	551				
600	599	601	602				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp.date : <u>6/22/2010</u>
Calibration Report No: <u>R044701</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 66-14 Orifice C-5
 Location warehouse Meter Yd 0.9898 Orifice K' 0.5643
 Test Date 03/30/10 Meter ΔH@ 1.7643 Orifice Cal. Date 02/03/10
 Operator E. Dieter Full Test Cal. Date 08/17/09

Leak Checks

Negative Pressure

No movement of manometer in one-minute

Pass

Positive Pressure

No movement of manometer in one-minute

Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp (°F)	Orifice ΔH (in. W.G.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run (scf)	Avg Meter Temp for Run (°F)	DGM Calibration Factor, Y _i	Percent Variation ΔY _i
			Inlet (°F)	Outlet (°F)								
	0.0	753.30	73	71								
1	5.0	756.99	72	70	74	1.70	19	5.0	3.69	71.5	0.9927	0.0%
2	10.0	760.71	74	71	74	1.70	19	5.0	3.72	71.8	0.9852	-0.8%
3	15.0	764.38	75	71	73	1.70	19	5.0	3.67	72.8	1.0014	0.8%

Average Y _i	0.9931
Cal. Error	0.3%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E-31

Meter Box Full Test Calibration


Meter Box No: 66-22

Date of Calibration: 10/29/2009

Meter Box Y_d : 1.0005

Calibration Conducted by: Jeff Ivens

Meter Box $\Delta H@$: 1.8097

Signature: 

Barometric Pressure: 29.30

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.973	3.00	-1.80	1.0000	0.000	10.000	10.000	631.172	641.189	10.017	68.5	68.5	68.50	80.0	73.0	76.50	10.05	1.0013	1.7288
0.969	3.00	-1.80	1.0000	0.000	10.000	10.000	641.189	651.236	10.047	68.5	68.5	68.50	81.0	73.0	77.00	10.09	0.9992	1.7426
0.376	0.50	-1.30	1.0000	0.000	5.000	5.000	706.800	711.641	5.041	69.5	69.5	69.50	78.0	76.0	77.00	12.97	1.0014	1.9160
0.376	0.50	-1.20	1.0000	0.000	5.000	5.000	711.641	716.682	5.041	69.5	69.5	69.50	78.0	76.0	77.00	12.97	1.0016	1.9160
0.676	1.50	-1.50	1.0000	0.000	10.000	10.000	723.300	733.419	10.119	69.5	69.5	69.50	83.0	77.0	80.00	14.44	1.0003	1.7779
0.676	1.50	-1.50	1.0000	0.000	10.000	10.000	733.419	743.556	10.137	69.5	69.5	69.50	83.0	78.0	80.50	14.45	0.9994	1.7771
Averages																1.00054	1.80972	

E - 32

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_1 \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_1 \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.5	5.0
10.2	10.0
15.3	15.0
20.5	20.0
25.2	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-22 Office: _____
 Calibrated by: Jeff Ivens Client: _____
 Date: 10/29/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	51	51				
100	99	101	101				
150	149	151	151				
200	199	201	201				
250	249	251	251				
300	299	301	301				
350	349	351	351				
400	399	401	401				
450	449	451	451				
500	498	501	501				
550	548	551	551				
600	598	601	601				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/7/2010</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 66-22 Orifice B-5
 Location warehouse Meter Yd 1.0005 Orifice K' 0.5463
 Test Date 03/29/10 Meter ΔH@ 1.8097 Orifice Cal. Date 01/28/10
 Operator E. Dieter Full Test Cal. Date 10/29/09

Leak Checks

Negative Pressure

No movement of manometer in one-minute Pass

Positive Pressure

No movement of manometer in one-minute Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp. T _{amb} (°F)	Orifice ΔH (in. W.G.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V _m (scf)	Avg. Meter Temp. for Run T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation ΔY _i
			Inlet (°F)	Outlet (°F)								
	0.0	625.20	59	52								
1	5.0	628.67	62	54	71	1.50	20	5.0	3.47	56.8	0.9969	0.1%
2	10.0	632.15	64	56	72	1.50	20	5.0	3.48	59.0	0.9975	0.2%
3	15.0	635.65	66	58	75	1.50	20	5.0	3.50	61.0	0.9928	-0.3%

Average Y _i	0.9957
Cal. Error	-0.5%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 34

Meter Box Full Test Calibration

Meter Box No: 66-24

Date of Calibration: 8/19/2009

Meter Box Y_d : 0.9904

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.7516

Barometric Pressure: 29.15

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.962	3.00	-1.80	1.0000	0.000	10.000	10.000	580.884	591.020	10.136	76.5	76.5	76.50	86.0	79.0	82.50	9.96	0.9856	1.7392
0.967	3.00	-1.80	1.0000	0.000	10.000	10.000	591.020	601.178	10.158	76.5	76.5	76.50	89.0	80.0	84.50	9.91	0.9871	1.7186
0.381	0.50	-1.10	1.0000	0.000	5.000	5.000	615.932	621.024	5.092	77.0	77.0	77.00	86.0	84.0	85.00	12.58	0.9925	1.8361
0.381	0.50	-1.10	1.0000	0.000	5.000	5.000	621.024	626.117	5.093	77.0	77.0	77.00	87.0	85.0	86.00	12.58	0.9942	1.8327
0.685	1.50	-1.50	1.0000	0.000	10.000	10.000	629.337	639.566	10.229	77.0	77.0	77.00	92.0	86.0	89.00	13.98	0.9919	1.8944
0.685	1.50	-1.50	1.0000	0.000	10.000	10.000	639.566	649.822	10.256	77.0	77.0	77.00	93.0	87.0	90.00	13.97	0.9911	1.6889
Averages																0.99042	1.75163	

E-35

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure Differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in. Hg)	Gauge (in. Hg)
4.7	5.0
9.8	10.0
14.7	15.0
20.0	20.0
24.2	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-24 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 8/19/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	48	48				
100	99	98	98				
150	149	148	148				
200	199	198	198				
250	249	248	248				
300	299	298	299				
350	349	348	349				
400	399	398	398				
450	450	448	449				
500	499	498	499				
550	549	548	549				
600	599	598	599				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>6/22/2010</u>
Calibration Report No: <u>RO44791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 66-24 Orifice B-5
 Location warehouse Meter Yd 0.9904 Orifice K' 0.5463
 Test Date 03/30/10 Meter ΔH@ 1.7516 Orifice Cal. Date 01/28/10
 Operator E. Dieter Full Test Cal. Date 08/19/09

Leak Checks

Negative Pressure

No movement of manometer in one-minute

Pass

Positive Pressure

No movement of manometer in one-minute

Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp. - T _{amb} (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V _m (scf)	Avg Meter Temp. for Run - T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation - ΔY
			Inlet (°F)	Outlet (°F)								
	0.0	253.50	69	67								
1	5.0	257.08	70	67	71	1.50	20	5.0	3.58	68.3	0.9878	0.2%
2	10.0	260.67	71	67	72	1.50	20	5.0	3.59	68.8	0.9851	-0.1%
3	15.0	264.26	73	69	74	1.50	20	5.0	3.59	70.0	0.9856	-0.1%

Average Y_i	0.9861
Cal. Error	-0.4%

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 37

Meter Box Full Test Calibration

Meter Box No: 85-2

Date of Calibration: 11/17/2009

Meter Box Y_d : 1.0066

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.7759

Barometric Pressure: 29.35

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.966	3.00	-1.70	1.0000	0.000	10.000	10.000	200.383	210.311	9.928	67.5	67.5	67.50	77.0	74.0	75.50	10.16	1.0106	1.7539
0.959	3.00	-1.70	1.0000	0.000	10.000	10.000	210.311	220.285	9.974	67.5	67.5	67.50	80.0	75.0	77.50	10.23	1.0097	1.7748
0.388	0.50	-1.10	1.0000	0.000	5.000	5.000	222.808	227.844	5.036	68.0	68.0	68.00	75.0	75.0	75.00	12.65	1.0020	1.8126
0.388	0.50	-1.10	1.0000	0.000	5.000	5.000	227.844	232.882	5.038	68.0	68.0	68.00	75.0	75.0	75.00	12.65	1.0016	1.8126
0.683	1.50	-1.50	1.0000	0.000	10.000	10.000	237.848	247.883	10.035	68.0	68.0	68.00	81.0	75.0	78.00	14.36	1.0078	1.7518
0.683	1.50	-1.50	1.0000	0.000	10.000	10.000	247.883	257.913	10.030	68.0	68.0	68.00	81.0	75.0	78.00	14.35	1.0083	1.7494
Averages																	1.00665	1.77586

E - 38

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right] \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
4.9	5.0
10.1	10.0
15.3	15.0
20.5	20.0
25.3	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 85-2 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 11/17/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	52	51				
100	98	101	101				
150	149	151	151				
200	200	201	201				
250	251	252	251				
300	301	301	301				
350	350	348	351				
400	400	401	400				
450	450	451	450				
500	500	502	500				
550	550	551	550				
600	600	602	600				

Tolerance = $\pm 2^\circ\text{F}$ difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/7/2010</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 85-2 Orifice C-5
 Location warehouse Meter Yd 1.0066 Orifice K' 0.5643
 Test Date 03/29/10 Meter ΔH@ 1.7759 Orifice Cal. Date 02/03/10
 Operator E. Dieter Full Test Cal. Date 11/17/09

Leak Checks

Negative Pressure Pass
 No movement of manometer in
 one-minute
 Positive Pressure Pass
 No movement of
 manometer in one-minute

Barom. Press. (P_b) 29.26 in. Hg

Important: All leak checks must pass in order for calibration to be valid.

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp. (F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time (minutes)	Net Meter Volume for Run (scf)	Avg Meter Temp. for Run (F)	DGM Calibration Factor	Percent Variation (ΔY _i)
			Inlet (F)	Outlet (F)								
	0.0	745.20	63	55								
1	5.0	748.71	65	56	73	1.60	19	5.0	3.51	59.8	1.0218	0.3%
2	10.0	752.24	66	58	75	1.60	19	5.0	3.53	61.3	1.0170	-0.2%
3	15.0	755.78	68	59	75	1.60	19	5.0	3.54	62.8	1.0171	-0.2%

Average Y _i	1.0186
Cal. Error	1.2%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E-40

Meter Box Full Test Calibration

Meter Box No: 85-4

Date of Calibration: 11/25/2009

Meter Box Y_d : 1.0085

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.7723

Barometric Pressure: 29.09

Standard Meter Gas Volume (ft ³)				Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results				
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.965	3.00	-1.70	1.0000	0.000	11.000	11.000	278.946	289.808	10.862	67.5	67.5	67.50	76.0	69.0	72.50	11.09	1.0103	1.7589
0.954	3.00	-1.70	1.0000	0.000	10.000	10.000	289.808	299.707	9.899	67.5	67.5	67.50	79.0	71.0	75.00	10.20	1.0125	1.7936
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	304.068	309.063	4.995	67.5	67.5	67.50	76.0	72.0	74.00	12.62	1.0092	1.8270
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	309.063	314.066	5.003	67.5	67.5	67.50	76.0	73.0	74.50	12.65	1.0086	1.8322
0.687	1.50	-1.30	1.0000	0.000	10.000	10.000	345.224	355.314	10.090	67.5	67.5	67.50	81.0	76.0	78.50	14.15	1.0046	1.7097
0.687	1.50	-1.30	1.0000	0.000	10.000	10.000	355.314	365.392	10.078	67.5	67.5	67.50	81.0	76.0	78.50	14.16	1.0058	1.7122
Averages																1.00850	1.77225	

E-41

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.1	5.0
9.9	10.0
15.1	15.0
19.5	20.0
24.8	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 85-4 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 11/25/09 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1	2	3	4	5	6	7
	Stack	Probe	Filter	Imp Out	Aux	DGM In	DGM Out
50	49	52	52				
100	99	102	102				
150	150	152	152				
200	200	202	202				
250	250	252	251				
300	300	302	301				
350	350	352	351				
400	400	401	401				
450	450	452	452				
500	500	501	501				
550	550	551	551				
600	600	601	601				

Tolerance = $\pm 2^{\circ}F$ difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp date : <u>10/7/2010</u>
Calibration Report No: <u>R044701</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10955 Meter No. 85-4 Orifice C-5
 Location warehouse Meter Yd 1.0085 Orifice K' 0.5643
 Test Date 03/30/10 Meter ΔH@ 1.7723 Orifice Cal. Date 02/03/10
 Operator E. Dieter Full Test Cal. Date 11/25/09

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute
 Positive Pressure Pass
No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.26 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. (F)	Orifice ΔH (In. W.C.)	Vacuum (In. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V _m (dcf)	Avg Meter Temp. for Run - T _m (F)	DCM Calibration Factor - Y _i	Percent Variation - ΔY
			Inlet (F)	Outlet (F)								
	0.0	77.40	70	67								
1	5.0	81.03	71	67	72	1.60	21	5.0	3.63	68.8	1.0061	0.0%
2	10.0	84.67	72	68	72	1.60	21	5.0	3.64	69.5	1.0047	-0.2%
3	15.0	88.30	73	68	73	1.60	21	5.0	3.63	70.3	1.0080	0.2%

Average Y _i	1.0063
Cal. Error	-0.2%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

E-43

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-1

Project Number: _____

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	70	67	3	0.57%	%Difference ≤ 1.5
2	200°F-250°F	228	221	7	1.02%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.556	0.810	0.820	0.000	
2	0.556	0.809	0.821	0.000	
3	0.554	0.805	0.821	0.000	
Side 'A' Average Probe C _{p(A)} =			0.8207	0.0002	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.554	0.800	0.824	0.002	
2	0.545	0.798	0.818	0.004	
3	0.555	0.800	0.825	0.002	
Side 'B' Average Probe C _{p(B)} =			0.8223	0.0026	

'A' Average C _p 0.821	-	'B' Average C _p 0.822	=	Difference -0.001	=	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	----------------------	---	--------------------------------------

Does assembly meet specifications? YES →

If "Yes", C_p= Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.822

Calibrated by: R ARNOLD

Date: 03/01/2010



Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-5

Project Number: _____

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69	67	2	0.38%	%Difference ≤ 1.5
2	200°F-250°F	241	237	4	0.57%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 49 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :

Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *	Abs. Deviation from Avg. C _{p(A)} **
1	0.551	0.773	0.836	0.001
2	0.549	0.778	0.832	0.003
3	0.555	0.777	0.837	0.002
Side 'A' Average Probe C _{p(A)} =			0.8348	0.0021

Specification
Avg. C_p Deviations ≤ 0.01

Pitot Side 'B' :

Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *	Abs. Deviation from Avg. C _{p(B)} **
1	0.566	0.772	0.847	0.003
2	0.557	0.777	0.838	0.006
3	0.568	0.775	0.847	0.003
Side 'B' Average Probe C _{p(B)} =			0.8442	0.0039

Specification
Avg. C_p Deviations ≤ 0.01

'A' Average C _p 0.835	-	'B' Average C _p 0.844	=	Difference -0.009
-------------------------------------	---	-------------------------------------	---	----------------------

Specification
|Difference| ≤ 0.01

Does assembly meet specifications?

YES

If "Yes", C_p= Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \bar{C}_{P(A \text{ or } B)}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.839

Calibrated by: R ARNOLD

Date: 03/01/2010

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot I.D. Number: 67-8-4
 Project Number: _____

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	75	70	5	0.93%	
2	200°F-250°F	246	240	6	0.85%	% Difference ≤ 1.5

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 49 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A' :

Trial No.	Reference ΔP	Probe ΔP	Probe C _{P(S)} *	Abs. Deviation from Avg. C _{P(A)} **
1	0.538	0.814	0.805	0.000
2	0.540	0.815	0.806	0.001
3	0.539	0.816	0.805	0.001
Side 'A' Average Probe C _{P(A)} =			0.8052	0.0008

Specification
Avg. C_P Deviations ≤ 0.01

Pitot Side 'B' :

Trial No.	Reference ΔP	Probe ΔP	Probe C _{P(S)} *	Abs. Deviation from Avg. C _{P(B)} **
1	0.542	0.818	0.806	0.002
2	0.536	0.814	0.803	0.001
3	0.538	0.818	0.803	0.001
Side 'B' Average Probe C _{P(B)} =			0.8039	0.0012

Specification
Avg. C_P Deviations ≤ 0.01

'A' Average C _p 0.805	—	'B' Average C _p 0.804	=	Difference 0.001
-------------------------------------	---	-------------------------------------	---	---------------------

Specification
|Difference| ≤ 0.01

Does assembly meet specifications?

YES



If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \bar{C}_{P(A \text{ or } B)}|$$

All specifications are from EPA-800/9-76-005, section 3.1

Probe Cp= 0.805 Calibrated by: B. ARNOLD Date: 09/21/2009

Sample Probe Calibration

JP
67.8.14

Probe Type: M5 with S-Type Pitot

I.D. Number: 5G-9611

Project Number: _____

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	75	72	3	0.56%	%Difference ≤ 1.5
2	200°F-250°F	247	254	-7	0.99%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.547	0.808	0.815	0.001	
2	0.548	0.813	0.813	0.001	
3	0.548	0.811	0.814	0.000	
Side 'A' Average Probe C _{p(A)} =			0.8139	0.0008	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.544	0.810	0.812	0.002	
2	0.543	0.810	0.811	0.000	
3	0.541	0.812	0.808	0.002	
Side 'B' Average Probe C _{p(B)} =			0.8102	0.0014	

'A' Average C _p 0.814	---	'B' Average C _p 0.810	==	Difference 0.004	Specification (Difference) ≤ 0.01
-------------------------------------	-----	-------------------------------------	----	---------------------	--------------------------------------

Does assembly meet specifications?

YES



If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{p(S)} = C_{p(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{p(S)} - \overline{C_{p(A \text{ or } B)}}|$$

All specifications are from EPA 600/9-76-005, section 3.1

Probe Cp = 0.812

Calibrated by: R. ARNOLD

Date: 09/21/2009



Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-17

Project Number: _____

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69	71	-2	0.38%	%Difference ≤ 1.5
2	200°F-250°F	240	235	5	0.71%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99


Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.566	0.790	0.838	0.001	
2	0.564	0.797	0.833	0.004	
3	0.568	0.790	0.840	0.003	
Side 'A' Average Probe C _{p(A)} =			0.8368	0.0028	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.548	0.769	0.836	0.005	
2	0.543	0.774	0.829	0.002	
3	0.548	0.782	0.829	0.003	
Side 'B' Average Probe C _{p(B)} =			0.8315	0.0032	

'A' Average C _p 0.837	—	'B' Average C _p 0.831	=	Difference 0.006	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES



If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA 800/9-76-005, section 3.1.

Probe Cp= 0.834

Calibrated by: R ARNOLD

Date: 03/04/2010

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot I.D. Number: 67-10-3
 Project Number: _____

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	72	76	-4	0.75%	%Difference ≤ 1.5
2	200°F-250°F	230	224	6	0.87%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.557	0.800	0.826	0.000	
2	0.557	0.799	0.826	0.000	
3	0.556	0.798	0.826	0.000	
Side 'A' Average Probe C _{p(A)} =			0.8259	0.0002	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.562	0.810	0.825	0.001	
2	0.566	0.817	0.824	0.000	
3	0.562	0.811	0.824	0.000	
Side 'B' Average Probe C _{p(B)} =			0.8244	0.0004	

'A' Average C _p 0.826	—	'B' Average C _p 0.824	=	Difference 0.002	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES →

If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \bar{C}_{P(A \text{ or } B)}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.825 Calibrated by: R ARNOLD Date: 03/01/2010



AIR LIQUIDE

Air Liquide America
Specialty Gases LLC



SCOTT™

Zero

Shipped 1290 COMBERMERE STREET
 From: TROY MI 48083
 Phone: 248-589-2950 Fax: 248-589-2134

C E R T I F I C A T E O F A N A L Y S I S

CLEAN AIR ENGINEERING
 SCOTT BROWN
 500 WEST WOOD STREET

PROJECT #: 05-76361-001
 PO#: 24559-66-65000
 ITEM #: 0501813 AL
 DATE: 29May2009

PALATINE IL 60067

CYLINDER #: AAL14589
 FILL PRESSURE: 02000 PSIG

PURE MATERIAL: NITROGEN

CAS# 7727-37-9

GRADE: ZERO GAS

PURITY: 99.998%

IMPURITY
 THC

MAXIMUM
CONCENTRATIONS
 0.5 PPM

ANALYST: _____

Archie



Air Liquide America
Specialty Gases LLC



RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

P.O. No.: 57534-71-65000
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-78153-003
1290 COMBERMERE STREET
TROY, MI 48083

Customer

CLEAN AIR ENGINEERING
DON ALLEN
500 W. WOOD STREET
PALATINE IL 60067

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM033730 Certification Date: 27Jul2009 Exp. Date: 26Jul2012
Cylinder Pressure***: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	5.91 %	+/- 1%	Direct NIST and NMI
OXYGEN	14.1 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2300	01Nov2010	1D002807	23.04 %	CARBON DIOXIDE
NTRM 2350	01Dec2011	K018398	23.20 %	OXYGEN

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	16Jul2009	NDIR
CAI/110P/V03018	01Jul2009	PARAMAGNETIC

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE


Date: 27Jul2009	Response Unit: MV	
Z1 = 0.00000	R1 = 102.5000	T1 = 43.00000
R2 = 102.5000	Z2 = 0.00000	T2 = 43.00000
Z3 = 0.00000	T3 = 43.00000	R3 = 102.5000
Avg. Concentration: 5.909 %		



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.999992	
Constants:	A = -0.00322681
B = 0.13615338	C = -0.0005754
D = 1.40219E-05	E = 0

OXYGEN

Date: 28Jul2009	Response Unit: %	
Z1 = 0.00000	R1 = 23.20000	T1 = 14.06000
R2 = 23.20000	Z2 = 0.00000	T2 = 14.06000
Z3 = 0.00000	T3 = 14.06000	R3 = 23.20000
Avg. Concentration: 14.05 %		



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.999992	
Constants:	A = -0.00675568
B = 0.999864575	C = 0
D = 0	E = 0

APPROVED BY: _____

JEFF CROWEAU



Air Liquide America
Specialty Gases LLC



RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

P.O. No.: 57439-71-65000
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-76738-005
1290 COMBERMERE STREET
TROY, MI 48083

Customer

CLEAN AIR ENGINEERING
DON ALLEN
500 W. WOOD STREET
PALATINE IL 60067

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM046255 Certification Date: 09Jun2009 Exp. Date: 08Jun2012
Cylinder Pressure***: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	13.9 %	+/- 1%	Direct NIST and NMI
OXYGEN	6.01 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1675	02Oct2012	K006545	13.93 %	CARBON DIOXIDE
NTRM 2658	01Jan2010	K001290	10.03 %	OXYGEN

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	11May2009	NDIR
CAI/110P/V03018	01Jun2009	PARAMAGNETIC

ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE


Date: 09Jun2009	Response Unit: MV	
Z1=0.00000	R1=80.80000	T1=80.30000
R2=80.80000	Z2=0.00000	T2=80.30000
Z3=0.00000	T3=80.30000	R3=80.60000
Avg. Concentration:	13.86	%



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴
r = 0.999998
Constants: A = -0.00492643
B = 0.111614122 C = 0.00014738
D = 6.76093E-06 E = 0

OXYGEN

Date: 09Jun2009	Response Unit: %	
Z1=0.00000	R1=10.06000	T1=6.01000
R2=10.06000	Z2=0.00000	T2=6.01000
Z3=0.00000	T3=6.01000	R3=10.06000
Avg. Concentration:	6.005	%



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴
r = 0.999998
Constants: A = -0.00970246
B = 0.999816092 C = 0
D = 0 E = 0

APPROVED BY: 
JEFF PROTEAU

WHEELABRATOR SOUTH BROWARD, INC.
FT. LAUDERDALE, FL

CleanAir Project No: 10955-4

ASTM D 6866-08 AND 7459-08 CO₂ SAMPLING/ANALYSIS RESULTS

F

This Page Intentionally Left Blank

RESULTS

Air Flow Summary

Run Number	Run Date	Run Time	Steam Flow Klbs/hour	Flue Gas Temp Deg F	Air Flow ACFM	O ₂ %	CO ₂ %	CO ₂ Sample Rate (ppm) ¹	Stack Flow 2RSD (%)	Air Flow, DSCFM	Air Flow, DSCFM@ 7%O ₂
1-O-M5/29-1	3/23/2010	07:43-09:56	183.5	285	177.014	9.6	9.7	0.2	11.6%	94.473	77.905
1-O-M5/29-2	3/23/2010	10:31-12:45	183.9	285	179.820	9.4	9.9	0.2	12.2%	95.858	79.279
1-O-M5/29-3	3/23/2010	13:32-15:46	183.3	296	181.927	9.7	9.8	0.2	13.1%	97.155	78.073
1-O-M13B-1	3/22/2010	13:19-14:34	183.8	283	175.956	9.2	10.3	0.4	9.1%	94.620	79.849
1-O-M13B-2	3/22/2010	15:07-16:21	184.2	293	178.989	9.3	10.0	0.4	13.9%	94.737	78.993
1-O-M13B-3	3/22/2010	16:30-17:41	184.8	293	189.528	9.2	10.3	0.4	11.1%	90.888	76.628
		Average	183.9	284	178.674	9.4	10.0	NA	11.8%	94.688	78.338
2-O-M5/29-1	3/24/2010	07:53-10:05	183.9	285	173.477	9.5	9.9	0.2	9.3%	92.545	76.233
2-O-M5/29-2	3/24/2010	11:03-13:35	183.7	289	178.750	9.4	10.2	0.2	6.4%	94.353	78.130
2-O-M5/29-3	3/24/2010	14:12-16:22	183.3	297	180.724	9.8	9.9	0.2	10.0%	95.903	76.653
2-O-M13B-1	3/24/2010	07:53-08:11	184.3	292	175.045	9.4	10.0	0.4	6.9%	93.851	77.782
2-O-M13B-2	3/24/2010	09:37-10:54	183.8	292	174.991	9.3	10.0	0.4	9.8%	93.928	78.001
2-O-M13B-3	3/24/2010	11:24-12:46	183.6	293	170.950	9.4	10.1	0.4	11.0%	91.463	75.934
2-O-M23-1	3/22/2010	10:04-14:44	184.2	293	173.437	9.2	10.2	0.1	8.9%	93.381	78.534
2-O-M23-2	3/23/2010	07:36-12:10	184.2	297	178.662	9.6	9.7	0.1	8.9%	95.611	78.098
2-O-M23-3	3/23/2010	12:32-17:02	183.9	299	177.895	9.3	10.2	0.1	10.8%	94.124	78.685
		Average	183.9	295	176.937	9.4	10.0	NA	8.9%	93.695	77.581
3-O-M5/29-1	3/22/2010	08:47-11:05	184.1	297	184.927	10.0	9.4	0.2	11.7%	98.675	78.178
3-O-M5/29-2	3/22/2010	11:43-13:57	184.0	286	170.489	9.7	9.8	0.2	9.0%	92.737	74.723
3-O-M5/29-3	3/22/2010	14:24-16:39	184.2	295	173.572	9.5	10.0	0.2	9.1%	94.492	77.497
3-O-M13B-1	3/23/2010	12:41-13:54	183.8	297	174.143	9.8	9.6	0.4	10.7%	92.603	74.282
3-O-M13B-2	3/23/2010	14:31-15:38	184.4	286	178.138	9.9	9.6	0.4	12.3%	96.238	75.952
3-O-M13B-3	3/23/2010	15:54-17:02	183.9	286	168.080	9.4	10.2	0.4	6.5%	89.943	73.586
		Average	184.1	286	174.727	9.7	9.6	NA	8.9%	94.148	76.703
Facility Average			184.0	286	176.779	9.6	9.9	NA	10.2%	94.211	77.201

¹ CO₂ gas sample flow rate was within 10% of initial flow rate throughout all test runs.

In accordance with the EPA Greenhouse Gas (GHG) Monitoring, Reporting and Recordkeeping Regulations (MRRR) an integrated gas sample (IGS) of all FF Outlet isokinetic sample trains was collected in accordance with ASTM Method 7459-08.

The IGS bags were all leak checked prior to use in accordance with the method. All samples were at the FF Outlets using Method 3 in conjunction with Method 5/29, 23 and 13B isokinetic sampling trains. All of the test run IGS bags that met the 2 times relative standard deviation (2RSD) stack flow rate criteria (<30%) were proportionally combined into a single Tedlar® bag for analysis by Beta Analytic, Inc for Biogenic CO₂ utilizing ASTM Method D6866-08.

All of the IGS bags were collected within 10% of the initial sample rate using the orifice off of the dry gas meter. The IGS bag collection rate is recorded on the field data sheets presented in Appendix G. All of the samples contained approximately 15L of stack gas. The stack flow rate 2RSD for each isokinetic test run is calculated from the square root of the pitot readings and presented in the field data printouts (Appendix H) of this report. All outlet isokinetic samples met the 2RSD requirements.



ISO-17025 Accredited Testing Laboratory

PJLA ISO/IEC 17025:2005 Testing Accreditation #

Beta Analytic Inc.
4985 SW 74 Court
Miami, Florida 33155 USA
Tel: 305-667-5167
Fax: 305-663-0964
info@betalabservices.com
www.betalabservices.com

Explanation of Results

Biomass Analysis using ASTM-D6866

The application of ASTM-D6866 to derive a "Biomass CO₂ content" for carbon dioxide effluents is built upon the same concepts as those used by the US Department of Agriculture to derive the biobased content of manufactured products containing biomass carbon. It is done by comparing a relative amount of radiocarbon (C¹⁴) in an unknown sample to that of a modern reference standard. The ratio in contemporary biomass will be 100% and the ratio in fossil materials will be zero. Carbon dioxide derived from combustion of a mixture of present day biomass and fossil carbon will yield an ASTM-D6866 result that directly correlates to the amount of biomass carbon combusted and carbon-neutral CO₂ generated.

The modern reference standard is a National Institute of Standards and Technology (NIST) standard with a defined radiocarbon content of 100% contemporary carbon for the year AD 1950. AD 1950 was chosen since it represented a time prior to thermo-nuclear weapons testing which introduced large amounts of excess radiocarbon into the atmosphere with each explosion (termed "bomb carbon"). This was a logical point in time to use as a reference since this excess bomb carbon would change with increased or decreased weapons testing. A fixed correction for this effect is applied per the ASTM-D6866 requirements, applying specifically to carbon removed from the atmospheric CO₂ reservoir since about 1996. Carbon removed prior to about 1996 will contain elevated radiocarbon signatures, not directly applicable to the ASTM-D6866 correction. Typical areas to which the correction may not apply are landfills more than 5-10 years old and to trees which began to grow more than 20 years ago.

Carbon dioxide effluent derived from combustion of 100% present day biomass will yield results of 100% renewable content. Carbon dioxide effluent derived from the combustion of 100% fossil fuel will yield results of 0% renewable content. Carbon dioxide produced from mixed fuels (biomass plus fossil fuel) will yield a percentage result in direct proportion to the biomass carbon consumed vs. fossil carbon consumed in the combustion. The final result is referred to as the MEAN BIOMASS CO₂ CONTENT and assumes all the carbon in the carbon dioxide was derived from either present day living or fossil sources.

The results provided in this report involved materials provided without any source information. This situation is highly probable in a real life situation. The MEAN VALUE quoted in this report encompasses an absolute range of 6% (plus and minus 3% on either side of the MEAN BIOMASS CO₂ CONTENT to account for variations in end component radiocarbon signatures (a conservative approximation). It is presumed that all materials are present day or fossil in origin and that the desired result is the amount of biomass component "present" in the material, not the amount of biomass material "used" in the manufacturing process. The most conservative interpretation of the reported percentages is as maximum values.

ASTM-D6866 results relate directly to the percentage carbon-neutral CO₂ in an incineration effluent. A value of 71% renewable content measured on CO₂ effluent would indicate that 71% of the exhausted CO₂ was from biomass (29% from fossil fuel). It does not represent the weight of biomass combusted or the weight of fossil fuel combusted. This is advantageous since the weight of the fuels only indirectly relate to the up-take of carbon dioxide from the atmosphere. The respiration uptake compound was carbon dioxide and the combustion effluent was carbon dioxide. The ASTM-D6866 result directly and specifically relates to the amount of carbon-neutral CO₂ consumed and expelled.



ISO-17025 Accredited Testing Laboratory

PJLA ISO/IEC 17025:2005 Testing Accreditation # 59423

Beta Analytic Inc.
4985 SW 74 Court
Miami, Florida 33155 USA
Tel: 305-667-5167
Fax: 305-663-0964
info@betalabservices.com
www.betalabservices.com

Summary of Results : Biogenic CO2 Determination using ASTM-D6866

Submitter: Mr. Scott A. Brown	Date Received:	March 25, 2010
Company: Clean Air Engineering	Date Reported:	March 29, 2010

Laboratory Number	Submitter Label	Material	Mean Biomass CO2 Content*
Beta-277427	WHEELABRATOR South Broward - 3/22-24/10	Biogenic CO2	65%

* ASTM-D6866 cites precision on the Mean Biomass CO2 Content as +/- 3% (absolute). This is the most conservative estimate of error in the measurement of complex biomass containing solids and liquids based on empirical results. Real precision for readily combustible and homogenous materials (e.g. gasoline) and especially samples recieved as CO2 (e.g. flue gas or CEMS exhaust) can be as low as +/- 0.5-2%. The result only applies to the analyzed material. Fluctuations in carbon content within a batch of product, gasoline or flue gas must be determined separately (e.g. averaged measurements of multiple solids or liquids, and single measurement of the combination of gas aliquots collected over time). The accuracy of the result as it applies to the analyzed product, fuel, or flue gas relies upon all the carbon in the analyzed material originating from either recently respired atmospheric carbon dioxide (within the last decade) or fossil carbon (more than 50,000 years old). "Percent biomass" specifically relates % renewable (or fossil) carbon to total carbon, not to total mass or molecular weight. Mean Biomass CO2 estimates greater than 100% are assigned a value of 100% for simplification.



ISO-17025 Accredited Testing Laboratory

PJLA ISO/IEC 17025:2005 Testing Accreditation #


Beta Analytic Inc.
4985 SW 74 Court
Miami, Florida 33155 USA
Tel: 305-667-5167
Fax: 305-663-0964
info@betalabservices.com
www.betalabservices.com

Report of Biomass CO2 Content Analysis using ASTM-D6866

Submitter: Clean Air Engineering
Submitter Label: WHEELABRATOR South Broward - 3/22-24/10
Laboratory Number: Beta-277427
Material Analyzed: Biogenic CO2
Date Received: March 25, 2010
Date Reported: March 29, 2010

Biomass CO2: 65% *
(carbon-neutral CO2) (renewable carbon to total carbon)

Proportions Biomass CO2 vs. Fossil CO2
indicated by C14 content



* ASTM-D6866 cites precision on the mean Biomass CO2 Result as +/- 3% (absolute). This is the most conservative estimate of error in the measurement of complex biomass containing solids and liquids based on empirical results. Real precision for readily combustible and homogenous materials (e.g. gasoline) and especially samples recieved as CO2 (e.g. flue gas or CEMS exhaust) can be as low as +/- 0.5-2%. The result only applies to the analyzed material. Fluctuations in carbon content within a batch of product, gasoline or flue gas must be determined separately (e.g. averaged measurements of multiple solids or liquids, and single measurement of the combination of gas aliquots collected over time). The accuracy of the result as it applies to the analyzed product, fuel, or flue gas relies upon all the carbon in the analyzed material originating from either recently respired atmospheric carbon dioxide (within the last few decades) or fossil carbon (more than 50,000 years old). "Percent biomass" specifically relates % renewable (or fossil) carbon to total carbon, not to total mass or molecular weight. Mean Biomass CO2 estimates greater than 100% are assigned a value of 100% for simplification.

This Page Intentionally Left Blank