



**Wheelabrator North Broward**

A Waste Management Company

2600 Wiles Road  
Pompano Beach, FL 33073  
(954) 971-8701 Tel  
(954) 971-8703 Fax

**RECEIVED**

**OCT 31 2013**

**DIVISION OF AIR  
RESOURCE MANAGEMENT**

October 28, 2013

CERTIFIED MAIL #70051160000234575598

Office of Permitting and Compliance  
Division of Air Resource Management – DEP  
2600 Blair Stone Road, Mail Stop 5500  
Tallahassee, FL 32399  
Attention: Syed Arif

Re: Wheelabrator North Broward  
Powdered Activated Carbon Injection System – Completion of Construction

Dear Mr. Arif:

As per Air Permit No. 0112120-012-AC/PSD-FL-112D, Wheelabrator North Broward completed construction of the powdered activated carbon system on October 23, 2013.

Construction commenced on August 2, 2013 with the initial removal of asphalt for the silo foundation. Delivery piping was installed in September 6, 2013. The silo foundation was completed with the silo set in place on September 9, 2013. Electrical and control wiring was terminated in September 25, 2013. Diverter valves, lances, silo equipment and accessories were installed on September 27, 2013. Carbon was placed in the silo on October 15, 2013 and the final signal tie in to the CEMS system was completed on October 23, 2013.

The facility shall continue doing shake down/start up activities on the system throughout the remainder of 2013. Compliance demonstration shall be completed in conjunction with the 2014 annual compliance stack testing, which will be completed in March of 2014.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, or if further information is required, please feel free to contact me at (954) 971-8701, ext. 212.

Sincerely,

Jim Epsilantis  
Plant Manager

cc:

Chuck Faller  
Rob French – MPI  
Ram Tewari – BCWRS





**Wheelabrator North Broward**

A Waste Management Company

2600 Wiles Road  
Pompano Beach, FL 33073  
(954) 971-8701 Tel  
(954) 971-8703 Fax

October 28, 2013

CERTIFIED MAIL #70073020000226892288

Mr. Joseph Lurix  
Air Program Administrator  
Florida Department of Environmental Protection  
Southeast District  
400 North Congress Ave., Suite 200  
West Palm Beach, FL 33401

Re: Wheelabrator North Broward  
F.A.C. 62-296.416 Quarterly Mercury Stack Testing  
Third Quarter of 2013, Report Submittal

Dear Mr. Lurix:

As required by F.A.C. 62-296.416, please find enclosed the 2013 third quarter report on mercury stack testing which was conducted on Unit #2.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 971-8701.

Sincerely,

Jim Epsilantis  
Plant Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement Branch, Air Enforcement Section CERTIFIED MAIL #70051160000234575567  
FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section, CERTIFIED MAIL #70051160000234575574  
Broward County Department of Planning and Environmental Protection, Air Quality Division CERTIFIED MAIL #70051160000234575581  
Chuck Faller (with)  
Rob French - MPI - (with)  
Ram Tewari - BCWRS (without)





Wheelabrator North Broward, Inc.  
2600 Wiles Road  
Pompano Beach, FL 33073

---

**REPORT ON MERCURY TESTING**


Performed for:  
**WHEELABRATOR NORTH BROWARD, INC.**  
**UNIT 2 FF OUTLET**  
**POMPANO BEACH, FL**

Client Reference No: Service Agreement  
CleanAir Project No: 12218-6  
Revision 0: October 23, 2013


---

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Submitted by,

  
\_\_\_\_\_  
Scott Brown  
Senior Project Manager  
sbrown@cleanair.com  
(800) 627-0033 ext. 4544

Reviewed by,

  
\_\_\_\_\_  
Mark Roach, P.E.  
Engineering Group Technical Leader  
mroach@cleanair.com  
(800) 627-0033 ext. 4599

**REVISION HISTORY**

**REPORT ON MERCURY TESTING**

***DRAFT REPORT REVISION HISTORY***

<b>Revision:</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
D0a	10/22/13	All	Draft version of original document.

***FINAL REPORT REVISION HISTORY***

<b>Revision:</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
0	10/23/13	All	Final version of original document.

**CONTENTS**

<b>1</b>	<b>PROJECT OVERVIEW</b> .....	<b>1-1</b>
	INTRODUCTION .....	1-1
	Key Project Participants .....	1-1
	Test Program Parameters .....	1-1
	TEST PROGRAM SYNOPSIS.....	1-2
	Test Schedule.....	1-2
	Table 1-1: Schedule of Activities .....	1-2
	Results Summary .....	1-2
	Table 1-2: Summary of Test Results.....	1-2
<b>2</b>	<b>RESULTS</b> .....	<b>2-1</b>
	Table 2-1: Unit 2 FF Outlet – Mercury .....	2-1
	Table 2-2: Quality Assurance and Quality Control.....	2-2
<b>3</b>	<b>DESCRIPTION OF INSTALLATION</b> .....	<b>3-1</b>
	PROCESS DESCRIPTION .....	3-1
	Figure 3-1: General Process Schematic.....	3-1
	Figure 3-2: Process Schematic .....	3-2
	DESCRIPTION OF SAMPLING LOCATION .....	3-3
	Table 3-1: Sampling Points .....	3-3
	Figure 3-3: Unit 2 FF Outlet Sampling Point Determination (EPA Method 1) .....	3-3
<b>4</b>	<b>METHODOLOGY</b> .....	<b>4-1</b>
	Table 4-1: Summary of Sampling Procedures.....	4-1
<b>5</b>	<b>APPENDIX</b> .....	<b>5-1</b>
	TEST METHOD SPECIFICATIONS .....	A
	SAMPLE CALCULATIONS .....	B
	PARAMETERS .....	C
	QA/QC DATA.....	D
	FIELD DATA .....	E
	FIELD DATA PRINTOUTS .....	F
	LABORATORY DATA.....	G
	PLANT DATA.....	H

**PROJECT OVERVIEW**

1-1

**INTRODUCTION**

Wheelabrator North Broward, Inc. operates a refuse-to-energy facility, located in Pompano Beach, Florida. The facility's emission levels are regulated by the Florida Department of Environmental Protection (DEP). Wheelabrator North Broward contracted Clean Air Engineering (CleanAir) to perform a compliance test program at its municipal waste combustor (MWC) facility in Pompano Beach, Florida. Testing was conducted in accordance with 40 CFR 60, Subpart Cb, and applicable sections of PSD-FL-112(B) and PA86-22. The sampling was conducted at the Unit 2 Fabric Filter (FF) Outlet on September 25 and 26, 2013.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (US EPA) and the DEP.

**Key Project Participants**

Individuals responsible for coordinating and conducting the test program were:

- C. Faller – Wheelabrator North Broward, Inc.
- S. Brown – CleanAir

**Test Program Parameters**

The testing included the following emissions measurements:

- flue gas composition (e.g., O<sub>2</sub>, CO<sub>2</sub>, H<sub>2</sub>O)
- flue gas flow rate
- flue gas temperature
- mercury (Hg)

Chuck Faller of Wheelabrator North Broward provided all the process (operating) data. This data is presented in its entirety in Appendix H.

The CleanAir test crew consisted of Sean Dooley, and all equipment utilized for testing was manufactured by CleanAir.

**PROJECT OVERVIEW**

**TEST PROGRAM SYNOPSIS**

**Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:  
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Unit 2 FF Outlet	USEPA Method 29	Mercury	09/25/13	10:06	12:27
2	Unit 2 FF Outlet	USEPA Method 29	Mercury	09/25/13	12:45	15:14
3	Unit 2 FF Outlet	USEPA Method 29	Mercury	09/26/13	07:41	09:58
4	Unit 2 FF Outlet	USEPA Method 29	Mercury	09/26/13	10:18	12:40

**Results Summary**

Table 1-2 summarizes the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown in Tables 2-1 and 2-2 on pages 2-1 and 2-2.

**Table 1-2:  
Summary of Test Results**

Source Constituent	Sampling Method	Average Emission	Permit Limit <sup>1</sup>
Unit 2 FF Outlet Mercury (µg/dscm @7% O <sub>2</sub> )	EPA M29	8.2	50

<sup>1</sup> Limit obtained from the facility's Title V Permit No. 0112120-010-AV and Subpart Cb as of April 28, 2009.

During the compliance testing, Unit 2 was operated within 10% of the 186,000 lb/hr maximum steam flow rating. The Unit 2 boiler and air pollution control equipment are in a well-maintained operating condition. Normal operating parameters for the fabric filters are a pressure drop of 2 to 7 inches of water and scrubber dilution water flow varies from 0 to 40 gallons per minute (gpm). The equipment operated within these ranges during compliance testing. Table 2-1 on page 2-1 presents the boiler's steam output for every test run.

Four Method 29 test runs for mercury were performed at the Unit 2 FF Outlet, and all four runs were averaged to determine compliance with the permit limit.

**PROJECT OVERVIEW**

**1-3**

An attempt was made to perform this testing on September 10 and 11, 2013. However, due to the lack of dry garbage and the plant's subsequent inability to hold the unit above 50% of its rated steam flow, the testing was rescheduled for September 25. A single 125-minute test run was completed during the initial mobilization. The samples created from this test run have been archived at Element One in Wilmington, North Carolina.

---

*End of Section 1 – Project Overview*



**RESULTS**

2-1

**Table 2-1:  
Unit 2 FF Outlet – Mercury**

Run No.	1	2	3	4	Average
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)	10:06	12:45	07:41	10:18	
Stop Time (approx.)	12:27	15:14	09:58	12:40	
<b>Process Conditions</b>					
R <sub>p</sub> Steam Production Rate - (Klbs/hour)	180.5	179.8	183.1	184.1	<b>181.8</b>
P <sub>1</sub> Fabric Filter Inlet Temperature - (°F)	280	283	292	292	<b>287</b>
<b>Gas Conditions</b>					
O <sub>2</sub> Oxygen (dry volume %)	8.4	8.7	8.5	8.5	<b>8.6</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.8	10.6	10.6	10.5	<b>10.6</b>
T <sub>s</sub> Sample temperature (°F)	273	272	286	285	<b>279</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	27.42	27.75	28.08	28.63	<b>27.97</b>
<b>Gas Flow Rate</b>					
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	179,000	183,000	184,000	180,000	<b>181,000</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	91,000	92,800	91,100	88,600	<b>90,900</b>
<b>Sampling Data</b>					
V <sub>std</sub> Volume metered, standard (dscf)	74.29	75.01	72.77	72.89	<b>73.74</b>
%I Isokinetic sampling (%)	101.4	100.4	99.2	102.2	<b>100.8</b>
<b>Laboratory Data</b>					
m <sub>n-1b</sub> Fraction 1B Prorated (µg)	0.134	0.124	0.115	<0.100	
m <sub>n-2b</sub> Fraction 2B Prorated (µg)	11.911	21.145	12.061	10.652	
m <sub>n-3a</sub> Fraction 3A Prorated (µg)	<0.200	<0.200	<0.200	<0.200	
m <sub>n-3b</sub> Fraction 3B Prorated (µg)	<0.500	<0.500	<0.500	<0.500	
m <sub>n-3c</sub> Fraction 3C Prorated (µg)	1.178	2.475	0.466	0.462	
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	13.224	23.744	12.642	11.114	
<b>Mercury Results - Total</b>					
C <sub>sd</sub> Concentration (µg/dscm)	6.3	11.2	6.1	5.38	<b>7.2</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	7.0	12.8	6.9	6.0	<b>8.2</b>
E <sub>lb/hr</sub> Rate (lb/hr)	2.1E-03	3.9E-03	2.1E-03	1.8E-03	<b>2.5E-03</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	6.3E-06	1.1E-05	6.2E-06	5.4E-06	<b>7.3E-06</b>

**RESULTS**

**Table 2-2:  
Quality Assurance and Quality Control**

Run Number	RPD RESULTS					
	FH Front Half	BH H <sub>2</sub> O <sub>2</sub> /HNO <sub>4</sub>	A Empty Impinger	B KMnO <sub>4</sub>	C HCl	
U2 Run 1	2.8%	0.8%	NA	NA	0.8%	
U2 Run 2	2.4%	0.1%	NA	NA	0.8%	
U2 Run 3	3.6%	0.3%	NA	NA	0.5%	
U2 Run 4	NA	0.9%	NA	NA	0.9%	
Field Blank	NA	NA	NA	NA	NA	
Reagent Blank	NA	NA	NA	NA	NA	
<b>Sample Spike and Recovery</b>						
U2 Run 3	#1	101%	99%	100%	89%	95%
	#2	100%	98%	100%	89%	95%
<b>Blanks</b>						
Field Blank	#1	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank	#1	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4

*End of Section 2 – Results*

**DESCRIPTION OF INSTALLATION**

3-1

**PROCESS DESCRIPTION**

The North Broward Resource Recovery facility operates three (3) 750 tons-per-day municipal refuse-fired, water-wall boiler trains. The trains were manufactured by Babcock & Wilcox to produce electricity for sale to a local utility company.

Each boiler is equipped with the following air pollution controls (APCs):

- 1) A selective non-catalytic reduction (SNCR) for nitrogen oxides (NO<sub>x</sub>) control;
- 2) A spray dry absorber (SDA) for acid gas removal;
- 3) A fabric filter for the control of particulate emissions.

Each fabric filter is followed by an induced draft (ID) fan that directs the flue gas to a dedicated flue in a common stack. The APC equipment is manufactured by Wheelabrator Air Pollution Control, Inc. All APC equipment is generally in excellent condition. Each boiler is also equipped with a continuous emission monitoring (CEM) system to demonstrate the compliance with sulfur dioxide (SO<sub>2</sub>), NO<sub>x</sub> and carbon monoxide (CO) limits.

Figure 3-1 shows a general schematic for the facility. All of the testing reported in this document was performed at the Unit 2 FF Outlet, as shown in Figure 3-2 on page 3-2.




Figure 3-1: General Process Schematic

**DESCRIPTION OF INSTALLATION**

3-2




Figure 3-2: Process Schematic


**DESCRIPTION OF INSTALLATION**

**DESCRIPTION OF SAMPLING LOCATION**

Sampling point locations were determined according to EPA Method 1. Table 3-1 outlines the sampling point configurations. Figure 3-3 illustrates the sampling points and orientation of sampling ports for the source tested in the program.

**Table 3-1:  
Sampling Points**

Location	Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
Unit 2 FF Outlet	Mercury	29	1-4	5	5	5	125	3-3



Equivalent Duct diameters upstream from flow disturbance (A): 0.5 Limit: 0.5  
 Equivalent Duct diameters downstream from flow disturbance (B): 2.0 Limit: 2.0

**Figure 3-3: Unit 2 FF Outlet Sampling Point Determination (EPA Method 1)**

**METHODOLOGY**

4-1

Clean Air Engineering followed procedures as detailed in US EPA Methods 1, 2, 3, 3B, 4 and 29. The following table summarizes the methods and their respective sources.

**Table 4-1:  
Summary of Sampling Procedures**

Title 40 CFR Part 60 Appendix A

---

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3B	"Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 29	"Determination of Metals Emissions from Stationary Sources"

---

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and are located on the internet at <http://ecfr.gpoaccess.gov>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and as prescribed in CleanAir's internal Quality Manual. Results of all QA/QC activities performed by CleanAir are summarized in Appendix D.

---

*End of Section 4 – Methodology*

WHEELABRATOR NORTH BROWARD, INC.  
POMPANO BEACH, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-6

**APPENDIX**

**5-1**

TEST METHOD SPECIFICATIONS .....A  
SAMPLE CALCULATIONS.....B  
PARAMETERS .....C  
QA/QC DATA.....D  
FIELD DATA .....E  
FIELD DATA PRINTOUTS .....F  
LABORATORY DATA.....G  
PLANT DATA.....H

**TEST METHOD SPECIFICATIONS**

A

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SB

Date: 10/23





**This Page Intentionally Left Blank**

# Specification Sheet for

# EPA Method 29

Source Location Name(s) Unit 2 FF Outlet  
 Pollutant(s) to be Determined Mercury  
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate


	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	125 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
<b>Sampling Probe</b>		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.814
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Glass Fiber	Quartz Fiber
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

# Specification Sheet for

# EPA Method 29

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	7	7
<b>Impinger Stem Types</b>		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 7	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 8	Modified Greenburg-Smith	Modified Greenburg-Smith
<b>Gas Density Determination</b>		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	Orsat
<b>Sample Recovery Information</b>		
Probe Brush Material	Non-metallic swab or bristle	Teflon Mat
Probe Rinse Reagent	0.1N Nitric Acid	0.1 N Nitric Acid
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Polyethylene or glass	Polyethylene
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Polyethylene
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Impinger Wash Bottle	Glass or Teflon	Teflon
Impinger Storage Container	See Recovery Flow Chart	See Recovery Flow Chart
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See Method 29 Analytical Flow Chart	For Metals Analysis
Front-Half Rinse Preparation	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Back-Half Analysis	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Additional Analysis	None	None


# EPA Method 29 Sampling Train Configuration



Impinger Contents


Impinger 1	Empty
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>
Impinger 7	Silica Gel

## EPA Method 29 Glassware Preparation Procedures




# EPA Method 29 Sample Recovery Flowchart (includes Mercury)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)
- Collect one complete blank set per field test



**EPA Method 29**  
**Analytical Flowchart**  
 (includes Mercury)



**SAMPLE CALCULATIONS**

B

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SB

Date: 10/23





**This Page Intentionally Left Blank**

**USEPA Method 29 (Mercury)  
 Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

101113 085411  
 M

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	596.4	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	28.07	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	29.90	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	95.46	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	77.75	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	1.0031	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.26	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	74.286	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	29.90	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-10.00	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.16	in. Hg

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	272.68	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.16	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.16	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.16	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	74.286	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	28.07	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2742	
		=	27.42	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.16	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.16	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2742	
$B_w$	= actual water vapor in gas	=	0.2742	
		=	27.42	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.8	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	8.4	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.77	%

10. Molecular weight of dry gas stream (lb/lb·mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb·mole)	=	44.00	lb/lb·mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb·mole)	=	32.00	lb/lb·mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb·mole)	=	28.00	lb/lb·mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.8	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	8.4	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.8	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb·mole)	=	30.07	lb/lb·mole

11. Molecular weight of sample gas (lb/lb·mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2742	
$M_d$	= dry molecular weight of sample gas (lb/lb·mole)	=	30.07	lb/lb·mole
$M_{H_2O}$	= molecular weight of water (lb/lb·mole)	=	18.00	lb/lb·mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb·mole)	=	26.76	lb/lb·mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)\left(\sqrt{\Delta P}\right)\left(\sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}}\right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.81	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb·mole)	=	26.76	lb/lb·mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.16	in. Hg
$T_s$	= average sample gas temperature (°F)	=	272.68	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.690	$\sqrt{\text{in. H}_2\text{O}}$
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	46.50	ft/sec

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	64.00	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	46.50	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	178,542	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a)\left(\frac{P_s}{29.92}\right)\left(\frac{68 + 460}{T_s + 460}\right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	178,542	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.16	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	272.7	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	125,417	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2742	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	125,417	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	91,026	dscfm

16. Dry flow of sample gas corrected to 7%O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q <sub>std</sub>	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	91,026	dscfm
O <sub>2</sub>	= proportion of oxygen in the gas stream by volume (%)	=	8.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%

Q <sub>std7</sub>	= volumetric flow rate at STP and 7%O <sub>2</sub> , dry basis (dscfm)	=	81,639	dscfm
-------------------	------------------------------------------------------------------------	---	--------	-------

17. Hourly time basis conversion of volumetric flow rate (Q<sub>std</sub> example)

$$Q_{std-hr} = (Q_{std-min}) (60)$$

Where

Q <sub>std-min</sub>	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	91,026	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

Q <sub>std-hr</sub>	= volumetric flow rate, hourly basis (dscf/hr)	=	5,461,545	dscf/hr
---------------------	------------------------------------------------	---	-----------	---------

18. Metric Conversion of Gas Volumes (Q<sub>std</sub> example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

Q <sub>std-english</sub>	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	91,026	dscfm
35.31	= conversion factor (ft <sup>3</sup> /m <sup>3</sup> )	=	35.31	ft <sup>3</sup> /m <sup>3</sup>
60	= conversion factor (min/hr)	=	60	min/hr

Q <sub>std-metric</sub>	= volumetric flow rate, metric units (m <sup>3</sup> /hr)	=	154,674	dry std m <sup>3</sup> /hr
-------------------------	-----------------------------------------------------------	---	---------	----------------------------

19. Standard to Normal Conversion of Gas Volumes (Q<sub>std</sub> example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

Q <sub>std-metric</sub>	= volumetric flow rate, metric units (dry std m <sup>3</sup> /hr)	=	154,674	dry std m <sup>3</sup> /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	

Q <sub>Normal</sub>	= volumetric flow rate, metric units (dry Nm <sup>3</sup> /hr)	=	144,128	dry Nm <sup>3</sup> /hr
---------------------	----------------------------------------------------------------	---	---------	-------------------------

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T}_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n}{144}\right)^2(\theta)(\Theta)(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.275	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2742	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.16	in. Hg
$\overline{T}_s$	= average sample gas temperature (°F)	=	272.7	°F
$V_{mstd}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	74.286	dscf
$V_s$	= sample gas velocity (ft/sec)	=	46.50	ft/sec
$\theta$	= total sampling time (min)	=	125	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	101.36	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\Theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{@})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\theta$	= total sampling time (min)	=	125	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	77.75	dcf
$T_m$	= average dry gas meter temperature (°F)	=	95.46	°F
$\Delta H_{@}$	= dry gas meter orifice coefficient	=	1.7992	
$P_{bar}$	= barometric pressure (in. Hg)	=	29.90	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.264	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.07	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.124	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	1.0160	

# LOGIC FOR TREATING DETECTION LIMITS

(mercury only)

## 1. Logic for Determining Total Blank ( $m_{Total-B}$ ) from 5 Fractions

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 fractions are ND	<b>CASE 3</b> All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < \text{Sum ND}$
$ND = 1x$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < \text{Sum ND}$
$ND = 0.5x$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < 0.5 \text{ Sum ND}$

## 2. Logic for Determining Total Sample ( $m_{Total-S}$ ) from 5 Fractions

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 fractions are ND	<b>CASE 3</b> All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = \text{Sum D}$	$m_{Total-S} = < \text{Sum ND}$
$ND = 1x$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = < [\text{Sum D} + \text{Sum ND}]$	$m_{Total-S} = < \text{Sum ND}$
$ND = 0.5x$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = < [\text{Sum D} + 0.5 \text{ Sum ND}]$	$m_{Total-S} = < 0.5 \text{ Sum ND}$

## 3. Logic for Determining Maximum Allowable Blank Correction ( $m_{T-B-allow}$ )

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 sample fractions are ND	<b>CASE 3</b> All 5 fractions are ND	<b>CASE 4</b> Any type of fractions
<b>Rule</b>	$m_{Total-B} = D$	$m_{Total-B} = D$	$m_{Total-B} = D$	$m_{Total-B} = ND$
$ND = 0$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$
$ND = 1x$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$
$ND = 0.5x$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$

\* M29 rule using only detected sample quantities for logical comparisons.

## 4. Logic for Determining Blank-Corrected Sample Amount ( $m_n$ )

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 sample fractions are ND	<b>CASE 3</b> All 5 fractions are ND	<b>CASE 4</b> Any type of fractions
	$m_{Total-S} - m_{T-B-allow} \geq \text{MIN(MDL)}$	$m_{Total-S} - m_{T-B-allow} \geq \text{MIN(MDL)}$	$m_{Total-S}$ and $m_{T-B-allow}$ anything	$m_{Total-S} - m_{T-B-allow} < \text{MIN(MDL)}$
<b>Rule</b>				
$ND = 0$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN(MDL)}$
$ND = 1x$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < [m_{Total-S} - m_{T-B-allow}]$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN(MDL)}$
$ND = 0.5x$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < [m_{Total-S} - m_{T-B-allow}]$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN(MDL)}$

### Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

MIN(MDL) = lowest quantity of all detection limits for 5 fractions.



**USEPA Method 29 (Mercury)  
 Mercury Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

101113 085411  
 M

1. Total blank amount (µg)

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

$m_{1b-B}$	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
$m_{2b-B}$	= mercury amount in blank for Fraction 2b	=	<0.2000	µg
$m_{3a-B}$	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
$m_{3b-B}$	= mercury amount in blank for Fraction 3b	=	<0.5000	µg
$m_{3c-B}$	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg

2. Total sample amount (µg)

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	0.1344	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	11.9109	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.5000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	1.1783	µg
$m_{total-S}$	= total amount of mercury in sample	=	13.2236	µg

3. Allowable blank correction (µg)

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = MAX [0.6, MIN (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	13.2236	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	0.6612	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total (µg)

$$m_n = m_{total-S} - m_{T-B-allow}$$

Where:

$m_{total-S}$	= total amount of mercury in sample	=	13.2236	µg
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg
$m_n$	= total mercury in sample corrected for allowable blank	=	13.2236	µg

5. Sample corrected for allowable blank - Prorated for each fraction (µg)

$$m_{n-i} = \left( \frac{m_{i-S}}{m_{total-S}} \right) (m_n)$$

Where:

$m_n$	= total mercury in sample corrected for allowable blank	=	13.2236	µg
$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	0.1344	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	11.9109	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.5000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	1.1783	µg
$m_{total-S}$	= total amount of mercury in sample	=	13.2236	µg
$m_{n-1b}$	= mercury corrected for blank - prorated for Fraction 1b	=	0.1344	µg
$m_{n-2b}$	= mercury corrected for blank - prorated for Fraction 2b	=	11.9109	µg
$m_{n-3a}$	= mercury corrected for blank - prorated for Fraction 3a	=	<0.2000	µg
$m_{n-3b}$	= mercury corrected for blank - prorated for Fraction 3b	=	<0.5000	µg
$m_{n-3c}$	= mercury corrected for blank - prorated for Fraction 3c	=	1.1783	µg

**USEPA Method 29 (Mercury)  
 Mercury Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

101113 085647  
 M\_M

1. Mercury concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 74.2864	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$C_{sd}$	= mercury concentration (lb/dscf)	= 3.9251E-10	lb/dscf

2. Mercury concentration ( $\mu\text{g/dscm}$ )

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 74.2864	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
$C_{sd}$	= mercury concentration ( $\mu\text{g/dscm}$ )	= 6.2855E+00	$\mu\text{g/dscm}$

3. Mercury concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 74.2864	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	= 1000	$\mu\text{g/mg}$
$C_{sd}$	= mercury concentration (mg/dscm)	= 6.2855E-03	mg/dscm

4. Mercury concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 74.2864	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

$C_{sd}$	= mercury concentration ( $\mu\text{g}/\text{Nm}^3$ dry)	= 6.7454E+00	$\mu\text{g}/\text{Nm}^3$ dry
----------	----------------------------------------------------------	--------------	-------------------------------

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 3.9251E-10	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 8.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

$C_{sdx}$	= mercury concentration corrected to x% oxygen (lb/dscf)	= 4.3764E-10	lb/dscf @ x% $O_2$
-----------	----------------------------------------------------------	--------------	--------------------

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 3.9251E-10	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.8	%

$C_{sdy}$	= mercury conc. corrected to y% carbon dioxide (lb/dscf)	= 4.3612E-10	lb/dscf @ y% $CO_2$
-----------	----------------------------------------------------------	--------------	---------------------

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 3.9251E-10	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 91,026	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 178,542	acfm

$C_a$	= mercury concentration at actual gas conditions (lb/acf)	= 2.0011E-10	lb/acf
-------	-----------------------------------------------------------	--------------	--------

8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.2864	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	91,026	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= mercury emission rate (lb/hr)	=	2.1437E-03	lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.2864	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	91,026	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	=	60	sec/min
$E_{g/s}$	= mercury emission rate (g/s)	=	2.7006E-04	g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.2864	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	91,026	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/year
2000	= conversion factor (lb/Ton)	=	2000	lb/Ton
$E_{T/yr}$	= mercury emission rate (Ton/yr)	=	9.3894E-03	Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 74.2864	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 8.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= mercury emission rate - Fd-based (lb/MMBtu)	= 6.2973E-06	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 13.2236	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 74.2864	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.8	%
100	= conversion factor	= 100	
$E_{Fc}$	= mercury emission rate - Fc-based (lb/MMBtu)	= 6.6145E-06	lb/MMBtu

**This Page Intentionally Left Blank**

**PARAMETERS**

C

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SB

Date: 10/23





**This Page Intentionally Left Blank**

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	4	Average
Date (2013)		Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)		10:06	12:45	07:41	10:18	
Stop Time (approx.)		12:27	15:14	09:58	12:40	
<b>Sampling Conditions</b>						
Y <sub>d</sub>	Dry gas meter correction factor	1.0031	1.0031	1.0031	1.0031	
C <sub>p</sub>	Pilot tube coefficient	0.8140	0.8140	0.8140	0.8140	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-10.0000	-10.0000	-11.0000	-11.0000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	64.0000	
P <sub>bar</sub>	Barometric pressure (in. Hg)	29.90	29.90	29.90	29.90	29.9000
D <sub>n</sub>	Nozzle diameter (in.)	0.2750	0.2750	0.2750	0.2750	
O <sub>2</sub>	Oxygen (dry volume %)	8.4333	8.7333	8.5333	8.5000	8.5500
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.8000	10.6000	10.6000	10.5333	10.6333
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.7667	80.6667	80.8667	80.9667	80.8167
V <sub>lc</sub>	Total Liquid collected (ml)	596.40	612.20	603.70	621.30	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	77.7500	78.8300	75.8100	76.8000	
T <sub>m</sub>	Dry gas meter temperature (°F)	95.4600	97.7800	92.8200	99.1400	
T <sub>s</sub>	Sample temperature (°F)	272.6800	272.0000	286.0000	285.3200	279.0000
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.2640	1.2840	1.1880	1.2280	
θ	Total sampling time (min)	125.0	125.0	125.0	125.0	
<b>Flow Results</b>						
V <sub>wstd</sub>	Volume of water collected (ft <sup>3</sup> )	28.0666	28.8101	28.4101	29.2384	28.6313
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.2864	75.0087	72.7652	72.8894	73.7374
P <sub>s</sub>	Sample gas pressure, absolute (in. Hg)	29.1647	29.1647	29.0912	29.0912	29.1279
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.1647	29.1647	29.0912	29.0912	29.1279
B <sub>wv</sub>	Moisture measured in sample (% by volume)	27.4214	27.7504	28.0801	28.6292	27.9703
B <sub>wvs</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000	100.0000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	27.4214	27.7504	28.0801	28.6292	27.9703
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.6895	0.7053	0.7026	0.6867	0.6960
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	30.0653	30.0453	30.0373	30.0253	30.0433
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	26.7569	26.7027	26.6572	26.5826	26.6748
V <sub>s</sub>	Velocity of sample (ft/sec)	46.4953	47.5828	47.9529	46.9119	47.2357
%I	Isokinetic sampling (%)	101.3626	100.3712	99.1669	102.2284	100.7823
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,542	182,718	184,139	180,142	181,385
Q <sub>c</sub>	Volumetric flow rate, standard (scfm)	125,417	128,469	126,719	124,081	126,171
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	91,026	92,819	91,136	88,557	90,884
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	81,639	81,244	81,083	79,001	80,742
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,712,506	10,963,068	11,048,340	10,808,494	10,883,102
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,525,003	7,708,164	7,603,120	7,444,851	7,570,285
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,461,545	5,569,119	5,468,157	5,313,449	5,453,067
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,384	310,481	312,896	306,103	308,216
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	213,113	218,300	215,325	210,843	214,395
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	154,674	157,721	154,861	150,480	154,434
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	138,725	138,053	137,778	134,241	137,199
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	198,582	203,416	200,644	196,467	199,777
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	144,128	146,967	144,303	140,220	143,904
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	129,266	128,640	128,384	125,088	127,845

Comments:

Average includes 4 runs.

101113 08D148  
 MMQK

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	4	Average
Date (2013)		Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)		10:06	12:45	07:41	10:18	
Stop Time (approx.)		12:27	15:14	09:58	12:40	
<b>Process Conditions</b>						
R <sub>P</sub>	Steam Production Rate - (Klbs/hour)	180.5	179.8	183.1	184.1	181.8
P <sub>1</sub>	Fabric Filter Inlet Temperature - (°F)	280	283	292	292	287
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>						
O <sub>2</sub>	Oxygen (dry volume %)	8.4333	8.7333	8.5333	8.5000	8.5500
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.8000	10.6000	10.6000	10.5333	10.6333
T <sub>s</sub>	Sample temperature (°F)	272.6800	272.0000	286.0000	285.3200	279.0000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	27.4214	27.7504	28.0801	28.6292	27.9703
<b>Gas Flow Rate</b>						
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,542	182,718	184,139	180,142	181,385
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	125,417	128,469	126,719	124,081	126,171
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	91,026	92,819	91,136	88,557	90,884
<b>Sampling Data</b>						
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.2864	75.0087	72.7652	72.8894	73.7374
%I	Isokinetic sampling (%)	101.3626	100.3712	99.1669	102.2284	100.7823
<b>Laboratory Data</b>						
m <sub>n-1b</sub>	Fraction 1B (µg)	0.1344	0.1242	0.1150	<0.1000	
m <sub>n-2b</sub>	Fraction 2B (µg)	11.9109	21.1451	12.0615	10.6516	
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub>	Fraction 3C (µg)	1.1783	2.4750	0.4655	0.4625	
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	13.2236	23.7443	12.6420	11.1140	
<b>Mercury Results - Total</b>						
C <sub>sd</sub>	Concentration (lb/dscf)	3.9251E-10	6.9800E-10	3.8309E-10	3.3621E-10	4.5245E-10
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	4.3764E-10	7.9744E-10	4.3059E-10	3.7688E-10	5.1064E-10
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	4.3612E-10	7.9019E-10	4.3369E-10	3.8303E-10	5.1076E-10
C <sub>a</sub>	Concentration (lb/acf)	2.0011E-10	3.5458E-10	1.8960E-10	1.6528E-10	2.2739E-10
C <sub>sd</sub>	Concentration (µg/dscm)	6.2855E+00	1.1178E+01	6.1347E+00	5.3840E+00	7.2454E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	7.0081E+00	1.2770E+01	6.8953E+00	6.0353E+00	8.1772E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	6.9839E+00	1.2654E+01	6.9449E+00	6.1337E+00	8.1790E+00
C <sub>sd</sub>	Concentration (mg/dscm)	6.2855E-03	1.1178E-02	6.1347E-03	5.3840E-03	7.2454E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	7.0081E-03	1.2770E-02	6.8953E-03	6.0353E-03	8.1772E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	6.9839E-03	1.2654E-02	6.9449E-03	6.1337E-03	8.1790E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	3.2046E+00	5.6781E+00	3.0362E+00	2.6468E+00	3.6414E+00
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	6.7454E+00	1.1995E+01	6.5835E+00	5.7779E+00	7.7756E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	7.5209E+00	1.3704E+01	7.3998E+00	6.4769E+00	8.7755E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	7.4949E+00	1.3580E+01	7.4531E+00	6.5825E+00	8.7775E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	2.1437E-03	3.8873E-03	2.0948E-03	1.7865E-03	2.4781E-03
E <sub>g/s</sub>	Rate (g/s)	2.7006E-04	4.8970E-04	2.6389E-04	2.2505E-04	3.1218E-04
E <sub>T/yr</sub>	Rate (Ton/yr)	9.3894E-03	1.7026E-02	9.1752E-03	7.8247E-03	1.0854E-02
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	6.2973E-06	1.1475E-05	6.1959E-06	5.4232E-06	7.3478E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	6.6145E-06	1.1985E-05	6.5778E-06	5.8093E-06	7.7465E-06

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	4	Average
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)	10:06	12:45	07:41	10:18	
Stop Time (approx.)	12:27	15:14	09:58	12:40	

**Mercury Results - Front Half**

C <sub>sd</sub>	Concentration (lb/dscf)	3.9891E-12	3.6505E-12	3.4844E-12	<3.0251E-12	<3.5373E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	4.4477E-12	4.1706E-12	3.9165E-12	<3.3911E-12	<3.9815E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	4.4323E-12	4.1327E-12	3.9446E-12	<3.4464E-12	<3.9890E-12
C <sub>a</sub>	Concentration (lb/acf)	2.0338E-12	1.8544E-12	1.7246E-12	<1.4872E-12	<1.7750E-12
C <sub>sd</sub>	Concentration (µg/dscm)	6.3880E-02	5.8458E-02	5.5798E-02	<4.8443E-02	<5.6645E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	7.1224E-02	6.6786E-02	6.2717E-02	<5.4303E-02	<6.3758E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	7.0978E-02	6.6179E-02	6.3168E-02	<5.5189E-02	<6.3878E-02
C <sub>sd</sub>	Concentration (mg/dscm)	6.3880E-05	5.8458E-05	5.5798E-05	<4.8443E-05	<5.6645E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	7.1224E-05	6.6786E-05	6.2717E-05	<5.4303E-05	<6.3758E-05
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	7.0978E-05	6.6179E-05	6.3168E-05	<5.5189E-05	<6.3878E-05
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	3.2568E-02	2.9696E-02	2.7616E-02	<2.3815E-02	<2.8424E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	6.8554E-02	6.2736E-02	5.9881E-02	<5.1988E-02	<6.0790E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	7.6436E-02	7.1673E-02	6.7306E-02	<5.8277E-02	<6.8423E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	7.6171E-02	7.1021E-02	6.7790E-02	<5.9227E-02	<6.8552E-02
E <sub>lb/hr</sub>	Rate (lb/hr)	2.1787E-05	2.0330E-05	1.9053E-05	<1.6074E-05	<1.9311E-05
E <sub>g/s</sub>	Rate (g/s)	2.7446E-06	2.5611E-06	2.4003E-06	<2.0249E-06	<2.4327E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	9.5425E-05	8.9046E-05	8.3454E-05	<7.0404E-05	<8.4582E-05
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	6.4000E-08	6.0013E-08	5.6356E-08	<4.8796E-08	<5.7291E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	6.7224E-08	6.2679E-08	5.9827E-08	<5.2270E-08	<6.0500E-08

101113 065559  
 M M O K M

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	4	Average
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)	10:06	12:45	07:41	10:18	
Stop Time (approx.)	12:27	15:14	09:58	12:40	
<b>Mercury Results - Impingers 1-3 Solution</b>					
C <sub>sd</sub> Concentration (lb/dscf)	3.5354E-10	6.2159E-10	3.6550E-10	3.2222E-10	4.1571E-10
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	3.9419E-10	7.1015E-10	4.1082E-10	3.6120E-10	4.6909E-10
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	3.9283E-10	7.0369E-10	4.1377E-10	3.6709E-10	4.6934E-10
C <sub>a</sub> Concentration (lb/acf)	1.8025E-10	3.1576E-10	1.8090E-10	1.5840E-10	2.0883E-10
C <sub>sd</sub> Concentration (µg/dscm)	5.6615E+00	9.9540E+00	5.8529E+00	5.1600E+00	6.6571E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	6.3124E+00	1.1372E+01	6.5787E+00	5.7841E+00	7.5118E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	6.2906E+00	1.1269E+01	6.6260E+00	5.8784E+00	7.5159E+00
C <sub>sd</sub> Concentration (mg/dscm)	5.6615E-03	9.9540E-03	5.8529E-03	5.1600E-03	6.6571E-03
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	6.3124E-03	1.1372E-02	6.5787E-03	5.7841E-03	7.5118E-03
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	6.2906E-03	1.1269E-02	6.6260E-03	5.8784E-03	7.5159E-03
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	2.8864E+00	5.0565E+00	2.8968E+00	2.5366E+00	3.3441E+00
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	6.0758E+00	1.0682E+01	6.2812E+00	5.5375E+00	7.1442E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	6.7743E+00	1.2204E+01	7.0600E+00	6.2074E+00	8.0615E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	6.7508E+00	1.2093E+01	7.1108E+00	6.3086E+00	8.0658E+00
E <sub>lb/hr</sub> Rate (lb/hr)	1.9309E-03	3.4617E-03	1.9986E-03	1.7121E-03	2.2758E-03
E <sub>g/s</sub> Rate (g/s)	2.4325E-04	4.3610E-04	2.5178E-04	2.1569E-04	2.8670E-04
E <sub>T/yr</sub> Rate (Ton/yr)	8.4573E-03	1.5162E-02	8.7539E-03	7.4991E-03	9.9682E-03
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	5.6722E-06	1.0219E-05	5.9114E-06	5.1975E-06	6.7499E-06
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	5.9579E-06	1.0673E-05	6.2755E-06	5.5675E-06	7.1184E-06

101113 085559  
 MNQK\_M

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.	1	2	3	4	Average
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)	10:06	12:45	07:41	10:18	
Stop Time (approx.)	12:27	15:14	09:58	12:40	

**Mercury Results - Impinger 4 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<5.9365E-12	<5.8793E-12	<6.0606E-12	<6.0503E-12	<5.9817E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<6.6190E-12	<6.7169E-12	<6.8120E-12	<6.7822E-12	<6.7325E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<6.5961E-12	<6.6558E-12	<6.8610E-12	<6.8927E-12	<6.7514E-12
C <sub>a</sub>	Concentration (lb/acf)	<3.0266E-12	<2.9866E-12	<2.9996E-12	<2.9743E-12	<2.9968E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<9.5064E-02	<9.4149E-02	<9.7052E-02	<9.6887E-02	<9.5788E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.0599E-01	<1.0756E-01	<1.0909E-01	<1.0861E-01	<1.0781E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.0563E-01	<1.0658E-01	<1.0987E-01	<1.1038E-01	<1.0811E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<9.5064E-05	<9.4149E-05	<9.7052E-05	<9.6887E-05	<9.5788E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.0599E-04	<1.0756E-04	<1.0909E-04	<1.0861E-04	<1.0781E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.0563E-04	<1.0658E-04	<1.0987E-04	<1.1038E-04	<1.0811E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<4.8467E-02	<4.7827E-02	<4.8034E-02	<4.7629E-02	<4.7989E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<1.0202E-01	<1.0104E-01	<1.0415E-01	<1.0398E-01	<1.0280E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.1375E-01	<1.1543E-01	<1.1707E-01	<1.1655E-01	<1.1570E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.1336E-01	<1.1438E-01	<1.1791E-01	<1.1845E-01	<1.1603E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<3.2422E-05	<3.2743E-05	<3.3140E-05	<3.2148E-05	<3.2613E-05
E <sub>g/s</sub>	Rate (g/s)	<4.0844E-06	<4.1248E-06	<4.1749E-06	<4.0499E-06	<4.1085E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<1.4201E-04	<1.4341E-04	<1.4515E-04	<1.4081E-04	<1.4285E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<9.5244E-08	<9.6653E-08	<9.8021E-08	<9.7591E-08	<9.6877E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.0004E-07	<1.0095E-07	<1.0406E-07	<1.0454E-07	<1.0240E-07

101113 085559  
 M N O K M

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	4	Average
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26	
Start Time (approx.)	10:06	12:45	07:41	10:18	
Stop Time (approx.)	12:27	15:14	09:58	12:40	

**Mercury Results - Filtered Permanganate Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.4841E-11	<1.4698E-11	<1.5151E-11	<1.5126E-11	<1.4954E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.6548E-11	<1.6792E-11	<1.7030E-11	<1.6955E-11	<1.6831E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.6490E-11	<1.6640E-11	<1.7153E-11	<1.7232E-11	<1.6879E-11
C <sub>a</sub>	Concentration (lb/acf)	<7.5665E-12	<7.4666E-12	<7.4989E-12	<7.4358E-12	<7.4919E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<2.3766E-01	<2.3537E-01	<2.4263E-01	<2.4222E-01	<2.3947E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.6499E-01	<2.6891E-01	<2.7271E-01	<2.7152E-01	<2.6953E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.6407E-01	<2.6646E-01	<2.7468E-01	<2.7594E-01	<2.7029E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<2.3766E-04	<2.3537E-04	<2.4263E-04	<2.4222E-04	<2.3947E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.6499E-04	<2.6891E-04	<2.7271E-04	<2.7152E-04	<2.6953E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.6407E-04	<2.6646E-04	<2.7468E-04	<2.7594E-04	<2.7029E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.2117E-01	<1.1957E-01	<1.2008E-01	<1.1907E-01	<1.1997E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.5505E-01	<2.5260E-01	<2.6038E-01	<2.5994E-01	<2.5699E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.8438E-01	<2.8858E-01	<2.9267E-01	<2.9138E-01	<2.8925E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.8339E-01	<2.8596E-01	<2.9477E-01	<2.9613E-01	<2.9006E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<8.1056E-05	<8.1857E-05	<8.2851E-05	<8.0369E-05	<8.1533E-05
E <sub>g/s</sub>	Rate (g/s)	<1.0211E-05	<1.0312E-05	<1.0437E-05	<1.0125E-05	<1.0271E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.5502E-04	<3.5853E-04	<3.6289E-04	<3.5202E-04	<3.5712E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.3811E-07	<2.4163E-07	<2.4505E-07	<2.4398E-07	<2.4219E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.5010E-07	<2.5237E-07	<2.6015E-07	<2.6135E-07	<2.5599E-07

**Mercury Results - HCl Rinse + HCl/MnO2 Precipitate**

C <sub>sd</sub>	Concentration (lb/dscf)	3.4976E-11	7.2756E-11	1.4107E-11	1.3990E-11	3.3957E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	3.8997E-11	8.3121E-11	1.5856E-11	1.5683E-11	3.8414E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	3.8862E-11	8.2365E-11	1.5970E-11	1.5938E-11	3.8284E-11
C <sub>a</sub>	Concentration (lb/acf)	1.7832E-11	3.6959E-11	6.9820E-12	6.8776E-12	1.7163E-11
C <sub>sd</sub>	Concentration (µg/dscm)	5.6009E-01	1.1651E+00	2.2590E-01	2.2403E-01	5.4378E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	6.2448E-01	1.3311E+00	2.5391E-01	2.5113E-01	6.1515E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	6.2232E-01	1.3190E+00	2.5574E-01	2.5523E-01	6.1306E-01
C <sub>sd</sub>	Concentration (mg/dscm)	5.6009E-04	1.1651E-03	2.2590E-04	2.2403E-04	5.4378E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	6.2448E-04	1.3311E-03	2.5391E-04	2.5113E-04	6.1515E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	6.2232E-04	1.3190E-03	2.5574E-04	2.5523E-04	6.1306E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	2.8555E-01	5.9185E-01	1.1181E-01	1.1013E-01	2.7484E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	6.0107E-01	1.2503E+00	2.4243E-01	2.4043E-01	5.8357E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	6.7018E-01	1.4285E+00	2.7249E-01	2.6951E-01	6.6016E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	6.6785E-01	1.4155E+00	2.7445E-01	2.7390E-01	6.5792E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	1.9102E-04	4.0519E-04	7.7139E-05	7.4336E-05	1.8692E-04
E <sub>g/s</sub>	Rate (g/s)	2.4064E-05	5.1044E-05	9.7177E-06	9.3646E-06	2.3548E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	8.3667E-04	1.7747E-03	3.3787E-04	3.2559E-04	8.1871E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	5.6114E-07	1.1961E-06	2.2816E-07	2.2566E-07	5.5276E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	5.8941E-07	1.2492E-06	2.4221E-07	2.4173E-07	5.8064E-07

**QA/QC DATA**

D

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SB

Date: 10/23





**This Page Intentionally Left Blank**

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

### USEPA Method 29 (Mercury) QA/QC Results

Run No.	1	2	3	4
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26
Start Time (approx.)	10:06	12:45	07:41	10:18
Stop Time (approx.)	12:27	15:14	09:58	12:40
Total Duration of Test Run (min.)	141	149	137	142
Net Sampling Time (min.)	125	125	125	125

#### Sampling System Calibration Summary

D <sub>n</sub>	Nozzle ID No:	0.275-1	0.275-1	0.275-1	0.275-1
	Nozzle Diameter (in):	0.275	0.275	0.275	0.275
C <sub>p</sub>	Probe ID No:	66-8-1	66-8-1	66-8-1	66-8-1
	Pitot Coefficient:	0.8140	0.8140	0.8140	0.814
Y <sub>d</sub>	Meter Box ID. No:	66-20	66-20	66-20	66-20
	Meter Box Yd - Field Sheet	1.0031	1.0031	1.0031	1.0031
	Meter Box Yd - Database	1.0031	1.0031	1.0031	1.0031
	Meter Box ΔH@ - Field Sheet	1.7992	1.7992	1.7992	1.7992
	Meter Box ΔH@ - Database	1.7992	1.7992	1.7992	1.7992

#### QA/QC

##### Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0249	0.0252	0.0243	0.0246
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0050	0.0030	0.0010	0.0010

##### Sample Volume

V <sub>mstd</sub>	Minimum Volume Required (dscf)	30.00	30.00	30.00	30.00
	Actual Sample Volume (dscf)	74.286	75.009	72.765	72.889

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1236	1.1330	1.0895	1.1075
Y <sub>qs</sub>	Alternative Meter Calibration Factor	1.0160	1.0128	1.0085	1.0178
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	1.3%	1.0%	0.5%	1.5%
					<b>Average 1.1%</b>

##### Mean Isokinetic Sampling Rate Variation

%I	Minimum Allowable (%)	90	90	90	90
	Maximum Allowable (%)	110	110	110	110
	Actual Variation (%)	101.36	100.37	99.17	102.23

##### Point-by-Point Isokinetic Variation

	Number of points <90%	1	2	0	1
	Number of points >110%	2	2	0	2
	Number of points <80%	0	0	0	0
	Number of points >120%	0	0	0	0

101113 085411  
 MMQK


# Nozzle Calibration Sheet

Client	Wheelabrator North Blvd	Project Number	12278
Calibrated by	S. Brown	Unit	2
Date	9/10/11/2013	Runs	1-4

Nozzle Identification	D <sub>1</sub> (inches)	D <sub>2</sub> (inches)	D <sub>3</sub> (inches)	ΔD (Inches)	D <sub>ave</sub> (inches)
0.273-1	0.2735	0.2730	0.2725	0.0010	0.2730
0.275-1	0.2755	0.2745	0.2750	0.001	0.2750
0.3168-1	0.3165	0.3165	0.3175	0.001	0.3168
0.275-2	0.2750	0.2750	0.2750	0.000	0.275

cal per 12156068

$D_1, D_2, D_3$  = three nozzle diameter measurements  
 $\Delta D$  = maximum difference between any two diameters  
 $\Delta D = 0.004$  inches\*  
 $D_{ave}$  = average of  $D_1, D_2, D_3$



\* (40 CFR 60, Appendix A, Method 5, Section 5.1)


# Clean Air Engineering - Meter Box Full Test Calibration

Client: Source Reviewed By: R. REDEL Calibration Signature: *[Signature]*  
 ID No: 66-20 Calibrated By: J. Ivens Meter Box Yd: 1.0031  
 Dept No: 66 Date of Calibration: 03/12/13 Meter Box ΔH@: 1.7992  
 Meter Box Serial No: 66-20 Due Date of Calibration: 03/13/13 Barometer Serial No: W12637  
 Manufacturer Part No: 0028 Meter Box Vacuum: 1.0 in. H<sub>2</sub>O Barometric Pressure: 29.10 in. Hg

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.389	0.50	-1.20	1.0000	0.000	5.000	5.000	207.700	212.795	5.095	65.0	65.0	65.00	82.0	80.0	81.00	12.58	1.0069	1.7710
0.389	0.50	-1.20	1.0000	0.000	5.000	5.000	212.795	217.883	5.088	65.0	65.0	65.00	82.0	79.0	80.50	12.57	1.0074	1.7714
0.669	1.50	-1.50	1.0000	0.000	10.000	10.000	231.600	241.831	10.231	65.0	65.0	65.00	86.0	80.0	83.00	14.61	1.0033	1.7915
0.669	1.50	-1.50	1.0000	0.000	10.000	10.000	241.831	262.066	10.235	65.0	65.0	65.00	86.0	80.0	83.00	14.61	1.0029	1.7915
0.936	3.00	-1.80	1.0000	0.000	10.000	10.000	176.902	187.162	10.260	64.0	64.0	64.00	88.0	80.0	84.00	10.47	0.9997	1.8331
0.936	3.00	-1.80	1.0000	0.000	10.000	10.000	187.162	197.433	10.271	64.0	64.0	64.00	88.0	80.0	84.00	10.48	0.9986	1.8366
Averages																	1.00313	1.79918

Nomenclature	Equations
<p>P<sub>b</sub> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p>ΔP Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p>V<sub>d</sub> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p>V<sub>ds</sub> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p>T<sub>d</sub> Average Meter Box Temperature (°F)</p> <p>T<sub>o</sub> Outlet Meter Box Temperature (°F)</p> <p>T<sub>os</sub> Average Standard Meter Temperature (°F)</p> <p>Y<sub>d</sub> Meter Correction Factor (unitless), Y<sub>1</sub> ≤ Y<sub>avg</sub> ± 0.02</p> <p>Y<sub>ds</sub> Standard Meter Correction Factor (unitless)</p> <p>ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p>ΔH@<sub>1</sub> ≤ ΔH@<sub>avg</sub> ± 0.2</p> <p>Θ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{os} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Average YD vs. Average CFM



Average CFM

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
4.5	5.0
9.4	10.0
14.0	15.0
19.0	20.0
24.0	25.0

Calibration Reference Information (Standard Meter)	
Reference Used: <u>Wet Test Meter</u>	Serial No: <u>11AG9</u>
Calibrated By: <u>Martin Vaquero</u>	Date Calibrated: <u>7/22/2012</u>
Percent Error: <u>0.245%</u>	Calibration Due Date: <u>7/23/2013</u>

Meter Box Pre-Calibration Inspection			
Positive Leak Check:	Pass	Electrical Check:	Pass
Negative Leak Check:	Pass	Pyrometer Check:	Pass
Vacuum Gauge Check:	Pass	YD Tolerance:	Pass



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-20 Office: n/a  
 Calibrated by: J. Ivens Client: n/a  
 Date: 3/12/13 Job No: n/a  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	52	51	50	52	52		
100	102	101	100	102	102		
150	152	151	150	152	152		
200	202	201	200	202	202		
250	252	251	250	252	252		
300	302	301	300	302	302		
350	352	351	350	352	352		
400	402	401	400	402	402		
450	452	451	450	452	452		
500	502	501	500	502	502		
550	552	551	550	552	552		
600	602	601	600	602	602		

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

### Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/18/2012</u>
Calibration Report No: <u>1000164938</u>	Calibration Due Date: <u>10/18/2013</u>

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 66-8-1  
Project Number: Browards

## Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69	69	0	0.00%	
2	200°F-250°F	248	249	-1	0.14%	%Difference ≤ 1.5

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

## Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C <sub>p(A)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.559	0.823	0.816	0.001	
2	0.555	0.823	0.813	0.001	
3	0.555	0.820	0.815	0.000	
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8145	0.0009	

Pitot Side 'B' :				Abs. Deviation from Avg. C <sub>p(B)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.557	0.821	0.815	0.002	
2	0.555	0.822	0.814	0.001	
3	0.552	0.824	0.810	0.003	
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8130	0.0019	

'A' Average C <sub>p</sub> 0.814	-	'B' Average C <sub>p</sub> 0.813	=	Difference 0.001	Specification  Difference  ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** \text{ Deviation} = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

## All specifications are from EPA-600/9-78-005, section 3.7

Probe Cp= 0.814 Calibrated by: S DOOLEY Date: 03/13/2013

# Caliper Calibration Sheet

Calibrated by	D. Leishman		
Calibration Date	June 17, 2013	Expiration Date	June 18, 2014

Caliper ID	12156068
------------	----------

Standard Caliper ID	101460021
---------------------	-----------

Inside Jaw Check		
Standard Caliper Setting (in)	Caliper Reading (in)	Deviation ( $\Delta D$ )
0.150	0.1500	0.0000
0.300	0.3005	0.0005
0.500	0.5000	0.0000

Outside Jaw Check		
Standard Caliper Setting (in)	Caliper Reading (in)	Deviation ( $\Delta D$ )
0.150	0.1500	0.0000
0.300	0.3005	0.0005
0.500	0.5000	0.0000

$\Delta D$  = maximum deviation between standard and caliper being calibrated  
 $\Delta D \leq 0.001$  inch for every reading

QA/QC *[Signature]*  
 Date 6/17/13



**FIELD DATA**

E

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SB

Date: 10/23





**This Page Intentionally Left Blank**

TEST LOCATION:

FF Outlet

Metals

TESTING

METHOD: 29

PAGE 1

OF 2

UNIT: 2

RUN: 1

FIELD DATA SHEET

Client <u>Wheelabrator</u>	Project No. <u>12218</u>
Plant <u>N. Browns</u>	Date <u>9/25/13</u>
Meter Operator <u>S. Dooley</u>	
Probe Operator <u>S. Dooley</u>	

Meter Box <u>66-20</u>	Sample Box No.
Meter Y <sub>d</sub> <u>1.0031</u>	Meter ΔH <sub>0</sub> <u>1.2792</u>
K Factor <u>2.65/2.70</u>	Pitot C <sub>p</sub> <u>0.814</u>

Leak Rate Before <u>0.002</u> (in. Hg) [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.005</u> (in. Hg) [Lpm] @ <u>7</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

Duct Dimensions (in.) 96 x 96

Static Pres (in. H <sub>2</sub> O) <u>-10.0</u>	Port Len. (in.) <u>12.0</u>	Gas Flow <input checked="" type="checkbox"/> In <input checked="" type="checkbox"/> Out	First point all the way <input checked="" type="checkbox"/> In <input type="checkbox"/> Out
-------------------------------------------------	-----------------------------	-----------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------

of page

Amb. Temp. (°F) <u>87</u>	Bar. Press. <u>29.90</u> (in. Hg) [mbar]
Probe I.D. No. <u>66-8-1</u>	
Liner Material <u>Glass</u>	

Filter No. <u>N/A</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>0.275</u>	Nozzle I.D. <u>275-1</u>

Start Time: <u>10:06</u>	Stop Time: <u>12:27</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
						250	250						
1-1	5	0.42	1.1	423.69	273	253	255	60	87	85	4	8.7	
2	10	0.42	1.1	426.59	273	251	256	60	89	86	4	7.9	
3	15	0.45	1.2	429.57	275	253	252	60	90	86	4	8.9	
4	20	0.47	1.2	432.50	273	251	252	59	91	87	4	8.3	
5	25	0.50	1.3	435.64	272	253	253	58	93	89	4	8.8	436.22
2-1	30	0.43	1.2	439.35	273	254	252	57	93	89	5	8.8	
2	35	0.52	1.4	442.56	273	251	259	58	94	90	5	8.9	
3	40	0.50	1.3	445.73	273	250	251	58	95	90	5	8.8	
4	45	0.50	1.3	448.89	273	252	252	58	95	91	5	8.8	
5	50	0.53	1.4	451.99	272	293	252	59	95	90	5	8.9	452.47
3-1	55	0.50	1.3	455.69	273	251	255	59	95	91	5	9.0	
2	60	0.49	1.3	458.75	272	250	250	59	97	92	5	8.7	
Total			15.1	78,280.0	3275								
Average		0.6895	1.2680			272.68					97.1800		

Sum of square roots 5.8  
1.264 10/10

SB 10/10 272.68 QA/QC SD  
Date 9/25/13

TEST LOCATION: FF Outlet  
 UNIT: 2 RUN: 1

Metals TESTING  
**FIELD DATA SHEET**

METHOD: 29 PAGE 2 OF 2

Client Wheelabrator Project No. 122 B  
 Plant N. Browns Date 9/25/13  
 Meter Operator S Dooley  
 Probe Operator S Dooley

Meter Box \_\_\_\_\_ Sample Box No. \_\_\_\_\_  
 Meter Y<sub>d</sub> \_\_\_\_\_ Meter ΔH<sub>@</sub> \_\_\_\_\_  
 K Factor \_\_\_\_\_ Pitot C<sub>p</sub> \_\_\_\_\_  
 Leak Rate Before [cfm] [Lpm] @ (in. Hg) \_\_\_\_\_  
 Leak Rate After [cfm] [Lpm] @ (in. Hg) \_\_\_\_\_  
 Pitot Leak Check Before:  After: Good  Bad

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F) \_\_\_\_\_ Bar. Press. (in. Hg) [mbar] \_\_\_\_\_  
 Probe I.D. No. \_\_\_\_\_  
 Liner Material \_\_\_\_\_

Filter No. \_\_\_\_\_  
 Thimble No. \_\_\_\_\_  
 Nozzle Diameter \_\_\_\_\_ Nozzle I.D. \_\_\_\_\_

Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T <sub>1</sub> (°F)	Notes
						Set Points							
3-3	65	0.51	1.3	<del>461.93</del> <u>455.69</u>	272	251	252	60	100	93	5	8.7	
4	70	0.50	1.3	465.12	272	252	252	60	103	94	5	8.6	
5	75	0.49	1.3	468.20	273	250	252	61	103	95	5	8.8	468.89
4-1	80	0.42	1.1	472.07	272	254	253	57	104	95	5	8.9	
-2	85	0.45	1.2	<del>475.99</del> <u>471.11</u>	273	251	251	58	104	96	5	8.6	
3	90	0.45	1.2	478.32	272	250	254	58	104	96	5	8.8	
4	95	0.45	1.2	481.48	272	250	253	60	105	96	5	8.9	K Factor: 2.70
5	100	0.47	1.3	484.63	272	250	250	61	105	96	5	8.7	
5-1	105	0.48	1.3	<del>488.48</del> <u>489.10</u>	273	250	250	62	103	96	5	8.7	485.88
2	110	0.46	1.3	492.47	272	253	252	64	103	97	5	8.8	
3	115	0.49	1.3	495.62	273	252	251	57	103	97	5	8.9	
4	120	0.50	1.35 in	498.95	272	251	250	58	103	98	5	8.8	
5	125	0.50	1.4	502.110	273	255	250	61	103	99	5	8.9	
	Total	*	16.6						259.1				
	Average												

\* Sum of square roots.

Circle correct bracketed units on data sheet.



E-4


TEST LOCATION: FF Outlet  
 UNIT: 2 RUN: 2

Metals TESTING  
 FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 2

Client Wheelabrator Project No. 12218  
 Plant N Browns Date 9/25/13  
 Meter Operator S Dasey  
 Probe Operator S Dasey

Meter Box 66-20 Sample Box No. M10  
 Meter Y<sub>d</sub> 1.0031 Meter ΔH<sub>0</sub> 1.7972  
 K Factor 270 29 Pitot C<sub>p</sub> 0.814  
 Leak Rate Before 0.005 (in. Hg) Lpm @ 15 (in. Hg)  
 Leak Rate After 0.002 (in. Hg) Lpm @ 8 (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad



Amb. Temp. (°F) 87 Bar. Press. 29.90 (in. Hg) [mbar]  
 Probe I.D. No. 66-8-1  
 Liner Material Glass

Filter No. N/A  
 Thimble No. N/A  
 Nozzle Diameter 0.275 Nozzle I.D. 2.25-1

Start Time: 12:45 Stop Time: 15:14

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>min</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
						Set Points							
				<u>303.33</u>		<u>250</u>	<u>250</u>						
<u>5-1</u>	<u>5</u>	<u>0.45</u>	<u>1.2</u>	<u>306.44</u>	<u>272</u>	<u>251</u>	<u>253</u>	<u>60</u>	<u>94</u>	<u>91</u>	<u>5</u>	<u>8.9</u>	
<u>2</u>	<u>10</u>	<u>0.45</u>	<u>1.2</u>	<u>509.44</u>	<u>272</u>	<u>253</u>	<u>254</u>	<u>57</u>	<u>94</u>	<u>91</u>	<u>5</u>	<u>8.8</u>	<u>*K factor 25</u>
<u>3</u>	<u>15</u>	<u>0.80</u>	<u>1.3</u>	<u>312.62</u>	<u>272</u>	<u>251</u>	<u>255</u>	<u>56</u>	<u>96</u>	<u>92</u>	<u>5</u>	<u>8.7</u>	
<u>4</u>	<u>20</u>	<u>0.51</u>	<u>1.3</u>	<u>515.91</u>	<u>272</u>	<u>251</u>	<u>254</u>	<u>53</u>	<u>97</u>	<u>92</u>	<u>5</u>	<u>8.8</u>	
<u>5</u>	<u>25</u>	<u>0.52</u>	<u>1.3</u>	<u>319.90</u>	<u>273</u>	<u>253</u>	<u>254</u>	<u>55</u>	<u>98</u>	<u>92</u>	<u>5</u>	<u>8.8</u>	<u>320.00</u>
<u>4-1</u>	<u>30</u>	<u>0.50</u>	<u>1.3</u>	<u>323.30</u>	<u>272</u>	<u>251</u>	<u>253</u>	<u>56</u>	<u>100</u>	<u>93</u>	<u>5</u>	<u>9.5</u>	
<u>2</u>	<u>35</u>	<u>0.50</u>	<u>1.3</u>	<u>526.44</u>	<u>272</u>	<u>253</u>	<u>255</u>	<u>57</u>	<u>100</u>	<u>93</u>	<u>5</u>	<u>9.2</u>	
<u>3</u>	<u>40</u>	<u>0.52</u>	<u>1.3</u>	<u>529.11</u>	<u>272</u>	<u>252</u>	<u>255</u>	<u>59</u>	<u>101</u>	<u>94</u>	<u>5</u>	<u>9.0</u>	
<u>4</u>	<u>45</u>	<u>0.53</u>	<u>1.4</u>	<u>532.95</u>	<u>272</u>	<u>252</u>	<u>255</u>	<u>61</u>	<u>102</u>	<u>94</u>	<u>5</u>	<u>9.1</u>	
<u>5</u>	<u>50</u>	<u>0.49</u>	<u>1.2</u>	<u>535.86</u>	<u>277</u>	<u>252</u>	<u>250</u>	<u>63</u>	<u>102</u>	<u>95</u>	<u>5</u>	<u>9.1</u>	<u>*0.20</u>
<u>3-1</u>	<u>55</u>	<u>0.51</u>	<u>1.3</u>	<u>539.03</u>	<u>272</u>	<u>255</u>	<u>251</u>	<u>59</u>	<u>103</u>	<u>95</u>	<u>5</u>	<u>9.0</u>	
<u>-2</u>	<u>60</u>	<u>0.51</u>	<u>1.3</u>	<u>541.81</u>	<u>272</u>	<u>250</u>	<u>250</u>	<u>55</u>	<u>103</u>	<u>94</u>	<u>5</u>	<u>9.0</u>	
			<u>N/A</u>			<u>251.50</u>			<u>2306</u>				
	Total			<u>79.8500</u>	<u>3264</u>								
	Average	<u>0.7053</u>	<u>1.5800</u>		<u>272.0000</u>				<u>97.7400</u>				

\* Sum of square roots

Circle correct bracketed units on data sheet.

1.284 58 10/10

QA/QC SD  
 Date 9/25/13

97.780 58 10/10



E-5

TEST LOCATION: RF Outlet  
 UNIT: 2 RUN: 2

Metals TESTING  
 FIELD DATA SHEET

METHOD: 29 PAGE 2 OF 2

Client Wheelabrator Project No. 12218  
 Plant N. Brewards Date 9/25/13  
 Meter Operator S Dooley  
 Probe Operator S Dooley

Meter Box 66-20 Sample Box No. \_\_\_\_\_  
 Meter Y<sub>d</sub> 1.0031 Meter ΔH<sub>0</sub> 1.7992  
 K Factor \_\_\_\_\_ Pitot C<sub>p</sub> 0.814  
 Leak Rate Before (cfm) [Lpm] @ \_\_\_\_\_ (in. Hg)  
 Leak Rate After (cfm) [Lpm] @ \_\_\_\_\_ (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
---------------------------------------	--------------------	-----------------------------------	------------------------------------------

Amb. Temp. (°F) \_\_\_\_\_ Bar. Press. (in. Hg) [mbar]  
 Probe I.D. No. \_\_\_\_\_  
 Liner Material \_\_\_\_\_

Filter No. \_\_\_\_\_  
 Thimble No. \_\_\_\_\_  
 Nozzle Diameter \_\_\_\_\_ Nozzle I.D. \_\_\_\_\_

Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. <u>(ft<sup>3</sup>)</u> [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in.Hg)	XAD Trap Temp. (°F)	Notes
						Set Points	Set Points						
3-3	65	0.51	1.3	544.90	272	251	252	56	102	94	5	8.5	
-4	70	0.50	1.3	547.94	272	251	252	55	102	94	5	8.8	
5	75	0.49	1.3	551.10	272	252	252	53	102	95	5	8.4	553 522 .462
2-1	80	0.50	1.3	556.89	273	253	250	55	103	94	5	8.7	
2	85	0.50	1.3	559.91	273	253	251	56	103	95	5	8.7	
3	80	0.51	1.3	563.09	271	252	252	58	103	95	5	8.6	
4	85	0.49	1.3	566.27	272	255	252	58	104	95	5	9.0	
5	100	0.49	1.3	569.45	272	251	252	60	104	95	5	8.9	570.19 0.574
1-1	105	0.48	1.2	573.63	272	253	252	61	105	96	5	8.8	
2	50/110	0.47	1.2	576.79	272	252	251	54	105	95	5	8.7	
3	55/115	0.51	1.3	580.10	272	251	251	55	105	95	5	8.9	
4	60/120	0.50	1.3	583.42	271	255	251	59	105	95	5	9.0	
5	125	0.50	1.3	586.62	272	253	252	61	106	96	5	9.1	
	Total	*											
	Average												

\* Sum of square roots. Circle correct bracketed units on data sheet.


E-6

TEST LOCATION: FF Outlet Metals TESTING METHOD: 29 PAGE 1 OF 2  
 UNIT: 2 RUN: 3 FIELD DATA SHEET

Client <u>Wheelabrator</u>	Project No. <u>12218</u>
Plant <u>N. Broward</u>	Date <u>9/26/13</u>
Meter Operator <u>S. Dadey</u>	
Probe Operator <u>S. Dadey</u>	

Meter Box <u>66-20</u>	Sample Box No. <u>M11</u>
Meter Y <sub>d</sub> <u>10031</u>	Meter ΔH <sub>0</sub> <u>1.792</u>
K Factor <u>2.5</u>	Pitot C <sub>p</sub> <u>0.841</u>

Leak Rate Before <u>0.00</u> (cfm) [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.00</u> (cfm) [Lpm] @ <u>9</u> (in. Hg)
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>



Amb. Temp. (°F) <u>85</u>	Bar. Press. <u>29.90</u> (in. Hg) [mbar]
Probe I.D. No. <u>66-8-1</u>	
Liner Material <u>Glass</u>	

Filter No. <u>N/A</u>		
Thimble No. <u>N/A</u>		
Nozzle Diameter <u>0.275</u>	Nozzle I.D.	<u>275-2</u>

Start Time: <u>7:41</u>	Stop Time: <u>9:58</u>
-------------------------	------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
						Set Points	Set Points							
	<u>5</u>			<u>598.90</u>		<u>250</u>	<u>250</u>						<u>02</u>	
<u>1-1</u>	<u>5</u>	<u>0.45</u>	<u>1.1</u>	<u>591.10</u>	<u>288</u>	<u>251</u>	<u>252</u>	<u>60</u>	<u>85</u>	<u>84</u>	<u>5</u>	<u>8.4</u>		
<u>2</u>	<u>10</u>	<u>0.45</u>	<u>1.1</u>	<u>594.05</u>	<u>287</u>	<u>253</u>	<u>250</u>	<u>61</u>	<u>87</u>	<u>85</u>	<u>5</u>	<u>8.1</u>		
<u>3</u>	<u>15</u>	<u>0.46</u>	<u>1.1</u>	<u>596.99</u>	<u>287</u>	<u>251</u>	<u>252</u>	<u>57</u>	<u>89</u>	<u>85</u>	<u>5</u>	<u>7.6</u>		
<u>4</u>	<u>20</u>	<u>0.50</u>	<u>1.2</u>	<u>600.00</u>	<u>286</u>	<u>252</u>	<u>252</u>	<u>58</u>	<u>90</u>	<u>85</u>	<u>5</u>	<u>8.2</u>		
<u>5</u>	<u>25</u>	<u>0.49</u>	<u>1.2</u>	<u>603.00</u>	<u>287</u>	<u>250</u>	<u>253</u>	<u>59</u>	<u>91</u>	<u>86</u>	<u>5</u>	<u>8.4</u>	<u>603 80<sup>th</sup></u>	
<u>2-1</u>	<u>30</u>	<u>0.46</u>	<u>1.1</u>	<u>606.92</u>	<u>285</u>	<u>251</u>	<u>252</u>	<u>62</u>	<u>92</u>	<u>87</u>	<u>5</u>	<u>8.8</u>		
<u>2</u>	<u>35</u>	<u>0.47</u>	<u>1.2</u>	<u>609.95</u>	<u>285</u>	<u>251</u>	<u>251</u>	<u>55</u>	<u>93</u>	<u>87</u>	<u>5</u>	<u>8.8</u>		
<u>3</u>	<u>40</u>	<u>0.51</u>	<u>1.2</u>	<u>612.97</u>	<u>286</u>	<u>250</u>	<u>252</u>	<u>56</u>	<u>95</u>	<u>88</u>	<u>5</u>	<u>8.8</u>		
<u>4</u>	<u>45</u>	<u>0.50</u>	<u>1.2</u>	<u>615.98</u>	<u>285</u>	<u>251</u>	<u>250</u>	<u>57</u>	<u>96</u>	<u>89</u>	<u>5</u>	<u>8.9</u>		
<u>5</u>	<u>50</u>	<u>0.51</u>	<u>1.2</u>	<u>618.97</u>	<u>285</u>	<u>250</u>	<u>250</u>	<u>59</u>	<u>97</u>	<u>89</u>	<u>5</u>	<u>9.1</u>	<u>619.60</u>	
<u>3-1</u>	<u>55</u>	<u>0.52</u>	<u>1.2</u>	<u>622.70</u>	<u>286</u>	<u>253</u>	<u>252</u>	<u>61</u>	<u>99</u>	<u>90</u>	<u>5</u>	<u>8.7</u>		
<u>2</u>	<u>60</u>	<u>0.53</u>	<u>1.3</u>	<u>625.75</u>	<u>286</u>	<u>254</u>	<u>253</u>	<u>59</u>	<u>100</u>	<u>90</u>	<u>5</u>	<u>8.8</u>		
			<u>1.1</u>		<u>287</u>				<u>259</u>					
	Total			<u>75.810</u>	<u>285</u>									
	Average	<u>1.7026</u>	<u>1.1880</u>		<u>286.0000</u>				<u>92.8200</u>					

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC SD  
Date 9/28/13

TEST LOCATION: F  
 UNIT: 2 RUN: 3

Metals TESTING  
 FIELD DATA SHEET

METHOD: 29 PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>12218</u>
Plant	Date <u>9/26/13</u>
Meter Operator	
Probe Operator	

Meter Box	Sample Box No.
Meter $Y_d$	Meter $\Delta H_{\oplus}$
K Factor	Pitot $C_p$

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/>	After: Good	<input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
---------------------------------------	--------------------	-----------------------------------	------------------------------------------

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head $\Delta P$ (in. H <sub>2</sub> O)	Orifice Setting $\Delta H$ (in. H <sub>2</sub> O)	Gas Sample Volume $V_m$ Init. Vol. [ft <sup>3</sup> ] [L]	Stack Temp. $T_s$ (°F)	Probe $T_p$ (°F)	Filter $T_f$ (°F)	Cond. Temp. $T_c$ (°F)	DGM Inlet $T_{min}$ (°F)	DGM Outlet $T_{mout}$ (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. $T_1$ (°F) $\beta_2$	Notes
						Set Points							
3-3	65	0.45	1.1	628.78	285	251	252	60	98	90	5	8.6	
4	70	0.47	1.1	631.74	286	253	250	59	98	90	5	8.5	
5	75	0.53	1.3	634.71	287	251	250	55	98	90	5	8.2	635.23 <sup>52</sup>
4-1	80	0.55	1.3	638.78	286	252	252	57	99	91	5	8.3	
2	85	0.50	1.2	641.81	286	252	253	59	99	90	5	8.7	
3	90	0.51	1.2	644.80	287	251	254	60	100	91	5	8.8	
4	95	0.49	1.2	647.80	285	253	253	61	100	91	5	8.9	
5	100	0.46	1.1	650.74	285	251	251	62	100	91	5	8.9	651.23 <sup>59</sup>
5-1	105	0.48	1.2	654.23	286	250	251	60	100	92	5	8.7	
2	110	0.51	1.2	657.31	287	249	250	58	101	92	5	8.6	
3	115	0.53	1.3	660.37	286	250	253	57	101	92	5	8.5	
4	120	0.50	1.2	663.39	285	251	253	59	102	92	5	8.6	
5	125	0.50	1.2	666.350	286	252	253	60	102	92	5	8.6	
	Total	*											
	Average												

\* Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC  
 Date 10/1/13

E-8

TEST LOCATION:

FF Outlet

Metals

TESTING


METHOD: 29 26 PAGE 1 OF 2

UNIT: 2

RUN: 4

FIELD DATA SHEET

Client Wheelabrator	Project No. 12218
Plant N. Broward	Date 9/26/13
Meter Operator S. Dookey	
Probe Operator S. Dookey	



Amb. Temp. (°F) 88	Bar. Press. 29.90 (in. Hg) [mbar]
Probe I.D. No. 66-8-1	
Liner Material Glass	

Meter Box 66-20	Sample Box No. M10
Meter Yd 1.0031	Meter ΔH@ 1.7992
K Factor 2.6	Pitot Cp 0.814

Filter No. NA	
Thimble No. NA	
Nozzle Diameter 0.275	Nozzle I.D. 275-2

Leak Rate Before 0.00 (in. Hg) [Lpm] @ 15 (in. Hg)	
Leak Rate After 0.00 (in. Hg) [Lpm] @ 8 (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Duct Dimensions (in.) 96x96			
Static Pres (in. H <sub>2</sub> O) -11.0	Port Len. (in.) 12.0	Gas Flow (In) (Out) of page (In) (Out)	First point all the way (In) (Out)

Start Time: 10:18	Stop Time: 12:40
-------------------	------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>min</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T <sub>i</sub> (°F) O <sub>2</sub>	Notes
						Set Points							
1-1	5	0.42	1.1	672.27	285	255	255	63	97	93	5	7.4	
2	10	0.43	1.1	675.22	284	257	255	62	99	94	5	8.1	
3	15	0.42	1.1	678.21	285	251	252	60	99	94	5	8.0	
4	20	0.50	1.3	681.24	287	252	251	57	100	94	5	8.2	
5	25	0.51	1.3	684.36	286	254	251	57	101	94	5	8.5	685.08
2-1	30	0.43	1.1	688.23	286	254	251	59	101	94	5	8.1	
2	35	0.47	1.2	691.33	286	251	252	61	101	98	5	8.7	
3	40	0.46	1.2	694.37	286	252	252	55	102	95	5	8.9	
4	45	0.47	1.2	697.45	285	252	250	58	102	94	5	8.3	
5	50	0.49	1.3	700.49	286	250	250	62	102	95	5	8.4	701.02
3-1	55	0.50	1.3	704.21	284	249	251	60	103	95	5	8.5	
2	60	0.42	1.1	707.27	285	255	252	61	103	95	5	8.6	
			1.3		285	2			242				
Total				79.1700									
Average		0.4867	1.2280	79.1700	285.3200				99.1200				

Sum of square roots.

Circle correct bracketed units on data sheet.

26.800 58

QA/QC Date 9/26/13

99.140 10/10





TEST LOCATION: FF Outlet

Metals TESTING

METHOD: 29 PAGE 2 OF 2


UNIT: 2 RUN: 4

**FIELD DATA SHEET**

Client	<u>Wheelabrator</u>	Project No.	<u>12218</u>
Plant		Date	<u>9/26/13</u>
Meter Operator	<u>S Dooley</u>		
Probe Operator	<u>S Dooley</u>		

Meter Box	Sample Box No.
Meter Y <sub>d</sub>	Meter ΔH <sub>@</sub>
K Factor	Pitot C <sub>p</sub>

Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/>	After: Good	<input type="checkbox"/> Bad <input type="checkbox"/>



Duct Dimensions (in.)			
Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. <u>(L)</u>	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub>	Filter T <sub>f</sub>	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	XAD Tap Temp.	Notes
						Set Points						1	
						250	250					8.1	
3-3	65	0.49	1.3	70.27	286	251	252	60	102	95	5	8.1	
4	70	0.50	1.3	713.38	285	250	252	60	103	95	5	8.7	
5	75	0.51	1.3	716.53	287	251	256	61	104	96	5	8.6	717.15 o.c. 2
4-1	80	0.50	1.3	720.00	284	251	251	63	104	96	5	8.5	
2	85	0.51	1.3	723.45	286	252	251	60	104	96	5	8.8	
3	90	0.49	1.3	726.20	286	253	251	55	104	96	5	8.9	
4	95	0.45	1.1	729.34	285	250	250	57	104	96	5	8.7	
5	100	0.49	1.3	732.42	284	255	250	59	105	97	5	8.6	732.92 o.s
5-1	105	0.45	1.2	736.06	285	251	250	60	106	97	5	8.4	
2	110	0.46	1.2	739.20	286	253	250	60	106	97	5	8.5	
3	115	0.46	1.2	742.31	284	252	253	62	106	97	5	8.7	
4	120	0.48	1.3	745.42	285	250	251	63	107	97	5	8.8	
5	125	0.49	1.3	748.51	285	249	251	63	107	97	5	8.9	
	Total												
	Average												

Sum of square roots.

Circle correct bracketed units on data sheet.

QA/QC SD  
Date 10/13



E - 10

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 FF Outlet	
Plant North Broward	Job No. 12118	Method	29

Balance Calibration Check			
Balance ID	802470 1068	Reference Weight Mass	500
Reference Weight ID	60150	Reference Weight Reading	499.8
Check must be performed at least Once per Method per Job		Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.	

Run No.	1	Filter Type Quartz	Sample Box No. M11
Date	9/25	Lot No. NA	pH NA
Analyst	S. Brown	Filter No. Untared	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	779.2	451.4	327.8	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	769.6	544.1	223.5	QA/QC SB
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	558.1	536.5	21.6	Date 9/25
Impinger 4	Empty	440.0	438.1	1.9	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	539.2	537.0	2.2	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	536.3	536.5	-0.2	576.8
Impinger 7	≈ 250 g Silica Gel	763.5	743.9	19.6	596.4

Run No.	2	Filter Type Quartz	Sample Box No. M10
Date	9/25	Lot No. NA	pH NA
Analyst	S. Brown	Filter No. Untared	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	793.4	439.3	354.1	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	758.1	550.7	207.4	QA/QC SB
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	566.7	541.7	25.0	Date 9/25
Impinger 4	Empty	439.4	436.3	3.1	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	537.1	534.5	2.6	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	523.1	521.2	1.9	594.1
Impinger 7	≈ 250 g Silica Gel	781.7	763.6	18.1	612.2

Run No.	3	Filter Type Quartz	Sample Box No. M11
Date		Lot No. NA	pH NA
Analyst		Filter No. Untared	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	775.6	452.9	322.7	0
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	784.5	545.9	238.6	0
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	557.6	537.0	20.6	0
Impinger 4	Empty	442.0	438.7	3.3	0
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	552.8	552.0	0.8	0
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	535.5	535.1	0.4	0
Impinger 7	≈ 250 g Silica Gel	780.6	763.3	17.3	0

QA/QC SB  
Date 9/26



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 FF Outlet	
Plant North Broward	Job No. 12118	Method	29

Balance Calibration Check			
Balance ID		Reference Weight Mass	
Reference Weight ID		Reference Weight Reading	

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 4	Filter Type Quartz	Sample Box No.
Date 9/26/13 <del>9/16/2012</del>	Lot No. NA	pH NA
Analyst J.D. <del>R. Vicere</del> S. Byrd	Filter No. Untared	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)				
Impinger 1	100 ml 0.1 N H2SO4	817.7	439.8	377.9	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>QA/QC <del>SB</del></td></tr> <tr><td>Date 9/26</td></tr> <tr><td>Total Weight (gm)</td></tr> </table>	QA/QC <del>SB</del>	Date 9/26	Total Weight (gm)
QA/QC <del>SB</del>								
Date 9/26								
Total Weight (gm)								
Impinger 2	100 ml 0.1 N H2SO4	753.3	553.1	200.2				
Impinger 3	Empty	563.2	545.5	17.7				
Impinger 4	Empty	440.8	436.7	4.1				
Impinger 5	100 ml 4%KMnO4/10%H2SO4	540.1	537.4	2.7				
Impinger 6	100 ml 4%KMnO4/10%H2SO4	524.6	523.6	1.0				
Impinger 7	≈ 250 g Silica Gel	798.9	781.2	17.7	621.3			

Run No.	Filter Type	Sample Box No.
Date	Lot No.	pH
Analyst	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)				
Impinger 1					<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>QA/QC</td></tr> <tr><td>Date</td></tr> <tr><td>Total Weight (gm)</td></tr> </table>	QA/QC	Date	Total Weight (gm)
QA/QC								
Date								
Total Weight (gm)								
Impinger 2								
Impinger 3								
Impinger 4								
Impinger 5								
Impinger 6								
Impinger 7								

Run No.	Filter Type	Sample Box No.
Date	Lot No.	pH
Analyst	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)				
Impinger 1				0	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>QA/QC</td></tr> <tr><td>Date</td></tr> <tr><td>Total Weight (gm)</td></tr> </table>	QA/QC	Date	Total Weight (gm)
QA/QC								
Date								
Total Weight (gm)								
Impinger 2				0				
Impinger 3				0				
Impinger 4				0				
Impinger 5				0				
Impinger 6				0				
Impinger 7				0				

QA/QC JD  
Date 9/26



# ORSAT READINGS

TEST LOCATION: Unit 2 FF Dotted

PAGE 1 OF 1

Client <u>Wheelabrator</u>	Project Number <u>12218</u>	$F_o = \frac{20.9 - \%O_2}{\%CO_2}$
Plant <u>North Broward</u>	Unit <u>2</u>	
Orsat ID	Fuel Type <u>MSW</u>	Leak Check Passed <input checked="" type="checkbox"/>

Run Number	Method Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	F <sub>o</sub>	Analyst	Analysis	
								Date	Time
		1							
		2							
		3							
		Avg.							
<u>2</u>	<u>29</u>	1	<u>8.6</u>	<u>19.3</u>	<u>10.7</u>		<u>S. Brown</u>	<u>9/11</u>	<u>12:07</u>
		2	<u>8.5</u>	<u>19.2</u>	<u>10.7</u>				
		3	<u>8.6</u>	<u>19.2</u>	<u>10.6</u>				
		Avg.	<u>8.6</u>	<u>19.3</u>	<u>10.7</u>				
<u>1</u>	<u>29</u>	1	<u>10.8</u>	<u>19.0</u>	<u>8.2</u>		<u>S. Brown</u>	<u>9/25</u>	<u>14:16</u>
		2	<u>10.8</u>	<u>19.0</u>	<u>8.2</u>				
		3	<u>10.7</u>	<u>19.0</u>	<u>8.2</u>				
		Avg.	<u>10.8</u>	<u>19.0</u>	<u>8.2</u>				
<u>2</u>	<u>29</u>	1	<u>10.6</u>	<u>19.3</u>	<u>8.7</u>		<u>S. Brown</u>	<u>9/25</u>	<u>14:50</u>
		2	<u>10.6</u>	<u>19.4</u>	<u>8.8</u>				
		3	<u>10.6</u>	<u>19.3</u>	<u>8.7</u>				
		Avg.	<u>10.6</u>	<u>19.3</u>	<u>8.7</u>				
<u>3</u>	<u>29</u>	1	<u>10.6</u>	<u>19.2</u>	<u>8.6</u>		<u>S. Brown</u>	<u>9/26</u>	<u>11:10</u>
		2	<u>10.5</u>	<u>19.1</u>	<u>8.4</u>				
		3	<u>10.7</u>	<u>19.1</u>	<u>8.6</u>				
		Avg.	<u>10.5</u>	<u>19.1</u>	<u>8.6</u>				
<u>4</u>	<u>29</u>	1	<u>10.5</u>	<u>19.0</u>	<u>8.5</u>		<u>S. Brown</u>	<u>9/26</u>	<u>13:45</u>
		2	<u>10.6</u>	<u>19.1</u>	<u>8.5</u>				
		3	<u>10.5</u>	<u>19.0</u>	<u>8.5</u>				
		Avg.	<u>10.5</u>	<u>19.0</u>	<u>8.5</u>				

Repeat the analysis procedure until the results of any three analyses differ by no more than 0.2 percent by volume. Average the three acceptable values and report the results to the nearest 0.1 percent. Calculate F<sub>o</sub> to verify results

Acceptable ranges for F<sub>o</sub>:

Coal: Anthracite and Lignite	1.016-1.130	Gas: Natural	1.600-1.836
Oil: Bituminous	1.083-1.230	Propane	1.434-1.586
Oil: Distillate	1.260-1.413	Butane	1.405-1.553
Oil: Residual	1.210-1.370	Wood	1.000-1.120
Municipal Solid Waste	1.030-1.300	Wood Bark	1.003-1.130

**This Page Intentionally Left Blank**

**FIELD DATA PRINTOUTS**

F

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials:   SJ  

Date:   10/23  



**This Page Intentionally Left Blank**

### Field Data Printout

Location: Unit 2 FF Outlet  
 Test Run: 1  
 Client: Wheelabrator  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: S. Dooley 593  
 Probe Operator: S. Dooley 593  
 Test Date: 9/25/13  
 Start Time: 10:06  
 Stop Time: 12:27  
 Leak Rate Before: 0.008 cfm @ 15 "Hg  
 Leak Rate After: 0.005 cfm @ 7 "Hg

Test Method:  
 Analyte:

USEPA Method 29  
 Mercury

Bar. Press. (in. Hg): 29.90  
 Static P: -10.0  
 O<sub>2</sub> (dry volume %): 8.43  
 CO<sub>2</sub> (dry volume %): 10.80  
 N<sub>2</sub>+CO (dry volume %): 80.77

Nozzle ID No: 0.275-1  
 Nozzle Diameter (D<sub>n</sub>): 0.275  
 Probe ID No: 66-8-1  
 Pitot C<sub>p</sub>: 0.814  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 576.8  
 H<sub>2</sub>O (silica, g): 19.6  
 Actual Moisture (%): 27.42

Meter Box ID. No: 66-20  
 Meter ΔH@: 1.79920  
 Meter Y<sub>d</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			420.830						
1-01	5.0	0.42	1.1	423.690	273	87	85	0.65	2.86	100.9
1-02	10.0	0.42	1.1	426.590	273	89	86	0.65	2.90	102.0
1-03	15.0	0.45	1.2	429.570	275	90	86	0.67	2.98	101.3
1-04	20.0	0.47	1.2	432.500	273	91	87	0.69	2.93	97.2
1-05	25.0	0.50	1.3	435.640	272	93	89	0.71	3.14	100.6
				436.220						
2-01	30.0	0.43	1.2	439.350	273	93	89	0.66	3.13	108.1
2-02	35.0	0.52	1.4	442.560	273	94	90	0.72	3.21	100.7
2-03	40.0	0.50	1.3	445.730	273	95	90	0.71	3.17	101.3
2-04	45.0	0.50	1.3	448.890	273	95	91	0.71	3.16	100.9
2-05	50.0	0.53	1.4	451.990	273	96	90	0.73	3.10	96.2
				452.470						
3-01	55.0	0.50	1.3	455.690	273	96	91	0.71	3.22	102.7
3-02	60.0	0.49	1.3	458.750	272	97	92	0.70	3.06	98.4
3-03	65.0	0.51	1.3	461.930	272	100	93	0.71	3.18	99.8
3-04	70.0	0.50	1.3	465.120	272	103	94	0.71	3.19	100.8
3-05	75.0	0.49	1.3	468.200	273	103	95	0.70	3.08	98.3
				468.890						
4-01	80.0	0.42	1.1	472.070	272	104	95	0.65	3.18	109.4
4-02	85.0	0.45	1.2	474.990	273	104	96	0.67	2.92	97.0
4-03	90.0	0.45	1.2	478.320	272	104	96	0.67	3.33	110.6*
4-04	95.0	0.45	1.2	481.480	272	105	96	0.67	3.16	104.8
4-05	100.0	0.47	1.3	484.100	272	105	96	0.69	2.62	85.1*
				485.880						
5-01	105.0	0.48	1.3	489.100	273	103	96	0.69	3.22	103.7
5-02	110.0	0.46	1.3	492.470	272	103	97	0.68	3.37	110.7*
5-03	115.0	0.49	1.4	495.620	273	103	97	0.70	3.15	100.4
5-04	120.0	0.50	1.3	498.950	272	103	98	0.71	3.33	104.8
5-05	125.0	0.50	1.3	502.110	273	103	99	0.71	3.16	99.5
Final	125.0		1.26400	77.75000	272.68000	95.46000		0.68954	77.75000	

25 points sampled

Sq.Rt.ΔP	0.6895	1.2640	77.7500	272.6800	95.4600
----------	--------	--------	---------	----------	---------

QC-Check: Field Averages

Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK

101113 090148  
M



**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 29**  
**Mercury**

Location: Unit 2 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: S. Dooley 593  
 Probe Operator: S. Dooley 593  
 Test Date: 9/25/13  
 Start Time: 12:45  
 Stop Time: 15:14  
 Leak Rate Before: 0.005 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 8 "Hg

Bar. Press. (in. Hg): 29.90  
 Static P: -10.0  
 O<sub>2</sub> (dry volume %): 8.73  
 CO<sub>2</sub> (dry volume %): 10.60  
 N<sub>2</sub>+CO (dry volume %): 80.67

Nozzle ID No: 0.275-1  
 Nozzle Diameter (D<sub>n</sub>): 0.275  
 Probe ID No: 66-8-1  
 Pitot C<sub>p</sub>: 0.814  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 594.1  
 H<sub>2</sub>O (silica, g): 18.1  
 Actual Moisture (%): 27.75

Meter Box ID. No: 66-20  
 Meter ΔH@: 1.79920  
 Meter Y<sub>d</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			503.330						
5-01	5.0	0.45	1.2	506.440	272	94	91	0.67	3.11	105.1
5-02	10.0	0.45	1.2	509.440	272	94	91	0.67	3.00	101.3
5-03	15.0	0.50	1.3	512.620	272	96	92	0.71	3.18	101.7
5-04	20.0	0.51	1.3	515.910	272	97	92	0.71	3.29	104.0
5-05	25.0	0.52	1.3	518.900	273	98	92	0.72	2.99	93.6
				520.000						
4-01	30.0	0.50	1.3	523.300	272	100	93	0.71	3.30	105.0
4-02	35.0	0.50	1.3	526.440	272	100	93	0.71	3.14	99.9
4-03	40.0	0.52	1.3	529.110	272	101	94	0.72	2.67	83.2*
4-04	45.0	0.53	1.4	532.850	272	102	94	0.73	3.74	115.3*
4-05	50.0	0.49	1.2	535.860	271	102	95	0.70	3.01	96.3
				536.060						
3-01	55.0	0.51	1.3	539.030	272	103	95	0.71	2.97	93.2
3-02	60.0	0.51	1.3	541.810	272	103	94	0.71	2.78	87.3*
3-03	65.0	0.51	1.3	544.900	272	102	94	0.71	3.09	97.1
3-04	70.0	0.50	1.3	547.940	272	102	94	0.71	3.04	96.5
3-05	75.0	0.49	1.3	551.100	272	102	95	0.70	3.16	101.2
				553.520						
2-01	80.0	0.50	1.3	556.890	273	103	94	0.71	3.37	106.9
2-02	85.0	0.50	1.3	559.910	273	103	95	0.71	3.02	95.7
2-03	90.0	0.51	1.3	563.090	271	103	95	0.71	3.18	99.7
2-04	95.0	0.49	1.3	566.270	272	104	95	0.70	3.18	101.7
2-05	100.0	0.49	1.3	569.450	272	104	95	0.70	3.18	101.7
				570.190						
1-01	105.0	0.48	1.2	573.630	272	105	96	0.69	3.44	110.9*
1-02	110.0	0.47	1.2	576.790	272	105	95	0.69	3.16	103.0
1-03	115.0	0.51	1.3	580.100	272	105	95	0.71	3.31	103.6
1-04	120.0	0.50	1.3	583.420	271	105	95	0.71	3.32	104.9
1-05	125.0	0.50	1.3	586.620	272	106	96	0.71	3.20	101.0
Final	125.0		1.28400	78.83000	272.00000	97.78000		0.70528	78.83000	

25 points sampled

Sq. Rt. ΔP	0.7053	1.2840	78.8300	272.0000	97.7800
QC-Check: Field Averages	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

101113 080148  
M

**Field Data Printout**

Location: Unit 2 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: S. Dooley 593  
 Probe Operator: S. Dooley 593  
 Test Date: 9/26/13  
 Start Time: 07:41  
 Stop Time: 09:58  
 Leak Rate Before: 0.001 cfm @ 15 "Hg  
 Leak Rate After: 0.001 cfm @ 9 "Hg

Test Method:  
 Analyte:

USEPA Method 29  
 Mercury

Bar. Press. (in. Hg): 29.90  
 Static P: -11.0  
 O<sub>2</sub> (dry volume %): 8.53  
 CO<sub>2</sub> (dry volume %): 10.60  
 N<sub>2</sub>+CO (dry volume %): 80.87

Nozzle ID No: 0.275-1  
 Nozzle Diameter (D<sub>n</sub>): 0.275  
 Probe ID No: 66-8-1  
 Pitot C<sub>p</sub>: 0.814  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 586.4  
 H<sub>2</sub>O (silica, g): 17.3  
 Actual Moisture (%): 28.08

Meter Box ID. No: 66-20  
 Meter ΔH@: 1.79920  
 Meter Y<sub>a</sub>: 1.00310

. Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			588.100						
1-01	5.0	0.45	1.1	591.100	288	85	84	0.67	3.00	104.4
1-02	10.0	0.45	1.1	594.050	287	87	85	0.67	2.95	102.3
1-03	15.0	0.46	1.1	596.990	287	89	85	0.68	2.94	100.7
1-04	20.0	0.50	1.2	600.000	286	90	85	0.71	3.01	98.8
1-05	25.0	0.49	1.2	603.000	287	91	86	0.70	3.00	99.3
				603.800						
2-01	30.0	0.46	1.1	606.920	285	92	87	0.68	3.12	106.2
2-02	35.0	0.49	1.2	609.950	285	93	87	0.70	3.03	99.9
2-03	40.0	0.51	1.2	612.970	286	95	88	0.71	3.02	97.4
2-04	45.0	0.50	1.2	615.980	285	96	89	0.71	3.01	97.8
2-05	50.0	0.51	1.2	618.970	285	97	89	0.71	2.99	96.1
				619.600						
3-01	55.0	0.52	1.2	622.700	286	99	90	0.72	3.10	98.5
3-02	60.0	0.53	1.3	625.750	286	100	90	0.73	3.05	95.9
3-03	65.0	0.45	1.1	628.780	285	98	90	0.67	3.03	103.5
3-04	70.0	0.47	1.1	631.740	286	98	90	0.69	2.96	99.0
3-05	75.0	0.53	1.3	634.710	287	98	90	0.73	2.97	93.6
				635.230						
4-01	80.0	0.55	1.3	638.780	286	99	91	0.74	3.55	109.6
4-02	85.0	0.50	1.2	641.810	286	99	90	0.71	3.03	98.2
4-03	90.0	0.51	1.2	644.800	287	100	91	0.71	2.99	95.8
4-04	95.0	0.49	1.2	647.800	285	100	91	0.70	3.00	97.9
4-05	100.0	0.46	1.1	650.740	285	100	91	0.68	2.94	99.0
				651.230						
5-01	105.0	0.48	1.2	654.230	286	100	92	0.69	3.00	98.9
5-02	110.0	0.51	1.2	657.310	287	101	92	0.71	3.08	98.5
5-03	115.0	0.53	1.3	660.370	286	101	92	0.73	3.06	96.0
5-04	120.0	0.50	1.2	663.390	285	102	92	0.71	3.02	97.3
5-05	125.0	0.50	1.2	666.350	286	102	92	0.71	2.96	95.5
Final	125.0		1.18800	75.81000	286.00000	92.82000		0.70258	75.81000	

25 points sampled  
 QC-Check: Field Averages

Sq. RL ΔP				
0.7026	1.1880	75.8100	286.0000	92.8200
<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

101113 080148  
 0

Field Data Printout

Test Method:  
Analyte:

USEPA Method 29  
Mercury

Location: Unit 2 FF Outlet  
Test Run: 4  
Client: Wheelabrator  
Project No: 12218  
Source Area (ft<sup>2</sup>): 64.00000  
Meter Operator: S. Dooley 593  
Probe Operator: S. Dooley 593  
Test Date: 9/26/13  
Start Time: 10:18  
Stop Time: 12:40  
Leak Rate Before: 0.004 cfm @ 15 "Hg  
Leak Rate After: 0.001 cfm @ 8 "Hg

Bar. Press. (in. Hg): 29.90  
Static P: -11.0  
O<sub>2</sub> (dry volume %): 8.50  
CO<sub>2</sub> (dry volume %): 10.53  
N<sub>2</sub>+CO (dry volume %): 80.97

Nozzle ID No: 0.275-1  
Nozzle Diameter (D<sub>n</sub>): 0.275  
Probe ID No: 66-8-1  
Pitot C<sub>p</sub>: 0.814  
Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 603.6  
H<sub>2</sub>O (silica, g): 17.7  
Actual Moisture (%): 28.63

Meter Box ID. No: 66-20  
Meter ΔH@: 1.79920  
Meter Y<sub>d</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			669.340						
1-01	5.0	0.42	1.10	672.270	285	97	93	0.65	2.93	104.0
1-02	10.0	0.43	1.10	675.220	284	99	94	0.66	2.95	103.2
1-03	15.0	0.42	1.10	678.210	285	99	94	0.65	2.99	105.9
1-04	20.0	0.50	1.30	681.240	287	100	94	0.71	3.03	98.4
1-05	25.0	0.51	1.30	684.360	286	101	94	0.71	3.12	100.2
				685.080						
2-01	30.0	0.43	1.10	686.230	286	101	94	0.66	3.15	110.1*
2-02	35.0	0.47	1.20	691.330	286	102	95	0.69	3.10	103.5
2-03	40.0	0.46	1.20	694.370	286	102	94	0.68	3.04	102.7
2-04	45.0	0.47	1.20	697.450	285	102	95	0.69	3.08	102.7
2-05	50.0	0.49	1.30	700.490	286	102	95	0.70	3.04	99.4
				701.020						
3-01	55.0	0.50	1.30	704.210	284	103	95	0.71	3.19	103.0
3-02	60.0	0.42	1.10	707.270	285	103	95	0.65	3.06	107.9
3-03	65.0	0.49	1.30	710.270	286	102	95	0.70	3.00	98.1
3-04	70.0	0.50	1.30	713.380	285	103	95	0.71	3.11	100.5
3-05	75.0	0.51	1.30	716.530	287	104	96	0.71	3.15	100.8
				717.150						
4-01	80.0	0.50	1.30	720.000	284	104	96	0.71	2.85	91.9
4-02	85.0	0.51	1.30	723.450	286	104	96	0.71	3.45	110.3*
4-03	90.0	0.49	1.30	726.200	286	104	96	0.70	2.75	89.7*
4-04	95.0	0.45	1.10	729.340	285	104	96	0.67	3.14	106.7
4-05	100.0	0.49	1.30	732.420	284	105	97	0.70	3.08	100.1
				732.920						
5-01	105.0	0.45	1.20	736.060	285	106	97	0.67	3.14	106.5
5-02	110.0	0.46	1.20	739.200	286	106	97	0.68	3.14	105.4
5-03	115.0	0.46	1.20	742.310	284	106	97	0.68	3.11	104.2
5-04	120.0	0.48	1.30	745.420	285	107	97	0.69	3.11	102.0
5-05	125.0	0.49	1.30	748.510	285	107	97	0.70	3.09	100.4
Final	125.0		1.22800	76.80000	285.32000	99.14000		0.68667	76.80000	

25 points sampled  
QC-Check: Field Averages  
Sq.Rt.ΔP  
0.6867 1.2280 76.8000 285.3200 99.1400  
 Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

101113 090148  
K

**USEPA Method 3 Laboratory Data**

Location: Unit 2 FF Outlet  
 Client: Wheelabrator  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEPA Method 29  
 Analyte: Mercury

Analyst: S. Brown  
 Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: Orsat
1	1	10.8	19.3	8.5	80.7	30.07	1.15432	All measurements in spec. <input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
	2	10.8	19.2	8.4	80.8	30.06		
	3	10.8	19.2	8.4	80.8	30.06		
Avg.		10.80000		8.43333	80.76667	30.07		
CEM or Other Avg:								

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: Orsat
2	1	10.6	19.3	8.7	80.7	30.04	1.14780	All measurements in spec. <input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
	2	10.6	19.4	8.8	80.6	30.05		
	3	10.6	19.3	8.7	80.7	30.04		
Avg.		10.60000		8.73333	80.66667	30.05		
CEM or Other Avg:								

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: Orsat
3	1	10.6	19.2	8.6	80.8	30.04	1.16667	All measurements in spec. <input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
	2	10.5	19.1	8.6	80.9	30.02		
	3	10.7	19.1	8.4	80.9	30.05		
Avg.		10.60000		8.53333	80.86667	30.04		
CEM or Other Avg:								

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: Orsat
4	1	10.5	19.0	8.5	81.0	30.02	1.17722	All measurements in spec. <input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
	2	10.6	19.1	8.5	80.9	30.04		
	3	10.5	19.0	8.5	81.0	30.02		
Avg.		10.53333		8.50000	80.96667	30.03		
CEM or Other Avg:								

101113 090148  
 M N O K

**USEPA Method 4 Laboratory Data**

Location: Unl 2 FF Outlet  
 Client: Wheelabrator  
 Project No: 12218

**Test Method: USEPA Method 29**  
**Analyte: Mercury**

Analyst: S. Brown  
 Analyst Emp No: 433

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	779.2	451.4	327.8		
Impinger 2	5%HNO3/10%H2O2	767.6	544.1	223.5		
Impinger 3	5%HNO3/10%H2O2	558.1	536.5	21.6		
Impinger 4	Empty	440.0	438.1	1.9		
Impinger 5	4%KMnO4/10%H2SO4	539.2	537.0	2.2		
Impinger 6	4%KMnO4/10%H2SO4	536.3	536.5	-0.2	576.8 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	763.5	743.9	19.6	0.0 less rinse (gm)	
Impinger 8					576.8 Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
					+ 19.6 Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
					596.4 Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	793.4	439.3	354.1		
Impinger 2	5%HNO3/10%H2O2	758.1	550.7	207.4		
Impinger 3	5%HNO3/10%H2O2	566.7	541.7	25.0		
Impinger 4	Empty	439.4	436.3	3.1		
Impinger 5	4%KMnO4/10%H2SO4	537.1	534.5	2.6		
Impinger 6	4%KMnO4/10%H2SO4	523.1	521.2	1.9	594.1 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	781.7	763.6	18.1	0.0 less rinse (gm)	
Impinger 8					594.1 Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
					+ 18.1 Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
					612.2 Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	775.6	452.9	322.7		
Impinger 2	5%HNO3/10%H2O2	784.5	545.9	238.6		
Impinger 3	5%HNO3/10%H2O2	557.6	537.0	20.6		
Impinger 4	Empty	442.0	438.7	3.3		
Impinger 5	4%KMnO4/10%H2SO4	552.8	552.0	0.8		
Impinger 6	4%KMnO4/10%H2SO4	535.5	535.1	0.4	586.4 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	780.6	763.3	17.3	0.0 less rinse (gm)	
Impinger 8					586.4 Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
					+ 17.3 Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
					603.7 Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run: 4

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	817.7	439.8	377.9		
Impinger 2	5%HNO3/10%H2O2	753.3	553.1	200.2		
Impinger 3	5%HNO3/10%H2O2	563.2	545.5	17.7		
Impinger 4	Empty	440.8	436.7	4.1		
Impinger 5	4%KMnO4/10%H2SO4	540.1	537.4	2.7		
Impinger 6	4%KMnO4/10%H2SO4	524.6	523.6	1.0	603.6 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	798.9	781.2	17.7	0.0 less rinse (gm)	
Impinger 8					603.6 Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
					+ 17.7 Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
					621.3 Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

101113 090148  
MMQK

**LABORATORY DATA**

G

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SB

Date: 10/23



**This Page Intentionally Left Blank**

Wheelabrator  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

### USEPA Method 29 (Mercury) Mercury (Hg) Laboratory Parameters

**Detection Limits**

m <sub>1b-DL</sub>	Fraction 1B Detection Limit (µg)	0.1000
m <sub>2b-DL</sub>	Fraction 2B Detection Limit (µg)	0.2000
m <sub>3a-DL</sub>	Fraction 3A Detection Limit (µg)	0.2000
m <sub>3b-DL</sub>	Fraction 3B Detection Limit (µg)	0.5000
m <sub>3c-DL</sub>	Fraction 3C Detection Limit (µg)	0.4000

**Blank Analysis**

m <sub>1b-B</sub>	Fraction 1B Blank (µg)	<0.1000
m <sub>2b-B</sub>	Fraction 2B Blank (µg)	<0.2000
m <sub>3a-B</sub>	Fraction 3A Blank (µg)	<0.2000
m <sub>3b-B</sub>	Fraction 3B Blank (µg)	<0.5000
m <sub>3c-B</sub>	Fraction 3C Blank (µg)	<0.4000
m <sub>total-B</sub>	Total Blank Amount (µg)	<1.4000

Run No.	1	2	3	4
Date (2013)	Sep 25	Sep 25	Sep 26	Sep 26
Start Time (approx.)	10:06	12:45	07:41	10:18
Stop Time (approx.)	12:27	15:14	09:58	12:40

**Sample Analysis**

m <sub>1b-S</sub>	Fraction 1B Sample (µg)	0.1344	0.1242	0.1150	<0.1000
m <sub>2b-S</sub>	Fraction 2B Sample (µg)	11.9109	21.1451	12.0615	10.6516
m <sub>3a-S</sub>	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>3b-S</sub>	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>3c-S</sub>	Fraction 3C Sample (µg)	1.1783	2.4750	0.4655	0.4625
m <sub>total-S</sub>	Total Sample Amount (µg)	13.2236	23.7443	12.6420	11.1140

**Allowable Blank**

m <sub>T-B-allow</sub>	Total Allowable Blank (µg)	0.0000	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------	--------

**Sample Corrected for Blank**

m <sub>n</sub>	Total Sample Amount (µg)	13.2236	23.7443	12.6420	11.1140
----------------	--------------------------	---------	---------	---------	---------

**Sample Corrected for Blank - Prorated Fractions**

m <sub>n-1b</sub>	Fraction 1B (µg)	0.1344	0.1242	0.1150	<0.1000
m <sub>n-2b</sub>	Fraction 2B (µg)	11.9109	21.1451	12.0615	10.6516
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>n-3c</sub>	Fraction 3C (µg)	1.1783	2.4750	0.4655	0.4625

101113 085411  
 M



# **Clean Air Engineering, Inc.**


500 West Wood Street  
Palatine, IL 60067

Project Number: 12218

Mercury

EPA Method 29 Analysis

Analytical Report  
21230



Element One, Inc.  
6319-D Carolina Beach Rd., Wilmington, NC 28412  
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 21230  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:



Daphne Woodman, Chemist  
October 9, 2013

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director  
October 9, 2013

**elementOne**

21230 CAE M29 Report Packet

Page 2 of 29

# SUMMARY OF RESULTS

## Summary of Analysis

### Summary of Method 29 Mercury Analysis

Run Number		Average Total Catch, µg	Front Half µg	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub> µg	Empty Impinger µg	KMnO <sub>4</sub> µg	HCl µg
U2 Run 1	#1	13.2	0.136	12.0	< 0.2	< 0.5	1.17
	#2		0.132	11.9	< 0.2	< 0.5	1.18
U2 Run 2	#1	23.7	0.123	21.2	< 0.2	< 0.5	2.48
	#2		0.126	21.1	< 0.2	< 0.5	2.47
U2 Run 3	#1	12.6	0.117	12.1	< 0.2	< 0.5	0.464
	#2		0.113	12.0	< 0.2	< 0.5	0.467
U2 Run 4	#1	11.1	< 0.1	10.6	< 0.2	< 0.5	0.460
	#2		< 0.1	10.7	< 0.2	< 0.5	0.465
Field Blank	#1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank	#1	< 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.2	< 0.2	< 0.5	< 0.4

# ANALYTICAL NARRATIVE

**elementOne**

21230 CAE M29 Report Packet

Page 5 of 29

G - 8

## Element One Analytical Narrative

Client:	Clean Air, IL	Element One #:	21230
Client ID:	12218 Wheelabrator Pompano Beach, FL	Analyst:	LAL & JWL
Method:	Method 29	Dates Received:	09/27/13
Analytes:	Hg	Dates Analyzed:	10/01-04/13

### Summary of Analysis

The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD) and spike sample recovery data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values.

# QUALITY CONTROL SUMMARY

**elementOne**

21230 CAE M29 Report Packet

Page 7 of 29

G - 10

## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

*(Method 29 QC limits: < 10% for RPD)*

Run Number	Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U2 Run 1	2.8%	0.8%	NA	NA	0.8%
U2 Run 2	2.4%	0.1%	NA	NA	0.8%
U2 Run 3	3.6%	0.3%	NA	NA	0.5%
U2 Run 4	NA	0.9%	NA	NA	0.9%
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA

### Mercury Spike Recoveries

*(Method 29 QC limits: ± 25% for Spike Recoveries)*

Run Number		Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U2 Run 3	#1	101%	99%	100%	89%	95%
	#2	100%	98%	100%	89%	95%



# SAMPLE CUSTODY


**elementOne**

21230 CAE M29 Report Packet

Page 9 of 29


G - 12

21230


CLIENT <u>Wheelabrator</u>		PROJECT <u>12218</u>		66-12218-1			
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>					
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatka, IL 60067 800-627-0633 (phone) 847-931-3385 (fax)		NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED Mercury Archieve	FORWARDING LAB
ANALYTICAL METHOD	CONTAINER NUMBER						SAMPLE FRACTION
USEPA M-29	1	QUARTZ FILTER 250 mL HDPE				ADDITIONAL INFORMATION	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX			
	9/25	Unit 2	1	Quartz Filter, 250 mL HDPE	1	X	X
	9/25	Unit 2	2	Quartz Filter, 250 mL HDPE	1	X	X
	9/28	Unit 2	3	Quartz Filter, 250 mL HDPE	1	X	X
	9/28	Unit 2	4	Quartz Filter, 250 mL HDPE	1	X	X
	9/25	Unit 2	Field Blank	Quartz Filter, 250 mL HDPE	1	X	X
	9/11	Unit 2	2	Quartz Filter, 250 mL HDPE	1	X	X
Relinquished By: (signature) S. Brown		Date / Time 9/24/13 15:00	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by: S. Brown
Received By: (signature) L. Branton		Date / Time 9/27/13 10:38	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature Date 26-Sep

Samples received in good condition in Fisherbrand + QEC Level 2 containers. No empty containers.


21230

CLIENT <u>Wheelabrator</u>		PROJECT <u>12218</u>		66-12218-2	
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>			
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatka, IL 60067 800-627-0033 (phone) 847-931-3385 (fax)		ANALYSIS REQUESTED <input type="checkbox"/> Mercury <input type="checkbox"/> Archive	
ANALYTICAL METHOD <b>USEPA M-29</b>	CONTAINER NUMBER <b>3</b>	SAMPLE FRACTION <b>FRONT HALF HNO<sub>3</sub> RINSE 250 mL HDPE</b>		FORWARDING LAB Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION
	9/25	Unit 2	Train Proof	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X
	9/25	Unit 2	1	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X X
	10/26	Unit 2	2	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X X
	9/26	Unit 2	3	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X X
	9/26	Unit 2	4	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X X
	9/25	Unit 2	Field Blank	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X X
	9/11	Unit 2	2	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1 X X X
Relinquished By: (signature) S. Brown		Date / Time 9/26/13 15:00	Relinquished By: (signature)		Date / Time
Received By: (signature) Doug Britton		Date / Time 9/27/13 10:38	Received By: (signature)		Date / Time
				This form completed by: S. Brown Signature Date 9/26/2013	


21230

CLIENT <u>Wheelebrator</u>		PROJECT <u>12218</u>		68-12218-3			
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>88</u>					
PROJECT MANAGER <u>S. Brown</u>		 <b>Clean Air</b> <small>ENGINEERING</small> 500 West Wood Street Palatine, IL 60067 800-627-0033 (phone) 847-991-3385 (fax)		NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED Mercury Arsenic	
ANALYTICAL METHOD	CONTAINER NUMBER						SAMPLE FRACTION
USEPA M-29	4	IMPINGERS 1-3 CATCH AND RINSE 1000 mL HDPE	Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith		ADDITIONAL INFORMATION		
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX			
	9/25	Unit 2	1	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	1	X	X
	9/25	Unit 2	2	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	1	X	X
	9/26	Unit 2	3	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	1	X	X
	9/26	Unit 2	4	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	1	X	X
	9/25	Unit 2	Field Bank	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	1	X	X
	9/11	Unit 2	2	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	1	X	X
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by:
S. Brown		9/26/13 15:00					S. Brown
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature Date
<i>S. Brown</i>		9/27/13 10:38					<i>[Signature]</i> 9/28/2013


21230

CLIENT <u>Wheelebrator</u>		PROJECT <u>12218</u>		66-12218-4				
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>						
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatine, IL 60067 800-627-0033 (phone) 847-991-3385 (fax)		ANALYSIS REQUESTED Mercury Arsenic				
ANALYTICAL METHOD	CONTAINER NUMBER					SAMPLE FRACTION	FORWARDING LAB	
USEPA M-29	5A					IMPINGER 4 CATCH AND RINSE 250 mL HDPE	Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION			
	9/25	Unit 2	1	Impinger 4 Catch and Rinse, 250 mL HDPE				
	9/25	Unit 2	2	Impinger 4 Catch and Rinse, 250 mL HDPE				
	9/28	Unit 2	3	Impinger 4 Catch and Rinse, 250 mL HDPE	Note: There are two Run 2's			
	9/26	Unit 2	4	Impinger 4 Catch and Rinse, 250 mL HDPE	Only analyze the run 2 from 9/25			
	9/25	Unit 2	Field Blank	Impinger 4 Catch and Rinse, 250 mL HDPE	Run 2 from 9/11 is archived			
	9/11	Unit 2	2	Impinger 4 Catch and Rinse, 250 mL HDPE				
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by:	
S. Brown		9/24/13 15:00					S. Brown	
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature Date	
Lisa Britton		9/27/13 1038					[Signature] 9/26/2013	


21230

CLIENT <u>Wheelerator</u>		PROJECT <u>12218</u>		66-12218-5						
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>								
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatine, IL 60067 800-827-0033 (phone) 847-991-3385 (fax)		ANALYSIS REQUESTED <table border="1" style="width:100%; height: 100px;"> <tr> <td style="writing-mode: vertical-rl; transform: rotate(180deg);">Mercury</td> <td style="writing-mode: vertical-rl; transform: rotate(180deg);">Arsenic</td> </tr> </table>		Mercury	Arsenic			
Mercury	Arsenic									
ANALYTICAL METHOD	CONTAINER NUMBER	SAMPLE FRACTION	FORWARDING LAB							
USEPA M-29	5B	IMPINGERS 5-6 CATCH AND RINSE 950 mL AMBER GLASS	Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith ADDITIONAL INFORMATION							
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER SEALED?	LIQUID LEVEL MARKED?	ANALYSIS REQUESTED		FORWARDING LAB
	0/25	Unit 2	1	mpingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X		X		
	9/26	Unit 2	2	mpingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X		X		
	9/26	Unit 2	3	mpingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X		X		Note: There are two Run 2's
	9/26	Unit 2	4	mpingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X		X		Only analyze the run 2 from 9/25
	9/25	Unit 2	Field Blank	mpingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X		X		Run 2 from 9/11 is archived.
	9/11	Unit 2	2	mpingers 5-6 Catch and Rinse, 950 mL Amber Glass					X	
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)		Date / Time	Relinquished By: (signature)		Date / Time	This form completed by:	
S. Brown		9/24/13 15:00							S. Brown	
Received By: (signature)		Date / Time	Received By: (signature)		Date / Time	Relinquished By: (signature)		Date / Time	Signature Date	
Lisa Brator		9/27/13 10:38							9/26/2013	

21230

CLIENT <u>Wheolabrator</u>		PROJECT <u>12218</u>		66-12218-6				
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>						
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatine, IL 60067 800-627-0033 (phone) 847-991-3385 (fax)		ANALYSIS REQUESTED <input type="checkbox"/> Mercury <input type="checkbox"/> Arsenic				
ANALYTICAL METHOD <b>USEPA M-29</b>	CONTAINER NUMBER <b>G</b>	SAMPLE FRACTION <b>IMPINGERS 5-6 CATCH AND RINSE 250 mL AMBER GLASS</b>		FORWARDING LAB Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ron Smith				
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ADDITIONAL INFORMATION	
	9/25	Unit 2	1	Impinger 5-6 8N HCl + DI Water, Container: 250 mL Amber Glass	1	X	X	
	9/26	Unit 2	2	Impinger 5-6 8N HCl + DI Water, Container: 250 mL Amber Glass	1	X	X	
	9/26	Unit 2	3	Impinger 5-6 8N HCl + DI Water, Container: 250 mL Amber Glass	1	X	X	
	9/26	Unit 2	4	Impinger 5-6 8N HCl + DI Water, Container: 250 mL Amber Glass	1	X	X	
	9/26	Unit 2	Field Blank	Impinger 5-6 8N HCl + DI Water, Container: 250 mL Amber Glass	1	X	X	
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)		Date / Time	Relinquished By: (signature)		Date / Time
S. Brown		9/26/13 15:57						This form completed by:
Received By: (signature)		Date / Time	Received By: (signature)		Date / Time	Received By: (signature)		Date / Time
<i>Lois Britton</i>		9/27/13 10:38						S. Brown Signature Date 9/26/2013

21230

CLIENT <u>Wheelabrator</u>		PROJECT <u>1221B</u>		66-12218-7				
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>68</u>						
PROJECT MANAGER <u>S. Brown</u>		 <p><b>Clean Air</b> INCORPORATING 500 West Wood Street Palatine, IL 60067 800-827-0033 (phone) 847-891-3385 (fax)</p>		NUMBER OF CONTAINERS CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED Mercury Archive	FORWARDING LAB		
ANALYTICAL METHOD	CONTAINER NUMBER					SAMPLE FRACTION	Element One, Inc	
USEPA M-29	SEE BELOW (IF APPLICABLE)					REAGENT BLANKS	6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX		ADDITIONAL INFORMATION		
	9/25	Reagent Blank	All	4% TN HNO <sub>3</sub> (500 mL), Container 9A: 500 mL HDPE	1	X	X	
	9/25	Reagent Blank	All	D <sub>2</sub> O Water (100 mL), Container 8B: 200 mL HDPE	1	X	X	
	9/25	Reagent Blank	All	5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub> (200 mL), Container B: 250 mL HDPE	1	X	X	
	9/25	Reagent Blank	All	4% HNO <sub>3</sub> / 10% H <sub>2</sub> SO <sub>4</sub> (100 mL), Container 10: 250 mL Amber Glass	1	X	X	
	9/25	Reagent Blank	All	D <sub>2</sub> O Water (200 mL) / 6N HCl (25 mL), Container 11: 250 mL Amber Glass	1	X	X	
	9/25	Reagent Blank	All	Quartz Fillers (3), Container 12: 250 mL HDPE	1	X	X	
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by:	
S. Brown		9/26/13 10:58					S. Brown	
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature	Date
Lisa Brown		9/27/13 10:58					X	9/28/2013



# ANALYTICAL DATA

## Analytical Calculations

### Mercury-

$$\text{Mercury Results } (\mu\text{g}) = \frac{\text{CVAA Results } (\mu\text{g}) * \text{Final Volume (ml)}}{\text{Aliquot (ml)}}$$

### Where-

CVAA Results= Raw sample reading ( $\mu\text{g}$ )--*Hg-Data Sheet*

Aliquot= Sample Aliquot (Alq.)--*Hg-Data Sheet*

Final Volume=Final Volume (FV)\*--*Sample Submission*

\* With the exception of the BH fraction where-  
=Received Volume (BV)--*Sample Submission*

## Analytical Calculations

### Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g/L}) - \text{Sample Result } (\mu\text{g/L}))}{\text{Spike Amount } (\mu\text{g/L})} \times 100$$

### Where-

Spike Result = Raw sample concentration (ppb)--*ICP-Data Sheet*

Sample Result = Raw sample concentration (ppb)--*ICP-Data Sheet*

Spike Amount--*ICP-MS Spike Table*

### Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g/L}) - \text{Sample Result } (\mu\text{g/L}))}{\text{Average } (\mu\text{g/L})} \times 100$$

### Where-

Sample Result =Raw sample concentration (ppb)--*ICP-Data Sheet*

Duplicate Results=Raw sample concentration (ppb)--*ICP-Data Sheet*

Average=  $\frac{(\text{Duplicate} + \text{Sample Results})}{2}$

elementOne AIR TESTING SAMPLE SUBMISSION FORM Lab ID 21230

[Empty Box]

Analysis Due Date 10.07.13  
QA/QC/Report Due Date 10.09.13

Client Clean Air IL  
Project No 12218

Date Rec 09.27.13  
Time Rec 1038

HNO <sub>3</sub> Lot 53094	HF Lot: 0000055115	HCl Lot: 4112010	Ref. Method:
Volume Marked $\checkmark$ / N	Volume Loss Y $\checkmark$ / ?		29

Sample Identification

1	U2-M29-R1	5	Field Blank
2	U2-M29-R2 U2-M29-R2 Duplicate	6	Reagent Blank
3	U2-M29-R3		
4	U2-M29-R3 Spike U2-M29-R4		

Analyses Requested Samples 1-6 Hg

Runs / FB	FH / Ace (FH)		HNO <sub>3</sub> (FH)		5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub> (BH)		HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)		
	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	
Lab ID	Fil ID	BV ml	BV ml	FV ml	BV ml	Used	FV ml	BV ml	FV ml	BV ml	FV ml	BV ml	FV ml
1			172	100	360			102	200	330	500	230	400
2.D			128		310			104		340		230	
3.S			150		385			104		330		230	
4			138		410			104		330		220	
5			100		310			104		370		220	

M-29 Reagent Blank

Lab ID	Fraction	BV, ml	FV, ml	Comments
6	C-7 FH Acetone Blank			
	C-8A FH 0.1N HNO <sub>3</sub>	300	100	used 100 ml
	C-8A A 0.1N HNO <sub>3</sub>	300	-	
	C-8B B DI H <sub>2</sub> O	100	100/33	used 33 ml
	C-9 BH 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	200	-	combined 200ml of w/ 100ml C8A -> 150 ml
	C-10 B 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	100	100/33	used 100 ml
	C-11 C 8N HCl DI H <sub>2</sub> O	225	100	
	C-12 FH Filter			

Lab Communications

LRB + Spike w/ 100 ml of std. A @ 25 ppm (FH)

M29: Received C1, C3, C4; C5A, C5B, C5C; RB C12, C8A, C8B, C9, C10, C11 - Archive Train Proof & R2 from c9.11.13--09.27.13 LLS

SS Page 1 of 1  
9/27/2013 3:43:40 PM  
SS by PLB  
Labeled By/Date PLB 9/30/13

FH Prep By/Date Jur 10.3.13 A Prep By/Date Jur 9.30.13  
BH Prep By/Date Jur 10.1.13 B Prep By/Date Jur 9.30.13  
BH/FH Prep By/Date Jur 10.3.13 C Prep By/Date Jur 10.1.13  
PM Prep By/Date - ID Verification By/Date Jur 9.30.13

elementOne

Method 29 Microwave Worksheet

Lab ID # 21230

Client:

21231

Date Digested: 10-5-13

Initials: JWR

Worksheet Prepared by: JWR

Auto Sample Loc.	Sample Lab ID	Sample Weight (g)	# of filters digested	Spike	Prep Volume (ml)	Weight In Micro / Weight Out Micro	Units
1	21230 L2B				100		
2	L2B+			100 µL Std A			
3	-1		1				
4	-2		↓				
5	-3						
6	-4						
7	-5						
8	-6		↓				
9	21231 L2B						
10	L2B+			100 µL Std A			
11	1		1				
12	2		↓				
13	3						
14	4		↓				
<p>L2B + 3,200 µL w/ 100 µL Std A (at 25 ppm)</p> <p>(21230 + 21231)</p>							

Element One, Inc. Form 104 - Revision 1.0

HF Lot # 000055115

HNO<sub>3</sub> Lot # 53079

2ml

6ml

elementOne

21230 CAE M29 Report Packet

Page 21 of 29

100113-1 (9-19) sent to 21200 Inst # 2  
 19-64 sent to 21200 100113-2 (Inst #3)

elementOne **MERCURY BATCH DIGESTION - RUN WORKSHEET** 100113-1  
 093013  
 Date Prepared/Digested: ~~09-10-13~~ 09-10-13 Prep By: JWL SIF File #: 100113-1  
 Block #1 Temperature: 92.27 Start Time: 5:55 Machine ID: #1  
 Block #2 Temperature: 94.78 Stop Time: 8:10 Batch Analyst: JWL  
 Block #3 Temperature: - Typed By: JWL Verified By: JWL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 1316504
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 093013-1 by: JWL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 093013-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 093013-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JWL

Initial Review By: JWL/LAL Date: 10-1-13 Time: 1:45  
 Final QC Review By: DJS Date: 10/2/13 Time: 11:57  
 Comments: 21200 - 3BH + @ .5 ml 21192 - 2B5FH + @ 1.4 ml

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol. ml	Spike ug
✓ 9	21200 - 10H				1	460	
10	- 2BH				.5	490	
11	- 25HD				↓	↓	
12	- 3SD				.1	440	
13	- 30H+				↓	↓	
14	- 43H				2	440	
15	- 53H				2	440	
16	- 53HD				↓	↓	
17	- 63H				2	↓	
18	- 63H+				↓	↓	
✓ 19	21230 - 1A				4	200	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
 Spike for Hg, Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
 Digestion chemicals to be added in order at the following rate per 40ml volumes.  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 53851 HNO<sub>3</sub> Lot # 53899 HCl Lot # 4112070  
 Persulfate Lot # 093013-3 KMnO<sub>4</sub> Lot # 093013-3 Hydrox Lot #: 093013-5  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

SIF File #: 100113-2

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol. ml	Spike µg
20	21230-2A				4	200	
21	-2AD						
22	-3A						
23	-3At						
24	-4A						
25	-5A						
26	-6A						
27	-1B					500	
28	-2B						
29	-2BD						
30	-3B						
31	-3Bf						
32	-4B						
33	-5B						
34	-6B						
✓35	21201-3				2	1	
36	-3f						
37	21192 LAB FH				4	100	
38	- LAB FH +				1.6		
39	- 4 FH				4		
40	- 5 FH						
41	- 5 FH D						
42	- 6 FH						
43	- 6 FH +						
44	- 10 FH						
45	11 FH						
46	- 11 FH D						
47	- 12 FH						
48	- 12 FH 1						
49	- 13 FH						
50	- 14 FH						
51	20159-3 Qc				1	10	
52	L/L LRC				1	1	
✓53	21203-2.4				5	250	
54	-2.4 top						

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 10.1.13 Prep By: JWL/LAL SIF File #: 100213-1  
 Block #1 Temperature: 96.67 Start Time: 5:55 Machine ID: #3  
 Block #2 Temperature: 93.33 Stop Time: 8:10 Batch Analyst: JWL  
 Block #3 Temperature: — Typed By: JWL Verified By: LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 1316504
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 093013-1 by: JWL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 013013-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 013013-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JWL

Initial Review By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Final QC Review By: (DPL) Date: 10/2/13 Time: 1232

Comments: \_\_\_\_\_

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
9	21203-25.1				10	500	
10	-26.1				↓	↓	
11	-26.1 tip				↓	↓	
12	-27.1				↓	↓	
13	-28.1				↓	↓	
14	-28.1 t				↓	↓	
15	21203-25.2				20	260	
16	26.2				↓	200	
17	26.2D				↓	↓	
18	-27.2				↓	300	
19	-28.2				↓	200	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
 Spike for Hg, Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
 Digestion chemicals to be added in order at the following rate per 40ml volumes.  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 53099 HCl Lot # 4112070  
 Persulfate Lot # 011513-3 KMnO<sub>4</sub> Lot # 071513-6 Hydrox Lot # 071513-5  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.



SIF File #: \_\_\_\_\_

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol. ml	Spike µg
20	21203-28.2F				20	200	
21	21203-28.3				10	700	
22	-26.3				↓	700	
23	-26.3F+D				↓	↓	
24	-27.3				↓	600	
25	-28.3				↓	600	
26	-28.3+				↓	↓	
27	21203-28.4				20	280	
28	-26.4				↓	↓	
29	-26.4trg				↓	↓	
30	-27.4				↓	↓	
31	-28.4				↓	↓	
32	-28.4+				↓	↓	
33	21203-28.5				20	600	
34	-26.5				↓	600	
35	-26.5trg				↓	↓	
36	-27.5				↓	600	
37	-28.5				↓	700	
38	-28.5+				↓	↓	
39	21200-38H				.5	440	
40	-38H+				↓	↓	
41	21122-LABFH				4	100	
42	-LABFH+				1.4	↓	
43	21230-1C				4	400	
44	-2C				↓	↓	
45	-2CD				↓	↓	
46	-3C				↓	↓	
47	-3C+				↓	↓	
48	-4C				↓	↓	
49	-5C				↓	↓	
50	-6C				↓	↓	
51	21230-18H					700	
52	-28H					870	
53	-28HD					↓	
54	-38H					825	

SIF File #: \_\_\_\_\_

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol, ml	Spike µg
55	21230 38H+				4	985	
56	- 48H					910	
57	- 58H					310	
58	- 68H				↓	200	
59	21232/53/34 02K				20	1	
60	02K +						
61	21232						
62	- Dup						
63	21233						
64	- 3PK						
65	21234				↓	↓	
66	20157-3 02K				11	10	
67	L/L 02K				1	1	
68							
69							
70							
71							
72							
73							
74							
75							
76							
77							
78							
79							
80							
81							
82							
83							
84							
85							
86							
87							
88							
89							

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 10-3-13 Prep By: Jwr SIF File #: 100413-1  
 Block #1 Temperature: --- Start Time: 5:55 Machine ID: #1  
 Block #2 Temperature: --- Stop Time: 8:10 Batch Analyst: Jwr  
 Block #3 Temperature: --- Typed By: Jwr Verified By: LAL

A/S	Curve & QC's	0.4ug/ml working std		BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0		40	40	Standard #1 (for working std) Lot #: 1516504
2	0.004 ug	0.01ml		40	40	Working Standard
3	0.04 ug	0.10ml		40	40	Lot #: 073013-1 by: Jwr
4	0.08 ug	0.20ml		40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml		40	40	Lot #: 073013-2
6	0.20ug	0.50ml		40	40	Standard #3 (QC #3): Lot #: 073013-3
7	QC #2= 0.08ug	0.2ml #2 std		40	40	
8	QC #3= 0.08ug	0.2ml #3 std		40	40	Curve prepared by: Jwr

Initial Review By: Jwr/LAL Date: 10-4-13 Time: 11:45  
 Final QC Review By: LS Date: 10-4-13 Time: 1340  
 Comments: 20223 21223-1 DCA 8ml 21233 (Totals) 268+0.2ml  
(21223) Southern States Typed as 20223 on Run

A/S	LAB #	Client	WUFV	Ali Used	ml used	Sample Vol. ml	Spike µg
9	21200-LRBFH				4	100	
10	-LRBFH+				1.6	↓	
11	21244				10	1	
12	-SPK				↓	↓	
13	21200-LRH				1	440	
14	-LRH+				↓	↓	
15	21230-LRBFH				4	100	
16	-LRBFH+				1.6	↓	
17	-IFH				4	↓	
18	-2FH				↓	↓	
19	-2FHD				↓	↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg,** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 53049 HCl Lot # 4112070  
 Persulfate Lot # 091513-3 KMnO<sub>4</sub> Lot # 011513-6 Hydrox Lot # 011513-5  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: 100413-1

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol, ml	Spike µg
✓ 20	21230-3FH				4	100	
21	-3FH+				↓	↓	
22	-4FH				↓	↓	
23	-5FH				↓	↓	
24	-6FH				↓	↓	
✓ 25	21231-LRBH+				4	100	
26	-LRBH+				1.6	↓	
27	-1FH				4	↓	
28	-2FH				↓	↓	
29	-2FHD				↓	↓	
30	-3FH				↓	↓	
31	-3FH+				↓	↓	
32	-4FH				↓	↓	
33	21231-1A				4	200	
34	-2A				↓	↓	
35	-2AD				↓	↓	
36	-3A				↓	↓	
37	-3A+				↓	↓	
38	-4A				↓	↓	
39	21231-1BH				4	970	
40	-2BH				↓	910	
41	-2BHD				↓	↓	
42	-3BH				↓	760	
43	-3BH+				↓	↓	
44	-4BH				↓	200	
45	21231-1B				4	500	
46	-2B				↓	↓	
47	-2BD				↓	↓	
48	-3B				↓	↓	
49	-3B+				↓	↓	
50	-4B				↓	↓	
51	20159-30C				.1	10	
52	L/LGC				↓	↓	
✓ 53	21223-1		10.015/100	8	.8015	↓	
54	-1D		↓	↓	↓	↓	



PerkinElmer FIMS-100 CVAA Mercury Analyzer

Sample_ID	Date	Time	Mean_Sig	Mean_Rd	Mean_Rt	Units	Alq.	Vol.	Sig 1	Reading-1	Result-1	Sig 2	Reading-2	Result-2
Calib Blank	10/4/2013	9:20:52	0.0001124			µg	4	100	0.0001124					
STD1=.004ug	10/4/2013	9:22:06	0.0010786			µg	4	100	0.0010786					
STD2=.04ug	10/4/2013	9:23:22	0.0108475			µg	4	100	0.0108475					
STD3=.08ug	10/4/2013	9:24:38	0.02164			µg	4	100	0.02164					
STD4=.16ug	10/4/2013	9:25:55	0.0429366			µg	4	100	0.0429366					
STD5=.2ug	10/4/2013	9:27:13	0.0537432			µg	4	100	0.0537432					
Reagent Blank	10/4/2013	9:28:59	3.172E-05	0.000118	0.000118	µg	4	100	4.375E-05	0.0001628	0.0001628	1.969E-05	7.328E-05	7.328E-05
0.004ug = DL	10/4/2013	9:30:12	0.0010636	0.0039567	0.0039567	µg	4	100	0.0010636	0.0039567	0.0039567			
0.080ug = STD.2	10/4/2013	9:31:27	0.0213559	0.0794487	0.0794487	µg	4	100	0.0213559	0.0794487	0.0794487			
REAGENT BLANK	10/4/2013	9:32:43	0.0002499	0.0009298	0.0009298	µg	4	100	0.0002499	0.0009298	0.0009298			
0.080ug = STD.2	10/4/2013	9:33:59	0.0212713	0.0791342	0.0791342	µg	4	100	0.0212713	0.0791342	0.0791342			
REAGENT BLANK	10/4/2013	9:35:15	0.0002386	0.0008878	0.0008878	µg	4	100	0.0002386	0.0008878	0.0008878			
21230-LRB FH	10/4/2013	9:47:39	3.523E-05	0.0001311	0.0032773	µg	4	100	2.688E-05	0.0001	0.0025008	4.358E-05	0.0001622	0.0040538
21230-LRB FH SPK	10/4/2013	9:49:29	0.0170829	0.0635522	3.9720117	µg	1.6	100	0.0171776	0.0639046	3.9940396	0.0169881	0.0631997	3.9499838
21230-1 FH	10/4/2013	9:51:15	0.001445	0.0053757	0.1343926	µg	4	100	0.0014654	0.0054518	0.1362941	0.0014245	0.0052996	0.132491
21230-2 FH	10/4/2013	9:52:58	0.0013352	0.0049673	0.1241821	µg	4	100	0.001319	0.0049072	0.1226789	0.0013514	0.0050274	0.1256853
0.004ug = DL	10/4/2013	9:54:11	0.0010737	0.0039943	0.0039943	µg	4	100	0.0010737	0.0039943	0.0039943			
0.080ug = STD.2	10/4/2013	9:55:27	0.0205922	0.0766077	0.0766077	µg	4	100	0.0205922	0.0766077	0.0766077			
REAGENT BLANK	10/4/2013	9:56:43	0.0002312	0.0008601	0.0008601	µg	4	100	0.0002312	0.0008601	0.0008601			
21230-2 FH DUP	10/4/2013	9:58:27	0.0015139	0.0056319	0.1407967	µg	4	100	0.0015258	0.0056761	0.1419035	0.0015019	0.0055876	0.1396898
21230-3 FH	10/4/2013	10:00:11	0.0012363	0.0045995	0.1149866	µg	4	100	0.0012585	0.0046818	0.1170444	0.0012142	0.0045172	0.1129289
21230-3FH SPK	10/4/2013	10:01:55	0.0229057	0.0852143	2.1303583	µg	4	100	0.0230451	0.0857329	2.1433215	0.0227663	0.0846958	2.1173951
21230-4FH	10/4/2013	10:03:41	0.0008588	0.0031948	0.0798697	µg	4	100	0.0008646	0.0032163	0.0804081	0.000853	0.0031733	0.0793313
21230-5FH	10/4/2013	10:05:27	1.699E-05	6.323E-05	0.0015808	µg	4	100	1.215E-05	4.523E-05	0.0011308	2.183E-05	8.123E-05	0.0020309
21230-6FH	10/4/2013	10:07:13	5.324E-05	0.0001981	0.0049519	µg	4	100	4.895E-05	0.0001821	0.004553	5.753E-05	0.000214	0.0053508
0.004ug = DL	10/4/2013	10:15:36	0.0010451	0.0038879	0.0038879	µg	4	100	0.0010451	0.0038879	0.0038879			
0.080ug = STD.2	10/4/2013	10:16:52	0.0206102	0.0766746	0.0766746	µg	4	100	0.0206102	0.0766746	0.0766746			
REAGENT BLANK	10/4/2013	10:18:08	0.0002698	0.0010038	0.0010038	µg	4	100	0.0002698	0.0010038	0.0010038			

**This Page Intentionally Left Blank**

**PLANT DATA**

H

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: SOB

Date: 10/23





**This Page Intentionally Left Blank**

**Wheelabrator  
NORTH BROWARD  
Emission Test Log**

Date: 09/25/13  
Start Time: 10:06  
End Time: 12:27

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	487.40	279.30	47.28	35.46	11.82	23.65	263.56	6.41	-10.65
Unit 2 29 run 1	493.63	280.33	47.22	35.89	11.32	23.64	258.57	6.60	1.61
Unit 3	86.83	88.69	0.07	0.01	0.06	90.00	92.00	0.77	1.41

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

Unit	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	173.27	875.96	829.06	85.16	-0.10	235.99	1072.60	4.49	175.34
Unit 2	190.66	878.20	834.50	89.27	-0.10	246.62	1223.94	6.97	180.48
Unit 3	0.00	4.45	496.87	0.43	-0.02	92.27	86.82	0.00	0.00

U1 lime (#/hr) 639.28

U2 lime (#/hr) 612.40

U3 lime (#/hr) 3.21

Specific Gravity 1.086

Round Down 1.080 0.833

Round Up 1.090 0.941

## Wheelabrator NORTH BROWARD Emission Test Log

Date: 09/25/13  
Start Time: 12:45  
End Time: 15:14

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
----------------	-----------------	-----------------	----------------	------------	-----------	-------------	-------	----------------

Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	483.00	280.11	43.95	33.03	10.92	24.70	264.04	6.50	-10.70
Unit 2 29 run 2	500.80	283.40	49.44	38.47	10.97	21.97	259.92	6.72	1.61
Unit 3	86.58	88.26	0.08	0.01	0.07	90.00	91.45	0.75	1.42

H 4

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
---------------	------------------	----------------	--------------	---------------	----------------	-------------	----------------	------------

Unit	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	173.01	875.70	829.12	80.68	-0.10	235.87	1069.83	4.47	175.00
Unit 2	189.31	877.62	827.14	91.29	-0.10	246.44	1196.65	10.11	179.78
Unit 3	0.00	4.47	496.87	0.43	-0.01	91.35	86.58	0.00	0.00

U1 lime (#/hr) 603.14

U2 lime (#/hr) 605.69

U3 lime (#/hr) 3.95

Specific Gravity 1.088

Round Down 1.080 0.833

Round Up 1.090 0.941

**Wheelabrator  
NORTH BROWARD  
Emission Test Log**

Date: 09/26/13  
Start Time: 7:41  
End Time: 9:58

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	486.47	293.16	44.12	33.02	11.10	25.21	275.65	6.27	-10.60
Unit 2 29 run 3	499.87	292.05	45.28	34.09	11.19	24.57	256.75	6.74	1.61
Unit 3	88.60	89.66	0.20	0.01	0.19	90.00	93.21	0.79	1.42

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	172.18	875.81	832.17	87.52	-0.10	235.85	1070.98	5.55	173.87
Unit 2	192.51	878.53	826.55	86.90	-0.09	246.54	1200.96	7.36	183.05
Unit 3	0.00	4.45	496.87	0.43	-0.01	90.22	88.32	0.00	0.00

U1 lime (#/hr) 603.56

U2 lime (#/hr) 608.42

U3 lime (#/hr) 10.42

Specific Gravity 1.087

Round Down 1.080 0.833

Round Up 1.090 0.941

## Wheelabrator NORTH BROWARD Emission Test Log

Date: 09/26/13  
Start Time: 10:18  
End Time: 12:40

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
----------------	-----------------	-----------------	----------------	------------	-----------	-------------	-------	----------------

Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	483.93	292.07	41.24	29.92	11.33	27.68	273.73	6.37	-10.35
Unit 2 29 run 4	507.42	292.19	48.13	36.64	11.49	23.69	270.91	6.73	1.61
Unit 3	88.52	90.02	0.10	0.04	0.06	90.00	93.72	0.79	1.41

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
---------------	------------------	----------------	--------------	---------------	----------------	-------------	----------------	------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	173.44	876.36	831.67	82.27	-0.10	236.72	1077.60	5.97	174.94
Unit 2	194.47	879.31	830.78	89.14	-0.10	247.28	1229.20	11.39	184.05
Unit 3	0.00	4.46	496.87	0.45	-0.03	90.09	88.18	0.00	0.00

U1 lime (#/hr) 602.15

U2 lime (#/hr) 610.91

U3 lime (#/hr) 3.06

Specific Gravity 1.085

Round Down 1.080 0.833

Round Up 1.090 0.941