



**Progress Energy**

July 13, 2006

To: Dave Meyer

Re: Aggreko Cooling Tower Drift Eliminator Certification

Aggreko Cooling Tower Services has completed installation of the modular cooling towers at the Crystal River Energy Complex. The drift eliminators installed are Brentwood Industries model CDX-80 with a guaranteed drift rate not to exceed 0.0015 percent of water flow. Please see the attached letter from Gary Rushing.

Sincerely,

Richard Reiland  
Lead Engineer  
Progress Energy