

7/10/06

Richard Reiland  
Progress Energy, Inc.  
8202 W. Venable Street  
CR36E  
Crystal River, FL 34429

Re: Certification of Drift Eliminators

Mr. Reiland,

This is to certify:

Drift eliminators (Brentwood Industries model CDX-80) installed and used in the Aggreko rental modular cooling towers, were constructed and installed to meet a 0.0015% drift rate in accordance with the manufacturer's specifications.

If you require additional information feel free to contact me.

Sincerely,

Gary Rushing



Technical Sales

Aggreko Cooling Tower Services



Member

[WWW.COOLINGTOWER.COM](http://WWW.COOLINGTOWER.COM)

Aggreko Cooling Tower Service  
PO Box 627  
Chickasha, OK 73023  
Tel 405.224.5301  
Fax 405.224.5332