

12.17.7

TWIN TOWERS OFFICE BUILDING
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32301



Bob Graham
GOVERNOR

Victoria Tschinkel
Acting Secretary

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

February 14, 1979

Mrs. Liz Cloud
Department of State
Florida Administrative Weekly
The Capitol
Tallahassee, Florida 32304

Dear Mrs. Cloud:

Subject: Best Available Control Technology (BACT)
Determination for Crystal River Units 1 and 2
Fly-Ash Handling System, FPC, Citrus County

Please publish the attached notice for the BACT
Determination referenced above in the February 16, 1979
issue of the Florida Administrative Weekly.

Should you have questions, please call me at 8-4807.

Sincerely,

A handwritten signature in cursive script that reads "Geneva M. Hartsfield".

Geneva M. Hartsfield
Administrative Assistant

GMH:es

Attachment

RECEIVED
FEB 14 10 04 AM 1979
DEPARTMENT OF STATE
TALLAHASSEE, FLORIDA

THE DEPARTMENT OF ENVIRONMENTAL REGULATION has determined Best Available Control Technology (BACT) for Florida Power Corporation Units 1 and 2 Fly-Ash Handling System, Crystal River Plant, Citrus County. The emission limitation set by this BACT determination are:

Particulate

lbs/hr.

Unit 1 conveying line	3.52 Attainable with 99.9±% efficient bag dust collector
Transfer silo vent	0.03 Attainable with 99.9±% efficient bag dust collector
Storage silo vent	0.59 Attainable with 99.9±% efficient bag dust collector

Opacity: Less than 5%

Test Method: EPA's methods 1-5 as described in the August 17, 1977 Federal Register.

Details of the Determination may be obtained by contacting Victoria Martinez, Department of Environmental Regulation, 2600 Blair Stone Road, Twin Towers Office Building, Tallahassee, Florida 32301

RECEIVED
FEB 14 10 04 AM 1979
DEPARTMENT OF STATE
TALLAHASSEE, FLORIDA