

07/18/06

**PROGRESS ENERGY  
SUB-BITUMINOUS BLEND TRIAL TEST REPORT  
CRYSTAL RIVER UNIT 5**

**RECEIVED**

JUL 21 2006

*Submitted to:*

**BUREAU OF AIR REGULATION**

*Mr. Jeff Koerner  
FDEP  
North Permitting Section  
Division of Air Resource Management  
2600 Blair Stone Road MS 5500*

*Submitted by:*

*Progress Energy Corporation  
Environmental Services Section  
100 Central Avenue CX1B  
St Petersburg, Fl. 33701*

Distribution:

2 Copies Department of Environmental Protection  
2 Copies Progress Energy Florida  
1 Copy Golder Associates Inc.

July 2006

## Table of Contents

1. Actual schedule and overall description of the trial burn;
2. Summary of sub-bituminous blends evaluated (amounts delivered; blend ratio; and proximate/ultimate analyses);
3. Discussion of operational issues of sub-bituminous blends including: coal unloading, handling, storage and firing; fugitive dust; soot blowing; ESP performance and adjustments; and ash handling and storage;
4. Comparison of baseline operations versus operation with the sub-bituminous coal blend;
5. Evaluation of current equipment compatibility with the sub-bituminous coal blend;
6. Summary of continuous emissions monitoring data;
7. Summary of boiler operating data;
8. Summary of emissions test results, actual test schedule, and procedures used;
9. Comparison of baseline emissions with emissions from firing the sub-bituminous coal blend (short-term and long-term); and,
10. Discussion of emissions changes as described in Appendix C of 40 CFR 60.

## Appendix

1. Proximate and ultimate analyses
2. Baseline (6/5/06) and Blend (5/22/06) - Particulate and CO Test Report
3. Baseline (4/19/06) - CO Test Report
4. Determination of Emission Rate Change – Data Sheets

1. Actual schedule and overall description of the trial burn

Actual Schedule

- 04/19/06 – Baseline CO testing on Unit 5 by CEMS Solutions
- 05/21/06 – Start Sub-bituminous blend burn at Crystal River Unit 5
- 05/22/06 – Sub-bituminous blend burn Particulate, CO, Resistivity, ESP Performance and Coal testing on Unit 5
- 05/23/06 - Sub-bituminous blend burn Ash Resistivity
- 05/23/06 – Completion of Sub-bituminous blend test burn – Unit 5
- 06/05/06 – Baseline CO, Resistivity and Coal testing on unit 5 by Koogler & Associates
- 06/06/06 – Baseline Ash Resistivity
- 07/08/06 – Baseline ESP Performance

Overall description of the trial burn

In an effort to continue expanding fuel diversity and ultimately enhancing market options through supplier flexibility at the Crystal River facility, a test burn of a blended bituminous product and a sub-bituminous product was conducted on Crystal River Unit 5 (referenced as CR5). This test burn was conducted following approval of a modified air permit by the Florida Department of Environmental Protection (FDEP) allowing testing of a sub-bituminous blended product.

The test consisted of one barge (15,900 tons) of the preblended product made up of 18% sub-bituminous coal & 82% bituminous coal. The barge arrived on site Saturday 5/20/06 and was burned Sunday 5/21/06 – Tuesday 5/23/06 on Unit 5. The sub-bituminous blend was coaled up directly to the unit from the barge without going to the ground allowing for better control and monitoring of the blended product. CR4 was coaled-up separately from the stockpile to prevent any opportunity for co-mingling of the sub-bituminous blend with the standard coal in CR4.

07/18/06

---

Blending of the coal product was conducted at the International Marine Terminal (IMT) in New Orleans prior to delivery.

There were no substantial issues raised during this trial. Full load was achieved and LOI (loss on ignition) was as good as or better than the base line coal performance measurements. Major emissions constituents, such as NOx, SO2, and opacity, were equivalent to or better than the same constituents utilizing the base line coal.

In addition to the major emissions constituents discussed above, detailed stack testing of CO, PM and ash resistivity testing were required to meet the Florida Department of Environmental Protection (FDEP) requirements. Particulate Matter was basically unaffected by the PRB blend as compared to baseline. CO, which is not currently regulated, was reportedly low during the baseline tests. CO readings did register while burning the PRB blend.

2. Summary of sub-bituminous blends evaluated (amounts delivered; blend ratio; and proximate/ultimate analyses)

- Amount Delivered - 15,900 Tons in one single continuous burn in Unit 5 from 5/21/6 to 5/23/6
- Blend Ratio - 18 % Sub-bituminous and 82 % Bituminous
- Proximate/ultimate analysis (See Appendix)

3. Discussion of operational issues of the sub-bituminous coal blend including: coal unloading, handling, storage and firing; fugitive dust; soot blowing; ESP performance and adjustments; and ash handling and storage;

**Discussion of Operational Issues:**

- **Coal Unloading:** The blend was observed unloading from barge and along conveyors. The large percentage of bituminous coal (82%) did an excellent job of controlling dust and in fact, little if any dusting at all was noticed.
- **Handling:** No problems were encountered with coal handling. Performed similar to current Crystal River coal.
- **Storage and firing:** The sub-bituminous blend was taken directly from the barge to Unit 5 and not put to the ground, therefore unable to evaluate storage on-site. Firing was adequate to achieve full load in the unit.
- **Fugitive Dust:** Coal blend was not dusty and fugitive dusting was not an issue.
- **Sootblowing:** Routine sootblowing operations were continued during trial. A small ash accumulation was observed in an area where sootblowers were non-operational. Accumulation was removed with air lance and did not reform during trial. Therefore, the accumulation may have been formed prior to the sub-bituminous blend.
- **ESP Performance and Adjustments:** No problems with ESP performance or opacity during the sub-bituminous blend burn.
- **Ash handling and storage:** Ash quality and LOI were well within acceptable limits to be able to utilize ash product. In fact, LOI was better than normal at 3.4 - 4%.

4. Comparison of baseline operations versus operation with the sub-bituminous coal blend

**Baseline Compared to PRB Blend burn:**

<b>Crystal River 5 PRB Blend Trial &amp; Baseline</b>					
<b>Test Type</b>	<b>Stack Test - Baseline</b>		<b>PRB Blend Test</b>		
	<b>Start Time</b>	06/05/2006 10:00:00	<b>End Time</b>	05/22/2006 07:30:00	
	<b>Ran By</b>	06/05/2006 14:00:00	<b>Ran By</b>	05/22/2006 19:30:00	
	<b>Measured Test Data (Average)</b>				
<i>Gross Load</i>	<i>MW</i>	711.29	711.31	0.02	0.00%
<i>Auxiliary Load</i>	<i>MW</i>	32.01	32.10	0.10	0.30%
<i>Net Load</i>	<i>MW</i>	679.29	679.21	-0.08	-0.01%
<i>Main Steam Temp</i>	<i>DEGF</i>	1003.33	1003.31	-0.02	0.00%
<i>Main Steam Press</i>	<i>PSI</i>	2392.81	2404.18	11.37	0.48%
<i>Hot Reheat Temp</i>	<i>DEGF</i>	998.77	998.20	-0.56	-0.06%
<i>Main Steam Flow</i>	<i>KPPH</i>	4899.27	4882.48	-16.79	-0.34%
<i>U5 COAL FDRS TOTAL COAL FLOW</i>	<i>KLB/HR</i>	534.48	540.02	5.55	1.04%
<i>Heat Input Rate</i>	<i>MMBTU/HR</i>	6257.43	6197.09	-60.34	-0.96%
<b>CEMS data &amp; LOI</b>					
<i>Opacity</i>	<i>%</i>	5.40	5.39	-0.02	-0.33%
<i>NOx</i>	<i>LB/MBTU</i>	0.50	0.44	-0.05	-10.69%
<i>SO2</i>	<i>LB/MBTU</i>	1.06	1.05	-0.02	-1.69%
<i>LOI (from PMI) - below 6% is good</i>	<i>%</i>	5.30	3.40	-1.90	-35.85%

5. Evaluation of current equipment compatibility with the sub-bituminous coal blend

**Evaluation of Current Equipment Compatibility with the Sub-bituminous Blend:**

There were no shortcomings in existing equipment during the sub-bituminous blend use. U5 was able to make full load without issues. More long term use of the product, or a similar product, would likely require some expenditures to complete repairs to existing equipment and provide additional safety measures needed for long-term use of a higher volatility product.

## 6. Summary of continuous emissions monitoring data

Crystal River 5 PRB Blend Trial & Baseline					
Test Type		Stack Test - Baseline	PRB Blend Test		
Start Time		06/05/2006 10:00:00	05/22/2006 07:30:00		
End Time		06/05/2006 14:00:00	05/22/2006 19:30:00		
Ran By					
Measured Test Data (Average)					
Gross Load	MW	711.29	711.31	0.02	0.00%
Auxiliary Load	MW	32.01	32.10	0.10	0.30%
Net Load	MW	679.29	679.21	-0.08	-0.01%
Main Steam Temp	DEGF	1003.33	1003.31	-0.02	0.00%
Main Steam Press	PSI	2392.81	2404.18	11.37	0.48%
Hot Reheat Temp	DEGF	998.77	998.20	-0.56	-0.06%
Main Steam Flow	KPPH	4899.27	4882.48	-16.79	-0.34%
U5 COAL FDRS TOTAL COAL FLOW	KLB/HR	534.48	540.02	5.55	1.04%
Heat Input Rate	MMBTU/HR	6257.43	6197.09	-60.34	-0.96%
CEMS data & LOI					
Opacity	%	5.40	5.39	-0.02	-0.33%
NOx	LB/MBTU	0.50	0.44	-0.05	-10.69%
SO2	LB/MBTU	1.06	1.05	-0.02	-1.69%
LOI (from PMI) - below 6% is good	%	5.30	3.40	-1.90	-35.85%

The continuous emission monitors recorded Opacity, NOx, and SO2 emissions. Referencing the above table:

- Opacity – During the baseline testing the opacity readings averaged 5.40. The sub-bituminous blend test value averaged 5.39. The percent change is an improvement of 0.33 percent with the blended coal.
- NOx - During the baseline testing the NOx readings averaged 0.50. The sub-bituminous blend test value averaged 0.44. The percent change is an improvement of 10.7 percent with the blended coal.
- SO2 - During the baseline testing the SO2 readings averaged 1.06. The sub-bituminous blend test value averaged 1.05. The percent change is an improvement of 1.7 percent with the blended coal.

## 7. Summary of boiler operating data

### Furnace Exit Gas Temperature (FEGT)

FEGT's were taken before and during the sub-bituminous blend trial at full load on 11<sup>th</sup> floor of CR5. The table below summarizes the main results of FEGT tests. Note that the Ash Fusion Softening Temperture (AFT) of the sub-bituminous coal blend used in the trial was 2170-2200 degrees F (from lab analyses) and ash fusion cannot be blended away. (Also, red O<sub>2</sub>% indicates a reducing atmosphere present.)

#### CR Unit 5

##### Benchmark HVT Data

4/19/2006

West Face of Boiler

11th Floor, Elev 224

Note: CO at 1000 ppm indicates offscale high

Insertion Length, ft	North Port, Near Wall			Center Port, Middle			South Port, Near Wall		
	O2, %	CO, ppm	Temp, F	O2, %	CO, ppm	Temp, F	O2, %	CO, ppm	Temp, F
2	1.55	608	1678	1.0	1000+	2416	4.40	530	1874
4	2.00	610	1742				3.20	410	2018
6	1.85	634	1858				1.20	20	2109
8	1.30	702	1909				0.00	1000	2175
10	1.00	739	1945				0.00	1000	2190
12	1.10	720	2119				0.00	1000	2287
14							0.00	1000	
16							0.00	1000	2300

#### CR Unit 5

##### PRB Blend HVT Data

5/23/2006

West Face of Boiler

11th Floor, Elev 224

Insertion Length, ft	North Port, Near Wall			Center Port, Middle			South Port, Near Wall		
	O2, %	CO, ppm	Temp, F	O2, %	CO, ppm	Temp, F	O2, %	CO, ppm	Temp, F
2	1.90	392	1660	2.1	527	2245	0.00	1000	1960
4	1.90	400	1775	1.7	565	2240	0.00	1000	2120
6	1.20	340	1855	1.8	575	2320	0.00	1000	2195
8	0.90	425	1960				0.00	1000	2245
10	0.45	500	2065				0.10	1000	2295
12	0.40	770	2145						
14	1.00	865	2165						
16									

Comparing the above tables, the temperatures appear to be about the same between the two tests, with the exception of the center readings, which dropped about 200 degrees F from the baseline to the sub-bituminous blend. This could be due to the high moisture content of PRB (28% moisture). It also appears that CO levels were in the same ballpark, if not slightly lower, with the sub-bituminous blend.

8. Summary of emissions test results, actual test schedule, and procedures used  
**Actual Schedule**

- 04/19/06 – Baseline CO testing on Unit \_ by CEMS Solutions
- 05/22/06 – Sub-bituminous blend burn - Particulate, CO, Ash Resistivity, ESP Performance and Coal testing on Unit 5
- 05/23/06 – Sub-bituminous blend burn - Ash Resistivity
- 06/05/06 – Baseline CO, Ash Resistivity and Coal testing on unit 5 by Koogler & Associates
- 06/06/06 – Baseline Ash Resistivity
- 07/08/06 – Baseline ESP Performance

**Summary of emissions test results**

**CO & PM**

CO & PM measurements were taken by Koogler & Associates both during the sub-bituminous blend and later on typical plant bituminous coal (baseline). Koogler performed (6) 1-hour tests on the sub-bituminous blend day (5/22) and (3) 1-hour tests on the baseline coal (6/5). CEMS Solutions performed (9) 20 minute CO tests on the baseline coal (4/19). Results are indicated below:

CR5 Stack Testing Results Summary (lb/mmbtu)					
Test Run #	Baseline Tests			Blend Tests	
	4/19	6/5	6/5	5/22	5/22
	CO	CO	PM	CO	PM
1	0.007	<.001*	0.003	0.031	0.004
2	0.005	<.001	0.004	0.058	0.004
3	0.006	<.001	0.004	0.033	0.004
4	0.006			0.03	0.003
5	0.006			0.024	0.003
6	0.004			0.019	0.002
7	0.004				
8	0.004				
9	0.006				
Avg	0.006	<.001	0.004	0.033	0.003
Min	0.004		0.003	0.019	0.002
Max	0.007		0.004	0.058	0.004

\* non-detectable (< 1ppm)

Particulate Matter was basically unaffected by the sub-bituminous blend as compared to baseline. CO, which is not currently regulated, was reportedly low during the baseline tests. CO readings did register while burning the sub-bituminous blend. However, in comparing the CO levels of the two coals in the HVT tests (Section 7), the two coals seem very similar in CO levels. This leads us to question how the CO levels could be similar within the boiler yet differ at the stack.

## ESP Voltages/Performance

We monitored ESP secondary voltage and secondary current and the total ESP secondary power input. The statistical results are summarized below:


ESP T/R Set	Baseline Run - 7/8/06 (710 MW)			PRB Blend - 5/22/06 (710 MW)		
	Baseline Secondary Current (mA)	Baseline Secondary Voltage (kV)	Baseline Secondary Power Input (KW)	PRB Blend - Secondary Current (mA)	PRB Blend Secondary Voltage (kV)	PRB Blend Secondary Power Input (KW)
<i>Descriptive Statistics</i>						
Mean	412.66	50.05	19.73	318.57	50.124	15.2
Median	387.00	50.00	18.90	272.0	50.0	11.5
Mode	474.00	50.00	9.90	162.0	50.0	8.8
Standard Deviation	181.74	2.33	8.98	177.32	1.85	8.73
Range	753	14.00	36.90	653	11	34
Minimum	94.0	41.1	3.5	86.0	44.3	4.0
Maximum	847.0	55.1	40.4	739.0	55.0	37.9
Count	77	77	77	79	79	79

## Ash Resistivity

Fly ash samples were pulled from ESP hoppers on CR5 at full load. Two samples were taken during the sub-bituminous blend burn and two more taken during normal coal burning operations. Samples were sent to APCO Services laboratories in Hopkinsville, KY. All (4) samples were tested simultaneously in a declining temperature batch resistivity test at 4.7% moisture to simulate conditions at the ESP inlet.

5/22/06	<b>PRB blend</b>	710
5/23/06	<b>PRB blend</b>	760
6/5/06	Typical CAPP	710
6/6/06	Typical CAPP	760

*Fig. 1 is APCO's resistivity curve results. Typical ESP inlet temperature is 300 degrees F.*



Upon evaluating APCO Services' Fig. 1, it appears that the sub-bituminous blend had, for the most part, slightly higher resistivity, yet still in the manageable range of the Electrostatic Precipitator. If we consider that the normal full load ESP inlet temperature is 300°F, the 5/22/06 sub-bituminous blend resistivity was actually lower than the 6/5/06 typical bituminous coal. Conclusion: the sub-bituminous blend ash resistivity is within normal parameters.

## Test Procedures

Test Parameter	Test Method
PM	EPA Method 17
Stack Gas Velocity	EPA Method 2
Stack Moisture	EPA Method 4
Dry Molecular Weight	EPA Method 3
Carbon Monoxide	EPA Method 10
Opacity	EPA Method 9
Ash Resistivity Measurements	IEEE Standard 58-1984
Proximate Analysis	ASTM D-3172
Ultimate Analysis	ASTM D-3176
Heating Value	ASTM D-5865
Sulfur Percent	ASTM D-4239

9. Comparison of baseline emissions with emissions from firing the sub-bituminous coal blend (short-term and long-term)

NOx – Baseline testing of NOx emissions was conducted on June 05, 2006. The blend testing was conducted on May 22, 2006. The results of the testing are as follows:

NOx Test Results

Run Number	Baseline Rate (lb/mmbtu)	Blend Rate (lb/mmbtu)
1	0.501	.443
2	0.504	.436
3	0.502	.455
4	0.513	.455
5	0.512	.447
6		.439
7		.446
8		.453
9		.456
10		.457
11		.456
12		.452
13		.485
Average	.506	.452

**SO<sub>2</sub>** - Baseline testing of SO<sub>2</sub> emissions was conducted on June 05, 2006. The blend testing was conducted on May 22, 2006. The results of the testing are as follows:

Run Number	Baseline Rate (lb/mmbtu)	Blend Rate (lb/mmbtu)
1	1.071	1.056
2	1.077	1.061
3	1.077	1.064
4	1.082	1.056
5	1.072	1.063
6		1.059
7		1.063
8		1.068
9		1.07
10		1.059
11		1.037
12		1.021
13		1.016
Average	1.076	1.053

**PM** - Baseline testing of PM emissions was conducted on June 05, 2006. The blend testing was conducted on May 22, 2006. The results of the testing are as follows:

Run Number	Baseline Rate (lb/mmbtu)	Blend Rate (lb/mmbtu)
1	.003	.004
2	.004	.004
3	.004	.004
4		.003
5		.003
6		.002
Average	.004	.003

07/18/06

CO - Baseline testing of CO emissions was conducted on April 19, 2006 and June 05, 2006. The blend testing was conducted on May 22, 2006. The results of the testing are as follows:

	Baseline Rate (lb/mmbtu)	Baseline Rate (lb/mmbtu)	Blend Rate (lb/mmbtu)
Run Number	4/19/2006	6/5/2006	5/22/2006
1	.007	<.001	.031
2	.005	<.001	.058
3	.006	<.001	.033
4	.006		.03
5	.006		.024
6	.004		.019
7	.004		
8	.004		
9	.006		
Average	.006	<.001	.033

10. Discussion of emissions changes as described in Appendix C of 40 CFR 60.

The measured emissions outlined in section 9 were evaluated using the statistical methodology found in 40 CFR 60 Appendix C. The methodology used is the student's t test. Please see the results in Appendix 4.

NOx, SOx, and PM all showed that the emission rate change was insignificant. The only pollutant measured that showed a significant rate increase was CO. The CO significant rate increase determination, however, is based on a relatively small number of tests – with only a single set of tests with the sub-bituminous blend.

## Appendix

Proximate and ultimate analyses

**SGS**

May 25, 2006

Progress Energy Corporation  
 PEB 10  
 P. O. Box 1551  
 Raleigh NC 27602  
 Attn: Debra Haynes

Kind of sample COAL  
 reported to us

Sample taken at INTERNATIONAL MARINE TERMINALS

Sample taken by SGS/MINERALS SERVICES DIVISION

Date sampled May 17-18, 2006

Date received May 18, 2006

PRB BLEND

IMT ANALYSIS

Sample identification by  
 CLIENT

CALCULATED COMPOSITE ON A WEIGHTED BASIS  
 GULF BARGE: MICKIE BIRDSALL  
 NOT TONS : 15567.98  
 COMMODITY : D/PRB BLEND  
 SAMPLING : MECHANICAL

Analysis Report No. 89-6312-60C


PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	10.16	xxxxxx
% Ash	10.96	12.20
% Volatile	29.74	33.10
% Fixed Carbon	49.14	54.70
	100.00	100.00
Btu/lb	11771	13102
% Sulfur	0.66	0.73
MAF Btu		14923

ULTIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	10.16	xxxxxx
% Carbon	66.45	73.96
% Hydrogen	3.99	4.44
% Nitrogen	1.12	1.25
% Sulfur	0.66	0.73
% Ash	10.96	12.20
% Oxygen (diff)	6.66	7.42
	100.00	100.00

Respectfully submitted,  
 SGS NORTH AMERICA INC.

  
 St. Rose Laboratory

SGS North America Inc. | Minerals Services Division  
 107 Pintail Street, St. Rose, LA 70087 | (504) 467-5522 | (504) 464-7220 | www.us.sgs.com/minerals

Member of the SGS Group

PRB blend son 'es

S.L. Sampler # 4				MAY 2006				As Bunker Samples					
Mech	#	I.D.	#/1000	Volatile	Fixed			Lbs SO2	MAF				
Date	Lab #	Hand Samp	Shift	Tons	Tonnage	Moisture	Ash	Matter Carbon Sulfur	BTU/LB	/MBTU	BTU		

Sun 05/21/06

UNIT 5	64176	M	42	0600-1600	17.6	2,385	9.33	12.13	30.53	48.01	0.64	11718	1.09	14920
UNIT#5	64178	M	54	16:00-24:00	17.9	3,025	10.32	11.21	31.68	46.73	0.55	11724	1.10	15016

Mon 05/22/06

UNIT#5	64185	M	26	00:01-08:00	17.9	1,456	10.46	9.69	31.34	48.51	0.69	11964	1.15	14983
UNIT#5	64187	M	36	08:00-16:00	50.1	718	9.30	10.69	31.21	48.80	0.65	11945	1.09	14929
UNIT#5	64189	M	35	16:00-24:00	21.2	1,650	9.37	10.96	33.40	46.27	0.57	11887	1.12	14920

Tues 05/23/06

UNIT#5	64196	M	42	00:01-08:00	18.5	2,269	9.93	11.12	31.39	47.51	0.59	11752	1.17	14895
UNIT#5	64198	M	36	08:00-16:00	18.3	1,967	8.87	10.02	33.52	47.59	0.70	12073	1.16	14885
UNIT5	64200	M	6	16:00-18:00	17.2	349	9.50	11.50	33.39	45.61	0.68	11694	1.16	14803
NO TEST	64201	M	103	18:00-24:00	23.3	4,424	11.52	7.24	34.83	46.41	0.57	11570	0.99	14242

PROXIMATE RESULTS from  
DAILY PRB BURN  
SAMPLERS

(Proximate)

Jun-02-06 03:39pm From-Standard Labs

BEST AVAILABLE COPY

6066338136

T-134 P.003/003 F-507



STANDARD LABORATORIES, INC.

Lab No. 60530195

Date Rec'd 05/30/06

Date Sampled 05/29/06 - TUES

Sampled By YOURSELVES

PO BOX 606  
WHITESBURG, KY 41658  
TEL: 606-633-9373  
FAX: 606-633-8136

SL-CRYSTAL RIVER (#23)  
ATTN: MIKE EBERHARDT  
P.O. BOX 2883  
CRYSTAL RIVER, FL 34423

Sample ID: 0004-600M  
4 - UNITS  
2269 TONS  
LAB #64196

ULTIMATE  
ANALYSES  
FOR  
PRB/CSPP  
BLEND

Taken from  
Plant  
Samplers.

ULTIMATE ANALYSIS OF COAL

ASH:  
HYDROGEN:  
CARBON:  
NITROGEN:  
SULFUR:  
OXYGEN:

	AS REC'D	% DRY BASIS
ASH:	11.12	12.35
HYDROGEN:	4.66	5.18
CARBON:	67.88	75.40
NITROGEN:	1.27	1.41
SULFUR:	0.69	0.77
OXYGEN:	4.40	4.89

Respectfully Submitted: R. Champion  
RICK CHAMPION / MANAGER  
BILLY MULLINS / ASSISTANT MANAGER

BEST AVAILABLE COPY

Jun-02-06 03:39pm From-Standard Labs

6066338136

T-134 P.002/003 P-507



STANDARD LABORATORIES, INC.

Lab No. 60530197

Date Rec'd 05/30/06

PO BOX 606  
WHITESBURG, KY 41186  
TEL: 606-633-9373  
FAX: 606-633-8136

Date Sampled 05/21/06 - SUN

Sampled By YOURSELVES

SL-CRYSTAL RIVER (#23)  
ATTN: MIKE EBERHARDT  
P.O. BOX 2803  
CRYSTAL RIVER, FL 34423

Sample ID: 1600-2400  
4 - UNIT 6 ORIGIN MB  
3025 TONS  
LAB #64178

ULTIMATE ANALYSIS OF COAL	AS REC'D	% DRY BASIS
ASH:	11.27	12.57
HYDROGEN:	4.69	5.12
CARBON:	67.59	75.35
NITROGEN:	1.27	1.42
SULFUR:	0.66	0.73
OXYGEN:	4.31	4.81

Respectfully Submitted:   
RICK CHAMPION / MANAGER  
BILLY MULLINS / ASSISTANT MANAGER

June 5-6 2006 Baseline Proximate Coal Samples																				
Pulled from sampler #4 and analyzed by Standard Labs.																				
S.L.	Sampler # 4			JUNE 2004			As Bunker Samples								MAF	Dry	Dry	Dry		
	Mech	Type	#	I.D.	#/1000		Volatile	Fixed		Lbs SO2										
Date	Lab #	Hand	A/D	Samp	Shift	Tons	Tonnage	Moisture	Ash	Matter	Carbon	Sulfur	BTU/LE	/MBTU	BTU	Ash	Sul	Btu	Vol	
4	06/05/06	64324	M	D	70	00:01-08:00	19.5	3,591	9.47	9.08	33.88	47.57	0.67	12004	1.12	14738	10.03	0.74	13260	37.42
4	06/06/06	64335	M	D	66	16:00-24:00	14.9	4,438	6.27	9.98	33.53	50.22	0.69	12621	1.09	15070	10.65	0.74	13465	35.77

JUNE  
2006  
BASELINE COAL  
(PROXIMATE)

JUNE 2006  
Baseline Coals



STANDARD LABORATORIES, INC.  
(ULTIMATE)

Lab No. 60612221

Date Rec'd 06/12/06

Date Sampled 06/06/06

Sampled By YOURSELVES

PO BOX 606  
WHITESBURG, KY 41858  
TELE: 606-633-9373  
FAX: 606-633-8136

PROGRESS ENERGY  
ATTN: JAY CHESSER  
P.O. BOX 2883  
CRYSTAL RIVER, FL 34423

Sample ID: 1600-2400 M - 4

D  
TONS: 4438  
LAB #64335

ULTIMATE ANALYSIS OF COAL	% AS RUN BASIS	% DRY BASIS
ASH:	9.98	10.65
HYDROGEN:	4.89	5.22
CARBON:	72.16	76.98
NITROGEN:	1.41	1.50
SULFUR:	0.69	0.74
OXYGEN:	4.60	4.91

Respectfully Submitted:  
RICK CHAMPION / MANAGER  
BILLY MULLINS / ASSISTANT MANAGER



STANDARD LABORATORIES, INC.

Lab No. 60612220

Date Rec'd 06/12/06

Date Sampled 06/05/06

Sampled By YOURSELVES

PO BOX 606  
WHITESBURG, KY 41858  
TELE: 606-633-9373  
FAX: 606-633-8136

PROGRESS ENERGY  
ATTN: JAY CHESSER  
P.O. BOX 2883  
CRYSTAL RIVER, FL 34423

Sample ID: 0001-0800 M - 4

D  
TONS: 3591  
LAB #64324

ULTIMATE ANALYSIS OF COAL	% AS RUN	% DRY BASIS
ASH:	9.08	10.03
HYDROGEN:	4.76	5.26
CARBON:	69.00	76.22
NITROGEN:	1.34	1.48
SULFUR:	0.67	0.74
OXYGEN:	5.68	6.27

Respectfully Submitted: Billy Mullins  
RICK CHAMPION / MANAGER  
BILLY MULLINS / ASSISTANT MANAGER

07/18/06

Baseline (6/5/06) and Blend (5/22/06) - Particulate and CO Test Report

**PARTICULATE MATTER AND CARBON MONOXIDE  
EMISSIONS TEST REPORT**

**EU-003 FOSSIL FUEL STEAM GENERATOR (Unit 5)**

**Sub-bituminous/Bituminous Coal Blend Trial Burn**

**Florida Power Corporation  
dba Progress Energy Florida, Inc.  
Crystal River Plant**

**Permit Numbers: 0170004-009-AV and  
0170004-012-AC**

**Test Date: May 22, 2006 and June 5, 2006  
Report Date: June 29, 2006**

**Koogler & Associates, Inc.  
4014 NW 13<sup>th</sup> Street  
Gainesville, Florida 32609  
352-377-58222**

**673-06-06**



PARTICULATE MATTER AND CARBON MONOXIDE  
EMISSIONS TEST REPORT

EU-003 FOSSIL FUEL STEAM GENERATOR (Unit 5)

**Sub-bituminous/Bituminous Coal Blend Trial Burn**

Florida Power Corporation  
dba Progress Energy Florida, Inc.  
Crystal River Plant


Permit Numbers: 0170004-009-AV and  
0170004-012-AC

Test Date: May 22, 2006 and June 5, 2006  
Report Date: June 29, 2006

**Responsible Official Certification:**

I certify that, based upon information and belief formed after reasonable inquiry,  
the statements and information in the attached documents are true, accurate  
and complete.

Bernie M. Cumbie,  
Manager, Crystal River Fossil Plant & Fuel Operations



Signature

Date:

7/6/06



**PARTICULATE MATTER AND CARBON MONOXIDE  
EMISSIONS TEST REPORT**

**EU-003 FOSSIL FUEL STEAM GENERATOR (Unit 5)**

**Sub-bituminous/Bituminous Coal Blend Trial Burn**

**Florida Power Corporation  
dba Progress Energy Florida, Inc.  
Crystal River Plant**

Permit Numbers: 0170004-009-AV and  
0170004-012-AC

Test Date: May 22, 2006 and June 5, 2006  
Report Date: June 29, 2006

**Responsible Official Certification:**

I certify that, based upon information and belief formed after reasonable inquiry,  
the statements and information in the attached documents are true, accurate  
and complete.



Bernie M. Cumbie,  
Manager, Crystal River Fossil Plant & Fuel Operations

Signature

Date:



To the best of my knowledge, all applicable field and analytical procedures comply with the Florida Department of Environmental Protection requirements and all test data and plant operating data are true and correct.

  
John B. Koogler, Ph.D., P.E.  
  
State of Florida  
License No. 12925

06|29|06

Date



## TABLE OF CONTENTS

1.0 INTRODUCTION.....	Page 1
2.0 SAMPLE PORT LOCATIONS .....	Page 4
3.0 FIELD AND ANALYTICAL METHODS.....	Page 6
4.0 SUMMARY OF RESULTS .....	Page 9
4.1 SUB-BITUMINOUS/BITUMINOUS COAL TRIAL BURN.....	Page 9
4.2 NORMAL BITUMINOUS COAL USE .....	Page 9

## APPENDIX



## 1.0 INTRODUCTION

Florida Power Corporation dba Progress Energy Florida, Inc. owns and operates an electrical power generation complex in Crystal River, Florida. The complex consists of four coal-fired fossil fuel steam generating (FFSG) units and one nuclear steam generating unit. The four fossil fuel power generation units are permitted under Title V Air Operation Permit Number 0170004-009-AV. Each of the four fossil fuel units has high efficiency electrostatic precipitators for particulate matter emission control.

On May 22, 2006, Koogler & Associates, Inc. of Gainesville, Florida conducted particulate matter (PM) and carbon monoxide (CO) emission measurements on the No. 5 FFSG unit (Emission Unit 003). Emission measurements for PM and CO were conducted to satisfy the requirements of Permit No. 0170004-012-AC that authorize Progress Energy to conduct a trial burn with a mixture of sub-bituminous coal and bituminous coal in Unit 4 and/or Unit 5.

The No. 5 FFSG unit is rated at 760 megawatt (MW) or 6,665 mmBTU per hour. The unit can burn bituminous coal; or a bituminous coal and bituminous coal briquette mixture. Distillate fuel oil may be burned as a startup fuel.

Additional emission measurements were conducted on the No. 5 FFSG for particulate matter and carbon monoxide on June 5, 2006. These measurements

were conducted under normal coal firing conditions. The PM measurements conducted during the June 5, 2006 test period were performed to meet the compliance assurance requirements of Permit No. 0170004-009-AV.

The CO and PM emission measurements conducted on June 5, 2006 are incorporated in this report to provide baseline Unit 5 emission data against which the trial burn test results can be compared.

Prior to testing, the Southwest District office of the Florida Department of Environmental Protection was notified of the test schedule.

Unit 5 is limited by permit to 0.1 pounds of particulate matter per million Btu (lb/mmBTU) heat input while operating normally. Koogler & Associates conducted six one-hour particulate matter emissions test runs and six one-hour carbon monoxide test runs on Unit 5 during the May 22, 2006 test period. During the June 5, 2006 annual compliance test, Koogler & Associates conducted three one-hour particulate matter runs and three one-hour carbon monoxide emission test runs on Unit 5.

Particulate matter emissions tests on Unit 5 during the May 22, 2006 bituminous coal and bituminous coal trial resulted in an average particulate matter emission rate of 0.003 lb/mmBTU at an average heat input rate of 6,455 mmBTU/hr (96.8

percent of permitted). Carbon monoxide emissions during the same test period averaged 0.032 lb/mmBTU (208.6 lb/hr).


Particulate matter emissions tests on Unit No. 5 during the June 5, 2006 test period while Unit 5 was fired with the coal normally fired to the unit resulted in an average particulate matter emission rate of 0.004 lb/mmBTU at an average heat input rate of 6,526 mmBTU/hr (97.9 percent of permitted). No carbon monoxide was detected (<1 ppm) during the CO test runs conducted during the June 5, 2006 test period.

## **2.0 SAMPLE PORT LOCATIONS**

Four sample ports are located at 90 degrees to one another in the 308 inch diameter stack. The sample ports are located approximately 350 feet (13.6 duct diameters) downstream from any flow disturbing ductwork and 188 feet (7.3 duct diameters) below the top of the stack. The overall stack height is 600 feet from the ground level. Based on a four port traverse configuration, 12 points were selected for the EPA Methods 2, 3, 4 and 5 sample train traverses; three points through each of the four sample ports. A diagram of the stack and sample traverse points is presented in Figure 1.

Figure 1

Progress Energy  
Crystal River Plant  
Unit 4 and Unit 5




### **3.0 FIELD AND ANALYTICAL PROCEDURES**

Particulate matter emission measurements were made using EPA Method 17 as adopted by FDEP in Rule 62-297.401(17), F.A.C. The in-stack filter holder was constructed of stainless steel with a 47 mm diameter filter. The sampling point locations for the EPA Method 17 test were established in accordance with EPA Method 1. A schematic diagram of the sampling train used for the particulate matter emission measurements is shown in Figure 2.


Stack gas velocity measurements and stack gas moisture measurements were made in conjunction with the EPA Method 17 tests in accordance with EPA Methods 2 and 4. The dry molecular weight of the stack gas was determined in accordance with EPA Method 3. Carbon monoxide emission measurements were made using EPA Method 10 as adopted by FDEP in Rule 62-297.401(10), F.A.C. The carbon monoxide emission sample was drawn into a heated probe and filter, heated sample line and a moisture removal system upstream of the CO monitor. A schematic diagram of the carbon monoxide continuous emission monitor is shown in Figure 3.

Opacity observations were made in accordance with EPA Method 9.

All EPA test methods are described in 40 CFR 60, Appendix A and have been adopted by reference by Rule 62-297.401, F.A.C.



**Figure 2**  
EPA Method 17 Particulate Matter Sample Train



**FIGURE 3**  
Continuous Stack Gas Monitoring System

## **4.0 SUMMARY OF RESULTS**

The results of particulate matter and carbon monoxide emission measurements conducted on the Unit 5 Fossil Fuel Steam Generator during the period of May 22, 2006 and June 5, 2006 are summarized in Table 1 and Table 2 respectively.

### **4.1 Sub-Bituminous Coal and Bituminous Coal Trial Burn**

The power plant boiler was fired with a blend of sub-bituminous and bituminous coal. The firing rate produced an average heat input rate of 6,455 mmBTU/hr or 96.8 percent of the permitted heat input rate. The permitted rate for Unit 5 is 6,665 mmBTU/hr. The average particulate matter emission rate for the six sample runs was 0.003 lb/mmBTU. Unit 5 is limited by permit to 0.1 pounds of particulate matter per million Btu (lb/mmBTU) heat input. The carbon monoxide emission rate for the six sample runs averaged 0.032 lb/mmBTU which is equivalent to 208.6 pounds of CO per hour or 32 ppm in a stack gas flow of 1,510,000 dscfm. The results of the emission measurements conducted during the sub-bituminous and bituminous coal trial burn are summarized in Table 1.

### **4.2 Normal Bituminous Coal Use**

The power plant boiler was fired with bituminous coal during the June 5, 2006 test period. The firing rate produced an average heat input rate of 6,526 mmBTU/hr or 97.9 percent of the permitted heat input rate. The permitted heat input rate for Unit 5 is 6,665 mmBTU/hr. The particulate matter emissions tests on Unit No. 5 during normal operations resulted in an average particulate matter

emission rate of 0.004 lb/mmBTU. Unit 5 is limited by permit to 0.1 pounds of particulate matter per million Btu (lb/mmBTU) heat input. Carbon monoxide emission measurements showed no detectable carbon monoxide in the stack gas (<1 ppm) during the normal operation of Unit 5. Results of the test conducted on June 5, 2006 are summarized in Table 2.

Table 1  
Summary of PM/PM10 and CO Emission Measurements

Unit No. 5 PM/PM10 and CO Emission Summary														
Progress Energy														
Crystal River, Florida														
May 22, 2006														
Date	Operating Condition	Run No.	Coal Feed (ton/hr)	Heat Input (MMBtu/hr)(1)	Stack Gas				Particulate Matter (PM/PM10)			Carbon Monoxide (CO)(4)(5)		
					Flow (dscfm)	Temp. (F)	Moisture (%)	CO <sub>2</sub> (%)	(gr/dscf)	(lb/hr)	(lb/MMBtu)(2)	ppmv	(lb/hr)	(lb/MMBtu)(3)
05/22/06	Normal	1	253.7	6045	1.50E+06	295	6.8	12.3	0.0017	21.9	0.004	28.6	186.9	0.031
05/22/06	Normal	2	269.0	6411	1.50E+06	295	7.4	12.1	0.0021	26.4	0.004	56.6	371.0	0.058
05/22/06	Normal	3	263.7	6284	1.51E+06	297	7.2	12.1	0.0021	27.3	0.004	31.3	206.8	0.033
05/22/06	Normal	4	295.4	7040	1.52E+06	297	7.8	12.1	0.0016	20.8	0.003	31.4	208.5	0.030
05/22/06	Normal	5	272.5	6494	1.52E+06	296	8.2	12.1	0.0016	20.2	0.003	24.0	158.9	0.024
05/22/06	Normal	6	271.0	6458	1.54E+06	297	7.8	12.2	0.0012	16.1	0.002	17.8	119.5	0.019
		Ave.>	270.9	6455	1.51E+06	296	7.5	12.2	0.0017	22.1	0.003	31.5	208.6	0.032

(1) (MMBtu/hr) = (Ton Coal/Hr) x (2000 lb/ton) x (12515 Btu/pound coal) x (MMBtu / 10<sup>6</sup> Btu)

(2) (lb/MMBtu) = (lb PM/hr) / (MMBtu/hr) see (1)

(3) (lb/MMBtu) = (lb CO/hr) / (MMBtu/hr) see (1)

(4) Corrected to 7% Oxygen

(5) Using EPA Method 19 and EPA Method 20 Conversion Equations, see Table below.

EPA Method 19 Table 19-2	F <sub>d</sub> = 9780 dscf/mmBtu F <sub>c</sub> = 1800 scf/mmBtu
EPA Method 20 7.2.1	F <sub>o</sub> =(.209*F <sub>d</sub> )/F <sub>c</sub> F <sub>o</sub> = 1.136
EPA Method 20 7.2.2	X <sub>CO<sub>2</sub></sub> =(20.9%O <sub>2</sub> -7 %O <sub>2</sub> )/F <sub>o</sub> X <sub>CO<sub>2</sub></sub> =(13.9)/F <sub>o</sub> X <sub>CO<sub>2</sub></sub> = 12.2
EPA Method 20 7.3.2	CO corr.=COPpmvd x (X <sub>CO<sub>2</sub></sub> /CO2 %)

Table 2  
Summary of PM10 and CO Emission Measurements

Unit No. 5 PM10 and CO Emission Summary Progress Energy Crystal River, Florida June 5, 2006													
Date	Operating Condition	Run No.	Coal Feed (ton/hr)	Heat Input (MMBtu/hr)(1)	Stack Gas			Particulate matter			Carbon Monoxide		
					Flow (dscfm)	Temp. (F)	Moisture (%)	(gr/dscf)	(lb/hr)	(lb/MMBtu)(2)	ppmv	(lb/hr)	(lb/MMBtu)(2)
06/05/06	Normal	1	301.7	6870	1.58E+06	297	8.1	0.0017	22.9	0.003	0.0	0.0	0.000
06/05/06	Normal	2	278.1	6333	1.59E+06	298	7.8	0.0019	25.4	0.004	0.0	0.0	0.000
06/05/06	Normal	3	280.0	6376	1.53E+06	298	8.6	0.0018	23.5	0.004	0.0	0.0	0.000
		Ave.>	286.6	6526	1.56E+06	298	8.1	0.0018	23.9	0.004	0.0	0.0	0.000

(1) (MMBtu/hr) = (Ton Coal/Hr) x (2000 lb/ton) x (12500 Btu/pound coal) x ( MMBtu /  $10^6$  Btu)

(2) (lb/MMBtu) = (lb PM/hr) / (MMBtu/hr) see (1)

(3) (lb/MMBtu) = (lb CO/hr) / (MMBtu/hr) see (1)

## Appendix

### **Unit 5 Sub-Bituminous/Bituminous Coal Trial Burn May 22, 2006**

#### Calculations

Particulate Matter

Carbon Monoxide

#### Field and Laboratory Data Sheets

Particulate Matter

Carbon Monoxide

#### Sampling Equipment Calibration Records

#### Plant Operating Data

### **Unit 5 Normal Operations June 5, 2006**

#### Calculations

Particulate Matter

Carbon Monoxide

#### Field and Laboratory Data Sheets

Particulate Matter

Carbon Monoxide

#### Sampling Equipment Calibration Records

#### Plant Operating Data

### **Project Participants**

**Unit 5 Sub-Bituminous/Bituminous Coal Trial Burn**  
**May 22, 2006**

## Calculations

## Particulate Matter

Progress Energy, Crystal River, FL  
 Unit No. 5  
 May 22, 2006

Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)	Particulate Matter	
				Conc. (gr/dscf)	Emission Rate (Lbs/Hr)
1	1,496,491	295	6.8	0.0017	21.93
2	1,502,732	295	7.4	0.0021	26.45
3	1,512,780	297	7.2	0.0021	27.28
Average	1,504,001	296	7.1	0.0020	25.22

GENERAL DATA

Plant	:	Progress Energy, Crystal River, FL		
Source/Unit	:	Unit No. 5		
Date	:	May 22, 2006	Cp	0.840
Stack dia.	:	308.00 inch	OR :	Duct Length 0.00 inch
Oxygen Corr.:	0.0 percent		Duct Width 0.00 inch	
CO2 Corr. :	0.0 percent		Std. Temp. 68 F	

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U	f	Process Wt.
----------------------------	---	-------------

Hydrogen, wt% : 0.00	Run 1 :	0 Tons/hr
----------------------	---------	-----------

Carbon, wt% : 0.00	Run 2 :	0
--------------------	---------	---

Sulfur, wt% : 0.00	Run 3 :	0
--------------------	---------	---

Nitrogen, wt% : 0.00
----------------------

Oxygen, wt% : 0.00
--------------------

Btu/lb : 0
------------

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter)	1
--	---

F-Factor :	dscf/MMBtu;
------------	-------------

<u>FIELD DATA</u>	METHOD 5	RUN	RUN	RUN
		1	2	3

Meter Temp., Tm (F) .....	91	100	103
---------------------------	----	-----	-----

Stack Temp., Ts (F) .....	295	295	297
---------------------------	-----	-----	-----

Sq.Rt. dP .....	1.10	1.11	1.12
-----------------	------	------	------

dH (in. H2O) .....	2.28	2.33	2.48
--------------------	------	------	------

Meter Vol.,Vm (ft3) .....	50.328	52.800	54.116
---------------------------	--------	--------	--------

Vol. H2O, Vlc (ml) .....	75.0	85.0	84.0
--------------------------	------	------	------

Meter Y .....	0.998	0.998	0.998
---------------	-------	-------	-------

Bar. Press.,Pb (in.Hg.) .....	30.12	30.12	30.12
-------------------------------	-------	-------	-------

Static Press.,Ps (in.H2O) .....	-0.88	-0.88	-0.88
---------------------------------	-------	-------	-------

Test Time (min.) .....	60.0	60.0	60.0
------------------------	------	------	------

Nozzle Dia.,Dn (in.) .....	0.232	0.232	0.232
----------------------------	-------	-------	-------

Oxygen, O2 (%) .....	13.0	8.5	5.0
----------------------	------	-----	-----

Carbon Dioxide, CO2 (%) .....	6.5	8.0	11.0
-------------------------------	-----	-----	------

Carbon Monoxide, CO (%) .....	0.0	0.0	0.0
-------------------------------	-----	-----	-----

Report Emission Criteria in ? l = lb/hr g = gr/dscf :	grams
---	-------

Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min:	T
--	---

Allowable Particulate Matter Concentration .....	0
--	---

<u>LABORATORY RESULTS</u>	RUN	RUN	RUN
	1	2	3
	grams	grams	grams

GRAVIMETRIC ANALYSIS METHOD 5 :
---------------------------------

Front Half Wash (FWH) .....	0.00160	0.00230	0.00220
-----------------------------	---------	---------	---------

Filterable Sample (MF) .....	0.00380	0.00440	0.00480
------------------------------	---------	---------	---------

Condensible Sample (BHW) .....	0.00000	0.00000	0.00000
--------------------------------	---------	---------	---------

A. FIELD DATA SUMMARY

---

Plant: Progress Energy, Crystal River, FL  
 Source/Unit: Unit No. 5  
 Date: May 22, 2006

	RUN 1	RUN 2	RUN 3
Vlc = Vol water collected in train, ml	75.0	85.0	84.0
Vm = Sample gas vol, meter cond., acf	50.328	52.800	54.116
Y = Meter calibration factor	0.9980	0.9980	0.9980
Pbar = Barometric pressure, in. Hg	30.12	30.12	30.12
Pstatic = Stack static pressure, in. H2O	-0.88	-0.88	-0.88
dH = Avg meter pressure diff, in. H2O	2.28	2.33	2.48
Tm = Absolute meter temp., degrees R	550.8	559.5	562.6
Vm(std) = Sample gas vol, Std. cond., dscf	48.737	50.344	51.335
Bws = Water vapor in gas stream, fraction	0.068	0.074	0.072
MF = Moisture factor ( 1 - Bws)	0.932	0.926	0.928
CO2 = Carbon Dioxide, dry, volume %	6.50	8.00	11.00
O2 = Oxygen, dry, volume %	13.00	8.50	5.00
N2 = Nitrogen, dry volume %	80.50	83.50	84.00
Md = Molecular weight of stack gas, dry	29.56	29.62	29.96
Ms = Molecular weight of stack gas, wet	28.78	28.76	29.10
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	1.0966	1.1084	1.1212
Ts = Absolute stack temp., degrees R	754.7	755.1	756.9
A = Area of stack, ft2	517.40	517.40	517.40
Qstd = Volumetric flowrate, dscfm	1,496,491	1,502,732	1,512,780
An = Nozzle area, ft2	2.94E-04	2.94E-04	2.94E-04
t = Sample time, minutes	60.00	60.00	60.00
%I = Isokinetic variation, percent	95.67	98.42	99.69

B. PARTICULATE DATA SUMMARY

---

Plant: Progress Energy, Crystal River, FL  
Source/Unit: Unit No. 5  
Date: May 22, 2006

	RUN 1	RUN 2	RUN 3
Sample Weight (FHW + MF + BHW), mg .....	5.40	6.70	7.00
Meter Volume, standard cond., Vm(std) .....	48.737	50.344	51.335
Carbon Dioxide, percent .....	6.50	8.00	11.00
Oxygen, percent .....	13.00	8.50	5.00
Sample Concentration :			
gr/scf .....	0.0016	0.0019	0.0020
gr/dscf .....	0.0017	0.0021	0.0021
gr/dscf @ 0 % CO2 .....	0.0032	0.0031	0.0023
gr/dscf @ 0 % O2 .....	0.0045	0.0035	0.0028
ppm * MW (dry gas) .....	94.0	113.0	115.7
ppm * MW @ 0% CO2 .....	0.0	0.0	0.0
ppm * MW @ 0% O2 .....	248.8	190.4	152.1

**EMISSION RATE CALCULATIONS**

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

Date: May 22, 2006

RUN NO.:

1

STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00160	grams	Vm(std)	48.737	ft3
Mass Filter (MF)	0.00380	grams	Vw(std)	3.530	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,496,491	dscfm
Vm(std) SO2		dscf	Bws	0.068	
CO2 CORR. 0.0 %			CO2	6.50	%
O2 CORR.: 0.0 %			O2	13.00	%

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (\text{Btu/lb}) \times [(T_{std} + 460)/528] \dots \dots \dots \text{dscf/MMBtu}$$

FUEL USE

$$\begin{aligned} \text{Use Rate (gal/ton)} * \text{Process Wt. (ton/hr)} &\dots \dots \dots \text{gal/hr} \\ \text{Heat Input} = (\text{Process Weight (ton/hr)} \times \text{Heating} \dots \dots \dots \text{MMBtu/hr} \\ \text{Value (Btu/gal)} \times \text{Fuel Use Rate (gal/ton)} / 1E6 \end{aligned}$$

TOTAL PARTICULATE

$$\begin{aligned} 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [\text{Vm(std)} + \text{Vw(std)}] \dots &0.0016 \text{ gr/scf} \\ 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / (\text{Vm(std)}) \dots \dots \dots &0.0017 \text{ gr/dscf} \\ \text{gr/dscf} \times (12 / \% \text{CO}_2) \dots \dots \dots &0.0032 @ 0\% \text{ CO}_2 \\ \text{gr/dscf} \times [(20.9 - \text{Oxygen corr.}) / (20.9 - \% \text{O}_2)] \dots \dots \dots &0.0045 @ 0\% \text{ O}_2 \\ 0.00857 \times \text{Qs(std)} \times \text{gr/dscf} \dots \dots \dots &21.93 \text{ lb/hr} \\ \text{F-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \% \text{O}_2)] \times \text{gr/dscf} \dots \dots \dots &\text{lb/MMBtu} \\ \text{Particulate (lb/hr)} / \text{Heat Input (MMBtu/hr)} \dots \dots \dots &\text{lb/MMBtu} \end{aligned}$$

TOTAL ACID MIST

$$\begin{aligned} [1.0811E-4 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} \dots &\text{lb Acid Mist} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std} \times 60 \dots &\text{lb/hr} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{F-Factor} \dots \dots \dots &\text{lb/MMBtu} \end{aligned}$$

SULFUR DIOXIDE (SO2)

$$\begin{aligned} [7.061E-5 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} &\text{lb SO2} \\ [\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std (ft}^3/\text{min}) \times 60 \dots &\text{lb/hr} \\ [\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{F} \dots \dots \dots &\text{lb/MMBtu} \\ [\text{Mass SO2 (lb)} \times 385 / 64E+6 (\text{ft}^3/\text{lb})] / \text{Vm (std)} &\text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 6.5 \% \text{ CO}_2 \text{ in Stack} \dots \dots \dots &\text{ppm} @ 0\% \text{ CO}_2 \\ \text{ppm} \times (20.9\% - 0.0\% \text{ O}_2 \text{ Corr}) / (20.9\% - 13.0\% \text{ O}_2 \text{ Stack}) &\text{ppm} @ 0\% \text{ O}_2 \\ \text{SO2 (lb/hr} / \text{Heat Input}) \dots \dots \dots &\text{lb/MMBtu} \end{aligned}$$

HYDROGEN CHLORIDE DATA SUMMARY

$$\begin{aligned} [\text{Mass HCl(mg)} \times 385 \times 1E6] / [453600 \times 36.5 \times \text{Vm(std)}] \dots &\text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 6.5 \% \text{ CO}_2 \text{ in Stack} \dots \dots \dots &\text{ppm} @ 0\% \text{ CO}_2 \\ \text{ppm} \times (20.9\% - 0.0\% \text{ O}_2 \text{ Corr}) / (20.9\% - 6.5\% \text{ O}_2 \text{ Stack}) &\text{ppm} @ 0\% \text{ O}_2 \\ [\text{Mass HCl(mg)} \times 60 \times \text{Qs} / (\text{Vm(std)} \times 453,600)] \dots \dots \dots &\text{lb/hr} \end{aligned}$$

EMISSION RATE CALCULATIONS

---

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

Date: May 22, 2006

RUN NO.:

2

STANDARD TEMP. : 68 F

---

Front Half Wash (FHW)	0.00230	grams	Vm(std)	50.344	ft3
Mass Filter (MF)	0.00440	grams	Vw(std)	4.001	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,502,732	dscfm
Vm(std) SO2		dscf	Bws	0.074	
CO2 CORR. 0.0 %			CO2	8.00	%
O2 CORR.: 0.0 %			O2	8.50	%

---

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -  
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] .....

dscf/MMBtu

FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) .....

gal/hr

Heat Input = (Process Weight (ton/hr) x Heating ....

MMBtu/hr

Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6

TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...

0.0019 gr/scf

15.432 x (FHW + MF + BHW) / (Vm(std) .....

0.0021 gr/dscf

gr/dscf x (12 / %CO2) .....

0.0031 @ 0% CO2

gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] .....

0.0035 @ 0% O2

0.00857 x Qs(std) x gr/dscf .....

26.45 lb/hr

F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..

lb/MMBtu

Particulate (lb/hr) / Heat Input (MMBtu/hr) .....

lb/MMBtu

TOTAL ACID MIST

[ 1.0811E-4 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog) .

lb Acid Mist

[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ...

lb/hr

[Acid Mist (lb) / Vm std (ft^3)] x F-Factor .....

lb/MMBtu

SULFUR DIOXIDE (SO2)

[ 7.061E-5 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog) .

lb SO2

[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ...

lb/hr

[SO2 (lb) / Vm std (ft^3)] x F .....

lb/MMBtu

[ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb) ] / Vm (std)

ppm

ppm x 0.0 % Corr. / 6.5 % CO2 in Stack .....

ppm @ 0% CO2

ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 6.5% O2 Stack)

ppm @ 0% O2

SO2 (lb/hr / Heat Input) .....

lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)]..

ppm

ppm x 0.0 % Corr. / 8.0 % CO2 in Stack .....

ppm @ 0% CO2

ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 8.0% O2 Stack)

ppm @ 0% O2

[ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )].....

lb/hr

EMISSION RATE CALCULATIONS

---

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

Date: May 22, 2006

RUN NO.:

3

STANDARD TEMP. : 68 F

---

Front Half Wash (FHW)	0.00220	grams	Vm(std)	51.335	ft3
Mass Filter (MF)	0.00480	grams	Vw(std)	3.954	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,512,780	dscfm
Vm(std) SO2		dscf	Bws	0.072	
CO2 CORR. 0.0 %			CO2	11.00	%
O2 CORR.: 0.0 %			O2	5.00	%

---

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (\text{Btu/lb}) \times [(T_{std} + 460)/528] \dots \text{dscf/MMBtu}$$

FUEL USE

$$\begin{aligned} \text{Use Rate (gal/ton)} * \text{Process Wt. (ton/hr)} &\dots \text{gal/hr} \\ \text{Heat Input} = (\text{Process Weight (ton/hr)} \times \text{Heating} \dots) &\text{MMBtu/hr} \\ \text{Value (Btu/gal)} \times \text{Fuel Use Rate (gal/ton)} / 1E6 & \\ \text{TOTAL PARTICULATE} & \end{aligned}$$

$$\begin{aligned} 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [\text{(Vm(std)} + \text{Vw(std)}] \dots & 0.0020 \text{ gr/scf} \\ 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / \text{(Vm(std)} \dots & 0.0021 \text{ gr/dscf} \\ \text{gr/dscf} \times (12 / \%CO2) \dots & 0.0023 @ 0\% CO2 \\ \text{gr/dscf} \times [(20.9 - \text{Oxygen corr.}) / (20.9 - \%O2)] \dots & 0.0028 @ 0\% O2 \\ 0.00857 \times \text{Qs(std)} \times \text{gr/dscf} \dots & 27.28 \text{ lb/hr} \\ \text{F-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times \text{gr/dscf} \dots & \text{lb/MMBtu} \\ \text{Particulate (lb/hr)} / \text{Heat Input (MMBtu/hr)} \dots & \text{lb/MMBtu} \\ \text{TOTAL ACID MIST} & \end{aligned}$$

$$\begin{aligned} [1.0811E-4 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} \dots & \text{lb Acid Mist} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std} \times 60 \dots & \text{lb/hr} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{F-Factor} \dots & \text{lb/MMBtu} \\ \text{SULFUR DIOXIDE (SO2)} & \end{aligned}$$

$$\begin{aligned} [7.061E-5 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} \dots & \text{lb SO2} \\ [\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std (ft}^3/\text{min}) \times 60 \dots & \text{lb/hr} \\ [\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{F} \dots & \text{lb/MMBtu} \\ [\text{Mass SO2 (lb)} \times 385 / 64E+6 (\text{ft}^3/\text{lb})] / \text{Vm (std)} & \text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 6.5 \% \text{ CO2 in Stack} \dots & \text{ppm} @ 0\% CO2 \\ \text{ppm} \times (20.9\% - 0.0\% O2 \text{ Corr}) / (20.9\% - 6.5\% O2 \text{ Stack}) & \text{ppm} @ 0\% O2 \\ \text{SO2 (lb/hr} / \text{Heat Input}) \dots & \text{lb/MMBtu} \\ \text{HYDROGEN CHLORIDE DATA SUMMARY} & \end{aligned}$$

$$\begin{aligned} [\text{Mass HCl(mg)} \times 385 \times 1E6] / [453600 \times 36.5 \times \text{Vm(std)}] \dots & \text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 11.0 \% \text{ CO2 in Stack} \dots & \text{ppm} @ 0\% CO2 \\ \text{ppm} \times (20.9\% - 0.0\% O2 \text{ Corr}) / (20.9\% - 11.0\% O2 \text{ Stack}) & \text{ppm} @ 0\% O2 \\ [\text{Mass HCl(mg)} \times 60 \times \text{Qs} / (\text{Vm(std)} \times 453,600)] \dots & \text{lb/hr} \end{aligned}$$

SOURCE TEST CALCULATIONS

Plant : Progress Energy, Crystal River, FL  
 Source/Unit : Unit No. 5  
 Date: May 22, 2006

RUN NO.: 1

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.88 in. H2O
METER TEMP, Tm =	90.83333 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	294.7 F	STACK I.D. =	308.00 inch
AVG.VEL.HEAD,dP =	1.203 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	2.28 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	50.328 Cu.Ft.	STACK AREA, As =	517.403 Sq.Ft.
METER COFF., Y =	0.998	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.232 inch
COND.(Vlc) =	75.0 ml	NOZZLE DIA., An =	2.9E-04 Sq.Ft.
GAS ANALYSIS =	13.00 % O2 6.50 % CO2	0.00 % CO 80.50 % N2	

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460) .....	=	48.737 dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	3.530 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.068   Lower   Bws   value
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000   used.
%EA = (%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =		157.54
Md = (.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)] =		29.56
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	28.78
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	73.56 ft/sec
Qs = vs x As x 60 .....	=	2,283,531 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,496,491 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	95.67 %

SOURCE TEST CALCULATIONS

Plant : Progress Energy, Crystal River, FL  
 Source/Unit : Unit No. 5  
 Date : May 22, 2006

RUN NO.: 2

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.88 in. H2O
METER TEMP, Tm =	99.50 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	295.1 F	STACK I.D. =	308.00 inch
AVG.VEL.HEAD,dP =	1.229 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	2.33 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	52.800 Cu.Ft.	STACK AREA, As =	517.403 Sq.Ft.
METER COFF., Y =	0.998	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.232 inch
COND.(Vlc) =	85.0 ml	NOZZLE DIA., An =	2.9E-04 Sq.Ft.
GAS ANALYSIS =	8.50 % O2	0.00 % CO	
	8.00 % CO2	83.50 % N2	

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	50.344 dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	4.001 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.074   Lower   Bws   value
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000   used.
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2-0.5%CO)) x 100 =		62.76
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)] =		29.62
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	28.76
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	74.39 ft/sec
Qs = vs x As x 60 .....	=	2,309,375 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,502,732 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	98.42 %

SOURCE TEST CALCULATIONS

Plant : Progress Energy, Crystal River, FL  
 Source/Unit : Unit No. 5  
 Date : May 22, 2006

RUN NO.: 3

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.88 in. H2O
METER TEMP, Tm =	102.58 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	296.9 F	STACK I.D. =	308.00 inch
Avg.Vel.Head, dP =	1.257 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	2.48 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	54.116 Cu.Ft.	STACK AREA, As =	517.403 Sq.Ft.
METER COFF., Y =	0.998	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.232 inch
COND.(Vlc) =	84.0 ml	NOZZLE DIA., An =	2.9E-04 Sq.Ft.
GAS ANALYSIS =	5.00 % O2	0.00 % CO	
	11.00 % CO2	84.00 % N2	

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460) .....	=	51.335 dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	3.954 scf
Bws = Vw(std) / (Vm(std) + Vw(std)) .....	=	0.072   Lower   Bws   value
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000   used.
%EA = (%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =		29.11
Md = (.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)] =		29.96
Ms = (Md x (1-Bws)) + (18.0 x Bws) .....	=	29.10
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	74.90 ft/sec
Qs = vs x As x 60 .....	=	2,325,169 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,512,780 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92) x 100 / [ Time x P(stack) x An x vs x 60] .....	=	99.69 %

Progress Energy, Crystal River, FL  
 Unit No. 5  
 May 22, 2006

Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%).	Particulate Matter	
				Conc. (gr/dscf)	Emission Rate (Lbs/Hr)
4	1,519,539	297	7.8	0.0016	20.82
5	1,518,273	296	8.2	0.0016	20.19
6	1,535,655	297	7.8	0.0012	16.07
Average	1,524,489	296	7.9	0.0015	19.03

GENERAL DATA

Plant :	Progress Energy, Crystal River, FL				
Source/Unit :	Unit No. 5				
Date :	May 22, 2006	Cp	0.840		
Stack dia. :	308.00 inch	OR :	Duct Length	0.00	inch
Oxygen Corr. :	0.0 percent		Duct Width	0.00	inch.
CO2 Corr. :	0.0 percent		Std. Temp.	68	F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U	f	Process Wt.
----------------------------	---	-------------

Hydrogen, wt% :	0.00	Run 1 :	0 Tons/hr
-----------------	------	---------	-----------

Carbon, wt% :	0.00	Run 2 :	0
---------------	------	---------	---

Sulfur, wt% :	0.00	Run 3 :	0
---------------	------	---------	---

Nitrogen, wt% :	0.00
-----------------	------

Oxygen, wt% :	0.00
---------------	------

Btu/lb :	0
----------	---

Type of Flow Meter :	(1=Meter Box 2=Mass Flow Meter)	1
----------------------	---------------------------------	---

F-Factor :	dscf/MMBtu;
------------	-------------

<u>FIELD DATA</u>	METHOD 5	RUN	RUN	RUN
		4	5	6

Meter Temp., Tm (F) .....	103	103	103
---------------------------	-----	-----	-----

Stack Temp., Ts (F) .....	297	296	297
---------------------------	-----	-----	-----

Sq.Rt. dP .....	1.13	1.13	1.14
-----------------	------	------	------

dH (in. H2O) .....	2.53	2.53	2.58
--------------------	------	------	------

Meter Vol.,Vm (ft <sup>3</sup> ) .....	55.020	54.555	54.615
--	--------	--------	--------

Vol. H2O, Vlc (ml) .....	94.0	98.0	93.0
--------------------------	------	------	------

Meter Y .....	0.998	0.998	0.998
---------------	-------	-------	-------

Bar. Press.,Pb (in.Hg.) .....	30.12	30.12	30.12
-------------------------------	-------	-------	-------

Static Press.,Ps (in.H2O) .....	-0.88	-0.88	-0.88
---------------------------------	-------	-------	-------

Test Time (min.) .....	60.0	60.0	60.0
------------------------	------	------	------

Nozzle Dia.,Dn (in.) .....	0.232	0.232	0.232
----------------------------	-------	-------	-------

Oxygen, O2 (%) .....	4.0	4.0	5.0
----------------------	-----	-----	-----

Carbon Dioxide, CO2 (%) .....	11.0	10.5	10.5
-------------------------------	------	------	------

Carbon Monoxide, CO (%) .....	0.0	0.0	0.0
-------------------------------	-----	-----	-----

Report Emission Criteria in ? l = lb/hr g = gr/dscf :	grams
---	-------

Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min:	T
--	---

Allowable Particulate Matter Concentration .....	0
--	---

<u>LABORATORY RESULTS</u>	RUN	RUN	RUN
	4	5	6
	grams	grams	grams

GRAVIMETRIC ANALYSIS METHOD 5 :	
---------------------------------	--

Front Half Wash (FWH) .....	0.00160	0.00100	0.00070
-----------------------------	---------	---------	---------

Filterable Sample (MF) .....	0.00380	0.00420	0.00340
------------------------------	---------	---------	---------

Condensible Sample (BHW) .....	0.00000	0.00000	0.00000
--------------------------------	---------	---------	---------

A. FIELD DATA SUMMARY

---

Plant: Progress Energy, Crystal River, FL  
 Source/Unit: Unit No. 5  
 Date: May 22, 2006

	RUN 4	RUN 5	RUN 6
Vlc = Vol water collected in train, ml	94.0	98.0	93.0
Vm = Sample gas vol, meter cond., acf	55.020	54.555	54.615
Y = Meter calibration factor	0.9980	0.9980	0.9980
Pbar = Barometric pressure, in. Hg	30.12	30.12	30.12
Pstatic = Stack static pressure, in. H2O	-0.88	-0.88	-0.88
dH = Avg meter pressure diff, in. H2O	2.53	2.53	2.58
Tm = Absolute meter temp., degrees R	563.4	563.0	562.7
Vm(std) = Sample gas vol, Std. cond., dscf	52.122	51.720	51.813
Bws = Water vapor in gas stream, fraction	0.078	0.082	0.078
MF = Moisture factor ( 1 - Bws)	0.922	0.918	0.922
CO2 = Carbon Dioxide, dry, volume %	11.00	10.50	10.50
O2 = Oxygen, dry, volume %	4.00	4.00	5.00
N2 = Nitrogen, dry volume %	85.00	85.50	84.50
Md = Molecular weight of stack gas, dry	29.92	29.84	29.88
Ms = Molecular weight of stack gas, wet	28.99	28.87	28.95
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	1.1320	1.1326	1.1429
Ts = Absolute stack temp., degrees R	756.7	755.8	756.7
A = Area of stack, ft2	517.40	517.40	517.40
Qstd = Volumetric flowrate, dscfm	1,519,539	1,518,273	1,535,655
An = Nozzle area, ft2	2.94E-04	2.94E-04	2.94E-04
t = Sample time, minutes	60.00	60.00	60.00
%I = Isokinetic variation, percent	100.76	100.07	99.12

B. PARTICULATE DATA SUMMARY

---

Plant: Progress Energy, Crystal River, FL  
Source/Unit: Unit No. 5  
Date: May 22, 2006

	RUN 4	RUN 5	RUN 6
Sample Weight (FHW + MF + BHW), mg .....	5.40	5.20	4.10
Meter Volume, standard cond., Vm(std) .....	52.122	51.720	51.813
Carbon Dioxide, percent .....	11.00	10.50	10.50
Oxygen, percent .....	4.00	4.00	5.00
Sample Concentration :			
gr/scf .....	0.0015	0.0014	0.0011
gr/dscf .....	0.0016	0.0016	0.0012
gr/dscf @ 0 % CO2 .....	0.0017	0.0018	0.0014
gr/dscf @ 0 % O2 .....	0.0020	0.0019	0.0016
ppm * MW (dry gas) .....	87.9	85.3	67.2
ppm * MW @ 0% CO2 .....	0.0	0.0	0.0
ppm * MW @ 0% O2 .....	108.7	105.5	88.3

EMISSION RATE CALCULATIONS

---

Plant : Progress Energy, Crystal River, FL  
 Source/Unit : Unit No. 5  
 Date: May 22, 2006  
 STANDARD TEMP. : 68 F

RUN NO.: 4

---

Front Half Wash (FWH)	0.00160	grams	Vm(std)	52.122	ft3
Mass Filter (MF)	0.00380	grams	Vw(std)	4.425	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,519,539	dscfm
Vm(std) SO2		dscf	Bws	0.078	
CO2 CORR. 0.0 %			CO2	11.00	%
O2 CORR.: 0.0 %			O2	4.00	%

---

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(\text{Tstd} + 460)/528] \dots \dots \dots \text{dscf/MMBtu}$$

FUEL USE

Use Rate (gal/ton) * Process Wt. (ton/hr) .....	gal/hr
Heat Input = (Process Weight (ton/hr) x Heating ....	MMBtu/hr
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6	
<u>TOTAL PARTICULATE</u>	

15.432 x (FWH + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0015 gr/scf
15.432 x (FWH + MF + BHW) / (Vm(std) .....)	0.0016 gr/dscf
gr/dscf x (12 / %CO2) .....	0.0017 @ 0% CO2
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] .....	0.0020 @ 0% O2
0.00857 x Qs(std) x gr/dscf .....	20.82 lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..	lb/MMBtu
Particulate (lb/hr) / Heat Input (MMBtu/hr) .....	lb/MMBtu
<u>TOTAL ACID MIST</u>	

[ 1.0811E-4 x (Vt - Vtb) x N x Vsol ] / Vol(alog) .	lb Acid Mist
[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ...	lb/hr
[Acid Mist (lb) / Vm std (ft^3)] x F-Factor .....	lb/MMBtu
<u>SULFUR DIOXIDE (SO2)</u>	

[ 7.061E-5 x (Vt - Vtb) x N x Vsol ] / Vol(alog)	lb SO2
[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ...	lb/hr
[SO2 (lb) / Vm std (ft^3)] x F .....	lb/MMBtu
[ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std)	ppm
ppm x 0.0 % Corr. / 11.0 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 4.0% O2 Stack)	ppm @ 0% O2
SO2 (lb/hr / Heat Input) .....	lb/MMBtu
<u>HYDROGEN CHLORIDE DATA SUMMARY</u>	

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)]..	ppm
ppm x 0.0 % Corr. / 11.0 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack)	ppm @ 0% O2
[ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )].....	lb/hr

EMISSION RATE CALCULATIONS

---

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

Date: May 22, 2006

RUN NO.:

5

STANDARD TEMP. : 68 F

---

Front Half Wash (FHW)	0.00100	grams	Vm(std)	51.720	ft3
Mass Filter (MF)	0.00420	grams	Vw(std)	4.613	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,518,273	dscfm
Vm(std) SO2		dscf	Bws	0.082	
CO2 CORR. 0.0 %			CO2	10.50	%
O2 CORR.: 0.0 %			O2	4.00	%

---

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -  
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] ..... dscf/MMBtu

FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
Heat Input = (Process Weight (ton/hr) x Heating .... MMBtu/hr  
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6

TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0014	gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std) .....	0.0016	gr/dscf
gr/dscf x (12 / %CO2) .....	0.0018	@ 0% CO2
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] .....	0.0019	@ 0% O2
0.00857 x Qs(std) x gr/dscf .....	20.19	lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..		lb/MMBtu
Particulate (lb/hr) / Heat Input (MMBtu/hr) .....		lb/MMBtu

TOTAL ACID MIST

[ 1.0811E-4 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog) .	lb Acid Mist
[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ...	lb/hr
[Acid Mist (lb) / Vm std (ft^3)] x F-Factor .....	lb/MMBtu

SULFUR DIOXIDE (SO2)

[ 7.061E-5 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog) .	lb SO2
[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ...	lb/hr
[SO2 (lb) / Vm std (ft^3)] x F .....	lb/MMBtu
[ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std)	ppm
ppm x 0.0 % Corr. / 11.0 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack)	ppm @ 0% O2
SO2 (lb/hr / Heat Input) .....	lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)]..	ppm
ppm x 0.0 % Corr. / 10.5 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.5% O2 Stack)	ppm @ 0% O2
[ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600' )].....	lb/hr

EMISSION RATE CALCULATIONS

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

Date: May 22, 2006

RUN NO.:

6

STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00070	grams	Vm(std)	51.813	ft3
Mass Filter (MF)	0.00340	grams	Vw(std)	4.378	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,535,655	dscfm
Vm(std) SO2		dscf	Bws	0.078	
CO2 CORR. 0.0 %			CO2	10.50	%
O2 CORR.: 0.0 %			O2	5.00	%

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -  
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] ..... dscf/MMBtu

FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
Heat Input = (Process Weight (ton/hr) x Heating ..... MMBtu/hr  
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6  
TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0011	gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std) .....	0.0012	gr/dscf
gr/dscf x (12 / %CO2) .....	0.0014	@ 0% CO2
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] .....	0.0016	@ 0% O2
0.00857 x Qs(std) x gr/dscf .....	16.07	lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..		lb/MMBtu
Particulate (lb/hr) / Heat Input (MMBtu/hr) .....		lb/MMBtu

TOTAL ACID MIST

[ 1.0811E-4 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog) .	lb Acid Mist
[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ...	lb/hr
[Acid Mist (lb) / Vm std (ft^3)] x F-Factor .....	lb/MMBtu

SULFUR DIOXIDE (SO2)

[ 7.061E-5 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog) .	lb SO2
[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ...	lb/hr
[SO2 (lb) / Vm std (ft^3)] x F .....	lb/MMBtu
[ Mass SO2 (lb) x .385 / 64E+6 (ft^3/lb)] / Vm (std)	ppm
ppm x 0.0 % Corr. / 11.0 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack)	ppm @ 0% O2
SO2 (lb/hr / Heat Input) .....	lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)]..	ppm
ppm x 0.0 % Corr. / 10.5 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.5% O2 Stack)	ppm @ 0% O2
[ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )].....	lb/hr

SOURCE TEST CALCULATIONS

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

RUN NO.:

4

Date: May 22, 2006

STD.TEMP, Tstd	=	68 F	STATIC PRESS., Ps	=	-0.88 in. H2O
METER TEMP, Tm	=	103.4167 F	PITOT COFF., Cp	=	0.840
STACK TEMP, Ts	=	296.7 F	STACK I.D.	=	308.00 inch
AVG. VEL. HEAD, dP	=	1.281 in. H2O	DUCT LENGTH	=	inch
METER ORIFICE, dH	=	2.53 in. H2O	DUCT WIDTH	=	inch
METER VOL., Vm	=	55.020 Cu.Ft.	STACK AREA, As	=	517.403 Sq.Ft.
METER COFF., Y	=	0.998	TEST TIME	=	60.00 min.
BAR. PRESS., Pb	=	30.12 in.Hg	NOZZLE DIA.	=	0.232 inch
COND.(Vlc)	=	94.0 ml	NOZZLE DIA., An	=	2.9E-04 Sq.Ft.
GAS ANALYSIS	=	4.00 % O2	0.00 % CO		
		11.00 % CO2	85.00 % N2		

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460) .....	=	52.122	dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	4.425	scf
Bws = Vw(std) / (Vm(std) + Vw(std)) .....	=	0.078	Lower   Bws
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000	value   used.
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2-0.5%CO)) x 100 =		21.69	
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)] =		29.92	
Ms = (Md x (1-Bws)) + (18.0 x Bws) .....	=	28.99	
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	75.76	ft/sec
Qs = vs x As x 60 .....	=	2,351,843	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,519,539	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	100.76	%

SOURCE TEST CALCULATIONS

Plant : Progress Energy, Crystal River, FL

Source/Unit : Unit No. 5

RUN NO. :

5

Date : May 22, 2006

STD. TEMP., Tstd =	68 F	STATIC PRESS., Ps =	-0.88 in. H2O
METER TEMP., Tm =	103.00 F	PITOT COFF., Cp =	0.840
STACK TEMP., Ts =	295.8 F	STACK I.D. =	308.00 inch
Avg. VEL. HEAD, dP =	1.283 in. H2O	DUCT LENGTH =	inch
METER ORIFICE, dH =	2.53 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	54.555 Cu.Ft.	STACK AREA, As =	517.403 Sq.Ft.
METER COFF., Y =	0.998	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.232 inch
COND. (Vlc) =	98.0 ml	NOZZLE DIA., An =	2.9E-04 Sq.Ft.
GAS ANALYSIS =	4.00 % O2 10.50 % CO2	0.00 % CO 85.50 % N2	

---

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460) .....	=	51.720	dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	4.613	scf
Bws = Vw(std) / (Vm(std) + Vw(std)) .....	=	0.082	Lower   Bws   value
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000	used.
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2-0.5%CO)) x 100 =		21.54	
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)] =		29.84	
Ms = (Md x (1-Bws)) + (18.0 x Bws) .....	=	28.87	
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	75.90	ft/sec
Qs = vs x As x 60 .....	=	2,356,341	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,518,273	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	100.07	%

SOURCE TEST CALCULATIONS

Plant : Progress Energy, Crystal River, FL  
 Source/Unit : Unit No. 5  
 Date : May 22, 2006

RUN NO.: 6

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.88 in. H2O
METER TEMP, Tm =	102.67 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	296.7 F	STACK I.D. =	308.00 inch
Avg.Vel. Head, dP =	1.306 in. H2O	DUCT LENGTH =	inch
METER ORIFICE, dH =	2.58 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	54.615 Cu.Ft.	STACK AREA, As =	517.403 Sq.Ft.
METER COFF., Y =	0.998	TEST TIME =	60.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.232 inch
COND.(Vlc) =	93.0 ml	NOZZLE DIA., An =	2.9E-04 Sq.Ft.
GAS ANALYSIS =	5.00 % O2	0.00 % CO	
	10.50 % CO2	84.50 % N2	

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460) .....	=	51.813	dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	4.378	scf
Bws = Vw(std) / (Vm(std) + Vw(std)) .....	=	0.078	Lower   Bws   value
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000	used.
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2-0.5%CO)) x 100 =		28.89	
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)] =		29.88	
Ms = (Md x (1-Bws)) + (18.0 x Bws) .....	=	28.95	
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06	in. Hg
vs = 85.49 x CP x (Sq.Rt.dp) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	76.53	ft/sec
Qs = vs x As x 60 .....	=	2,375,904	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,535,655	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92) x 100 / [ Time x P(stack) x An x vs x 60] .....	=	99.12	%

## Carbon Monoxide

EPA Protocol Gas Analyzer Calibration Data						
CO Concentration Instrument Range Setting ( 0 - 200 ppm CO )						
EPA Method 10						
Calibration Gas	Conc. (ppmv)	Run No.	Date/Time	Response through Train System Loop (ppmv)	Drift (% of Range)(1)	Accuracy Diff. from Actual (% of Range)(2)
Zero	0.0	R1-Pre	5/22/2006 11:14	-0.75		-0.38
Zero	0.0	R1-Post	5/22/2006 12:27	-0.88	-0.06	-0.44
CO	195.0	R1-Pre	5/22/2006 10:51	194.6		-0.21
CO	99.1	R1-Pre	5/22/2006 10:59	97.2		-0.97
CO	50.2	R1-Pre	5/22/2006 11:04	50.3		0.04
CO	50.2	R1-Post	5/22/2006 12:34	49.5	-0.38	-0.34
Zero	0.0	R2-Pre	5/22/2006 12:27	-0.88		-0.44
Zero	0.0	R2-Post	5/22/2006 13:51	-2.01	-0.56	-1.00
CO	50.2	R2-Pre	5/22/2006 11:04	49.5		-0.34
CO	50.2	R2-Post	5/22/2006 13:59	48.6	-0.44	-0.78
Zero	0.0	R3-Pre	5/22/2006 13:51	-2.01		-1.00
Zero	0.0	R3-Post	5/22/2006 15:16	-1.00	0.50	-0.50
CO	50.2	R3-Pre	5/22/2006 13:59	48.6		-0.78
CO	50.2	R3-Post	5/22/2006 15:23	49.1	0.25	-0.53
Zero	0.0	R4-Pre	5/22/2006 15:16	-1.00		0.00
Zero	0.0	R4-Post	5/22/2006 16:38	-1.50	-0.25	-0.75
CO	50.2	R4-Pre	5/22/2006 15:23	49.1		-0.53
CO	50.2	R4-Post	5/22/2006 16:46	49.3	0.06	-0.46
Zero	0.0	R5-Pre	5/22/2006 15:23	-1.50		-0.75
Zero	0.0	R5-Post	5/22/2006 18:01	-2.01	-0.25	-1.00
CO	50.2	R5-Pre	5/22/2006 15:23	49.3		-0.46
CO	50.2	R5-Post	5/22/2006 18:09	48.9	-0.19	-0.65
Zero	0.0	R6-Pre	5/22/2006 18:01	-2.01		-1.00
Zero	0.0	R6-Post	5/22/2006 19:25	0.13	1.07	0.06
CO	50.2	R6-Pre	5/22/2006 18:09	48.9		-0.65
CO	50.2	R6-Post	5/22/2006 19:30	51.0	1.07	0.41
Drift For The 6-Run Test Period						
Zero	0.0	R1-Pre*	5/22/2006 11:14	-0.75		-0.38
Zero	0.0	R6-Post	5/22/2006 19:25	0.13	0.44	0.06
CO	50.2	R1-Pre*	5/22/2006 11:04	50.3		0.04
CO	50.2	R6-Post	5/22/2006 19:30	51.0	0.38	0.41

#### Method 10 Performance Specification

##### Section 6.1 Span = 1.5 x Emission Standard

Cal. Gas ppm	% of Range
195.0	97.50
99.1	49.55
50.2	25.10

(1) Addenda A, Maximum 10 % of Range per 8 Hours

(2) Addenda A, Maximum 2% Of Range

##### Instrument Range Setting ( 0 - 1200 ppm CO )

##### Linearity ; Method 10, Addenda, B 13

	Response	Actual
zero	-0.75	0.0
Span	194.6	195.0
slope	1.002	=m
y-int	-0.752	=b
R^2	1.000	
	certified conc.	=x
	predicted conc.	=Y

y=m(x)+b		
49.53	predicted mid	pre-R1
98.5	predicted low	pre-R1
Mid gas Differences M10, Addenda A		
-0.37	mid% dif	pre-R1
0.68	low %dif	pre-R1

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials

Date	Time	CO ppmv
5/22/2006	10:30	3.0
5/22/2006	10:31	3.3
5/22/2006	10:32	2.8
5/22/2006	10:33	3.0
5/22/2006	10:34	3.8
5/22/2006	10:35	2.8
5/22/2006	10:36	3.5
5/22/2006	10:37	4.3
5/22/2006	10:38	3.0
5/22/2006	10:39	1.0
5/22/2006	10:40	1.0 <<Zero air
5/22/2006	10:41	1.0 <average
5/22/2006	10:42	1.0
5/22/2006	10:43	1.8
5/22/2006	10:44	64.9
5/22/2006	10:45	139.4
5/22/2006	10:46	167.5
5/22/2006	10:47	182.5
5/22/2006	10:48	189.8
5/22/2006	10:49	194.3
5/22/2006	10:50	193.8
5/22/2006	10:51	194.8 <<195 ppm CO
5/22/2006	10:52	194.3 194.6 <average
5/22/2006	10:53	184.6
5/22/2006	10:54	135.4
5/22/2006	10:55	108.3
5/22/2006	10:56	100.8
5/22/2006	10:57	98.0
5/22/2006	10:58	97.5
5/22/2006	10:59	97.3 <<99.1ppm CO
5/22/2006	11:00	97.0 97.2 <average
5/22/2006	11:01	93.8
5/22/2006	11:02	69.5
5/22/2006	11:03	54.4
5/22/2006	11:04	50.4 <<50.2 ppm CO
5/22/2006	11:05	50.2 50.3 <average
5/22/2006	11:06	49.6
5/22/2006	11:07	48.9
5/22/2006	11:08	40.4
5/22/2006	11:09	8.5
5/22/2006	11:10	1.0
5/22/2006	11:11	0.0
5/22/2006	11:12	-0.8
5/22/2006	11:13	-1.0
5/22/2006	11:14	-0.8 <<Zero air
5/22/2006	11:15	-0.8 -0.8 <average
5/22/2006	11:16	6.0

5/22/2006 11:17	15.3
5/22/2006 11:18	31.1
5/22/2006 11:19	40.4
5/22/2006 11:20	31.8
5/22/2006 11:21	16.6
5/22/2006 11:22	13.3
5/22/2006 11:23	17.1
5/22/2006 11:24	15.3
5/22/2006 11:25	9.3
5/22/2006 11:26	29.6
5/22/2006 11:27	20.1
5/22/2006 11:28	8.8
5/22/2006 11:29	7.3
5/22/2006 11:30	36.4
5/22/2006 11:31	32.3
5/22/2006 11:32	29.8
5/22/2006 11:33	26.1
5/22/2006 11:34	27.6
5/22/2006 11:35	34.1
5/22/2006 11:36	39.9
5/22/2006 11:37	29.3
5/22/2006 11:38	20.6
5/22/2006 11:39	13.3
5/22/2006 11:40	14.8
5/22/2006 11:41	31.3
5/22/2006 11:42	26.8
5/22/2006 11:43	17.3
5/22/2006 11:44	20.6
5/22/2006 11:45	16.3
5/22/2006 11:46	19.3
5/22/2006 11:47	28.8
5/22/2006 11:48	42.1
5/22/2006 11:49	31.1
5/22/2006 11:50	16.3
5/22/2006 11:51	23.3
5/22/2006 11:52	38.6
5/22/2006 11:53	29.3
5/22/2006 11:54	17.3
5/22/2006 11:55	17.1
5/22/2006 11:56	20.8
5/22/2006 11:57	30.8
5/22/2006 11:58	25.6
5/22/2006 11:59	35.4
5/22/2006 12:00	50.9
5/22/2006 12:01	84.0
5/22/2006 12:02	74.2
5/22/2006 12:03	83.8
5/22/2006 12:04	62.7
5/22/2006 12:05	46.6
5/22/2006 12:06	33.9
5/22/2006 12:07	34.9
5/22/2006 12:08	37.1

<< Start Run 1

5/22/2006 12:09	29.8
5/22/2006 12:10	24.3
5/22/2006 12:11	14.8
5/22/2006 12:12	14.0
5/22/2006 12:13	14.5
5/22/2006 12:14	11.3
5/22/2006 12:15	22.6
5/22/2006 12:16	19.1
5/22/2006 12:17	28.8
5/22/2006 12:18	32.3
5/22/2006 12:19	33.1
5/22/2006 12:20	35.4
5/22/2006 12:21	42.1
5/22/2006 12:22	23.8
5/22/2006 12:23	5.8
5/22/2006 12:24	1.5
5/22/2006 12:25	-0.3
5/22/2006 12:26	-1.0
5/22/2006 12:27	-1.3
5/22/2006 12:28	-0.5
5/22/2006 12:29	22.3
5/22/2006 12:30	37.9
5/22/2006 12:31	44.1
5/22/2006 12:32	48.9
5/22/2006 12:33	48.1
5/22/2006 12:34	49.4
5/22/2006 12:35	49.6
5/22/2006 12:36	49.4
5/22/2006 12:37	49.9

Run 1 CO ppm	
--------------	--

28.8	Average
------	---------

<< End Run 1

<<Zero air	
------------	--

-0.9	<average
------	----------

<<50.2 ppm CO	
---------------	--

49.5	<average
------	----------

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials

Date	Time	CO ppmv
5/22/2006	12:45	85.0 << Start Run 2
5/22/2006	12:46	90.8
5/22/2006	12:47	82.5
5/22/2006	12:48	72.7
5/22/2006	12:49	70.2
5/22/2006	12:50	95.3
5/22/2006	12:51	113.6
5/22/2006	12:52	99.5
5/22/2006	12:53	82.7
5/22/2006	12:54	64.2
5/22/2006	12:55	74.2
5/22/2006	12:56	47.4
5/22/2006	12:57	22.1
5/22/2006	12:58	12.8
5/22/2006	12:59	14.0
5/22/2006	13:00	24.1
5/22/2006	13:01	22.8
5/22/2006	13:02	70.5
5/22/2006	13:03	97.0
5/22/2006	13:04	66.2
5/22/2006	13:05	60.2
5/22/2006	13:06	66.4
5/22/2006	13:07	77.2
5/22/2006	13:08	82.0
5/22/2006	13:09	63.4
5/22/2006	13:10	50.4
5/22/2006	13:11	37.1
5/22/2006	13:12	53.7
5/22/2006	13:13	50.4
5/22/2006	13:14	39.9
5/22/2006	13:15	64.9
5/22/2006	13:16	77.7
5/22/2006	13:17	86.0
5/22/2006	13:18	78.7
5/22/2006	13:19	74.0
5/22/2006	13:20	48.9
5/22/2006	13:21	34.4
5/22/2006	13:22	31.3
5/22/2006	13:23	31.6
5/22/2006	13:24	36.6
5/22/2006	13:25	39.4
5/22/2006	13:26	42.1
5/22/2006	13:27	27.3
5/22/2006	13:28	13.5
5/22/2006	13:29	10.8
5/22/2006	13:30	6.8
5/22/2006	13:31	53.2

5/22/2006 13:32	52.9
5/22/2006 13:33	84.5
5/22/2006 13:34	97.8
5/22/2006 13:35	57.7
5/22/2006 13:36	40.1
5/22/2006 13:37	73.7
5/22/2006 13:38	48.6
5/22/2006 13:39	29.8
5/22/2006 13:40	60.7
5/22/2006 13:41	57.2
5/22/2006 13:42	37.4
5/22/2006 13:43	37.6
5/22/2006 13:44	55.2
5/22/2006 13:45	88.8
<u>&lt;&lt; End Run 2</u>	
	Run 2 CO ppm
	56.8      Average
5/22/2006 13:46	54.7
5/22/2006 13:47	15.3
5/22/2006 13:48	5.0
5/22/2006 13:49	0.0
5/22/2006 13:50	-1.0
5/22/2006 13:51	-1.8
	<<Zero air
5/22/2006 13:52	-2.3
	-2.0    <average
5/22/2006 13:53	7.3
5/22/2006 13:54	32.3
5/22/2006 13:55	40.6
5/22/2006 13:56	44.4
5/22/2006 13:57	46.4
5/22/2006 13:58	48.1
5/22/2006 13:59	48.9
	<<50.2 ppm CO
5/22/2006 14:00	48.4
	48.6    <average

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials

Date	Time	CO ppmv
5/22/2006	14:09	12.5      << Start Run 3
5/22/2006	14:10	16.3
5/22/2006	14:11	20.1
5/22/2006	14:12	12.0
5/22/2006	14:13	9.0
5/22/2006	14:14	8.8 )
5/22/2006	14:15	16.3
5/22/2006	14:16	17.3
5/22/2006	14:17	57.2
5/22/2006	14:18	35.6
5/22/2006	14:19	20.6
5/22/2006	14:20	28.6
5/22/2006	14:21	37.9
5/22/2006	14:22	31.8
5/22/2006	14:23	27.1
5/22/2006	14:24	30.8
5/22/2006	14:25	34.9
5/22/2006	14:26	29.1
5/22/2006	14:27	35.9
5/22/2006	14:28	52.4
5/22/2006	14:29	39.1
5/22/2006	14:30	29.6
5/22/2006	14:31	24.3
5/22/2006	14:32	17.6
5/22/2006	14:33	29.6
5/22/2006	14:34	34.9
5/22/2006	14:35	21.8
5/22/2006	14:36	45.6
5/22/2006	14:37	53.9
5/22/2006	14:38	58.7
5/22/2006	14:39	36.1
5/22/2006	14:40	32.6
5/22/2006	14:41	33.4
5/22/2006	14:42	18.8
5/22/2006	14:43	8.0
5/22/2006	14:44	13.5
5/22/2006	14:45	25.8
5/22/2006	14:46	30.6
5/22/2006	14:47	24.8
5/22/2006	14:48	24.1
5/22/2006	14:49	38.6
5/22/2006	14:50	36.9
5/22/2006	14:51	23.6
5/22/2006	14:52	29.8
5/22/2006	14:53	30.1
5/22/2006	14:54	32.1
5/22/2006	14:55	46.4

5/22/2006 14:56	48.6
5/22/2006 14:57	36.1
5/22/2006 14:58	35.6
5/22/2006 14:59	28.6
5/22/2006 15:00	31.6
5/22/2006 15:01	31.6
5/22/2006 15:02	42.1
5/22/2006 15:03	46.1
5/22/2006 15:04	49.6
5/22/2006 15:05	51.4
5/22/2006 15:06	57.7
5/22/2006 15:07	36.6
5/22/2006 15:08	25.3
5/22/2006 15:09	25.1
5/22/2006 15:10	54.9
5/22/2006 15:11	55.4
5/22/2006 15:12	17.6
5/22/2006 15:13	3.5
5/22/2006 15:14	0.8
5/22/2006 15:15	-0.5
5/22/2006 15:16	-1.3
5/22/2006 15:17	-0.8
5/22/2006 15:18	12.3
5/22/2006 15:19	38.9
5/22/2006 15:20	44.9
5/22/2006 15:21	46.4
5/22/2006 15:22	47.6
5/22/2006 15:23	48.9
5/22/2006 15:24	49.4
5/22/2006 15:25	48.6

Run 3 CO ppm

31.5 Average

&lt;&lt; End Run 3

-1.3	<<Zero air
-0.8	-1.0 <average

48.9	<<50.2 ppm CO
49.4	49.1 <average

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials

Date	Time	CO ppmv
5/22/2006	15:34	43.1
5/22/2006	15:35	55.2
5/22/2006	15:36	67.0
5/22/2006	15:37	83.8
5/22/2006	15:38	81.0
5/22/2006	15:39	83.5
5/22/2006	15:40	77.7
5/22/2006	15:41	45.4
5/22/2006	15:42	16.8
5/22/2006	15:43	8.5
5/22/2006	15:44	2.5
5/22/2006	15:45	-0.8
5/22/2006	15:46	0.5
5/22/2006	15:47	5.3
5/22/2006	15:48	6.3
5/22/2006	15:49	19.3
5/22/2006	15:50	27.8
5/22/2006	15:51	20.8
5/22/2006	15:52	10.0
5/22/2006	15:53	6.8
5/22/2006	15:54	9.3
5/22/2006	15:55	9.8
5/22/2006	15:56	4.5
5/22/2006	15:57	7.3
5/22/2006	15:58	13.8
5/22/2006	15:59	12.0
5/22/2006	16:00	16.6
5/22/2006	16:01	19.8
5/22/2006	16:02	29.3
5/22/2006	16:03	25.8
5/22/2006	16:04	18.1
5/22/2006	16:05	33.9
5/22/2006	16:06	38.4
5/22/2006	16:07	58.4
5/22/2006	16:08	45.6
5/22/2006	16:09	37.6
5/22/2006	16:10	39.4
5/22/2006	16:11	59.7
5/22/2006	16:12	42.9
5/22/2006	16:13	35.9
5/22/2006	16:14	19.6
5/22/2006	16:15	21.8
5/22/2006	16:16	33.4
5/22/2006	16:17	59.4
5/22/2006	16:18	61.4
5/22/2006	16:19	49.9
5/22/2006	16:20	59.7

<< Start Run 4

5/22/2006 16:21	73.0	
5/22/2006 16:22	70.2	
5/22/2006 16:23	54.9	
5/22/2006 16:24	23.6	
5/22/2006 16:25	12.5	
5/22/2006 16:26	9.0	
5/22/2006 16:27	9.0	
5/22/2006 16:28	10.8	
5/22/2006 16:29	14.3	
5/22/2006 16:30	29.6	
5/22/2006 16:31	26.1	
5/22/2006 16:32	25.1	
5/22/2006 16:33	24.6	
5/22/2006 16:34	20.8	
	Run 4 CO ppm	
	31.6	Average
5/22/2006 16:35	16.3	
5/22/2006 16:36	18.8	
5/22/2006 16:37	5.0	
5/22/2006 16:38	-0.3	
	<<Zero air	
5/22/2006 16:39	-2.8	
	-1.5	<average
5/22/2006 16:40	-0.3	
5/22/2006 16:41	-0.5	
5/22/2006 16:42	6.0	
5/22/2006 16:43	33.9	
5/22/2006 16:44	44.6	
5/22/2006 16:45	47.6	
5/22/2006 16:46	49.1	
	<<50.2 ppm CO	
5/22/2006 16:47	49.4	
	49.3	<average
5/22/2006 16:48	49.4	

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials

Date	Time	CO ppmv
5/22/2006	16:57	29.3 << Start Run 5
5/22/2006	16:58	21.3
5/22/2006	16:59	13.3
5/22/2006	17:00	11.0
5/22/2006	17:01	13.5
5/22/2006	17:02	14.3
5/22/2006	17:03	19.6
5/22/2006	17:04	39.1
5/22/2006	17:05	40.9
5/22/2006	17:06	47.4
5/22/2006	17:07	34.1
5/22/2006	17:08	15.0
5/22/2006	17:09	17.3
5/22/2006	17:10	21.6
5/22/2006	17:11	17.3
5/22/2006	17:12	13.8
5/22/2006	17:13	13.5
5/22/2006	17:14	19.6
5/22/2006	17:15	24.8
5/22/2006	17:16	34.9
5/22/2006	17:17	22.6
5/22/2006	17:18	29.6
5/22/2006	17:19	37.6
5/22/2006	17:20	31.1
5/22/2006	17:21	18.3
5/22/2006	17:22	9.0
5/22/2006	17:23	7.8
5/22/2006	17:24	16.6
5/22/2006	17:25	24.1
5/22/2006	17:26	20.8
5/22/2006	17:27	13.0
5/22/2006	17:28	23.6
5/22/2006	17:29	11.3
5/22/2006	17:30	11.5
5/22/2006	17:31	13.0
5/22/2006	17:32	20.6
5/22/2006	17:33	21.3
5/22/2006	17:34	63.7
5/22/2006	17:35	34.4
5/22/2006	17:36	19.1
5/22/2006	17:37	19.6
5/22/2006	17:38	12.3
5/22/2006	17:39	17.3
5/22/2006	17:40	19.3
5/22/2006	17:41	18.8
5/22/2006	17:42	10.5
5/22/2006	17:43	25.1

5/22/2006 17:44	50.4
5/22/2006 17:45	55.7
5/22/2006 17:46	46.6
5/22/2006 17:47	34.9
5/22/2006 17:48	28.6
5/22/2006 17:49	20.3
5/22/2006 17:50	16.6
5/22/2006 17:51	25.3
5/22/2006 17:52	31.8
5/22/2006 17:53	43.4
5/22/2006 17:54	25.1
5/22/2006 17:55	12.5
5/22/2006 17:56	18.1
5/22/2006 17:57	27.8
<hr/>	
5/22/2006 17:58	14.5
5/22/2006 17:59	12.5
5/22/2006 18:00	3.5
5/22/2006 18:01	-2.0
5/22/2006 18:02	-2.0
<hr/>	
5/22/2006 18:03	-1.5
5/22/2006 18:04	-0.8
5/22/2006 18:05	25.1
5/22/2006 18:06	42.6
5/22/2006 18:07	46.9
5/22/2006 18:08	47.1
5/22/2006 18:09	49.4
5/22/2006 18:10	48.4
5/22/2006 18:11	50.2
5/22/2006 18:12	48.4

Run 5 CO ppm

24.1 Average

&lt;&lt;Zero air

-2.0 &lt;average

&lt;&lt;50.2 ppm CO

48.9 &lt;average

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials

Date	Time	CO ppmv
5/22/2006	18:18	11.8
5/22/2006	18:19	11.3
5/22/2006	18:20	19.3
5/22/2006	18:21	18.3
5/22/2006	18:22	12.3
5/22/2006	18:23	13.0
5/22/2006	18:24	7.0
5/22/2006	18:25	7.0
5/22/2006	18:26	9.0
5/22/2006	18:27	6.8
5/22/2006	18:28	15.0
5/22/2006	18:29	22.3
5/22/2006	18:30	15.8
5/22/2006	18:31	12.3
5/22/2006	18:32	11.8
5/22/2006	18:33	17.1
5/22/2006	18:34	21.3
5/22/2006	18:35	12.3
5/22/2006	18:36	10.5
5/22/2006	18:37	9.3
5/22/2006	18:38	11.5
5/22/2006	18:39	16.0
5/22/2006	18:40	31.6
5/22/2006	18:41	26.6
5/22/2006	18:42	35.4
5/22/2006	18:43	51.4
5/22/2006	18:44	38.9
5/22/2006	18:45	35.6
5/22/2006	18:46	22.8
5/22/2006	18:47	35.6
5/22/2006	18:48	22.1
5/22/2006	18:49	10.3
5/22/2006	18:50	9.8
5/22/2006	18:51	5.5
5/22/2006	18:52	3.5
5/22/2006	18:53	2.5
5/22/2006	18:54	3.8
5/22/2006	18:55	8.0
5/22/2006	18:56	27.8
5/22/2006	18:57	26.1
5/22/2006	18:58	21.3
5/22/2006	18:59	21.3
5/22/2006	19:00	20.3
5/22/2006	19:01	20.1
5/22/2006	19:02	30.6
5/22/2006	19:03	19.8
5/22/2006	19:04	12.0

5/22/2006 19:05	7.5
5/22/2006 19:06	4.3
5/22/2006 19:07	19.1
5/22/2006 19:08	45.9
5/22/2006 19:09	32.3
5/22/2006 19:10	20.1
5/22/2006 19:11	19.8
5/22/2006 19:12	17.3
5/22/2006 19:13	12.0
5/22/2006 19:14	17.6
5/22/2006 19:15	13.0
5/22/2006 19:16	14.0
5/22/2006 19:17	20.3
5/22/2006 19:18	16.6
<u>&lt;&lt; End Run 6</u>	
5/22/2006 19:19	21.6
5/22/2006 19:20	15.8
5/22/2006 19:21	5.8
5/22/2006 19:22	2.3
5/22/2006 19:23	0.3
5/22/2006 19:24	0.8
5/22/2006 19:25	0.0
<<Zero air	
5/22/2006 19:26	0.3
0.1     <average	
5/22/2006 19:27	16.8
5/22/2006 19:28	41.6
5/22/2006 19:29	48.4
5/22/2006 19:30	49.9
<<50.2 ppm CO	
5/22/2006 19:31	52.2
51.0     <average	
5/22/2006 19:32	51.4

Field and Laboratory Data Sheets



## Particulate Matter

# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Units 5

Control Type: E.A.P.

Sample Type: 5-226 Part

Date: 5-22-06

Run No.: 1

Time Start: 1118

Time End: 1230

Sample Time: 5

min/point 60 Total Mins.

Dry Bulb: 80 °F

Wet Bulb: 70.06 °F

VP@DP:

Bar. Pres: 30.12 "Hg

Stack Pres: 30.06 "Hg

Ps:

-0.88

"H<sub>2</sub>O

Moisture: 8 %

FDA: Gas Density Factor:

Temp: 80 °F

Wind Direction: —

Wind Speed: —

Weather: Cloudy

Thermocouple Readout:

KAK-8

Sample Box No: KAK-8

Meter Box No.:

KAK-8

Meter Y: 0.998 @

Delta H: 1.69

Pitot Corr.:

0.84

Nozzle Diameter: 0.232 inches

Probe Length:

9.21 feet

Probe Heater Setting: 320°F

Nomograph Cf:

1.89

Stack Dimensions:

308

inches


Stack Area: 517.4

ft<sup>2</sup>

Effective Stack Area: 517.4

ft<sup>2</sup>

Stack Height: ft



Material Processing Rate:

967,230

ft<sup>3</sup>

Final Gas Meter Reading:

916,902

ft<sup>3</sup>

Initial Gas Meter Reading:

50,328

ft<sup>3</sup>

Total Metered Gas Volume:

65

mL

Condensate Gain in Impingers:

10

g

Weight Gain in Silica Gel:

15

mL

Total Moisture Gain:

39

mL

Silica Gel Container No.:

1

Filter Number:

Leak Check - Meter Box:

Initial 0.003 cfm @

15

inches Hg

Final 0.001 cfm @

16

inches Hg

Leak Check - Pitot Tubes:

Impact 3 "H<sub>2</sub>O for 15 sec. Stable, Leak

Static 3 "H<sub>2</sub>O for 15 sec. Stable, Leak

Umbilical: KAK-100

Thermocouple

Probe No. KAK-10

Test Conducted By: R Paul - Al West

O<sub>2</sub>: 13.0 % CO<sub>2</sub>: 0.5 %

Pitot Tube: KAK-551

Stack Test Observers:

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			16.9	1.4	2.65	2.65	295	(	68	86	6	
2			21.3	1.1	2.08	2.08	294		62	86	5	
3			25.4	1.0	1.89	1.89	295		64	86	5	
2-1			29.3	1.3	2.46	2.46	293		67	88	6	
2			33.5	1.3	2.46	2.46	294		60	88	6	
3			37.9	0.97	1.83	1.83	294		61	90	5	
3-1			41.8	1.2	2.27	2.27	295		65	92	6	
2			46.0	1.2	2.27	2.27	295	)	58	93	6	



# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Cenit 5

Control Type: E&P

Sample Type: Part

Date: 5-22-06

Run No.: 2

Time Start: 1245

Time End: 1352

Sample Time: 5

min/point 60 Total Mins.

Dry Bulb: °F

Wet Bulb: °F VP@DP:

Bar. Pres: 30.12 "Hg

Stack Pres: 3006 Ig Ps: -0.88 "H<sub>2</sub>O

Moisture: 8 %

FDA: Gas Density Factor:

Temp: 85 °F

Wind Direction: — Wind Speed: —

Weather: cloudy

Thermocouple Readout: KAK-8

Sample Box No. KA8

Meter Box No.: KA8

Meter Y: 0.998 @ Delta H: 1.69

Pitot Corr.: 0.84

Nozzle Diameter: 0.232 inches

Probe Length: 9.1 feet

Probe Heater Setting: 320°

Nomograph Cf: 1.89

Stack Dimensions:

308 inches

Stack Area:

517.4 ft<sup>2</sup>

Effective Stack Area:

517.4 ft<sup>2</sup>

Stack Height:

ft

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			67.5	1.2	2.27	2.27	293	72	98	6		
2			71.7	1.3	2.46	2.46	295	68	98	6		
3			76.2	1.3	2.46	2.46	295	66	98	6		
2-1			80.5	1.3	2.46	2.46	295	69	99	6		
2			84.9	1.3	2.46	2.46	296	66	99	6		
3			89.4	0.97	1.83	1.83	295	64	99	6		
3-1			93.3	1.2	2.36	2.36	294	65	99	6		
2			97.7	1.3	2.56	2.56	296	62	100	7		

CF  
1.97

Stack Dimensions	Material Processing Rate:
	1020,300 ft <sup>3</sup>
	Initial Gas Meter Reading:
	967,500 ft <sup>3</sup>
	Total Metered Gas Volume:
	52900 ft <sup>3</sup>
	Condensate Gain in Impingers:
	74 mL
	Weight Gain in Silica Gel:
	11 g
	Total Moisture Gain:
	85 mL
	Silica Gel Container No.:
	25
	Filter Number:
	2

Leak Check - Meter Box:  
 Initial 0.004 cfm @ 19 inches Hg  
 Final 0.003 cfm @ 19 inches Hg

Leak Check - Pitot Tubes:  
 Impact 3 "H<sub>2</sub>O for 15 sec: Stable, Leak  
 Static 3 "H<sub>2</sub>O for 15 sec Stable, Leak

Umbilical: KAK-100  
 Thermocouple  
 Probe No. KAK-10  
 Pitot Tube: KASSI  
 Test Conducted By: R Paul-A-West  
 O<sub>2</sub>: 8.5 % CO<sub>2</sub>: 8.6 %  
 Stack Test Observers:





# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Unit 5

Control Type: E&P

Sample Type: Part

Date: 5-22-06

Run No.: 3

Time Start: 1409

Time End: 1517

Sample Time: 5

min/point 60 Total Mins.

Dry Bulb: °F Wet Bulb: °F VP@DP:

Bar. Pres: 30.12 "Hg Stack Pres: 30.06 "Hg Ps: -0.88 "H<sub>2</sub>O

Moisture: 7 % FDA: Gas Density Factor:

Temp: 88 °F Wind Direction: — Wind Speed: —

Weather: cloudy Thermocouple Readout: KAK-8

Sample Box No. KA-8 Meter Box No.:

Meter Y: 0.998 @ Delta H: 1.69 Pitot Corr.: 0.84

Nozzle Diameter: 0.232 inches Probe Length: 9.12 feet

Probe Heater Setting: 3.20 Nomograph Cf: 1.97

Stack Dimensions: 30.8 inches

Stack Area: 517.4 ft<sup>2</sup>

Effective Stack Area: 517.4 ft<sup>2</sup>

Stack Height: ft

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			20.5	1.4	2.76	2.76	298	(	72	102	6	
2			25.2	1.3	2.56	2.56	297		68	103	6	
3			30.0	1.1	2.17	2.17	297		66	102	6	
2-1			34.3	1.3	2.56	2.56	296		69	102	6	
2			38.8	1.3	2.56	2.56	297		65	102	6	
3			43.2	1.2	2.36	2.36	297		66	103	6	
3-1			47.6	1.3	2.56	2.56	293		66	103	6	
2			52.2	1.3	2.56	2.56	297		64	103	6	

Material Processing Rate:

Final Gas Meter Reading: 74,601.6 ft<sup>3</sup>

Initial Gas Meter Reading: 20,500 ft<sup>3</sup>

Total Metered Gas Volume: 54,116 ft<sup>3</sup>

Condensate Gain in Impingers: 72 mL

Weight Gain in Silica Gel: 12 g

Total Moisture Gain: 84 mL

Silica Gel Container No.: 217

Filter Number: 3

## Leak Check - Meter Box:

Initial 0.006 cfm @ 10 inches Hg

Final: 0.004 cfm @ 10 inches Hg

## Leak Check - Pitot Tubes:

Impact 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Static 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Test Conducted By: R Paul

O<sub>2</sub>: 5.0 % CO<sub>2</sub>: 11.0 %

Stack Test Observers:





# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: 11 net 5

Control Type: E&P

Sample Type: Part

Date: 5-22-06

Run No.: 4

Time Start: 1534

Time End: 1642

Sample Time: 5

min/point 60 Total Mins.

Dry Bulb: °F Wet Bulb: °F VP@DP:

Bar. Pres: 30.12 "Hg Stack Pres: 3006 "Hg Ps: 0.88 "H<sub>2</sub>O

Moisture: 7 % FDA: Gas Density Factor:

Temp: 90 °F Wind Direction: — Wind Speed: —

Weather: cloudy Thermocouple Readout: KAK-8

Sample Box No.: KA-8 Meter Box No.: KA-8

Meter Y: 0.998 @ Delta H: KA-8 Pitot Corr.: 0.84

Nozzle Diameter: 0.232 inches Probe Length: 9.11 feet

Probe Heater Setting: 320 ° Nomograph Cf: 1.97

Stack Dimensions: 30.8 inches

Stack Area: 517.4 ft<sup>2</sup>

Effective Stack Area: 517.4 ft<sup>2</sup>

Stack Height: ft

Material Processing Rate:

Final Gas Meter Reading: 129,920 ft<sup>3</sup>

Initial Gas Meter Reading: 74,900 ft<sup>3</sup>

Total Metered Gas Volume: 55,020 ft<sup>3</sup>

Condensate Gain in Impingers: 84 mL

Weight Gain in Silica Gel: 10 g

Total Moisture Gain: 94 mL

Silica Gel Container No.: 37

Filter Number: 4

**Leak Check - Meter Box:**

Initial 0.008 cfm @ 10 inches Hg

Final 0.004 cfm @ 9 inches Hg

**Leak Check - Pitot Tubes:**

Impact 3 "H<sub>2</sub>O for 15 sec Stable, Leak

Static 3 "H<sub>2</sub>O for 15 sec Stable, Leak

Umbilical: KAK-100

Thermocouple Test Conducted By: R Paul A West

Probe No. XAK-10 O<sub>2</sub>: 4.0 % CO<sub>2</sub>: 11.0 %

Pitot Tube: XASSI Stack Test Observers:

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			74.9	1.3	2.56	2.56	299	(	104	104	7	
2			79.5	1.3	2.56	2.56	298	102	104	104	7	
3			84.1	1.2	2.36	2.36	296	102	104	104	7	
2-1			88.6	1.4	2.76	2.76	297	103	103	103	8	
2			93.3	1.3	2.56	2.56	298	58	103	103	7	
3			98.0	1.1	2.17	2.17	297	58	103	103	7	
3-1			102.3	1.4	2.76	2.76	295	60	103	103	8	
2			71.1	1.4	2.76	2.76	298	58	103	103	8	



**KOOGLER & ASSOCIATES, INC.**  
*ENVIRONMENTAL SERVICES*

# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Cn175

Control Type: E&P

Sample Type: Part

Date: 5-22-06

Run No.: 5

Time Start: 1657

Time End: 1805

Sample Time: 5

min/point 60 Total Mins.

Dry Bulb: °F

Wet Bulb: °F

VP@DP:

Bar. Pres: 30.12 "Hg

Stack Pres: 30.00 "Hg

Ps: 2.88

"H<sub>2</sub>O

Moisture: 7

% FDA:

Gas Density Factor:

Temp: 85

°F Wind Direction: —

Wind Speed: —

Weather: PC

Thermocouple Readout:

KAH-8

Sample Box No.: KAH-8

Meter Box No.:

KAH-8

Meter Y: 0.998

@ Delta H: 1.69

Pitot Corr.: 0.84

Nozzle Diameter: 0.232 inches

Probe Length:

9.11

feet

Probe Heater Setting: 320°

Nomograph Cf:

1.97

Stack Dimensions:

308

inches

Stack Area: 517.4

ft<sup>2</sup>

Effective Stack Area: 517.4

ft<sup>2</sup>

Stack Height:

ft

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1			30.1	1.3	2.56	2.56	297		66	103	6	
2			35.0	1.3	2.56	2.56	297		59	103	6	
3			39.5	1.3	2.56	2.56	298		59	103	6	
2-1			44.1	1.3	2.56	2.56	292		62	103	6	
2			48.6	1.3	2.56	2.56	298		58	103	6	
3			53.3	1.3	2.56	2.56	295		57	103	6	
3-1			57.7	1.3	2.56	2.56	292		62	103	6	
2			62.2	1.3	2.56	2.56	297		56	103	6	







## SAMPLING RATE CALCULATIONS

Date:

5-22-06

Plant Name/Location:

Progress Energy  
Crystal River

Source:

Unit 5

1) Calculate the optimum Cf:

$$\Delta H @ / \Delta P_{avg} = Cf$$

$\Delta H$	$/ \Delta P_{avg}$	$= Cf$

2) Calculate the optimum nozzle size:

Record Values		
R1	R2	R3
90	104	
0.08	0.07	
28.1	28.7	
300		
1.69		

Tm = Meter Temperature ( °F ) (Add 5 °F for initial temp.)

Bw = Moisture Fraction

Ms = Wet Molecular Weight of Stack Gas (from Table)

Ts = Stack Temperature ( °F )

$\Delta H@$  = Meter Box Constant (box front)

$\Delta P$  = Average Pitot Reading (Inches H2O)

Dn = Nozzle Diameter (Inches) measured

Moisture Fraction	MS
0	29
0.05	28.5
0.1	27.9
0.15	27.4
0.2	26.8
0.25	26.2
0.3	25.7
0.35	25.2
0.4	24.6

$$Dn = \left[ \frac{Cf}{\left( \frac{Tm+460}{Ms*(Ts+460)} \right) * \left( 1 - \frac{Bw}{100} \right)^2 * (\Delta H@) * (1774)} \right]^{0.25}$$

3) Calculate the correction factor Cf. Cf times the stack  $\Delta P$  will determine the manometer setting  $\Delta H$ :

$$Cf = \left[ \frac{Tm+460}{Ms*(Ts+460)} \right] * (1 - Bw)^2 * \Delta H@ * Dn^4 * 1774 \quad Cf * \Delta P = \Delta H$$

Calculation	Run No. 1	Run No. 2	Run No. 3
Tm + 460 =	550	561	
/ [MS*(Ts+460)] =	21356	21291	
* (1 - Bw) <sup>2</sup> =	0.8464	0.8649	
* $\Delta H@$ =	1.69	1.69	
* $(Dn)^4$ =	0.00289	0.00289	
* 17741 = Cf		1.97	

## Chain of Custody

Plant Name: Progress Energy Project Number: \_\_\_\_\_

Location: Crystal River      Source: Unit 5

Sample Identification	Remarks
1-CR5-M	
2-CR5-M	
3-CR5-M	
1-CR5-F	Mozzle Wash Run Filter Run
2-CR5-F	
3-CR5-F	
39	Silica Set Run
25	
17	

Sampled by: K Paul Date: 5-22-06 See data

**Signature**

Date

Time

**Relinquished by:** \_\_\_\_\_

**Signature**

Date

Time

Received by:

**Signature**

Date

Time

**Relinquished by:**

## Signatures

B-4

三

Laboratory:

51

6

3

Laboratory: DD 1 (130)

Received by: R Fall 5/25/06 1610

**Signature**

Date

## Time

Sample Shipped Via:  UPS  Federal Express  Other

UPS    Federal Express

Other

**Shipping Bill Number:** \_\_\_\_\_





# Particulate Lab Data Sheet

Test Date: 5-22-06

Plant Name: Progress Energy / Crystal River

Source: Unit 5

	Run No. 1	Run No. 2	Run No. 3	Blank
Container No.	1	2	802	111
Total Volume (ml)	50	55	50	50
Aliquot Evaporated (ml)	50	55	50	50
Final Weight (g)	116.2591	111.0304	98.9915	110.5752
Tare Weight (g)	116.2575	111.0281	98.9893	110.5756
Gross Weight Gained (g)	0.0016	0.0023	0.0022	-0.0004
Average Blank (g)	—	—	—	
Net Weight (g)	0.0016	0.0023	0.0022	
Aliquot Factor	x 1.0	x 1.0	x 1.0	x
Total Net Weight (mg)	1.6	2.3	2.2	

Container No.	1-A	2-A	3-A	3-B
Filter No.	4404	4405	4406	4435
Final Weight (g)	0.1270	0.1274	0.1270	0.1226
Tare Weight (g)	0.1232	0.1230	0.1222	0.1228
Gross Weight Gained	0.0038	0.0044	0.0048	-0.0002
Average Blank (g)	—	—	—	
Total Net Weight (mg)	3.8	4.4	4.8	

## Tare Balance Check

0.0 0.0000    10.0 9.9998  
 1.0 1.0000    50.0 50.0002  
 5.0 5.0001    100.0 100.0001  
 T/H 73/43

Z3 T Paul

Signature

05/22/06

Date

## Final Balance Check

0.0 /    10.0 /  
 1.0 /    50.0 /  
 5.0 /    100.0 /  
 T/H 77-43

R Paul

Signature

5-30-06

Date

# Particulate Lab Data Sheet

Test Date: 5-22-06

Plant Name: Progress Energy/Crystal River  
 Source: Unit 5

	Run No. <u>4</u>	Run No. <u>5</u>	Run No. <u>6</u>	Blank
Container No.	10	429	76	
Total Volume (ml)	70	70	55	
Aliquot Evaporated (ml)	70	70	55	
Final Weight (g)	116.6960	113.4460	111.4473	
Tare Weight (g)	116.6944	113.4459	111.4466	
Gross Weight Gained (g)	0.0016	0.0010	0.0007	
Average Blank (g)	—	—	—	
Net Weight (g)	0.0016	0.0010	0.0007	
Aliquot Factor	x 1.0	x 1.0	x 1.0	x
Total Net Weight (mg)	1.6	1.0	0.7	

Container No.	1-B	2-B	3-B
Filter No.	4407	4408	4409
Final Weight (g)	0.1260	0.1269	0.1256
Tare Weight (g)	0.1222	0.1227	0.1222
Gross Weight Gained	0.0038	0.0042	0.0034
Average Blank (g)	—	—	—
Total Net Weight (mg)	3.8	4.2	3.4

### Tare Balance Check

✓  
 0.0      10.0      5.9997  
 1.0      1.0001      50.0      49.9999  
 5.0      5.0002      100.0      100.0002  
 T/H      74/42

M. Bent  
Signature

5/22/06  
Date

### Final Balance Check

✓  
 0.0      10.0  
 1.0      50.0  
 5.0      100.0  
 T/H      77/43

R Paul  
Signature

5-30-06  
Date

## Carbon Monoxide

PLANT Progress Energy  
 LOCATION Crystal River, FL  
 EMISSION UNIT Unit #5  
 TEST CO
 DATE 5/22/06  
 INST. RANGE 0-500 (200 ppm)  
 LEAK CHECK 0.0"  
 NOTES \_\_\_\_\_

TIME	GAS	TIME	GAS
10:36	Zero air on	16:41	50.2 CO on
10:40	Zero air = 1.0	16:45	50.2 CO = 48.7
10:43	195 CO on	16:57	Start Run #5
10:49	195 CO = 194	17:57	End Run #5
10:53	99.1 CO on	17:58	Zero air on
10:57	99.1 CO = 100 ~ 98	18:01	Zero air = -0.6
11:01	50.2 CO on	18:03	50.2 CO on
11:04	50.2 CO = 51	18:08	50.2 CO = 48.5
11:07	Zero air on	18:18	Start Run #6
11:11	Zero air = 1.5 ~ 0.5	19:18	End Run #6
11:19	Start Run #1	19:19	Zero air on
12:21	End Run #1	19:23	Zero air = 0.1
12:22	Zero air on	19:27	<del>Zero air</del> = 50.2 CO on
12:25	Zero air = 0	19:29	50.2 CO = 50.9
12:28	50.2 CO on		
12:32	50.2 CO = 49		
12:45	Start Run #2		
13:45	End Run #2 Zero air <sup>15.44</sup> on		
13:49	Zero air = ~1.5		
13:52	50.2 CO on		
13:54	50.2 CO = 48.8		
14:09	Start Run #3		
15:09	End Run #3		
15:10	Zero air on		
15:14	Zero air = ~1		
15:17	50.2 CO on		
15:23	50.2 CO = 48.6		
15:34	Start Run #4		
16:34	End Run #4		
16:35	Zero air on		
16:38	Zero air = 0.6		

**Sampling Equipment Calibration Records**



## Nozzle Calibration

Date: 5-22-06


Plant Name: Progress Energy

Location: Crystal River

Source: Unit 5

Measurement Number	Inside Diameter (inches)
1	0.232
2	0.231
3	0.233
Average	0.232
Area of Nozzle	0.000294 Ft. <sup>2</sup>

Calibrated by: R Paul



Nozzle X-Section

# Pitot Tube Calibration Measurements

Pitot Tube Identification Number: SSI

Date Calibrated: 12-15-05

Pitot Tube Assembly Level: Yes  No

Pitot Tube Openings Damaged: Yes  No  If yes, please explain:

---



---

$$D_{tA} = 0.371 \text{ in. } (D_{tA} = 0.1875 - 0.3750 \text{ in.})$$

$$D_{tB} = 0.372 \text{ in. } (D_{tB} = 0.1875 - 0.3750 \text{ in.})$$

$$\alpha_A = 1.5^\circ (<10^\circ) \quad \alpha_B = 1.5^\circ (<10^\circ)$$

$$\beta_A = 2.5^\circ (<5^\circ) \quad \beta_B = 1.5^\circ (<5^\circ)$$

$$\gamma = 0.5^\circ, \theta = 0.5^\circ,$$


$$P_A = 0.465 \quad (P_A = 1.05 D_t \text{ to } 1.50 D_t)$$

$$P_B = 0.466 \quad (P_B = 1.05 D_t \text{ to } 1.50 D_t)$$

$$P_A + P_B = A = 0.930 \quad [A = 2x(1.05 D_t \text{ to } 1.50 D_t)]$$

$$Z = A \sin \gamma = <0.01 \text{ in. } (<0.125 \text{ in.})$$

$$W = A \sin \theta = <0.01 \text{ in. } (<0.031 \text{ in.})$$



Comments: Pitot tubes looked OK day of test

---



---

Calibration required? Yes  No

Calibrated by: R Paul

## Post Test Thermocouple Calibration

Date: 5-22-06

Plant Name: Progress Energy

Location: Crystal River

Source: Unit 5

Thermocouple Readout No.	<u>KAK-8</u>
Umbilical Cord No.	<u>KAK-100</u>
Switch Box No.	<u>KAK-8</u>
Thermocouple No.	<u>KAK-110</u>
Average Stack Temperature °F	<u>296</u>
* Observed Mercury in Glass (ASTM) °F	<u>297</u>
Observed Thermocouple Reading °F	<u>297</u>

\* Observed temperature must be within ten percent of the average stack temperature.

Percent Difference  $\frac{(\text{ASTM} + 460) - (\text{Thermo} + 460)}{(\text{ASTM} + 460)} \times 100 =$  0.09%

Tolerance  $\leq 1.5\%$

Signature: R Paul

**FIELD DATA SHEET: POST-TEST DRY GAS METER CALIBRATION  
USING CRITICAL ORIFICES**

**Koogler & Associates  
Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which approximates the test average delta H range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below.

COMPANY: Progress Energy (Crystal River)  
 SOURCE: Unit # 5  
 TEST DATE: 5/22/06  
 METER Y: 0.998  
 AVG. DELTA H: 1.69

METER SERIAL #: KA - 8  
 CRITICAL ORIFICE SERIAL #: 1376-26

INITIAL      FINAL

BAROMETRIC PRESSURE (in Hg): 30.00      30.00

RUN	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)
				INITIAL	FINAL	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL			
1	26	0.7142	18	679.764	686.364	76	77	77	77	7.0	2.6
2	26	0.7142	18	686.364	694.421	76	77	77	77	8.5	2.7
3	26	0.7142	18	694.421	702.969	76	77	77	77	9.0	2.6

Test Conducted by: ADAM WEST

Signature: Adam West

Date: 5/26/06



**POST-TEST DRY GAS METER CALIBRATION USING CRITICAL ORIFICES**

**Koogler & Associates  
Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which represents the observed operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

**COMPANY: Progress Energy "Crystal "River"**

**SOURCE: Unit #5**

**DATE: 5/22/06**

**PRETEST Y: 0.998**

**METER SERIAL #: KA-8**

**CRITICAL ORIFICE SERIAL #: 1376-26**

	INITIAL	FINAL	Avg (P <sub>bar</sub> )
<b>BAROMETRIC PRESSURE (in Hg):</b>	30	30	30

RUN NO.	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F					ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>e</sub>	
				INITIAL	FINAL	NET (V <sub>m</sub> )	AMBIENT	DGM INLET	INITIAL FINAL	INITIAL FINAL	DGM AVG							
1	26	0.7142	18	679.764	686.364	8.690	76	77	77	77	77	77	7.0	2.6	6.55	6.48	0.989	1.707
2	26	0.7142	18	686.364	694.421	8.087	76	77	77	77	77	77	8.5	2.7	8.00	7.87	0.984	1.772
3	26	0.7142	18	694.421	702.969	8.542	76	77	77	77	77	77	9.0	2.6	8.48	8.33	0.982	1.707
<b>AVG = .985</b>																		

**USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:**

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) \quad V_m(\text{std}) = K_1 V_m Y \left[ \frac{P_{\text{bar}} + (\Delta H / 136)}{T_m} \right]$$

V<sub>m</sub>(std) = Net volume of gas sample passed through DGM, corrected to standard conditions.

K<sub>1</sub> = 17.64 °R/in. Hg

Y = DGM calibration factor

V<sub>cr</sub>(std) = Volume of gas sample passed through the critical orifice, corrected to standard conditions.

P<sub>bar</sub> = Barometric pressure at the sampling site (in. Hg).

ΔH = Orifice pressure differential (in. H<sub>2</sub>O).

θ = Total sampling time (min.)

T<sub>m</sub> = Absolute DGM avg. temperature °R

T<sub>amb</sub> = Absolute ambient temperature °R

K' = Average K' factor from Critical Orifice Calibration

$$(2) \quad V_{cr}(\text{std}) = K \left[ \frac{P_{\text{bar}} \theta}{\sqrt{T_{\text{amb}}}} \right]$$

$$(3) \quad Y = \frac{V_{cr}(\text{std})}{V_m(\text{std})}$$

$$(4) \quad \Delta H_{@} = \left( \frac{0.75 * \theta}{V_{cr}(\text{std})} \right)^2 * \Delta H$$

**AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.985**

**AVERAGE DELTA Y = -0.013**

**DELTA Y LIMIT = 0.05**

**IS TEST WITHIN 5%? YES**

## METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.



ENVIRONMENTAL SUPPLY COMPANY

		DATE: .1/12/06		METER SERIAL #: KA-8		BAROMETRIC PRESSURE (in Hg): 30.16		INITIAL	FINAL	AVG (P <sub>bar</sub> )	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED							
		METER PART #: KA-8		CRITICAL ORIFICE SET SERIAL #: 1376														
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	Y VARIATION (%)	ΔH <sub>⊖</sub>	
				INITIAL	FINAL	NET (V <sub>m</sub> )	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL	DGM AVG								
22	1	0.5836	18	685.617	692.456	6.839	74	75	76	76	77	76	9.00	1.8	6.8220	6.8572	1.005	1.74
	2	0.5836	18	734.865	741.458	6.593	77	78	78	85	86	81.75	8.50	1.8	6.5068	6.4581	0.993	1.73
	3	0.5836	18	741.458	748.806	7.348	78	78	78	86	87	82.25	9.50	1.8	7.2452	7.2111	0.995	1.73
17	1	0.4505	18	699.593	707.321	7.728	75	76	77	79	81	78.25	13.00	1	7.6616	7.6387	0.997	1.62
	2	0.4505	18	748.806	754.534	6.728	78	78	79	87	87	82.75	9.50	1	5.6317	5.5665	0.988	1.61
	3	0.4505	18	754.534	760.269	6.735	78	79	79	87	87	83	9.50	1	5.6360	5.5665	0.988	1.61
26	1	0.7142	18	707.321	717.568	10.247	76	77	78	81	83	79.75	11.00	2.7	10.1726	10.2373	1.006	1.74
	2	0.7142	18	717.568	725.976	8.408	76	78	78	83	84	80.75	9.00	2.7	8.3315	8.3760	1.005	1.74
	3	0.7142	18	725.976	734.865	8.889	77	78	83	84	85	82.5	9.50	2.7	8.7797	8.8331	1.006	1.74
															Avg = 0.998	-0.05		

### USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.998

AVERAGE ΔH<sub>⊖</sub> = 1.69

$$(1) \quad V_{m(\text{std})} = K_1 * V_m * \frac{P_{\text{bar}} + (\Delta H / 13.6)}{T_m}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions  
 $K_1 = 17.64^{\circ}\text{R}/\text{in. Hg}$  (English),  $0.3858^{\circ}\text{K}/\text{mm Hg}$  (Metric)

$T_m$  = Absolute DGM avg. temperature ( $^{\circ}\text{R}$  - English,  $^{\circ}\text{K}$  - Metric)

$$\Delta H_{\ominus} = \left( \frac{0.75 \theta}{V_{\text{cr}}(\text{std})} \right)^2 \Delta H \left( \frac{V_m(\text{std})}{V_{\text{cr}}(\text{std})} \right)$$

$$(2) \quad V_{\text{cr}(\text{std})} = K_2 * \frac{P_{\text{bar}} * \theta}{\sqrt{T_{\text{amb}}}}$$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions  
 $T_{\text{amb}}$  = Absolute ambient temperature ( $^{\circ}\text{R}$  - English,  $^{\circ}\text{K}$  - Metric)

$K'$  = Average K' factor from Critical Orifice Calibration

$$(3) \quad Y = \frac{V_{\text{cr}(\text{std})}}{V_{m(\text{std})}}$$

= DGM calibration factor

**KOOGLER & ASSOCIATES, Inc.**  
**THERMOCOUPLE CALIBRATION**

Probe ID	"K" TYPE									Average % Δ	Average Δ (F°)		
	Ice			Ambient			Hot Oil						
	NIST (F°)	Probe (F°)	% Δ	NIST (F°)	Probe (F°)	% Δ	NIST (F°)	Probe (F°)	% Δ				
KAK-5							Missing						
KAK-7	32	33	-3.1	74	76	-2.7	251	251	0.0	-1.9	1.0		
KAK-8	32	33	-3.1	73	74	-1.4	251	250	0.4	-1.4	0.3		
KAK-9	32	33	-3.1	72	74	-2.8	257	257	0.0	-2.0	1.0		
KAK-10	32	33	-3.1	74	76	-2.7	251	252	-0.4	-2.1	1.3		
KAK-11	32	34	-6.3	73	73	0.0	274	274	0.0	-2.1	0.7		
KAK-12							Missing						
KAK-20	32	33	-3.1	72	74	-2.8	271	271	0.0	-2.0	1.0		
KAK-33	32	34	-6.3	74	73	1.4	265	265	0.0	-1.6	0.3		
KAK-35	32	34	-6.3	74	74	0.0	260	260	0.0	-2.1	0.7		
KAK-36	32	34	-6.3	72	73	-1.4	276	277	-0.4	-2.7	1.3		
KAK-38	32	34	-6.3	74	75	-1.4	275	275	0.0	-2.5	1.0		
KAK-50	32	33	-3.1	75	76	-1.3	275	274	0.4	-1.4	0.3		
KAK-51	32	34	-6.3	73	75	-2.7	271	272	-0.4	-3.1	1.7		
KAK-52	32	34	-6.3	72	72	0.0	276	276	0.0	-2.1	0.7		
KAK-55	32	32	0.0	71	73	-2.8	276	276	0.0	-0.9	0.7		
KAK-60	32	34	-6.3	73	74	-1.4	264	265	-0.4	-2.7	1.3		
KAK-61	32	34	-6.3	73	72	1.4	267	268	-0.4	-1.8	0.7		
KAK-63	32	34	-6.3	73	74	-1.4	273	274	-0.4	-2.7	1.3		
KAK-65	32	33	-3.1	72	72	0.0	277	280	-1.1	-1.4	1.3		
KAK-71	32	34	-6.3	75	76	-1.3	279	281	-0.7	-2.8	1.7		
KAK-72	32	33	-3.1	72	74	-2.8	275	277	-0.7	-2.2	1.7		
KAK-76	32	35	-9.4	73	75	-2.7	275	275	0.0	-4.0	1.7		
KAK-110	32	33	-3.1	72	71	1.4	276	276	0.0	-0.6	0.0		
KAK-112	32	33	-3.1	72	73	-1.4	275	274	0.4	-1.4	0.3		
KAK-72-A	32	33	-3.1	72	74	-2.8	275	277	-0.7	-2.2	1.7		

DATE: 8/16/2005

TESTER: G.Haven and E.Thomas

Plant Operating Data



**Progress Energy**  
**Unit 5**

DATE: 5/22/06	<b>Run 1</b>	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-6	Tons/hr Coal 1-5	
time start	11:18	19083	300600	393870	244121	434401	426603			
time stop	12:34	19137	300653	393922	244175	434455	426658	Total	<b>Total</b>	MMBTU/Hr
Total	1:16	53.8	53.0	51.6	53.7	54.1	55.1	321.3	<b>253.66</b>	<b>6045</b>

DATE: 5/22/06	<b>Run 2</b>	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-5	Tons/hr Coal 1-5	
time start	12:50	19149	300666	393934	244187	434468	426670			
time stop	13:57	19199	300715	393983	244237	434518	426722	Total	<b>Total</b>	MMBTU/Hr
Total	1:07	50.2	49.7	48.4	50.4	50.4	51.3	300.4	<b>269.01</b>	<b>6411</b>

DATE: 5/22/06	<b>Run 3</b>	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-5	Tons/hr Coal 1-5	
time start	14:09	19213	300729	393996	244251	434531	426735			
time stop	15:22	19264	300780	394046	244302	434583	426788	Total	<b>Total</b>	MMBTU/Hr
Total	1:13	51.5	51.3	50.0	51.0	51.4	52.4	307.6	<b>263.70</b>	<b>6284</b>

AVE. % Capacity
<b>93.73</b>

**Progress Energy**  
**Unit 5**

DATE: 5/22/06	<b>Run 4</b>	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-6	Tons/hr Coal 1-5	
time start	15:36	19273	300788	394054	244315	434596	426801			
time stop	16:41	19326	300842	394106	244369	434650	426855	Total	Total	MMBTU/Hr
Total	1:05	53.2	53.5	51.9	53.7	53.6	54.1	320.0	295.38	7040

DATE: 5/22/06	<b>Run 5</b>	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-5	Tons/hr Coal 1-5	
time start	17:00	19337	300851	394115	244377	434659	426865			
time stop	18:12	19391	300905	394168	244432	434714	426921	Total	Total	MMBTU/Hr
Total	1:12	54.0	54.0	53.0	55.0	55.0	56.0	327.0	272.50	6494

DATE: 5/22/06	<b>Run 6</b>	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-5	Tons/hr Coal 1-5	
time start	18:18	19399	300913	394175	244437	434718	426926			
time stop	19:20	19444	300958	394219	244485	434767	426975	Total	Total	MMBTU/Hr
Total	1:02	45.0	45.0	44.0	48.0	49.0	49.0	280.0	270.97	6458

<b>AVE. % Capacity</b>
<b>99.98</b>

<b>Run 1-6</b>	<b>AVE. % Capacity</b>
	<b>96.86</b>

**Crystal River Fossil Plant**  
**PRB Trial – 5/22/06**  
**Heat Rate Data Collection Form**  
**Unit 5 only**

Test Identification: Run #1						
Test Date: MAY 22, 2006						
	Coal Feeder Integrators					
HR:MN	502	503	504	505	506	507
Start Time:	11:18	19082.800	300597.900	319870.300	244121.200	434401.300
End Time:	12:34	19136.530	300632.900	319421.900	244174.900	434455.400
Difference:	:					
	Unit MWs at Start:	710	710	Unit MWs at End:	711	711

Test Identification: Run #2						
Test Date:						
	Coal Feeder Integrators					
HR:MN	502	503	504	505	506	507
Start Time:	12:50	19149.100	300665.500	319134.300	244187.000	434467.700
End Time:	13:57	19199.300	300715.200	319398.200	244237.400	434518.100
Difference:	:					
	Unit MWs at Start:	711	711	Unit MWs at End:	710	710

Test Identification: Run #3						
Test Date:						
	Coal Feeder Integrators					
HR:MN	502	503	504	505	506	507
Start Time:	14:09	19212.800	300728.300	319195.700	244250.500	434536.400
End Time:	15:22	19264.348	300779.800	319405.700	244371.500	434592.800
Difference:	:					
	Unit MWs at Start:	710	710	Unit MWs at End:	711	711

Comments: \_\_\_\_\_

\_\_\_\_\_

Test Identification: Run #4						
Test Date: MAY 22, 2006						
	Coal Feeder Integrators					
HR:MN	502	503	504	505	506	507
Start Time:	15 : 36	19272.9m	300782,100	394454,000	244314,800	434546,000
End Time:	16 : 41	19326,100	300841,500	394105,100	244368,500	434649,500
Difference:	:					
	Unit MWs at Start:	712		Unit MWs at End:	709	

Test Identification: Run #5						
Test Date:						
	Coal Feeder Integrators					
HR:MN	502	503	504	505	506	507
Start Time:	17 : 00	19337	300851	394115	244377	434659
End Time:	18 : 12	19391	300905	394168	244432	434714
Difference:	:					
	Unit MWs at Start:	710		Unit MWs at End:	711	

Test Identification: Run #6						
Test Date:						
	Coal Feeder Integrators					
HR:MN	502	503	504	505	506	507
Start Time:	18 : 18	19399	300913	394175	244437	434718
End Time:	19 : 20	19444	300958	394219	244485	434767
Difference:	:					
	Unit MWs at Start:	710		Unit MWs at End:	711	

Comments: \_\_\_\_\_

\_\_\_\_\_

S.L.	Sampler # 4	MAY 2006							As Bunkered Samples															
		Date	Lab #	Mech Hand	Type A/D	# Samp	I.D. Shift	#/1000 Tons	Tonnage	Moisture	Ash	Volatile Matter	Fixed Carbon	Sulfur	BTU/LB BTU/MBTU	Lbs SO2 /MBTU	MAF BTU	Dry Ash	Dry Sul	Dry Btu	Dry Vol	WT X M	WT X A	WT X V
4	05/22/06	64185 M	D	26	00:01-08:00	17.9	1,456	10.46	9.69	31.34	48.51	0.69	11964	1.15	14983	10.82	0.77	13362	35.00	15230	14109	45631	1005	#####
		64187 M	D	36	08:00-16:00	50.1	718	9.30	10.69	31.21	48.80	0.65	11945	1.09	14929	11.79	0.72	13170	34.41	6677	7675	22409	467	8576510
		64189 M	D	35	16:00-24:00	21.2	1,650	9.37	10.96	33.40	46.27	0.67	11887	1.13	14920	12.09	0.74	13116	36.85	15461	18084	55110	1106	#####

X = 100

**Unit 5 Normal Operations June 5, 2006**

## Calculations

## Particulate Matter

PROGRESS ENERGY - CRYSTAL RIVER  
UNIT 5  
JUNE 5, 2006

Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)	Particulate Matter	
				Conc. (gr/dscf)	Emission Rate (Lbs/Hr)
1	1,579,764	297.4	8.1	0.0017	22.92
2	1,587,093	297.8	7.8	0.0019	25.41
3	1,525,604	297.9	8.6	0.0018	23.47
Avg.	1,564,154	297.7	8.1	0.0018	23.93

GENERAL DATA

Plant :	PROGRESS ENERGY - CRYSTAL RIVER			
Source/Unit :	UNIT 5			
Date :	JUNE 5, 2006	Cp	0.840	
Stack dia. :	308.00 inch	OR :	Duct Length	0.00 inch
Oxygen Corr.:	0.0 percent		Duct Width	0.00 inch
CO2 Corr. :	0.0 percent		Std. Temp.	68 F

FUEL ANALYSIS DATA; (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U	f	Process Wt.
----------------------------	---	-------------

Hydrogen, wt% :	0.00	Run 1 :	0 Tons/hr
-----------------	------	---------	-----------

Carbon, wt% :	0.00	Run 2 :	0
---------------	------	---------	---

Sulfur, wt% :	0.00	Run 3 :	0
---------------	------	---------	---

Nitrogen, wt% :	0.00
-----------------	------

Oxygen, wt% :	0.00
---------------	------

Btu/lb :	0
----------	---

Type of Flow Meter :	(1=Meter Box 2=Mass Flow Meter)	1
----------------------	---------------------------------	---

F-Factor :	dscf/MMBtu;
------------	-------------

<u>FIELD DATA</u>	METHOD 5	RUN 1	RUN 2	RUN 3
-------------------	----------	----------	----------	----------

Meter Temp., Tm (F) .....	102	109	111
Stack Temp., Ts (F) .....	297	298	298
Sq.Rt. dP .....	1.18	1.18	1.14
dH (in. H2O) .....	1.77	1.82	1.71
Meter Vol.,Vm (ft3) .....	48.300	49.630	48.100
Vol. H2O, Vlc (ml) .....	85.0	83.0	89.0
Meter Y .....	0.993	0.993	0.993
Bar. Press.,Pb (in.Hg.) .....	30.13	30.13	30.13
Static Press.,Ps (in.H2O) .....	-0.97	-0.97	-0.97
Test Time (min.) .....	60.0	60.0	60.0
Nozzle Dia.,Dn (in.) .....	0.214	0.214	0.214
Oxygen, O2 (%) .....	4.5	4.0	4.0
Carbon Dioxide, CO2 (%) .....	10.5	10.5	11.0
Carbon Monoxide, CO (%) .....	0.0	0.0	0.0

Report Emission Criteria in ?	l = lb/hr	g = gr/dscf :	grams
-------------------------------	-----------	---------------	-------

Process Rate Units ?	T = Ton/hr, L = Lbs/hr, C = Cans/min:	T
----------------------	---------------------------------------	---

Allowable Particulate Matter Concentration .....	0
--	---

<u>LABORATORY RESULTS</u>	RUN 1	RUN 2	RUN 3
	grams	grams	grams

GRAVIMETRIC ANALYSIS METHOD 5 :

Front Half Wash (FWH) .....	0.00100	0.00060	0.00050
Filterable Sample (MF) .....	0.00400	0.00500	0.00470
Condensible Sample (BHW) .....	0.00000	0.00000	0.00000

A. FIELD DATA SUMMARY

Plant: PROGRESS ENERGY - CRYSTAL RIVER  
 Source/Unit: UNIT 5  
 Date: JUNE 5, 2006

	RUN 1	RUN 2	RUN 3
Vlc = Vol water collected in train, ml	85.0	83.0	89.0
Vm = Sample gas vol, meter cond., acf	48.300	49.630	48.100
Y = Meter calibration factor	0.9930	0.9930	0.9930
Pbar = Barometric pressure, in. Hg	30.13	30.13	30.13
Pstatic = Stack static pressure, in. H2O	-0.97	-0.97	-0.97
dH = Avg meter pressure diff, in. H2O	1.77	1.82	1.71
Tm = Absolute meter temp., degrees R	562.0	568.9	570.6
Vm(std) = Sample gas vol, Std. cond., dscf	45.572	46.264	44.695
Bws = Water vapor in gas stream, fraction	0.081	0.078	0.086
MF = Moisture factor ( 1 - Bws)	0.919	0.922	0.914
CO2 = Carbon Dioxide, dry, volume %	10.50	10.50	11.00
O2 = Oxygen, dry, volume %	4.50	4.00	4.00
N2 = Nitrogen, dry volume %	85.00	85.50	85.00
Md = Molecular weight of stack gas, dry	29.86	29.84	29.92
Ms = Molecular weight of stack gas, wet	28.90	28.92	28.90
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	1.1788	1.1813	1.1449
Ts = Absolute stack temp., degrees R	757.4	757.8	757.9
A = Area of stack, ft2	517.40	517.40	517.40
Qstd = Volumetric flowrate, dscfm	1,579,764	1,587,093	1,525,604
An = Nozzle area, ft2	2.50E-04	2.50E-04	2.50E-04
t = Sample time, minutes	60.00	60.00	60.00
%I = Isokinetic variation, percent	99.60	100.64	101.15

B. PARTICULATE DATA SUMMARY

Plant: PROGRESS ENERGY - CRYSTAL RIVER  
Source/Unit: UNIT 5  
Date: JUNE 5, 2006

	RUN	RUN	RUN
	1	2	3
Sample Weight (FWH + MF + BHW), mg .....	5.00	5.60	5.20
Meter Volume, standard cond., Vm(std) .....	45.572	46.264	44.695
Carbon Dioxide, percent .....	10.50	10.50	11.00
Oxygen, percent .....	4.50	4.00	4.00
Sample Concentration :			
gr/scf .....	0.0016	0.0017	0.0016
gr/dscf .....	0.0017	0.0019	0.0018
gr/dscf @ 0 % CO <sub>2</sub> .....	0.0019	0.0021	0.0020
gr/dscf @ 0 % O <sub>2</sub> .....	0.0022	0.0023	0.0022
ppm * MW (dry gas).....	93.1	102.7	98.7
ppm * MW @ 0% CO <sub>2</sub> .....	0.0	0.0	0.0
ppm * MW @ 0% O <sub>2</sub> .....	118.7	127.1	122.1

EMISSION RATE CALCULATIONS

---

Plant :	PROGRESS ENERGY - CRYSTAL RIVER		
Source/Unit :	UNIT 5		
Date:	JUNE 5, 2006		
STANDARD TEMP. :	68 F		

---

RUN NO.: 1

Front Half Wash (FHW)	0.00100	grams	Vm(std)	45.572	ft3
Mass Filter (MF)	0.00400	grams	Vw(std)	4.001	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,579,764	dscfm
Vm(std) SO2		dscf	Bws	0.081	
CO2 CORR.	0.0 %		CO2	10.50	%
O2 CORR.:	0.0 %		O2	4.50	%

---

F-FACTOR

10E6 x [3.64(%H) + 1.53(%C) + 0.57(%S) + 0.14(%N) -  
0.46(%O2)] / (Btu/lb) x [(Tstd + 460)/528] ..... dscf/MMBtu  
FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
Heat Input = (Process Weight (ton/hr) x Heating ..... MMBtu/hr  
Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6

TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0016	gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std) .....	0.0017	gr/dscf
gr/dscf x (12 / %CO2) .....	0.0019	@ 0% CO2
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] .....	0.0022	@ 0% O2
0.00857 x Qs(std) x gr/dscf .....	22.92	lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..		lb/MMBtu
Particulate (lb/hr) / Heat Input (MMBtu/hr) .....		lb/MMBtu

TOTAL ACID MIST

[ 1.0811E-4 x { Vt - Vtb } x N x Vsol ] / Vol(alog) .	lb Acid Mist
[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60, ...	lb/hr
[Acid Mist (lb) / Vm std (ft^3)] x F-Factor .....	lb/MMBtu

SULFUR DIOXIDE (SO2)

[ 7.061E-5 x ( Vt - Vtb ) x N x Vsol ] / Vol(alog)	lb SO2
[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ...	lb/hr
[SO2 (lb) / Vm std (ft^3)] x F .....	lb/MMBtu
[ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std)	ppm
ppm x 0.0 % Corr. / 10.5 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 4.5% O2 Stack)	ppm @ 0% O2
SO2 (lb/hr / Heat Input) .....	lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)] ..	ppm
ppm x 0.0 % Corr. / 10.5 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.5% O2 Stack)	ppm @ 0% O2
[ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )].....	lb/hr

EMISSION RATE CALCULATIONS

---

Plant :	PROGRESS ENERGY - CRYSTAL RIVER		
Source/Unit :	UNIT 5		
Date:	JUNE 5, 2006		
STANDARD TEMP. :	68 F		
	RUN NO.: 2		

---

Front Half Wash (FHW)	0.00060	grams	Vm(std)	46.264	ft <sup>3</sup>
Mass Filter (MF)	0.00500	grams	Vw(std)	3.907	ft <sup>3</sup>
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,587,093	dscfm
Vm(std) SO2		dscf	Bws	0.078	
CO2 CORR. 0.0 %			CO2	10.50	%
O2 CORR.: 0.0 %			O2	4.00	%

---

F-FACTOR

$$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{std} + 460)/528] \dots \dots \dots \text{dscf/MMBtu}$$

FUEL USE

$$\begin{aligned} \text{Use Rate (gal/ton)} * \text{Process Wt. (ton/hr)} &\dots \dots \dots \text{gal/hr} \\ \text{Heat Input} = (\text{Process Weight (ton/hr)} \times \text{Heating} \dots \dots \dots \text{MMBtu/hr} \\ \text{Value (Btu/gal)} \times \text{Fuel Use Rate (gal/ton)} / 1E6 \end{aligned}$$

TOTAL PARTICULATE

$$\begin{aligned} 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [\text{Vm(std)} + \text{Vw(std)}] \dots &0.0017 \text{ gr/scf} \\ 15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / (\text{Vm(std)}) \dots \dots \dots &0.0019 \text{ gr/dscf} \\ \text{gr/dscf} \times (12 / \% \text{CO}_2) \dots \dots \dots &0.0021 @ 0\% \text{ CO}_2 \\ \text{gr/dscf} \times [(20.9 - \text{Oxygen corr.}) / (20.9 - \% \text{O}_2)] \dots \dots \dots &0.0023 @ 0\% \text{ O}_2 \\ 0.00857 \times \text{Qs(std)} \times \text{gr/dscf} \dots \dots \dots &25.41 \text{ lb/hr} \\ \text{F-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \% \text{O}_2)] \times \text{gr/dscf} \dots \dots \dots &1 \text{ lb/MMBtu} \\ \text{Particulate (lb/hr)} / \text{Heat Input (MMBtu/hr)} \dots \dots \dots &1 \text{ lb/MMBtu} \end{aligned}$$

TOTAL ACID MIST

$$\begin{aligned} [1.0811E-4 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} \dots &1 \text{ lb Acid Mist} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std} \times 60 \dots &1 \text{ lb/hr} \\ [\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{F-Factor} \dots \dots \dots &1 \text{ lb/MMBtu} \end{aligned}$$

SULFUR DIOXIDE (SO2)

$$\begin{aligned} [7.061E-5 \times (\text{Vt} - \text{Vtb}) \times \text{N} \times \text{Vsol}] / \text{Vol(alog)} \dots &1 \text{ lb SO2} \\ [\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std (ft}^3/\text{min}) \times 60 \dots &1 \text{ lb/hr} \\ [\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{F} \dots \dots \dots &1 \text{ lb/MMBtu} \\ [\text{Mass SO2 (lb)} \times 385 / 64E+6 (\text{ft}^3/\text{lb})] / \text{Vm (std)} &\text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 10.5 \% \text{ CO}_2 \text{ in Stack} \dots \dots \dots &\text{ppm} @ 0\% \text{ CO}_2 \\ \text{ppm} \times (20.9\% - 0.0\% \text{ O}_2 \text{ Corr}) / (20.9\% - 10.5\% \text{ O}_2 \text{ Stack}) &\text{ppm} @ 0\% \text{ O}_2 \\ \text{SO2 (lb/hr} / \text{Heat Input}) \dots \dots \dots &1 \text{ lb/MMBtu} \end{aligned}$$

HYDROGEN CHLORIDE DATA SUMMARY

$$\begin{aligned} [\text{Mass HCl(mg)} \times 385 \times 1E6] / [453600 \times 36.5 \times \text{Vm(std)}] \dots &\text{ppm} \\ \text{ppm} \times 0.0 \% \text{ Corr.} / 10.5 \% \text{ CO}_2 \text{ in Stack} \dots \dots \dots &\text{ppm} @ 0\% \text{ CO}_2 \\ \text{ppm} \times (20.9\% - 0.0\% \text{ O}_2 \text{ Corr}) / (20.9\% - 10.5\% \text{ O}_2 \text{ Stack}) &\text{ppm} @ 0\% \text{ O}_2 \\ [\text{Mass HCl(mg)} \times 60 \times \text{Qs} / (\text{Vm(std)} \times 453,600)] \dots \dots \dots &1 \text{ lb/hr} \end{aligned}$$

EMISSION RATE CALCULATIONS

---

Plant : PROGRESS ENERGY - CRYSTAL RIVER

Source/Unit : UNIT 5

Date: JUNE 5, 2006

RUN NO.:

3

STANDARD TEMP. : 68 F

---

Front Half Wash (FHW)	0.00050	grams	Vm(std)	44.695	ft3
Mass Filter (MF)	0.00470	grams	Vw(std)	4.189	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(std)	1,525,604	dscfm
Vm(std) SO2		dscf	Bws	0.086	
CO2 CORR. 0.0 %			CO2	11.00	%
O2 CORR.: 0.0 %			O2	4.00	%

---

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (\text{Btu/lb}) \times [(T_{\text{std}} + 460)/528] \dots \dots \dots \text{dscf/MMBtu}$

FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating ..... MMBtu/hr  
 Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6  
TOTAL PARTICULATE

15.432 x (FHW + MF + BHW) / [(Vm(std) + Vw(std)] ...	0.0016	gr/scf
15.432 x (FHW + MF + BHW) / (Vm(std) .....	0.0018	gr/dscf
gr/dscf x (12 / %CO2) .....	0.0020	@ 0% CO2
gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] .....	0.0022	@ 0% O2
0.00857 x Qs(std) x gr/dscf .....	23.47	lb/hr
F-Fac x 1.4286E-4 x [20.9 / (20.9-%O2)] x gr/dscf ..		lb/MMBtu
Particulate (lb/hr) / Heat Input (MMBtu/hr) .....		lb/MMBtu

TOTAL ACID MIST

[ 1.0811E-4 x (Vt - Vtb) x N x Vsol ] / Vol(alog) .	lb Acid Mist
[Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ...	lb/hr
[Acid Mist (lb) / Vm std (ft^3)] x F-Factor .....	lb/MMBtu

SULFUR DIOXIDE (SO2)

[ 7.061E-5 x (Vt - Vtb) x N x Vsol ] / Vol(alog) .	lb SO2
[SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ...	lb/hr
[SO2 (lb) / Vm std (ft^3)] x F .....	lb/MMBtu
[ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std)	ppm
ppm x 0.0 % Corr. / 10.5 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.5% O2 Stack)	ppm @ 0% O2
SO2 (lb/hr / Heat Input) .....	lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)]..	ppm
ppm x 0.0 % Corr. / 11.0 % CO2 in Stack .....	ppm @ 0% CO2
ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack)	ppm @ 0% O2
[ Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600 )].....	lb/hr

## SOURCE TEST CALCULATIONS

Plant : PROGRESS ENERGY - CRYSTAL RIVER  
Source/Unit : UNIT 5  
Date: JUNE 5, 2006

RUN NO.: 1

STD.TEMP, Tstd	=	68 F	STATIC PRESS., Ps	=	-0.97	in. H2O
METER TEMP, Tm	=	102 F	PITOT COFF., Cp	=	0.840	
STACK TEMP, Ts	=	297.4 F	STACK I.D.	=	308.00	inch
AVG.VEL.HEAD,dP	=	1.390 in. H2O	DUCT LENGTH	=		inch
METER ORIFICE,dH	=	1.77 in. H2O	DUCT WIDTH	=		inch
METER VOL., Vm	=	48.300 Cu.Ft.	STACK AREA, As	=	517.403	Sq.Ft.
METER COFF., Y	=	0.993	TEST TIME	=	60.00	min.
BAR. PRESS., Pb	=	30.13 in.Hg	NOZZLE DIA.	=	0.214	inch
COND.(Vlc)	=	85.0 ml	NOZZLE DIA., An	=	2.5E-04	Sq.Ft.
<hr/>						
GAS ANALYSIS	=	4.50 % O2	0.00	% CO		
		10.50 % CO2	85.00	% N2		

```

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x
          (Pb + (dH / 13.6)) / (Tm + 460) ..... = 45.572 dscf

Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc = 4.001 scf

Bws = Vw(std) / (Vm(std) + Vw(std)) ..... = 0.081 | Lower
                                                | Bws
                                                | value

Bws @ Saturated Conditions = Vapor Press. of H2O
@ Dew Point Temp. / (Ps, in.Hg.) ..... = 1.000 | used.

%EA = (%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 = 25.08

Md = (.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)] = 29.86

Ms = (Md x (1-Bws)) + (18.0 x Bws) ..... = 28.90

P(stack) = Pbar + (Ps / 13.6) ..... = 30.06 in. Hg

vs = 85.49 x CP x (Sq.Rt.dp) x [Sq.Rt.(Ts + 460)
    / (Ms x P(stack))] ..... = 79.04 ft/sec

Qs = vs x As x 60 ..... = 2,453,756 acf/min

Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460))
           x (P(stack)/29.92) ..... = 1,579,764 dscf/min

I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) /
           (T(std) + 460) / 29.92) x 100 / [ Time x
           P(stack) x An x vs x 60] ..... = 99.60 %

```

## SOURCE TEST CALCULATIONS

Plant : PROGRESS ENERGY - CRYSTAL RIVER  
Source/Unit : UNIT 5  
Date : JUNE 5, 2006

RUN NO.: 2

STD.TEMP, Tstd	=	68 F		STATIC PRESS., Ps	=	-0.97	in. H2O
METER TEMP, Tm	=	108.92 F		PITOT COFF., Cp	=	0.840	
STACK TEMP, Ts	=	297.8 F		STACK I.D.	=	308.00	inch
AVG.VEL.HEAD,dP	=	1.395 in. H2O		DUCT LENGTH	=		inch
METER ORIFICE,dH	=	1.82 in. H2O		DUCT WIDTH	=		inch
METER VOL., Vm	=	49.630 Cu.Ft.		STACK AREA, As	=	517.403	Sq.Ft.
METER COFF., Y	=	0.993		TEST TIME	=	60.00	min.
BAR. PRESS., Pb	=	30.13 in.Hg		NOZZLE DIA.	=	0.214	inch
COND.(Vlc)	=	83.0 ml		NOZZLE DIA., An	=	2.5E-04	Sq.Ft.
GAS ANALYSIS	=	4.00 % O2		0.00 % CO			
		10.50 % CO2		85.50 % N2			

SOURCE TEST CALCULATIONS

Plant : PROGRESS ENERGY - CRYSTAL RIVER  
 Source/Unit : UNIT 5  
 Date : JUNE 5, 2006

RUN NO.: 3

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.97	in. H2O
METER TEMP, Tm =	110.58 F	PITOT COFF., Cp =	0.840	
STACK TEMP, Ts =	297.9 F	STACK I.D. =	308.00	inch
Avg.Vel.HEAD,dP =	1.311 in. H2O	DUCT LENGTH =		inch
METER ORIFICE,dH=	1.71 in. H2O	DUCT WIDTH =		inch
METER VOL., Vm =	48.100 Cu.Ft.	STACK AREA, As =	517.403	Sq.Ft.
METER COFF., Y =	0.993	TEST TIME =	60.00	min.
BAR. PRESS., Pb =	30.13 in.Hg	NOZZLE DIA. =	0.214	inch
COND.(Vlc) =	89.0 ml	NOZZLE DIA., An =	2.5E-04	Sq.Ft.
GAS ANALYSIS =	4.00 % O2	0.00 % CO		
	11.00 % CO2	85.00 % N2		

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	44.695	dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	4.189	scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.086	Lower   Bws   value   used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000	
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2-0.5%CO)) x 100 =		21.69	
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)] =		29.92	
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	28.90	
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06	in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	76.80	ft/sec
Qs = vs x As x 60 .....	=	2,384,137	acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	1,525,604	dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	101.15	%

## Carbon Monoxide

EPA Protocol Gas Analyzer Calibration Data						
CO Concentration Instrument Range Setting ( 0 - 200 ppm CO )						
EPA Method 10						
Calibration Gas	Conc. (ppmv)	Run No.	Date/Time	Response through Train System Loop (ppmv)	Drift (% of Range)(1)	Accuracy Diff. from Actual (% of Range)(2)
Zero	0.0	R1-Pre	6/5/2006 9:36	-1.51		-0.75
Zero	0.0	R1-Post	6/5/2006 11:25	1.00	1.25	0.50
CO	195.0	R1-Pre	6/5/2006 9:06	194.6		-0.21
CO	99.1	R1-Pre	6/5/2006 9:13	98.5		-0.28
CO	50.2	R1-Pre	6/5/2006 9:29	47.9		-1.15
CO	50.0	R1-Post	6/5/2006 11:33	50.5	1.32	0.26
<hr/>						
Zero	0.0	R2-Pre	6/5/2006 11:25	1.00		0.50
Zero	0.0	R2-Post	6/5/2006 12:48	0.00	-0.50	0.00
CO	50.2	R2-Pre	6/5/2006 9:29	50.5		0.16
CO	50.2	R2-Post	6/5/2006 12:55	49.8	-0.38	-0.21
<hr/>						
Zero	0.0	R3-Pre	6/5/2006 12:48	0.00		0.00
Zero	0.0	R3-Post	6/5/2006 14:13	-0.13	-0.06	-0.06
CO	50.2	R3-Pre	6/5/2006 12:55	49.8		-0.21
CO	50.2	R3-Post	6/5/2006 14:21	49.9	0.06	-0.15
<hr/>						
Zero	0.0	R1-Pre*	6/5/2006 9:36	-1.51		-0.75
Zero	0.0	R3-Post	6/5/2006 14:13	-0.13	0.69	-0.06
CO	50.2	R1-Pre*	6/5/2006 9:29	47.9		-1.15
CO	50.2	R3-Post	6/5/2006 14:21	49.9	1.00	-0.15

#### Method 10 Performance Specification

##### Section 6.1 Span = 1.5 x Emission Standard

Cal. Gas ppm	% of Range
195.0	97.50
99.1	49.55
50.2	25.10

(1) Addenda A, Maximum 10 % of Range per 8 Hours

(2) Addenda A, Maximum 2% Of Range

##### Instrument Range Setting ( 0 - 1200 ppm CO)

##### Linearity ; Method 10, Addenda, B 13

	Response	Actual
zero	-1.51	0.0
Span	194.6	195.0
<hr/>		
slope	1.006	=m
y-int	-1.505	=b
R^2	1.000	
	certified conc. =x	
	predicted conc. =Y	

$$y=m(x)+b$$

48.98	predicted mid	pre-R1
98.1	predicted low	pre-R1

##### Mid gas Differences M10, Addenda A

0.54	mid% dif	pre-R1
-0.20	low %dif	pre-R1

Progress Energy , Crystal River Complex  
 No. 5 FFSG , EU 003  
 PRB Fuel Burn Trials ( Normal Coal Burn baseline Emission Measurements)

Date	Time	CO ppmv
6/5/2006	8:50	5.0
6/5/2006	8:51	5.8
6/5/2006	8:52	5.3
6/5/2006	8:53	2.5
6/5/2006	8:54	0.5
6/5/2006	8:55	0.3 <<Zero air
6/5/2006	8:56	0.3 <average
6/5/2006	8:57	0.3
6/5/2006	8:58	2.5
6/5/2006	8:59	75.5
6/5/2006	9:00	145.2
6/5/2006	9:01	170.5
6/5/2006	9:02	186.1
6/5/2006	9:03	191.6
6/5/2006	9:04	192.8
6/5/2006	9:05	195.1
6/5/2006	9:06	194.6 <<195 ppm CO
6/5/2006	9:07	194.6 194.6 <average
6/5/2006	9:08	194.8
6/5/2006	9:09	182.0
6/5/2006	9:10	131.4
6/5/2006	9:11	106.1
6/5/2006	9:12	100.3
6/5/2006	9:13	98.8 <<99.1ppm CO
6/5/2006	9:14	98.3 98.5 <average
6/5/2006	9:15	97.8
6/5/2006	9:16	66.4
6/5/2006	9:17	50.9
6/5/2006	9:18	77.7
6/5/2006	9:19	85.5
6/5/2006	9:20	90.3
6/5/2006	9:21	92.3
6/5/2006	9:22	94.5
6/5/2006	9:23	97.3
6/5/2006	9:24	96.3
6/5/2006	9:25	77.0
6/5/2006	9:26	56.4
6/5/2006	9:27	49.6
6/5/2006	9:28	48.1
6/5/2006	9:29	47.9 <<50.2 ppm CO
6/5/2006	9:30	47.9 47.9 <average
6/5/2006	9:31	47.4
6/5/2006	9:32	47.1
6/5/2006	9:33	25.1
6/5/2006	9:34	1.5
6/5/2006	9:35	-1.0
6/5/2006	9:36	-1.5 <<Zero air
6/5/2006	9:37	-1.5 -1.5 <average

6/5/2006 9:38	-1.5
6/5/2006 9:39	-1.5
6/5/2006 10:17	-1.0
6/5/2006 10:18	<< Start Run 1
6/5/2006 10:19	-0.5
6/5/2006 10:20	-1.0
6/5/2006 10:21	-1.3
6/5/2006 10:22	-0.8
6/5/2006 10:23	-0.8
6/5/2006 10:24	-0.5
6/5/2006 10:25	-1.3
6/5/2006 10:26	-1.0
6/5/2006 10:27	-0.8
6/5/2006 10:28	-1.0
6/5/2006 10:29	-1.3
6/5/2006 10:30	-0.5
6/5/2006 10:31	-0.5
6/5/2006 10:32	-0.5
6/5/2006 10:33	-0.5
6/5/2006 10:34	-0.8
6/5/2006 10:35	-0.8
6/5/2006 10:36	-0.5
6/5/2006 10:37	-0.3
6/5/2006 10:38	-0.5
6/5/2006 10:39	-0.8
6/5/2006 10:40	-0.3
6/5/2006 10:41	-0.8
6/5/2006 10:42	-1.0
6/5/2006 10:43	-0.8
6/5/2006 10:44	-0.5
6/5/2006 10:45	-1.0
6/5/2006 10:46	-0.8
6/5/2006 10:47	-1.0
6/5/2006 10:48	-0.5
6/5/2006 10:49	0.3
6/5/2006 10:50	-0.3
6/5/2006 10:51	-0.5
6/5/2006 10:52	-0.5
6/5/2006 10:53	-0.5
6/5/2006 10:54	-0.8
6/5/2006 10:55	-1.0
6/5/2006 10:56	-0.5
6/5/2006 10:57	-1.0
6/5/2006 10:58	-0.8
6/5/2006 10:59	-1.0
6/5/2006 11:00	-0.8
6/5/2006 11:01	-0.8
6/5/2006 11:02	-0.8
6/5/2006 11:03	0.0
6/5/2006 11:04	-0.5
6/5/2006 11:05	0.0
6/5/2006 11:06	-0.5

6/5/2006 11:07	-0.8	
6/5/2006 11:08	-1.3	
6/5/2006 11:09	-0.8	
6/5/2006 11:10	-0.5	
6/5/2006 11:11	-0.5	
6/5/2006 11:12	-1.0	
6/5/2006 11:13	-0.8	
6/5/2006 11:14	-0.5	
6/5/2006 11:15	-0.5	
6/5/2006 11:16	-0.8	
6/5/2006 11:17	-0.5	
6/5/2006 11:18	0.0	
	<u>&lt;&lt; End Run 1</u>	Run 1 CO ppm
		-0.7 Average
6/5/2006 11:19	-0.5	
6/5/2006 11:20	0.5	
6/5/2006 11:21	0.5	
6/5/2006 11:22	0.8	
6/5/2006 11:23	1.0	
6/5/2006 11:24	0.8	
6/5/2006 11:25	1.0	
	<u>&lt;&lt;Zero air</u>	
6/5/2006 11:26	1.0	
	1.0	<average
6/5/2006 11:27	4.3	
6/5/2006 11:28	28.3	
6/5/2006 11:29	41.4	
6/5/2006 11:30	46.4	
6/5/2006 11:31	48.6	
6/5/2006 11:32	50.2	
6/5/2006 11:33	50.4	
	<u>&lt;&lt;50.2 ppm CO</u>	
6/5/2006 11:34	50.7	
	50.5	<average

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials ( Normal Coal Burn baseline Emission Measurements)

Date Time CO ppmv

6/5/2006	11:40	-0.5
6/5/2006	11:41	-0.8
6/5/2006	11:42	-1.0
		<< Start Run 2
6/5/2006	11:43	-0.8
6/5/2006	11:44	0.0
6/5/2006	11:45	-0.8
6/5/2006	11:46	-1.0
6/5/2006	11:47	-0.8
6/5/2006	11:48	-0.3
6/5/2006	11:49	-1.0
6/5/2006	11:50	-0.3
6/5/2006	11:51	-0.8
6/5/2006	11:52	-0.8
6/5/2006	11:53	-0.5
6/5/2006	11:54	-0.5
6/5/2006	11:55	-0.5
6/5/2006	11:56	-0.8
6/5/2006	11:57	-0.5
6/5/2006	11:58	-1.0
6/5/2006	11:59	-1.0
6/5/2006	12:00	-0.8
6/5/2006	12:01	-0.8
6/5/2006	12:02	-0.8
6/5/2006	12:03	-1.0
6/5/2006	12:04	-1.0
6/5/2006	12:05	-1.0
6/5/2006	12:06	-0.8
6/5/2006	12:07	-1.0
6/5/2006	12:08	-1.0
6/5/2006	12:09	-1.0
6/5/2006	12:10	-0.8
6/5/2006	12:11	-1.5
6/5/2006	12:12	-0.8
6/5/2006	12:13	-1.0
6/5/2006	12:14	-1.0
6/5/2006	12:15	-0.8
6/5/2006	12:16	-0.8
6/5/2006	12:17	-0.8
6/5/2006	12:18	-1.0
6/5/2006	12:19	-1.3
6/5/2006	12:20	-0.5
6/5/2006	12:21	-1.3
6/5/2006	12:22	-1.0
6/5/2006	12:23	-1.0
6/5/2006	12:24	-0.8
6/5/2006	12:25	-0.5

6/5/2006 12:26	-0.8	
6/5/2006 12:27	-0.8	
6/5/2006 12:28	-0.5	
6/5/2006 12:29	-1.0	
6/5/2006 12:30	-0.5	
6/5/2006 12:31	-0.5	
6/5/2006 12:32	-0.8	
6/5/2006 12:33	-1.0	
6/5/2006 12:34	-1.0	
6/5/2006 12:35	-1.0	
6/5/2006 12:36	-1.5	
6/5/2006 12:37	-1.0	
6/5/2006 12:38	-1.3	
6/5/2006 12:39	-1.5	
6/5/2006 12:40	-1.3	
6/5/2006 12:41	-1.3	
6/5/2006 12:42	-1.0	
	Run 2 CO ppm	
	-0.9	Average
6/5/2006 12:43	0.8	
6/5/2006 12:44	5.8	
6/5/2006 12:45	1.3	
6/5/2006 12:46	0.5	
6/5/2006 12:47	0.8	
6/5/2006 12:48	0.0	
	<<Zero air	
6/5/2006 12:49	0.0	
	0.0	<average
6/5/2006 12:50	4.8	
6/5/2006 12:51	30.3	
6/5/2006 12:52	42.9	
6/5/2006 12:53	45.9	
6/5/2006 12:54	48.1	
6/5/2006 12:55	49.6	
	<<50.2 ppm CO	
6/5/2006 12:56	49.9	
	49.8	<average
6/5/2006 12:57	47.9	
6/5/2006 12:58	28.6	
6/5/2006 12:59	3.8	

Progress Energy , Crystal River Complex  
No. 5 FFSG , EU 003  
PRB Fuel Burn Trials ( Normal Coal Burn baseline Emission Measurements)

Date	Time	CO ppmv
6/5/2006	13:05	-1.3
6/5/2006	13:06	-1.5
6/5/2006	13:07	-1.0 << Start Run 3
6/5/2006	13:08	-1.5
6/5/2006	13:09	-1.3
6/5/2006	13:10	-1.0
6/5/2006	13:11	-1.0
6/5/2006	13:12	-1.3
6/5/2006	13:13	-1.3
6/5/2006	13:14	-1.0
6/5/2006	13:15	-1.5
6/5/2006	13:16	-1.5
6/5/2006	13:17	-1.5
6/5/2006	13:18	-1.3
6/5/2006	13:19	-1.3
6/5/2006	13:20	-1.5
6/5/2006	13:21	-1.3
6/5/2006	13:22	-1.8
6/5/2006	13:23	-1.5
6/5/2006	13:24	-1.5
6/5/2006	13:25	-1.5
6/5/2006	13:26	-1.8
6/5/2006	13:27	-1.8
6/5/2006	13:28	-1.5
6/5/2006	13:29	-1.3
6/5/2006	13:30	-1.3
6/5/2006	13:31	-1.8
6/5/2006	13:32	-1.5
6/5/2006	13:33	-1.5
6/5/2006	13:34	-1.5
6/5/2006	13:35	-1.5
6/5/2006	13:36	-1.5
6/5/2006	13:37	-1.5
6/5/2006	13:38	-0.8
6/5/2006	13:39	-1.5
6/5/2006	13:40	-1.5
6/5/2006	13:41	-1.5
6/5/2006	13:42	-1.8
6/5/2006	13:43	-1.8
6/5/2006	13:44	-1.5
6/5/2006	13:45	-1.5
6/5/2006	13:46	-1.8
6/5/2006	13:47	-1.5
6/5/2006	13:48	-2.0
6/5/2006	13:49	-1.5
6/5/2006	13:50	-2.0
6/5/2006	13:51	-1.3

6/5/2006 13:52	-1.8
6/5/2006 13:53	-1.8
6/5/2006 13:54	-1.5
6/5/2006 13:55	-1.3
6/5/2006 13:56	-2.0
6/5/2006 13:57	-1.8
6/5/2006 13:58	-1.5
6/5/2006 13:59	-1.0
6/5/2006 14:00	-1.3
6/5/2006 14:01	-1.5
6/5/2006 14:02	-2.0
6/5/2006 14:03	-1.8
6/5/2006 14:04	-1.5
6/5/2006 14:05	-1.5
6/5/2006 14:06	-1.5
6/5/2006 14:07	-1.5
6/5/2006 14:08	-1.8
6/5/2006 14:09	-1.3
6/5/2006 14:10	-0.5
6/5/2006 14:11	-0.8
6/5/2006 14:12	-0.5
6/5/2006 14:13	-0.3
6/5/2006 14:14	0.0
6/5/2006 14:15	10.8
6/5/2006 14:16	35.9
6/5/2006 14:17	43.4
6/5/2006 14:18	46.1
6/5/2006 14:19	47.6
6/5/2006 14:20	49.1
6/5/2006 14:21	49.9
6/5/2006 14:22	49.9
6/5/2006 14:23	49.4

Run 3 CO ppm

<< End Run 3	-1.5	Average
--------------	------	---------

<<Zero air

-0.1	<average
------	----------

<<50.2 ppm CO

49.9	<average
------	----------

**Field and Laboratory Data Sheets**

Particulate Matter

# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Unit 5

Control Type: ESP

Sample Type: RP Part

Date: 6-6-06

Run No.: 1

Time Start: 1017

Time End: 1124

Sample Time: 5

min/point 60 Total Mins.

Dry Bulb: °F

Wet Bulb: °F VP@DP:

Bar. Pres: 30.13 "Hg

Stack Pres: 30.06 "Hg Ps: 0.97 "H<sub>2</sub>O

Moisture: 8 %

FDA: Gas Density Factor:

Temp: 85 °F

Wind Direction: — Wind Speed: —

Weather: Clear

Thermocouple Readout: KAK-7

Sample Box No: KA7

Meter Box No.: KA-7

Meter Y: 0.993 @

Delta H: 1.55 Pitot Corr.: 0.84

Nozzle Diameter: 0.214 inches

Probe Length: 10.11 feet

Probe Heater Setting: 320

Nomograph Cf: 1.27

Stack Dimensions:

308 inches

Stack Area:

517.4 ft<sup>2</sup>

Effective Stack Area:

517.4 ft<sup>2</sup>

Stack Height:

ft

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			17.0	1.5	1.91	1.91	298		72	96	4	
2			21.2	1.4	1.78	1.78	298		64	97	3	
3			25.3	1.4	1.78	1.78	298		62	98	3	
2-1			29.2	1.4	1.78	1.78	296		66	99	3	
2			33.1	1.4	1.78	1.78	298		60	101	3	
3			37.2	1.4	1.78	1.78	297		59	102	3	
3-1			41.2	1.4	1.78	1.78	297		60	103	3	
2			45.3	1.4	1.78	1.78	298		56	104	3	

Material Processing Rate:

Final Gas Meter Reading: 765,300 ft<sup>3</sup>

Initial Gas Meter Reading: 717,000 ft<sup>3</sup>

Total Metered Gas Volume: 48,300 ft<sup>3</sup>

Condensate Gain in Impingers: 74 mL

Weight Gain in Silica Gel: 71 g

Total Moisture Gain: 85 mL

Silica Gel Container No.: 701

Filter Number: 1

#### Leak Check - Meter Box:

Initial: 0.003 cfm @ 15 inches Hg

Final: 0.000 cfm @ 5 inches Hg

#### Leak Check - Pitot Tubes:

Impact 3 "H<sub>2</sub>O for 15 sec Stable Leak

Static 3 "H<sub>2</sub>O for 15 sec Stable Leak

Test Conducted By: R Paul-A-West

O<sub>2</sub>: 4.5 % CO<sub>2</sub>: 10.5 %

Pitot Tube: KASSI Stack Test Observers:





# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Unit 5

Control Type: EDP

Sample Type: RP Part

Date: 10-6-06 Run No.: 2

Time Start: 1142 Time End: 1249

Sample Time: 5 min/point 60 Total Mins.

Dry Bulb: 70.12 °F Wet Bulb: 68 °F VP@DP:

Bar. Pres: 30.06 "Hg Stack Pres: 30.06 "Hg Ps: 0.97 "H<sub>2</sub>O

Moisture: 8 % FDA: Gas Density Factor:

Temp: 85 °F Wind Direction: — Wind Speed: —

Weather: clear Thermocouple Readout: KAK-7

Sample Box No.: KA-7 Meter Box No.: KA-7

Meter Y: 0.993 @ Delta H: 1.55 Pitot Corr.: 0.84

Nozzle Diameter: 0.41 inches Probe Length: 10.25 feet

Probe Heater Setting: 320 Nomograph Cf: 1.3

Stack Dimensions: 30.8 inches

Stack Area: 517.4 ft<sup>2</sup>

Effective Stack Area: 517.4 ft<sup>2</sup>

Stack Height: ft

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			65.6	1.4	1.82	1.82	298	74	106	3		
2			69.9	1.4	1.82	1.82	298	63	107	3		
3			74.1	1.1	1.43	1.43	297	59	107	2		
2-1			77.7	1.2	1.56	1.56	299	66	109	3		
2			81.6	1.4	1.82	1.82	299	56	108	3		
3			85.6	1.2	1.56	1.56	297	53	109	3		
3-1			89.5	1.6	2.08	2.08	297	57	109	4		
2			93.9	1.6	2.08	2.08	298	51	110	4		

Stack Dimensions	Material Processing Rate:	
	Final Gas Meter Reading:	<u>815.230</u> ft <sup>3</sup>
	Initial Gas Meter Reading:	<u>765.600</u> ft <sup>3</sup>
	Total Metered Gas Volume:	<u>49.63</u> ft <sup>3</sup>
	Condensate Gain in Impingers:	<u>74</u> mL
	Weight Gain in Silica Gel:	<u>7</u> g
	Total Moisture Gain:	<u>83</u> mL
	Silica Gel Container No.:	<u>29</u>
	Filter Number:	<u>2</u>

Leak Check - Meter Box:  
 Initial: 0.001 cfm @ 10 inches Hg  
 Final: 0.022 cfm @ 5 inches Hg

Leak Check - Pitot Tubes:  
 Impact 3 "H<sub>2</sub>O for 15 sec. Stable, Leak  
 Static 3 "H<sub>2</sub>O for 15 sec. Stable, Leak

Test Conducted By: R Paul A West  
 O<sub>2</sub>: 4.0 % CO<sub>2</sub>: 10.5 %

Stack Test Observers:



# Multiple Methods Data Sheet

Plant: Progress Energy - Crystal River

Sample Location: Line 5

Control Type: EAP

Sample Type: PP Port

Date: 6-5-06

Run No.: 3

Time Start: 1307

Time End: 1413

Sample Time: 5

min/point 100 Total Mins.

Dry Bulb:

°F

Wet Bulb:

°F VP@DP:

Bar. Pres: 30.13

"Hg

Stack Pres: 30.06

"Hg Ps: 20.97

"H<sub>2</sub>O

Moisture:

%

FDA: Gas Density Factor:

Temp: 85

°F

Wind Direction: — Wind Speed: —

Weather: Clear

Thermocouple Readout:

XAH-7

Sample Box No: XAH

Meter Box No.:

XAH

Meter Y: 0.993

@ Delta H:

1.55 Pitot Corr.: 0.84

Nozzle Diameter: 0.214

inches

Probe Length: 10.25

feet

Probe Heater Setting: 320

Nomograph Cf: 1.3

Stack Dimensions:

30.8

inches

Stack Area:

51.74

ft<sup>2</sup>

Effective Stack Area:

51.74

ft<sup>2</sup>

Stack Height:

ft

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			15.5	1.3	1.69	1.69	296	()	75	109	3	
2			19.4	1.3	1.69	1.69	299		60	109	3	
3			23.3	1.1	1.43	1.43	298		58	110	3	
2-1			26.9	1.5	1.95	1.95	297		60	110	3	
2			31.3	1.5	1.95	1.95	299		53	110	3	
3			35.5	1.4	1.82	1.82	298		52	111	3	
3-1			39.6	1.4	1.82	1.82	298		56	111	3	
2			43.8	1.2	1.56	1.56	299		52	111	3	

Material Processing Rate:

863,600 ft<sup>3</sup>

Final Gas Meter Reading:

815,500 ft<sup>3</sup>

Initial Gas Meter Reading:

48,100 ft<sup>3</sup>

Total Metered Gas Volume:

48,100 ft<sup>3</sup>

Condensate Gain in Impingers:

80 mL

Weight Gain in Silica Gel:

9 g

Total Moisture Gain:

89 mL

Silica Gel Container No.:

339

Filter Number:

3

### Leak Check - Meter Box:

Initial 0.002 cfm @ 10 inches Hg

Final: 0.000 cfm @ 5 inches Hg

### Leak Check - Pitot Tubes:

Impact 3 "H<sub>2</sub>O for 15 sec Stable Leak

Static 3 "H<sub>2</sub>O for 15 sec Stable Leak

Umbilical: XAH-100

Thermocouple

Probe No. XAH-110

Pitot Tube: XAH-SS1

Test Conducted By: R Paul A West

O<sub>2</sub>: 4.0 % CO<sub>2</sub>: 11.0 %

Stack Test Observers:



ENVIRONMENTAL SERVICES



SAMPLING RATE CALCULATIONS

Date:

RP

6-6-06

Plant Name/Location:

Progress Energy  
Crystal River

Source:

Unit 5

1) Calculate the optimum Cf:

$$\Delta H @ / \Delta P_{avg} = Cf$$

$\Delta H$	$/ \Delta P_{avg}$	$= Cf$

2) Calculate the optimum nozzle size:

Record Values		
R1	R2	R3
90	110	
008	008	
28.1	28.1	
295		
1.55		
1.214		

Tm = Meter Temperature ( °F ) (Add 5 °F for initial temp.)

Bw = Moisture Fraction

Ms = Wet Molecular Weight of Stack Gas (from Table)

Ts = Stack Temperature ( °F )

$\Delta H@$  = Meter Box Constant (box front)

$\Delta P$  = Average Pitot Reading (Inches H20)

Dn = Nozzle Diameter (Inches) measured

Moisture Fraction	MS
0	29
0.05	28.5
0.1	27.9
0.15	27.4
0.2	26.8
0.25	26.2
0.3	25.7
0.35	25.2
0.4	24.6

$$Dn = \left[ \frac{Cf}{\left( \frac{Tm+460}{Ms*(Ts+460)} \right) * \left( 1 - \frac{Bw}{100} \right)^2 * (\Delta H @) * (1774)} \right]^{0.25}$$

3) Calculate the correction factor Cf. Cf times the stack  $\Delta P$  will determine the manometer setting  $\Delta H$ :

$$Cf = \left[ \frac{Tm+460}{Ms*(Ts+460)} \right] * (1 - Bw)^2 * \Delta H @ * Dn^4 * 1774 \quad Cf * \Delta P = \Delta H$$

Calculation	Run No. 1	Run No. 2	Run No. 3
Tm + 460 =	550	570	
/ [MS*(Ts+460)] =	82895		
* (1 - Bw) <sup>2</sup> =	0.8464		
* $\Delta H @$ =	1.55		
* $(Dn)^4$ =	0.002097		
* 17741 = Cf	1.27	1.3	

## Chain of Custody

Plant Name: Progress Energy Project Number: \_\_\_\_\_

Location: Crystal River      Source: Units

Sampled by: R Paul Date: 6/6/06 Time: See notes

Relinquished by: \_\_\_\_\_

Received by: \_\_\_\_\_

Relinquished by: \_\_\_\_\_

**Laboratory:** R Paul    **Received by:** 6-6-06    **Date:** 10:30    **Time:**

Sample Shipped Via:  UPS  Federal Express  Other

Shipping Bill Number:



# Particulate Lab Data Sheet

Test Date: 6-5-06

Plant Name: PE-Crystal River

Source: Unit 5

	Run No. 1	Run No. 2	Run No. 3	Blank
Container No.	XXX	2	713	666
Total Volume (ml)	75	75	75	50
Aliquot Evaporated (ml)	75	75	75	50
Final Weight (g)	114.8401	113.8749	112.4788	110.0225
Tare Weight (g)	114.8391	113.8743	112.4783	110.0222
Gross Weight Gained (g)	0.0010	0.0006	0.0005	0.0003
Average Blank (g)	—	—	—	
Net Weight (g)	0.0010	0.0006	0.0005	
Aliquot Factor	x 1.0	x 1.0	x 1.0	x
Total Net Weight (mg)	1.0	0.6	0.5	

Container No.	1-A	2-A	3-A	3-P
Filter No.	4436	4437	4438	4435
Final Weight (g)	0.1258	0.1272	0.1277	0.1224
Tare Weight (g)	0.1218	0.1222	0.1230	0.1228
Gross Weight Gained	0.0040	0.0050	0.0047	0.0004
Average Blank (g)	—	—	—	
Total Net Weight (mg)	4.0	5.0	4.7	

## Tare Balance Check

0.0        10.0         
 1.0        50.0         
 5.0        100.0         
 T/H 77-45

R Paul

Signature

6-2-06

Date

## Final Balance Check

0.0        10.0         
 1.0        50.0         
 5.0        100.0         
 T/H 77-43

R Paul

Signature

6-6-06

Date

## Carbon Monoxide

PLANT Progress Energy DATE 06/05/06  
LOCATION Crystal River, FL INST. RANGE 0-500 (202)  
EMISSION UNIT Unit No. 5 LEAK CHECK 0.0" Hg  
TEST Carbon Monoxide M10 NOTES \_\_\_\_\_

TIME	GAS	TIME	GAS
08:50	Zero air on		
08:55	Zero air = 0.5		
08:57	195 CO on		
09:05	195 CO = 195.3		
09:08	99.1 CO on		
09:13	99.1 = 99		
09:24	50.2 CO on		
09:28	50.2 CO = 49		
09:31	Zero air on		
09:35	Zero air = -0.05		
10:17	Start Run #1		
11:19	Zero air on End Run #1		
11:24	Zero air = 0		
11:27	50.2 CO on		
11:31	50.2 CO = 48		
11:42	Start Run #2		
12:42	End Run #2		
12:43	Zero air on		
12:47	Zero air = 0.8		
12:50	50.2 CO on		
12:54	50.2 CO = 48		
13:07	Start Run #3		
14:07	End Run #3		
14:08	Zero air on		
14:12	Zero air = 0		
14:15	50.2 CO on		
14:20	50.2 CO = 48.3		

**Sampling Equipment Calibration Records**

# Nozzle Calibration

Date: 6-5-06

Plant Name: Progress Energy


Location: Crystal River

Source: Unit 5

Measurement Number	Inside Diameter (inches)
1	0.215
2	0.213
3	0.214
Average	0.214
Area of Nozzle	0.000249 Ft. <sup>2</sup>

Calibrated by:

R Paul



Nozzle X-Section

# Pitot Tube Calibration Measurements

Pitot Tube Identification Number: SSI

Date Calibrated: 12-15-05

Pitot Tube Assembly Level: Yes  No

Pitot Tube Openings Damaged: Yes  No  If yes, please explain: \_\_\_\_\_

$$Dt_A = 0.371 \text{ in. } (Dt_A = 0.1875 - 0.3750 \text{ in.})$$

$$Dt_B = 0.372 \text{ in. } (Dt_B = 0.1875 - 0.3750 \text{ in.})$$

$$\alpha_A = 15^\circ (< 10^\circ) \quad \alpha_B = 15^\circ (< 10^\circ)$$

$$\beta_A = 25^\circ (< 5^\circ) \quad \beta_B = 15^\circ (< 5^\circ)$$

$$\gamma = 0.5^\circ, \theta = 0.5^\circ,$$

$$P_A = 0.465 \quad (P_A = 1.05 Dt \text{ to } 1.50 Dt)$$

$$P_B = 0.466 \quad (P_B = 1.05 Dt \text{ to } 1.50 Dt)$$

$$P_A + P_B = A = 0.930 \quad [A = 2x(1.05 Dt \text{ to } 1.50 Dt)]$$

$$Z = A \sin \gamma = <0.01 \text{ in. } (<0.125 \text{ in.})$$

$$W = A \sin \theta = <0.01 \text{ in. } (<0.031 \text{ in.})$$

Comments:

Pitot tubes looked OK day of test

Calibration required? Yes  No

Calibrated by: R Paul

# Post Test Thermocouple Calibration

Date: 6-6-06

Plant Name: Progress Energy

Location: Crystal River

Source: Unit 5

Thermocouple Readout No.	KAK-7
Umbilical Cord No.	KAK-108
Switch Box No.	KAK-7
Thermocouple No.	KAK-110
Average Stack Temperature °F	298
* Observed Mercury in Glass (ASTM) °F	298
Observed Thermocouple Reading °F	298

\* Observed temperature must be within ten percent of the average stack temperature.

$$\text{Percent Difference } \frac{(\text{ASTM} + 460) - (\text{Thermo} + 460)}{(\text{ASTM} + 460)} \times 100 = 0.0\%$$

Tolerance  $\leq 1.5\%$

Signature: R Paul

**POST-TEST DRY GAS METER CALIBRATION USING CRITICAL ORIFICES**

- 1) Select one critical orifice to calibrate the dry gas meter which represents the observed operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

**Koogler & Associates  
Environmental Services**

**COMPANY:** Progress Energy

**SOURCE:** Unit#S

**DATE:** 6/5/06

**PRETEST Y:** 0.993

METER SERIAL #:	KA-7
CRITICAL ORIFICE SERIAL #:	1376-22

INITIAL	FINAL	Avg (P <sub>bar</sub> )
29.92	29.92	29.92

RUN NO.	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT')			TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>e</sub>		
				INITIAL	FINAL	NET (V <sub>m</sub> )	AMBIENT	INITIAL	FINAL	INITIAL	FINAL							
1	22	0.5836	18	863.927	870.011	6.084	76	77	78	78	78	78	8.0	1.6	6.00	6.04	1.006	1.581
2	22	0.5836	18	870.011	875.365	5.354	77	78	79	79	79	79	7.0	1.6	5.27	5.28	1.001	1.584
3	22	0.5836	18	875.365	882.259	6.894	78	79	80	79	80	80	9.0	1.6	6.77	6.78	1.000	1.587
AVG = 1.003																		

**USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:**

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) \quad V_m(\text{std}) = K_1 V_m Y \left[ \frac{P_{\text{bar}} + (\Delta H / 136)}{T_m} \right]$$

V<sub>m</sub>(std) = Net volume of gas sample passed through DGM, corrected to standard conditions.

K<sub>1</sub> = 17.64 °R/in. Hg

Y = DGM calibration factor

V<sub>cr</sub>(std) = Volume of gas sample passed through the critical orifice, corrected to standard conditions.

P<sub>bar</sub> = Barometric pressure at the sampling site (in. Hg).

ΔH = Orifice pressure differential (in. H<sub>2</sub>O).

θ = Total sampling time (min.)

T<sub>m</sub> = Absolute DGM avg. temperature °R

T<sub>amb</sub> = Absolute ambient temperature °R

K' = Average K' factor from Critical Orifice Calibration

$$(2) \quad V_{cr}(\text{std}) = K \left[ \frac{P_{\text{bar}} \theta}{\sqrt{T_{\text{amb}}}} \right]$$

$$(3) \quad Y = \frac{V_{cr}(\text{std})}{V_m(\text{std})}$$

$$(4) \quad \Delta H_{@} = \left( \frac{0.75 * \theta}{V_{cr}(\text{std})} \right)^2 * \Delta H$$

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 1.003

AVERAGE DELTA Y = 0.010

DELTA Y LIMIT = 0.05

IS TEST WITHIN 5%? YES

## BEST AVAILABLE COPY

FIELD DATA SHEET: POST-TEST DRY GAS METER CALIBRATION  
USING CRITICAL ORIFICESKoogler & Associates  
Environmental Services

- 1) Select one critical orifice to calibrate the dry gas meter which approximates the test average delta H range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below.

COMPANY: Progress Energy "Crystal River"  
 SOURCE: Unit #3  
 TEST DATE: 6/3/06  
 METER Y: 0.993  
 AVG. DELTA H: 1.55

METER SERIAL #: KA-7  
 CRITICAL ORIFICE SERIAL #: 1376-22

INITIAL      FINAL

BAROMETRIC PRESSURE (in Hg): 29.92      29.92

RUN	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)
				INITIAL	FINAL	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL			
1	22	0.5836	18	863.927	870.011	76	77	78	77	78	8.0
2	22	0.5836	18	870.011	875.365	77	78	79	78	79	7.0
3	22	0.5836	18	875.365	882.259	78	79	80	79	80	9.0

Test Conducted by: ADAM WEST  
 Signature: Adam West  
 Date: 6/6/06

## METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.



ENVIRONMENTAL SUPPLY COMPANY

DATE: 5-16-06		METER SERIAL #: KA-7		BAROMETRIC PRESSURE (in Hg): 29.94		INITIAL	FINAL	AVG (P <sub>bar</sub> )	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED									
METER PART #: KA-7		CRITICAL ORIFICE SET SERIAL #: 1376																
ORIFICE #	RUN #	K' FACTOR	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	Y VARIATION (%)	ΔH@	
				INITIAL	FINAL	NET (V <sub>m</sub> )	AMBIENT INITIAL FINAL	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL	DGM AVG								
17	1	0.4505	18	667.90	674.506	6.606	77 77	79 79	79 80	79 80	79 79.5	11.00 12.00	0.94 0.94	6.4916 7.0629	6.4044 6.9866	0.987 0.989	1.53 1.53	
	2	0.4505	18	674.506	681.70	7.194								6.7856	6.6955	0.987	1.53	
	3	0.4505	18	681.70	688.618	6.918	77 77	80 80	80 80	80 80	80 80	11.50 11.50	0.94 0.94				AVG = 0.987	-0.52
22	1	0.5836	18	617.602	622.955	5.353	75 75	72 73	73 74	72 73	73 73.5	7.00 9.50	1.6 1.6	5.3332 7.2454	5.2895 7.1786	0.992 0.991	1.57 1.57	
	2	0.5836	18	622.955	630.241	7.286								6.0794	6.0451	0.994	1.56	
	3	0.5836	18	630.241	636.366	6.125	75 75	74 75	75 74	75 75	74.5 74.5	8.00 8.00	1.6 1.6				AVG = 0.992	-0.04
26	1	0.7142	18	688.90	696.396	7.496	75 75	77 77	77 78	77 78	77 78	8.00 11.50	2.4 2.4	7.4201 10.7420	7.3979 10.6345	0.997 0.990	1.56 1.56	
	2	0.7142	18	696.396	707.258	10.862								8.7192	8.7850	1.008	1.56	
	3	0.7142	18	707.258	716.229	8.833	75 75	78 79	79 78	78 79	78.5 78.5	9.50 9.50	2.4 2.4				AVG = 0.998	0.56

### USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.993

AVERAGE ΔH@ = 1.55

$$(1) \quad V_{m(\text{std})} = K_1 * V_m * \frac{P_{\text{bar}} + (\Delta H / 13.6)}{T_m}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions  
 $K_1 = 17.64^{\circ}\text{R}/\text{in. Hg}$  (English),  $0.3858^{\circ}\text{K}/\text{mm Hg}$  (Metric)

$T_m$  = Absolute DGM avg. temperature ( $^{\circ}\text{R}$  - English,  $^{\circ}\text{K}$  - Metric)

$$(2) \quad V_{cr(\text{std})} = K' * \frac{P_{\text{bar}} * \Theta}{\sqrt{T_{\text{amb}}}}$$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions  
 $T_{\text{amb}}$  = Absolute ambient temperature ( $^{\circ}\text{R}$  - English,  $^{\circ}\text{K}$  - Metric)

$K'$  = Average K' factor from Critical Orifice Calibration

$$(3) \quad Y = \frac{V_{cr(\text{std})}}{V_{m(\text{std})}}$$

= DGM calibration factor

$$\Delta H@ = \left( \frac{0.75 \Theta}{V_{cr(\text{std})}} \right)^2 \Delta H \left( \frac{V_{m(\text{std})}}{V_m} \right)$$

**KOOGLER & ASSOCIATES, Inc.**  
**THERMOCOUPLE CALIBRATION**

Probe ID	"K" TYPE									Average % Δ	Average Δ (F°)		
	Ice			Ambient			Hot Oil						
	NIST (F°)	Probe (F°)	% Δ	NIST (F°)	Probe (F°)	% Δ	NIST (F°)	Probe (F°)	% Δ				
KAK-5							Missing						
KAK-7	32	33	-3.1	74	76	-2.7	251	251	0.0	-1.9	1.0		
KAK-8	32	33	-3.1	73	74	-1.4	251	250	0.4	-1.4	0.3		
KAK-9	32	33	-3.1	72	74	-2.8	257	257	0.0	-2.0	1.0		
KAK-10	32	33	-3.1	74	76	-2.7	251	252	-0.4	-2.1	1.3		
KAK-11	32	34	-6.3	73	73	0.0	274	274	0.0	-2.1	0.7		
KAK-12							Missing						
KAK-20	32	33	-3.1	72	74	-2.8	271	271	0.0	-2.0	1.0		
KAK-33	32	34	-6.3	74	73	1.4	265	265	0.0	-1.6	0.3		
KAK-35	32	34	-6.3	74	74	0.0	260	260	0.0	-2.1	0.7		
KAK-36	32	34	-6.3	72	73	-1.4	276	277	-0.4	-2.7	1.3		
KAK-38	32	34	-6.3	74	75	-1.4	275	275	0.0	-2.5	1.0		
KAK-50	32	33	-3.1	75	76	-1.3	275	274	0.4	-1.4	0.3		
KAK-51	32	34	-6.3	73	75	-2.7	271	272	-0.4	-3.1	1.7		
KAK-52	32	34	-6.3	72	72	0.0	276	276	0.0	-2.1	0.7		
KAK-55	32	32	0.0	71	73	-2.8	276	276	0.0	-0.9	0.7		
KAK-60	32	34	-6.3	73	74	-1.4	264	265	-0.4	-2.7	1.3		
KAK-61	32	34	-6.3	73	72	1.4	267	268	-0.4	-1.8	0.7		
KAK-63	32	34	-6.3	73	74	-1.4	273	274	-0.4	-2.7	1.3		
KAK-65	32	33	-3.1	72	72	0.0	277	280	-1.1	-1.4	1.3		
KAK-71	32	34	-6.3	75	76	-1.3	279	281	-0.7	-2.8	1.7		
KAK-72	32	33	-3.1	72	74	-2.8	275	277	-0.7	-2.2	1.7		
KAK-76	32	35	-9.4	73	75	-2.7	275	275	0.0	-4.0	1.7		
KAK-110	32	33	-3.1	72	71	1.4	276	276	0.0	-0.6	0.0		
KAK-112	32	33	-3.1	72	73	-1.4	275	274	0.4	-1.4	0.3		
KAK-72-A	32	33	-3.1	72	74	-2.8	275	277	-0.7	-2.2	1.7		

DATE: 8/16/2005

TESTER: G.Haven and E.Thomas

## Certificate of Analysis: EPA Protocol Gas Mixture

Cylinder Number: SG9114880 Reference Number: 82-124051838-1  
Cylinder Pressure: 2000.6 PSIG Expiration Date: 12/9/2008  
Certification Date: 12/9/2005 Laboratory: ASG - Riverton - NJ

**Airgas Specialty Gases**  
600 Union Landing Road  
Riverton, NJ 08077  
(856) 829-7878  
Fax (856) 829-0571  
[www.airgas.com](http://www.airgas.com)

### Certified Concentrations

Component	Concentration	Accuracy	Analytical Principle	Procedure
PROPANE	49.2 PPM	+/- 1%	FID	G1
CARBON MONOXIDE	50.15 PPM	+/- 1%	NDIR	G1
NITROGEN	Balance			

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.  
Analytical Methodology does not require correction for analytical interferences.

### Notes:

Do not use cylinder below 150 psig.

Approval Signature 

### Reference Standard Information

Type	Balance Gas	Component	Cyl.Number	Concentration
NTRM 81678	NITROGEN	CARBON MONOXIDE	XC013124B	49.59 PPM
NTRM 81667	AIR	PROPANE	XC019582B	48.1 PPM

### Analytical Results

#### 1st Component

		PROPANE	
1st Analysis Date:	12/02/2005		
R 15183	S 15573	Z 0000	Conc 49.3 PPM
S 15571	Z 0000	R 15177	Conc 49.3 PPM

#### 2nd Component

		CARBON MONOXIDE	
1st Analysis Date:	12/02/2005	2nd Analysis Date:	12/02/2005
R 15183	S 15573	R 5.113	S 5.154
S 15571	Z 0000	S 5.156	Z 1.041
Z 0000	R 15220	Z 1.036	R 5.111
AVG: 49.2 PPM		AVG: 50.04 PPM	
		2nd Analysis Date:	
		R 4.969	S 5.028
		S 5.028	Z 1.019
		Z 1.018	R 4.976
		AVG: 50.27 PPM	

**Certificate of Analysis: EPA Protocol Gas Mixture**

Cylinder Number: CC16342 Reference Number: 82-124051837-1  
Cylinder Pressure: 2000.6 PSIG Expiration Date: 12/9/2008  
Certification Date: 12/9/2005 Laboratory: ASG - Riverton - NJ

**Airgas Specialty Gases**  
600 Union Landing Road  
Riverton, NJ 08077  
(856) 829-7878  
Fax (856) 829-0571  
[www.airgas.com](http://www.airgas.com)

**Certified Concentrations**

Component	Concentration	Accuracy	Analytical Principle	Procedure
CARBON MONOXIDE	99.1 PPM	+/- 1%	NDIR	G1
PROPANE	99.4 PPM	+/- 1%	FID	G1
NITROGEN	Balance			

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.  
Analytical Methodology does not require correction for analytical interferences.

**Notes:**

Do not use cylinder below 150 psig.

Approval Signature C. Canale DO

**Reference Standard Information**

Type	Balance Gas	Component	Cyl.Number	Concentration
NTRM 81679	NITROGEN	CARBON MONOXIDE	CC97637	98.0 PPM
NTRM 81668	AIR	PROPANE	XC003536B	93.9 PPM

**Analytical Results**

1st Component			2nd Component		
1st Analysis Date:	12/02/2005		1st Analysis Date:	12/02/2005	
R 29551	S 31353	Z 0000	Conc 99.5 PPM	R 2.915	S 2.938
S 31330	Z 0000	R 29588	Conc 99.5 PPM	S 2.937	Z 1.024
Z 0000	R 29586	S 31294	Conc 99.4 PPM	Z 1.025	R 2.915
			AVG: 99.4 PPM		
				2nd Analysis Date:	12/09/2005
				R 2.940	S 2.960
				S 2.961	Z 1.018
				Z 1.020	R 2.940
					Z 0.998
					Conc 99.0 PPM
					R 2.942
					Conc 98.9 PPM
					S 2.967
					Conc 99.4 PPM
					AVG: 99.1 PPM

**Certificate of Analysis: EPA Protocol Gas Mixture**

Cylinder Number: CC218888 Reference Number: 82-124049491-1  
Cylinder Pressure: 2000.6 PSIG Expiration Date: 11/8/2008  
Certification Date: 11/8/2005 Laboratory: ASG - Riverton - NJ

Airgas Specialty Gases  
600 Union Landing Road  
Riverton, NJ 08077  
(856) 829-7878  
Fax (856) 829-0571  
[www.airgas.com](http://www.airgas.com)

**Certified Concentrations**

Component	Concentration	Accuracy	Analytical Principle	Procedure
CARBON MONOXIDE	195.0 PPM	+/- 1%	NDIR	G1
PROPANE	202 PPM	+/- 1%	FID	G1
NITROGEN	Balance			

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.  
Analytical Methodology does not require correction for analytical interferences.

**Notes:**

Do not use cylinder below 150 psig.

Approval Signature C. Caraballo

**Reference Standard Information**

Type	Balance Gas	Component	Cyl.Number	Concentration
NTRM 82636	NITROGEN	CARBON MONOXIDE	XC014219B	246.2 PPM
NTRM 81668	AIR	PROPANE	XC003536B	93.9 PPM

**Analytical Results**

1st Component			2nd Component			CARBON MONOXIDE		
1st Analysis Date:	11/03/2005		1st Analysis Date:			11/01/2005		
R 30674	S 65836	Z 0	Conc 202 PPM	R 1.978	S 1.777	Z 0.999	Conc 195.2 PPM	
S 65852	Z 0	R 30648	Conc 202 PPM	S 1.778	Z 1.002	R 1.978	Conc 195.4 PPM	
Z 0	R 30645	S 65825	Conc 202 PPM	Z 1.002	R 1.978	S 1.776	Conc 194.9 PPM	
			AVG: 202 PPM				AVG: 195.1 PPM	
				2nd Analysis Date:		11/08/2005		
				R 1.965	S 1.767	Z 0.999	Conc 195.3 PPM	
				S 1.768	Z 1.000	R 1.966	Conc 195.3 PPM	
				Z 0.997	R 1.968	S 1.765	Conc 194.1 PPM	
							AVG: 194.9 PPM	

**Certificate of Analysis: EPA Protocol Gas Mixture**

Cylinder Number: SG9114880 Reference Number: 82-124051838-1  
Cylinder Pressure: 2000.6 PSIG Expiration Date: 12/9/2008  
Certification Date: 12/9/2005 Laboratory: ASG - Riverton - NJ

**Airgas Specialty Gases**  
600 Union Landing Road  
Riverton, NJ 08077  
(856) 829-7878  
Fax (856) 829-0571  
[www.airgas.com](http://www.airgas.com)

**Certified Concentrations**

Component	Concentration	Accuracy	Analytical Principle	Procedure
PROPANE	49.2 PPM	+/- 1%	FID	G1
CARBON MONOXIDE	50.15 PPM	+/- 1%	NDIR	G1
NITROGEN	Balance			

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.  
Analytical Methodology does not require correction for analytical interferences.

**Notes:**

Do not use cylinder below 150 psig.

Approval Signature 

**Reference Standard Information**

Type	Balance Gas	Component	Cyl.Number	Concentration
NTRM 81678	NITROGEN	CARBON MONOXIDE	XC013124B	49.59 PPM
NTRM 81667	AIR	PROPANE	XC019582B	48.1 PPM

**Analytical Results**

1st Component		PROPANE		2nd Component		CARBON MONOXIDE	
1st Analysis Date:	12/02/2005	R 15183	Z 0000	Conc 49.3 PPM	R 5.113	S 5.154	Z 1.039
S 15571	Z 0000	R 15177	R 15522	Conc 49.3 PPM	S 5.156	Z 1.041	Conc 50.01 PPM
Z 0000	R 15220	S 15522	AVG: 49.2 PPM	Conc 49.1 PPM	Z 1.036	R 5.111	Conc 50.03 PPM
							Conc 50.08 PPM
							AVG: 50.04 PPM
				2nd Analysis Date:	12/09/2005		
				R 4.969	S 5.028	Z 1.010	Conc 50.31 PPM
				S 5.028	Z 1.019	R 4.973	Conc 50.27 PPM
				Z 1.018	R 4.976	S 5.029	Conc 50.24 PPM
							AVG: 50.27 PPM

## Certificate of Analysis: EPA Protocol Gas Mixture

Cylinder Number: CC16342 Reference Number: 82-124051837-1  
Cylinder Pressure: 2000.6 PSIG Expiration Date: 12/9/2008  
Certification Date: 12/9/2005 Laboratory: ASG - Riverton - NJ

**Airgas Specialty Gases**  
600 Union Landing Road  
Riverton, NJ 08077  
(856) 829-7878  
Fax (856) 829-0571  
[www.airgas.com](http://www.airgas.com)

### **Certified Concentrations**

Component	Concentration	Accuracy	Analytical Principle	Procedure
CARBON MONOXIDE	99.1 PPM	+/- 1%	NDIR	G1
PROPANE	99.4 PPM	+/- 1%	FID	G1
NITROGEN	Balance			

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.  
Analytical Methodology does not require correction for analytical interferences.

### Notes:

Do not use cylinder below 150 psig.

Approval Signature C. Canaballar

### **Reference Standard Information**

Type	Balance Gas	Component	Cyl.Number	Concentration
NTRM 81679	NITROGEN	CARBON MONOXIDE	CC97637	98.0 PPM
NTRM 81668	AIR	PROPANE	XC003536B	93.9 PPM

### **Analytical Results**

1st Component			2nd Component		
PROPANE			CARBON MONOXIDE		
1st Analysis Date:	12/02/2005		1st Analysis Date:	12/02/2005	
R 29551	S 31353	Z 0000	R 2.915	S 2.938	Z 1.003
S 31330	Z 0000	R 29588	S 2.937	Z 1.024	R 2.915
Z 0000	R 29586	S 31294	Z 1.025	R 2.915	S 2.938
Conc 99.5 PPM			Conc 99.1 PPM		
AVG: 99.4 PPM			Conc 99.1 PPM		
			AVG: 99.1 PPM		
			2nd Analysis Date:	12/09/2005	
			R 2.940	S 2.960	Z 0.998
			S 2.961	Z 1.018	R 2.942
			Z 1.020	R 2.940	S 2.967
			Conc 99.0 PPM		
			Conc 98.9 PPM		
			Conc 99.4 PPM		
			AVG: 99.1 PPM		

**Certificate of Analysis: EPA Protocol Gas Mixture**

Cylinder Number: CC218888 Reference Number: 82-124049491-1  
Cylinder Pressure: 2000.6 PSIG Expiration Date: 11/8/2008  
Certification Date: 11/8/2005 Laboratory: ASG - Riverton - NJ

Airgas Specialty Gases  
600 Union Landing Road  
Riverton, NJ 08077  
(856) 829-7878  
Fax (856) 829-0571  
[www.airgas.com](http://www.airgas.com)

**Certified Concentrations**

Component	Concentration	Accuracy	Analytical Principle	Procedure
CARBON MONOXIDE	195.0 PPM	+/- 1%	NDIR	G1
PROPANE	202 PPM	+/- 1%	FID	G1
NITROGEN	Balance			

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed.  
Analytical Methodology does not require correction for analytical interferences.

**Notes:**

Do not use cylinder below 150 psig.

Approval Signature C. Caraballo

**Reference Standard Information**

Type	Balance Gas	Component	Cyl.Number	Concentration
NTRM 82636	NITROGEN	CARBON MONOXIDE	XC014219B	246.2 PPM
NTRM 81668	AIR	PROPANE	XC003536B	93.9 PPM

**Analytical Results**

1st Component			2nd Component		
PROPANE			CARBON MONOXIDE		
1st Analysis Date:	11/03/2005		1st Analysis Date:	11/01/2005	
R 30674	S 65836	Z 0	Conc 202 PPM	R 1.978	S 1.777
S 65852	Z 0	R 30648	Conc 202 PPM	S 1.778	Z 1.002
Z 0	R 30645	S 65825	Conc 202 PPM	Z 1.002	R 1.978
			AVG: 202 PPM		
				2nd Analysis Date:	11/08/2005
				R 1.965	S 1.767
				S 1.768	Z 1.000
				Z 0.997	R 1.968
				Z 0.999	Conc 195.2 PPM
				R 1.978	Conc 195.4 PPM
				S 1.776	Conc 194.9 PPM
					AVG: 195.1 PPM
				R 1.966	Conc 195.3 PPM
				S 1.765	Conc 194.1 PPM
					AVG: 194.9 PPM

**Plant Operating Data**

**Progress Energy**  
**Unit 5**

DATE: 6/5/06	Run 1	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-6	Tons/hr Coal 1-5	
time start	10:13	30515	314875	407796	258416	448497	438810			
time stop	11:25	30576	314935	407854	258476	448558	438872	Total	Total	MMBTU/Hr
Total	1:12	61.0	60.0	58.0	60.0	61.0	62.0	362.0	301.67	6870

DATE: 6/5/06	Run 2	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-5	Tons/hr Coal 1-5	
time start	11:42	30583	314943	407861	258481	448563	438877			
time stop	12:45	30632	314991	407908	258530	448612	438927	Total	Total	MMBTU/Hr
Total	1:03	49.0	48.0	47.0	49.0	49.0	50.0	292.0	278.10	6333

DATE: 6/5/06	Run 3	Tons Coal 02	Tons Coal 03	Tons Coal 04	Tons Coal 05	Tons Coal 06	Tons Coal 07	Tons Coal 1-5	Tons/hr Coal 1-5	
time start	13:07	30644	315003	407920	258542	448624	438939			
time stop	14:10	30693	315052	407968	258591	448673	438989	Total	Total	MMBTU/Hr
Total	1:03	49.0	49.0	48.0	49.0	49.0	50.0	294.0	280.00	6376

AVE. % Capacity
97.92

S.L.	Jun-06										As Bunker Samples																	
	Date	Lab #	Mech Hand	Type A/D	# Samp	I.D. Shift	#/1000 Tons	Tonnage	Moisture	Ash	Volatile Matter			Fixed Carbon		Sulfur	BTU/LB	Lbs SO2 /MBTU	MAF BTU	Dry Ash	Dry Sul	Dry Blt	Dry Vol	WT X M	WT X A	WT X V	WT X S	WT X BTU
											#VALUE!																	
4 06/05/06	64324 M	D	70 00:01-08:0	19.5	3,591	9.47	9.08	33.88	47.57	0.67	12004	1.12	14738	10.03	0.74	13260	37.42	34007	32606	121663	2406	43105354						
	64325 M	D	50 08:00-16:0	19.3	2,597	14.74	8.07	30.31	46.88	0.68	11386	1.19	14751	9.47	0.80	13354	35.55	38280	20958	78715	1766	29569442						
	64326 M	D	44 16:00-24:0	8.7	5,066	8.96	8.19	33.31	49.54	0.67	12231	1.10	14763	9.00	0.74	13435	36.59	45391	41491	168748	3394	61962246						

**Crystal River Fossil Plant**  
**Heat Rate Data Collection Form**  
**Unit 5**

Test Identification: Run #1						
Test Date: 6-4-06						
<i>S RP</i>		Coal Feeder Integrators				
HR:MN		502	503	504	505	506
Start Time:	10 : 13	30513	314875	407790	258416	448497
End Time:	11 : 25	30576	314935	407854	258476	448558
Difference:	11:45					
	Unit MWs at Start:		710		Unit MWs at End:	710

Test Identification: Run #2						
Test Date: 6-4-06						
<i>S RP</i>		Coal Feeder Integrators				
HR:MN		502	503	504	505	506
Start Time:	11 : 44	30543	314943	407861	258491	448563
End Time:	12 : 45	30632	314991	407908	258530	448612
Difference:	11:45					
	Unit MWs at Start:		710		Unit MWs at End:	710

Test Identification: Run #3						
Test Date: 6-4-06						
<i>S RP</i>		Coal Feeder Integrators				
HR:MN		502	503	504	505	506
Start Time:	13 : 07	30644	315003	407920	258542	448624
End Time:	11 : 10	30693	315052	407968	258591	448673
Difference:	:					
	Unit MWs at Start:		708		Unit MWs at End:	710

Comments: \_\_\_\_\_

\_\_\_\_\_

## **Project Participants**

## PROJECT PARTICIPANTS

### **Koogler & Associates**

John B. Koogler, Ph.D., P.E.	Project Advisor
Steven Cloutier	Technical Manager
Rodney Paul	Field Test Crew
Glen Haven	Field Test Crew
Adam West	Field Test Crew

### **Progress Energy Florida, Inc.**

Cynthia Wilkinson	Senior Environmental Specialist
James Long	Senior Environmental Specialist

### **Strategic Engineering Technical Services Section**

Dan Donochod, P.E.	Engineer
--------------------	----------



07/18/06

---

Baseline (4/19/06) - CO Test Report

**Carbon Monoxide  
Emissions Test  
Report**

**Progress Energy Florida  
Crystal River, Unit 5  
Crystal River, Florida**

**C.E.M. Solutions Project No. 2670**


**Testing Completed: April 2006**

**Client Purchase Order Number: 49782  
C.E.M. Solutions, Inc Report Number: 20-2670-05-001**

**C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, Florida 34429  
Phone: 352-564-0441**

## **Statement of Validity**

I hereby certify the information and data provided in this emissions test report for tests performed at Progress Energy's Crystal River facility Unit 5, conducted on April 19, 2006 are complete and accurate to the best of my knowledge.



\_\_\_\_\_  
Jeremy A. Johnson  
President  
C.E.M. Solutions, Inc.

## Project Background

Name of Source Owner: Progress Energy

Address of Owner: One Power Plaza  
263 13<sup>th</sup> Avenue South  
St. Petersburg, FL 33701

Source Identification: Oris Code 628  
Facility ID: 0170004  
Emissions Unit 003

Location of Source: Citrus County, Florida

Type of Operation: SIC Code: 4911

Tests Performed: Method 3A – Determination of Oxygen and Carbon Dioxide  
Method 10 – Determination of Carbon Monoxide

Test Supervisor: Mr. Jeremy A. Johnson

Date(s) Tests Conducted: April 19, 2006

Site Test Coordinator: Mr. James T. Long

State Regulatory Observers: No Attendees

## **C.E.M. Solutions, Inc Test Personnel**

Project Field Manager:                   Mr. Jeremy A. Johnson

Test Technicians:                         Mr. Charles Horton  
  Mr. Joseph Conti

## **Table of Contents**

1.0	Introduction .....	1
2.0	Facility Description.....	2
2.1	Process Equipment.....	2
2.2	Regulatory Requirements .....	2
3.0	Test Program/Operating Conditions .....	3
4.0	Test Methods .....	4
4.1	CO and CO <sub>2</sub> Instrument Analyzer Methods.....	4
4.2	Sampling Location/Traverse Points/Test Run Duration .....	5
4.3	Quality Assurance/Quality Control Procedures .....	6
5.0	Test Results .....	7
5.1	Carbon Monoxide .....	7

## **List of Tables**

Table 1:	Summary of EPA Reference Methods and Instrumentation .....	4
Table 2:	Reference Method Instrument Ranges and Calibration Gases.....	5
Table 3:	CO Test Summary .....	8

## **Appendices**

Appendix A:	Facility Operating Data
Appendix B:	Mathematical Equations
Appendix C:	Reference Method Calibration Gas Certificates of Analysis
Appendix D:	Sample Location Diagram
Appendix E:	Reference Method Quality Assurance, Quality Control (QA/QC) Checks
Appendix F:	Reference Method Support Data

## **1.0 Introduction**

Progress Energy, Florida retained C.E.M. Solutions, Inc. to perform air source emissions testing on Unit 5 at its Crystal River facility located in Citrus County, Florida.

The test program was conducted to determine air emissions from the Unit 5 exhaust stack. Target pollutants include the following:

- CO (in ppmvd, lb/MMBtu and lb/hr )
- CO<sub>2</sub> % (used to calculate emissions rates)

The test program and results are presented and discussed in this report.

Mr. James Long of Progress Energy's Environmental Services Section coordinated plant operations throughout the test program. All testing was conducted in accordance with test methods promulgated by the Florida Department of Environmental Protection.

CO test runs were completed during the annual CEMS Relative Accuracy Test Audit.

Crystal River Unit 5's carbon monoxide emissions averaged 5.3 ppmvd, 0.0053 lbs/MMBtu, and 35.21 lbs/hr over the test program.

## **2.0 Facility Description**

Crystal River Unit 5 is a fossil fuel steam generator consisting of a dry bottom wall-fired boiler, rated at 760 MW, 6665 mmBtu/hr. Primary fuel is bituminous coal or a bituminous coal and bituminous coal briquette mixture. Number 2 fuel oil and natural gas may be burned as a startup fuel and for low load flame stabilization.

### **2.1 Process Equipment**

Fossil Fuel Steam Generator, Unit 5 is a pulverized coal, dry bottom, wall-fired boiler. Emissions are controlled from the unit with a high efficiency electrostatic precipitator, manufactured by Combustion Engineering. Emissions are exhausted through a brick and mortar 600 ft. stack.

### **2.2 Regulatory Requirements**

Emissions tests are to be conducted within 90-100 percent of the unit's rated capacity (6665 mmBtu/hr Heat Input) in accordance with permit condition B.1.

### **3.0 Test Program/Operating Conditions**

The test program was conducted to determine the CO emissions from Unit 5 stack while operating at maximum load while firing 100% bituminous coal.

Testing was completed on the April 19, 2006.

During the test program, Unit 5's heat input averaged 6599 mmBtu/hr while operating on 100 percent solid fuel, which correlates to 99 percent of the maximum heat input (6665 mmBtu/hr).

Unit 5's heat input data is located in Appendix A.

Heat input reports were provided by Progress Energy.

## 4.0 Test Methods

All testing was performed in accordance with methods approved by the USEPA and FDEP. The following discusses the methods, as well as quality assurance and sample handling procedures.

### 4.1 CO and CO<sub>2</sub> Instrument Analyzer Methods

CO reference method data was determined using instrument analyzer procedures. In addition, diluent gas concentrations of carbon dioxide (CO<sub>2</sub>) were measured via instrumental methods. CO<sub>2</sub> data was also used to calculate CO emissions in pounds per million Btu. Mathematical equations used to determine calculated emissions standards can be reviewed in Appendix B. Table 1 summarizes the EPA methods and instrumentation:

**Table 1: Summary of EPA Reference Methods and Instrumentation**  
Progress Energy Florida  
Crystal River Energy Complex  
Unit 5

Pollutant	EPA Method	Instrument	Serial Number
CO	10	TEI Model 48C	48C-74094-375
CO <sub>2</sub>	3A	Servomex 1440	1415D/3379

All reference method analyzers used meet or exceed applicable performance specifications detailed in the appropriate method.

Gas samples were continuously extracted from the stack by a gas sample probe heated to approximately 250°F. Samples were then transported to a gas sample conditioner via a heated sample line operating at 250°F or above. The gas sample conditioner lowers the dew point of the sample gas to approximately 5°C through minimum interference heat exchangers. The dry, cool sample is then sent to the gas analyzers, located in the environmentally controlled test trailer for analysis by the reference method analyzers.

Instrument outputs were recorded continuously with a Windows compatible personal computer, compiled into 15 second averages, and stored in a database for future reference.

Instrument ranges and calibration gases were chosen in accordance with each pollutant's applicable EPA method. Instrument ranges and calibration gases used are shown in Table 2:

**Table 2: Reference Method Instrument Ranges and Calibration Gases**  
**Progress Energy Florida**  
**Crystal River Energy Complex**  
**Unit 5**

Pollutant	Test Location	Instrument Span	Calibration Gases <sup>a</sup>
CO	Unit 5	1000 ppm	0.0 ppm CO 293.0 ppm CO 613.0 ppm CO 948.0 ppm CO
CO <sub>2</sub>	Unit 5	20 %	0.0 % CO <sub>2</sub> 10.8 % CO <sub>2</sub> 17.6 % CO <sub>2</sub>

<sup>a</sup> Concentrations of CO and CO<sub>2</sub> are in a balance of purified nitrogen (N<sub>2</sub>). All analyzers were zeroed with ultra high purity N<sub>2</sub>. All calibration gases have been certified to NIST traceable standards.

Calibration gas Certificates of Analysis can be found in Appendix C.

#### 4.2 Sampling Location/Traverse Points/Test Run Duration

Unit 5's exhaust stack inner diameter, at the sample location, is 28.29 feet (339.5"). The emissions sampling location is 303 feet downstream from the nearest flow disturbance, and 195 feet upstream from the stack exhaust. A diagram of the sample location can be viewed in Appendix D.

Gas sample traverse points were located in accordance with 40CFR, Part 75, Appendix A, Section 6.5.6(b)(2) at 4.4%(14.9"), 14.6%(49.6"), and 29.6%(100.5") from the inner wall of the stack. Each point was sampled for seven minutes, equaling a total of 21 minutes per test run as required by a 40CFR, Part 75 RATA. A minimum of nine test runs are required.

A total of three RATA runs were averaged to equal one 63 minute test run; for example, RATA runs 1, 2, and 3 were combined to equal one run for compliance determination.

#### **4.3 Quality Assurance/Quality Control Procedures**

All sampling, analytical, and Quality Assurance/Quality Control (QA/QC) procedures outlined in the EPA methods were followed. All test equipment was calibrated before or during use in the field. Interference checks and response time checks were performed on each instrumental analyzer, as applicable, before field use. In the field, each analyzer and the entire instrument measurement system was checked for system bias before and following each test run using the calibration gases listed in Table 2.

Appendix E contains the QA/QC checks.

## **5.0 Test Results**

Table 4 summarizes the CO test results. Supporting RM field data and calculated values are presented in Appendix F.

### **5.1 Carbon Monoxide**

Units 5's carbon monoxide emissions during the test were 5.3 parts per million on a dry basis (ppmvd), which corresponds to 0.005 pounds per million British thermal units (lbs/MMBtu), and 35.21 pounds per hour (lbs/hr) based upon a heat input of 6599 MMBtu/hr, while operating on 100 percent bituminous coal.

**Table 3: CO Test Summary**  
**Progress Energy**  
**Crystal River, Unit 5**

## Summary

Test Performed For:  
 Progress Energy Florida  
 Crystal River  
 Unit 5  
 CO Emissions Test at High Load  
 Date: 4/19/06

Test Performed By:  
 C.E.M. Solutions, Inc.  
 7990 W. Gulf to Lake Hwy.  
 Crystal River, FL 34429  
 Ph: 352-564-0441

Run Number	Units	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Run 8	Run 9	Average
Date of Run	1905	19-Apr	19-Apr	19-Apr	19-Apr	19-Apr	19-Apr	19-Apr	19-Apr	19-Apr	
Start Time		9:02:00	10:40:00	11:27:00	12:13:00	13:01:00	13:56:00	14:44:00	15:24:00	16:04:00	
Stop Time		9:23:00	11:01:00	11:48:00	12:34:00	13:22:00	14:17:00	15:05:00	15:45:00	16:25:00	
Unit Load	MW	763.56	758.34	759.10	760.00	759.87	758.29	757.08	757.76	760.17	
Heat Input	mmBtu/Hr	6635	6633	6627	6663	6618	6578	6524	6532	6582	6599
CO2	%, dry	13.4	13.3	13.3	13.3	13.3	13.2	13.2	13.2	13.2	13.3
CO	ppmvd	7.3	5.0	6.1	6.3	5.9	4.1	3.8	3.7	5.6	5.3
CO / CO2	Lbs/mmBtu	0.0070	0.0050	0.0060	0.0060	0.0060	0.0040	0.0040	0.0040	0.0060	0.006
CO / CO2	Lbs/Hr	46.45	33.17	39.76	39.98	39.71	26.31	26.10	26.13	39.49	37.56
Compiled Run Data											
Heat Input	mmBtu/Hr		6632			6620			6546		6599
CO / CO2	ppmvd			6.1		5.4			4.4		5.3
CO / CO2	Lbs/mmBtu		0.0060			0.0053			0.0047		0.0053
CO / CO2	Lbs/Hr		39.79			35.30			30.55		35.21

## **Appendix A: Facility Operating Data**

**Unit 5 Heat Input Data (provided by Progress Energy)**

Crystal River Heat Input 4/19/6

4/19/06 10:02	6635.261	
4/19/06 10:03	6664.201	
4/19/06 10:04	6629.715	
4/19/06 10:05	6660.102	
4/19/06 10:06	6682.959	
4/19/06 10:07	6703.472	
4/19/06 10:08	6567.258	
4/19/06 10:09	6630.36	
4/19/06 10:10	6645.75	
4/19/06 10:11	6599.596	
4/19/06 10:12	6627.185	
4/19/06 10:13	6635.698	
4/19/06 10:14	6656.72	
4/19/06 10:15	6634.915	
4/19/06 10:16	6655.215	
4/19/06 10:17	6701.202	
4/19/06 10:18	6565.514	
4/19/06 10:19	6570.413	
4/19/06 10:20	6657.809	
4/19/06 10:21	6593.545	
4/19/06 10:22	6616.212	
4/19/06 10:23	6672.542	
4/19/06 10:24	6599.532	RUN 1      6635.008
4/19/06 11:40	6662.461	
4/19/06 11:41	6589.643	
4/19/06 11:42	6601.601	
4/19/06 11:43	6658.603	
4/19/06 11:44	6617.02	
4/19/06 11:45	6683.251	
4/19/06 11:46	6651.075	
4/19/06 11:47	6665.468	
4/19/06 11:48	6584.929	
4/19/06 11:49	6598.02	
4/19/06 11:50	6656.959	
4/19/06 11:51	6567.151	
4/19/06 11:52	6606.17	
4/19/06 11:53	6686.687	
4/19/06 11:54	6687.763	
4/19/06 11:55	6608.359	
4/19/06 11:56	6594.479	
4/19/06 11:57	6621.28	
4/19/06 11:58	6661.627	
4/19/06 11:59	6712.848	
4/19/06 12:00	6539.926	
4/19/06 12:01	6677.909	Run 2      6633.328
4/19/06 12:27	6537.813	
4/19/06 12:28	6596.931	
4/19/06 12:29	6705.424	
4/19/06 12:30	6727.451	

4/19/06 12:31	6677.016
4/19/06 12:32	6604.701
4/19/06 12:33	6628.425
4/19/06 12:34	6582.913
4/19/06 12:35	6563.433
4/19/06 12:36	6586.221
4/19/06 12:37	6579.603
4/19/06 12:38	6689.938
4/19/06 12:39	6683.715
4/19/06 12:40	6691.604
4/19/06 12:41	6592.818
4/19/06 12:42	6592.087
4/19/06 12:43	6603.718
4/19/06 12:44	6601.308
4/19/06 12:45	6645.633
4/19/06 12:46	6698.698
4/19/06 12:47	6562.884
4/19/06 12:48	6646.288
4/19/06 13:13	6572.108
4/19/06 13:14	6668.564
4/19/06 13:15	6669.365
4/19/06 13:16	6704.529
4/19/06 13:17	6655.902
4/19/06 13:18	6791.056
4/19/06 13:19	6717.447
4/19/06 13:20	6653.702
4/19/06 13:21	6654.459
4/19/06 13:22	6688.816
4/19/06 13:23	6742.263
4/19/06 13:24	6684.267
4/19/06 13:25	6663.813
4/19/06 13:26	6651.219
4/19/06 13:27	6626.005
4/19/06 13:28	6693.727
4/19/06 13:29	6619.014
4/19/06 13:30	6665.912
4/19/06 13:31	6635.212
4/19/06 13:32	6590.338
4/19/06 13:33	6638.587
4/19/06 13:34	6609.343
4/19/06 14:01	6588.015
4/19/06 14:02	6624.043
4/19/06 14:03	6587.097
4/19/06 14:04	6654.394
4/19/06 14:05	6593.765
4/19/06 14:06	6653.613
4/19/06 14:07	6708.179
4/19/06 14:08	6627.887
4/19/06 14:09	6670.89
4/19/06 14:10	6695.009
4/19/06 14:11	6553.458
4/19/06 14:12	6553.03

Run 3      6627.21

Run 4      6663.439

4/19/06 14:13	6614.405
4/19/06 14:14	6695.237
4/19/06 14:15	6611.554
4/19/06 14:16	6597.636
4/19/06 14:17	6659.264
4/19/06 14:18	6586.133
4/19/06 14:19	6633.275
4/19/06 14:20	6562.646
4/19/06 14:21	6524.237
4/19/06 14:22	6601.826
4/19/06 14:56	6603.536
4/19/06 14:57	6539.661
4/19/06 14:58	6540.385
4/19/06 14:59	6590.54
4/19/06 15:00	6600.113
4/19/06 15:01	6560.716
4/19/06 15:02	6654.27
4/19/06 15:03	6536.91
4/19/06 15:04	6609.04
4/19/06 15:05	6528.721
4/19/06 15:06	6558.452
4/19/06 15:07	6537.75
4/19/06 15:08	6598.692
4/19/06 15:09	6558.211
4/19/06 15:10	6586.755
4/19/06 15:11	6617.734
4/19/06 15:12	6686.982
4/19/06 15:13	6605.139
4/19/06 15:14	6606.954
4/19/06 15:15	6669.328
4/19/06 15:16	6473.833
4/19/06 15:17	6455.484
4/19/06 15:44	6456.093
4/19/06 15:45	6526.23
4/19/06 15:46	6578.951
4/19/06 15:47	6643.747
4/19/06 15:48	6461.447
4/19/06 15:49	6545.304
4/19/06 15:50	6564.205
4/19/06 15:51	6490.833
4/19/06 15:52	6553.395
4/19/06 15:53	6484.695
4/19/06 15:54	6565.114
4/19/06 15:55	6498.571
4/19/06 15:56	6541.332
4/19/06 15:57	6459.402
4/19/06 15:58	6525.003
4/19/06 15:59	6420.828
4/19/06 16:00	6550.043
4/19/06 16:01	6555.734
4/19/06 16:02	6524.033
4/19/06 16:03	6522.374

Run 5      6617.981

Run 6      6578.146

4/19/06 16:04	6529.142	
4/19/06 16:05	6539.355	Run 7      6524.356
4/19/06 16:24	6555.979	
4/19/06 16:25	6543.974	
4/19/06 16:26	6516.433	
4/19/06 16:27	6583.33	
4/19/06 16:28	6495.167	
4/19/06 16:29	6534.782	
4/19/06 16:30	6491.346	
4/19/06 16:31	6490.512	
4/19/06 16:32	6573.685	
4/19/06 16:33	6627.64	
4/19/06 16:34	6521.839	
4/19/06 16:35	6494.575	
4/19/06 16:36	6515.466	
4/19/06 16:37	6579.381	
4/19/06 16:38	6550.543	
4/19/06 16:39	6485.849	
4/19/06 16:40	6476.115	
4/19/06 16:41	6522.427	
4/19/06 16:42	6541.407	
4/19/06 16:43	6585.687	
4/19/06 16:44	6550.423	
4/19/06 16:45	6482.636	Run 8      6532.691
4/19/06 17:04	6603.273	
4/19/06 17:05	6659.355	
4/19/06 17:06	6646.365	
4/19/06 17:07	6559.297	
4/19/06 17:08	6547.446	
4/19/06 17:09	6672.437	
4/19/06 17:10	6602.064	
4/19/06 17:11	6592.966	
4/19/06 17:12	6576.352	
4/19/06 17:13	6612.77	
4/19/06 17:14	6555.595	
4/19/06 17:15	6618.907	
4/19/06 17:16	6686.183	
4/19/06 17:17	6543.528	
4/19/06 17:18	6564.983	
4/19/06 17:19	6494.054	
4/19/06 17:20	6552.118	
4/19/06 17:21	6424.745	
4/19/06 17:22	6492.173	
4/19/06 17:23	6612.93	
4/19/06 17:24	6606.893	
4/19/06 17:25	6579.391	Run 9      6581.992

## **Appendix B: Mathematical Equations**

## **Reference Method Calibrations**

### **Difference**

The absolute difference is calculated in accordance with 40 CFR 60, App. B, Meth. 6C, Sect 6.3.1, 6.3.2 and figure 6C-4. The algebraic expression used to return this result is:

$$\text{Analyzer Response} - \text{Reference Gas Concentration}$$

### **Calibration Error**

The calibration error is calculated in accordance with 40 CFR 60, App. B, Meth. 6C, Sect 6.3.1, 6.3.2 and figure 6C-4 and displayed as a percent of the span described in section 2.1 of this document. The algebraic expression used to return this result is:

$$\text{Difference} / \text{Full Scale} * 100$$

All measured parameters are subjected to the calibration error test for reporting by the operator. Should the test not be required, (i.e. method 20 or method 25a) it may be deleted.

### **Pre Run Bias**

The Pre Run Bias is calculated in accordance with 40 CFR 60, App. B, Meth. 6C, Sect 6.4 and figure 6C-5 and displayed as a percent of the span described in section 2.1 of this document. The algebraic expression used to return this result is:

$$\text{Initial Cal Value} - \text{Analyzer Cal Response} / \text{Full Scale} * 100$$

All measured parameters are subjected to the calibration error test for reporting by the operator. Should the test not be required, (i.e. method 20 or method 25a) it may be deleted.

### **Post Run Bias**

The Post Run Bias is calculated in accordance with 40 CFR 60, App. B, Meth. 6C, Sect 6.4 and figure 6C-5 and displayed as a percent of the span described in section 2.1 of this document. The algebraic expression used to return this result is:

$$\text{Final Cal Value} - \text{Analyzer Cal Response} / \text{Full Scale} * 100$$

## Reference Method Calibrations, continued

### Total Run Drift

The Total Run Drift is calculated in accordance with 40 CFR 60, App. B, Meth. 6C, Sect 7.4 and figure 6C-5 and displayed as a percent of the span. The algebraic expression used to return this result is:

$$\text{Final Cal Value} - \text{Initial Cal Value} / \text{Full Scale} * 100$$

### Average

The average calibration results are calculated in accordance with 40 CFR 60, App. B, Meth. 6C, Sect 8 and equation 6C-1. This calculation yields the variable "C<sub>o</sub> or C<sub>m</sub>" as appropriate. The algebraic expression used to return this result is:

$$\text{Initial Cal Value} + \text{Final Cal Value} / 2$$

This format yields a number expressed in ppm or percent, as appropriate.

### Corrected Results

The corrected results are calculated for all gases except Oxygen in accordance with 40 CFR 60, App. B, Meth. 6C, Sect. 8 and equation 6C-1. Oxygen corrected results are calculated per 40 CFR 60, App. B, Meth. 3A, Sect 9 and equation 3A-1. The algebraic expression used to return this result for all gases except oxygen is:

$$C_{\text{gas}} = (C - C_o) * C_{\text{ma}} / (C_m - C_o) \quad \text{Eq. 6C-1}$$

Where:

C<sub>gas</sub> = Effluent gas concentration, dry basis, ppm.

C = Average gas concentration, dry basis, ppm.

C<sub>o</sub> = Average of initial and final system bias check responses for the zero gas, ppm.

C<sub>m</sub> = Average of initial and final system bias check responses for the upscale calibration gas, ppm.

C<sub>ma</sub> = Actual concentration of the upscale calibration gas, ppm.

## Emissions Rates in lbs/mmBtu

When reference method readings for pollutant and carbon dioxide are on a dry basis, equation 19-6 of Method 19 is utilized.

$$E = C_d * F_d * \frac{100}{\%CO_{2d}} \quad \text{Eq. 19-6}$$

Where:

- $C_d$  = Pollutant concentration, dry basis, in lb/scf (to convert ppm to lb/scf refer to Table 19-1).  
 $F_d$  = Volume of combustion components per unit of heat input, dry basis, dscf/mmBtu. (for oil 9190)  
 $\%CO_{2d}$  = Carbon dioxide, dry basis, percent

Table 19-1: Conversion Factors For Concentrations.

From	To	Multiply by
ppm SO <sub>2</sub>	lb/scf	$1.660 \times 10^{-7}$
ppm NO <sub>x</sub>	lb/scf	$1.194 \times 10^{-7}$
ppm CO	lb/scf	$2.5955 \times 10^{-9} \times 28.01$

## **Appendix C: Reference Method Calibration Gas Certificates of Analysis**

BEST AVAILABLE COPY



Certificate of Analysis  
EPA Protocol  
performed according to EPA 40 CFR 191, Procedure G1  
HiQ® Certificate

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

LINDE OCALA INTERBRANCH  
214 S W 33RD AVE  
OCALA FL 34474  
USA  
352-351-4417

Material:	2179	A31	Blend Tolerance:	5 % Relative
MISC 3 COMPONENT EPA			EPA Protocol	
Production #:	100100352		Cyl. Pressure:	2000 psig
Lot #:	02499E5060ZD		Balance Gas:	Nitrogen
Cylinder #:	CC89066		CGA:	590
Expiration Date:	5/10/2008		Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months		Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7782-44-7	Oxygen	13	12.9 +/- 0.1 %	05/10/2005
124-38-9	Carbon Dioxide	11	10.9 +/- 0.1 %	05/10/2005
7727-37-9	Nitrogen		Balance	05/10/2005

CAS #	Reference Standard	GL Index/Standard #	Concentration	Expiry Date
124-38-9	Carbon Dioxide	CC59277 , NTRM	6.900 %	10/02/2008
7782-44-7	Oxygen	CC73287 , NTRM	9.90 %	10/02/2008

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568849043	Non-Dispersive Infrared	05/04/2005
Rosemount 755R	1000559	Paramagnetic	05/05/2005

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Roy Yoder

Roy Yoder



**BEST AVAILABLE COPY****Certificate of Analysis****EPA Protocol**

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

Linde Gas LLC  
 Maumee Specialty Gas Plant  
 6421 Monclova Road  
 MAUMEE OH 43537  
 419-893-7226

*Produced for customer:*

CYLINDER/HARDWARE ACCT  
 HOLOX LTD  
 1500 INDIAN TRAIL RD #C  
 NORCROSS GA 30093  
 770-925-4640

<b>Material:</b>	2179	<b>A31</b>	<b>Blend Tolerance:</b>	1 % Relative
MISC 3 COMPONENT EPA			<b>Blend Type:</b>	EPA Protocol
<b>Production #:</b>	100081154		<b>Cyl. Pressure:</b>	2000 psig
<b>Lot #:</b>	0249934270ME		<b>Balance Gas:</b>	Nitrogen
<b>Cylinder #:</b>	CCJ9200		<b>CGA:</b>	590
<b>Expiration Date:</b>	3/9/2007		<b>Analytical Accuracy:</b>	1.00 % Relative
<b>Shelf Life:</b>	36 months		<b>Confidence:</b>	95 %

<b>CAS #</b>	<b>Certified Component</b>	<b>Requested Concentration</b>	<b>Concentration and Uncertainty</b>	<b>Date of Certification</b>
124-38-9	Carbon Dioxide	18	17.6 +/- 0.2 %	03/09/2004
7782-44-7	Oxygen	21	21.0 +/- 0.2 %	03/09/2004
7727-37-9	Nitrogen		Balance	03/09/2004

<b>CAS #</b>	<b>Reference Standard</b>	<b>Cylinder/Standard #</b>	<b>Concentration</b>	<b>Expire Date</b>
7782-44-7	Oxygen	CC73601 , NTRM	20.89 %	05/29/2005
124-38-9	Carbon Dioxide	CC59203 , NTRM	19.91 %	08/01/2005

<b>Instrument</b>	<b>Serial #</b>	<b>Analytical Principle</b>	<b>Calibration Date</b>
Horiba VIA-510	568849043	Non-Dispersive Infrared	10/22/2003
Rosemount 755R	1000559	Paramagnetic	12/19/2003

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jim Healy



**Certificate of Analysis**

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

Linde Gas LLC  
 Maumee Specialty Gas Plant  
 6421 Monclova Road  
 MAUMEE OH 43537  
 419-893-7226

*Produced for customer:*

LINDE OCALA INTERBRANCH  
 214 S W 33RD AVE  
 OCALA FL 34474  
 USA  
 352-351-4417

<b>Material:</b>	6198	<b>Blend Tolerance:</b>	5 % Relative
EPA CO/N2 100-999 PPM	A31	<b>Blend Type:</b>	EPA Protocol
<b>Production #:</b>	100088507	<b>Cyl. Pressure:</b>	2000 psig
<b>Lot #:</b>	02499H4260YA	<b>Balance Gas:</b>	Nitrogen
<b>Cylinder #:</b>	CC183009	<b>CGA:</b>	350
<b>Expiration Date:</b>	9/8/2007	<b>Analytical Accuracy:</b>	1.00 % Relative
<b>Shelf Life:</b>	36 months	<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	300	293 +/- 3 ppm	09/08/2004
7727-37-9	Nitrogen		Balance	09/08/2004

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC110784 , GMIS	2522 ppm	01/09/2006
630-08-0	Carbon Monoxide	CC155679 , GMIS	251.4 ppm	01/12/2006

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568384012	Non-Dispersive Infrared	07/16/2004

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jennifer Carney



Certificate of Analysis

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

LINDE OCALA INTERBRANCH  
214 S.W. 33RD AVE  
OCALA FL 34474  
USA  
352-351-4417

Material:	6198	Blend Tolerance:	5 % Relative
EPA CO/N2 100-999 PPM	A31	Store/Use Temp:	35 to 90 F
Production #:	100100610	Blend Type:	Gravimetric
Lot #:	02499H2140MC1	Cyl. Pressure:	1438 psig
Cylinder #:	CC149888	Balance Gas:	Nitrogen
Expiration Date:	5/24/2008	CGA:	350
Shelf Life:	36 months	Analytical Accuracy:	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	600	613 +/- 6 ppm	05/24/2005
7727-37-9	Nitrogen		Balance	05/24/2005

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC27004 , GMIS	506.3 ppm	08/09/2004
630-08-0	Carbon Monoxide	CC10347 , GMIS	1023.4 ppm	12/22/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	569466011	Non-Dispersive Infrared	05/09/2005

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jennifer Carney

Jennifer Carney



**Certificate of Analysis**

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

LINDE OCALA INTERBRANCH  
214 S W 33RD AVE  
OCALA FL 34474  
USA  
352-351-4417

Material:	6198	A31	Blend Tolerance:	5 % Relative
	EPA CO/N2 100-999 PPM		Store/Use Temp:	35 to 90 F
Production #:	100100611		Blend Type:	Gravimetric
Lot #:	02499H2140MB1		Cyl. Pressure:	1502 psig
Cylinder #:	CC150173		Balance Gas:	Nitrogen
Expiration Date:	5/24/2008		CGA:	350
Shelf Life:	36 months		Analytical Accuracy:	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	950	948 +/- 9 ppm	05/24/2005
7727-37-9	Nitrogen		Balance	05/24/2005
CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC27004 , GMIS	506.3 ppm	08/09/2004
630-08-0	Carbon Monoxide	CC10347 , GMIS	1023.4 ppm	12/22/2005
Instrument	Serial #		Analytical Principle	Calibration Date
Horiba VIA-510	569466011		Non-Dispersive Infrared	05/09/2005

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jennifer Carney

Jennifer Carney



## **Appendix D: Sample Location Diagram**

**BEST AVAILABLE COPY**

**CEM Solutions, Inc.**

**METHOD 1: Determining Number of Particulate and Velocity Traverse Points  
For a Circular Stack**

Company:	<u>Progress Energy</u>	Date:	<u>4/10/2006</u>
Facility:	<u>Crystal River</u>	Project #:	<u>2543</u>
Unit No.:	<u>Unit 5</u>	Operator:	<u>Joe Conti</u>
Sample Location:	<u>Stack</u>		

**Stack or Duct Diameter**

Shape of Stack	Circular
# of Test Ports	14
Stack Diameter (D), inches	339.5
Port Depth (P), inches	15
Stack Area ( $A_s$ ), $\text{ft}^2$	628.3284

**Distance from Test Ports to Disturbances**


Distance Upstream (A), inches	2343
Diameters Upstream ( $A_D$ )	6.90
Distance Downstream (B), inches	3633
Diameters Downstream ( $B_D$ )	10.70

**Minimum number of particulate traverse points**

calculated for upstream distance	12
calculated for downstream distance	12
if $12'' < D < 24''$ and $A_D > 2$ and $B_D > 8$	0
<b>NUMBER OF POINTS TO BE USED</b>	<b>12</b>

**Minimum number of velocity traverse points**

calculated for upstream distance	12
calculated for downstream distance	12
if $12'' < D < 24''$ and $A_D > 2$ and $B_D > 8$	0
<b>NUMBER OF POINTS TO BE USED</b>	<b>12</b>



**Appendix E: Reference Method Quality Assurance,  
Quality Control (QA/QC) Checks**

## Response Time Test

Date of test: 4/18/2006  
Plant: PEF Crystal River  
Unit Number: 5  
Analyzer type: CO  
Serial Number: 48C-74094-375  
Span gas Concentration: 948 ppm  
Analyzer span setting: 1000 ppm

Upscale:

<u>Run</u>	<u>Seconds</u>
1	<u>180</u>
2	<u>180</u>
3	<u>180</u>

Average upscale response: 180

Downscale:

<u>Run</u>	<u>Seconds</u>
1	<u>180</u>
2	<u>180</u>
3	<u>180</u>

Average downscale response: 180

System response time: 180  
Slower average time: 180

## Response Time Test

Date of test: 4/18/2006  
Plant: PEF Crystal River  
Unit Number: 5  
Analyzer type: CO2  
Serial Number: 1415D/3379  
Span gas Concentration: 17.6  
Analyzer span setting: 20

Upscale:

<u>Run</u>	<u>Seconds</u>
1	<u>120</u>
2	<u>120</u>
3	<u>120</u>

Average upscale response: 120

Downscale:

<u>Run</u>	<u>Seconds</u>
1	<u>120</u>
2	<u>120</u>
3	<u>120</u>

Average downscale response: 120

System response time: 120  
Slower average time: 180

# Analyzer Calibration Error

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 1

## Carbon Dioxide Monitor

Full Scale: 20.00 %

## Method 3A

Serial Number: 01415D/3379

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC 81224/cg1	0.00 %	0.06 %	0.06 %	0.30 %
CC89066/cg2	10.90 %	10.85 %	-0.05 %	-0.25 %
CC59200/cg3	17.60 %	17.61 %	0.01 %	0.05 %

## Carbon Monoxide Monitor

Full Scale: 1,000.0 ppm

## Method 10

Serial Number: 48C-74094-375

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC 81224/cg1	0.0 ppm	-0.2 ppm	-0.2 ppm	-0.02 %
CC183009/cg6	293.0 ppm	293.1 ppm	0.1 ppm	0.01 %
CC149888/cg7	613.0 ppm	610.0 ppm	-3.0 ppm	-0.30 %
CC150173/cg8	948.0 ppm	946.1 ppm	-1.9 ppm	-0.19 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date:4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 1

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.10 %	0.20 %	0.15 %	0.45 %	0.25 %
CO <sub>2</sub>	10.85 %	10.72 %	-0.65 %	10.76 %	-0.45 %	0.20 %
CO	-0.2 ppm	0.0 ppm	0.02 %	0.0 ppm	0.02 %	0.00 %
CO	293.1 ppm	290.3 ppm	-0.28 %	289.4 ppm	-0.37 %	-0.09 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date:4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 2

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.15 %	0.45 %	0.21 %	0.75 %	0.30 %
CO <sub>2</sub>	10.85 %	10.76 %	-0.45 %	10.79 %	-0.30 %	0.15 %
CO	-0.2 ppm	0.0 ppm	0.02 %	0.0 ppm	0.02 %	0.00 %
CO	293.1 ppm	289.4 ppm	-0.37 %	288.4 ppm	-0.47 %	-0.10 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 3

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.21 %	0.75 %	0.16 %	0.50 %	-0.25 %
CO <sub>2</sub>	10.85 %	10.79 %	-0.30 %	10.81 %	-0.20 %	0.10 %
CO	-0.2 ppm	0.0 ppm	0.02 %	0.0 ppm	0.02 %	0.00 %
CO	293.1 ppm	288.4 ppm	-0.47 %	288.7 ppm	-0.44 %	0.03 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date:4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 4

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.16 %	0.50 %	0.22 %	0.80 %	0.30 %
CO <sub>2</sub>	10.85 %	10.81 %	-0.20 %	10.80 %	-0.25 %	-0.05 %
CO	-0.2 ppm	0.0 ppm	0.02 %	0.0 ppm	0.02 %	0.00 %
CO	293.1 ppm	288.7 ppm	-0.44 %	287.9 ppm	-0.52 %	-0.08 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 5

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.22 %	0.80 %	0.19 %	0.65 %	-0.15 %
CO <sub>2</sub>	10.85 %	10.80 %	-0.25 %	10.81 %	-0.20 %	0.05 %
CO	-0.2 ppm	0.0 ppm	0.02 %	-0.2 ppm	0.00 %	-0.02 %
CO	293.1 ppm	287.9 ppm	-0.52 %	288.7 ppm	-0.44 %	0.08 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 6

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.19 %	0.65 %	0.15 %	0.45 %	-0.20 %
CO <sub>2</sub>	10.85 %	10.81 %	-0.20 %	10.78 %	-0.35 %	-0.15 %
CO	-0.2 ppm	-0.2 ppm	0.00 %	0.0 ppm	0.02 %	0.02 %
CO	293.1 ppm	288.7 ppm	-0.44 %	289.8 ppm	-0.33 %	0.11 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 7

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.15 %	0.45 %	0.22 %	0.80 %	0.35 %
CO <sub>2</sub>	10.85 %	10.78 %	-0.35 %	10.77 %	-0.40 %	-0.05 %
CO	-0.2 ppm	0.0 ppm	0.02 %	0.0 ppm	0.02 %	0.00 %
CO	293.1 ppm	289.8 ppm	-0.33 %	289.2 ppm	-0.39 %	-0.06 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 8

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.22 %	-0.80 %	0.20 %	0.70 %	-0.10 %
CO <sub>2</sub>	10.85 %	10.77 %	-0.40 %	10.77 %	-0.40 %	0.00 %
CO	-0.2 ppm	0.0 ppm	0.02 %	0.0 ppm	0.02 %	0.00 %
CO	293.1 ppm	289.2 ppm	-0.39 %	289.2 ppm	-0.39 %	0.00 %

# Sampling System Bias and Drift

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 9

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
CO <sub>2</sub>	0.06 %	0.20 %	0.70 %	0.22 %	0.80 %	0.10 %
CO <sub>2</sub>	10.85 %	10.77 %	-0.40 %	10.79 %	-0.30 %	0.10 %
CO	-0.2 ppm	0.0 ppm	0.02 %	-0.2 ppm	0.00 %	-0.02 %
CO	293.1 ppm	289.2 ppm	-0.39 %	289.0 ppm	-0.41 %	-0.02 %

## **Appendix F: Reference Method Support Data**

Average Emissions Calculations  
Raw Data

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 1

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.10 %	0.15 %	0.12
10.90 percent CO <sub>2</sub>	10.72 %	10.76 %	10.74
0.0 ppm CO	0.0 ppm	0.0 ppm	0.00
293.0 ppm CO	290.3 ppm	289.4 ppm	289.86
<b>Mean Reference Values:</b>		<b>Corrected Results:</b>	<b>Basis:</b>
13.18 percent CO <sub>2</sub>		13.40 percent CO <sub>2</sub>	DRY
7.3 ppm CO		7.3 ppm CO	DRY

**Emission Calculations:**  
0.0070 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 2

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.15 %	0.21 %	0.18
10.90 percent CO <sub>2</sub>	10.76 %	10.79 %	10.77

0.0 ppm CO	0.0 ppm	0.0 ppm	0.00
293.0 ppm CO	289.4 ppm	288.4 ppm	288.90

**Mean Reference Values:**  
13.14 percent CO<sub>2</sub>  
4.9 ppm CO

**Corrected Results:**  
13.30 percent CO<sub>2</sub>  
5.0 ppm CO

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
0.0050 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 3

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.21 %	0.16 %	0.18
10.90 percent CO <sub>2</sub>	10.79 %	10.81 %	10.80

0.0 ppm CO	0.0 ppm	0.0 ppm	0.00
293.0 ppm CO	288.4 ppm	288.7 ppm	288.55

**Mean Reference Values:**  
13.16 percent CO<sub>2</sub>  
6.0 ppm CO

**Corrected Results:**  
13.30 percent CO<sub>2</sub>  
**6.1** ppm CO

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
0.0060 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 4

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.16 %	0.22 %	0.19
10.90 percent CO <sub>2</sub>	10.81 %	10.80 %	10.80

0.0 ppm CO	0.0 ppm	0.0 ppm	0.00
293.0 ppm CO	288.7 ppm	287.9 ppm	288.27

**Mean Reference Values:**  
13.14 percent CO<sub>2</sub>  
6.2 ppm CO

**Corrected Results:**  
13.30 percent CO<sub>2</sub>  
6.3 ppm CO

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
0.0060 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 5

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.22 %	0.19 %	0.21
10.90 percent CO <sub>2</sub>	10.80 %	10.81 %	10.80
0.0 ppm CO	0.0 ppm	-0.2 ppm	-0.10
293.0 ppm CO	287.9 ppm	288.7 ppm	288.26
<b>Mean Reference Values:</b>		<b>Corrected Results:</b>	<b>Basis:</b>
13.13 percent CO <sub>2</sub>		13.30 percent CO <sub>2</sub>	DRY
5.7 ppm CO		5.9 ppm CO	DRY

Emission Calculations:  
0.0060 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 6

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.19 %	0.15 %	0.17
10.90 percent CO <sub>2</sub>	10.81 %	10.78 %	10.80

0.0 ppm CO	-0.2 ppm	0.0 ppm	-0.10
293.0 ppm CO	288.7 ppm	289.8 ppm	289.22

**Mean Reference Values:**  
13.05 percent CO<sub>2</sub>  
4.0 ppm CO

**Corrected Results:**  
13.20 percent CO<sub>2</sub>  
4.1 ppm CO

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
0.0040 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 7

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.15 %	0.22 %	0.18
10.90 percent CO <sub>2</sub>	10.78 %	10.77 %	10.77

0.0 ppm CO	0.0 ppm	0.0 ppm	0.00
293.0 ppm CO	289.8 ppm	289.2 ppm	289.49

**Mean Reference Values:**  
12.96 percent CO<sub>2</sub>  
3.7 ppm CO

**Corrected Results:**  
13.20 percent CO<sub>2</sub>  
3.8 ppm CO

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
0.0040 CO Lbs/mmBtu From CO<sub>2</sub>

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 8

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.22 %	0.20 %	0.21
10.90 percent CO <sub>2</sub>	10.77 %	10.77 %	10.77

0.0 ppm CO	0.0 ppm	0.0 ppm	0.00
293.0 ppm CO	289.2 ppm	289.2 ppm	289.21

**Mean Reference Values:**  
12.97 percent CO<sub>2</sub>  
3.7 ppm CO

**Corrected Results:**  
**13.20 percent CO<sub>2</sub>**  
**3.7 ppm CO**

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
**0.0040 CO Lbs/mmBtu From CO<sub>2</sub>**

# Calculation of Average Emissions

Test Performed For:  
Progress Energy Florida  
Crystal River  
Unit 5  
Pt. 75 High Load Gas and Flow RATA  
Date: 4/19/06

Test Performed By:  
C.E.M. Solutions, Inc.  
7990 W. Gulf to Lake Hwy.  
Crystal River, FL 34429  
Ph: 352-564-0441  
Run 9

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent CO <sub>2</sub>	0.20 %	0.22 %	0.21
10.90 percent CO <sub>2</sub>	10.77 %	10.79 %	10.78

0.0 ppm CO	0.0 ppm	-0.2 ppm	-0.09
293.0 ppm CO	289.2 ppm	289.0 ppm	289.11

**Mean Reference Values:**  
13.02 percent CO<sub>2</sub>  
5.5 ppm CO

**Corrected Results:**  
13.20 percent CO<sub>2</sub>  
5.6 ppm CO

**Basis:**  
DRY  
DRY

**Emission Calculations:**  
0.0060 CO Lbs/mmBtu From CO<sub>2</sub>

filename	C.E.M. Solutions, Inc.	4/19/2012
testby1	7990 W. Gulf to Lake Hwy.	
testby2	Crystal River, FL 34429	
testby3	Ph: 352-564-0441	
testby4	Progress Energy Florida	
testfor1	Crystal River	
testfor2	Unit 5	
testfor3	Pt 75 High Load Gas and Flow RATA	
testfor4		

5 CO<sub>2</sub>      5 CO  
01415O/3379 48C-74094-375

filename 4/19/2006 7:51:00

filename	C.E.M. Solutions, Inc.
testby1	7990 W. Gulf to Lake Hwy.
testby2	Crystal River, FL 34429
testby3	Ph: 352-564-0441
testfor1	Progress Energy Florida
testfor2	Crystal River
testfor3	Unit 5
testfor4	Pt. 75 High Load Gas and Flow RA

5 CO<sub>2</sub>      5 CO  
01415D/3379 48C-74094-375  
0  
20      100  
1  
CO<sub>2</sub> 3a      CO 10

filename		4/19/2006	7:51:00														
testby1	C.E.M. Solutions, Inc.																
testby2	7990 W. Gulf to Lake Hwy.																
testby3	Crystal River, FL 34429																
testby4	Ph: 352-564-0441																
testfor1	Progress Energy Florida																
testfor2	Crystal River																
testfor3	Unit 5																
testfor4	Pt. 75 High Load Gas and Flow RATA																
name		5 CO2	5 CO														
sn		01415D/3379	48C-74094-375														
offset		0	0														
fullscale		20	1000														
train		1	1														
gasstype		co2 3a	co 10														
scg4	4/19/2006	7:19:45	8.58	2.1	CC150094/cg4	NOx	243	SO2	448	0	0						
noxspan1	4/19/2006	7:23:15	8.58	1.9	CC150094/cg4	NOx	243	SO2	448	0	0						
so2span1	4/19/2006	7:23:30	8.58	2.1	CC150094/cg4	NOx	243	SO2	448	0	0						
scg6	4/19/2006	7:23:45	8.59	2.1	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:24:00	8.59	2.2	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:24:15	8.59	2.2	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:24:30	8.59	2.2	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:24:45	8.58	2.1	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:25:00	8.59	2.2	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:25:15	8.59	1.9	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:25:30	7.96	6.6	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:25:45	1.34	83.2	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:26:00	0.26	217.1	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:26:15	0.19	275.3	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:26:30	0.16	288.5	CC183009/cg6	CO	293	0	0	0	0						
scg6	4/19/2006	7:26:45	0.14	290.3	CC183009/cg6	CO	293	0	0	0	0						
cospan1	4/19/2006	7:27:00	0.14	290.3	CC183009/cg6	CO	293	0	0	0	0						
run1	4/19/2006	8:59:45	13.16	5.0													
run1	4/19/2006	9:00:00	13.17	6.4													
run1	4/19/2006	9:00:15	13.18	7.7													
run1	4/19/2006	9:00:30	13.18	8.6													
run1	4/19/2006	9:00:45	13.17	7.3													
run1	4/19/2006	9:01:00	13.11	6.2													
run1	4/19/2006	9:01:15	13.20	5.3													
run1	4/19/2006	9:01:30	13.17	4.9													
run1	4/19/2006	9:01:45	13.17	4.7													
run1	4/19/2006	9:02:00	13.22	6.4													
run1	4/19/2006	9:02:15	13.23	8.7													
run1	4/19/2006	9:02:30	13.30	7.9													
run1	4/19/2006	9:02:45	13.23	7.5													
run1	4/19/2006	9:03:00	13.22	5.9													
run1	4/19/2006	9:03:15	13.17	5.1													
run1	4/19/2006	9:03:30	13.14	4.7													
run1	4/19/2006	9:03:45	13.26	7.7													
run1	4/19/2006	9:04:00	13.22	14.8													
run1	4/19/2006	9:04:15	13.18	13.0													
run1	4/19/2006	9:04:30	13.12	7.6													
run1	4/19/2006	9:04:45	13.16	5.1													
run1	4/19/2006	9:05:00	13.22	7.8													
run1	4/19/2006	9:05:15	13.28	10.7													
run1	4/19/2006	9:05:30	13.24	9.6													
run1	4/19/2006	9:05:45	13.17	7.2													
run1	4/19/2006	9:06:00	13.21	10.4													
run1	4/19/2006	9:06:15	13.24	17.4													
run1	4/19/2006	9:06:30	13.32	26.5													
run1	4/19/2006	9:06:45	13.18	24.9													
run1	4/19/2006	9:07:00	13.17	13.9													
run1	4/19/2006	9:07:15	13.14	8.5													
run1	4/19/2006	9:07:30	13.21	7.5													
run1	4/19/2006	9:07:45	13.25	8.4													
run1	4/19/2006	9:08:00	13.15	5.9													
run1	4/19/2006	9:08:15	13.15	4.6													
run1	4/19/2006	9:08:30	13.12	5.1													
run1	4/19/2006	9:08:45	13.23	5.7													
run1	4/19/2006	9:09:00	13.20	6.1													
run1	4/19/2006	9:09:15	13.19	6.4													
run1	4/19/2006	9:09:30	13.21	8.7													
run1	4/19/2006	9:09:45	13.14	13.8													
run1	4/19/2006	9:10:00	13.18	11.1													
run1	4/19/2006	9:10:15	13.21	6.8													
run1	4/19/2006	9:10:30	13.20	4.9													
run1	4/19/2006	9:10:45	13.12	3.6													
run1	4/19/2006	9:11:00	13.19	4.3													
run1	4/19/2006	9:11:15	13.20	9.0													
run1	4/19/2006	9:11:30	13.21	11.3													
run1	4/19/2006	9:11:45	13.21	11.5													
run1	4/19/2006	9:12:00	13.15	8.3													
run1	4/19/2006	9:12:15	13.16	4.9													
run1	4/19/2006	9:12:30	13.14	3.9													
run1	4/19/2006	9:12:45	13.23	4.2													
run1	4/19/2006	9:13:00	13.21	4.2													
run1	4/19/2006	9:13:15	13.14	3.4													
run1	4/19/2006	9:13:30	13.17	2.7													
run1	4/19/2006	9:13:45	13.20	3.4													

filename 4/19/2006 7:51:00

filename	
testby1	C.E.M. Solutions, Inc.
testby2	7990 W. Gulf to Lake Hwy.
testby3	Crystal River, FL 34429
testby4	Ph: 352-564-0441
testfor1	Progress Energy Florida
testfor2	Crystal River
testfor3	Unit 5
testfor4	Pt. 75 High Load Gas and Flow RA

name

5 CO<sub>2</sub>      5 CO  
01415D/3379 48C-74094-375  
0                100  
20  
1  
CO<sub>2</sub> 3a      CO 10

gasstype					
run1		4/19/2006	9:14:00	13.24	6.
run1		4/19/2006	9:14:15	13.14	6.
run1		4/19/2006	9:14:30	13.16	4.
run1		4/19/2006	9:14:45	13.17	6.
run1		4/19/2006	9:15:00	13.18	6.
run1		4/19/2006	9:15:15	13.19	7.
run1		4/19/2006	9:15:30	13.15	6.
run1		4/19/2006	9:15:45	13.18	7.
run1		4/19/2006	9:16:00	13.16	8.
run1		4/19/2006	9:16:15	13.16	6.
run1		4/19/2006	9:16:30	13.16	3.
run1		4/19/2006	9:16:45	13.18	3.
run1		4/19/2006	9:17:00	13.16	4.
run1		4/19/2006	9:17:15	13.16	5.
run1		4/19/2006	9:17:30	13.13	5.
run1		4/19/2006	9:17:45	13.17	5.
run1		4/19/2006	9:18:00	13.22	6.
run1		4/19/2006	9:18:15	13.12	5.
run1		4/19/2006	9:18:30	13.15	4.
run1		4/19/2006	9:18:45	13.11	5.
run1		4/19/2006	9:19:00	13.21	6.
run1		4/19/2006	9:19:15	13.26	8.
run1		4/19/2006	9:19:30	13.15	6.
run1		4/19/2006	9:19:45	13.16	5.
run1		4/19/2006	9:20:00	13.11	5.
run1		4/19/2006	9:20:15	13.17	5.
run1		4/19/2006	9:20:30	13.19	4.
run1		4/19/2006	9:20:45	13.12	4.
run1		4/19/2006	9:21:00	13.15	5.
run1		4/19/2006	9:21:15	13.10	6.
run1		4/19/2006	9:21:30	13.19	7.
run1		4/19/2006	9:21:45	13.21	6.
run1		4/19/2006	9:22:00	13.19	5.
run1		4/19/2006	9:22:15	13.17	6.
run1		4/19/2006	9:22:30	13.16	6.
run1		4/19/2006	9:22:45	13.16	5.
averun1		4/19/2006	9:02:00	13.18	7.
scg4		4/19/2006	9:23:15	13.15	5.
scg4		4/19/2006	9:23:30	13.15	3.
scg4		4/19/2006	9:23:45	13.20	3.
scg4		4/19/2006	9:24:00	13.12	3.
scg4		4/19/2006	9:24:15	13.23	4.
scg4		4/19/2006	9:24:30	11.16	17.
scg4		4/19/2006	9:24:45	1.77	97.
scg4		4/19/2006	9:25:00	3.37	185.
scg4		4/19/2006	9:25:15	8.35	115.
scg4		4/19/2006	9:25:30	8.59	27.
scg4		4/19/2006	9:25:45	8.61	4.
scg4		4/19/2006	9:26:00	8.62	1.
scg4		4/19/2006	9:26:15	8.62	2.
scg4		4/19/2006	9:26:30	8.62	2.
scg4		4/19/2006	9:26:45	8.62	2.
scg4		4/19/2006	9:27:00	8.62	2.
noxspan1		4/19/2006	9:26:30	8.62	2.
so2span1		4/19/2006	9:26:45	8.62	2.
scg6		4/19/2006	9:27:15	8.63	2.
scg6		4/19/2006	9:27:30	8.63	2.
scg6		4/19/2006	9:27:45	8.63	2.
scg6		4/19/2006	9:28:00	8.63	2.
scg6		4/19/2006	9:28:15	8.63	2.
scg6		4/19/2006	9:28:30	8.63	2.
scg6		4/19/2006	9:28:45	8.63	2.
scg6		4/19/2006	9:29:00	7.04	15.
scg6		4/19/2006	9:29:15	0.83	102.
scg6		4/19/2006	9:29:30	0.25	235.
scg6		4/19/2006	9:29:45	0.20	279.
scg6		4/19/2006	9:30:00	0.17	288.
scg6		4/19/2006	9:30:15	0.15	289.
scg6		4/19/2006	9:30:30	0.14	289.
cospan1		4/19/2006	9:30:15	0.15	289.
scg2		4/19/2006	9:30:45	0.13	289.
scg2		4/19/2006	9:31:00	0.12	290.
scg2		4/19/2006	9:31:15	0.12	290.
scg2		4/19/2006	9:31:30	0.11	289.

filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.

testby2 7990 W. Gulf to Lake Hwy.

testby3 Crystal River, FL 34429

testby4 Ph: 352-564-0441

testfor1 Progress Energy Florida

testfor2 Crystal River

testfor3 Unit 5

testfor4 Pt. 75 High Load Gas and Flow RATA

5 CO2 5 CO

01415D/3379 48C-74094-375

name

sn

offset

fullscale

train

gasstype

co2 3a co 10

scg2

4/19/2006 9:31:45 0.10 290.3

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:32:00 0.10 290.4

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:32:15 0.10 290.2

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:32:30 2.07 265.7

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:32:45 9.87 156.5

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:33:00 10.69 41.0

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:33:15 10.76 8.5

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg2

4/19/2006 9:33:30 10.79 -0.2

CC89066/cg2 O2 12.9 CO2 10.9 0 0

co2span1

4/19/2006 9:33:15 10.76 8.5

CC89066/cg2 O2 12.9 CO2 10.9 0 0

o2span1

4/19/2006 9:33:15 10.76 8.5

CC89066/cg2 O2 12.9 CO2 10.9 0 0

scg1

4/19/2006 9:33:45 10.81 -0.2

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:34:00 10.83 -0.2

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:34:15 10.84 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:34:30 10.84 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:34:45 10.85 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:35:00 10.85 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:35:15 10.86 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:35:30 7.40 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:35:45 0.64 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:36:00 0.25 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:36:15 0.19 -0.2

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:38:30 0.16 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

scg1

4/19/2006 9:36:45 0.15 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

co2zero1

4/19/2006 9:36:45 0.15 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

o2zero1

4/19/2006 9:36:15 0.19 -0.2

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

noxzero1

4/19/2006 9:36:45 0.15 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

so2zero1

4/19/2006 9:36:45 0.15 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

cozero1

4/19/2006 9:36:30 0.16 0.0

CC 81224/cg1 CO2 0 NOx 0 SO2 0 O2 0

run2

4/19/2006 10:35:15 13.11 4.2

run2

4/19/2006 10:35:30 13.06 3.7

run2

4/19/2006 10:35:45 13.10 6.5

run2

4/19/2006 10:36:00 13.15 9.6

run2

4/19/2006 10:36:15 13.08 8.6

run2

4/19/2006 10:36:30 13.08 5.0

run2

4/19/2006 10:36:45 13.11 4.4

run2

4/19/2006 10:37:00 13.13 5.7

run2

4/19/2006 10:37:15 13.24 5.1

run2

4/19/2006 10:37:30 13.17 3.6

run2

4/19/2006 10:37:45 13.19 3.0

run2

4/19/2006 10:38:00 13.15 3.2

run2

4/19/2006 10:38:15 13.13 4.3

run2

4/19/2006 10:38:30 13.22 5.1

run2

4/19/2006 10:38:45 13.16 5.6

run2

4/19/2006 10:39:00 13.12 7.2

run2

4/19/2006 10:39:15 13.06 7.1

run2

4/19/2006 10:39:30 13.13 5.0

run2

4/19/2006 10:39:45 13.23 4.7

run2

4/19/2006 10:40:00 13.17 5.1

run2

4/19/2006 10:40:15 13.14 3.8

run2

4/19/2006 10:40:30 13.09 3.0

run2

4/19/2006 10:40:45 13.13 2.9

run2

4/19/2006 10:41:00 13.14 3.0

run2

4/19/2006 10:41:15 13.13 3.0

run2

4/19/2006 10:41:30 13.11 2.4

run2

4/19/2006 10:41:45 13.15 1.5

run2

4/19/2006 10:42:00 13.17 1.5

run2

4/19/2006 10:42:15 13.18 2.5

run2

4/19/2006 10:42:30 13.19 5.2

run2

4/19/2006 10:42:45 13.15 6.7

run2

4/19/2006 10:43:00 13.19 6.7

run2

4/19/2006 10:43:15 13.13 6.6

run2

4/19/2006 10:43:30 13.21 5.6

run2

4/19/2006 10:43:45 13.17 4.2

run2

4/19/2006 10:44:00 13.11 3.6

run2

4/19/2006 10:44:15 13.11 2.7

run2

4/19/2006 10:44:30 13.06 2.4

run2

4/19/2006 10:44:45 13.17 4.0

run2

4/19/2006 10:45:00 13.19 8.7

run2

4/19/2006 10:45:15 13.15 10.3

run2

4/19/2006 10:45:30 13.09 10.3

run2

4/19/2006 10:45:45 13.03 7.2

run2

4/19/2006 10:46:00 13.09 4.0

run2

4/19/2006 10:46:15 13.09 3.1

run2

4/19/2006 10:46:30 13.12 3.1

filename 4/19/2006 7:51:00

filename	C.E.M. Solutions, Inc.
testby1	7990 W. Gulf to Lake Hwy.
testby2	Crystal River, FL 34429
testby3	
testby4	Ph: 352-564-0441
testfor1	Progress Energy Florida
testfor2	Crystal River
testfor3	Unit 5
testfor4	Pt. 75 High Load Gas and

Test No. 1575 Flight Load Gas and Flow Test A

5 CO<sub>2</sub>      5 CO  
01415D/3379 48C-74094-375  
0                0  
20              1000  
1

co2 3a co 10

run2	4/19/2006	10:46:45	13.05	1.
run2	4/19/2006	10:47:00	13.06	1.
run2	4/19/2006	10:47:15	13.13	3.3
run2	4/19/2006	10:47:30	13.16	5.6
run2	4/19/2006	10:47:45	13.16	5.6
run2	4/19/2006	10:48:00	13.11	4.6
run2	4/19/2006	10:48:15	13.12	6.1
run2	4/19/2006	10:48:30	13.14	7.8
run2	4/19/2006	10:48:45	13.22	5.5
run2	4/19/2006	10:49:00	13.13	4.1
run2	4/19/2006	10:49:15	13.12	2.8
run2	4/19/2006	10:49:30	13.05	2.
run2	4/19/2006	10:49:45	13.05	1.8
run2	4/19/2006	10:50:00	13.15	2.7
run2	4/19/2006	10:50:15	13.10	4.4
run2	4/19/2006	10:50:30	13.12	5.7
run2	4/19/2006	10:50:45	13.08	5.0
run2	4/19/2006	10:51:00	13.13	3.6
run2	4/19/2006	10:51:15	13.12	2.5
run2	4/19/2006	10:51:30	13.15	3.1
run2	4/19/2006	10:51:45	13.14	6.9
run2	4/19/2006	10:52:00	13.09	12.7
run2	4/19/2006	10:52:15	13.06	10.1
run2	4/19/2006	10:52:30	13.10	5.1
run2	4/19/2006	10:52:45	13.16	6.6
run2	4/19/2006	10:53:00	13.15	8.7
run2	4/19/2006	10:53:15	13.11	6.9
run2	4/19/2006	10:53:30	13.17	6.1
run2	4/19/2006	10:53:45	13.24	6.4
run2	4/19/2006	10:54:00	13.25	6.5
run2	4/19/2006	10:54:15	13.20	6.1
run2	4/19/2006	10:54:30	13.21	7.7
run2	4/19/2006	10:54:45	13.11	8.7
run2	4/19/2006	10:55:00	13.21	7.9
run2	4/19/2006	10:55:15	13.19	9.9
run2	4/19/2006	10:55:30	13.12	8.5
run2	4/19/2006	10:55:45	13.13	5.7
run2	4/19/2006	10:56:00	13.07	3.5
run2	4/19/2006	10:56:15	13.17	3.2
run2	4/19/2006	10:56:30	13.19	3.0
run2	4/19/2006	10:56:45	13.17	3.2
run2	4/19/2006	10:57:00	13.11	3.1
run2	4/19/2006	10:57:15	13.08	2.8
run2	4/19/2006	10:57:30	13.13	2.1
run2	4/19/2006	10:57:45	13.15	2.1
run2	4/19/2006	10:58:00	13.16	3.1
run2	4/19/2006	10:58:15	13.17	3.7
run2	4/19/2006	10:58:30	13.15	5.7
run2	4/19/2006	10:58:45	13.15	6.1
run2	4/19/2006	10:59:00	13.14	5.5
run2	4/19/2006	10:59:15	13.10	3.9
run2	4/19/2006	10:59:30	13.09	2.5
run2	4/19/2006	10:59:45	13.07	2.1
run2	4/19/2006	11:00:00	13.11	3.4
run2	4/19/2006	11:00:15	13.24	6.7
run2	4/19/2006	11:00:30	13.16	7.5
run2	4/19/2006	11:00:45	13.22	7.5
run2	4/19/2006	11:01:00	13.23	12.9
averun2	4/19/2006	10:40:00	13.14	4.9
scg4	4/19/2006	11:01:15	13.19	16.3
scg4	4/19/2006	11:01:30	13.22	13.1
scg4	4/19/2006	11:01:45	13.20	7.8
scg4	4/19/2006	11:02:00	13.22	7.1
scg4	4/19/2006	11:02:15	13.15	6.1
scg4	4/19/2006	11:02:30	13.17	5.5
scg4	4/19/2006	11:02:45	13.13	3.7
scg4	4/19/2006	11:03:00	5.21	3.2
scg4	4/19/2006	11:03:15	7.08	4.2
scg4	4/19/2006	11:03:30	8.59	3.3
scg4	4/19/2006	11:03:45	8.63	1.8
scg4	4/19/2006	11:04:00	8.64	1.9
scg4	4/19/2006	11:04:15	8.64	1.9
scg4	4/19/2006	11:04:30	8.64	1.9
scg4	4/19/2006	11:04:45	8.64	2.1



filename 4/19/2006 7:51:00  
 testby1 C.E.M. Solutions, Inc.  
 testby2 7990 W. Gulf to Lake Hwy.  
 testby3 Crystal River, FL 34429  
 testby4 Ph: 352-564-0441  
 testfor1 Progress Energy Florida  
 testfor2 Crystal River  
 testfor3 Unit 5  
 testfor4 Pt. 75 High Load Gas and Flow RATA  
  
 name 5 CO2 5 CO  
 sn 01415D/3379 48C-74094-375  
 offset 0 0  
 fullscale 20 1000  
 train 1 1  
 gasstype  
 run3 co2 3a co 10  
 4/19/2006 11:28:45 13.17 4.5  
 4/19/2006 11:29:00 13.26 5.3  
 run3 4/19/2006 11:29:15 13.15 8.2  
 run3 4/19/2006 11:29:30 13.18 9.0  
 run3 4/19/2006 11:29:45 13.19 7.7  
 run3 4/19/2006 11:30:00 13.11 6.4  
 run3 4/19/2006 11:30:15 13.14 5.7  
 run3 4/19/2006 11:30:30 13.07 4.4  
 run3 4/19/2006 11:30:45 13.15 4.2  
 run3 4/19/2006 11:31:00 13.14 3.7  
 run3 4/19/2006 11:31:15 13.15 4.5  
 run3 4/19/2006 11:31:30 13.14 5.8  
 run3 4/19/2006 11:31:45 13.09 5.1  
 run3 4/19/2006 11:32:00 13.07 5.1  
 run3 4/19/2006 11:32:15 13.09 4.7  
 run3 4/19/2006 11:32:30 13.13 4.2  
 run3 4/19/2006 11:32:45 13.11 4.2  
 run3 4/19/2006 11:33:00 13.11 3.4  
 run3 4/19/2006 11:33:15 13.06 2.5  
 run3 4/19/2006 11:33:30 13.19 1.9  
 run3 4/19/2006 11:33:45 13.16 1.8  
 run3 4/19/2006 11:34:00 13.09 2.1  
 run3 4/19/2006 11:34:15 13.11 2.1  
 run3 4/19/2006 11:34:30 13.09 2.8  
 run3 4/19/2006 11:34:45 13.24 5.3  
 run3 4/19/2006 11:35:00 13.23 9.5  
 run3 4/19/2006 11:35:15 13.25 17.1  
 run3 4/19/2006 11:35:30 13.18 16.4  
 run3 4/19/2006 11:35:45 13.16 9.9  
 run3 4/19/2006 11:36:00 13.20 6.6  
 run3 4/19/2006 11:36:15 13.12 4.3  
 run3 4/19/2006 11:36:30 13.11 2.4  
 run3 4/19/2006 11:36:45 13.08 2.5  
 run3 4/19/2006 11:37:00 13.11 3.9  
 run3 4/19/2006 11:37:15 13.19 5.1  
 run3 4/19/2006 11:37:30 13.19 5.1  
 run3 4/19/2006 11:37:45 13.10 3.3  
 run3 4/19/2006 11:38:00 13.10 2.2  
 run3 4/19/2006 11:38:15 13.13 1.9  
 run3 4/19/2006 11:38:30 13.14 2.2  
 run3 4/19/2006 11:38:45 13.20 3.1  
 run3 4/19/2006 11:39:00 13.14 4.1  
 run3 4/19/2006 11:39:15 13.22 6.9  
 run3 4/19/2006 11:39:30 13.19 7.0  
 run3 4/19/2006 11:39:45 13.22 4.7  
 run3 4/19/2006 11:40:00 13.17 3.3  
 run3 4/19/2006 11:40:15 13.09 2.5  
 run3 4/19/2006 11:40:30 13.19 3.1  
 run3 4/19/2006 11:40:45 13.22 5.9  
 run3 4/19/2006 11:41:00 13.25 9.6  
 run3 4/19/2006 11:41:15 13.22 12.9  
 run3 4/19/2006 11:41:30 13.20 11.8  
 run3 4/19/2006 11:41:45 13.25 6.5  
 run3 4/19/2006 11:42:00 13.13 4.3  
 run3 4/19/2006 11:42:15 13.12 2.5  
 run3 4/19/2006 11:42:30 13.12 2.1  
 run3 4/19/2006 11:42:45 13.12 1.7  
 run3 4/19/2006 11:43:00 13.10 2.9  
 run3 4/19/2006 11:43:15 13.13 4.0  
 run3 4/19/2006 11:43:30 13.18 7.6  
 run3 4/19/2006 11:43:45 13.35 12.5  
 run3 4/19/2006 11:44:00 13.34 13.9  
 run3 4/19/2006 11:44:15 13.24 12.0  
 run3 4/19/2006 11:44:30 13.19 11.3  
 run3 4/19/2006 11:44:45 13.14 9.6  
 run3 4/19/2006 11:45:00 13.19 7.5  
 run3 4/19/2006 11:45:15 13.15 7.0  
 run3 4/19/2006 11:45:30 13.19 13.9  
 run3 4/19/2006 11:45:45 13.19 14.9  
 run3 4/19/2006 11:46:00 13.14 11.7  
 run3 4/19/2006 11:46:15 13.21 8.2  
 run3 4/19/2006 11:46:30 13.15 4.8  
 run3 4/19/2006 11:46:45 13.22 4.2  
 run3 4/19/2006 11:47:00 13.18 4.2

filename 4/19/2006 7:51:00  
 testby1 C.E.M. Solutions, Inc.  
 testby2 7990 W. Gulf to Lake Hwy.  
 testby3 Crystal River, FL 34429  
 testby4 Ph: 352-564-0441  
 testfor1 Progress Energy Florida  
 testfor2 Crystal River  
 testfor3 Unit 5  
 testfor4 Pt. 75 High Load Gas and Flow RATA  
 name  
 sn 01415D/3379 48C-74094-375  
 offset 0 0  
 fullscale 20 1000  
 train 1 1  
 gasstype  
 run3 4/19/2006 11:47:15 13.15 4.2  
 run3 4/19/2006 11:47:30 13.24 4.2  
 run3 4/19/2006 11:47:45 13.22 4.2  
 averun3 4/19/2006 11:27:00 13.16 6.0  
 scg4 4/19/2006 11:48:00 13.22 5.0  
 scg4 4/19/2006 11:48:15 13.18 5.4  
 scg4 4/19/2006 11:48:30 13.19 4.4  
 scg4 4/19/2006 11:48:45 13.16 3.5  
 scg4 4/19/2006 11:49:00 13.18 3.3  
 scg4 4/19/2006 11:49:15 13.13 4.2  
 scg4 4/19/2006 11:49:30 10.24 4.0  
 scg4 4/19/2006 11:49:45 4.17 3.2  
 scg4 4/19/2006 11:50:00 8.40 2.3  
 scg4 4/19/2006 11:50:15 8.62 2.1  
 scg4 4/19/2006 11:50:30 8.64 2.1  
 scg4 4/19/2006 11:50:45 8.64 2.1  
 scg4 4/19/2006 11:51:00 8.64 2.1  
 scg4 4/19/2006 11:51:15 8.64 1.9  
 scg4 4/19/2006 11:51:30 8.64 1.7  
 noxspan1 4/19/2006 11:51:30 8.64 1.7  
 so2span1 4/19/2006 11:51:30 8.64 1.7  
 scg6 4/19/2006 11:51:45 8.64 2.1  
 scg6 4/19/2006 11:52:00 8.64 2.1  
 scg6 4/19/2006 11:52:15 8.65 2.1  
 scg6 4/19/2006 11:52:30 8.64 1.3  
 scg6 4/19/2006 11:52:45 8.64 2.0  
 scg6 4/19/2006 11:53:00 8.65 1.9  
 scg6 4/19/2006 11:53:15 8.64 2.1  
 scg6 4/19/2006 11:53:30 8.07 6.5  
 scg6 4/19/2006 11:53:45 1.42 84.1  
 scg6 4/19/2006 11:54:00 0.28 209.4  
 scg6 4/19/2006 11:54:15 0.21 274.9  
 scg6 4/19/2006 11:54:30 0.18 287.2  
 scg6 4/19/2006 11:54:45 0.16 288.7  
 cospan1 4/19/2006 11:54:45 0.16 288.7  
 scg2 4/19/2006 11:55:00 0.15 288.7  
 scg2 4/19/2006 11:55:15 0.14 288.9  
 scg2 4/19/2006 11:55:30 0.12 289.7  
 scg2 4/19/2006 11:55:45 0.12 289.4  
 scg2 4/19/2006 11:56:00 0.11 289.5  
 scg2 4/19/2006 11:56:15 0.10 290.4  
 scg2 4/19/2006 11:56:30 0.10 289.4  
 scg2 4/19/2006 11:56:45 3.64 252.5  
 scg2 4/19/2006 11:57:00 10.31 126.3  
 scg2 4/19/2006 11:57:15 10.73 32.8  
 scg2 4/19/2006 11:57:30 10.79 5.5  
 scg2 4/19/2006 11:57:45 10.81 0.0  
 co2span1 4/19/2006 11:57:45 10.81 0.0  
 o2span1 4/19/2006 11:57:45 10.81 0.0  
 scg1 4/19/2006 11:58:00 10.84 0.0  
 scg1 4/19/2006 11:58:15 10.85 0.0  
 scg1 4/19/2006 11:58:30 10.86 0.0  
 scg1 4/19/2006 11:58:45 10.86 0.0  
 scg1 4/19/2006 11:59:00 10.87 -0.4  
 scg1 4/19/2006 11:59:15 10.87 0.0  
 scg1 4/19/2006 11:59:30 10.88 -0.2  
 scg1 4/19/2006 11:59:45 9.92 0.0  
 scg1 4/19/2006 12:00:00 1.59 -0.2  
 scg1 4/19/2006 12:00:15 0.29 0.0  
 scg1 4/19/2006 12:00:30 0.21 0.0  
 scg1 4/19/2006 12:00:45 0.17 0.0  
 scg1 4/19/2006 12:01:00 0.16 0.0  
 co2zero1 4/19/2006 12:01:00 0.16 0.0  
 o2zero1 4/19/2006 12:00:30 0.21 0.0  
 noxzero1 4/19/2006 11:59:00 10.87 -0.4  
 so2zero1 4/19/2006 11:59:15 10.87 0.0  
 cozero1 4/19/2006 11:58:45 10.86 0.0  
 run4 4/19/2006 12:06:45 13.13 4.6  
 run4 4/19/2006 12:07:00 13.12 4.0  
 run4 4/19/2006 12:07:15 13.10 3.0  
 run4 4/19/2006 12:07:30 13.10 2.0  
 run4 4/19/2006 12:07:45 13.10 2.1  
 run4 4/19/2006 12:08:00 13.11 2.1  
 run4 4/19/2006 12:08:15 13.02 2.0

filename	4/19/2006 7:51:00		
testby1	C.E.M. Solutions, Inc.		
testby2	7990 W. Gulf to Lake Hwy.		
testby3	Crystal River, FL 34429		
testby4	Ph: 352-564-0441		
testfor1	Progress Energy Florida		
testfor2	Crystal River		
testfor3	Unit 5		
testfor4	Pt. 75 High Load Gas and Flow RATA		
name	5 CO2	5 CO	
sn	01415D/3379	48C-74094-375	
offset	0	0	
fullscale	20	1000	
train	1	1	
gasstype	co2 3a	co 10	
run4	4/19/2006 12:08:30	13.04	2.3
run4	4/19/2006 12:08:45	13.11	4.1
run4	4/19/2006 12:09:00	13.18	5.9
run4	4/19/2006 12:09:15	13.26	6.3
run4	4/19/2006 12:09:30	13.15	7.1
run4	4/19/2006 12:09:45	13.11	6.6
run4	4/19/2006 12:10:00	13.04	5.3
run4	4/19/2006 12:10:15	13.07	4.6
run4	4/19/2006 12:10:30	13.08	4.3
run4	4/19/2006 12:10:45	13.10	5.6
run4	4/19/2006 12:11:00	13.15	7.7
run4	4/19/2006 12:11:15	13.14	9.6
run4	4/19/2006 12:11:30	13.19	10.9
run4	4/19/2006 12:11:45	13.18	8.5
run4	4/19/2006 12:12:00	13.18	6.1
run4	4/19/2006 12:12:15	13.06	3.7
run4	4/19/2006 12:12:30	13.05	2.2
run4	4/19/2006 12:12:45	13.04	3.1
run4	4/19/2006 12:13:00	13.10	5.8
run4	4/19/2006 12:13:15	13.17	5.1
run4	4/19/2006 12:13:30	13.04	3.1
run4	4/19/2006 12:13:45	13.09	1.6
run4	4/19/2006 12:14:00	13.09	2.1
run4	4/19/2006 12:14:15	13.16	3.7
run4	4/19/2006 12:14:30	13.21	6.8
run4	4/19/2006 12:14:45	13.15	11.6
run4	4/19/2006 12:15:00	13.16	9.8
run4	4/19/2006 12:15:15	13.07	6.0
run4	4/19/2006 12:15:30	13.11	3.4
run4	4/19/2006 12:15:45	13.12	3.2
run4	4/19/2006 12:16:00	13.15	4.2
run4	4/19/2006 12:16:15	13.17	6.8
run4	4/19/2006 12:16:30	13.17	8.5
run4	4/19/2006 12:16:45	13.17	8.1
run4	4/19/2006 12:17:00	13.15	7.7
run4	4/19/2006 12:17:15	13.12	5.0
run4	4/19/2006 12:17:30	13.07	4.2
run4	4/19/2006 12:17:45	13.15	5.1
run4	4/19/2006 12:18:00	13.20	8.0
run4	4/19/2006 12:18:15	13.20	10.0
run4	4/19/2006 12:18:30	13.12	13.0
run4	4/19/2006 12:18:45	13.07	13.6
run4	4/19/2006 12:19:00	13.04	8.8
run4	4/19/2006 12:19:15	13.05	5.0
run4	4/19/2006 12:19:30	13.19	3.3
run4	4/19/2006 12:19:45	13.17	4.2
run4	4/19/2006 12:20:00	13.17	3.7
run4	4/19/2006 12:20:15	13.18	7.1
run4	4/19/2006 12:20:30	13.08	8.9
run4	4/19/2006 12:20:45	13.14	7.8
run4	4/19/2006 12:21:00	13.11	9.6
run4	4/19/2006 12:21:15	13.09	8.5
run4	4/19/2006 12:21:30	13.13	9.0
run4	4/19/2006 12:21:45	13.15	9.5
run4	4/19/2006 12:22:00	13.16	6.6
run4	4/19/2006 12:22:15	13.10	5.1
run4	4/19/2006 12:22:30	13.08	4.9
run4	4/19/2006 12:22:45	13.09	4.2
run4	4/19/2006 12:23:00	13.16	4.6
run4	4/19/2006 12:23:15	13.20	7.1
run4	4/19/2006 12:23:30	13.18	8.5
run4	4/19/2006 12:23:45	13.10	6.0
run4	4/19/2006 12:24:00	13.15	5.1
run4	4/19/2006 12:24:15	13.15	6.2
run4	4/19/2006 12:24:30	13.17	6.9
run4	4/19/2006 12:24:45	13.21	5.6
run4	4/19/2006 12:25:00	13.12	3.9
run4	4/19/2006 12:25:15	13.18	3.2
run4	4/19/2006 12:25:30	13.17	4.5
run4	4/19/2006 12:25:45	13.17	6.1
run4	4/19/2006 12:26:00	13.15	6.1
run4	4/19/2006 12:26:15	13.05	6.1
run4	4/19/2006 12:26:30	13.14	7.0
run4	4/19/2006 12:26:45	13.11	6.0



filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.

testby2 7990 W. Gulf to Lake Hwy.

testby3 Crystal River, FL 34429

testby4 Ph: 352-564-0441

testfor1 Progress Energy Florida

testfor2 Crystal River

testfor3 Unit 5

testfor4 Pt. 75 High Load Gas and Flow RATA

5 CO2 5 CO  
01415D/3379 48C-74094-375

0 0  
20 1000

1 1

co2 3a co 10

scg1	4/19/2006 12:44:00	10.83	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:44:15	10.84	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:44:30	10.85	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:44:45	10.86	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:45:00	10.87	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:45:15	10.88	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:45:30	10.88	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:45:45	10.28	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:46:00	1.91	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:46:15	0.30	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 12:46:30	0.22	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
o2zero1	4/19/2006 12:46:30	0.22	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
o2zero1	4/19/2006 12:46:30	0.22	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
noxzero1	4/19/2006 12:46:30	0.22	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
so2zero1	4/19/2006 12:46:15	0.30	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
cozero1	4/19/2006 12:46:15	0.30	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
run5	4/19/2006 12:52:00	13.14	5.3						
run5	4/19/2006 12:52:15	13.15	9.4						
run5	4/19/2006 12:52:30	13.07	8.4						
run5	4/19/2006 12:52:45	13.13	6.4						
run5	4/19/2006 12:53:00	13.16	6.1						
run5	4/19/2006 12:53:15	13.10	5.9						
run5	4/19/2006 12:53:30	13.16	6.8						
run5	4/19/2006 12:53:45	13.06	8.1						
run5	4/19/2006 12:54:00	13.11	6.6						
run5	4/19/2006 12:54:15	13.15	4.5						
run5	4/19/2006 12:54:30	13.11	3.2						
run5	4/19/2006 12:54:45	13.11	3.2						
run5	4/19/2006 12:55:00	13.05	4.1						
run5	4/19/2006 12:55:15	13.11	4.2						
run5	4/19/2006 12:55:30	13.10	5.5						
run5	4/19/2006 12:55:45	13.10	6.1						
run5	4/19/2006 12:56:00	13.08	5.2						
run5	4/19/2006 12:56:15	13.10	5.1						
run5	4/19/2006 12:56:30	13.15	6.4						
run5	4/19/2006 12:56:45	13.14	8.1						
run5	4/19/2006 12:57:00	13.09	5.4						
run5	4/19/2006 12:57:15	13.06	3.5						
run5	4/19/2006 12:57:30	13.10	3.2						
run5	4/19/2006 12:57:45	13.04	4.2						
run5	4/19/2006 12:58:00	13.12	4.5						
run5	4/19/2006 12:58:15	13.12	5.1						
run5	4/19/2006 12:58:30	13.16	6.3						
run5	4/19/2006 12:58:45	13.16	13.1						
run5	4/19/2006 12:59:00	13.15	16.1						
run5	4/19/2006 12:59:15	13.20	11.4						
run5	4/19/2006 12:59:30	13.13	6.4						
run5	4/19/2006 12:59:45	13.13	4.5						
run5	4/19/2006 13:00:00	13.06	4.2						
run5	4/19/2006 13:00:15	13.14	3.9						
run5	4/19/2006 13:00:30	13.11	4.8						
run5	4/19/2006 13:00:45	13.09	6.8						
run5	4/19/2006 13:01:00	13.17	8.4						
run5	4/19/2006 13:01:15	13.11	10.9						
run5	4/19/2006 13:01:30	13.09	10.1						
run5	4/19/2006 13:01:45	13.10	6.8						
run5	4/19/2006 13:02:00	13.17	7.4						
run5	4/19/2006 13:02:15	13.11	7.4						
run5	4/19/2006 13:02:30	13.07	4.8						
run5	4/19/2006 13:02:45	13.00	3.5						
run5	4/19/2006 13:03:00	13.13	3.5						
run5	4/19/2006 13:03:15	13.22	4.8						
run5	4/19/2006 13:03:30	13.06	5.1						
run5	4/19/2006 13:03:45	13.08	5.1						
run5	4/19/2006 13:04:00	13.05	5.5						
run5	4/19/2006 13:04:15	13.13	5.8						
run5	4/19/2006 13:04:30	13.17	5.8						
run5	4/19/2006 13:04:45	13.15	4.5						
run5	4/19/2006 13:05:00	13.12	3.8						
run5	4/19/2006 13:05:15	13.05	3.1						
run5	4/19/2006 13:05:30	13.16	5.5						
run5	4/19/2006 13:05:45	13.14	6.1						
run5	4/19/2006 13:06:00	13.12	6.1						
run5	4/19/2006 13:06:15	13.07	6.8						

filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.

testby2 7990 W. Gulf to Lake Hwy.

testby3 Crystal River, FL 34429

testby4 Ph: 352-564-0441

testfor1 Progress Energy Florida

testfor2 Crystal River

testfor3 Unit 5

testfor4 Pt. 75 High Load Gas and Flow RATA

name	5 CO2	5 CO
sn	01415D/3379	48C-74094-375
offset	0	0
fullscale	20	1000
train	1	1
gasstype	co2 3a	co 10
run5	4/19/2006 13:06:30	13.04
run5	4/19/2006 13:06:45	13.18
run5	4/19/2006 13:07:00	13.19
run5	4/19/2006 13:07:15	13.19
run5	4/19/2006 13:07:30	13.16
run5	4/19/2006 13:07:45	13.12
run5	4/19/2006 13:08:00	13.10
run5	4/19/2006 13:08:15	13.16
run5	4/19/2006 13:08:30	13.13
run5	4/19/2006 13:08:45	13.12
run5	4/19/2006 13:09:00	13.08
run5	4/19/2006 13:09:15	13.10
run5	4/19/2006 13:09:30	13.21
run5	4/19/2006 13:09:45	13.13
run5	4/19/2006 13:10:00	13.13
run5	4/19/2006 13:10:15	13.05
run5	4/19/2006 13:10:30	13.06
run5	4/19/2006 13:10:45	13.18
run5	4/19/2006 13:11:00	13.12
run5	4/19/2006 13:11:15	13.15
run5	4/19/2006 13:11:30	13.05
run5	4/19/2006 13:11:45	13.11
run5	4/19/2006 13:12:00	13.21
run5	4/19/2006 13:12:15	13.23
run5	4/19/2006 13:12:30	13.19
run5	4/19/2006 13:12:45	13.11
run5	4/19/2006 13:13:00	13.11
run5	4/19/2006 13:13:15	13.17
run5	4/19/2006 13:13:30	13.25
run5	4/19/2006 13:13:45	13.23
run5	4/19/2006 13:14:00	13.18
run5	4/19/2006 13:14:15	13.10
run5	4/19/2006 13:14:30	13.13
run5	4/19/2006 13:14:45	13.21
run5	4/19/2006 13:15:00	13.14
run5	4/19/2006 13:15:15	13.17
run5	4/19/2006 13:15:30	13.06
run5	4/19/2006 13:15:45	13.16
run5	4/19/2006 13:16:00	13.18
run5	4/19/2006 13:16:15	13.17
run5	4/19/2006 13:16:30	13.16
run5	4/19/2006 13:16:45	13.07
run5	4/19/2006 13:17:00	13.17
run5	4/19/2006 13:17:15	13.19
run5	4/19/2006 13:17:30	13.21
run5	4/19/2006 13:17:45	13.16
run5	4/19/2006 13:18:00	13.05
run5	4/19/2006 13:18:15	13.15
run5	4/19/2006 13:18:30	13.19
run5	4/19/2006 13:18:45	13.10
run5	4/19/2006 13:19:00	13.05
run5	4/19/2006 13:19:15	13.04
run5	4/19/2006 13:19:30	13.10
run5	4/19/2006 13:19:45	13.26
run5	4/19/2006 13:20:00	13.15
run5	4/19/2006 13:20:15	13.08
run5	4/19/2006 13:20:30	13.09
run5	4/19/2006 13:20:45	13.10
run5	4/19/2006 13:21:00	13.18
run5	4/19/2006 13:21:15	13.07
run5	4/19/2006 13:21:30	13.07
run5	4/19/2006 13:21:45	13.08
run5	4/19/2006 13:22:00	13.05
run5	4/19/2006 13:22:15	13.15
run5	4/19/2006 13:22:30	13.14
run5	4/19/2006 13:22:45	13.18
run5	4/19/2006 13:23:00	13.10
averun5	4/19/2006 13:01:00	13.13
scg4	4/19/2006 13:23:15	13.11
scg4	4/19/2006 13:23:30	13.17
scg4	4/19/2006 13:23:45	13.20
scg4	4/19/2006 13:24:00	13.17
scg4	4/19/2006 13:24:15	13.09
scg4	4/19/2006 13:24:30	13.09

21

CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0



filename 4/19/2006 7:51:00  
 testby1 C.E.M. Solutions, Inc.  
 testby2 7990 W. Gulf to Lake Hwy.  
 testby3 Crystal River, FL 34429  
 testby4 Ph: 352-564-0441  
 testfor1 Progress Energy Florida  
 testfor2 Crystal River  
 testfor3 Unit 5  
 testfor4 Pt. 75 High Load Gas and Flow RATA  
 name  
 sn 01415D/3379 48C-74094-375  
 offset 0 0  
 fullscale 20 1000  
 train 1 1  
 gasstype  
 run6 co2 3a co 10  
 4/19/2006 13:41:15 12.95 3.1  
 4/19/2006 13:41:30 13.01 3.2  
 run6 4/19/2006 13:41:45 13.01 3.2  
 run6 4/19/2006 13:42:00 12.94 3.2  
 run6 4/19/2006 13:42:15 12.92 2.4  
 run6 4/19/2006 13:42:30 12.93 3.1  
 run6 4/19/2006 13:42:45 13.03 3.0  
 run6 4/19/2006 13:43:00 12.98 2.1  
 run6 4/19/2006 13:43:15 12.95 2.1  
 run6 4/19/2006 13:43:30 12.98 1.9  
 run6 4/19/2006 13:43:45 12.99 3.7  
 run6 4/19/2006 13:44:00 13.09 5.1  
 run6 4/19/2006 13:44:15 13.02 6.9  
 run6 4/19/2006 13:44:30 12.98 6.2  
 run6 4/19/2006 13:44:45 12.93 3.4  
 run6 4/19/2006 13:45:00 12.95 2.0  
 run6 4/19/2006 13:45:15 13.03 3.0  
 run6 4/19/2006 13:45:30 13.02 5.1  
 run6 4/19/2006 13:45:45 13.06 4.4  
 run6 4/19/2006 13:46:00 13.01 3.7  
 run6 4/19/2006 13:46:15 13.02 3.0  
 run6 4/19/2006 13:46:30 13.07 2.1  
 run6 4/19/2006 13:46:45 13.08 2.1  
 run6 4/19/2006 13:47:00 12.99 2.6  
 run6 4/19/2006 13:47:15 13.01 3.9  
 run6 4/19/2006 13:47:30 13.00 4.2  
 run6 4/19/2006 13:47:45 13.05 4.0  
 run6 4/19/2006 13:48:00 13.06 3.2  
 run6 4/19/2006 13:48:15 12.99 2.3  
 run6 4/19/2006 13:48:30 13.05 4.2  
 run6 4/19/2006 13:48:45 13.05 5.9  
 run6 4/19/2006 13:49:00 13.10 5.6  
 run6 4/19/2006 13:49:15 13.12 4.2  
 run6 4/19/2006 13:49:30 13.05 2.5  
 run6 4/19/2006 13:49:45 13.06 3.1  
 run6 4/19/2006 13:50:00 13.00 4.2  
 run6 4/19/2006 13:50:15 13.04 3.2  
 run6 4/19/2006 13:50:30 13.03 2.1  
 run6 4/19/2006 13:50:45 12.99 2.0  
 run6 4/19/2006 13:51:00 12.98 3.1  
 run6 4/19/2006 13:51:15 12.95 3.9  
 run6 4/19/2006 13:51:30 13.05 3.6  
 run6 4/19/2006 13:51:45 13.04 2.6  
 run6 4/19/2006 13:52:00 13.05 2.0  
 run6 4/19/2006 13:52:15 13.04 2.1  
 run6 4/19/2006 13:52:30 13.03 2.1  
 run6 4/19/2006 13:52:45 13.05 2.2  
 run6 4/19/2006 13:53:00 13.10 3.0  
 run6 4/19/2006 13:53:15 13.09 4.0  
 run6 4/19/2006 13:53:30 13.07 4.2  
 run6 4/19/2006 13:53:45 13.05 4.3  
 run6 4/19/2006 13:54:00 13.00 5.6  
 run6 4/19/2006 13:54:15 13.08 5.7  
 run6 4/19/2006 13:54:30 13.05 4.6  
 run6 4/19/2006 13:54:45 13.05 4.2  
 run6 4/19/2006 13:55:00 13.05 4.2  
 run6 4/19/2006 13:55:15 12.99 3.7  
 run6 4/19/2006 13:55:30 13.09 3.3  
 run6 4/19/2006 13:55:45 13.04 4.7  
 run6 4/19/2006 13:56:00 13.05 4.6  
 run6 4/19/2006 13:56:15 12.99 4.2  
 run6 4/19/2006 13:56:30 13.03 4.2  
 run6 4/19/2006 13:56:45 13.09 4.2  
 run6 4/19/2006 13:57:00 13.06 4.2  
 run6 4/19/2006 13:57:15 13.04 3.3  
 run6 4/19/2006 13:57:30 12.99 2.4  
 run6 4/19/2006 13:57:45 13.00 1.9  
 run6 4/19/2006 13:58:00 13.06 2.6  
 run6 4/19/2006 13:58:15 13.11 3.2  
 run6 4/19/2006 13:58:30 13.08 2.9  
 run6 4/19/2006 13:58:45 13.04 4.0  
 run6 4/19/2006 13:59:00 13.03 3.4  
 run6 4/19/2006 13:59:15 13.07 3.1  
 run6 4/19/2006 13:59:30 13.12 3.2

filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.

testby2 7990 W. Gulf to Lake Hwy.

testby3 Crystal River, FL 34429

testby4 Ph: 352-564-0441

testfor1 Progress Energy Florida

testfor2 Crystal River

testfor3 Unit 5

testfor4 Pt. 75 High Load Gas and Flow RATA

5 CO2 5 CO  
01415D/3379 48C-74094-375

name

sn

offset

fullscale

train

gasstype

co2 3a co 10

run6	4/19/2006 13:59:45	13.04	4.2
run6	4/19/2006 14:00:00	13.05	4.6
run6	4/19/2006 14:00:15	13.02	4.0
run6	4/19/2006 14:00:30	13.08	3.1
run6	4/19/2006 14:00:45	13.06	3.1
run6	4/19/2006 14:01:00	13.04	3.2
run6	4/19/2006 14:01:15	13.11	4.4
run6	4/19/2006 14:01:30	13.01	6.1
run6	4/19/2006 14:01:45	13.04	5.3
run6	4/19/2006 14:02:00	13.10	5.6
run6	4/19/2006 14:02:15	13.07	5.9
run6	4/19/2006 14:02:30	13.07	4.6
run6	4/19/2006 14:02:45	13.05	3.1
run6	4/19/2006 14:03:00	13.07	3.1
run6	4/19/2006 14:03:15	13.07	4.0
run6	4/19/2006 14:03:30	13.07	4.2
run6	4/19/2006 14:03:45	13.05	4.2
run6	4/19/2006 14:04:00	13.06	4.7
run6	4/19/2006 14:04:15	13.02	4.5
run6	4/19/2006 14:04:30	13.07	4.6
run6	4/19/2006 14:04:45	13.03	4.2
run6	4/19/2006 14:05:00	12.97	3.9
run6	4/19/2006 14:05:15	12.96	4.0
run6	4/19/2006 14:05:30	12.96	2.9
run6	4/19/2006 14:05:45	13.12	4.0
run6	4/19/2006 14:06:00	13.08	4.2
run6	4/19/2006 14:06:15	13.09	2.8
run6	4/19/2006 14:06:30	13.06	2.5
run6	4/19/2006 14:06:45	13.07	2.3
run6	4/19/2006 14:07:00	13.10	3.2
run6	4/19/2006 14:07:15	13.06	4.0
run6	4/19/2006 14:07:30	13.06	3.6
run6	4/19/2006 14:07:45	13.05	2.7
run6	4/19/2006 14:08:00	13.07	1.6
run6	4/19/2006 14:08:15	13.09	2.1
run6	4/19/2006 14:08:30	13.08	2.0
run6	4/19/2006 14:08:45	13.08	2.1
run6	4/19/2006 14:09:00	13.02	1.9
run6	4/19/2006 14:09:15	13.02	2.0
run6	4/19/2006 14:09:30	13.08	2.5
run6	4/19/2006 14:09:45	13.09	3.1
run6	4/19/2006 14:10:00	13.05	3.1
run6	4/19/2006 14:10:15	13.02	3.1
run6	4/19/2006 14:10:30	12.97	3.0
run6	4/19/2006 14:10:45	13.06	2.9
run6	4/19/2006 14:11:00	13.13	2.9
run6	4/19/2006 14:11:15	13.05	3.1
run6	4/19/2006 14:11:30	13.08	2.6
run6	4/19/2006 14:11:45	13.04	2.1
run6	4/19/2006 14:12:00	13.13	2.1
run6	4/19/2006 14:12:15	13.11	3.4
run6	4/19/2006 14:12:30	13.06	5.1
run6	4/19/2006 14:12:45	13.09	5.1
run6	4/19/2006 14:13:00	13.01	5.1
run6	4/19/2006 14:13:15	13.06	6.4
run6	4/19/2006 14:13:30	13.10	8.6
run6	4/19/2006 14:13:45	13.02	6.6
run6	4/19/2006 14:14:00	13.05	4.6
run6	4/19/2006 14:14:15	12.98	4.3
run6	4/19/2006 14:14:30	13.06	9.4
run6	4/19/2006 14:14:45	13.05	12.5
run6	4/19/2006 14:15:00	13.08	8.7
run6	4/19/2006 14:15:15	13.06	5.1
run6	4/19/2006 14:15:30	13.00	4.2
run6	4/19/2006 14:15:45	12.99	3.6
run6	4/19/2006 14:16:00	13.08	4.7
run6	4/19/2006 14:16:15	13.07	4.9
run6	4/19/2006 14:16:30	13.02	3.4
run6	4/19/2006 14:16:45	12.98	2.2
averun6	4/19/2006 13:56:00	13.05	4.0
scg4	4/19/2006 14:17:15	13.06	2.1
scg4	4/19/2006 14:17:30	12.98	2.1
scg4	4/19/2006 14:17:45	12.95	2.1
scg4	4/19/2006 14:18:00	12.93	2.1

21

CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0
CC150094/cg4	NOx	243	SO2	448	0	0

filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.

testby2 7990 W. Gulf to Lake Hwy.

testby3 Crystal River, FL 34429

testby4 Ph: 352-564-0441

testfor1 Progress Energy Florida

testfor2 Crystal River

testfor3 Unit 5

testfor4 Pt. 75 High Load Gas and Flow RATA

5 CO2  
01415D/3379

5 CO  
48C-74094-375

0  
20

0  
1000

1  
1

co2 3a co 10

gasstype

scg4 4/19/2006 14:18:15 12.99 2.1

scg4 4/19/2006 14:18:30 13.09 3.6

scg4 4/19/2006 14:18:45 8.97 4.8

scg4 4/19/2006 14:19:00 4.87 4.2

scg4 4/19/2006 14:19:15 8.50 3.0

scg4 4/19/2006 14:19:30 8.62 2.1

scg4 4/19/2006 14:19:45 8.63 1.6

scg4 4/19/2006 14:20:00 8.63 1.9

scg4 4/19/2006 14:20:15 8.64 2.0

scg4 4/19/2006 14:20:30 8.63 2.1

noxspan1 4/19/2006 14:20:30 8.63 2.1

so2span1 4/19/2006 14:20:30 8.63 2.1

scg6 4/19/2006 14:20:45 8.63 1.9

scg6 4/19/2006 14:21:00 8.64 2.1

scg6 4/19/2006 14:21:15 8.64 1.6

scg6 4/19/2006 14:21:30 8.64 2.1

scg6 4/19/2006 14:21:45 8.64 2.1

scg6 4/19/2006 14:22:00 8.64 1.9

scg6 4/19/2006 14:22:15 8.64 2.1

scg6 4/19/2006 14:22:30 7.84 5.6

scg6 4/19/2006 14:22:45 1.24 91.2

scg6 4/19/2006 14:23:00 0.27 215.9

scg6 4/19/2006 14:23:15 0.20 276.7

scg6 4/19/2006 14:23:30 0.17 287.6

scg6 4/19/2006 14:23:45 0.15 289.8

cospan1 4/19/2006 14:23:45 0.15 289.8

scg2 4/19/2006 14:24:00 0.14 289.4

scg2 4/19/2006 14:24:15 0.13 288.7

scg2 4/19/2006 14:24:30 0.12 289.1

scg2 4/19/2006 14:24:45 0.11 289.4

scg2 4/19/2006 14:25:00 0.10 289.1

scg2 4/19/2006 14:25:15 0.10 289.6

scg2 4/19/2006 14:25:30 0.10 289.8

scg2 4/19/2006 14:25:45 4.56 239.6

scg2 4/19/2006 14:26:00 10.45 112.8

scg2 4/19/2006 14:26:15 10.73 26.8

scg2 4/19/2006 14:26:30 10.78 3.8

co2span1 4/19/2006 14:26:30 10.78 3.8

o2span1 4/19/2006 14:26:30 10.78 3.8

scg1 4/19/2006 14:26:45 10.81 0.1

scg1 4/19/2006 14:27:00 10.83 0.0

scg1 4/19/2006 14:27:15 10.85 0.0

scg1 4/19/2006 14:27:30 10.85 0.0

scg1 4/19/2006 14:27:45 10.86 0.0

scg1 4/19/2006 14:28:00 10.86 0.0

scg1 4/19/2006 14:28:15 10.87 0.0

scg1 4/19/2006 14:28:30 9.78 0.0

scg1 4/19/2006 14:28:45 1.42 0.0

scg1 4/19/2006 14:29:00 0.28 0.0

scg1 4/19/2006 14:29:15 0.21 0.0

scg1 4/19/2006 14:29:30 0.17 0.0

scg1 4/19/2006 14:29:45 0.15 0.0

co2zero1 4/19/2006 14:29:45 0.15 0.0

o2zero1 4/19/2006 14:29:45 0.15 0.0

noxzero1 4/19/2006 14:29:45 0.15 0.0

so2zero1 4/19/2006 14:29:30 0.17 0.0

cozero1 4/19/2006 14:29:45 0.15 0.0

run71 4/19/2006 14:31:15 0.10 0.0

run71 4/19/2006 14:31:30 0.09 0.0

run71 4/19/2006 14:31:45 0.10 0.0

run71 4/19/2006 14:32:00 5.29 0.6

run7 4/19/2006 14:32:15 11.74 2.3

run7 4/19/2006 14:32:30 12.73 3.8

run7 4/19/2006 14:32:45 12.93 3.9

run7 4/19/2006 14:33:00 12.86 3.2

run7 4/19/2006 14:33:15 12.86 1.8

run7 4/19/2006 14:33:30 12.85 2.8

run7 4/19/2006 14:33:45 12.89 3.0

run7 4/19/2006 14:34:00 12.92 2.8

run7 4/19/2006 14:34:15 12.86 2.9

run7 4/19/2006 14:34:30 12.93 2.9

run7 4/19/2006 14:34:45 12.88 2.1

run7 4/19/2006 14:35:00 12.99 1.7

run7 4/19/2006 14:35:15 13.01 3.4

CC150094/cg4 NOx 243 SO2 448 0 0

CC183009/cg6 CO 293 0 0 0 0

filename 4/19/2006 7:51:00  
 testby1 C.E.M. Solutions, Inc.  
 testby2 7990 W. Gulf to Lake Hwy.  
 testby3 Crystal River, FL 34429  
 testby4 Ph: 352-564-0441  
 testfor1 Progress Energy Florida  
 testfor2 Crystal River  
 testfor3 Unit 5  
 testfor4 PL 75 High Load Gas and Flow RATA  
  
 name 5 CO2 5 CO  
 sn 01415D/3379 48C-74094-375  
 offset 0 0  
 fullscale 20 1000  
 train 1 1  
 gasstype co2 3a co 10  
  
 run7 4/19/2006 14:35:30 12.98 4.7  
 run7 4/19/2006 14:35:45 12.96 4.8  
 run7 4/19/2006 14:36:00 12.94 3.4  
 run7 4/19/2006 14:36:15 13.01 2.2  
 run7 4/19/2006 14:36:30 13.03 1.9  
 run7 4/19/2006 14:36:45 12.95 1.9  
 run7 4/19/2006 14:37:00 12.96 1.8  
 run7 4/19/2006 14:37:15 12.93 2.2  
 run7 4/19/2006 14:37:30 13.00 2.6  
 run7 4/19/2006 14:37:45 13.01 3.1  
 run7 4/19/2006 14:38:00 12.96 3.8  
 run7 4/19/2006 14:38:15 12.94 3.9  
 run7 4/19/2006 14:38:30 13.01 3.2  
 run7 4/19/2006 14:38:45 12.99 2.4  
 run7 4/19/2006 14:39:00 12.99 3.0  
 run7 4/19/2006 14:39:15 12.94 2.8  
 run7 4/19/2006 14:39:30 12.93 2.1  
 run7 4/19/2006 14:39:45 12.96 2.7  
 run7 4/19/2006 14:40:00 12.96 2.9  
 run7 4/19/2006 14:40:15 13.06 2.7  
 run7 4/19/2006 14:40:30 12.97 4.5  
 run7 4/19/2006 14:40:45 12.99 4.9  
 run7 4/19/2006 14:41:00 12.98 4.8  
 run7 4/19/2006 14:41:15 12.95 4.8  
 run7 4/19/2006 14:41:30 13.00 3.9  
 run7 4/19/2006 14:41:45 12.99 3.2  
 run7 4/19/2006 14:42:00 12.97 3.2  
 run7 4/19/2006 14:42:15 12.95 2.0  
 run7 4/19/2006 14:42:30 12.96 3.4  
 run7 4/19/2006 14:42:45 13.01 7.2  
 run7 4/19/2006 14:43:00 13.03 7.1  
 run7 4/19/2006 14:43:15 12.97 6.8  
 run7 4/19/2006 14:43:30 12.92 6.1  
 run7 4/19/2006 14:43:45 12.89 3.8  
 run7 4/19/2006 14:44:00 12.93 2.7  
 run7 4/19/2006 14:44:15 13.02 2.9  
 run7 4/19/2006 14:44:30 12.96 3.1  
 run7 4/19/2006 14:44:45 12.97 2.0  
 run7 4/19/2006 14:45:00 12.93 2.1  
 run7 4/19/2006 14:45:15 12.94 2.0  
 run7 4/19/2006 14:45:30 13.02 2.7  
 run7 4/19/2006 14:45:45 13.01 7.4  
 run7 4/19/2006 14:46:00 13.01 7.4  
 run7 4/19/2006 14:46:15 12.96 5.8  
 run7 4/19/2006 14:46:30 13.01 5.1  
 run7 4/19/2006 14:46:45 13.08 7.1  
 run7 4/19/2006 14:47:00 13.01 9.5  
 run7 4/19/2006 14:47:15 12.96 7.9  
 run7 4/19/2006 14:47:30 12.92 4.6  
 run7 4/19/2006 14:47:45 13.00 3.5  
 run7 4/19/2006 14:48:00 13.07 5.5  
 run7 4/19/2006 14:48:15 13.07 7.1  
 run7 4/19/2006 14:48:30 13.03 5.8  
 run7 4/19/2006 14:48:45 12.94 2.6  
 run7 4/19/2006 14:49:00 12.96 2.8  
 run7 4/19/2006 14:49:15 13.00 3.8  
 run7 4/19/2006 14:49:30 12.96 3.2  
 run7 4/19/2006 14:49:45 12.95 2.1  
 run7 4/19/2006 14:50:00 12.90 1.8  
 run7 4/19/2006 14:50:15 12.92 3.8  
 run7 4/19/2006 14:50:30 13.04 5.8  
 run7 4/19/2006 14:50:45 12.97 6.8  
 run7 4/19/2006 14:51:00 12.95 5.5  
 run7 4/19/2006 14:51:15 12.96 4.2  
 run7 4/19/2006 14:51:30 -12.96 3.9  
 run7 4/19/2006 14:51:45 13.00 3.9  
 run7 4/19/2006 14:52:00 12.96 3.4  
 run7 4/19/2006 14:52:15 12.93 2.8  
 run7 4/19/2006 14:52:30 12.88 1.9  
 run7 4/19/2006 14:52:45 12.89 1.8  
 run7 4/19/2006 14:53:00 12.98 2.1  
 run7 4/19/2006 14:53:15 12.92 1.9  
 run7 4/19/2006 14:53:30 12.93 2.1  
 run7 4/19/2006 14:53:45 12.92 1.9

filename 4/19/2006 7:51:00

4/  
lilname1 C.E.M. Solutions, Inc.  
testby2 7990 W. Gulf to Lake Hwy.  
testby3 Crystal River, FL 34429  
testby4 Ph: 352-564-0441  
testfor1 Progress Energy Florida  
testfor2 Crystal River  
testfor3 Unit 5  
testfor4 Pt. 75 High Load Gas and Flow R

#### **testfor4 Pt. 75 High Load Gas and Flow RATA**

5 CO<sub>2</sub>      5 CO  
01415D/3379 48C-74094-375  
0                0  
20              1000  
1                1  
CO<sub>2</sub> 3a      CO 10

gastype			co2	so	to
run7	4/19/2006	14:54:00	13.01	2.6	
run7	4/19/2006	14:54:15	13.04	3.0	
run7	4/19/2006	14:54:30	12.96	2.7	
run7	4/19/2006	14:54:45	12.94	3.9	
run7	4/19/2006	14:55:00	12.96	4.2	
run7	4/19/2006	14:55:15	12.96	4.2	
run7	4/19/2006	14:55:30	13.02	4.6	
run7	4/19/2006	14:55:45	12.98	4.7	
run7	4/19/2006	14:56:00	12.91	3.4	
run7	4/19/2006	14:56:15	12.97	3.1	
run7	4/19/2006	14:56:30	12.96	3.9	
run7	4/19/2006	14:56:45	-12.97	4.8	
run7	4/19/2006	14:57:00	13.00	3.9	
run7	4/19/2006	14:57:15	12.90	7.1	
run7	4/19/2006	14:57:30	12.97	9.0	
run7	4/19/2006	14:57:45	12.93	7.8	
run7	4/19/2006	14:58:00	12.96	7.4	
run7	4/19/2006	14:58:15	12.98	5.5	
run7	4/19/2006	14:58:30	12.90	3.1	
run7	4/19/2006	14:58:45	12.91	2.0	
run7	4/19/2006	14:59:00	12.89	1.7	
run7	4/19/2006	14:59:15	12.97	2.1	
run7	4/19/2006	14:59:30	12.98	1.8	
run7	4/19/2006	14:59:45	12.97	2.1	
run7	4/19/2006	15:00:00	12.87	2.0	
run7	4/19/2006	15:00:15	12.88	2.1	
run7	4/19/2006	15:00:30	12.98	2.4	
run7	4/19/2006	15:00:45	13.12	4.5	
run7	4/19/2006	15:01:00	13.06	5.1	
run7	4/19/2006	15:01:15	12.94	3.8	
run7	4/19/2006	15:01:30	12.89	2.4	
run7	4/19/2006	15:01:45	12.85	2.1	
run7	4/19/2006	15:02:00	12.99	2.0	
run7	4/19/2006	15:02:15	12.94	1.9	
run7	4/19/2006	15:02:30	12.96	2.1	
run7	4/19/2006	15:02:45	12.95	1.9	
run7	4/19/2006	15:03:00	12.93	2.1	
run7	4/19/2006	15:03:15	13.03	2.9	
run7	4/19/2006	15:03:30	12.95	3.1	
run7	4/19/2006	15:03:45	12.94	2.6	
run7	4/19/2006	15:04:00	12.90	3.1	
run7	4/19/2006	15:04:15	12.87	2.5	
run7	4/19/2006	15:04:30	12.92	2.1	
run7	4/19/2006	15:04:45	12.94	2.1	
run7	4/19/2006	15:05:00	12.90	1.9	
run7	4/19/2006	15:05:15	12.91	1.8	
run7	4/19/2006	15:05:30	12.92	2.1	
run7	4/19/2006	15:05:45	12.94	2.0	
averun7	4/19/2006	14:44:00	12.96	3.7	
scg4	4/19/2006	15:06:15	13.00	3.5	
scg4	4/19/2006	15:06:30	12.97	3.9	
scg4	4/19/2006	15:06:45	12.90	2.8	
scg4	4/19/2006	15:07:00	12.95	2.1	
scg4	4/19/2006	15:07:15	12.97	1.9	
scg4	4/19/2006	15:07:30	12.97	1.9	
scg4	4/19/2006	15:07:45	8.62	2.1	
scg4	4/19/2006	15:08:00	5.10	2.1	
scg4	4/19/2006	15:08:15	8.52	2.1	
scg4	4/19/2006	15:08:30	8.62	2.1	
scg4	4/19/2006	15:08:45	8.63	1.9	
scg4	4/19/2006	15:09:00	8.63	2.1	
noxspan1	4/19/2006	15:09:00	8.63	2.1	
so2span1	4/19/2006	15:09:00	8.63	2.1	
scg6	4/19/2006	15:09:15	8.64	2.1	
scg6	4/19/2006	15:09:30	8.64	2.1	
scg6	4/19/2006	15:09:45	8.64	2.0	
scg6	4/19/2006	15:10:00	8.64	1.9	
scg6	4/19/2006	15:10:15	8.64	2.1	
scg6	4/19/2006	15:10:30	8.64	1.8	
scg6	4/19/2006	15:10:45	8.64	2.1	
scg6	4/19/2006	15:11:00	8.55	4.3	
scg6	4/19/2006	15:11:15	2.61	59.2	
scg6	4/19/2006	15:11:30	0.32	179.6	
scg6	4/19/2006	15:11:45	0.21	266.5	

filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.  
testby2 7990 W. Gulf to Lake Hwy.  
testby3 Crystal River, FL 34429  
testby4 Ph: 352-564-0441  
testfor1 Progress Energy Florida  
testfor2 Crystal River  
testfor3 Unit 5  
testfor4 Pt. 75 High Load Gas and Flow RATA

name	5 CO2	5 CO						
sn	01415D/3379	48C-74094-375						
offset	0	0						
fullscale	20	1000						
train	1	1						
gasstype	co2 3a	co 10						
scg6	4/19/2006 15:12:00	0.18	286.1	CC183009/cg6	CO	293	0	0
scg6	4/19/2006 15:12:15	0.16	289.2	CC183009/cg6	CO	293	0	0
cospan1	4/19/2006 15:12:15	0.16	289.2	CC183009/cg6	CO	293	0	0
scg2	4/19/2006 15:12:30	0.15	289.6	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:12:45	0.14	289.4	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:13:00	0.13	289.2	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:13:15	0.12	288.8	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:13:30	0.11	289.5	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:13:45	0.11	290.4	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:14:00	0.10	290.1	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:14:15	1.67	271.1	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:14:30	9.74	160.1	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:14:45	10.70	42.7	CC89066/cg2	O2	12.9	CO2	10.9
scg2	4/19/2006 15:15:00	10.77	8.4	CC89066/cg2	O2	12.9	CO2	10.9
co2span1	4/19/2006 15:15:00	10.77	8.4	CC89066/cg2	O2	12.9	CO2	10.9
o2span1	4/19/2006 15:15:00	10.77	8.4	CC89066/cg2	O2	12.9	CO2	10.9
scg1	4/19/2006 15:15:15	10.80	0.4	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:15:30	10.82	0.0	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:15:45	10.83	0.0	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:16:00	10.85	-0.2	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:16:15	10.85	-0.1	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:16:30	10.86	-0.1	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:16:45	10.87	-0.2	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:17:00	10.79	0.0	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:17:15	3.38	0.0	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:17:30	0.34	0.0	CC 81224/cg1	CO2	0	NOx	0
scg1	4/19/2006 15:17:45	0.22	0.0	CC 81224/cg1	CO2	0	NOx	0
co2zero1	4/19/2006 15:17:45	0.22	0.0	CC 81224/cg1	CO2	0	NOx	0
noxzero1	4/19/2006 15:17:30	0.34	0.0	CC 81224/cg1	CO2	0	NOx	0
so2zero1	4/19/2006 15:17:30	0.34	0.0	CC 81224/cg1	CO2	0	NOx	0
cozer01	4/19/2006 15:17:30	0.34	0.0	CC 81224/cg1	CO2	0	NOx	0
run8	4/19/2006 15:23:00	12.95	4.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:23:15	12.97	6.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:23:30	12.92	5.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:23:45	12.98	3.7	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:24:00	12.98	3.0	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:24:15	12.95	2.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:24:30	12.90	2.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:24:45	12.90	3.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:25:00	13.03	3.0	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:25:15	12.94	2.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:25:30	12.98	2.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:25:45	13.00	3.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:26:00	12.95	4.3	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:26:15	13.03	5.9	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:26:30	13.03	8.4	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:26:45	13.02	8.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:27:00	12.95	4.7	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:27:15	13.03	3.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:27:30	13.12	6.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:27:45	13.07	8.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:28:00	12.97	6.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:28:15	12.92	3.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:28:30	12.90	2.3	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:28:45	12.96	2.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:29:00	13.01	2.9	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:29:15	12.93	3.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:29:30	12.94	5.0	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:29:45	12.95	6.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:30:00	12.96	5.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:30:15	12.99	3.7	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:30:30	12.91	3.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:30:45	12.96	2.6	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:31:00	12.92	2.9	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:31:15	12.96	3.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:31:30	13.00	2.7	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:31:45	12.95	3.0	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:32:00	12.94	2.4	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:32:15	12.96	3.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:32:30	12.99	3.0	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:32:45	13.00	2.1	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:33:00	12.96	2.2	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:33:15	12.93	2.7	CC 81224/cg1	CO2	0	SO2	0
run8	4/19/2006 15:33:30	12.98	2.7	CC 81224/cg1	CO2	0	SO2	0

filename 4/19/2006 7:51:00

lname	
testby1	C.E.M. Solutions, Inc.
testby2	7990 W. Gulf to Lake Hwy.
testby3	Crystal River, FL 34429
testby4	Ph: 352-564-0441
testfor1	Progress Energy Florida
testfor2	Crystal River
testfor3	Unit 5
testfor4	Pt. 75 High Load Gas and F

5 CO2 5 CO  
01415D/3379 48C-74094-375  
0  
20 100  
1

train	gasstype		co2 3a	co 10
run8		4/19/2006 15:33:45	13.00	2.
run8		4/19/2006 15:34:00	12.98	3.
run8		4/19/2006 15:34:15	12.92	3.
run8		4/19/2006 15:34:30	12.92	8.
run8		4/19/2006 15:34:45	12.98	9.
run8		4/19/2006 15:35:00	12.96	6.
run8		4/19/2006 15:35:15	12.98	3.
run8		4/19/2006 15:35:30	12.94	2.
run8		4/19/2006 15:35:45	12.92	2.
run8		4/19/2006 15:36:00	12.92	2.
run8		4/19/2006 15:36:15	12.89	2.
run8		4/19/2006 15:36:30	13.02	2.
run8		4/19/2006 15:36:45	13.02	5.
run8		4/19/2006 15:37:00	12.98	7.
run8		4/19/2006 15:37:15	12.95	7.
run8		4/19/2006 15:37:30	12.90	4.
run8		4/19/2006 15:37:45	12.96	2.
run8		4/19/2006 15:38:00	12.97	3.
run8		4/19/2006 15:38:15	13.00	3.
run8		4/19/2006 15:38:30	12.93	2.
run8		4/19/2006 15:38:45	12.94	4.
run8		4/19/2006 15:39:00	12.99	5.
run8		4/19/2006 15:39:15	13.02	3.
run8		4/19/2006 15:39:30	12.99	2.
run8		4/19/2006 15:39:45	12.97	3.
run8		4/19/2006 15:40:00	12.96	2.
run8		4/19/2006 15:40:15	12.99	2.
run8		4/19/2006 15:40:30	13.03	3.
run8		4/19/2006 15:40:45	12.97	5.
run8		4/19/2006 15:41:00	12.97	5.
run8		4/19/2006 15:41:15	12.95	4.
run8		4/19/2006 15:41:30	12.96	3.
run8		4/19/2006 15:41:45	12.95	1.
run8		4/19/2006 15:42:00	12.81	2.
run8		4/19/2006 15:42:15	12.89	2.
run8		4/19/2006 15:42:30	12.95	2.
run8		4/19/2006 15:42:45	13.02	3.
run8		4/19/2006 15:43:00	13.06	3.
run8		4/19/2006 15:43:15	12.97	2.
run8		4/19/2006 15:43:30	12.95	1.
run8		4/19/2006 15:43:45	12.93	2.
run8		4/19/2006 15:44:00	12.98	2.
run8		4/19/2006 15:44:15	13.00	2.
run8		4/19/2006 15:44:30	12.92	3.
run8		4/19/2006 15:44:45	12.87	3.
run8		4/19/2006 15:45:00	12.89	2.
run8		4/19/2006 15:45:15	12.96	1.
run8		4/19/2006 15:45:30	12.99	2.
averun8		4/19/2006 15:24:00	12.97	3.
scg4		4/19/2006 15:46:00	12.97	2.
scg4		4/19/2006 15:46:15	12.99	2.
scg4		4/19/2006 15:46:30	12.97	3.
scg4		4/19/2006 15:46:45	12.98	3.
scg4		4/19/2006 15:47:00	12.94	3.
scg4		4/19/2006 15:47:15	12.94	2.
scg4		4/19/2006 15:47:30	7.06	1.
scg4		4/19/2006 15:47:45	5.74	2.
scg4		4/19/2006 15:48:00	8.55	1.
scg4		4/19/2006 15:48:15	8.61	2.
scg4		4/19/2006 15:48:30	8.62	1.
scg4		4/19/2006 15:48:45	8.63	2.
scg4		4/19/2006 15:49:00	8.62	1.
scg4		4/19/2006 15:49:15	8.63	2.
noxspan1		4/19/2006 15:49:15	8.63	2.
so2span1		4/19/2006 15:49:00	8.62	1.
scg6		4/19/2006 15:49:30	8.63	2.
scg6		4/19/2006 15:49:45	8.63	2.
scg6		4/19/2006 15:50:00	8.62	2.
scg6		4/19/2006 15:50:15	8.63	2.
scg6		4/19/2006 15:50:30	8.62	2.
scg6		4/19/2006 15:50:45	8.62	2.
scg6		4/19/2006 15:51:00	8.63	1.
scg6		4/19/2006 15:51:15	7.05	11.
scg6		4/19/2006 15:51:30	0.82	108.

filename 4/19/2006 7:51:00  
 testby1 C.E.M. Solutions, Inc.  
 testby2 7990 W. Gulf to Lake Hwy.  
 testby3 Crystal River, FL 34429  
 testby4 Ph: 352-564-0441  
 testfor1 Progress Energy Florida  
 testfor2 Crystal River  
 testfor3 Unit 5  
 testfor4 Pt. 75 High Load Gas and Flow RATA

	5 CO2	5 CO										
	01415D/3379	48C-74094-375										
name			0	0								
sn			20	1000								
offset												
fullscale			1	1								
train												
gasstype	co2 3a	co 10										
scg6	4/19/2006 15:51:45	0.25	224.1	CC183009/cg6	CO	293	0	0	0			
scg6	4/19/2006 15:52:00	0.20	278.3	CC183009/cg6	CO	293	0	0	0			
scg6	4/19/2006 15:52:15	0.17	288.5	CC183009/cg6	CO	293	0	0	0			
scg6	4/19/2006 15:52:30	0.15	289.2	CC183009/cg6	CO	293	0	0	0			
cospan1	4/19/2006 15:52:30	0.15	289.2	CC183009/cg6	CO	293	0	0	0			
scg2	4/19/2006 15:52:45	0.14	289.6	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:53:00	0.13	289.3	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:53:15	0.12	289.4	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:53:30	0.11	289.9	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:53:45	0.10	289.9	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:54:00	0.10	290.1	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:54:15	0.09	289.4	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:54:30	3.43	253.9	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:54:45	10.28	125.1	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:55:00	10.71	32.0	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:55:15	10.77	5.2	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg2	4/19/2006 15:55:30	10.80	-0.5	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
co2span1	4/19/2006 15:55:15	10.77	5.2	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
o2span1	4/19/2006 15:55:15	10.77	5.2	CC89066/cg2	O2	12.9	CO2	10.9	0	0	0	
scg1	4/19/2006 15:55:45	10.81	-0.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:56:00	10.83	-0.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:56:15	10.84	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:56:30	10.85	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:56:45	10.85	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:57:00	10.85	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:57:15	10.86	-0.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:57:30	8.67	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:57:45	0.93	-0.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:58:00	0.27	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
scg1	4/19/2006 15:58:15	0.20	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
co2zero1	4/19/2006 15:58:15	0.20	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
o2zero1	4/19/2006 15:58:15	0.20	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
noxzero1	4/19/2006 15:58:15	0.20	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
so2zero1	4/19/2006 15:57:00	10.85	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
cozero1	4/19/2006 15:56:45	10.85	0.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:02:30	12.89	5.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:02:45	12.91	6.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:03:00	12.85	5.9	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:03:15	12.90	5.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:03:30	12.95	4.9	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:03:45	12.87	4.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:04:00	12.91	4.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:04:15	12.92	4.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:04:30	12.95	3.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:04:45	13.00	3.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:05:00	12.87	3.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:05:15	12.87	3.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:05:30	12.93	4.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:05:45	13.00	4.7	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:06:00	13.02	5.3	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:06:15	13.00	5.9	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:06:30	13.02	6.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:06:45	12.96	5.5	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:07:00	12.94	3.9	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:07:15	12.99	2.3	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:07:30	13.00	1.7	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:07:45	12.97	2.5	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:08:00	13.00	3.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:08:15	13.03	3.6	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:08:30	13.08	4.4	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:08:45	13.04	5.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:09:00	12.97	4.3	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:09:15	13.03	3.4	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:09:30	12.99	4.6	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:09:45	13.06	7.2	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:10:00	13.00	7.8	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:10:15	12.99	6.5	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:10:30	13.00	5.0	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:10:45	13.01	5.8	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:11:00	13.09	11.5	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:11:15	13.06	13.1	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:11:30	13.07	11.3	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:11:45	12.99	8.9	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0
run9	4/19/2006 16:12:00	12.91	5.7	CC 81224/cg1	CO2	0	NOx	0	SO2	0	O2	0



filename 4/19/2006 7:51:00

testby1 C.E.M. Solutions, Inc.

testby2 7990 W. Gulf to Lake Hwy.

testby3 Crystal River, FL 34429

testby4 Ph: 352-564-0441

testfor1 Progress Energy Florida

testfor2 Crystal River

testfor3 Unit 5

testfor4 Pt. 75 High Load Gas and Flow RATA

name	5 CO2	5 CO							
sn	01415D/3379	48C-74094-375	0	0	0	0	0		
offset	20	1000	0	0	0	0	0		
fullscale	1	1	0	0	0	0	0		
train									
gastype	co2 3a	co 10							
scg6	4/19/2006 16:30:00	8.62	2.1	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:30:15	8.62	1.9	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:30:30	8.11	7.7	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:30:45	1.52	73.5	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:31:00	0.27	217.5	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:31:15	0.21	272.9	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:31:30	0.17	287.7	CC183009/cg6	CO	293	0	0	0
scg6	4/19/2006 16:31:45	0.15	289.0	CC183009/cg6	CO	293	0	0	0
cospan1	4/19/2006 16:31:45	0.15	289.0	CC183009/cg6	CO	293	0	0	0
scg2	4/19/2006 16:32:00	0.14	289.1	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:32:15	0.13	289.1	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:32:30	0.12	288.6	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:32:45	0.12	289.4	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:33:00	0.11	289.4	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:33:15	0.10	288.8	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:33:30	0.09	289.7	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:33:45	3.46	260.4	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:34:00	10.28	116.5	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:34:15	10.71	34.6	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:34:30	10.76	3.7	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:34:45	10.79	0.3	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:35:00	10.81	0.0	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:35:15	10.82	0.0	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg2	4/19/2006 16:35:30	10.83	0.0	CC89066/cg2	O2	12.9 CO2	10.9	0	0
co2span1	4/19/2006 16:34:45	10.79	0.3	CC89066/cg2	O2	12.9 CO2	10.9	0	0
o2span1	4/19/2006 16:35:00	10.81	0.0	CC89066/cg2	O2	12.9 CO2	10.9	0	0
scg1	4/19/2006 16:35:45	10.84	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:36:00	10.85	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:36:15	10.85	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:36:30	10.85	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:36:45	10.86	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:37:00	10.86	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:37:15	10.86	-0.4	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:37:30	10.42	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:37:45	2.14	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:38:00	0.31	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
scg1	4/19/2006 16:38:15	0.22	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
co2zero1	4/19/2006 16:38:15	0.22	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
o2zero1	4/19/2006 16:38:15	0.22	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
noxzero1	4/19/2006 16:37:30	10.42	0.0	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
so2zero1	4/19/2006 16:38:00	0.31	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
cozero1	4/19/2006 16:37:45	2.14	-0.2	CC 81224/cg1	CO2	0 NOx	0 SO2	0 O2	0
so2zero									
so2span									
noxzero									
noxspan									
co2zero									
co2span									
o2zero									
o2span									
thczero									
thcspan									
cozero									
cospan									

so2ezero Parameter Not Found  
so2mid Parameter Not Found  
so2high Parameter Not Found  
noxezero Parameter Not Found  
noxlow Parameter Not Found  
noxmid Parameter Not Found  
noxhigh Parameter Not Found  
co2ezero Parameter Not Found  
co2mid Parameter Not Found  
co2high Parameter Not Found  
o2ezero Parameter Not Found  
o2mid Parameter Not Found  
o2high Parameter Not Found  
thcezero Parameter Not Found  
thclow Parameter Not Found  
thcmid Parameter Not Found  
thchigh Parameter Not Found  
coazero Parameter Not Found  
colow Parameter Not Found  
comid Parameter Not Found

filename 4/19/2006 7:51:00  
testby1 C.E.M. Solutions, Inc.  
testby2 7990 W. Gulf to Lake Hwy.  
testby3 Crystal River, FL 34429  
testby4 Ph: 352-564-0441  
testfor1 Progress Energy Florida  
testfor2 Crystal River  
testfor3 Unit 5  
testfor4 Pt. 75 High Load Gas and Flow RATA  
name 5 CO2 5 CO  
sn 01415D/3379 48C-74094-375  
offset 0 0  
fullscale 20 1000  
train 1 1  
gastype co2 3a co 10  
cohig Parameter Not Found  
End

07/18/06

---

## Determination of Emission Rate Change – Data Sheets

NOX DETERMINATION OF EMISSION RATE CHANGE

Emission Rate Change  
40 CFR 60 Appendix C

Test Data	Baseline	Blend	3.3	3.3	Look-up Table t'
	6/5/2006 lb/mmbtu	5/22/2006 lb/mmbtu	Eq 2 Varance S^2	Eq 2 Varance S^2	
Run 1	0.501	0.443	2.92E-05	8.66E-05	2 2.920
Run 2	0.504	0.436	5.76E-06	0.000266	3 2.353
Run 3	0.502	0.455	1.94E-05	7.25E-06	4 2.132
Run 4	0.513	0.455	4.36E-05	7.25E-06	5 2.015
Run 5	0.512	0.447	3.14E-05	2.82E-05	6 1.943
Run 6		0.439		0.000177	7 1.895
Run 7		0.446		3.98E-05	8 1.860
Run 8		0.453		4.79E-07	9 1.833
Run 9		0.456		1.36E-05	10 1.812
Run 10		0.457		2.2E-05	11 1.796
Run 11		0.456		1.36E-05	12 1.782
Run 12		0.452		9.47E-08	13 1.771
Run 13		0.485		0.001069	14 1.761
Run 14					15 1.753
Run 15					16 1.746
Run 16					17 1.740
Run 17					18 1.734
Run 18					19 1.729
Run 19					20 1.725
Run 20					21 1.721
Run 21					22 1.717
	Sum	2.532	5.88	0.000129	23 1.714
	Runs	5	13	0.001731	24 1.711
3.2 Arithmetic Mean	E	0.5064	0.452308	Eq 1	25 1.708
3.3 Variance	S^2	3.23E-05	0.000144	Eq 2	26 1.706
3.4 Pooled Estimate	Sp		0.010782	Eq 3	27 1.703
3.5 Test Statistic	t		-9.533734		28 1.701
Look-up table	na + nb -2	16			29 1.699
	t' 95% Confidence	1.746			>=30 1.645

Results

4.1 Significant Increase (t > t')

NO

SO<sub>2</sub> DETERMINATION OF EMISSION RATE CHANGE

Emission Rate Change  
40 CFR 60 Appendix C

Test Data	Baseline	Blend	3.3	3.3	Look-up Table t'
	6/5/2006 lb/mmbtu	5/22/2006 lb/mmbtu	Eq 2 Varance S^2	Eq 2 Varance S^2	
Run 1	1.071	1.056	2.3E-05	7.25E-06	2 2.920
Run 2	1.077	1.061	1.44E-06	5.92E-05	3 2.353
Run 3	1.077	1.064	1.44E-06	0.000114	4 2.132
Run 4	1.082	1.056	3.84E-05	7.25E-06	5 2.015
Run 5	1.072	1.063	1.44E-05	9.39E-05	6 1.943
Run 6		1.059		3.24E-05	7 1.895
Run 7		1.063		9.39E-05	8 1.860
Run 8		1.068		0.000216	9 1.833
Run 9		1.07		0.000279	10 1.812
Run 10		1.059		3.24E-05	11 1.796
Run 11		1.037		0.000266	12 1.782
Run 12		1.021		0.001044	13 1.771
Run 13		1.016		0.001392	14 1.761
Run 14					15 1.753
Run 15					16 1.746
Run 16					17 1.740
Run 17					18 1.734
Run 18					19 1.729
Run 19					20 1.725
Run 20					21 1.721
Run 21					22 1.717
	Sum	5.379	13.693	7.88E-05	23 1.714
	Runs	5	13	0.003637	24 1.711
3.2 Arithmetic Mean	E	1.0758	1.053308	Eq 1	25 1.708
3.3 Variance	S^2	1.97E-05	0.000303	Eq 2	26 1.706
3.4 Pooled Estimate	Sp		0.015239	Eq 3	27 1.703
3.5 Test Statistic	t		-2.804799		28 1.701
Look-up table	na + nb -2	16			29 1.699
	t' 95% Confidence	1.746			>=30 1.645

Results

4.1 Significant Increase ( $t > t'$ )

NO

PM DETERMINATION OF EMISSION RATE CHANGE

Emission Rate Change  
40 CFR 60 Appendix C

Test Data	Baseline 6/5/2006	Blend 5/22/2006	3.3 Eq 2	3.3 Eq 2	Look-up Table t'
	lb/mmbtu	lb/mmbtu	Varance S^2	Varance S^2	
Run 1	0.003	0.004	4.44E-07	4.44E-07	2 2.920
Run 2	0.004	0.004	1.11E-07	4.44E-07	3 2.353
Run 3	0.004	0.004	1.11E-07	4.44E-07	4 2.132
Run 4		0.003		1.11E-07	5 2.015
Run 5		0.003		1.11E-07	6 1.943
Run 6		0.002		1.78E-06	7 1.895
Run 7					8 1.860
Run 8					9 1.833
Run 9					10 1.812
Run 10					11 1.796
Run 11					12 1.782
Run 12					13 1.771
Run 13					14 1.761
Run 14					15 1.753
Run 15					16 1.746
Run 16					17 1.740
Run 17					18 1.734
Run 18					19 1.729
Run 19					20 1.725
Run 20					21 1.721
Run 21					22 1.717
	Sum	0.011	0.02	6.67E-07	23 1.714
	Runs	3	6	3.33E-06	24 1.711
3.2 Arithmetic Mean	E	0.003667	0.003333	Eq 1	25 1.708
3.3 Variance	S^2	3.33E-07	6.67E-07	Eq 2	26 1.706
3.4 Pooled Estimate	Sp		0.000756	Eq 3	27 1.703
3.5 Test Statistic	t		-0.62361		28 1.701
Look-up table	na + nb -2	7			29 1.699
	t' 95% Confidence	1.895			>=30 1.645

Results

4.1 Significant Increase ( $t > t'$ ) NO

CO DETERMINATION OF EMISSION RATE CHANGE

Emission Rate Change  
40 CFR 60 Appendix C

Test Data	Baseline	Blend	3.3	3.3	Look-up Table t'
	4/19/2006	5/22/2006	Eq 2	Eq 2	
	lb/mmbtu	lb/mmbtu	Varance S^2	Varance S^2	
Run 1	0.007	0.031	2.78E-06	2.25E-06	2 2.920
Run 2	0.005	0.058	1.11E-07	0.00065	3 2.353
Run 3	0.006	0.033	4.44E-07	2.5E-07	4 2.132
Run 4	0.006	0.03	4.44E-07	6.25E-06	5 2.015
Run 5	0.006	0.024	4.44E-07	7.22E-05	6 1.943
Run 6	0.004	0.019	1.78E-06	0.000182	7 1.895
Run 7	0.004		1.78E-06		8 1.860
Run 8	0.004		1.78E-06		9 1.833
Run 9	0.006		4.44E-07		10 1.812
Run 10					11 1.796
Run 11					12 1.782
Run 12					13 1.771
Run 13					14 1.761
Run 14					15 1.753
Run 15					16 1.746
Run 16					17 1.740
Run 17					18 1.734
Run 18					19 1.729
Run 19					20 1.725
Run 20					21 1.721
Run 21					22 1.717
	Sum Runs	0.048 9	0.195 6	0.00001 0.000914	23 1.714
3.2 Arithmetic Mean	E	0.005333	0.0325	Eq 1	24 1.711
3.3 Variance	S^2	1.25E-06	0.000183	Eq 2	25 1.708
3.4 Pooled Estimate	Sp		0.008428	Eq 3	26 1.706
3.5 Test Statistic	t		6.115625		27 1.703
Look-up table	na + nb -2	13			28 1.701
	t' 95% Confidence	1.771			29 1.699
					>=30 1.645

Results

4.1 Significant Increase ( $t > t'$ ) YES