

RECEIVED

OCT 11 2004

BUREAU OF AIR REGULATION

**ACID MIST, LEAD, AND MERCURY
EMISSION MEASUREMENTS**


Kiln/Raw Mill/Clinker Cooler System

RINKER MATERIALS CORPORATION
Miami Cement Plant
Miami, Florida

Permit Nos. 0250014-008-AC (PSD-FL-324)
and
0250014-009-AV

Test Dates: August 6, 2004
Report Date: September 20, 2004

263-04-05



KOOGLER & ASSOCIATES
ENVIRONMENTAL SERVICES

4014 NW THIRTEENTH STREET
GAINESVILLE, FLORIDA 32609
352/377-5822 ■ FAX/377-7158

**ACID MIST, LEAD, AND MERCURY
EMISSION MEASUREMENTS**

Kiln/Raw Mill/Clinker Cooler System

RINKER MATERIALS CORPORATION
Miami Cement Plant
Miami, Florida

Permit Nos. 0250014-008-AC (PSD-FL-324) and
0250014-009-AV

Test Dates: August 6, 2004
Report Date: September 20, 2004

Koogler & Associates Environmental Services
4014 N.W. 13th Street
Gainesville, Florida 32609
(352) 377-5822

263-04-05



**ACID MIST, LEAD, AND MERCURY
EMISSION MEASUREMENTS**

Kiln/Raw Mill/Clinker Cooler System

RINKER MATERIALS CORPORATION
Miami Cement Plant
Miami, Florida

Permit Nos. 0250014-008-AC (PSD-FL-324) and
0250014-009-AV

Test Dates: August 6, 2004
Report Date: September 20, 2004

Responsible Official Certification:

I certify that, based upon information and belief formed after reasonable inquiry, the statements and information in the attached documents are true, accurate and complete.

Ed Allsopp, Vice President, Cement Operations


Signature

Date:

263-04-05



To the best of my knowledge, all applicable field and analytical procedures comply with the Florida Department of Environmental Protection requirements and all test data and plant operating data are true and correct.



John B. Koogler, Ph.D., P.E.

State of Florida
Registration No. 12925

09/20/04

Date



Table of Contents

| | | |
|-----|---------------------------------------|---|
| 1.0 | Introduction | 1 |
| 2.0 | Location of Sampling Ports | 3 |
| 3.0 | Field and Analytical Procedures | 5 |
| 4.0 | Summary of Results | 6 |

Appendix

1.0 INTRODUCTION

Rinker Materials Corporation (Rinker) owns and operates a preheater/precalciner Portland cement plant located at 1200 N.W. 137th Avenue, Miami, Dade County, Florida. The plant is rated at a preheater feed rate of 220 tons per hour (tph) and a clinker production rate of 138 tph. Rinker is currently operating under FDEP approval to evaluate operating at a preheater feed rate of 267 tph and a clinker production rate of 162 tph.

During the period August 6, 2004, Koogler & Associates, Inc. of Gainesville, Florida, conducted acid mist, lead and mercury emission measurements on the kiln/raw mill/clinker cooler exhaust stack in accordance with EPA Method 8 and Method 29, respectively, (40 CFR 60, Appendix A). At Rinker the kiln, raw mill and clinker cooler are all exhausted through a common baghouse and stack. The emission measurements were conducted with the raw mill operating.

The purpose of the testing was to demonstrate compliance with the acid mist, lead and mercury emission limiting standard of Permit 0250014-009-AV while operating at the increased production rate.

The emissions on the kiln/raw mill/cooler were conducted on August 6, 2004 with the raw mill operating. During the test period, the preheater feed rate averaged 245 tons per hour and the clinker production rate averaged 147 tons per hour. The acid

mist emission rate averaged 0.436 pounds per hour, or 0.0030 pounds per ton of clinker, the lead emission rate averaged 0.0026 pounds per hour, or 0.000018 pounds per tons of clinker, and the mercury emission rate averaged 0.00099 pounds per hour or 0.000007 pounds per ton of clinker. The permit limits the emission rates of acid mist, lead and mercury to 0.014, 0.000075 and 0.000024 pounds per ton of clinker, respectively.

Based on the data presented herein, it can be concluded that during the test period of August 6, 2004, the acid mist, lead, and mercury emissions from the kiln/raw mill/clinker cooler system of Rinker's Miami Cement Plant were well within the limits established by Permit 0250014-009-AV.

2.0 LOCATION OF SAMPLE PORTS


The locations of the sampling points are shown in Figure 1. Stack gas flow rate measurements and sample collection for dioxin/furan emission measurements were made through four sampling ports located 90 degrees to one another in the 136.5-inch diameter stack. The ports are located 203.5 feet (18.5 diameters) above the point where the stack gas enters the stack and 101.7 feet (9.3 diameters) below the top of the stack. A total of 12 sampling points were used for the velocity and sampling traverses. The sampling points were located in accordance with criteria established by EPA Test Method 1 (40 CFR 60, Appendix A).

FIGURE 1

SAMPLING POINT LOCATIONS

CEMENT PLANT

RINKER MATERIALS CORP
Miami, Florida



| <u>Traverse Points</u> | <u>Distance from Inside Stack Wall</u> |
|------------------------|--|
| 1 | 6.01 |
| 2 | 19.9 |
| 3 | 40.4 |

3.0 FIELD AND ANALYTICAL PROCEDURES

Acid mist emission measurements were made on the kiln/raw mill/clinker cooler stack in accordance with EPA Method 8 and the emission measurements for lead and mercury were conducted in accordance with EPA Method 29. The requirements of three methods were followed without exception. The sample time of each lead and mercury test run was two hours and the sample time of the acid mist test runs was one hour.

The sampling point locations were established in accordance with EPA Method 1, the stack gas velocity measurements and stack gas moisture measurements were made in conjunction with the EPA Method 8 and Method 29 tests in accordance with EPA Methods 2 and 4. Measurements to determine the dry molecular weight of the stack gas were made in accordance with EPA Method 3. All EPA test methods are described in 40 CFR 60, Appendix A and have been adopted by reference by FDEP by Rule 62-297.401, F.A.C.

4.0 SUMMARY OF RESULTS

During the test period on August 6, 2004, with the raw mill operating, the feed rate to the preheater averaged 245 tons per hour and the clinker production averaged 147 tons per hour. The pyroprocessing system (kiln and precalciner) was fired with coal and oil. The coal firing rate was equivalent to a heat input rate of approximately 394 mmBTU per hour and the oil contributed 2.0 mmBTU per hour for a total heat input of about 396 mmBTU per hour.

During the acid mist emission tests (see Table 1), the stack gas flow rate from the kiln/raw mill/clinker cooler averaged 220,947 dry standard cubic feet per minute at a stack gas temperature of 249°F. The moisture content of the stack gas averaged 15.6 percent. The acid mist emission rate ranged from 0.0022 to 0.0044 pounds per ton of clinker and averaged 0.0030 pounds per ton of clinker. The permit limit for acid mist is 0.014 pounds per ton of clinker.

During the lead and mercury emission tests (see Table 2), the stack gas flow rate averaged 200,559 dry standard cubic feet per minute at a stack gas temperature of 246°F. The moisture content of the stack gas averaged 16.4 percent. The lead and mercury emission rates averaged 0.000018 and 0.000007 pounds per ton of clinker, respectively. The emission limit for lead is 0.000075 pounds per ton of clinker, and the limit for mercury is 0.000024 pounds per ton of clinker.

Based on the data presented herein, it can be concluded that during the period of testing on August 6, 2004 while operating at a preheater feed rate of 245 tons per hour and a clinker production rate of 147 tons per hour, the Rinker Miami Cement Plant was operating in compliance with permitted emission limiting standards for acid mist, lead and mercury.

Table 1
Acid Mist Emission Summary
Rinker Miami Cement Plant
Facility ID - 0250014
August 6, 2004

| Run | Preheater Feed (tph) | Clinker Production (tph) | Stack Gas | | | Acid Mist | |
|---------|----------------------|--------------------------|--------------|-----------|-----------|-----------|------------------|
| | | | Flow (dscfm) | Temp (°F) | Moist (%) | (lb/hr) | (lb/ton clinker) |
| 1 | 244.4 | 146.7 | 218354 | 254 | 15.2 | 0.333 | 0.0023 |
| 2 | 245.5 | 147.4 | 228686 | 243 | 16.0 | 0.655 | 0.0044 |
| 3 | 245.3 | 147.3 | 215801 | 249 | 15.6 | 0.322 | 0.0022 |
| | | | | | | | |
| Average | 245.1 | 147.1 | 220947 | 249 | 15.6 | 0.436 | 0.0030 |

Permit Limit = 1.92 lb/hr and 0.014 lb/ton clinker

Table 2
Lead and Mercury Emission Summary
Rinker Miami Cement Plant
Facility ID - 0250014
August 6, 2004

| Run | Preheater Feed (tph) | Clinker Production (tph) | Stack Gas | | | Lead | | Mercury | |
|---------|----------------------|--------------------------|--------------|-----------|-----------|---------|------------------|---------|------------------|
| | | | Flow (dscfm) | Temp (°F) | Moist (%) | (lb/hr) | (lb/ton clinker) | (lb/hr) | (lb/ton clinker) |
| 1 | 244.4 | 146.7 | 196147 | 248 | 16.8 | 0.00137 | 0.9 E-05 | 0.00093 | 0.6 E-05 |
| 2 | 245.3 | 147.3 | 203565 | 249 | 16.2 | 0.00391 | 2.7 E-05 | 0.00109 | 0.7 E-05 |
| 3 | 245.4 | 147.3 | 201965 | 242 | 16.1 | 0.00263 | 1.8 E-05 | 0.00094 | 0.6 E-05 |
| | | | | | | | | | |
| Average | 245.0 | 147.1 | 200559 | 246 | 16.4 | 0.00264 | 1.8 E-05 | 0.00099 | 0.7 E-05 |

Lead Permit Limit = 0.01 lb/hr and 7.5 E-05 lb/ton clinker

Mercury Permit Limit = 0.0033 lb/hr and 2.4 E-05 lb/ton clinker

Appendix

Sulfuric Acid Mist

- Calculations
- Field Data Sheets
- Laboratory Data Sheets
- Equipment Calibration Data

Lead and Mercury

- Calculations
- Field Data Sheets
- Laboratory Data Sheets
- Equipment Calibration Data

Process Data

Project Participants

Sulfuric Acid Mist

Calculations

GENERAL DATA

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date : AUG. 6, 2004 Cp 0.840
 Stack dia. : 136.50 inch OR : Duct Length 0.00 inch
 Oxygen Corr.: 0.0 percent Duct Width 0.00 inch
 CO2 Corr. : 0.0 percent Std. Temp. 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U F Process Wt.

Hydrogen, wt% : 0.00 Run 1 : 0 Tons/hr
 Carbon, wt% : 0.00 Run 2 : 0
 Sulfur, wt% : 0.00 Run 3 : 0
 Nitrogen, wt% : 0.00
 Oxygen, wt% : 0.00
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

FIELD DATA METHOD 5 RUN RUN RUN
 1 2 3

Meter Temp., Tm (F) 89 83 82
 Stack Temp., Ts (F) 254 243 249
 Sq.Rt. dP 0.87 0.91 0.87
 dH (in. H2O) 1.41 1.61 1.44
 Meter Vol., Vm (ft3) 43.629 45.926 44.100
 Vol. H2O, Vlc (ml) 159.5 181.0 169.0
 Meter Y 1.000 1.000 1.000
 Bar. Press., Pb (in.Hg.) 29.78 29.78 29.78
 Static Press., Ps (in.H2O) -0.72 -0.72 -0.72
 Test Time (min.) 60.0 60.0 60.0
 Nozzle Dia., Dn (in.) 0.240 0.240 0.240
 Oxygen, O2 (%) 11.8 11.5 11.2
 Carbon Dioxide, CO2 (%) 11.0 12.2 14.5
 Carbon Monoxide, CO (%) 0.0 0.0 0.0
 Report Emission Criteria in ? 1 = lb/hr g = gr/dscf : grams
 Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min: T
 Allowable Particulate Matter Concentration 0

LABORATORY RESULTS RUN RUN RUN
 1 2 3
 grams grams grams

GRAVIMETRIC ANALYSIS METHOD 5 :
 Front Half Wash (FHW) 0.00000 0.00000 0.00000
 Filterable Sample (MF) 0.00000 0.00000 0.00000
 Condensable Sample (BHW) 0.00000 0.00000 0.00000

A. FIELD DATA SUMMARY

Plant: RINKER - MIAMI, FL.
 Source/Unit: CEMENT KILN
 Date: AUG. 6, 2004

| | RUN 1 | RUN 2 | RUN 3 |
|--|----------|----------|----------|
| Vlc = Vol water collected in train, ml | 159.5 | 181.0 | 169.0 |
| Vm = Sample gas vol, meter cond., acf | 43.629 | 45.926 | 44.100 |
| Y = Meter calibration factor | 1.0000 | 1.0000 | 1.0000 |
| Pbar = Barometric pressure, in. Hg | 29.78 | 29.78 | 29.78 |
| Pstatic = Stack static pressure, in. H2O | -0.72 | -0.72 | -0.72 |
| dH = Avg meter pressure diff, in. H2O | 1.41 | 1.61 | 1.44 |
| Tm = Absolute meter temp., degrees R | 549.3 | 542.9 | 542.4 |
| Vm(std) = Sample gas vol, Std. cond., dscf | 41.884 | 44.631 | 42.879 |
| Bws = Water vapor in gas stream, fraction | 0.152 | 0.160 | 0.156 |
| MF = Moisture factor (1 - Bws) | 0.848 | 0.840 | 0.844 |
| CO2 = Carbon Dioxide, dry, volume % | 11.00 | 12.20 | 14.50 |
| O2 = Oxygen, dry, volume % | 11.80 | 11.50 | 11.20 |
| N2 = Nitrogen, dry volume % | 77.20 | 76.30 | 74.30 |
| Md = Molecular weight of stack gas, dry | 30.23 | 30.41 | 30.77 |
| Ms = Molecular weight of stack gas, wet | 28.37 | 28.42 | 28.77 |
| Cp = Pitot tube coefficient | 0.84 | 0.84 | 0.84 |
| Sq.Rt. dP = Avg. square root of each dP | 0.8697 | 0.9140 | 0.8671 |
| Ts = Absolute stack temp., degrees R | 713.7 | 703.3 | 708.7 |
| A = Area of stack, ft ² | 101.62 | 101.62 | 101.62 |
| Qstd = Volumetric flowrate, dscfm | 218,354 | 228,686 | 215,801 |
| An = Nozzle area, ft ² | 3.14E-04 | 3.14E-04 | 3.14E-04 |
| 0 = Sample time, minutes | 60.00 | 60.00 | 60.00 |
| %I = Isokinetic variation, percent | 103.42 | 105.23 | 107.13 |

EMISSION RATE CALCULATIONS

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date: AUG. 6, 2004 RUN NO.: 1
 STANDARD TEMP. : 68 F

| | | | | | |
|-----------------------|---------|-------|---------|---------|-------|
| Front Half Wash (FHW) | 0.00000 | grams | Vm(std) | 41.884 | ft3 |
| Mass Filter (MF) | 0.00000 | grams | Vw(std) | 7.508 | ft3 |
| Back Half Wash (BHW) | 0.00000 | grams | Qs(std) | 218,354 | dscfm |
| Vm(std) SO2 | 41.884 | dscf | Bws | 0.152 | |
| CO2 CORR. 0.0 % | | | CO2 | 11.00 | % |
| O2 CORR.: 0.0 % | | | O2 | 11.80 | % |

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{std} + 460)/528]$ dscf/MMBtu
 FUEL USE

Use Rate (gal/ton) * Process Wt. (ton/hr) gal/hr
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6 MMBtu/hr

TOTAL PARTICULATE

$15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [(\text{Vm}(\text{std}) + \text{Vw}(\text{std}))]$... 0.0000 gr/scf
 $15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / (\text{Vm}(\text{std}))$ 0.0000 gr/dscf
 gr/dscf x (12 / %CO2) 0.0000 @ 0% CO2
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] 0.0000 @ 0% O2
 $0.00857 \times \text{Qs}(\text{std}) \times \text{gr/dscf}$ 0.00 lb/hr
 F-Fac x $1.4286E-4 \times [20.9 / (20.9 - \%O_2)] \times \text{gr/dscf}$.. lb/MMBtu
 Particulate (lb/hr) / Heat Input (MMBtu/hr) lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (V_t - V_{tb}) \times N \times V_{sol}] / \text{Vol}(\text{alq})$ ##### lb Acid Mist
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... 0.33 lb/hr
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor lb/MMBtu
SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (V_t - V_{tb}) \times N \times V_{sol}] / \text{Vol}(\text{alq})$ lb SO2
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr
 [SO2 (lb) / Vm std (ft^3)] x F lb/MMBtu
 [Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.8% O2 Stack) ppm @ 0% O2
 SO2 (lb/hr / Heat Input) lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl (mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack) ppm @ 0% O2

EMISSION RATE CALCULATIONS

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date: AUG. 6, 2004 RUN NO.: 2
 STANDARD TEMP. : 68 F

| | | | | | |
|-----------------------|---------|-------|---------|---------|-------|
| Front Half Wash (FHW) | 0.00000 | grams | Vm(std) | 44.631 | ft3 |
| Mass Filter (MF) | 0.00000 | grams | Vw(std) | 8.520 | ft3 |
| Back Half Wash (BHW) | 0.00000 | grams | Qs(std) | 228,686 | dscfm |
| Vm(std) SO2 | 44.631 | dscf | Bws | 0.160 | |
| CO2 CORR. 0.0 % | | | CO2 | 12.20 | % |
| O2 CORR.: 0.0 % | | | O2 | 11.50 | % |

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$ dscf/MMBtu

FUEL USE

-
 Use Rate (gal/ton) * Process Wt. (ton/hr) gal/hr
 Heat Input = (Process Weight (ton/hr) x Heating MMBtu/hr
 Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6

TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))]$... 0.0000 gr/scf
 $15.432 \times (FHW + MF + BHW) / (Vm(std))$ 0.0000 gr/dscf
 gr/dscf x (12 / %CO2) 0.0000 @ 0% CO2
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] 0.0000 @ 0% O2
 $0.00857 \times Qs(std) \times gr/dscf$ 0.00 lb/hr
 $F-Fac \times 1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times gr/dscf$.. lb/MMBtu
 Particulate (lb/hr) / Heat Input (MMBtu/hr) lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$. ##### lb Acid Mist
 $[Acid Mist (lb) / Vm std (ft^3)] \times Qs std \times 60$... 0.65 lb/hr
 $[Acid Mist (lb) / Vm std (ft^3)] \times F-Factor$ lb/MMBtu

SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$. lb SO2
 $[SO2 (lb) / Vm std (ft^3)] \times Qs std (ft^3/min) \times 60$... lb/hr
 $[SO2 (lb) / Vm std (ft^3)] \times F$ lb/MMBtu
 $[Mass SO2 (lb) \times 385 / 64E+6 (ft^3/lb)] / Vm (std)$ ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack) ppm @ 0% O2
 SO2 (lb/hr / Heat Input) lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

$[Mass HCl(mg) \times 385 \times 1E6] / [453600 \times 36.5 \times Vm(std)]$.. ppm
 ppm x 0.0 % Corr. / 12.2 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 12.2% O2 Stack) ppm @ 0% O2

EMISSION RATE CALCULATIONS

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date: AUG. 6, 2004 RUN NO.: 3
 STANDARD TEMP. : 68 F

| | | | | | |
|-----------------------|---------|-------|---------|---------|-------|
| Front Half Wash (FHW) | 0.00000 | grams | Vm(std) | 42.879 | ft3 |
| Mass Filter (MF) | 0.00000 | grams | Vw(std) | 7.955 | ft3 |
| Back Half Wash (BHW) | 0.00000 | grams | Qs(std) | 215,801 | dscfm |
| Vm(std) SO2 | 42.879 | dscf | Bws | 0.156 | |
| CO2 CORR. 0.0 % | | | CO2 | 14.50 | % |
| O2 CORR.: 0.0 % | | | O2 | 11.20 | % |

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{std} + 460)/528]$ dscf/MMBtu
 FUEL USE

Use Rate (gal/ton) * Process Wt. (ton/hr) gal/hr
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6 MMBtu/hr

TOTAL PARTICULATE

$15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [(\text{Vm}(\text{std}) + \text{Vw}(\text{std}))]$... 0.0000 gr/scf
 $15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / \text{Vm}(\text{std})$ 0.0000 gr/dscf
 gr/dscf x (12 / %CO2) 0.0000 @ 0% CO2
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] 0.0000 @ 0% O2
 $0.00857 \times \text{Qs}(\text{std}) \times \text{gr/dscf}$ 0.00 lb/hr
 F-Fac x $1.4286E-4 \times [20.9 / (20.9 - \%O_2)] \times \text{gr/dscf}$.. lb/MMBtu
 Particulate (lb/hr) / Heat Input (MMBtu/hr) lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (V_t - V_{tb}) \times N \times V_{sol}] / \text{Vol}(\text{alq})$. ##### lb Acid Mist
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... 0.32 lb/hr
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor lb/MMBtu

SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (V_t - V_{tb}) \times N \times V_{sol}] / \text{Vol}(\text{alq})$. lb SO2
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr
 [SO2 (lb) / Vm std (ft^3)] x F lb/MMBtu
 [Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack) ppm @ 0% O2
 SO2 (lb/hr / Heat Input) lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm
 ppm x 0.0 % Corr. / 14.5 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 14.5% O2 Stack) ppm @ 0% O2

SOURCE TEST CALCULATIONS

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date: AUG. 6, 2004

RUN NO.: 1

| | | | |
|----------------------|----------------|---------------------|-----------------|
| STD. TEMP, Tstd = | 68 F | STATIC PRESS., Ps = | -0.72 in. H2O |
| METER TEMP, Tm = | 89.33333 F | PITOT COFF., Cp = | 0.840 |
| STACK TEMP, Ts = | 253.7 F | STACK I.D. = | 136.50 inch |
| AVG. VEL. HEAD, dP = | 0.756 in. H2O | DUCT LENGTH = | inch |
| METER ORIFICE, dH = | 1.41 in. H2O | DUCT WIDTH = | inch |
| METER VOL., Vm = | 43.629 Cu. Ft. | STACK AREA, As = | 101.623 Sq. Ft. |
| METER COFF., Y = | 1.000 | TEST TIME = | 60.00 min. |
| BAR. PRESS., Pb = | 29.78 in. Hg | NOZZLE DIA. = | 0.240 inch |
| COND. (Vlc) = | 159.5 ml | NOZZLE DIA., An = | 3.1E-04 Sq. Ft. |
| | | | |
| GAS ANALYSIS = | 11.80 % O2 | 0.00 % CO | |
| | 11.00 % CO2 | 77.20 % N2 | |

$$Vm(std) = [(T(std) + 460) / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots \dots = 41.884 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 7.508 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots \dots \dots = 0.152 \text{ | Lower Bws value used.}$$

Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) = 1.000

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 137.52$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 30.23$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots \dots \dots = 28.37$$

$$P(stack) = Pbar + (Ps / 13.6) \dots \dots \dots = 29.73 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times P(stack))] \dots \dots \dots = 57.45 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots \dots \dots = 350,299 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (P(stack) / 29.92) \dots \dots \dots = 218,354 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (T(std) + 460) / 29.92) \times 100 / [Time \times P(stack) \times An \times vs \times 60]] \dots \dots \dots = 103.42 \%$$

SOURCE TEST CALCULATIONS

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date : AUG. 6, 2004

RUN NO.: 2

| | | | |
|----------------------|---------------|---------------------|----------------|
| STD. TEMP, Tstd = | 68 F | STATIC PRESS., Ps = | -0.72 in. H2O |
| METER TEMP, Tm = | 82.92 F | PITOT COFF., Cp = | 0.840 |
| STACK TEMP, Ts = | 243.3 F | STACK I.D. = | 136.50 inch |
| AVG. VEL. HEAD, dP = | 0.835 in. H2O | DUCT LENGTH = | inch |
| METER ORIFICE, dH = | 1.61 in. H2O | DUCT WIDTH = | inch |
| METER VOL., Vm = | 45.926 Cu.Ft. | STACK AREA, As = | 101.623 Sq.Ft. |
| METER COFF., Y = | 1.000 | TEST TIME = | 60.00 min. |
| BAR. PRESS., Pb = | 29.78 in.Hg | NOZZLE DIA. = | 0.240 inch |
| COND. (Vlc) = | 181.0 ml | NOZZLE DIA., An = | 3.1E-04 Sq.Ft. |
| | | | |
| GAS ANALYSIS = | 11.50 % O2 | 0.00 % CO | |
| | 12.20 % CO2 | 76.30 % N2 | |

$$\begin{aligned}
 Vm(std) &= [(T(std) + 460) / 29.92] \times Vm \times Y \times \\
 &\quad (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 44.631 \text{ dscf} \\
 Vw(std) &= (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 8.520 \text{ scf} \\
 Bws &= Vw(std) / (Vm(std) + Vw(std)) \dots\dots = 0.160 \text{ | Lower} \\
 &\quad \text{| Bws} \\
 Bws @ \text{ Saturated Conditions} &= \text{Vapor Press. of H2O} \text{ | value} \\
 @ \text{ Dew Point Temp. / (Ps, in.Hg.)} &\dots\dots = 1.000 \text{ | used..} \\
 \%EA &= (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 133.05 \\
 Md &= (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 30.41 \\
 Ms &= (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots = 28.42 \\
 P(stack) &= Pbar + (Ps / 13.6) \dots\dots = 29.73 \text{ in. Hg} \\
 vs &= 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) \\
 &\quad / (Ms \times P(stack))] \dots\dots = 59.88 \text{ ft/sec} \\
 Qs &= vs \times As \times 60 \dots\dots = 365,131 \text{ acf/min} \\
 Qs(std) &= Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \\
 &\quad \times (P(stack) / 29.92) \dots\dots = 228,686 \text{ dscf/min} \\
 I &= (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / \\
 &\quad (T(std) + 460) / 29.92] \times 100 / [Time \times \\
 &\quad P(stack) \times An \times vs \times 60] \dots\dots = 105.23 \%
 \end{aligned}$$

SOURCE TEST CALCULATIONS

Plant : RINKER - MIAMI, FL.
 Source/Unit : CEMENT KILN
 Date : AUG. 6, 2004

RUN NO. : 3

| | | | | |
|----------------------|---------------|--|---------------------|----------------|
| STD. TEMP, Tstd = | 68 F | | STATIC PRESS., Ps = | -0.72 in. H2O |
| METER TEMP, Tm = | 82.42 F | | PITOT COFF., Cp = | 0.840 |
| STACK TEMP, Ts = | 248.7 F | | STACK I.D. = | 136.50 inch |
| AVG. VEL. HEAD, dP = | 0.752 in. H2O | | DUCT LENGTH = | inch |
| METER ORIFICE, dH = | 1.44 in. H2O | | DUCT WIDTH = | inch |
| METER VOL., Vm = | 44.100 Cu.Ft. | | STACK AREA, As = | 101.623 Sq.Ft. |
| METER COFF., Y = | 1.000 | | TEST TIME = | 60.00 min. |
| BAR. PRESS., Pb = | 29.78 in.Hg | | NOZZLE DIA. = | 0.240 inch |
| COND. (Vlc) = | 169.0 ml | | NOZZLE DIA., An = | 3.1E-04 Sq.Ft. |
| | | | | |
| GAS ANALYSIS = | 11.20 % O2 | | 0.00 % CO | |
| | 14.50 % CO2 | | 74.30 % N2 | |

$$\begin{aligned}
 Vm(std) &= [(T(std) + 460) / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots\dots = 42.879 \text{ dscf} \\
 Vw(std) &= (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 7.955 \text{ scf} \\
 Bws &= Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.156 \text{ | Lower Bws value used.} \\
 Bws @ \text{ Saturated Conditions} &= \text{Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)} \dots\dots\dots = 1.000 \\
 \%EA &= (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 133.09 \\
 Md &= (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 30.77 \\
 Ms &= (Md \times (1-Bws)) + (18.0 \times Bws) \dots\dots\dots = 28.77 \\
 P(stack) &= Pbar + (Ps / 13.6) \dots\dots\dots = 29.73 \text{ in. Hg} \\
 vs &= 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times P(stack))] \dots\dots\dots = 56.68 \text{ ft/sec} \\
 Qs &= vs \times As \times 60 \dots\dots\dots = 345,606 \text{ acf/min} \\
 Qs(std) &= Qs \times (1-Bws) \times ((Tstd + 460) / (Ts + 460)) \times (P(stack) / 29.92) \dots\dots\dots = 215,801 \text{ dscf/min} \\
 I &= (Ts+460) \times [(0.002669 \times Vlc) + (Vm(std) / (T(std) + 460) / 29.92)] \times 100 / [Time \times P(stack) \times An \times vs \times 60] \dots\dots\dots = 107.13 \%
 \end{aligned}$$

Field Data Sheets

Multiple Methods Data Sheet

Plant: Rinker - Miami, FL
 Sample Location: Cement Kiln
 Control Type: Bag house
 Sample Type: Air dust
 Date: 8-6-04 Run No.: 1
 Time Start: 1023 Time End: 1130
 Sample Time: 5 min/point 60 Total Minutes
 Dry Bulb: °F Wet Bulb: °F VP@DP:
 Bar. Pressure: 29.78 Hg Stack Press: 29.73 Hg Ps: 0.72 H₂O
 Moisture: 12 % FDA: Gas Density Factor:
 Temperature: °F Wind Direction: W Wind Speed: 5-8
 Weather: Partly cloudy Thermocouple Readout: KA-2
 Sample Box No.: KA-2 Meter Box No.: KA-2
 Meter Y: 1000 @ Delta H: 154 Pitot Corr.: 0.84
 Nozzle Diameter: 0.240 inches Probe Length: 10.25 feet
 Probe Heater Setting: Nomograph Cf: 1.85
 Stack Dimensions: 136.5 inches Umbilical: 200'
 Stack Area: 101.62 ft² Thermocouple
 Effective Stack Area: 101.62 ft² Probe No.: KA-50
 Stack Height: ft Pitot Tube: KASSTL

Purged for
 15 min
 at 1.4 ΔH

Stack Dimensions

Material Processing Rate:
 Final Gas Meter Reading: 1040.029 ft³
 Initial Gas Meter Reading: 996.400 ft³
 Total Metered Gas Volume: 43.629 ft³
 Condensate Gain in Impingers: 140 mL
 Weight Gain in Silica Gel: 19.5 g
 Total Moisture Gain mL
 Silica Gel Container No.: 39
 Filter Number:

Leak Check - Meter Box:

Initial: 0.006 cfm @ 15 inches Hg
 Final: 0.002 cfm @ 6 inches Hg

Leak Check - Pitot Tubes

Impact 3 "H₂O for 15 sec. Stable, Leak
 Static 3 "H₂O for 15 sec. Stable, Leak
 Test Conducted By: R Paul - C Bell
 O₂ 11.8 % CO₂ 11.0 %
 Stack Test Observers:

| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temp. (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| Average | | | | | | | | | | | | |
| 1-1 | | | 96.4 | 0.86 | 1.59 | 1.59 | 288 | } | 69 | 88 | 5 | |
| 2 | | | 1000.3 | 0.86 | 1.59 | 1.59 | 269 | | 62 | 88 | 5 | |
| 3 | | | 4.0 | 0.66 | 1.22 | 1.22 | 257 | | 57 | 89 | 5 | |
| 2-1 | | | 7.5 | 0.82 | 1.52 | 1.52 | 260 | | 56 | 90 | 5 | |
| 2 | | | 14.0 | 0.64 | 1.18 | 1.18 | 249 | | 57 | 90 | 4 | |
| 3 | | | 15.0 | 0.64 | 1.18 | 1.18 | 252 | | 56 | 90 | 4 | |
| 3-1 | | | 18.3 | 0.88 | 1.63 | 1.63 | 253 | | 58 | 90 | 5 | |
| 2 | | | 22.1 | 0.85 | 1.57 | 1.57 | 249 | | 56 | 89 | 5 | |



Multiple Methods Data Sheet

Plant: Rinker-Miami, Fl.
 Sample Location: Cement Kiln
 Control Type: Baghouse
 Sample Type: Acid Mist
 Date: 8-6-04 Run No.: 2
 Time Start: 1205 Time End: 1311
 Sample Time: 5 min/point 600 Total Minutes
 Dry Bulb: °F Wet Bulb: °F VP@DP:
 Bar. Pressure: 29.78 Hg Stack Press: 29.73 Hg Ps: 0.72 H₂O
 Moisture: 14 % FDA: Gas Density Factor:
 Temperature: 85 °F Wind Direction: W Wind Speed: 10-12
 Weather: Partly cldy Thermocouple Readout: KA-2
 Sample Box No.: KA-2 Meter Box No.: KA-2
 Meter Y: 1.000 @ Delta H: 1.54 Pitot Corr.: 0.84
 Nozzle Diameter: 0.240 inches Probe Length: 10.5 feet
 Probe Heater Setting: Nomograph Cf: 1.9
 Stack Dimensions: 136.5 inches Umbilical: 200'
 Stack Area: 101.62 ft² Thermocouple
 Effective Stack Area: 101.62 ft² Probe No.: KA-5C
 Stack Height: ft Pitot Tube: KASSII

Stack Dimensions

Purged for
15 min
at 60 ΔH

Material Processing Rate:
 Final Gas Meter Reading: 97.326 ft³
 Initial Gas Meter Reading: 51.400 ft³
 Total Metered Gas Volume: 45.926 ft³
 Condensate Gain in Impingers: 154 mL
 Weight Gain in Silica Gel: 22.1 g
 Total Moisture Gain mL
 Silica Gel Container No.: 19
 Filter Number:

Leak Check - Meter Box:
 Initial: 0.004 cfm @ 15 inches Hg
 Final: 0.006 cfm @ 6 inches Hg
 Leak Check - Pitot Tubes
 Impact 3 "H₂O for 15 sec. Stable Leak
 Static 3 "H₂O for 15 sec. Stable Leak
 Test Conducted By: R Paul-C Bell
 O₂ 11.5 % CO₂ 12.2 %
 Stack Test Observers:

| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temp. (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| Average | | | | | | | | | | | | |
| 1-1 | | | 51.4 | 0.90 | 1.7 | 1.7 | 239 | | 63 | 84 | 5 | |
| 2 | | | 55.6 | 0.78 | 1.48 | 1.48 | 237 | | 42 | 84 | 4 | |
| 3 | | | 59.2 | 0.55 | 1.05 | 1.05 | 237 | | 44 | 84 | 3 | |
| 2-1 | | | 62.4 | 0.91 | 1.73 | 1.73 | 242 | | 46 | 85 | 4 | |
| 2 | | | 66.2 | 0.88 | 1.67 | 1.67 | 242 | | 48 | 85 | 4 | |
| 3 | | | 70.2 | 0.90 | 1.7 | 1.7 | 245 | | 50 | 84 | 4 | |
| 3-1 | | | 74.0 | 1.05 | 2.0 | 2.0 | 251 | | 53 | 83 | 5 | |
| 2 | | | 77.9 | 0.97 | 1.84 | 1.84 | 248 | | 57 | 83 | 5 | |



Multiple Methods Data Sheet

Plant: Reiber - Miami, FL
 Sample Location: Cement Kiln
 Control Type: Baghouse
 Sample Type: Dried Mist
 Date: 8-6-04 Run No.: 3
 Time Start: 1346 Time End: 1454
 Sample Time: 5 min/point 600 Total Minutes
 Dry Bulb: °F Wet Bulb: °F VP@DP:
 Bar. Pressure: 29.78 Hg Stack Press: 29.73 Hg Ps: 0.72 H₂O
 Moisture: 14 % FDA: Gas Density Factor:
 Temperature: 85 °F Wind Direction: W Wind Speed: 10-12
 Weather: Cloudy Thermocouple Readout: KA-2
 Sample Box No.: KA-2 Meter Box No.: KA-2
 Meter Y: 1,000 @ Delta H: 1.54 Pitot Corr.: 0.84
 Nozzle Diameter: 0.240 inches Probe Length: 10 ft
 Probe Heater Setting: Nomograph Cf: 1.9
 Stack Dimensions: 136.5 inches Umbilical: 200'
 Stack Area: 101.62 ft² Thermocouple
 Effective Stack Area: 101.62 ft² Probe No.: KA-150
 Stack Height: ft Pitot Tube: KA-SSII

Stack Dimensions

Purged for
15 min at
1,44 ΔH

Material Processing Rate:
 Final Gas Meter Reading: 153.500 ft³
 Initial Gas Meter Reading: 109.400 ft³
 Total Metered Gas Volume: 44,100 ft³
 Condensate Gain in Impingers: 140 mL
 Weight Gain in Silica Gel: 28.9 g
 Total Moisture Gain mL
 Silica Gel Container No.: 9
 Filter Number:

Leak Check - Meter Box:
 Initial: 0.006 cfm @ 15 inches Hg
 Final: 0.003 cfm @ 6 inches Hg
Leak Check - Pitot Tubes
 Impact 3 "H₂O for 15 sec: Stable Leak
 Static 3 "H₂O for 15 sec: Stable Leak
 Test Conducted By: R Paul C Bell
 O₂ 11.2 % CO₂ 14.5 %
 Stack Test Observers:

| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temp. (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| Average | | | | | | | | | | | | |
| 1 | | | 9.4 | 0.81 | 1.54 | 1.54 | 249 | | 64 | 81 | 4 | |
| 2 | | | 13.3 | 0.88 | 1.67 | 1.67 | 245 | | 46 | 81 | 4 | |
| 3 | | | 17.2 | 0.74 | 1.41 | 1.41 | 246 | | 48 | 81 | 4 | |
| 2-1 | | | 20.8 | 0.91 | 1.73 | 1.73 | 252 | | 52 | 82 | 5 | |
| 2 | | | 24.8 | 0.83 | 1.58 | 1.58 | 250 | | 55 | 82 | 4 | |
| 3 | | | 28.5 | 0.61 | 1.16 | 1.16 | 246 | | 55 | 82 | 3 | |
| 3-1 | | | 31.8 | 0.88 | 1.67 | 1.67 | 254 | | 59 | 83 | 4 | |
| 2 | | | 35.4 | 0.78 | 1.48 | 1.48 | 250 | | 56 | 83 | 4 | |



Sampling Rate Calculations

Plant Name: Rinker Date: 9-6-04
 Location: Miami Source: Cement Kiln Acid Mist

- ΔH = Orifice Reading (Inches H₂O)
- D_n = Nozzle Diameter (Inches)
- $\Delta H@$ = Meter Box Constant
- B_w = Moisture Fraction
- T_m = Meter Temperature (°F)
- T_s = Stack Temperature (°F)
- M_s = Wet Molecular Weight of Stack Gas (from Table)
- ΔP = Pitot Reading (Inches H₂O)

$$\frac{[T_m + 460]}{MS(T_s=460)} (1 - B_w)^2 \Delta H@ (D_n)^4 17741 \Delta P = \Delta H$$

| Moisture Fraction | MS |
|-------------------|------|
| 0.0 | 29.0 |
| 0.05 | 28.5 |
| 0.10 | 27.9 |
| 0.15 | 27.4 |
| 0.20 | 26.8 |
| 0.25 | 26.2 |
| 0.30 | 25.7 |
| 0.35 | 25.2 |
| 0.40 | 24.6 |

$$\frac{555}{277 (160) 21052}$$

$$\frac{545}{275 (700) 19250}$$

| | | Run No. 1 | Run No. 2 | Run No. 3 |
|---------------------------------|---|-----------|-----------|-----------|
| $\frac{T_m + 460}{MS(T_s+460)}$ | = | | | |
| | = | 0.02634 | 0.0283 | |
| $\times (1 - B_w)^2$ | = | 0.7744 | 0.7396 | |
| $\times \Delta H@$ | = | 1.54 | 1.54 | |
| $\times (D_n)^4$ | = | | 0.00332 | |
| $\times 17741$ | = | 17741 | 17741 | |
| $\times \Delta P$ | = | 1.85 | 1.9 | |

Laboratory Data Sheets



Lab Data

SO₂ or Acid Mist

Plant Name: Pinker Date Analyzed: 8-10-04

Analyzed by: R Paul

| Stack | Sample No. | V.T. (ml) | V.T.B. (ml) | N. | V. Soln (ml) | V.A. (ml) |
|--------|------------|-----------|-------------|---------|--------------|-----------|
| Cement | 1-1 | 0.3 | 0.2 | 0.00985 | 500 | 50 |
| Water | 2 | 0.3 | 0.2 | | | 5 |
| f | 2-1 | 0.4 | f | f | f | 50 |
| | 2 | 0.4 | | | | 5 |
| f | 3-1 | 0.3 | f | f | f | 50 |
| | 2 | 0.3 | | | | 5 |
| | | | | | | |
| | | | | | | |
| | | | | | | |

- V.T. = Volume of Barium Perchlorate Titrant used for Sample (ml)
- V.T.B. = Volume of Barium Perchlorate Titrant used for Blank (ml)
- N. = Normality of Barium Perchlorate
- V. Soln. = Total Solution Volume
- V.A. = Volume of Sample Aliquot Titrated (ml)




Equipment Calibration Data

Nozzle Calibration

Date: 8-6-04
Plant Name: Rinker
Location: Miami, FL
Source: Cement Kiln Acid Mist

| Measurement Number | Inside Diameter (inches) |
|--------------------|---------------------------|
| 1 | 0.241 |
| 2 | 0.239 |
| 3 | 0.240 |
| Average | 0.240 |
| Area of Nozzle | 0.000314 Ft. ² |

Calibrated by: R Paul



Nozzle X-Section

KAForms: Nozzle Calibration
jhm,04/24/01



Pitot Tube Calibration Measurements

Pitot Tube Identification Number: SS II

Date Calibrated: 7-1-03

Pitot Tube Assembly Level: Yes No

Pitot Tube Openings Damaged: Yes No If yes, please explain: _____

$D_{t_A} = \underline{0.373}$ in. ($D_{t_A} = 0.1875 - 0.3750$ in.)

$D_{t_B} = \underline{0.373}$ in. ($D_{t_B} = 0.1875 - 0.3750$ in.)

$\alpha_A = \underline{1.5^\circ}$ ($< 10^\circ$) $\alpha_B = \underline{2.0^\circ}$ ($< 10^\circ$)

$\beta_A = \underline{1.5^\circ}$ ($< 5^\circ$) $\beta_B = \underline{1.5^\circ}$ ($< 5^\circ$)

$\gamma = \underline{1.0^\circ}$, $\theta = \underline{1.0^\circ}$


$P_A = \underline{0.465}$ ($P_A = 1.05 D_t$ to $1.50 D_t$)

$P_B = \underline{0.466}$ ($P_B = 1.05 D_t$ to $1.50 D_t$)

$P_A + P_B = A = \underline{0.931}$ [$A = 2x(1.05 D_t$ to $1.50 D_t)$]

$Z = A \sin \gamma = \underline{0.016}$ in. (< 0.125 in.)

$W = A \sin \theta = \underline{0.016}$ in. (< 0.031 in.)



Comments: Pitot tubes leaked O2 during test

Calibration required? Yes No

Calibrated by: Rodney Paul

Post Test Thermocouple Calibration

Date: 8-6-04

Plant Name: Rinker

Location: Miami

Source: Cement Kiln

| | |
|---------------------------------------|-------|
| Thermocouple Readout No. | KA-2 |
| Umbilical Cord No. | 200' |
| Switch Box No. | KA-2 |
| Thermocouple No. | KA-50 |
| Average Stack Temperature °F | 249 |
| * Observed Mercury in Glass (ASTM) °F | 252 |
| Observed Thermocouple Reading °F | 252 |

* Observed temperature must be within ten percent of the average stack temperature.

Percent Difference $\frac{(ASTM + 460) - (Thermo + 460)}{(ASTM + 460)} \times 100 = \underline{0.070}$

Tolerance $\leq 1.5\%$

Signature: R Paul



KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
 ANNUAL THERMOCOUPLE CALIBRATION
 MAY 5-6, 2003

| KA70 RO/UMB | | ICE (F) | ASTM (F) | AMB. (F) | ASTM (F) | 212 (F) | ASTM (F) | 400 (F) | ASTM (F) | KA70 RO/UMB | | |
|--------------------------------|-------|------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|--------|-----|
| KA1/100' | STACK | 31 | 32 | 78 | 77 | 211 | 210 | 421 | 420 | KA1/100' | STACK | |
| | BOX | 33 | 33 | 77 | 77 | 210 | 210 | 421 | 420 | | BOX | |
| | IMP | 32 | 33 | 77 | 78 | 210 | 209 | 420 | 421 | | IMP | |
| KA2/200' | STACK | 32 | 33 | 78 | 77 | 210 | 209 | 414 | 415 | KA2/200' | STACK | |
| | BOX | 31 | 33 | 78 | 77 | 210 | 209 | 417 | 416 | | BOX | |
| | IMP | 32 | 32 | 77 | 77 | 211 | 210 | 419 | 418 | | IMP | |
| KA3/25' SWBXKA3 | STACK | 33 | 33 | 77 | 78 | 211 | 210 | 413 | 412 | KA3/25' | STACK | |
| | BOX | 32 | 33 | 78 | 78 | 212 | 211 | 410 | 411 | | BOX | |
| | IMP | 34 | 33 | 78 | 77 | 210 | 211 | 410 | 411 | | IMP | |
| KA4/25' SWBXKA3 | STACK | 33 | 32 | 77 | 78 | 212 | 213 | 412 | 413 | KA4/25' | STACK | |
| | BOX | 32 | 33 | 78 | 77 | 211 | 211 | 413 | 413 | | BOX | |
| | IMP | 32 | 33 | 77 | 78 | 212 | 212 | 413 | 414 | | IMP | |
| KAK/200K KAK-38 SWBXKAK1 | STACK | 32 | 33 | 78 | 78 | 209 | 211 | 417 | 418 | KAK/200K | STACK | |
| | BOX | 32 | 32 | 78 | 78 | 210 | 211 | 418 | 419 | | KAK-38 | BOX |
| | IMP | 31 | 32 | 78 | 78 | 212 | 212 | 420 | 419 | | IMP | |
| KA1/200' | STACK | 31 | 32 | 77 | 77 | 211 | 210 | 423 | 422 | KA1/200' | STACK | |
| | BOX | 31 | 32 | 77 | 77 | 209 | 210 | 421 | 420 | | BOX | |
| | IMP | 33 | 32 | 77 | 78 | 210 | 211 | 420 | 420 | | IMP | |
| KA2/100' | STACK | 33 | 33 | 77 | 78 | 208 | 209 | 420 | 419 | KA2/100' | STACK | |
| | BOX | 31 | 32 | 78 | 77 | 210 | 211 | 420 | 421 | | BOX | |
| | IMP | 32 | 33 | 78 | 78 | 210 | 210 | 422 | 421 | | IMP | |

Signature *John D. O'Keefe*
 Date 5/6/03

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
ANNUAL THERMOCOUPLE CALIBRATION
MAY 5-6, 2003

| THERMOCOUPLE # | ICE (F) | ASTM (F) | AMB. (F) | ASTM (F) | 212 (F) | ASTM (F) | 400 (F) | ASTM (F) | THERMOCOUPLE # |
|----------------|------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|
| KA-06 | 32 | 32 | 77 | 78 | 211 | 210 | 420 | 419 | KA-06 |
| KA-07 | 32 | 33 | 78 | 77 | 212 | 211 | 420 | 421 | KA-07 |
| KA-08 | 34 | 33 | 77 | 78 | 209 | 210 | 423 | 422 | KA-08 |
| KA-09 | 33 | 33 | 77 | 78 | 212 | 211 | 420 | 419 | KA-09 |
| KA-10 | 33 | 32 | 78 | 77 | 212 | 212 | 417 | 418 | KA-10 |
| KA-11 | 35 | 34 | 78 | 78 | 209 | 209 | 415 | 416 | KA-11 |
| KA-12 | 34 | 34 | 79 | 78 | 211 | 210 | 419 | 418 | KA-12 |
| KA-38 | 33 | 33 | 79 | 78 | 212 | 211 | 422 | 422 | KA-38 |
| KA-39 | 33 | 32 | 78 | 77 | 209 | 210 | 420 | 421 | KA-39 |
| KA-50 | 31 | 32 | 77 | 77 | 210 | 211 | 420 | 420 | KA-50 |
| KA-64 | 33 | 34 | 77 | 78 | 213 | 212 | 414 | 415 | KA-64 |
| KA-70 | 35 | 34 | 77 | 78 | 210 | 209 | 416 | 417 | KA-70 |
| KA-71 | 34 | 33 | 78 | 78 | 212 | 211 | 418 | 418 | KA-71 |
| KA-72 | 31 | 32 | 76 | 77 | 211 | 210 | 421 | 421 | KA-72 |
| KA-105 | 31 | 32 | 77 | 78 | 210 | 210 | 421 | 420 | KA-105 |
| KA-108 | 33 | 33 | 76 | 77 | 212 | 211 | 422 | 423 | KA-108 |
| KA-115 | 33 | 33 | 77 | 77 | 211 | 212 | 421 | 422 | KA-115 |
| KA-126 | 31 | 32 | 77 | 78 | 211 | 210 | 424 | 423 | KA-126 |

| THERMOCOUPLE # | ICE (F) | ASTM (F) | AMB. (F) | ASTM (F) | 212 (F) | ASTM (F) | 400 (F) | ASTM (F) | THERMOCOUPLE # |
|----------------|------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|
| KAK-08 | 32 | 32 | 77 | 77 | 210 | 210 | 420 | 419 | KAK-08 |
| KAK-09 | 32 | 31 | 78 | 78 | 212 | 211 | 418 | 418 | KAK-09 |
| KAK-10 | 31 | 32 | 76 | 77 | 211 | 210 | 420 | 421 | KAK-10 |
| KAK-11 | 33 | 33 | 78 | 77 | 211 | 212 | 424 | 423 | KAK-11 |
| KAK-12 | 32 | 33 | 77 | 78 | 211 | 210 | 423 | 422 | KAK-12 |
| KAK-38 | 34 | 33 | 78 | 77 | 210 | 209 | 420 | 420 | KAK-38 |
| KAK-65 | 33 | 32 | 76 | 77 | 209 | 208 | 417 | 418 | KAK-65 |
| KAK-72 | 32 | 31 | 77 | 77 | 211 | 211 | 415 | 416 | KAK-72 |
| KAK-110 | 34 | 33 | 79 | 78 | 211 | 210 | 421 | 422 | KAK-110 |
| KAK-07 | 32 | 32 | 78 | 77 | 212 | 211 | 421 | 421 | KAK-07 |

Signature *John A. H...*
Date 5/6/03

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
 ANNUAL THERMOCOUPLE CALIBRATION
 MAY 5-6, 2003

| Range (C) | Measured Voltage (mV) | Measured Voltage (V) | Calc. Temp. (C) | Readout Temp. (C) | Percent Difference (%) |
|--------------|-----------------------------|----------------------------|-----------------------|-------------------------|------------------------------|
| KAK-12 | 33.0 | 0.033 | 793 | 796 | -0.3453 |
| | 41.0 | 0.041 | 993 | 989 | 0.4131 |
| KAK-38 | 32.5 | 0.033 | 781 | 784 | -0.3728 |
| | 41.4 | 0.041 | 1003 | 999 | 0.4346 |
| KAK-72 | 32.8 | 0.033 | 788 | 790 | -0.2045 |
| | 41.1 | 0.041 | 996 | 993 | 0.2676 |
| KAK-65 | 32.1 | 0.032 | 771 | 769 | 0.3079 |
| | 40.9 | 0.041 | 991 | 995 | -0.4500 |
| KA-110 | 32.7 | 0.033 | 786 | 788 | -0.2605 |
| | 40.5 | 0.041 | 980 | 981 | -0.0695 |

EQUATIONS :


$$T(\text{calc.}) = (0.226584602 + (24152.109 * V) + (67233.4248 * V^2) + (2210340.682 * V^3) - (860963914.9 * V^4) + (48350600000 * V^5) - (1184520000000 * V^6) + (13869000000000 * V^7) - (63370800000000 * V^8))$$

Where :

V = Measured Voltage (Volts)

T(calc.) = Temperature calculated based on voltage

Signature



Date

5/6/03

POST-TEST DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

Koogler & Associates
Environmental Services

- 1) Select one critical orifice to calibrate the dry gas meter which represents the observed operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

COMPANY: Rinker

SOURCE: Klln

DATE: 8/10/04

PRETEST Y: 1

METER SERIAL #: KA-2

CRITICAL ORIFICE SERIAL #: 1376

BAROMETRIC PRESSURE (in Hg): INITIAL 30.60 FINAL 30.50 AVG (P_{bar}) 30.50

| RUN NO. | ORIFICE NO. | K' FACTOR (AVG) | TESTED VACUUM (in Hg) | DGM READINGS (FT ³) | | | TEMPERATURES °F | | | | | ELAPSED TIME (MIN) | DGM ΔH (in H ₂ O) | (1) V _m (STD) | (2) V _{cr} (STD) | (3) Y | (4) ΔH _@ | |
|---------|-------------|-----------------|-----------------------|---------------------------------|---------|-----------------------|-----------------|-----------|-------|------------|-------|--------------------|------------------------------|--------------------------|---------------------------|-------|---------------------|---------|
| | | | | INITIAL | FINAL | NET (V _m) | AMBIENT | DGM INLET | | DGM OUTLET | | | | | | | | DGM AVG |
| | | | | | | | | INITIAL | FINAL | INITIAL | FINAL | | | | | | | |
| 1 | 17 | 0.4505 | 18 | 165.989 | 171.874 | 5.875 | 72.5 | 72.5 | 72.5 | 74.9 | 75.1 | 74 | 10.0 | 0.95 | 8.94 | 5.96 | 1.003 | 1.506 |
| 2 | 17 | 0.4505 | 18 | 171.874 | 179.044 | 7.170 | 73 | 74 | 76 | 75.1 | 75.7 | 75 | 12.0 | 0.95 | 7.23 | 7.14 | 0.988 | 1.508 |
| 3 | 17 | 0.4505 | 18 | 179.044 | 188.003 | 8.959 | 74 | 75 | 77 | 75.8 | 77 | 76 | 15.0 | 0.95 | 9.02 | 8.92 | 0.990 | 1.511 |

AVG = 0.994

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) V_m(std) = K_1 V_m Y \left[\frac{P_{bar} + (\Delta H / 136)}{T_m} \right]$$

$$(2) V_{cr}(std) = K' \left[\frac{P_{bar} \theta}{\sqrt{T_{amb}}} \right]$$

$$(3) Y = \frac{V_{cr}(std)}{V_m(std)}$$

$$(4) \Delta H_{@} = \left(\frac{0.75 * \theta}{V_{cr}(std)} \right)^2 * \Delta H$$

V_m(std) = Net volume of gas sample passed through DGM, corrected to standard conditions.

K₁ = 17.64 °R/in. Hg

Y = DGM calibration factor

V_{cr}(std) = Volume of gas sample passed through the critical orifice, corrected to standard conditions.

P_{bar} = Barometric pressure at the sampling site (in. Hg).

ΔH = Orifice pressure differential (in. H₂O).

θ = Total sampling time (min.)

T_m = Absolute DGM avg. temperature °R

T_{amb} = Absolute ambient temperature °R

K' = Average K' factor from Critical Orifice Calibration

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.994

AVERAGE DELTA Y = -0.006

DELTA Y LIMIT = 0.05

IS TEST WITHIN 5%? YES

**FIELD DATA SHEET: POST-TEST DRY GAS METER CALIBRATION
USING CRITICAL ORIFICES**

**Koogler & Associates
Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which approximates the test average delta H range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below.

COMPANY: Baker, Miami
 SOURCE: Kiln
 TEST DATE: August 10, 2004
 METER Y: 1800
 AVG. DELTA H: 1.54

METER SERIAL #: KA-2
 CRITICAL ORIFICE SERIAL #: 1376
 INITIAL FINAL
 BAROMETRIC PRESSURE (in Hg): 30.50 30.50

| RUN | ORIFICE NO. | K' FACTOR (AVG) | TESTED VACUUM (in Hg) | DGM READINGS (FT ³) | | TEMPERATURES °F | | | | ELAPSED TIME (MIN) | DGM ΔH (in H ₂ O) | |
|-----|-------------|-----------------|-----------------------|---------------------------------|---------|-----------------|-----------|-------|------------|--------------------|------------------------------|---------------------|
| | | | | INITIAL | FINAL | AMBIENT | DGM INLET | | DGM OUTLET | | | |
| | | | | | | | INITIAL | FINAL | INITIAL | | | FINAL |
| 1 | 17 | .4505 | 18" | 165.999 | 171.874 | 72.5 | 72.5 | 72.5 | 74.9 | 75.1 | 10.0 | 1.54 .95 |
| 2 | 17 | .4505 | 18" | 171.874 | 179.044 | 73 | 74 | 76 | 75.1 | 75.7 | 12.0 | .95 |
| 3 | 17 | .4505 | 18" | 179.044 | 188.003 | 74 | 75 | 77 | 75.8 | 77.0 | 15.00 | .95 |

Test Conducted by: Cory J Bell
 Signature: Cory J Bell
 Date: 08/10/04

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

| DATE: 6/2204 | | METER SERIAL #: KA-2 | | BAROMETRIC PRESSURE (in Hg): | | INITIAL | FINAL | AVG (P _{bar}) | IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED | | | | | | | | |
|--------------------|-------|-------------------------------------|-----------------------|---------------------------------|---------|-----------------------|-----------------|-------------------------|---|--------------------|----------------------|------------------------------|--------------------------|---------------------------|--------|-----------------|-----------------|
| METER PART #: KA-2 | | CRITICAL ORIFICE SET SERIAL #: 1376 | | | | 29.95 | 29.95 | 29.95 | | | | | | | | | |
| ORIFICE # | RUN # | K' FACTOR [AVG] | TESTED VACUUM (in Hg) | DGM READINGS (FT ³) | | | TEMPERATURES °F | | | | ELAPSED TIME (MIN) Ø | DGM ΔH (in H ₂ O) | (1) V _m (STD) | (2) V _{cr} (STD) | (3) Y | Y VARIATION (%) | ΔH _Ø |
| | | | | INITIAL | FINAL | NET (V _m) | AMBIENT | DGM INLET INITIAL | DGM INLET FINAL | DGM OUTLET INITIAL | | | | | | | |
| 17 | 1 | 0.4505 | 18 | 689.311 | 695.673 | 6.362 | 78 | 78 | 78 | 78 | 78 | 10.70 | 0.94 | 6.2655 | 6.2260 | 0.994 | 1.54 |
| | 2 | 0.4505 | 18 | 695.673 | 702.817 | 7.144 | 78 | 78 | 78 | 78 | 78 | 12.00 | 0.94 | 7.0357 | 6.9824 | 0.992 | 1.54 |
| | 3 | 0.4505 | 18 | 702.817 | 710.457 | 7.640 | 78 | 77 | 78 | 77 | 78 | 12.90 | 0.94 | 7.5312 | 7.5061 | 0.997 | 1.54 |
| AVG = | | | | | | | | | | | | | | | | 0.994 | -0.62 |
| 22 | 1 | 0.5836 | 18 | 628.759 | 636.326 | 7.567 | 76 | 76 | 77 | 77 | 77 | 10.00 | 1.6 | 7.4817 | 7.5519 | 1.009 | 1.56 |
| | 2 | 0.5836 | 18 | 636.326 | 644.024 | 7.698 | 78 | 75 | 75 | 78 | 78 | 10.00 | 1.6 | 7.6148 | 7.5378 | 0.990 | 1.57 |
| | 3 | 0.5836 | 18 | 653.457 | 661.064 | 7.607 | 78 | 76 | 78 | 76 | 76 | 10.00 | 1.6 | 7.5248 | 7.5378 | 1.002 | 1.57 |
| AVG = | | | | | | | | | | | | | | | | 1.000 | -0.01 |
| 26 | 1 | 0.7142 | 16 | 661.064 | 670.70 | 9.636 | 78 | 78 | 77 | 78 | 77 | 10.40 | 2.3 | 9.5304 | 9.5937 | 1.007 | 1.50 |
| | 2 | 0.7142 | 16 | 670.70 | 680.075 | 9.375 | 78 | 77 | 77 | 77 | 77 | 10.10 | 2.3 | 9.2809 | 9.3169 | 1.004 | 1.51 |
| | 3 | 0.7142 | 16 | 680.075 | 689.311 | 9.236 | 78 | 77 | 78 | 77 | 78 | 10.00 | 2.4 | 9.1370 | 9.2247 | 1.010 | 1.57 |
| AVG = | | | | | | | | | | | | | | | | 1.007 | 0.63 |

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **1.000**

AVERAGE ΔH_Ø = **1.54**

(1)
$$Vm_{(std)} = K_1 * Vm * \frac{Pbar + (\Delta H / 13.6)}{Tm}$$
 = Net volume of gas sample passed through DGM, corrected to standard conditions
 K₁ = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)
 T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

(2)
$$Vcr_{(std)} = K' * \frac{Pbar * \Theta}{\sqrt{Tamb}}$$
 = Volume of gas sample passed through the critical orifice, corrected to standard conditions
 T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)
 K' = Average K' factor from Critical Orifice Calibration

(3)
$$Y = \frac{Vcr_{(std)}}{Vm_{(std)}}$$
 = DGM calibration factor

$$\Delta H_{\Theta} = \left(\frac{0.75 \Theta}{V_{cr}(std)} \right)^2 \Delta H \left(\frac{V_m(std)}{V_m} \right)$$

Lead and Mercury

Calculations

GENERAL DATA

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date : August 6, 2004 Cp 0.840
 Stack dia. : 136.50 inch OR : Duct Length 0.00 inch
 Oxygen Corr.: 0.0 percent Duct Width 0.00 inch
 CO2 Corr. : 0.0 percent Std. Temp. 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U F Process Wt.
 Hydrogen, wt% : 0.00 Run 1 : 0 Tons/hr
 Carbon, wt% : 0.00 Run 2 : 0
 Sulfur, wt% : 0.00 Run 3 : 0
 Nitrogen, wt% : 0.00
 Oxygen, wt% : 0.00
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

| <u>FIELD DATA</u> | METHOD 5 | RUN 1 | RUN 2 | RUN 3 |
|--|----------|----------|----------|----------|
| Meter Temp., Tm (F) | | 96 | 90 | 93 |
| Stack Temp., Ts (F) | | 248 | 249 | 242 |
| Sq.Rt. dP | | 0.79 | 0.82 | 0.81 |
| dH (in. H2O) | | 1.16 | 1.23 | 1.13 |
| Meter Vol., Vm (ft3) | | 77.109 | 80.599 | 75.553 |
| Vol. H2O, Vlc (ml) | | 310.6 | 312.9 | 290.5 |
| Meter Y | | 0.988 | 0.988 | 0.988 |
| Bar. Press., Pb (in.Hg.) | | 29.78 | 29.78 | 29.78 |
| Static Press., Ps (in.H2O) | | -0.72 | -0.72 | -0.72 |
| Test Time (min.) | | 120.0 | 120.0 | 120.0 |
| Nozzle Dia., Dn (in.) | | 0.233 | 0.233 | 0.233 |
| Oxygen, O2 (%) | | 11.8 | 11.2 | 12.0 |
| Carbon Dioxide, CO2 (%) | | 11.0 | 14.5 | 12.0 |
| Carbon Monoxide, CO (%) | | 0.0 | 0.0 | 0.0 |
| Report Emission Criteria in ? l = lb/hr g = gr/dscf : | | | | grams |
| Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min: | | | | T |
| Allowable Particulate Matter Concentration | | | | 0 |

LABORATORY RESULTS

| | RUN 1 | RUN 2 | RUN 3 |
|---------------------------------|----------|----------|----------|
| | grams | grams | grams |
| GRAVIMETRIC ANALYSIS METHOD 5 : | | | |
| Front Half Wash (FW) | 0.00000 | 0.00000 | 0.00000 |
| Filterable Sample (MF) | 0.00000 | 0.00000 | 0.00000 |
| Condensable Sample (BHW) | 0.00000 | 0.00000 | 0.00000 |

SOURCE TEST CALCULATIONS

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date: August 6, 2004

RUN NO.: 1

| | | | | |
|----------------------|---------------|--|---------------------|----------------|
| STD. TEMP, Tstd = | 68 F | | STATIC PRESS., Ps = | -0.72 in. H2O |
| METER TEMP, Tm = | 96.04167 F | | PITOT COFF., Cp = | 0.840 |
| STACK TEMP, Ts = | 248.2 F | | STACK I.D. = | 136.50 inch |
| AVG. VEL. HEAD, dP = | 0.625 in. H2O | | DUCT LENGTH = | inch |
| METER ORIFICE, dH = | 1.16 in. H2O | | DUCT WIDTH = | inch |
| METER VOL., Vm = | 77.109 Cu.Ft. | | STACK AREA, As = | 101.623 Sq.Ft. |
| METER COFF., Y = | 0.988 | | TEST TIME = | 120.00 min. |
| BAR. PRESS., Pb = | 29.78 in.Hg | | NOZZLE DIA. = | 0.233 inch |
| COND. (Vlc) = | 310.6 ml | | NOZZLE DIA., An = | 3.0E-04 Sq.Ft. |
| | | | | |
| GAS ANALYSIS = | 11.80 % O2 | | 0.00 % CO | |
| | 11.00 % CO2 | | 77.20 % N2 | |

$$Vm(std) = [(T(std) + 460) / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots = 72.210 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 14.620 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots = 0.168 \text{ } \left\{ \begin{array}{l} \text{Lower} \\ \text{Bws} \\ \text{value} \\ \text{used.} \end{array} \right.$$

Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) $\dots = 1.000$

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 137.52$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 30.23$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots = 28.17$$

$$P(stack) = Pbar + (Ps / 13.6) \dots = 29.73 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times P(stack))] \dots = 52.22 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots = 318,414 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (P(stack) / 29.92) \dots = 196,147 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (T(std) + 460) / 29.92) \times 100 / [Time \times P(stack) \times An \times vs \times 60]] \dots = 105.30 \%$$

SOURCE TEST CALCULATIONS

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date : August 6, 2004

RUN NO. : 2

| | | | |
|----------------------|---------------|---------------------|----------------|
| STD. TEMP, Tstd = | 68 F | STATIC PRESS., Ps = | -0.72 in. H2O |
| METER TEMP, Tm = | 89.71 F | PITOT COFF., Cp = | 0.840 |
| STACK TEMP, Ts = | 249.2 F | STACK I.D. = | 136.50 inch |
| AVG. VEL. HEAD, dP = | 0.676 in. H2O | DUCT LENGTH = | inch |
| METER ORIFICE, dH = | 1.23 in. H2O | DUCT WIDTH = | inch |
| METER VOL., Vm = | 80.599 Cu.Ft. | STACK AREA, As = | 101.623 Sq.Ft. |
| METER COFF., Y = | 0.988 | TEST TIME = | 120.00 min. |
| BAR. PRESS., Pb = | 29.78 in.Hg | NOZZLE DIA. = | 0.233 inch |
| COND. (Vlc) = | 312.9 ml | NOZZLE DIA., An = | 3.0E-04 Sq.Ft. |
| | | | |
| GAS ANALYSIS = | 11.20 % O2 | 0.00 % CO | |
| | 14.50 % CO2 | 74.30 % N2 | |

$$V_m(\text{std}) = \left[\frac{(T(\text{std}) + 460)}{29.92} \right] \times V_m \times Y \times \frac{1}{(P_b + (dH / 13.6)) / (T_m + 460)} \dots \dots = 76.360 \text{ dscf}$$

$$V_w(\text{std}) = (8.9148 \times 10^{-5}) \times (T_{\text{std}} + 460) \times V_{lc} = 14.728 \text{ scf}$$

$$B_{ws} = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std})) \dots \dots = 0.162 \text{ | Lower Bws value used.}$$

$$B_{ws} \text{ @ Saturated Conditions} = \text{Vapor Press. of H}_2\text{O @ Dew Point Temp.} / (P_s, \text{ in.Hg.}) \dots \dots = 1.000$$

$$\%EA = (\%O_2 - 0.5\%CO) / (0.264\%N_2 - (\%O_2 - 0.5\%CO)) \times 100 = 133.09$$

$$M_d = (.44 \times \%CO_2) + (.32 \times \%O_2) + [.28 \times (\%N_2 + \%CO)] = 30.77$$

$$M_s = (M_d \times (1 - B_{ws})) + (18.0 \times B_{ws}) \dots \dots = 28.70$$

$$P(\text{stack}) = P_{\text{bar}} + (P_s / 13.6) \dots \dots = 29.73 \text{ in. Hg}$$

$$v_s = 85.49 \times C_P \times (\text{Sq.Rt. } dP) \times [\text{Sq.Rt. } (T_s + 460) / (M_s \times P(\text{stack}))] \dots \dots = 53.84 \text{ ft/sec}$$

$$Q_s = v_s \times A_s \times 60 \dots \dots = 328,265 \text{ acf/min}$$

$$Q_s(\text{std}) = Q_s \times (1 - B_{ws}) \times ((T_{\text{std}} + 460) / (T_s + 460)) \times (P(\text{stack}) / 29.92) \dots \dots = 203,565 \text{ dscf/min}$$

$$I = (T_s + 460) \times [(0.002669 \times V_{lc}) + (V_m(\text{std}) / (T(\text{std}) + 460) / 29.92)] \times 100 / [\text{Time} \times P(\text{stack}) \times A_n \times v_s \times 60] \dots \dots = 107.30 \%$$

SOURCE TEST CALCULATIONS

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date : August 6, 2004

RUN NO.: 3

| | | | |
|----------------------|----------------|---------------------|-----------------|
| STD. TEMP., Tstd = | 68 F | STATIC PRESS., Ps = | -0.72 in. H2O |
| METER TEMP., Tm = | 92.50 F | PITOT COFF., Cp = | 0.840 |
| STACK TEMP., Ts = | 242.4 F | STACK I.D. = | 136.50 inch |
| AVG. VEL. HEAD, dP = | 0.651 in. H2O | DUCT LENGTH = | inch |
| METER ORIFICE, dH = | 1.13 in. H2O | DUCT WIDTH = | inch |
| METER VOL., Vm = | 75.553 Cu. Ft. | STACK AREA, As = | 101.623 Sq. Ft. |
| METER COFF., Y = | 0.988 | TEST TIME = | 120.00 min. |
| BAR. PRESS., Pb = | 29.78 in. Hg | NOZZLE DIA. = | 0.233 inch |
| COND. (Vlc) = | 290.5 ml | NOZZLE DIA., An = | 3.0E-04 Sq. Ft. |
| | | | |
| GAS ANALYSIS = | 12.00 % O2 | 0.00 % CO | |
| | 12.00 % CO2 | 76.00 % N2 | |

$$Vm(std) = [(T(std) + 460) / 29.92] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots = 71.200 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 13.674 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots = 0.161 \text{ Lower Bws value used.}$$

$$Bws @ \text{ Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.)} = 1.000$$

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 148.81$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 30.40$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots = 28.40$$

$$P(stack) = Pbar + (Ps / 13.6) \dots = 29.73 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times P(stack))] \dots = 52.87 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots = 322,340 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (P(stack) / 29.92) \dots = 201,965 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (T(std) + 460) / 29.92) \times 100 / [Time \times P(stack) \times An \times vs \times 60]] \dots = 100.84 \%$$

A. FIELD DATA SUMMARY

Plant: Rinker Materials
 Source/Unit: Cement Kiln
 Date: August 6, 2004

| | RUN 1 | RUN 2 | RUN 3 |
|--|----------|----------|----------|
| Vlc = Vol water collected in train, ml | 310.6 | 312.9 | 290.5 |
| Vm = Sample gas vol, meter cond., acf | 77.109 | 80.599 | 75.553 |
| Y = Meter calibration factor | 0.9880 | 0.9880 | 0.9880 |
| Pbar = Barometric pressure, in. Hg | 29.78 | 29.78 | 29.78 |
| Pstatic = Stack static pressure, in. H2O | -0.72 | -0.72 | -0.72 |
| dH = Avg meter pressure diff, in. H2O | 1.16 | 1.23 | 1.13 |
| Tm = Absolute meter temp., degrees R | 556.0 | 549.7 | 552.5 |
| Vm(std) = Sample gas vol, Std. cond., dscf | 72.210 | 76.360 | 71.200 |
| Bws = Water vapor in gas stream, fraction | 0.168 | 0.162 | 0.161 |
| MF = Moisture factor (1 - Bws) | 0.832 | 0.838 | 0.839 |
| CO2 = Carbon Dioxide, dry, volume % | 11.00 | 14.50 | 12.00 |
| O2 = Oxygen, dry, volume % | 11.80 | 11.20 | 12.00 |
| N2 = Nitrogen, dry volume % | 77.20 | 74.30 | 76.00 |
| Md = Molecular weight of stack gas, dry | 30.23 | 30.77 | 30.40 |
| Ms = Molecular weight of stack gas, wet | 28.17 | 28.70 | 28.40 |
| Cp = Pitot tube coefficient | 0.84 | 0.84 | 0.84 |
| Sq.Rt. dP = Avg. square root of each dP | 0.7908 | 0.8223 | 0.8071 |
| Ts = Absolute stack temp., degrees R | 708.2 | 709.2 | 702.4 |
| A = Area of stack, ft2 | 101.62 | 101.62 | 101.62 |
| Qstd = Volumetric flowrate, dscfm | 196,147 | 203,565 | 201,965 |
| An = Nozzle area, ft2 | 2.96E-04 | 2.96E-04 | 2.96E-04 |
| 0 = Sample time, minutes | 120.00 | 120.00 | 120.00 |
| %I = Isokinetic variation, percent | 105.30 | 107.30 | 100.84 |

B. PARTICULATE DATA SUMMARY

Plant: Rinker Materials
 Source/Unit: Cement Kiln
 Date: August 6, 2004

| | RUN 1 | RUN 2 | RUN 3 |
|---|----------|----------|----------|
| Sample Weight (FHW + MF + BHW), mg | 0.00 | 0.00 | 0.00 |
| Meter Volume, standard cond., Vm(std) | 72.210 | 76.360 | 71.200 |
| Carbon Dioxide, percent | 11.00 | 14.50 | 12.00 |
| Oxygen, percent | 11.80 | 11.20 | 12.00 |
| Sample Concentration : | | | |
| gr/scf | 0.0000 | 0.0000 | 0.0000 |
| gr/dscf | 0.0000 | 0.0000 | 0.0000 |
| gr/dscf @ 0 % CO2 | 0.0000 | 0.0000 | 0.0000 |
| gr/dscf @ 0 % O2 | 0.0000 | 0.0000 | 0.0000 |
| ppm * MW (dry gas) | 0.0 | 0.0 | 0.0 |
| ppm * MW @ 0% CO2 | 0.0 | 0.0 | 0.0 |
| ppm * MW @ 0% O2 | 0.0 | 0.0 | 0.0 |

EMISSION RATE CALCULATIONS

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date: August 6, 2004 RUN NO.: 1
 STANDARD TEMP. : 68 F

| | | | | | |
|-----------------------|---------|-------|---------|---------|-------|
| Front Half Wash (FHW) | 0.00000 | grams | Vm(std) | 72.210 | ft3 |
| Mass Filter (MF) | 0.00000 | grams | Vw(std) | 14.620 | ft3 |
| Back Half Wash (BHW) | 0.00000 | grams | Qs(std) | 196,147 | dscfm |
| Vm(std) SO2 | | dscf | Bws | 0.168 | |
| CO2 CORR. 0.0 % | | | CO2 | 11.00 | % |
| O2 CORR.: 0.0 % | | | O2 | 11.80 | % |

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$ dscf/MMBtu
 FUEL USE

Use Rate (gal/ton) * Process Wt. (ton/hr) gal/hr
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6 MMBtu/hr

TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))]$... 0.0000 gr/scf
 $15.432 \times (FHW + MF + BHW) / (Vm(std))$ 0.0000 gr/dscf
 gr/dscf x (12 / %CO2) 0.0000 @ 0% CO2
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] 0.0000 @ 0% O2
 $0.00857 \times Qs(std) \times gr/dscf$ 0.00 lb/hr
 F-Fac x $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times gr/dscf$.. lb/MMBtu
 Particulate (lb/hr) / Heat Input (MMBtu/hr) lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(a\log)$. lb Acid Mist
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor lb/MMBtu
SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(a\log)$ lb SO2
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr
 [SO2 (lb) / Vm std (ft^3)] x F lb/MMBtu
 [Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.8% O2 Stack) ppm @ 0% O2
 SO2 (lb/hr / Heat Input) lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack) ppm @ 0% O2

EMISSION RATE CALCULATIONS

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date: August 6, 2004 RUN NO.: 2
 STANDARD TEMP. : 68 F

| | | | | | |
|-----------------------|---------|-------|---------|---------|-------|
| Front Half Wash (FHW) | 0.00000 | grams | Vm(std) | 76.360 | ft3 |
| Mass Filter (MF) | 0.00000 | grams | Vw(std) | 14.728 | ft3 |
| Back Half Wash (BHW) | 0.00000 | grams | Qs(std) | 203,565 | dscfm |
| Vm(std) SO2 | | dscf | Bws | 0.162 | |
| CO2 CORR. 0.0 % | | | CO2 | 14.50 | % |
| O2 CORR.: 0.0 % | | | O2 | 11.20 | % |

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)] / (\text{Btu/lb}) \times [(T_{\text{std}} + 460)/528]$ dscf/MMBtu

FUEL USE

-
 Use Rate (gal/ton) * Process Wt. (ton/hr) gal/hr
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6) MMBtu/hr

TOTAL PARTICULATE

$15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / [(\text{Vm}(\text{std}) + \text{Vw}(\text{std}))]$... 0.0000 gr/scf
 $15.432 \times (\text{FHW} + \text{MF} + \text{BHW}) / (\text{Vm}(\text{std}))$ 0.0000 gr/dscf
 gr/dscf x (12 / %CO2) 0.0000 @ 0% CO2
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] 0.0000 @ 0% O2
 $0.00857 \times \text{Qs}(\text{std}) \times \text{gr/dscf}$ 0.00 lb/hr
 $\text{F-Fac} \times 1.4286E-4 \times [20.9 / (20.9 - \%O_2)] \times \text{gr/dscf}$.. lb/MMBtu
 Particulate (lb/hr) / Heat Input (MMBtu/hr) lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (V_t - V_{tb}) \times N \times V_{\text{sol}}] / \text{Vol}(\text{aloq})$. lb Acid Mist
 $[\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std} \times 60$... lb/hr
 $[\text{Acid Mist (lb)} / \text{Vm std (ft}^3)] \times \text{F-Factor}$ lb/MMBtu

SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (V_t - V_{tb}) \times N \times V_{\text{sol}}] / \text{Vol}(\text{aloq})$. lb SO2
 $[\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{Qs std (ft}^3/\text{min}) \times 60$... lb/hr
 $[\text{SO2 (lb)} / \text{Vm std (ft}^3)] \times \text{F}$ lb/MMBtu
 $[\text{Mass SO2 (lb)} \times 385 / 64E+6 (\text{ft}^3/\text{lb})] / \text{Vm (std)}$ ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack) ppm @ 0% O2
 SO2 (lb/hr / Heat Input) lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

$[\text{Mass HCl (mg)} \times 385 \times 1E6] / [453600 \times 36.5 \times \text{Vm}(\text{std})]$.. ppm
 ppm x 0.0 % Corr. / 14.5 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 14.5% O2 Stack) ppm @ 0% O2

EMISSION RATE CALCULATIONS

Plant : Rinker Materials
 Source/Unit : Cement Kiln
 Date: August 6, 2004 RUN NO.: 3
 STANDARD TEMP. : 68 F

| | | | | | |
|-----------------------|---------|-------|---------|---------|-------|
| Front Half Wash (FHW) | 0.00000 | grams | Vm(std) | 71.200 | ft3 |
| Mass Filter (MF) | 0.00000 | grams | Vw(std) | 13.674 | ft3 |
| Back Half Wash (BHW) | 0.00000 | grams | Qs(std) | 201,965 | dscfm |
| Vm(std) SO2 | | dscf | Bws | 0.161 | |
| CO2 CORR. 0.0 % | | | CO2 | 12.00 | % |
| O2 CORR.: 0.0 % | | | O2 | 12.00 | % |

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$ dscf/MMBtu
 FUEL USE

Use Rate (gal/ton) * Process Wt. (ton/hr) gal/hr
 Heat Input = (Process Weight (ton/hr) x Heating MMBtu/hr
 Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6

TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std)]$... 0.0000 gr/scf
 $15.432 \times (FHW + MF + BHW) / (Vm(std)$ 0.0000 gr/dscf
 gr/dscf x (12 / %CO2) 0.0000 @ 0% CO2
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] 0.0000 @ 0% O2
 $0.00857 \times Qs(std) \times gr/dscf$ 0.00 lb/hr
 $F-Fac \times 1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times gr/dscf$.. lb/MMBtu
 Particulate (lb/hr) / Heat Input (MMBtu/hr) lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(alog)$. lb Acid Mist
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor lb/MMBtu

SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(alog)$. lb SO2
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr
 [SO2 (lb) / Vm std (ft^3)] x F lb/MMBtu
 [Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm
 ppm x 0.0 % Corr. / 11.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 11.0% O2 Stack) ppm @ 0% O2
 SO2 (lb/hr / Heat Input) lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY


[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm
 ppm x 0.0 % Corr. / 12.0 % CO2 in Stack ppm @ 0% CO2
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 12.0% O2 Stack) ppm @ 0% O2

Field Data Sheets



Multiple Methods Data Sheet

Plant: Rinker, Materials, Miami
 Sample Location: Cement Kila
 Control Type: Baghouse
 Sample Type: Method 29
 Date: 8/6/04 Run No.: 1
 Time Start: 10:20 Time End: 12:30
 Sample Time: 10 min/point 120 Total Minutes
 Dry Bulb: °F Wet Bulb: °F VP@DP:
 Bar. Pressure: 29.78 "Hg Stack Press: "Hg Ps: .72 "H₂O
 Moisture: 12 % FDA: Gas Density Factor:
 Temperature: °F Wind Direction: Wind Speed: 10-15 mph
 Weather: Clear Thermocouple Readout: KA-6
 Sample Box No.: KA-6 Meter Box No.: KA-6
 Meter Y: 2.988 @ Delta H: 1.61 Pitot Corr.: .84
 Nozzle Diameter: .233 inches Probe Length: 4 feet
 Probe Heater Setting: 250 Nomograph Cf: 1.85
 Stack Dimensions: 136.5 inches Umbilical: KA-100
 Stack Area: 101.62 ft² Thermocouple
 Effective Stack Area: 101.62 ft² Probe No.: KAK 55
 Stack Height: ~300' ft Pitot Tube:



Stack Dimensions

Material Processing Rate:
 Final Gas Meter Reading: 251.309 ft³
 Initial Gas Meter Reading: 174.200 ft³
 Total Metered Gas Volume: 77.109 ft³
 Condensate Gain in Impingers: 298 mL
 Weight Gain in Silica Gel: 12.6 g
 Total Moisture Gain 311 mL
 Silica Gel Container No.: 3
 Filter Number:

Leak Check - Meter Box:
 Initial: .013 cfm @ 12 inches Hg
 Final: 0.0 cfm @ 4 inches Hg

Leak Check - Pitot Tubes
 Impact 3 "H₂O for 15 sec: Stable, Leak
 Static 3 "H₂O for 15 sec: Stable, Leak
 Test Conducted By: Stowers, A. West, G. Haven
 O₂ 11.8 % CO₂ 11 %
 Stack Test Observers:


| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temp. (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| Average: | | | | | | | | | | | | |
| 1-1A | | 0 | 174.2 | .76 | 1.41 | 1.41 | 297 | 260 | 68 | 92 | 3 | |
| 1B | | 5 | 177.7 | .7 | 1.3 | 1.3 | 291 | 256 | 63 | 93 | 3 | |
| 2A | | 10 | 181.1 | +.054 | 1.2 | 1.3 | 280 | 242 | 62 | 95 | 3 | |
| 2B | | 15 | 184.1 | .7 | 1.3 | 1.3 | 266 | 260 | 63 | 96 | 3 | |
| 3A | | 20 | 187.5 | .51 | .94 | .94 | 259 | 244 | 64 | 97 | 3 | |
| 3B | | 25 | 190.3 | .51 | .94 | .94 | 247 | 259 | 65 | 98 | 3 | |
| 2-1A | | 30 | 193.7 | .72 | 1.33 | 1.33 | 246 | 233 | 66 | 98 | 3 | |
| 1B | | 35 | 196.8 | .72 | 1.33 | 1.33 | 254 | 246 | 61 | 99 | 3 | |

| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temperature (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-------------------------------|--------------------------------|------------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| 2-2 A | | 40 | 200.2 | .64 | 1.18 | 1.18 | 250 | 254 | 60 | 99 | 3 | |
| 2 B | | 45 | 203.6 | .66 | 1.22 | 1.22 | 249 | 244 | 61 | 99 | 3 | |
| 3 A | | 50 | 206.8 | .51 | .94 | .94 | 246 | 252 | 62 | 99 | 3 | |
| 3 B | | 55 | 209.8 | .51 | .94 | .94 | 238 | 255 | 63 | 99 | 3 | |
| 3-1 A | | 60 | 212.7 | .74 | 1.37 | 1.37 | 243 | 252 | 68 | 96 | 3 | |
| 1 B | | 65 | 216.1 | .75 | 1.39 | 1.39 | 241 | 246 | 63 | 97 | 3 | |
| 2 A | | 70 | 219.7 | .67 | 1.24 | 1.24 | 238 | 247 | 64 | 96 | 3 | |
| 2 B | | 75 | 223.0 | .65 | 1.2 | 1.2 | 234 | 244 | 65 | 95 | 3 | |
| 3 A | | 80 | 24.3 | .51 | .94 | .94 | 232 | 257 | 62 | 95 | 3 | |
| 3 B | | 85 | 29.2 | .51 | .94 | .94 | 224 | 252 | 63 | 94 | 3 | |
| 4 1 A | | 90 | 32.1 | .37 | 1.3 | 1.3 | 232 | 232 ²³⁵ | 66 | 93 | 3 | |
| 2 B | | 95 | 35.4 | .72 | 1.33 | 1.33 | 240 | 235 | 65 | 94 | 3 | |
| 2 A | | 100 | 38.8 | .65 | 1.2 | 1.2 | 241 | 255 | 67 | 95 | 3 | |
| 2 B | | 105 | 42.1 | .65 | 1.2 | 1.2 | 240 | 254 | 66 | 95 | 3 | |
| 3 A | | 110 | 45.4 | .53 | .98 | .98 | 235 | 247 | 65 | 96 | 3 | |
| 3 B | | 115 | 48.3 | .53 | .98 | .98 | 232 | 252 | 66 | 95 | 3 | |
| | | 120-END | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Multiple Methods Data Sheet

Rinker Materials Miami

Sample Location: Cement Kiln
 Control Type: Baghouse
 Sample Type: Method 29 (Multi-Metals) Lead + Hg
 Date: 8/6/04 Run/No.: 2
 Time Start: 12:45 Time End: 14:50
 Sample Time: 10 min/point 120 Total Minutes
 Dry Bulb: °F Wet Bulb: °F VP@DP:
 Bar. Pressure: 29.78 "Hg Stack Press: "Hg Ps: -0.72 "H₂O
 Moisture: 14 % FDA: Gas Density Factor:
 Temperature: °F Wind Direction: Wind Speed: 25-30
 Weather: Overcast/Cloudy Thermocouple Readout: KA-6
 Sample Box No.: KA-6 Meter Box No.: KA-6
 Meter Y: .988 @ Delta H: 1.61 Pitot Corr.: .84
 Nozzle Diameter: .233 inches Probe Length: 4 feet
 Probe Heater Setting: 250 Nomograph Cf: 1.81
 Stack Dimensions: 136.5 inches Umbilical: KA-100
 Stack Area: 101.62 ft² Thermocouple
 Effective Stack Area: 101.62 ft² Probe No.: KAK-55
 Stack Height: ~300 ft Pitot Tube:



Stack Dimensions

Material Processing Rate:
 Final Gas Meter Reading: 332.199 ft³
 Initial Gas Meter Reading: 251.600 ft³
 Total Metered Gas Volume: 80.599 ft³
 Condensate Gain in Impingers: 295 mL
 Weight Gain in Silica Gel: 1817.9 g
 Total Moisture Gain 313 mL
 Silica Gel Container No.: 4
 Filter Number:

Leak Check - Meter Box:
 Initial: 0.0 cfm @ 10 inches Hg
 Final: 0.009 cfm @ 5 inches Hg

Leak Check - Pitot Tubes
 Impact 3 "H₂O for 15 sec: Stable, Leak
 Static 3 "H₂O for 15 sec: Stable, Leak
 Test Conducted By: E. Thomas, G. Hamer, A. West ^{C.S. Bell}
 O₂ 11.2 % CO₂ 14.5 %
 Stack Test Observers:


| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temp. (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| Average | | | | | | | | | | | | |
| 1 1A | | 0 | 251.6 | .82 | 1.48 | 1.48 | 250 | 240 | 67 | 91 | 4 | |
| 1 B | | 5 | 55.1 | .8 | 1.45 | 1.45 | 252 | 237 | 66 | 91 | 4 | |
| 2 A | | 10 | 59.1 | .73 | 1.32 | 1.32 | 253 | 240 | 66 | 90 | 4 | |
| 2 B | | 15 | 43.1 | .72 | 1.3 | 1.3 | 251 | 232 | 65 | 89 | 4 | |
| 3 A | | 20 | 67.1 | .54 | .98 | .98 | 242 | 246 | 66 | 89 | 3 | |
| 3 B | | 25 | 69.9 | .56 | 1.01 | 1.01 | 242 | 245 | 64 | 88 | 3 | |
| 2 1A | | 30 | 73.0 | .76 | 1.38 | 1.38 | 252 | 241 | 64 | 89 | 3 | |
| 1 B | | 35 | 76.0 | .76 | 1.38 | 1.38 | 252 | 237 | 64 | 89 | 3 | |



| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temperature (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| 2-2A | | 90 | 79.6 | .7 | 1.27 | 1.27 | 251 | 240 | 65 | 90 | 3 | |
| 2B | | 45 | 83.0 | .68 | 1.23 | 1.23 | 249 | 249/241 | 65 | 89 | 3 | |
| 3A | | 50 | 86.2 | .57 | 1.03 | 1.03 | 246 | 241 | 66 | 89 | 3 | |
| 3B | | 55 | 89.3 | .52 | .94 | .94 | 238 | 251 | 63 | 90 | 3 | |
| 3-1A | | 60 | 92.2 | .74 | 1.34 | 1.34 | 250 | 257 | 64 | 88 | 3 | |
| 1B | | 65 | 95.7 | .76 | 1.38 | 1.38 | 251 | 244 | 61 | 89 | 3 | |
| 2A | | 70 | 99.1 | .72 | 1.3 | 1.3 | 251 | 235 | 60 | 90 | 3 | |
| 2B | | 75 | 302.5 | .7 | 1.27 | 1.27 | 249 | 230 | 61 | 89 | 3 | |
| 3A | | 80 | 5.9 | .58 | 1.05 | 1.05 | 246 | 255 | 61 | 90 | 3 | |
| 3B | | 85 | 9.2 | .59 | 1.07 | 1.07 | 245 | 247 | 61 | 90 | 3 | |
| 4-1A | | 90 | 12.2 | .73 | 1.32 | 1.32 | 255 | 236 | 60 | 89 | 3 | |
| 1B | | 95 | 15.5 | .76 | 1.38 | 1.38 | 254 | 229 | 62 | 90 | 4 | |
| 2A | | 100 | 19.0 | .7 | 1.27 | 1.27 | 254 | 246 | 64 | 90 | 4 | |
| 2B | | 105 | 22.5 | .7 | 1.27 | 1.27 | 251 | 257 | 59 | 91 | 4 | |
| 3A | | 110 | 25.9 | .6 | 1.08 | 1.08 | 252 | 239 | 59 | 91 | 4 | |
| 3B | | 115 | 29.2 | .56 | 1.01 | 1.01 | 245 | 254 | 60 | 92 | 3 | |
| | | 120 end | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Multiple Methods Data Sheet

Plant: Rinker Materials, Miami
 Sample Location: Cement Kiln
 Control Type: Baghouse
 Sample Type: Method 29 (Multi-Metals) Pb + Hg
 Date: 8/6/04 Run No.: 3
 Time Start: 15:09 Time End: 17:15
 Sample Time: 10 min/point 120 Total Minutes
 Dry Bulb: _____ °F Wet Bulb: _____ °F VP@DP: _____
 Bar. Pressure: 29.78 "Hg Stack Press: _____ "Hg Ps: -0.72 "H₂O
 Moisture: _____ % FDA: _____ Gas Density Factor: _____
 Temperature: _____ °F Wind Direction: W Wind Speed: 20-25
 Weather: overcast Thermocouple Readout: KA-6
 Sample Box No.: KA-6 Meter Box No.: KA-6
 Meter Y: 988 @ Delta H: 1.61 Pitot Corr.: .84
 Nozzle Diameter: .233 inches Probe Length: 4 feet
 Probe Heater Setting: 250 Nomograph Cf: 1.72
 Stack Dimensions: 136.5 inches Umbilical: KA-100
 Stack Area: 101.62 ft² Thermocouple: KAK5
 Effective Stack Area: 101.62 ft² Probe No.: KAK 55
 Stack Height: ~ 200 ft Pitot Tube: _____



Stack Dimensions

Material Processing Rate: _____
 Final Gas Meter Reading: 408.411 ft³
 Initial Gas Meter Reading: ~~332.604~~ 332.858 ft³
 Total Metered Gas Volume: 75.752 ft³
 Condensate Gain in Impingers: ~~245~~ 272 mL
 Weight Gain in Silica Gel: ~~18~~ 18.5 g
 Total Moisture Gain ~~295~~ 291 mL
 Silica Gel Container No.: 27
 Filter Number: _____

Leak Check - Meter Box:

Initial: .010 cfm @ 10 inches Hg
 Final: .009 cfm @ 6 inches Hg

Leak Check - Pitot Tubes

Impact 3 "H₂O for 15 sec: Stable, Leak
 Static 3 "H₂O for 15 sec: Stable, Leak
 Test Conducted By: E. Thomas, G. Haven, A. West
 O₂ 12 % CO₂ 12 %
 Stack Test Observers: _____

| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temp. (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| Average | | | | | | | | | | | | |
| 1-1A | | 0 | 332.8 | .73 | 1.26 | 1.26 | 254 | 232 | 66 | 89 | 5 | |
| 1B | | 5 | 36.1 | .73 | 1.26 | 1.26 | 253 | 230 | 62 | 89 | 3 | |
| 2A | | 10 | 39.3 | .68 | 1.17 | 1.17 | 249 | 231 | 62 | 90 | 3 | |
| 2B | | 15 | 42.5 | .68 | 1.17 | 1.17 | 247 | 249 | 62 | 90 | 3 | |
| 3A | | 20 | 45.7 | .58 | 1.0 | 1.0 | 244 | 244 | 62 | 91 | 3 | |
| 3B | | 25 | 48.7 | .54 | .93 | .93 | 238 | 252 | 63 | 91 | 3 | |
| 2-1A | | 30 | 51.6 | .75 | 1.29 | 1.29 | 249 | 247 | 63 | 91 | 3 | |
| 1B | | 35 | 55.0 | .74 | 1.28 | 1.28 | 248 | 258 | 63 | 91 | 3 | |



| Port and Traverse Point No. | Distance from Inside Stack Wall (in.) | Clock Time | Gas Meter Reading (ft ³) | Stack Velocity Head (H ₂ O) | Meter Orifice Pressure Difference (H ₂ O) | | Stack Gas Temperature (°F) | Sample Box Temperature (°F) | Last Impinger Temperature (°F) | Meter Temperature (°F) | Vacuum on Sample Train ("Hg) | Oxygen Meter Reading (% O ₂) |
|-----------------------------|---------------------------------------|------------|--------------------------------------|--|--|--------|----------------------------|-----------------------------|--------------------------------|------------------------|------------------------------|--|
| | | | | | Calculated | Actual | | | | | | |
| 2-2A | | 40 | 58.4 | .65 | 1.12 | 1.12 | 245 | 256 | 65 | 93 | 3 | |
| 2B | | 45 | 61.4 | .67 | 1.15 | 1.15 | 244 | 252 | 67 | 93 | 3 | |
| 3A | | 50 | 64.8 | .54 | .93 | .93 | 236 | 247 | 65 | 93 | 3 | |
| 3B | | 55 | 67.8 | .55 | .95 | .95 | 236 | 245 | 69 | 93 | 3 | |
| 3-1A | | 60 | 70.7 | .72 | 1.24 | 1.24 | 248 | 261 | 68 68 | 94 | 3 | |
| 1B | | 65 | 73.7 | .75 | 1.29 | 1.29 | 249 | 254 | 65 | 93 | 3 | |
| 2A | | 70 | 77.6 | .68 | 1.17 | 1.17 | 249 | 262 | 68 68 | 94 | 3 | |
| 2B | | 75 | 80.8 | .7 | 1.2 | 1.2 | 243 | 260 | 68 | 94 | 3 | |
| 3A | | 80 | 84.0 | .55 | .95 | .95 | 238 | 247 | 68 | 94 | 3 | |
| 3B | | 85 | 86.9 | .55 | .95 | .95 | 232 | 245 | 67 | 94 | 3 | |
| 4-1A | | 90 | 89.9 | .72 | 1.24 | 1.24 | 234 | 253 | 63 | 94 | 3 | |
| 1B | | 95 | 93.2 | .75 | 1.29 | 1.29 | 242 | 241 | 63 | 94 | 3 | |
| 2A | | 100 | 96.4 | .7 | 1.2 | 1.2 | 241 | 254 | 63 | 93 | 3 | |
| 2B | | 105 | 99.7 | .7 | 1.2 | 1.2 | 238 | 247 | 62 | 94 | 3 | |
| 2A | | 110 | 402.8 | .52 | .89 | .89 | 234 | 246 | 64 | 94 | 3 | |
| 2B | | 115 | 5.4 | .52 | .89 | .89 | 226 | 254 | 63 | 94 | 3 | |
| | | 120 end | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

SAMPLING RATE CALCULATIONS

Date: 8/6/04

Plant Name/Location: Rinker, Miami

Source: Cement Kiln

1) Calculate the optimum Cf: $\Delta H@ * \Delta P_{avg} = Cf$

| DH | DP _{avg} | Cf |
|----|-------------------|----|
| | * | = |

2) Calculate the optimum nozzle size:

| Record Values | |
|---------------------------|------|
| <u>90</u> <u>97(99)</u> | 90 |
| <u>.12</u> <u>.14</u> | .15 |
| <u>27.7</u> <u>27.5</u> | 27.4 |
| <u>250</u> <u>240</u> | 250 |
| <u>1.61</u> | 1.61 |
| <u>.233</u> | .233 |

- Tm = Meter Temperature (°F) (Add 5 °F for initial temp.)
- Bw = Moisture Fraction
- Ms = Wet Molecular Weight of Stack Gas (from Table)
- Ts = Stack Temperature (°F)
- ΔH@ = Meter Box Constant (box front)
- ΔP = Average Pitot Reading (Inches H2O)
- Dn = Nozzle Diameter (Inches) measured

| Moisture Fraction | MS |
|-------------------|------|
| 0 | 29 |
| 0.05 | 28.5 |
| 0.1 | 27.9 |
| .12 | 27.7 |
| 0.15 | 27.4 |
| 0.2 | 26.8 |
| 0.25 | 26.2 |
| 0.3 | 25.7 |
| 0.35 | 25.2 |
| 0.4 | 24.6 |

$$Dn = \left[\frac{Cf}{\left(\frac{Tm+460}{MsTs+460} \right) * \left(1 - \frac{Bw}{100} \right)^2 * (\Delta H@) * (1774)} \right]^{0.25}$$

549
 19454
 .7225
 1.61
 .00295
 17741

3) Calculate the correction factor Cf. Cf times the stack ΔP will determine the manometer setting ΔH:

$$Cf = \left[\frac{Tm+460}{Ms*(Ts+460)} \right] * (1-Bw)^2 * \Delta H@ * Dn^4 * 1774$$

$Cf * \Delta P = \Delta H$

| Calculation | Run No. 1 | Run No. 2 | Run No. 3 |
|---------------------------|-----------|-----------|-----------|
| Tm + 460 = | 557 | 559 | 550 |
| 1/[MS*(Ts+460)] = | 19667 | 19250 | 19454 |
| * (1 - Bw) ² = | .7744 | .7396 | .7225 |
| * ΔH@ = | 1.61 | 1.61 | 1.61 |
| * (Dn) ⁴ = | .00295 | .00295 | .00295 |
| * 17741 = Cf | 17741 | 17741 | 17741 |

1.85
~~1.81~~

1.81

1.72



Cont. #

Rinker
Pb + Hg
M29
Run 1
8/6/04

1 - Filter

3 - Rinse (ml)
150 ml 0.1N HNO₃

4 Gain Rinse (ml)
~~295~~ 100 0.1N HNO₃
295


5A Gain Rinse (ml)
1 100 0.1N HNO₃

5B Gain Rinse (ml)
21 100 KMnO₄ + 100 H₂O

5C Rinse ml
200 DI + 25 8N HCL

5G3 # 13(g)

Total
moisture
gain



Cont.

A

Rinker

M 29

Run 2

8/6/04

1 Filter

3 150 rinse

4 ^{bain}
204
192
104

rinses

100 0.1N HNO₃

5A 3

100 0.1N HNO₃

5B -7

100 K₂NO₄ + 100 H₂O

5C —

200 DI + 25 ml 8N HCL

SG# 18

4

Coord. #

1 Filter

3 150 ml 0.1N HNO₃ Rinse

Gain

192

172

115

Rinse

5A 100 ml 0.1N HNO₃ Rinse

5B Gain
~~75~~

5C 25ml 8N HCl 200 ml H₂O

5b 18g

Rinker

M29

Run 3

8/6/04

Laboratory Data Sheets





**PPB ENVIRONMENTAL
LABORATORIES, INC.**

6821 SW Archer Road, Gainesville, FL 32608 Ph: (352) 377-2349 Fax: (352) 395-6639 E-mail: ppb@ppb-envlabs.com NELAP Certified—FDH # E82001

September 16, 2004

Mr. Neal Lofgren
Koogler and Associates
4014 NW 13 St
Gainesville, FL 32609

Dear Mr. Lofgren::

Enclosed are the hard copy analytical results for the Rinker samples received August 11, 2004.

If you have any questions concerning this report, please contact me.

Sincerely,

Paul Berman
Project Manager

Enclosures

| | | | |
|--|----------------------|----------------|-------------|
| Post-It™ brand fax transmittal memo 7671 | | # of pages > 5 | |
| To | John Koogler | From | Paul Berman |
| Co. | Koogler & Associates | Co. | PPB |
| Dept. | | Phone # | |
| Fax # | 377-7158 | Fax # | |

REPORT OF ANALYSES
(SN-00003499)

Mr. Neal Lofgren
Koogler and Associates
4014 NW 13 St
Gainesville, FL 32609

Project No.: 87-011
Date: September 16, 2004
FDH No.: E82001

Table 1. Run 1 Lead and Mercury results for Rinker Samples Received August 11, 2004.

| Client ID | Lab ID | Sample Volume, mL | Mercury, Total μg | Lead, Total μg |
|------------------------|--------|-------------------|------------------------------|---------------------------|
| Filter & Probe Rinse | 257396 | 110 | 0.03 | <4.0 |
| Impingers 1 - 3 | 257398 | 580 | 1.34 | 1.8 |
| 0.1 N HNO ₃ | 257399 | 100 | 0.03 | NA |
| Potassium Permanganate | 257400 | 400 | 0.22 | NA |
| 8N HCl | 257401 | 230 | 1.33 | NA |

REPORT OF ANALYSES
(SN-00003499)

Mr. Neal Lofgren
Koogler and Associates
4014 NW 13 St
Gainesville, FL 32609

Project No.: 87-011
Date: September 16, 2004
FDH No.: E82001

Table 2. Run 2 Lead and Mercury results for Rinker Samples Received August 11, 2004.

| Client ID | Lab ID | Sample Volume, mL | Mercury, Total μg | Lead, Total μg |
|------------------------|--------|-------------------|------------------------------|---------------------------|
| Filter & Probe Rinse | 257402 | 120 | 0.01 | <4.0 |
| Impingers 1 - 3 | 257404 | 590 | 1.85 | 9.1 |
| 0.1 N HNO ₃ | 257405 | 96 | 0.01 | NA |
| Potassium Permanganate | 257406 | 380 | 0.37 | NA |
| 8N HCl | 257407 | 220 | 1.35 | NA |

REPORT OF ANALYSES
(SN-00003499)

Mr. Neal Lofgren
Koogler and Associates
4014 NW 13 St
Gainesville, FL 32609

Project No.: 87-011
Date: September 16, 2004
FDH No.: E82001

Table3. Run 3 Lead and Mercury results for Rinker Samples Received August 11, 2004.

| Client ID | Lab ID | Sample Volume, mL | Mercury, Total µg | Lead, Total µg |
|------------------------|--------|-------------------|-------------------|----------------|
| Filter & Probe Rinse | 257408 | 150 | 0.03 | <6.0 |
| Impingers 1 - 3 | 257410 | 510 | 1.20 | 4.0 |
| 0.1 N HNO ₃ | 257411 | 100 | 0.01 | NA |
| Potassium Permanganate | 257412 | 370 | 0.55 | NA |
| 8N HCl | 257413 | 230 | 1.19 | NA |

REPORT OF ANALYSES
(SN-00003499)

Mr. Neal Lofgren
Koogler and Associates
4014 NW 13 St
Gainesville, FL 32609

Project No.: 87-011
Date: September 16, 2004
FDH No.: E82001

Table 4. Blanks Lead and Mercury results for Rinker Samples Received August 11, 2004.

| Client ID | Lab ID | Sample Volume, mL | Mercury, Total μg | Lead, Total μg |
|--|--------|-------------------|------------------------------|---------------------------|
| 0.1 N HNO ₃ Blank | 257414 | 300 | <0.01 | 0.5 |
| 5% HNO ₃ /10% H ₂ O ₂ | 257416 | 200 | 0.04 | NA |
| KMnO ₄ Blank | 257417 | 100 | 0.02 | NA |
| 8 N HCl Blank | 257418 | 225 | 0.22 | NA |
| Filter Blank | 257419 | 250 | <0.01 | <10.0 |

Chain of Custody

Plant Name: RINKER

Project Number: 263-04-05

Location: MIAMI, FL

Source: KILN

| Sample Identification | Remarks |
|--------------------------|--|
| Run 1 Cont. 1 | Filter |
| Run 1 Cont. 2 | NO PM N/A |
| Run 1 Cont. 3 | PROBE RINSE |
| Run 1 Cont. 4 | IMPINGERS 1-3 |
| Run 1 Cont. 5A | 0.1 N HNO ₃ |
| Run 1 Cont. 5B | KMnO ₄ / H ₂ SO ₄ |
| Run 1 Cont. 5C | 8 N HCl |
| | Analysis → LEAD and MERCURY |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

Sampled by: Glen Haven 8/6/04

Relinquished by: Glen Haven 8/9/04 Time

Received by: Neil Folger 8/11/04 Time

Relinquished by: Neil Folger 8/11/04 Time

Laboratory: Kal Benson 8/11/04 Time

Received by: Kal Benson 8/11/04 Time

Sample Shipped Via: UPS Federal Express Other

Shipping Bill Number: _____



Chain of Custody

Plant Name: RINKER

Project Number: 263-04-05

Location: MIAMI, FL

Source: KILN

| Sample Identification | Remarks |
|--------------------------|--|
| Run 2 Cont. 1 | Filter |
| Run 2 Cont. 2 | NO PM N/A |
| Run 2 Cont. 3 | PROBE RINSE |
| Run 2 Cont. 4 | IMPINGER 1-3 |
| Run 2 Cont. 5A | 0.1 N HNO ₃ |
| Run 2 Cont. 5B | KMnO ₄ / H ₂ SO ₄ |
| Run 2 Cont. 5C | 8 N HCl |
| | Analysis → LEAD and |
| | MERCURY |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

Sampled by: Glen Haven 8/6/04

Relinquished by: Glen Haven 8/9/04 Time

Received by: Neil Polgren 8/11/04 Time

Relinquished by: Neil Polgren 8/11/04 Time

Laboratory: Paul Beaman 8/11/04 Time

Received by: Paul Beaman 8/11/04 Time 1015

Sample Shipped Via: UPS Federal Express Other

Shipping Bill Number: _____



Chain of Custody

Plant Name: RINKER

Project Number: 263-04-05

Location: MIAMI, FL

Source: KILN

| Sample Identification | Remarks |
|--------------------------|---|
| Run 3 Cont. 1 | Filter |
| Run 3 Cont. 2 | No PM N/A |
| Run 3 Cont. 3 | PROBE RINSE |
| RUN 3 Cont. 4 | FRADINGER 1-3 |
| RUN 3 Cont. 5A | 0.1 N HNO ₃ |
| RUN 3 Cont. 5B | KIMN O ₄ /H ₂ SO ₄ |
| RUN 3 Cont. 5C | 8 N HCl |
| | |
| | ANALYSIS → LEAD and |
| | Mercury |
| | |
| | |
| | |
| | |
| | |
| | |

Sampled by: Glen Haven 8/6/04

Relinquished by: Glen Haven 8/9/04

Received by: Neil Polgren 8/11/04

Relinquished by: Neil Polgren 8/11/04

Laboratory: Paul Benson 8/11/04 1015

Sample Shipped Via: UPS Federal Express Other

Shipping Bill Number: _____



Equipment Calibration Data

Nozzle Calibration

Date: 8/6/04


Plant Name: Rinker, Miami

Location: Miami, FL

Source: Cement Kiln

| Measurement Number | Inside Diameter (inches) |
|--------------------|--------------------------|
| 1 | .233 |
| 2 | .253 |
| 3 | .253 |
| Average | .253 |
| Area of Nozzle | _____ Ft. ² |

Calibrated by: _____



Nozzle X-Section

Pitot Tube Calibration Measurements

Pitot Tube Identification Number: SS I

Date Calibrated: 7-1-03

Pitot Tube Assembly Level: Yes No

Pitot Tube Openings Damaged: Yes No ; If yes, please explain: _____

$Dt_A = \underline{0.372}$ in. ($Dt_A = 0.1875 - 0.3750$ in.)

$Dt_B = \underline{0.373}$ in. ($Dt_B = 0.1875 - 0.3750$ in.)

$\alpha_A = \underline{1.5^\circ}$ ($< 10^\circ$) $\alpha_B = \underline{1.0^\circ}$ ($< 10^\circ$)

$\beta_A = \underline{1.5^\circ}$ ($< 5^\circ$) $\beta_B = \underline{2.0^\circ}$ ($< 5^\circ$)

$\gamma = \underline{0.5^\circ}$; $\theta = \underline{0.5^\circ}$;


$P_A = \underline{0.464}$ ($P_A = 1.05 Dt$ to $1.50 Dt$)

$P_B = \underline{0.467}$ ($P_B = 1.05 Dt$ to $1.50 Dt$)

$P_A + P_B = A = \underline{0.931}$ [$A = 2x(1.05 Dt$ to $1.50 Dt)$]

$Z = A \sin \gamma = \underline{0.01}$ in. (< 0.125 in.)

$W = A \sin \theta = \underline{0.01}$ in. (< 0.031 in.)



Comments: Pitot tubes tested OK during test

Calibration required? Yes No

Calibrated by: Rodney Paul

Post Test Thermocouple Calibration

Date: 8-6-04
 Plant Name: Reinbu
 Location: miami
 Source: Cement Kiln

| | |
|---------------------------------------|---------|
| Thermocouple Readout No. | KAK-6 |
| Umbilical Cord No. | KAK-100 |
| Switch Box No. | KAK-6 |
| Thermocouple No. | KAK-55 |
| Average Stack Temperature °F | 246 |
| * Observed Mercury in Glass (ASTM) °F | 248 |
| Observed Thermocouple Reading °F | 248 |

* Observed temperature must be within ten percent of the average stack temperature.

Percent Difference $\frac{(ASTM + 460) - (Thermo + 460)}{(ASTM + 460)} \times 100 = \underline{0.07\%}$

Tolerance $\leq 1.5\%$

Signature: R Paul



KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
 ANNUAL THERMOCOUPLE CALIBRATION
 MAY 5-6, 2003

| KA70 RO/UMB | | ICE (F) | ASTM (F) | AMB. (F) | ASTM (F) | 212 (F) | ASTM (F) | 400 (F) | ASTM (F) | KA70 RO/UMB | | |
|--------------------------------|-------|------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|--------|-----|
| KA1/100' | STACK | 31 | 32 | 78 | 77 | 211 | 210 | 421 | 420 | KA1/100' | STACK | |
| | BOX | 33 | 33 | 77 | 77 | 210 | 210 | 421 | 420 | | BOX | |
| | IMP | 32 | 33 | 77 | 78 | 210 | 209 | 420 | 421 | | IMP | |
| KA2/200' | STACK | 32 | 33 | 78 | 77 | 210 | 209 | 414 | 415 | KA2/200' | STACK | |
| | BOX | 31 | 33 | 78 | 77 | 210 | 209 | 417 | 416 | | BOX | |
| | IMP | 32 | 32 | 77 | 77 | 211 | 210 | 419 | 418 | | IMP | |
| KA3/25' SWBXKA3 | STACK | 33 | 33 | 77 | 78 | 211 | 210 | 413 | 412 | KA3/25' | STACK | |
| | BOX | 32 | 33 | 78 | 78 | 212 | 211 | 410 | 411 | | BOX | |
| | IMP | 34 | 33 | 78 | 77 | 210 | 211 | 410 | 411 | | IMP | |
| KA4/25' SWBXKA3 | STACK | 33 | 32 | 77 | 78 | 212 | 213 | 412 | 413 | KA4/25' | STACK | |
| | BOX | 32 | 33 | 78 | 77 | 211 | 211 | 413 | 413 | | BOX | |
| | IMP | 32 | 33 | 77 | 78 | 212 | 212 | 413 | 414 | | IMP | |
| KAK/200K KAK-38 SWBXKAK1 | STACK | 32 | 33 | 78 | 78 | 209 | 211 | 417 | 418 | KAK/200K | STACK | |
| | BOX | 32 | 32 | 78 | 78 | 210 | 211 | 418 | 419 | | KAK-38 | BOX |
| | IMP | 31 | 32 | 78 | 78 | 212 | 212 | 420 | 419 | | IMP | |
| KA1/200' | STACK | 31 | 32 | 77 | 77 | 211 | 210 | 423 | 422 | KA1/200' | STACK | |
| | BOX | 31 | 32 | 77 | 77 | 209 | 210 | 421 | 420 | | BOX | |
| | IMP | 33 | 32 | 77 | 78 | 210 | 211 | 420 | 420 | | IMP | |
| KA2/100' | STACK | 33 | 33 | 77 | 78 | 208 | 209 | 420 | 419 | KA2/100' | STACK | |
| | BOX | 31 | 32 | 78 | 77 | 210 | 211 | 420 | 421 | | BOX | |
| | IMP | 32 | 33 | 78 | 78 | 210 | 210 | 422 | 421 | | IMP | |

Signature *[Handwritten Signature]*
 Date 5/6/03

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
ANNUAL THERMOCOUPLE CALIBRATION

MAY 5-6, 2003

| THERMOCOUPLE # | ICE (F) | ASTM (F) | AMB. (F) | ASTM (F) | 212 (F) | ASTM (F) | 400 (F) | ASTM (F) | THERMOCOUPLE # |
|----------------|------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|
| KA-06 | 32 | 32 | 77 | 78 | 211 | 210 | 420 | 419 | KA-06 |
| KA-07 | 32 | 33 | 78 | 77 | 212 | 211 | 420 | 421 | KA-07 |
| KA-08 | 34 | 33 | 77 | 78 | 209 | 210 | 423 | 422 | KA-08 |
| KA-09 | 33 | 33 | 77 | 78 | 212 | 211 | 420 | 419 | KA-09 |
| KA-10 | 33 | 32 | 78 | 77 | 212 | 212 | 417 | 418 | KA-10 |
| KA-11 | 35 | 34 | 78 | 78 | 209 | 209 | 415 | 416 | KA-11 |
| KA-12 | 34 | 34 | 79 | 78 | 211 | 210 | 419 | 418 | KA-12 |
| KA-38 | 33 | 33 | 79 | 78 | 212 | 211 | 422 | 422 | KA-38 |
| KA-39 | 33 | 32 | 78 | 77 | 209 | 210 | 420 | 421 | KA-39 |
| KA-50 | 31 | 32 | 77 | 77 | 210 | 211 | 420 | 420 | KA-50 |
| KA-64 | 33 | 34 | 77 | 78 | 213 | 212 | 414 | 415 | KA-64 |
| KA-70 | 35 | 34 | 77 | 78 | 210 | 209 | 416 | 417 | KA-70 |
| KA-71 | 34 | 33 | 78 | 78 | 212 | 211 | 418 | 418 | KA-71 |
| KA-72 | 31 | 32 | 76 | 77 | 211 | 210 | 421 | 421 | KA-72 |
| KA-105 | 31 | 32 | 77 | 78 | 210 | 210 | 421 | 420 | KA-105 |
| KA-108 | 33 | 33 | 76 | 77 | 212 | 211 | 422 | 423 | KA-108 |
| KA-115 | 33 | 33 | 77 | 77 | 211 | 212 | 421 | 422 | KA-115 |
| KA-126 | 31 | 32 | 77 | 78 | 211 | 210 | 424 | 423 | KA-126 |

| THERMOCOUPLE # | ICE (F) | ASTM (F) | AMB. (F) | ASTM (F) | 212 (F) | ASTM (F) | 400 (F) | ASTM (F) | THERMOCOUPLE # |
|----------------|------------|-------------|-------------|-------------|------------|-------------|------------|-------------|----------------|
| KAK-08 | 32 | 32 | 77 | 77 | 210 | 210 | 420 | 419 | KAK-08 |
| KAK-09 | 32 | 31 | 78 | 78 | 212 | 211 | 418 | 418 | KAK-09 |
| KAK-10 | 31 | 32 | 76 | 77 | 211 | 210 | 420 | 421 | KAK-10 |
| KAK-11 | 33 | 33 | 78 | 77 | 211 | 212 | 424 | 423 | KAK-11 |
| KAK-12 | 32 | 33 | 77 | 78 | 211 | 210 | 423 | 422 | KAK-12 |
| KAK-38 | 34 | 33 | 78 | 77 | 210 | 209 | 420 | 420 | KAK-38 |
| KAK-65 | 33 | 32 | 76 | 77 | 209 | 208 | 417 | 418 | KAK-65 |
| KAK-72 | 32 | 31 | 77 | 77 | 211 | 211 | 415 | 416 | KAK-72 |
| KAK-110 | 34 | 33 | 79 | 78 | 211 | 210 | 421 | 422 | KAK-110 |
| KAK-07 | 32 | 32 | 78 | 77 | 212 | 211 | 421 | 421 | KAK-07 |

Signature

John A. [Signature]

Date

5/6/03

KOOGLER & ASSOCIATES, ENVIRONMENTAL SERVICES
ANNUAL THERMOCOUPLE CALIBRATION
MAY 5-6, 2003

| Range (C) | Measured Voltage (mV) | Measured Voltage (V) | Calc. Temp. (C) | Readout Temp. (C) | Percent Difference (%) |
|--------------|-----------------------------|----------------------------|-----------------------|-------------------------|------------------------------|
| KAK-12 | 33.0 | 0.033 | 793 | 796 | -0.3453 |
| | 41.0 | 0.041 | 993 | 989 | 0.4131 |
| KAK-38 | 32.5 | 0.033 | 781 | 784 | -0.3728 |
| | 41.4 | 0.041 | 1003 | 999 | 0.4346 |
| KAK-72 | 32.8 | 0.033 | 788 | 790 | -0.2045 |
| | 41.1 | 0.041 | 996 | 993 | 0.2676 |
| KAK-65 | 32.1 | 0.032 | 771 | 769 | 0.3079 |
| | 40.9 | 0.041 | 991 | 995 | -0.4500 |
| KA-110 | 32.7 | 0.033 | 786 | 788 | -0.2605 |
| | 40.5 | 0.041 | 980 | 981 | -0.0695 |

EQUATIONS :

$$T(\text{calc.}) = (0.226584602 + (24152.109 * V) + (67233.4248 * V^2) + (2210340.682 * V^3) - (860963914.9 * V^4) + (48350600000 * V^5) - (1184520000000 * V^6) + (13869000000000 * V^7) - (63370800000000 * V^8))$$

Where :

V = Measured Voltage (Volts)

T(calc.) = Temperature calculated based on voltage

Signature

J. D. Harn

Date

5/6/03

POST-TEST DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

Koogler & Associates
Environmental Services

- 1) Select one critical orifice to calibrate the dry gas meter which represents the observed operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

COMPANY: RINKER - MIAMI, FL.

SOURCE: CEMENT KILN

DATE: 8/9/04

PRETEST Y: 0.988

METER SERIAL #: KA6
CRITICAL ORIFICE SERIAL #: 1376

BAROMETRIC PRESSURE (in Hg): INITIAL 30.08 FINAL 30.08 AVG (P_{bar}) 30.08

| RUN NO. | ORIFICE NO. | K' FACTOR (AVG) | TESTED VACUUM (in Hg) | DGM READINGS (FT ³) | | | TEMPERATURES °F | | | | | ELAPSED TIME (MIN) | DGM ΔH (in H ₂ O) | (1) V _m (STD) | (2) V _{cr} (STD) | (3) Y | (4) ΔH _@ | |
|---------|-------------|-----------------|-----------------------|---------------------------------|---------|-----------------------|-----------------|-----------|-------|------------|-------|--------------------|------------------------------|--------------------------|---------------------------|-------|---------------------|---------|
| | | | | INITIAL | FINAL | NET (V _m) | AMBIENT | DGM INLET | | DGM OUTLET | | | | | | | | DGM AVG |
| | | | | | | | | INITIAL | FINAL | INITIAL | FINAL | | | | | | | |
| 1 | 22 | 0.5836 | 18 | 828.500 | 836.169 | 7.669 | 75 | 62 | 63 | 76 | 77 | 70 | 10.0 | 1.9 | 7.73 | 7.59 | 0.983 | 1.854 |
| 2 | 22 | 0.5836 | 18 | 836.169 | 843.075 | 6.906 | 75 | 63 | 63 | 77 | 77 | 70 | 9.0 | 1.9 | 6.95 | 6.83 | 0.983 | 1.854 |
| 3 | 22 | 0.5836 | 18 | 843.075 | 850.748 | 7.673 | 75 | 63 | 63 | 77 | 78 | 70 | 10.0 | 1.9 | 7.72 | 7.59 | 0.984 | 1.854 |

AVG = 0.983

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) V_m(std) = K_1 V_m Y \left[\frac{P_{bar} + \left(\frac{\Delta H}{1.36} \right)}{T_m} \right]$$

$$(2) V_{cr}(std) = K' \left[\frac{P_{bar} \theta}{\sqrt{T_{amb}}} \right]$$

$$(3) Y = \frac{V_{cr}(std)}{V_m(std)}$$

$$(4) \Delta H_{@} = \left(\frac{0.75 * \theta}{V_{cr}(std)} \right)^2 * \Delta H$$

V_m(std) = Net volume of gas sample passed through DGM, corrected to standard conditions.

K₁ = 17.64 °R/in. Hg

Y = DGM calibration factor

V_{cr}(std) = Volume of gas sample passed through the critical orifice, corrected to standard conditions.

P_{bar} = Barometric pressure at the sampling site (in. Hg).

ΔH = Orifice pressure differential (in. H₂O).

θ = Total sampling time (min.)

T_m = Absolute DGM avg. temperature °R

T_{amb} = Absolute ambient temperature °R

K' = Average K' factor from Critical Orifice Calibration

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.983

AVERAGE DELTA Y = -0.005

DELTA Y LIMIT = 0.05

IS TEST WITHIN 5%? YES

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

| DATE: May 24, 2004 | | METER SERIAL #: KA-6 | | BAROMETRIC PRESSURE (in Hg): | | INITIAL: 30.06 | | FINAL: 30.05 | | AVG (P _{bar}): 30.05 | | IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED | | | | | | | | | | |
|--------------------|-------|-------------------------------------|-----------------------|---------------------------------|-----------|-----------------------|-----------------|-------------------|-----------------|--------------------------------|------------------|---|------------------------------|--------------------------|--------------------------|-------|-----------------|-----------------|---------|--|--|--|
| METER PART #: KA-6 | | CRITICAL ORIFICE SET SERIAL #: 1376 | | TEMPERATURES °F | | | | | ELAPSED | | | | | | | | | | | | | |
| ORIFICE # | RUN # | K FACTOR (AVG) | TESTED VACUUM (in Hg) | DGM READINGS (FT ³) | | | TEMPERATURES °F | | | | | ELAPSED TIME (MIN) Ø | DGM ΔH (in H ₂ O) | (1) V _m (STD) | (2) V _c (STD) | (3) Y | Y VARIATION (%) | ΔH _Ø | | | | |
| | | | | INITIAL | FINAL | NET (V _m) | AMBIENT | DGM INLET INITIAL | DGM INLET FINAL | DGM OUTLET INITIAL | DGM OUTLET FINAL | | | | | | | | DGM AVG | | | |
| 22 | 1 | 0.5836 | 20 | 878.714 | 881.878 | 7.164 | 74 | 81 | 81 | 81 | 81 | 8.30 | 1.7 | 7.8448 | 7.9589 | 1.002 | 1.63 | | | | | |
| | 2 | 0.5836 | 20 | 885.870 | 892.478 | 6.608 | 74 | 81 | 82 | 81 | 82 | 8.50 | 1.7 | 8.1893 | 8.4528 | 0.884 | 1.53 | | | | | |
| | 3 | 0.5836 | 20 | 892.414 | 1,000.973 | 8.559 | 75 | 82 | 83 | 82 | 83 | 11.00 | 1.7 | 8.4827 | 8.3428 | 0.983 | 1.63 | | | | | |
| | | | | | | | | | | | | | | | AVG = | | 0.956 | 0.92 | | | | |
| 17 | 1 | 0.4588 | 18 | 1,080.973 | 1,096.413 | 6.440 | 74 | 83 | 83 | 83 | 83 | 9.00 | 1.05 | 8.3270 | 8.2740 | 0.989 | 1.63 | | | | | |
| | 2 | 0.4505 | 18 | 8.413 | 12.780 | 6.367 | 72 | 82 | 83 | 82 | 83 | 10.50 | 1.03 | 8.2406 | 8.1845 | 0.988 | 1.63 | | | | | |
| | 3 | 0.4505 | 18 | 14.173 | 20.857 | 6.684 | 72 | 83 | 84 | 83 | 84 | 14.00 | 1.03 | 8.3821 | 8.3134 | 0.980 | 1.64 | | | | | |
| | | | | | | | | | | | | | | | AVG = | | 0.989 | 0.95 | | | | |
| 12 | 1 | 0.316 | 18 | 36.657 | 38.547 | 6.890 | 71 | 83 | 83 | 83 | 83 | 23.00 | 0.48 | 5.9718 | 5.8907 | 0.986 | 1.59 | | | | | |
| | 2 | 0.316 | 18 | 38.547 | 42.798 | 6.249 | 72 | 83 | 83 | 83 | 83 | 14.50 | 0.48 | 6.1110 | 5.9713 | 0.977 | 1.58 | | | | | |
| | 3 | 0.316 | 18 | 42.798 | 47.968 | 5.172 | 72 | 83 | 83 | 83 | 83 | 12.00 | 0.48 | 5.9578 | 4.9418 | 0.877 | 1.59 | | | | | |
| | | | | | | | | | | | | | | | AVG = | | 0.978 | -0.89 | | | | |

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_c (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **0.986**

AVERAGE ΔH_Ø = **1.61**

(1)
$$Vm_{(std)} = K_1 * Vm * \frac{Pbar + (\Delta H / 13.6)}{Tm}$$
 = Net volume of gas sample passed through DGM, corrected to standard conditions
 K₁ = 17.64 °R/in. Hg (English), 0.3856 °K/mm Hg (Metric)
 T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

(2)
$$Vc_{(std)} = K * \frac{Pbar * \Theta}{\sqrt{Tamb}}$$
 = Volume of gas sample passed through the critical orifice, corrected to standard conditions
 T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)
 K = Average K factor from Critical Orifice Calibration

(3)
$$Y = \frac{Vc_{(std)}}{Vm_{(std)}}$$
 = DGM calibration factor

$$\Delta H_{\Theta} = \left(\frac{0.75 \Theta}{V_{c(Std)}} \right)^2 \Delta H \left(\frac{V_{m(Std)}}{V_{c(Std)}} \right)$$

Process Data

0.6003

| AAGLOGS Kiln | | | | | | | | | | | | | | | Raw Mill | | |
|----------------|----------------|---------------------|--------------|--------------------|-------------|-----------------------|-------------|-------------|-------------|---------------|---------------|---------------|--|--|-------------|-------|-------|
| 461-KL1_ONTIME | | | 431-RW1-FZ1 | | 481-RW1-FZ1 | 481-BU1-FZ1 | 451-RW1-FZ1 | 461-2K1-AZ3 | 461-2K1-AZ1 | 461-2K1-AZ2 | 441-2K1-AZ3 | 441-2K1-AZ1 | 441-2K1-AZ2 | 421-BF1-TZ4 | 421-BF1-TZ5 | | |
| kiln run time | Kiln run Hours | kiln feed flow rate | Clinker Rate | pulv. coal to kiln | oil to kiln | pulv. coal to catcher | kiln O2 | kiln CO | kiln NO | pre heater O2 | pre heater CO | pre heater NO | MAIN BAGHOUSE INLET TEMPERATURE MIXING | MAIN BAGHOUSE INLET TEMPERATURE MIXING | | | |
| 4-Aug-04 | 0:00:00 | 1:00:00 | 13739.7 | 1.0 | 250.6 | 150.4 | 6.6 | 0.0 | 8.8 | 1.2 | 312.1 | 633.4 | 5.0 | 717.4 | 325.2 | 255.0 | 235.8 |
| 4-Aug-04 | 1:00:00 | 2:00:00 | 13740.7 | 1.0 | 250.4 | 150.3 | 6.6 | 0.0 | 8.9 | 1.0 | 279.6 | 551.4 | 3.8 | 779.2 | 349.9 | 263.1 | 241.2 |
| 4-Aug-04 | 2:00:00 | 3:00:00 | 13741.7 | 1.0 | 250.4 | 150.3 | 6.5 | 0.0 | 9.0 | 0.8 | 458.8 | 507.5 | 3.3 | 801.1 | 357.0 | 303.2 | 289.2 |
| 4-Aug-04 | 3:00:00 | 4:00:00 | 13742.7 | 1.0 | 250.4 | 150.3 | 6.6 | 0.0 | 9.1 | 1.7 | 162.8 | 621.4 | 3.5 | 740.6 | 380.8 | 248.4 | 233.7 |
| 4-Aug-04 | 4:00:00 | 5:00:00 | 13743.8 | 1.0 | 250.4 | 150.3 | 6.7 | 0.2 | 9.0 | 1.2 | 164.7 | 802.7 | 3.5 | 740.5 | 398.4 | 254.9 | 236.3 |
| 4-Aug-04 | 5:00:00 | 6:00:00 | 13744.6 | 1.0 | 250.4 | 150.3 | 6.8 | 0.0 | 9.6 | 1.2 | 159.0 | 1877.7 | 3.0 | 693.6 | 543.1 | 268.4 | 243.7 |
| 4-Aug-04 | 6:00:00 | 7:00:00 | 13745.6 | 1.0 | 250.5 | 150.4 | 6.4 | 0.1 | 9.9 | 1.8 | 156.2 | 2015.8 | 2.9 | 684.6 | 573.4 | 283.5 | 252.2 |
| 4-Aug-04 | 7:00:00 | 8:00:00 | 13746.8 | 1.0 | 248.3 | 149.0 | 6.5 | 0.2 | 9.9 | 1.4 | 158.7 | 1924.3 | 2.7 | 702.6 | 548.4 | 290.3 | 254.7 |
| 4-Aug-04 | 8:00:00 | 9:00:00 | 13747.6 | 1.0 | 245.6 | 147.4 | 6.6 | 0.1 | 9.9 | 0.8 | 175.8 | 1858.5 | 2.7 | 695.0 | 525.5 | 295.6 | 254.5 |
| 4-Aug-04 | 9:00:00 | 10:00:00 | 13748.6 | 1.0 | 245.6 | 147.4 | 6.5 | 0.0 | 9.8 | 0.3 | 241.7 | 1360.2 | 2.6 | 738.6 | 466.2 | 295.9 | 253.9 |
| 4-Aug-04 | 10:00:00 | 11:00:00 | 13749.6 | 1.0 | 245.6 | 147.4 | 6.4 | 0.1 | 9.7 | 0.2 | 308.6 | 1385.7 | 2.6 | 721.0 | 472.6 | 298.4 | 256.1 |
| 4-Aug-04 | 11:00:00 | 12:00:00 | 13750.6 | 1.0 | 245.6 | 147.4 | 6.2 | 0.2 | 9.7 | 0.2 | 359.7 | 1542.7 | 2.3 | 787.9 | 473.6 | 328.9 | 268.8 |
| 4-Aug-04 | 12:00:00 | 13:00:00 | 13751.6 | 1.0 | 245.5 | 147.4 | 6.1 | 0.4 | 9.7 | 0.8 | 163.7 | 1940.2 | 2.7 | 718.7 | 513.7 | 404.2 | 328.8 |
| 4-Aug-04 | 13:00:00 | 14:00:00 | 13752.8 | 1.0 | 245.5 | 147.4 | 6.2 | 0.4 | 9.7 | 0.5 | 210.5 | 1753.5 | 2.6 | 758.6 | 499.4 | 382.4 | 368.5 |
| 4-Aug-04 | 14:00:00 | 15:00:00 | 13753.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.4 | 9.5 | 0.2 | 218.2 | 1670.4 | 2.3 | 818.9 | 476.5 | 337.1 | 263.0 |
| 4-Aug-04 | 15:00:00 | 16:00:00 | 13754.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.5 | 9.5 | 0.0 | 354.1 | 1124.3 | 2.3 | 831.4 | 452.5 | 358.4 | 273.4 |
| 4-Aug-04 | 16:00:00 | 17:00:00 | 13755.8 | 1.0 | 245.6 | 147.4 | 6.4 | 0.4 | 9.5 | 0.1 | 309.9 | 1286.1 | 2.3 | 866.9 | 436.8 | 367.9 | 273.1 |
| 4-Aug-04 | 17:00:00 | 18:00:00 | 13756.6 | 1.0 | 245.6 | 147.4 | 6.4 | 0.5 | 9.3 | 0.1 | 225.3 | 1424.7 | 2.4 | 814.9 | 457.5 | 378.3 | 278.7 |
| 4-Aug-04 | 18:00:00 | 19:00:00 | 13757.6 | 1.0 | 245.6 | 147.4 | 6.4 | 0.4 | 9.6 | 1.6 | 183.4 | 1551.6 | 2.9 | 706.8 | 489.1 | 264.2 | 239.6 |
| 4-Aug-04 | 19:00:00 | 20:00:00 | 13758.8 | 1.0 | 245.2 | 147.2 | 6.3 | 0.3 | 9.5 | 2.7 | 163.5 | 1455.4 | 2.9 | 681.6 | 491.2 | 263.1 | 239.7 |
| 4-Aug-04 | 20:00:00 | 21:00:00 | 13759.6 | 1.0 | 250.6 | 150.5 | 6.4 | 0.2 | 9.7 | 2.9 | 163.2 | 1355.2 | 2.7 | 733.6 | 480.3 | 272.9 | 248.2 |
| 4-Aug-04 | 21:00:00 | 22:00:00 | 13760.6 | 1.0 | 250.6 | 150.4 | 6.5 | 0.2 | 9.6 | 4.6 | 229.7 | 1238.6 | 2.6 | 773.5 | 459.4 | 310.1 | 287.0 |
| 4-Aug-04 | 22:00:00 | 23:00:00 | 13761.6 | 1.0 | 250.6 | 150.4 | 6.5 | 0.2 | 9.6 | 1.0 | 403.9 | 1514.3 | 2.6 | 819.5 | 449.2 | 351.2 | 353.9 |
| 4-Aug-04 | 23:00:00 | 0:00:00 | 13762.6 | 1.0 | 250.6 | 150.4 | 6.4 | 0.0 | 9.6 | 1.0 | 321.5 | 1542.2 | 2.7 | 771.5 | 456.6 | 253.9 | 236.9 |
| 5-Aug-04 | 0:00:00 | 1:00:00 | 13763.6 | 1.0 | 250.5 | 150.4 | 6.4 | 0.1 | 9.8 | 1.1 | 285.8 | 1449.1 | 2.7 | 778.5 | 451.8 | 259.8 | 240.4 |
| 5-Aug-04 | 1:00:00 | 2:00:00 | 13764.6 | 1.0 | 250.6 | 150.4 | 6.4 | 0.0 | 9.8 | 0.8 | 352.5 | 1306.1 | 2.7 | 790.4 | 437.4 | 262.1 | 239.0 |
| 5-Aug-04 | 2:00:00 | 3:00:00 | 13765.6 | 1.0 | 250.5 | 150.4 | 6.4 | 0.0 | 9.6 | 0.7 | 406.8 | 1260.8 | 2.8 | 775.8 | 434.1 | 264.7 | 241.4 |
| 5-Aug-04 | 3:00:00 | 4:00:00 | 13766.6 | 1.0 | 250.5 | 150.4 | 6.4 | 0.1 | 9.5 | 0.8 | 276.5 | 1317.7 | 2.9 | 753.8 | 445.5 | 267.1 | 245.2 |
| 5-Aug-04 | 4:00:00 | 5:00:00 | 13767.6 | 1.0 | 250.6 | 150.4 | 6.4 | 0.1 | 9.4 | 1.0 | 270.5 | 1198.7 | 2.9 | 782.4 | 422.2 | 342.0 | 331.9 |
| 5-Aug-04 | 5:00:00 | 6:00:00 | 13768.6 | 1.0 | 250.6 | 150.4 | 6.4 | 0.1 | 9.4 | 0.9 | 478.4 | 1025.0 | 3.0 | 800.6 | 413.9 | 331.2 | 330.4 |
| 5-Aug-04 | 6:00:00 | 7:00:00 | 13769.5 | 1.0 | 250.6 | 150.5 | 6.3 | 0.0 | 9.6 | 1.3 | 262.7 | 1059.3 | 3.1 | 756.8 | 427.9 | 290.4 | 280.3 |
| 5-Aug-04 | 7:00:00 | 8:00:00 | 13770.5 | 1.0 | 248.2 | 149.0 | 6.3 | 0.1 | 9.5 | 1.4 | 371.7 | 910.2 | 3.1 | 764.2 | 402.8 | 427.6 | 432.3 |
| 5-Aug-04 | 8:00:00 | 9:00:00 | 13771.5 | 1.0 | 245.6 | 147.4 | 6.3 | 0.1 | 9.2 | 0.8 | 458.3 | 1145.4 | 3.1 | 727.9 | 428.0 | 510.1 | 517.0 |
| 5-Aug-04 | 9:00:00 | 10:00:00 | 13772.5 | 1.0 | 245.6 | 147.4 | 6.2 | 0.1 | 9.6 | 0.6 | 392.0 | 1385.1 | 2.8 | 745.6 | 442.8 | 508.5 | 515.5 |
| 5-Aug-04 | 10:00:00 | 11:00:00 | 13773.5 | 1.0 | 245.6 | 147.4 | 6.2 | 0.1 | 9.4 | 0.5 | 409.6 | 1508.9 | 2.8 | 753.5 | 447.1 | 508.7 | 515.4 |
| 5-Aug-04 | 11:00:00 | 12:00:00 | 13774.5 | 0.2 | 165.3 | 99.2 | 1.5 | 0.1 | 2.3 | 14.1 | 161.3 | 410.7 | 14.6 | 421.4 | 151.9 | 512.1 | 518.9 |
| 5-Aug-04 | 12:00:00 | 13:00:00 | 13774.8 | 0.5 | 124.0 | 74.4 | 0.0 | 13.5 | 2.9 | 6.3 | 1134.3 | 484.5 | 9.9 | 396.1 | 238.3 | 437.0 | 437.5 |
| 5-Aug-04 | 13:00:00 | 14:00:00 | 13775.3 | 1.0 | 222.8 | 133.7 | 2.6 | 14.4 | 8.8 | 1.6 | 372.7 | 1659.2 | 2.8 | 845.9 | 469.8 | 453.9 | 459.9 |
| 5-Aug-04 | 14:00:00 | 15:00:00 | 13776.3 | 1.0 | 245.6 | 147.4 | 6.3 | 1.6 | 9.1 | 1.2 | 290.3 | 1255.3 | 2.4 | 865.9 | 457.9 | 498.4 | 505.2 |

0.6003

| | | | 461-KL1 ONTIME | 431-RW1-FZ1 | 481-RW1-FZ1 | 461-BU1-FZ1 | 431-RW1-FZ1 | 461-2K1-AZ3 | 461-2K1-AZ1 | 461-2K1-AZ2 | 441-2K1-AZ3 | 441-2K1-AZ1 | 441-2K1-AZ2 | 421-BF1-TZ4 | 421-BF1-TZ5 | | |
|----------|----------|----------|----------------|----------------|---------------------|--------------|--------------------|-------------|------------------------|-------------|-------------|-------------|---------------|---------------|---------------|---------------------------------|---------------------------------|
| | | | kiln run time | kiln run hours | kiln feed flow rate | Clinker Rate | pulv. coal to kiln | oil to kiln | pulv. coal to calciner | kiln O2 | kiln CO | kiln NO | pre heater O2 | pre heater CO | pre heater NO | MAIN BAGHOUSE INLET TEMPERATURE | MAIN BAGHOUSE INLET TEMPERATURE |
| 5-Aug-04 | 15:00:00 | 16:00:00 | 13777.3 | 1.0 | 245.6 | 147.4 | 6.5 | 0.3 | 9.3 | 3.3 | 159.3 | 1420.8 | 3.0 | 720.8 | 528.7 | 505.5 | 512.3 |
| 5-Aug-04 | 16:00:00 | 17:00:00 | 13778.3 | 0.7 | 245.6 | 147.4 | 4.4 | 0.0 | 6.4 | 6.9 | 129.2 | 1191.5 | 7.4 | 708.8 | 382.3 | 506.0 | 513.0 |
| 5-Aug-04 | 17:00:00 | 18:00:00 | 13779.0 | 0.8 | 174.4 | 104.7 | 0.3 | 17.0 | 5.7 | 5.7 | 300.3 | 1273.2 | 8.7 | 521.7 | 323.0 | 473.1 | 475.7 |
| 5-Aug-04 | 18:00:00 | 19:00:00 | 13779.8 | 1.0 | 239.3 | 143.7 | 6.1 | 0.4 | 8.6 | 3.8 | 160.7 | 1911.5 | 2.8 | 756.8 | 455.8 | 484.6 | 490.8 |
| 5-Aug-04 | 19:00:00 | 20:00:00 | 13780.8 | 1.0 | 245.6 | 147.4 | 6.2 | 0.1 | 9.1 | 4.4 | 156.9 | 1638.7 | 3.1 | 751.9 | 478.0 | 505.0 | 510.7 |
| 5-Aug-04 | 20:00:00 | 21:00:00 | 13781.8 | 1.0 | 237.4 | 142.5 | 6.2 | 0.0 | 8.8 | 4.5 | 157.0 | 1709.5 | 3.4 | 691.6 | 494.1 | 385.9 | 402.2 |
| 5-Aug-04 | 21:00:00 | 22:00:00 | 13782.8 | 1.0 | 235.6 | 141.4 | 6.2 | 0.0 | 8.9 | 5.0 | 153.4 | 1782.3 | 3.9 | 614.2 | 499.5 | 236.9 | 225.9 |
| 5-Aug-04 | 22:00:00 | 23:00:00 | 13783.7 | 1.0 | 235.6 | 141.4 | 6.2 | 0.1 | 8.7 | 4.3 | 154.8 | 1805.2 | 3.7 | 613.7 | 530.7 | 243.3 | 230.3 |
| 5-Aug-04 | 23:00:00 | 0:00:00 | 13784.7 | 1.0 | 235.6 | 141.4 | 6.2 | 0.0 | 8.7 | 3.5 | 158.9 | 1698.5 | 3.6 | 616.5 | 552.8 | 247.8 | 233.8 |
| 6-Aug-04 | 0:00:00 | 1:00:00 | 13785.7 | 1.0 | 235.6 | 141.4 | 6.2 | 0.0 | 8.7 | 3.9 | 157.3 | 1567.0 | 3.6 | 625.5 | 518.7 | 242.1 | 228.8 |
| 6-Aug-04 | 1:00:00 | 2:00:00 | 13786.7 | 1.0 | 235.6 | 141.4 | 6.3 | 0.0 | 8.5 | 3.2 | 161.7 | 1169.1 | 3.4 | 670.7 | 452.2 | 243.3 | 229.7 |
| 6-Aug-04 | 2:00:00 | 3:00:00 | 13787.7 | 1.0 | 235.6 | 141.4 | 6.4 | 0.0 | 8.5 | 2.2 | 175.7 | 1151.8 | 3.5 | 677.7 | 457.2 | 249.6 | 232.7 |
| 6-Aug-04 | 3:00:00 | 4:00:00 | 13788.7 | 1.0 | 235.6 | 141.4 | 6.4 | 0.0 | 8.6 | 2.2 | 176.6 | 1208.3 | 3.5 | 680.4 | 459.6 | 249.2 | 232.0 |
| 6-Aug-04 | 4:00:00 | 5:00:00 | 13789.7 | 1.0 | 218.1 | 130.9 | 6.2 | 0.0 | 7.7 | 3.2 | 163.3 | 1046.7 | 4.3 | 641.1 | 437.9 | 254.2 | 235.4 |
| 6-Aug-04 | 5:00:00 | 6:00:00 | 13790.7 | 1.0 | 205.1 | 123.1 | 6.0 | 0.1 | 7.7 | 3.0 | 168.3 | 1123.9 | 4.0 | 621.7 | 424.4 | 281.5 | 276.0 |
| 6-Aug-04 | 6:00:00 | 7:00:00 | 13791.7 | 0.0 | 125.2 | 75.1 | 0.1 | 4.4 | 0.2 | 3.8 | 3488.3 | 216.6 | 9.7 | 194.2 | 89.4 | 337.2 | 342.3 |
| 6-Aug-04 | 7:00:00 | 8:00:00 | 13791.7 | 0.0 | 151.4 | 80.9 | 0.0 | 4.4 | 0.0 | 3.1 | 822.8 | 439.1 | 8.1 | 156.2 | 271.1 | 289.5 | 295.1 |
| 6-Aug-04 | 8:00:00 | 9:00:00 | 13791.7 | 0.9 | 131.6 | 79.0 | 0.0 | 21.0 | 5.2 | 4.1 | 153.7 | 1443.4 | 5.4 | 547.8 | 488.8 | 358.0 | 372.2 |
| 6-Aug-04 | 9:00:00 | 10:00:00 | 13792.7 | 1.0 | 234.8 | 140.9 | 3.5 | 10.9 | 9.3 | 2.1 | 469.0 | 2216.5 | 2.2 | 1131.7 | 492.6 | 394.2 | 415.0 |
| 6-Aug-04 | 10:00:00 | 11:00:00 | 13793.7 | 1.0 | 244.4 | 146.7 | 6.5 | 0.3 | 8.8 | 2.3 | 324.8 | 1800.7 | 3.0 | 756.8 | 517.3 | 248.0 | 237.7 |
| 6-Aug-04 | 11:00:00 | 12:00:00 | 13794.7 | 1.0 | 244.4 | 146.7 | 6.5 | 0.2 | 9.2 | 2.5 | 213.8 | 2014.2 | 3.2 | 702.2 | 527.9 | 241.5 | 228.2 |
| 6-Aug-04 | 12:00:00 | 13:00:00 | 13795.7 | 1.0 | 245.5 | 147.4 | 6.5 | 0.2 | 9.4 | 1.9 | 181.1 | 1837.7 | 3.0 | 760.8 | 504.4 | 264.0 | 243.4 |
| 6-Aug-04 | 13:00:00 | 14:00:00 | 13796.7 | 1.0 | 245.4 | 147.3 | 6.5 | 0.2 | 9.6 | 1.8 | 194.9 | 1800.6 | 3.1 | 739.9 | 508.3 | 266.2 | 245.1 |
| 6-Aug-04 | 14:00:00 | 15:00:00 | 13797.7 | 1.0 | 245.3 | 147.3 | 6.3 | 0.2 | 10.0 | 2.4 | 181.3 | 1763.7 | 3.2 | 658.7 | 533.7 | 270.1 | 246.4 |
| 6-Aug-04 | 15:00:00 | 16:00:00 | 13798.6 | 1.0 | 245.4 | 147.3 | 6.3 | 0.3 | 10.0 | 2.5 | 170.1 | 1877.0 | 3.4 | 627.0 | 557.2 | 261.3 | 241.2 |
| 6-Aug-04 | 16:00:00 | 17:00:00 | 13799.6 | 1.0 | 245.4 | 147.3 | 6.3 | 0.3 | 9.9 | 3.1 | 174.6 | 1723.5 | 3.3 | 682.2 | 545.6 | 254.9 | 236.2 |
| 6-Aug-04 | 17:00:00 | 18:00:00 | 13800.6 | 1.0 | 245.4 | 147.3 | 6.3 | 0.3 | 9.8 | 2.6 | 171.7 | 1723.5 | 3.3 | 647.9 | 541.1 | 254.4 | 235.8 |
| 6-Aug-04 | 18:00:00 | 19:00:00 | 13801.6 | 1.0 | 245.5 | 147.3 | 6.3 | 0.3 | 9.9 | 2.2 | 165.8 | 1725.8 | 3.1 | 666.3 | 525.5 | 262.1 | 239.1 |
| 6-Aug-04 | 19:00:00 | 20:00:00 | 13802.6 | 1.0 | 245.4 | 147.3 | 6.3 | 0.2 | 9.7 | 2.2 | 163.3 | 1707.8 | 3.2 | 702.5 | 525.7 | 269.8 | 244.5 |
| 6-Aug-04 | 20:00:00 | 21:00:00 | 13803.6 | 1.0 | 245.5 | 147.3 | 6.3 | 0.1 | 9.9 | 2.6 | 162.8 | 1641.0 | 3.3 | 661.1 | 535.3 | 264.9 | 242.2 |
| 6-Aug-04 | 21:00:00 | 22:00:00 | 13804.6 | 1.0 | 245.6 | 147.4 | 6.2 | 0.0 | 9.9 | 1.7 | 188.2 | 1856.1 | 3.1 | 675.9 | 535.6 | 260.5 | 237.4 |
| 6-Aug-04 | 22:00:00 | 23:00:00 | 13805.6 | 1.0 | 245.6 | 147.4 | 6.2 | 0.0 | 9.9 | 2.1 | 161.5 | 1913.0 | 3.3 | 644.1 | 562.2 | 261.7 | 238.4 |
| 6-Aug-04 | 23:00:00 | 0:00:00 | 13806.6 | 1.0 | 245.6 | 147.4 | 6.2 | 0.0 | 10.0 | 1.7 | 162.6 | 1910.8 | 3.1 | 673.5 | 540.7 | 258.4 | 237.1 |
| 7-Aug-04 | 0:00:00 | 1:00:00 | 13807.6 | 1.0 | 245.6 | 147.4 | 6.2 | 0.0 | 9.9 | 2.2 | 161.2 | 1839.7 | 3.0 | 671.1 | 520.7 | 344.4 | 334.6 |
| 7-Aug-04 | 1:00:00 | 2:00:00 | 13808.6 | 1.0 | 245.6 | 147.4 | 6.2 | 0.1 | 9.7 | 3.2 | 160.2 | 1714.9 | 3.0 | 704.2 | 512.6 | 370.9 | 375.3 |
| 7-Aug-04 | 2:00:00 | 3:00:00 | 13809.6 | 1.0 | 245.6 | 147.4 | 6.4 | 0.1 | 9.4 | 8.9 | 110.0 | 1198.1 | 3.2 | 680.2 | 542.3 | 259.8 | 248.6 |
| 7-Aug-04 | 3:00:00 | 4:00:00 | 13810.6 | 1.0 | 245.6 | 147.4 | 6.5 | 0.0 | 8.6 | 20.5 | -4.2 | -4.2 | 3.1 | 710.9 | 540.8 | 252.2 | 234.1 |
| 7-Aug-04 | 4:00:00 | 5:00:00 | 13811.6 | 1.0 | 245.6 | 147.4 | 6.5 | 0.0 | 8.4 | 20.5 | -4.0 | 0.4 | 3.1 | 720.1 | 516.6 | 248.0 | 230.4 |
| 7-Aug-04 | 5:00:00 | 6:00:00 | 13812.6 | 1.0 | 245.6 | 147.4 | 6.5 | 0.0 | 9.1 | 20.5 | -4.0 | -3.9 | 3.3 | 721.4 | 489.7 | 235.1 | 224.2 |
| 7-Aug-04 | 6:00:00 | 7:00:00 | 13813.6 | 1.0 | 245.6 | 147.4 | 6.6 | 0.0 | 9.1 | 20.5 | -4.0 | -4.0 | 3.3 | 693.4 | 484.8 | 239.2 | 225.8 |
| 7-Aug-04 | 7:00:00 | 8:00:00 | 13814.6 | 1.0 | 245.5 | 147.4 | 6.6 | 0.0 | 9.0 | 10.4 | 107.6 | 884.7 | 2.9 | 772.8 | 460.3 | 277.4 | 240.8 |
| 7-Aug-04 | 8:00:00 | 9:00:00 | 13815.6 | 1.0 | 245.5 | 147.4 | 6.6 | 0.0 | 9.0 | 1.3 | 206.7 | 1288.9 | 2.5 | 688.6 | 432.6 | 348.5 | 263.7 |
| 7-Aug-04 | 9:00:00 | 10:00:00 | 13816.6 | 1.0 | 245.6 | 147.4 | 6.5 | 0.1 | 8.9 | 1.0 | 255.6 | 933.1 | 2.5 | 1080.2 | 373.3 | 360.1 | 261.9 |
| 7-Aug-04 | 10:00:00 | 11:00:00 | 13817.6 | 1.0 | 245.6 | 147.4 | 6.4 | 0.1 | 9.2 | 1.0 | 249.8 | 1298.2 | 2.5 | 924.3 | 424.6 | 366.8 | 262.0 |

0.6003

| | | | 401-R1-1-CONTN | 401-R01-FZ1 | | | 401-RW1-FZ1 | 401-BU1-FZ1 | 401-RW1-FZ1 | 401-2K1-AZ3 | 401-2K1-AZ1 | 401-2K1-AZ2 | 401-2K1-AZ2 | 401-2K1-AZ1 | 401-2K1-AZ2 | 401-2K1-TZA | 401-2K1-TZB |
|----------|----------|----------|----------------|---------------|----------------------|--------------|---------------------|-------------|--------------------------|-------------|-------------|-------------|------------------|------------------|------------------|---|---|
| | | | kln run time | kln run hours | kln feed bow rate | clinker rate | puv. coal to kln | oil to kln | puv. coal to calciner | kln O2 | kln CO | kln NO | pre heater O2 | pre heater CO | pre heater NO | MAIN BAGHOUSE INLET TEMPERATURE INDIC | MAIN BAGHOUSE INLET TEMPERATURE INDIC |
| 7-Aug-04 | 11:00:00 | 12:00:00 | 13818.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.1 | 9.6 | 2.1 | 173.2 | 1550.3 | 2.6 | 808.0 | 458.2 | 381.3 | 306.2 |
| 7-Aug-04 | 12:00:00 | 13:00:00 | 13819.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.1 | 9.4 | 3.1 | 172.6 | 1464.6 | 2.7 | 825.9 | 445.2 | 319.3 | 248.6 |
| 7-Aug-04 | 13:00:00 | 14:00:00 | 13820.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.1 | 9.0 | 3.1 | 196.8 | 1439.1 | 3.2 | 716.4 | 445.1 | 305.3 | 254.5 |
| 7-Aug-04 | 14:00:00 | 15:00:00 | 13821.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.1 | 9.2 | 12.1 | 125.4 | 501.4 | 3.0 | 797.1 | 410.2 | 350.9 | 258.4 |
| 7-Aug-04 | 15:00:00 | 16:00:00 | 13822.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.1 | 9.6 | 2.9 | 194.4 | 1335.9 | 3.3 | 715.0 | 452.8 | 423.9 | 408.9 |
| 7-Aug-04 | 16:00:00 | 17:00:00 | 13823.6 | 1.0 | 245.6 | 147.4 | 6.3 | 0.0 | 9.2 | 2.1 | 232.7 | 1224.2 | 2.7 | 867.3 | 405.3 | 357.4 | 288.1 |
| 7-Aug-04 | 17:00:00 | 18:00:00 | 13824.5 | 1.0 | 237.8 | 142.8 | 6.3 | 0.0 | 8.9 | 3.0 | 242.9 | 732.5 | 3.3 | 776.9 | 383.3 | 355.5 | 267.4 |
| 7-Aug-04 | 18:00:00 | 19:00:00 | 13825.5 | 1.0 | 205.6 | 123.4 | 6.1 | 0.0 | 7.9 | 20.0 | 0.4 | 18.4 | 3.3 | 621.1 | 367.4 | 239.6 | 225.4 |
| 7-Aug-04 | 19:00:00 | 20:00:00 | 13826.5 | 1.0 | 205.6 | 123.4 | 6.0 | 0.0 | 7.6 | 20.6 | -4.6 | -4.6 | 3.3 | 609.9 | 377.4 | 247.4 | 228.7 |
| 7-Aug-04 | 20:00:00 | 21:00:00 | 13827.5 | 1.0 | 205.6 | 123.4 | 6.1 | 0.0 | 7.5 | 20.7 | -4.3 | -3.5 | 3.5 | 583.5 | 388.1 | 247.2 | 227.6 |
| 7-Aug-04 | 21:00:00 | 22:00:00 | 13828.5 | 1.0 | 205.6 | 123.4 | 6.1 | 0.0 | 7.5 | 6.9 | 159.4 | 1328.7 | 3.7 | 554.5 | 432.6 | 245.3 | 225.6 |
| 7-Aug-04 | 22:00:00 | 23:00:00 | 13829.5 | 1.0 | 205.6 | 123.4 | 6.0 | 0.1 | 7.7 | 1.1 | 254.9 | 1839.8 | 3.7 | 545.6 | 447.1 | 257.8 | 234.9 |
| 7-Aug-04 | 23:00:00 | 0:00:00 | 13830.5 | 1.0 | 205.6 | 123.4 | 6.0 | 0.2 | 7.7 | 1.9 | 288.6 | 1402.5 | 4.2 | 532.4 | 408.5 | 258.3 | 234.0 |
| 8-Aug-04 | 0:00:00 | 1:00:00 | 13831.5 | 1.0 | 205.6 | 123.4 | 6.0 | 0.3 | 7.7 | 2.8 | 162.7 | 1389.9 | 4.1 | 518.5 | 417.1 | 249.9 | 227.7 |
| 8-Aug-04 | 1:00:00 | 2:00:00 | 13832.5 | 1.0 | 205.6 | 123.4 | 6.0 | 0.2 | 7.9 | 1.6 | 182.2 | 1403.0 | 4.2 | 532.1 | 400.2 | 251.4 | 228.7 |
| 8-Aug-04 | 2:00:00 | 3:00:00 | 13833.5 | 1.0 | 205.6 | 123.4 | 6.0 | 0.2 | 7.8 | 3.4 | 160.4 | 1864.6 | 4.2 | 483.3 | 501.1 | 262.3 | 242.0 |
| 8-Aug-04 | 3:00:00 | 4:00:00 | 13834.5 | 1.0 | 205.6 | 123.4 | 5.9 | 0.2 | 7.9 | 3.2 | 155.5 | 2508.4 | 4.1 | 476.7 | 557.6 | 257.4 | 235.2 |
| 8-Aug-04 | 4:00:00 | 5:00:00 | 13835.5 | 1.0 | 205.6 | 123.4 | 5.9 | 0.2 | 8.3 | 3.0 | 155.2 | 2529.0 | 4.0 | 486.9 | 549.6 | 264.8 | 243.5 |
| 8-Aug-04 | 5:00:00 | 6:00:00 | 13836.5 | 1.0 | 208.6 | 125.2 | 5.9 | 0.2 | 8.5 | 2.5 | 156.6 | 2438.8 | 3.5 | 517.2 | 522.2 | 267.6 | 245.5 |
| 8-Aug-04 | 6:00:00 | 7:00:00 | 13837.5 | 1.0 | 224.9 | 135.0 | 6.3 | 0.2 | 9.0 | 2.5 | 166.8 | 2341.3 | 4.1 | 565.3 | 490.6 | 270.0 | 248.8 |
| 8-Aug-04 | 7:00:00 | 8:00:00 | 13838.5 | 1.0 | 242.0 | 145.3 | 6.5 | 0.2 | 8.4 | 3.2 | 161.0 | 2140.6 | 3.3 | 680.5 | 483.6 | 462.8 | 464.8 |
| 8-Aug-04 | 8:00:00 | 9:00:00 | 13839.5 | 1.0 | 245.6 | 147.4 | 6.5 | 0.2 | 9.5 | 2.6 | 166.7 | 1778.7 | 3.2 | 771.9 | 437.7 | 511.4 | 516.0 |
| 8-Aug-04 | 9:00:00 | 10:00:00 | 13840.5 | 1.0 | 245.6 | 147.4 | 6.5 | 0.2 | 9.5 | 2.1 | 163.6 | 1359.7 | 3.3 | 832.0 | 387.9 | 510.3 | 514.9 |
| 8-Aug-04 | 10:00:00 | 11:00:00 | 13841.5 | 1.0 | 245.6 | 147.4 | 6.6 | 0.3 | 9.4 | 1.9 | 170.2 | 1176.6 | 3.5 | 791.6 | 380.5 | 514.3 | 518.8 |
| 8-Aug-04 | 11:00:00 | 12:00:00 | 13842.5 | 1.0 | 237.0 | 142.3 | 6.6 | 0.3 | 8.9 | 2.4 | 158.6 | 1250.2 | 5.5 | 601.1 | 370.3 | 434.8 | 451.7 |
| 8-Aug-04 | 12:00:00 | 13:00:00 | 13843.5 | 1.0 | 235.6 | 141.4 | 6.6 | 0.3 | 8.7 | 2.2 | 171.1 | 955.7 | 6.3 | 591.1 | 333.9 | 293.8 | 289.9 |
| 8-Aug-04 | 13:00:00 | 14:00:00 | 13844.5 | 1.0 | 235.6 | 141.4 | 6.6 | 0.3 | 8.5 | 1.9 | 169.7 | 829.3 | 6.5 | 562.0 | 306.4 | 244.5 | 228.6 |
| 8-Aug-04 | 14:00:00 | 15:00:00 | 13845.5 | 1.0 | 235.6 | 141.4 | 6.6 | 0.2 | 8.3 | 1.7 | 172.2 | 763.8 | 6.8 | 581.6 | 291.0 | 242.6 | 227.1 |
| 8-Aug-04 | 15:00:00 | 16:00:00 | 13846.5 | 1.0 | 235.6 | 141.4 | 6.6 | 0.2 | 8.4 | 2.1 | 184.6 | 748.0 | 6.7 | 591.4 | 291.2 | 250.5 | 231.1 |
| 8-Aug-04 | 16:00:00 | 17:00:00 | 13847.5 | 1.0 | 235.6 | 141.4 | 6.7 | 0.3 | 8.4 | 1.4 | 198.6 | 561.1 | 6.8 | 604.0 | 263.2 | 262.2 | 238.0 |
| 8-Aug-04 | 17:00:00 | 18:00:00 | 13848.5 | 1.0 | 235.6 | 141.4 | 6.7 | 0.3 | 8.3 | 1.1 | 1135.8 | 469.6 | 6.8 | 600.8 | 273.1 | 265.6 | 241.1 |
| 8-Aug-04 | 18:00:00 | 19:00:00 | 13849.5 | 1.0 | 235.6 | 141.4 | 6.7 | 0.3 | 7.9 | 5.4 | 2697.6 | 212.6 | 7.0 | 561.6 | 266.2 | 260.4 | 236.9 |
| 8-Aug-04 | 19:00:00 | 20:00:00 | 13850.5 | 1.0 | 235.6 | 141.4 | 6.7 | 0.3 | 8.1 | 2.2 | 163.6 | 657.5 | 6.9 | 571.6 | 290.3 | 241.4 | 226.0 |
| 8-Aug-04 | 20:00:00 | 21:00:00 | 13851.4 | 1.0 | 226.6 | 136.1 | 6.9 | 0.3 | 7.7 | 1.9 | 165.2 | 856.0 | 7.5 | 520.9 | 304.7 | 245.3 | 227.9 |
| 8-Aug-04 | 21:00:00 | 22:00:00 | 13852.4 | 1.0 | 225.5 | 135.4 | 6.9 | 0.3 | 7.8 | 2.3 | 172.1 | 1785.3 | 7.8 | 465.9 | 398.9 | 256.3 | 235.7 |
| 8-Aug-04 | 22:00:00 | 23:00:00 | 13853.4 | 1.0 | 225.5 | 135.4 | 6.9 | 0.2 | 7.8 | 1.7 | 209.8 | 2136.8 | 8.0 | 453.9 | 427.3 | 262.4 | 239.3 |
| 8-Aug-04 | 23:00:00 | 0:00:00 | 13854.4 | -13854.4 | 225.5 | 135.3 | 6.7 | 0.1 | 8.4 | 1.2 | 302.4 | 1983.4 | 7.6 | 465.7 | 400.6 | 275.9 | 245.8 |



GEOCHEMICAL TESTING

Environmental and Energy Analysis

Mike Miller

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

COAL ANALYSIS REPORT

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/04/2004

Analyzed on: 08/13/2004

Description: Coal Sample 10:00

LAB NO. 04-069547

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.43 | | |
| Ash.....D3174-02.. | 17.30 | 17.55 | |
| Sulfur.....D4239-02.. | 1.09 | 1.11 | |
| BTU/LB.....D5865-03.. | 12330 | 12509 | 15172 |
| Free Swelling Index D720-91 | 7.5 | | |
| Lbs Sulfur/Million Btu | 0.88 | | |
| Nitrogen.....D5373.... | 1.34 | 1.36 | 1.65 |
| Mercury.....ASTM D3684-01 | | .173 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

COAL ANALYSIS REPORT

2005 N Center Ave
Somerset PA 15501

B14/443-1671
814/445-6666
FAX: 814/445-6729

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/04/2004

Analyzed on: 08/13/2004

Description: Coal Sample 14:00

LAB NO. 04-069548

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.33 | | |
| Ash.....D3174-02.. | 17.21 | 17.44 | |
| Sulfur.....D4239-02.. | 1.11 | 1.12 | |
| BTU/LB.....D5865-03.. | 12414 | 12581 | 15239 |
| Free Swelling Index D720-91 | 7.5 | | |
| Lbs Sulfur/Million Btu | 0.89 | | |
| Nitrogen.....D5373..... | 1.31 | 1.33 | 1.61 |
| Mercury.....ASTM D3684-01 | | .181 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

COAL ANALYSIS REPORT

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/05/2004

Analyzed on: 08/13/2004

Description: Coal Sample 10:00

LAB NO. 04-069549

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.36 | | |
| Ash.....D3174-02.. | 17.69 | 17.93 | |
| Sulfur.....D4239-02.. | 1.11 | 1.13 | |
| BTU/LB.....D5865-03.. | 12318 | 12488 | 15216 |
| Free Swelling Index D720-91 | 7.5 | | |
| Lbs Sulfur/Million Btu | 0.90 | | |
| Nitrogen.....D5373..... | 1.29 | 1.31 | 1.59 |
| Mercury.....ASTM D3684-01 | | .206 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

COAL ANALYSIS REPORT

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/05/2004

Analyzed on: 08/13/2004

Description: Coal Sample 14:00

LAB NO. 04-069550

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.45 | | |
| Ash.....D3174-02.. | 18.99 | 19.27 | |
| Sulfur.....D4239-02.. | 1.08 | 1.10 | |
| BTU/LB.....D5865-03.. | 11961 | 12137 | 15034 |
| Free Swelling Index D720-91 | 7.0 | | |
| Lbs Sulfur/Million Btu | 0.90 | | |
| Nitrogen.....D5373.... | 1.26 | 1.28 | 1.58 |
| Mercury.....ASTM D3684-01 | | .257 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

COAL ANALYSIS REPORT

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/06/2004

Analyzed on: 08/13/2004

Description: Coal Sample 14:00

LAB NO. 04-069551

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.52 | | |
| Ash.....D3174-02.. | 18.32 | 18.60 | |
| Sulfur.....D4239-02.. | 1.11 | 1.13 | |
| BTU/LB.....D5865-03.. | 12129 | 12316 | 15131 |
| Free Swelling Index D720-91 | 7.5 | | |
| Lbs Sulfur/Million Btu | 0.92 | | |
| Nitrogen.....D5373.... | 1.27 | 1.29 | 1.58 |
| Mercury.....ASTM D3684-01 | | .241 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

COAL ANALYSIS REPORT

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/07/2004

Analyzed on: 08/13/2004

Description: Coal Sample 06:00

LAB NO. 04-069552

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.43 | | |
| Ash.....D3174-02.. | 18.18 | 18.44 | |
| Sulfur.....D4239-02.. | 1.05 | 1.07 | |
| BTU/LB.....D5865-03.. | 12188 | 12365 | 15161 |
| Free Swelling Index D720-91 | 7.5 | | |
| Lbs Sulfur/Million Btu | 0.86 | | |
| Nitrogen.....D5373.... | 1.32 | 1.34 | 1.64 |
| Mercury.....ASTM D3684-01 | | .201 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

COAL ANALYSIS REPORT

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/07/2004

Analyzed on: 08/13/2004

Description: Coal Sample 10:00

LAB NO. 04-069553

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.55 | | |
| Ash.....D3174-02.. | 17.05 | 17.32 | |
| Sulfur.....D4239-02.. | 1.09 | 1.11 | |
| BTU/LB.....D5865-03.. | 12400 | 12595 | 15234 |
| Free Swelling Index D720-91 | 7.5 | | |
| Lbs Sulfur/Million Btu | 0.88 | | |
| Nitrogen.....D5373..... | 1.34 | 1.36 | 1.65 |
| Mercury.....ASTM D3684-01 | | .255 mg/kg, dry | |

Robert L. Stull
Director of Coal Services





GEOCHEMICAL TESTING

Environmental and Energy Analysis

COAL ANALYSIS REPORT

2005 N Center Ave
Somerset PA 15501

814/443-1671
814/445-6666
FAX: 814/445-6729

Client: RINKER MATERIALS CORP

Sampled by: Oliver Sohn

Sampling Date: 08/07/2004

Analyzed on: 08/13/2004

Description: Coal Sample 14:00

LAB NO. 04-069554

| | As Received | Dry | Dry Ash-Free |
|-----------------------------|-------------|-----------------|--------------|
| Total Moisture...D2961-02.. | 1.64 | | |
| Ash.....D3174-02.. | 16.18 | 16.45 | |
| Sulfur.....D4239-02.. | 1.11 | 1.13 | |
| BTU/LB.....D5865-03.. | 12551 | 12760 | 15272 |
| Free Swelling Index D720-91 | 7.0 | | |
| Lbs Sulfur/Million Btu | 0.88 | | |
| Nitrogen.....D5373.... | 1.32 | 1.34 | 1.61 |
| Mercury.....ASTM D3684-01 | | .174 mg/kg, dry | |

Robert L. Stull
Director of Coal Services



Project Participants



PROJECT PARTICIPANTS

Koogler & Associates

John B. Koogler, Ph.D., P.E. Project Advisor
Steven Cloutier Technical Manager
Glen Haven Field Test Crew
Rodney Paul Field Test Crew
Cory J Bell Field Test Crew
Adam West Field Test Crew
Eric Thomas Field Test Crew

Rinker Materials Corporation

Michael Vardeman Environmental Manager, Cement Division
Tom Stokes

