

Attachment 8 - Summary of Stationary Engines on Site

Location	Manufacturer	Model No.	Serial No.	Purchase Date (Month-YY)	Generator Rating (KW)
Transfer Building	Cummins	QSL9-G2NR3	73036295	June-11	230
Incinerator Building	Cummins	440FDR7012	KA-926301-1/14-12	March-80	215
Scale house	Generac	DS30D6SGT	N/A	October-11	30

Location	Engine Use	Fuel Tupe	40 CFR 63 Subpart ZZZZ Applicable?	40 CFR 60 Subpart IIII Applicable ?	40 CFR 60 Subpart JJJJ Applicable ?
1. Transfer Building	Standby/Emergency	No. 2 Fuel Oil	YES	YES	NO
2. Incinerator Building	Standby/Emergency	No. 2 Fuel Oil	YES	NO	NO
3. Scale house	Standby/Emergency	No. 2 Fuel Oil	YES	YES	NO

Stationary Reciprocating Internal Combustion Engines - Applicable Operation Requirements

Location	Manufacturer	Model No.	40 CFR 63 Subpart ZZZZ Applicable Operation Requirements (New Emergency CI Stationary RICE at Area Source of HAPs)	40 CFR 60 Subpart IIII Applicable Operation Requirements (NSPS for Emergency CI RICE) - 40 CFR 60.4211(f)
Transfer Building	Cummins	QSL9-G2NR3	Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	Engine must be certified. Install non-resettable hour meter. Limit of 100 hrs/yr for maintenance/readiness testing and record engine hours.
Scale house	Generac	DS30D6SGT	Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	Engine must be certified. Install non-resettable hour meter. Limit of 100 hrs/yr for maintenance/readiness testing and record engine hours.

Location	Manufacturer	Model No.	40 CFR 63 Subpart ZZZZ Applicable Operation Requirements (EXISTING Emergency CI Stationary RICE at Area Source of HAPs)	40 CFR 60 Subpart IIII Applicable Operation Requirements (NSPS for Emergency CI RICE) - 40 CFR 60.4211(f)
Incinerator Building	Cummins	440FDR7012	Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	NONE