



Enron North America Corp.

P.O. Box 1188

Houston, TX 77251-1188

RECEIVED

AUG 23 2000

BUREAU OF AIR REGULATION

August 21, 2000

CERTIFIED MAIL – RETURN RECEIPT REQUESTED

Mr. Al Linero, PE
Administrator, New Source Review Section
Florida Department of Environmental Protection
2600 Blair Stone Road, MS#5505
Tallahassee, FL 32399-2400

RE: Medley Electric Generating Plant
Midway-St. Lucie Electric Generating Plant
Broward-Thornborough Electric Generating Plant
Applications for Air Construction Permit
Request to Terminate Application Review

Dear Mr. Linero:

On July 19, 2000 Enron North America submitted permit applications for air construction permits for the Medley and Midway-St. Lucie Electric Generating Facilities. A permit application for the Broward-Thornborough Electric Generating Plant was submitted on August 9, 2000. At the time of application submittal, the fees for permit review were also submitted. These applications were submitted in anticipation of achieving a June, 2001 startup date at one or more of these sites.


After a recent evaluation of the environmental and land use approvals required for these sites, we have decided that developing these projects for a start date in calendar year 2001 is not realistic. As a result, we are advising the Florida Department of Environmental Protection (DEP) to halt review of these permit applications.

It is our intention to continue development of these sites for projects that would be commercially viable in the year 2002. However, it is possible that for this later start date we would employ combustion turbine configurations that differ from those identified in the applications we have submitted. As a result, we feel that it would not be productive to receive permits for the LM6000 configuration.

Mr. A. A. Linero
August 21, 2000
Page 2

Please feel free to contact me at (713) 853-3161 if you have any questions regarding this request.

Sincerely,
Enron North America

A handwritten signature in black ink that reads "David A. Kellermeyer". The signature is written in a cursive style with a long, sweeping underline that extends to the right.

David A. Kellermeyer
Director

cc: Greg Krause
Steve Krimsky



Facsimile Cover Sheet

To: Al Linero
Company: Florida DEP
Phone: (850) 921-9523
Fax: (850) 922-6979

From: Dave Kellermeyer
Company: Enron North America
Phone: (713) 853-3161
Fax: (713) 646-3037

Date: 08/21/00

**Pages including this
cover page:** 3

Comments:

Al-

Please see attached re: pending permit applications.

Dave Kellermeyer

**Enron North America Corp.**

P.O. Box 1188

Houston, TX 77251-1188

August 21, 2000

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Al Linero, PE
Administrator, New Source Review Section
Florida Department of Environmental Protection
2600 Blair Stone Road, MS#5505
Tallahassee, FL 32399-2400

RE: Medley Electric Generating Plant
Midway-St. Lucie Electric Generating Plant
Broward-Thornborough Electric Generating Plant
Applications for Air Construction Permit
Request to Terminate Application Review

Dear Mr. Linero:

On July 19, 2000 Enron North America submitted permit applications for air construction permits for the Medley and Midway-St. Lucie Electric Generating Facilities. A permit application for the Broward-Thornborough Electric Generating Plant was submitted on August 9, 2000. At the time of application submittal, the fees for permit review were also submitted. These applications were submitted in anticipation of achieving a June, 2001 startup date at one or more of these sites.


After a recent evaluation of the environmental and land use approvals required for these sites, we have decided that developing these projects for a start date in calendar year 2001 is not realistic. As a result, we are advising the Florida Department of Environmental Protection (DEP) to halt review of these permit applications.

It is our intention to continue development of these sites for projects that would be commercially viable in the year 2002. However, it is possible that for this later start date we would employ combustion turbine configurations that differ from those identified in the applications we have submitted. As a result, we feel that it would not be productive to receive permits for the LM6000 configuration.

Mr. A. A. Linero
August 21, 2000
Page 2


Please feel free to contact me at (713) 853-3161 if you have any questions regarding this request.

Sincerely,
Enron North America

A handwritten signature in black ink that reads "David A. Kellermeyer". The signature is written in a cursive style with a long, sweeping underline that extends to the right.

David A. Kellermeyer
Director

cc: Greg Krause
Steve Krinsky



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

August 9, 2000

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Ms. Janet Dietrich
Managing Director
1400 Smith Street
Houston, Texas 77002-7631

Re: DEP File No. 0251029-001-AC and 1110099-001-AC
Medley Electric Generating Plant
Midway-St. Lucie Electric Generating Plant

Dear Ms. Dietrich:

On July 19, 2000 the Department received your application and complete fee for an air construction permit for the above reference electric generating plant projects to be located at Dade and St. Lucie Counties. Based on our initial review, the application is incomplete. Pursuant to Rules 62-4, 62-204, 62-210, 62-212, and 62-297, F.A.C., please submit the information requested below:

1. Address all phases planned for these two projects, if any. [Rule 62-212.400(6)(b), F.A.C. and 40CFR51.166(j)(4)].
2. Submit a design and operating features of the GE LM6000PC SPRINT® including type of combustors, drawings, heat input curves, manufacturer's emissions performance vs load diagrams, etc. [Rule 62-4.070(3), F.A.C.]
3. Estimate emissions of sulfuric acid mist (SAM). [Rules 62-212.400(2)(d), F.A.C and 62-4.070(3), F.A.C.]

Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. Permit applicants are advised that Rule 62-4.055(1), F.A.C. now requires applicants to respond to requests for information within 90 days.

If you have any questions regarding this matter, please call Teresa Heron at 850/921-9529 or e-mail her at teresa.heron@dep.state.fl.us.

Sincerely,

A.A. Linero, P.E. Administrator
New Source Review Section

Cc: Lennon Anderson SED
Patrick Wong, DERM

"More Protection, Less Process"

Printed on recycled paper.

*to
Files*

*We gave them
this letter at
the meeting.*



Enron North America Corp.

P.O. Box 1188

Houston, TX 77251-1188

July 17, 2000

RECEIVED

JUL 19 2000

BUREAU OF AIR REGULATION

Mr. Al Linero, P.E.
Administrator, New Source Review Section
Florida Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

RE: Challenger Development Company, LLC
Permit Application for Medley Electric Generating Plant

Dear Mr. Linero:

On behalf of Challenger Development Company, LLC, enclosed are four (4) copies of an air permit application for the Medley Electric Generating Plant in Dade County, Florida. This application is for a non-PSD permit for a simple cycle combustion turbine power plant consisting of 6 LM6000 dual-fuel units. Also enclosed is a check for \$5,750 to cover the permit application fee. Separate copies of this application are being sent to the Southeast District of the DEP as well as to the local air quality agency in Dade County.

If you have any questions, please don't hesitate to call me at (713) 853-3161.

Sincerely,
Enron North America

A handwritten signature in cursive script that reads "David A. Kellermeier". The signature is written in black ink and has a long, sweeping underline that extends to the right.

David A. Kellermeier
Director

Enclosures

cc: Lennon Anderson, Southeast District
Courtney Pitters, Dade County

A handwritten signature in cursive script that reads "J. Heron". The signature is written in black ink and is relatively compact.

RECEIVED

JUL 19 2000

BUREAU OF AIR REGULATION

**Challenger Development
Company, LLC
Houston, Texas**



**Air Permit Application for
Medley Electric
Generating Plant**

ENSR Corporation

July 2000

Document Number 6792-123-710

**Challenger Development
Company, LLC
Houston, Texas**

**Air Permit Application for
Medley Electric
Generating Plant**

RECEIVED

JUL 19 2000

BUREAU OF AIR REGULATION

**ENSR Corporation
July 2000
Document Number 6792-123-710**

CONTENTS

1.0 INTRODUCTION	1-1
2.0 PROJECT DESCRIPTION	2-1
3.0 EMISSIONS SUMMARY	3-1
3.1 Criteria Pollutant Emissions	3-1
3.2 Hazardous Air Pollutant Emissions.....	3-3
4.0 REFERENCES	4-1

APPENDICES**A FDEP PERMIT APPLICATION FORMS****B EMISSION CALCULATIONS**

LIST OF TABLES

Table 3-1	Combustion Turbine Maximum Hourly Emission Rate Summary	3-2
Table 3-2	Annual Criteria Pollutant Emissions	3-3
Table 3-3	HAP Emission Summary, Medley Electric Generating Facility	3-4
Table 3-4	Summary of Proposed Permit Limits for Combustion Turbine, Natural Gas Operation	3-5
Table 3-5	Summary of Proposed Permit Limits for Combustion Turbine, Distillate Oil Operation	3-5

LIST OF FIGURES

Figure 1-1 Site Location Map.....	1-2
Figure 2-1 Equipment Arrangement Plan.....	2-3
Figure 2-2 Process Flow Diagram.....	2-4
Figure 2-3 CTG Relative Criteria Pollutant Emission Rates.....	2-5

1.0 INTRODUCTION

Challenger Development Company, L.L.C. is proposing to construct and operate a simple cycle combustion turbine peaking electric generating facility in Dade County, Florida. The Medley Electric Generating Facility (the Facility) will be a non-utility power generating facility (merchant plant) designed to produce electric energy for sale to the wholesale power market.


The Facility will be sited on approximately 20 acres located in Dade County, Florida (see Figure 1-1). The facility will consist of six GE LM6000 PC SPRINT[®] simple cycle combustion turbines with a nominal generating capacity of approximately 288 megawatts (MW). The plant will fire natural gas and low sulfur distillate fuel oil. Natural gas will be the primary fuel. Distillate fuel will be used as a back-up fuel, in the event that natural gas is unavailable to the facility. The turbines will use water injection to minimize NO_x formation and good combustion practices for control of CO and VOC emissions. The turbines will be equipped with inlet air chilling and SPRINT[®] (SPRay INTERcooling) for power augmentation.

The facility is scheduled to begin producing power in June, 2001. Construction will take approximately 6 months with a planned start date of December 1, 2000 (upon receipt of all necessary local and environmental approvals).

As a peaking facility, the project will operate on an intermittent basis, primarily during periods when short-term electrical demand exceeds base load supply. Hence, the facility will run primarily during the peak demand hours of the summer months and to a limited extent on the coldest winter days. In order to be permitted as a minor source of air emissions, the facility will limit emissions of all criteria pollutants to less than 248 tons per year (TPY) by accepting an enforceable limitation on tons per year of all criteria pollutants emitted. NO_x and CO have been determined to be the limiting pollutants for major source status. As such, it is proposed that NO_x and CO emissions be limited to no more than 248 TPY, as measured by NO_x and CO continuous emission monitoring systems.

Section 2 of this application provides a more detailed project description. Section 3 presents a summary of the project emissions and the basis and methods used to calculate emissions. The required Florida Department of Environmental Protection (FDEP) application forms are presented in Appendix A, with supporting calculations for emissions included in Appendix B. As "new affected units" under Phase II of the Acid Rain Program, the facility is required to obtain SO₂ allowances. The application for the Phase II Acid Rain permit will be submitted shortly after this application is filed.

Figure 1-1 Site Location Map



2.0 PROJECT DESCRIPTION

The GE LM 6000 PC SPRINT[®] combustion turbine (CT) is a nominal 48 MW class industrial gas turbine. The LM 6000 is a 2-shaft gas turbine engine derived from the core of the CF6-80C2 - GE's high thrust, high efficiency aircraft engine. Over eighteen hundred CF6-80C2's are in service and over 2000 more are on order or option. The CF6-80C2 has logged more than 30,000,000 flight hours in the Boeing 747 and other wide-body aircraft, with a 99.88% dispatch reliability. GE used the extensive flight experience of the CF6-80C2 to create the LM 6000. Both engines have a common design and share most major parts. The Low Pressure Turbines, High Pressure Compressors, High Pressure Turbines, and Combustors are virtually identical. This use of flight-proven parts, produced in high volume, contributes to the low initial cost and high operating efficiency of the LM6000.

The GE LM6000 PC SPRINT[®] enhances the efficiency and output of the LM6000 gas turbine engine by injecting micro-droplets of atomized water into the interstage air stream between the Low Pressure Compressor and the High Pressure Compressor. The SPRINT[®] system increases the power output by as much as 20% at 90 °F and by improving the expected heat rate from 9,330 Btu/kWh LHV to 8,984 Btu/kWh LHV at 90 °F.

The proposed facility will utilize six GE LM6000 CTs, providing a total nominal generating capacity of approximately 288 MWs. Emissions from each turbine will be vented through stacks that are 45 feet tall and 10 feet in diameter. Figure 2-1 is a conceptual drawing depicting the layout of the proposed turbine configuration, Figure 2-2 is a process flow diagram for the proposed combustion turbines.

The turbines will be equipped to fire both natural gas and fuel oil, utilizing natural gas as the primary fuel. The project will not use any other fuel source for startup, shutdown, or backup. The Facility will have the ability to utilize power from the grid for startup. Electrical power produced by the project will be interconnected to the electric grid by a transmission line to FPL's transmission line in the vicinity of the property.


The Facility will use simple cycle power generation for peaking electrical generation for periods when short-term electrical demand exceeds base load supply. Peaking units have the ability to be brought on-and off-line quickly in response to fluctuations in electrical demand. Typical startup to 100% load and shutdown from 100% load can be achieved in approximately 20 minutes .

The Facility will be permitted and operated as a synthetic minor source under the Clean Air Act by accepting a permit limitation on tons per year of criteria pollutants emitted. Figure 2-3 illustrates the relative emissions rates of criteria pollutants from the proposed turbines. Based on the proposed permit limits, the most limiting pollutants are NO_x during distillate oil operation and CO during natural gas operation. Challenger Development Company, LLC proposes to limit potential emissions from the Facility through the use of a Continuous Emission Monitoring System (CEMS) for NO_x and CO. By

limiting emissions of NO_x and CO to less than the major source threshold of 248 tons per year, it can be seen that none of the remaining criteria pollutants will exceed the 250 ton per year threshold. Although performance data has been included for operating conditions from 50% to 100% load, each CT will typically be operated at full (100%) load. Depending upon demand, all units may not be in operation.

The Facility will also incorporate two tanks used to store distillate oil for the combustion turbines and a fire-water pump engine. The on site oil storage requirements have been estimated to be a maximum of 1,500,000 gallons, with a maximum day storage tank requirement of 300,000 gallons. The working and breathing losses from the two tanks has been estimated using the Tanks 4.0 program to be 0.7 tons per year.

For emergency purposes the Facility will incorporate a fire water pump powered by a 250 hp diesel engine. The emissions from this engine have been estimated using AP-42 emission factors, assuming a maximum operation of 500 hours per year. Based on this operational limitation the fire water pump engine satisfies the applicable criteria of Rule 62-210.300(b)1 for exemption from permitting and thus has not been addressed in the Section III of the FDEP application forms. In addition, a 6 MMBtu/hour fuel gas heater will be included in the Facility design for use as a means to prevent condensation of moisture and hydrates in natural gas used in the gas turbines. This emissions unit also meets the criteria for the generic emissions unit exemption under Rule 62.210.300(b)1 and has not been included in Section III of the application forms.



24

697205A.DWG


ENSRTM

ENSR CONSULTING AND ENGINEERING

FIGURE 2-2
PROCESS FLOW DIAGRAM
 SIMPLE CYCLE COMBUSTION TURBINE

DRAWN:	JK	DATE:	6/00	PROJECT NUMBER:	REV.
APPVD:	DD	REVISED:	X	6792-123	0

Figure 2-3 CTG Relative Criteria Pollutant Emission Rates



3.0 EMISSIONS SUMMARY

This section discusses the basis and methods used to estimate potential emissions for the Facility.

The data used during the development of this application rely on process information developed by GE for Challenger Development Company, L.L.C. The summary presented in Table 3-1 has been prepared for the six GE LM6000 PC SPRINT[®] combustion turbines. Similar to other machines, as combustion turbines age the performance achieved in practice will degrade from the initial condition. The most noticeable result of the aging process for combustion turbines is that the heat rate of the turbine will rise over time (i.e. efficiency will drop) The result of this aging effect is that to achieve the same electrical output more fuel will need to be consumed. To account for this aging effect the hourly emissions, presented in Table 3-1, include a 10% margin on the mass emission rate above what has been calculated from the manufacturer's performance data. This aging effect only influences the mass emission rate and not the emission concentration. The 10% margin is based on previous experience with similar combustion turbines.

Detailed emission calculations for these turbines are presented at 100%, 75%, and 50% load cases in Appendix B along with operating specifications at the following ambient conditions:

- 42°F dry bulb at 72% relative humidity,
- 90°F dry bulb at 65% relative humidity chilled to 50°F and 95% relative humidity.

The effect of the SPRINT[®] power augmentation system is included in both temperature cases.

3.1 Criteria Pollutant Emissions

The primary emission sources at the Facility will be the six CTs. Each CT, when used, will typically operate at 100% load, but may, at times, be operated down to 50% load. The turbines will fire natural gas, supplied directly to the site by pipeline and fuel oil, provided by onsite storage. Hourly emissions from these units were calculated from manufacturers' operating parameters and guaranteed in-stack concentrations for CO, NO_x, and VOC.

According to GE, limited data are available for particulate emissions; however, GE guarantees 4.5 lbs/hr per turbine while firing natural gas, including condensable and filterable particulate matter, under a load range of 50 to 100% of full load. Particulate emissions are estimated to be 20 lb/hour while firing fuel oil. As PM₁₀ emissions are based on manufacturer's guaranteed hourly emission rates, a worst case lb/MMBtu emission factor has been calculated from the lb/hr guarantee emission rate for purposes of calculating annual PM₁₀ emissions. SO₂ emissions were calculated using the manufacturers' supplied fuel consumption data and expected maximum fuel gas sulfur contents of 2.0 grains per 100 standard cubic feet for natural gas and 0.05% for fuel oil.

Table 3-1 Combustion Turbine Maximum Hourly Emission Rate Summary

Compound	Load (%)	Temperature (deg F)			
		90	42	90	42
Emissions for one GE LM 6000 Turbine - With Margin (lb/hr)					
		Natural Gas		Distillate Oil	
NOx	100	46.3	47.1	78.7	79.9
	75	36.6	36.5	62.8	62.1
	50	27.8	27.6	47.7	47.3
CO	100	63.2	64.2	63.9	64.9
	75	49.9	49.8	51.0	50.4
	50	37.9	37.6	38.7	38.4
VOC	100	7.2	7.3	6.5	6.6
	75	5.7	5.6	5.2	5.2
	50	4.3	4.1	4.0	3.9
SO2	100	2.8	2.8	24.6	25.0
	75	2.2	2.2	19.7	19.5
	50	1.7	1.7	15.0	14.9
Pb	100	0.000	0.000	0.007	0.007
	75	0.000	0.000	0.005	0.005
	50	0.000	0.000	0.004	0.004
PM10	100	5.0	5.0	22.0	22.0
	75	5.0	5.0	22.0	22.0
	50	5.0	5.0	22.0	22.0
Notes:					
Margin on Emissions 10%					
Emissions for six GE LM 6000 PC SPRINT Turbines - With Margin (lb/hr)					
NOx	100	278.1	282.3	472.0	479.4
	75	219.6	219.1	376.7	372.9
	50	166.9	165.6	285.9	283.6
CO	100	379.2	385.1	383.1	389.2
	75	299.5	298.7	305.8	302.7
	50	227.6	225.9	232.1	230.2
VOC	100	43.4	43.9	39.2	39.8
	75	34.3	33.4	31.3	31.0
	50	25.8	24.8	23.7	23.5
SO2	100	16.6	16.9	147.7	150.2
	75	13.1	13.1	118.2	117.1
	50	10.0	9.9	89.8	89.2
Pb	100	0.0	0.0	0.0	0.0
	75	0.0	0.0	0.0	0.0
	50	0.0	0.0	0.0	0.0
PM10	100	29.7	29.7	132.0	132.0
	75	29.7	29.7	132.0	132.0
	50	29.7	29.7	132.0	132.0
Notes:					
Margin on Emissions 10%					

Maximum hourly emission rates for each pollutant were established after reviewing the calculations for the two ambient temperatures at three turbine load conditions (50%, 75%, and 100%) that represent the range of expected operating conditions. The maximum emissions for all criteria pollutants are at 100% load, 42°F. The annual facility emissions of NO_x and CO will be limited through the use of CEMS, to a maximum of 248 tons per year. Although annual operation is restricted through the use of NO_x and CO CEMS rather than a fuel cap, an estimate of the maximum annual fuel consumption is used to calculate the maximum annual emissions of VOC, SO₂, Pb, and PM₁₀.

Based on the guaranteed emission concentrations, during natural gas operation CO is the limiting pollutant, while during distillate oil operation NO_x is the limiting pollutant. The CO emissions presented in this application are based on a guaranteed CO emission concentration of 56 ppmvd @ 15% O₂. This guaranteed concentration covers turbine operation over a broad range of ambient conditions, including extremely low temperatures that will not be experienced by a turbine used for summer peaking in Florida. At typical ambient temperatures for the Facility, Challenger Development Company, L.L.C. expects actual CO emission concentrations to be substantially lower than the guaranteed emission concentration. Thus, annual emissions of VOC, SO₂, Pb, and PM₁₀ have been estimated assuming NO_x to be the limiting pollutant as not as much variability is expected in the NO_x concentration. The data used in this analysis is presented in Appendix B. Table 3-2 presents a summary of annual emissions for the six combustion turbines, the natural gas fuel heater, the distillate oil storage tank, and the fire-water pump engine. Tables 3-4 and 3-5 provide a summary of proposed permit limits for the combustion turbines.

Table 3-2 Annual Criteria Pollutant Emissions

Source Name	NO _x ⁽¹⁾	CO ⁽¹⁾	VOC ⁽²⁾	SO ₂ ⁽²⁾	Pb ⁽²⁾	PM ⁽²⁾	PM ₁₀ ⁽²⁾
Annual Emission Rates (tons/year)							
LM 6000 Combustion Turbines.	245.5	247.2	41.6	85.0	0.02	125.1	125.1
Distillate Oil Storage Tank	N/A	N/A	0.9	N/A	N/A	N/A	N/A
Fire-Water Pump Engine	2.0	0.4	0.2	0.1	0.0	0.2	0.2
Natural Gas Fuel Heater	0.5	0.4	0.3	0.0	0.0	0.0	0.0
Total	248.0	248.0	43.0	85.1	0.02	125.3	125.3
Notes:							
(1) Limited by CEMS on NO _x and CO.							
(2) Estimated from CEMS limitation on NO _x and CO. Annual emissions of VOC, SO ₂ , Pb, and PM/PM ₁₀ increased by 10% margin.							

3.2 Hazardous Air Pollutant Emissions

Emissions of hazardous air pollutants (HAPs) were calculated to confirm that the Facility will not be a new major HAP source subject to preconstruction permitting under 40 CFR 63 Subpart B. HAP emissions (with the exception of formaldehyde) were derived from the April 2000 version of AP-42 Section 3.1 which provides emission factors for stationary combustion turbines. An emission factor for

formaldehyde was developed from a subset of the database used by EPA to develop the AP-42 emission factors (see Appendix B for details).

Annual HAP emissions are presented in Table 3-3. Total facility-wide emissions for all HAPs combined is 2.7 TPY with the largest single HAP being less than 1.1 TPY. Both of these values are well below the 25/10 tpy major source thresholds for HAPs.

Table 3-3 HAP Emission Summary, Medley Electric Generating Facility

Pollutant	CTG Natural Gas		CTG Distillate Oil		Facility	
	Emission Rate, Per Turbine		Emission Rate, Per Turbine		Emission Rate All CTGs	
	Max Hourly (lb/hr)	Annual (tpy)	Max Hourly (lb/hr)	Annual (tpy)	Max Hourly (lb/hr)	Annual (tpy)
1,3-Butadiene	2.01E-04	1.56E-04	7.20E-03	4.45E-03	4.32E-02	2.67E-02
Acetaldehyde	1.87E-02	1.45E-02	0.00E+00	0.00E+00	1.12E-01	8.70E-02
Acrolein	3.00E-03	2.32E-03	0.00E+00	0.00E+00	1.80E-02	1.39E-02
Benzene ^(a)	6.07E-03	4.70E-03	2.48E-02	1.53E-02	1.49E-01	9.17E-02
Ethylbenzene	1.50E-02	1.16E-02	0.00E+00	0.00E+00	9.00E-02	6.96E-02
Formaldehyde ^(b)	5.93E-02	4.59E-02	1.26E-01	7.78E-02	7.56E-01	4.67E-01
Naphthalene	6.09E-04	4.71E-04	1.58E-02	9.72E-03	9.45E-02	5.83E-02
PAHs	1.03E-03	7.98E-04	1.80E-02	1.11E-02	1.08E-01	6.67E-02
Propylene Oxide	1.36E-02	1.05E-02	0.00E+00	0.00E+00	8.15E-02	6.31E-02
Toluene ^(a)	3.18E-02	2.46E-02	0.00E+00	0.00E+00	1.91E-01	1.48E-01
Xylene	3.00E-02	2.32E-02	0.00E+00	0.00E+00	1.80E-01	1.39E-01
Arsenic	0.00E+00	0.00E+00	4.95E-03	3.06E-03	2.97E-02	1.83E-02
Beryllium	0.00E+00	0.00E+00	1.40E-04	8.61E-05	8.37E-04	5.17E-04
Cadmium	0.00E+00	0.00E+00	2.16E-03	1.33E-03	1.30E-02	8.00E-03
Chromium	0.00E+00	0.00E+00	4.95E-03	3.06E-03	2.97E-02	1.83E-02
Lead	0.00E+00	0.00E+00	6.30E-03	3.89E-03	3.78E-02	2.33E-02
Manganese	0.00E+00	0.00E+00	3.56E-01	2.19E-01	2.13E+00	1.32E+00
Mercury	0.00E+00	0.00E+00	5.40E-04	3.33E-04	3.24E-03	2.00E-03
Nickel	0.00E+00	0.00E+00	2.07E-03	1.28E-03	1.24E-02	7.67E-03
Selenium	0.00E+00	0.00E+00	1.13E-02	6.95E-03	6.75E-02	4.17E-02
Facility Total HAPs						2.7
Maximum Individual HAP						1.3

Proposed emission limits for the combustion turbines during natural gas and distillate oil operation are presented in Tables 3-4 and 3-5, respectively. Annual limits for VOCs, SO₂, PM₁₀, and Pb are not proposed to be included in the permit. This is because compliance with a 248 ton/year limit for NO_x

and CO will insure that these other pollutants are emitted in quantities considerably lower than the 250 ton/year major source threshold.

Table 3-4 Summary of Proposed Permit Limits for Combustion Turbine, Natural Gas Operation

	ppmvd @ 15% O ₂	Lb/hr ¹ Each Turbine	CTG Annual Tons/Yr	Control Technology	Test Method
NO _x	25	47.1	245.5	Water Injection	Stack Test Ref. Method 19 & 20
CO	56	64.2	247.2	Good Combustion Practices	Stack Test Ref. Method 10 & 19
VOC	10	7.3		Good Combustion Practices	Stack Test Ref. Method 25a less Methane via bag sample & Method 18
SO ₂	N/A	2.8		Low Sulfur Fuel (less than 2.0 grain S/100 SCF gas)	Fuel Monitoring
PM ₁₀	N/A	5.0		Low Sulfur and Ash Fuel (less than 2.0 grain S/100 SCF gas)	Stack Test Ref. Method 5 & 202
¹lb/hr for each turbine is based on 100% load at 42°F and includes a margin of 10% representing maximum potential to emit					

Table 3-5 Summary of Proposed Permit Limits for Combustion Turbine, Distillate Oil Operation

	Ppmvd @ 15% O ₂	Lb/hr ¹ Each Turbine	CTG Annual Tons/Yr	Control Technology	Test Method
NO _x	42	79.9	245.5	Water Injection	Stack Test Ref. Method 19 & 20
CO	56	64.9	247.2	Good Combustion Practices	Stack Test Ref. Method 10 & 19
VOC	10	6.6		Good Combustion Practices	Stack Test Ref. Method 25a less Methane via bag sample & Method 18
SO ₂	N/A	25		Low Sulfur Fuel	Fuel Monitoring
Pb	N/A	<0.01		Low Ash Fuel	N/A
PM ₁₀	N/A	22		Low Sulfur and Ash Fuel	Stack Test Ref. Method 5 & 202
¹lb/hr for each turbine is based on 100% load at 42°F and includes a margin of 10% representing maximum potential to emit					

4.0 REFERENCES

Pequot Publishing, 1997. Gas Turbine World 1997 Handbook.

Rasnic, John B., August 1987. Letter to Air Compliance Branch Chiefs, Regions I-IX, RC: NSPS Custom Fuel Monitoring.

U.S. EPA. September 1977. Standards Support and Environmental Impact Statement - Volume I: Proposed Standards of Performance for Stationary Gas Turbines. EPA 450/2-77-017a.

U.S. EPA. October 1990. New Source Review Workshop Manual. Draft.

U.S. EPA. October 1996. AP-42.

APPENDIX A

**APPLICATION FOR AIR PERMIT – TITLE V SOURCE
DEP FORM NO. 62-210.900(1)**

Purpose of Application

Air Operation Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: _____

- Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: _____

Operation permit number to be revised: _____

- Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)

Operation permit number to be revised/corrected: _____

- Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit number to be revised: _____

Reason for revision: _____

Air Construction Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- Air construction permit to construct or modify one or more emissions units.
- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- Air construction permit for one or more existing, but unpermitted, emissions units.

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official: Janet Dietrich – Managing Director
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: Challenger Development Company, L.L.C. Street Address: 1400 Smith Street City: Houston State: TX Zip Code: 77002-7631
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (713) 853-4836 Fax: (713) 646-3239
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative*(check here [], if so) or the responsible official (check here [], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i> Signature: <u>Janet R. Dietrich</u> Date: <u>7-18-00</u>

* Attach letter of authorization if not currently on file.

Professional Engineer Certification

1. Professional Engineer Name: Blair Burgess Registration Number: 45460
2. Professional Engineer Mailing Address: Organization/Firm: ENSR Street Address: 2809 West Mall Drive City: Florence State: AL Zip Code: 35630
3. Professional Engineer Telephone Numbers: Telephone: (256) 767-1210 Fax: (256) 767-1211

4. Professional Engineer Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

7/12/00
No. 00000000
STATE OF FLORIDA

Signature

(seal)

EMBOSSSED METALLIC

Date

7/12/00

* Attach any exception to certification statement.

Scope of Application

Emissions Unit ID	Description of Emissions Unit	Permit Type	Processing Fee
CT001 – CT06	LM6000 Simple Cycle Combustion Turbines (Six identical combustion turbines)	AC1B	\$5,000 Similar emissions unit fee per Rule 62-4.050(4)(a)(4)
T001 – T002	Distillate Fuel Oil Storage Tanks	AC1E	\$250
FWP	Firewater Pump Diesel Engine	AC1F	\$250
NGH	Natural Gas Fuel Heater	ACIF	\$250

Application Processing Fee

Check one: Attached - Amount: \$5,750 Not Applicable

Construction/Modification Information

1. Description of Proposed Project or Alterations

Challenger Development Company, L.L.C. proposes to construct and operate a peaking electrical power generating facility at a greenfield site in Dade County, Florida. The facility will consist of up to six (6) GE LM6000 combustion turbines operating in simple cycle mode; each turbine has a nominal generating capacity of 48 MW. The combustion turbines will be fired primarily with natural gas with low sulfur distillate oil as a backup fuel. NO_x emissions will be controlled with water injection. Permit conditions will limit total facility annual emissions to less than 248 tons per year of any regulated air pollutant in order to be permitted as a synthetic minor source with respect to Rule 62-212.400, Prevention of Significant Deterioration. Ancillary equipment includes one 1.5 million gallon distillate oil storage tank, one 300,000 gallon distillate oil storage tank, one natural gas fuel heater and one emergency diesel fired IC engine driving a firewater pump.

2. Projected or Actual Date of Commencement of Construction:

December 1, 2000

3. Projected Date of Completion of Construction:

June 1, 2001

Application Comment

B. FACILITY POLLUTANTS

List of Pollutants Emitted

1. Pollutant Emitted	2. Pollutant Classif.	3. Requested Emissions Cap		4. Basis for Emissions Cap	5. Pollutant Comment
		lb/hour	tons/year		
NOX	A, SM (PSD/248 tpy)		248	ESCPSD	Units CT001-CT06, FWP + NGH included under NO _x cap.
CO	A, SM (PSD/248 tpy)		248	ESCPSD	Units CT001-CT06, FWP + NGH included under CO cap.
SO2	B				CT SO ₂ emissions and fuel sulfur content regulated under 40 CFR 60, Subpart GG
VOC	B				Unit T001 subject to record keeping requirements of 40 CFR 60, Subpart Kb

Additional Supplemental Requirements for Title V Air Operation Permit Applications

8. List of Proposed Insignificant Activities: <input checked="" type="checkbox"/> Attached, Document ID: Section 2 <input type="checkbox"/> Not Applicable
9. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input checked="" type="checkbox"/> Not Applicable
10. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Risk Management Plan Verification: <input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID: _____) or previously submitted to DEP (Date and DEP Office: _____) <input type="checkbox"/> Plan to be submitted to CEPPO (Date required: _____) <input checked="" type="checkbox"/> Not Applicable
14. Compliance Report and Plan: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Compliance Certification (Hard-copy Required): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)**

Emissions Unit Description and Status

<p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p>			
<p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>			
<p>3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): CT001 through CT06 are identical LM6000 simple cycle combustion turbines (CT) each having a nominal rating 48 megawatts (MW). Each CT will be fired primarily with natural gas with low sulfur distillate oil as a back up fuel.</p>			
<p>4. Emissions Unit Identification Number: ID: CT001 – CT06 Unknown</p>		<p><input checked="" type="checkbox"/> No ID <input type="checkbox"/> ID</p>	
<p>5. Emissions Unit Status Code: C</p>	<p>6. Initial Startup Date: June 2001</p>	<p>7. Emissions Unit Major Group SIC Code: 49</p>	<p>8. Acid Rain Unit? <input checked="" type="checkbox"/></p>
<p>9. Emissions Unit Comment: (Limit to 500 Characters) Each combustion turbine (CT001 to CT06) should be considered separate emissions units. The grouping of all turbines into one Emissions Unit Information Section has been done for administrative convenience since the information required in Subsections A through J is identical for each combustion turbine.</p>			

Emissions Unit Information Section 1 of 2

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

Each turbine will be equipped with water-injected combustors to control NO_x formation.

2. Control Device or Method Code(s): **028**

Emissions Unit Details

1. Package Unit:	
Manufacturer: General Electric	Model Number: LM6000 PC Sprint
2. Generator Nameplate Rating:	48 MW (nominal)
3. Incinerator Information: N/A	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

**B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**

Emissions Unit Operating Capacity and Schedule

1. Maximum Heat Input Rate: 469 mmBtu/hr HHV (base load on natural gas @ 42°F)
2. Maximum Incineration Rate: N/A lb/hr N/A tons/day
3. Maximum Process or Throughput Rate: N/A
4. Maximum Production Rate: N/A
5. Requested Maximum Operating Schedule:
24 hours/day 7 days/week
52 weeks/year 8760¹ hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):
 1 – Annual operations will be limited through the use of a Continuous Emissions Monitoring System for NO_x and CO.

Emissions Unit Information Section 1 of 2

**D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram? CT1 through CT6		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): Exhaust stacks for combustion turbines; one stack per turbine unit.			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: N/A			
5. Discharge Type Code: V	6. Stack Height: 45 feet	7. Exit Diameter: 10 feet	
8. Exit Temperature: 842°F (NG) 845°F (Oil)	9. Actual Volumetric Flow Rate: 602,800 acfm (NG) 594,500 acfm (Oil)	10. Water Vapor: 10.25 % (NG) 8.3 % (Oil)	
11. Maximum Dry Standard Flow Rate: 219,397 dscfm (NG) 215,878 dscfm (Oil)		12. Nonstack Emission Point Height: N/A feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): * North (km): *			
14. Emission Point Comment (limit to 200 characters): Exhaust temperatures and flow rates are at 100% load and 42° F operating conditions. Stack temperatures and flow rates will vary with load and ambient temperature. * For UTM coordinates of combustion turbine stacks, please see Attachment A.			

Emissions Unit Information Section 1 of 2

**E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)**

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Natural gas		
1. Source Classification Code (SCC): 2-01-002-01		3. SCC Units: Million Cubic Feet Burned
6. Maximum Hourly Rate: 0.4479	7. Maximum Annual Rate: 5163.89	6. Estimated Annual Activity Factor: N/A
7. Maximum % Sulfur: 2 grains/100 SCF	8. Maximum % Ash: N/A	9. Million Btu per SCC Unit: 1047
10. Segment Comment (limit to 200 characters): Annual operation will be restricted through the use of NOx and CO CEMS. Maximum Annual Rate is an estimate only.		

Segment Description and Rate: Segment 2 of 2

2. Segment Description (Process/Fuel Type) (limit to 500 characters): No. 2 Distillate Fuel Oil		
3. Source Classification Code (SCC): 2-01-001-0		3. SCC Units: Thousand Gallons Burned
4. Maximum Hourly Rate: 3.12	5. Maximum Annual Rate: 23120	6. Estimated Annual Activity Factor: N/A
7. Maximum % Sulfur: 0.05	8. Maximum % Ash: Trace	9. Million Btu per SCC Unit: 144.5
10. Segment Comment (limit to 200 characters): Annual operation will be restricted through the use of NOx and CO CEMS. Maximum Annual Rate is an estimate only.		

Emissions Unit Information Section 1 of 2

Pollutant Detail Information Page 1 of 6

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: NOX	2. Total Percent Efficiency of Control:
3. Potential Emissions: 79.9 lb/hour (per turbine) 246 tons/year (total six turbines)	4. Synthetically Limited? [<input checked="" type="checkbox"/>]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 0.162 lb/MMBtu (HHV) Reference: See Appendix B for emissions calculations	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil. Hourly emission rate includes a 10% margin. Annual NOx emissions will be restricted through the use of CEMS.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: ESCPSD	2. Future Effective Date of Allowable Emissions: N/A
3. Requested Allowable Emissions and Units: 246 tons/yr (CT1 –CT6)	4. Equivalent Allowable Emissions: N/A lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): Direct emissions monitoring of stack emissions using Part 75-certified CEMs	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	

Emissions Unit Information Section 1 of 2

Pollutant Detail Information Page 2 of 6

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: CO		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 64.9 lb/hour (per turbine) 247.2 tons/year (total six turbines)		4. Synthetically Limited? <input checked="" type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: 0.131 lb/MMBtu (HHV) Reference: See Appendix B for emission calculations		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate is based on worst case emissions for both natural gas and distillate oil. Hourly emission rate includes a 10% margin. Annual CO emissions will be restricted through the use of CEMS.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: ESCPSD		2. Future Effective Date of Allowable Emissions: N/A	
3. Requested Allowable Emissions and Units: 248 tons/yr (CT1 – CT6)		4. Equivalent Allowable Emissions: N/A lb/hour N/A tons/year	
5. Method of Compliance (limit to 60 characters): Direct emissions monitoring of stack emissions using certified continuous emissions monitors on each turbine stack			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: PM	2. Total Percent Efficiency of Control:
3. Potential Emissions: 22.0 lb/hour(per turbine) 125.07 tons/year (total six turbines)	4. Synthetically Limited? <input checked="" type="checkbox"/>
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 0.034 lb/MMBtu (HHV) Reference: See Appendix B for emissions calculations	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil. Hourly emission rate includes a 10% margin.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions _____ of _____ N/A

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance (limit to 60 characters):	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: PM10		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 22.0 lb/hour (per turbine) 125.07 tons/year (total six turbines)		4. Synthetically Limited? <input checked="" type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: 0.034 lb/MMBtu (HHV) Reference: See Appendix B for emissions calculations		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil. Hourly emission rate includes a 10% margin.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions _____ of _____ N/A

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

Emissions Unit Information Section 1 of 2

Pollutant Detail Information Page 5 of 6

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: SO2	2. Total Percent Efficiency of Control:
3. Potential Emissions: 25 lb/hour (per turbine) 85.03 tons/year (total six turbines)	4. Synthetically Limited? [<input checked="" type="checkbox"/>]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 0.051 lb/MMBtu (HHV) Reference: See Appendix B for emissions calculations	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil. Hourly emission rate includes a 10% margin.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions _____ of _____ N/A

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance (limit to 60 characters):	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: VOC	2. Total Percent Efficiency of Control:
3. Potential Emissions: 7.3 lb/hour (per turbine) 41.6 tons/year (total six turbines)	4. Synthetically Limited? <input checked="" type="checkbox"/>
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 0.014 lb/MMBtu (HHV) Reference: See Appendix B for emissions calculations	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil. Hourly emission rate includes a 10% margin.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions _____ of _____ N/A

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance (limit to 60 characters):	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**

Supplemental Requirements

1. Process Flow Diagram <input checked="" type="checkbox"/> Attached, Document ID: Fig. 2-2 <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input checked="" type="checkbox"/> Attached, Document ID: App. B <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input checked="" type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input checked="" type="checkbox"/> Attached, Document ID: ENSR Doc. No. 6792-123-710
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:

Emissions Unit Information Section 1 of 2

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

III. TANK EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)**

Emissions Unit Description and Status

<p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p>			
<p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>			
<p>3. Description of Emissions Unit Addressed in This Section (limit to 60 characters):</p> <p>Distillate fuel oil storage tanks</p>			
<p>4. Emissions Unit Identification Number:</p> <p>ID: T001, T002</p>		<p><input checked="" type="checkbox"/> No ID</p> <p><input type="checkbox"/> ID Unknown</p>	
<p>5. Emissions Unit Status Code:</p> <p>C</p>	<p>6. Initial Startup Date:</p> <p>June 2001</p>	<p>7. Emissions Unit Major Group SIC Code:</p> <p>49</p>	<p>8. Acid Rain Unit?</p> <p><input type="checkbox"/></p>
<p>9. Emissions Unit Comment: (Limit to 500 Characters)</p> <p>T001 - main storage tank</p> <p>T002 - day storage tank.</p>			

Emissions Unit Information Section 2 of 2

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

None

2. Control Device or Method Code(s):

Emissions Unit Details

1. Package Unit:

Manufacturer:

Model Number:

2. Generator Nameplate Rating:

MW

3. Incinerator Information:

Dwell Temperature:

°F

Dwell Time:

seconds

Incinerator Afterburner Temperature:

°F

Emissions Unit Information Section 2 of 2

**D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram? T001 + T002		2. Emission Point Type Code: 4	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): N/A			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: N/A			
5. Discharge Type Code: V	6. Stack Height: N/A feet	7. Exit Diameter: N/A feet	
8. Exit Temperature: N/A	9. Actual Volumetric Flow Rate: N/A	10. Water Vapor: N/A	
11. Maximum Dry Standard Flow Rate: N/A dscfm		12. Nonstack Emission Point Height: N/A feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): * North (km): *			
14. Emission Point Comment (limit to 200 characters): * For UTM coordinates of Distillate oil tanks, please see Attachment A.			

Emissions Unit Information Section 2 of 2

**E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)**

Segment Description and Rate: Segment 1 of 1

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Distillate fuel oil storage tanks		
2. Source Classification Code (SCC): 40301021		3. SCC Units: Thousand Gallons Throughput
4. Maximum Hourly Rate: N/A	5. Maximum Annual Rate: 24,300,000	6. Estimated Annual Activity Factor: N/A
7. Maximum % Sulfur: N/A	8. Maximum % Ash: N/A	9. Million Btu per SCC Unit: N/A
10. Segment Comment (limit to 200 characters):		

Segment Description and Rate: Segment ___ of ___

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: VOC		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour tons/year		4. Synthetically Limited? <input type="checkbox"/> <input type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Potential VOC emissions from distillate fuel oil storage tanks are less than 5 tons per year (less than the threshold amount for reporting in this subsection). See Appendix B for emission calculations.			

Allowable Emissions Allowable Emissions 1 of 1 N/A

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**

Supplemental Requirements N/A

1. Process Flow Diagram <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input type="checkbox"/> Attached, Document ID: _____
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:

Emissions Unit Information Section 2 of 2

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

ATTACHMENT A

UTM COORDINATES

<u>Emission Source/ID Number</u>	<u>UTM Easting(km)</u>	<u>UTM Northing(km)</u>
Combustion Turbines CT1-CT6	564.773	2860.702
	564.796	2860.702
	564.819	2860.702
	564.842	2860.702
	564.865	2860.702
	564.888	2860.702
Distillate Oil Storage Tanks T001 and T002	564.674	2860.784
	564.715	2860.780

APPENDIX B
EMISSION CALCULATIONS

ENSR
 Challenger Development Company, L.L.C.
 Medley Facility
 GE LM 6000 SPRINT Simple Cycle Emissions
 EMISSIONS COMPUTATION PER SINGLE CTG
 GAS Fired CTG

Date 7/5/00
 Author MDK Griffin
 Revision 2

CASE NUMBER and OPERATION CONDITIONS

- (1) AMBIENT TEMPERATURE, °F
- (1) RELATIVE HUMIDITY, %
- CTG LOAD
- SPRINT STATUS
- CHILLER STATUS
- (1) CTG EFFECTIVE INLET TEMPERATURE, F
- (1) CTG EFFECTIVE INLET RELATIVE HUMIDITY, %
- (1) CTG GROSS POWER OUTPUT, kW
- (1) CTG FUEL CONSUMPTION, MMBtu/hr LHV
- (1) CTG FUEL CONSUMPTION, lb/hr
- CTG FUEL CONSUMPTION, MMBtu/hr HHV
- (1) CTG EXHAUST GAS FLOW RATE, 1000 lb/hr
- (1) STACK TEMPERATURE, °F

CTG STACK EXHAUST ANALYSIS (%VOL)

- (1) ARGON + NITROGEN
- (1) OXYGEN
- (1) CARBON DIOXIDE
- (1) WATER
- TOTAL
- CTG EXHAUST MOLECULAR WEIGHT
- CTG EXHAUST GAS FLOW RATE, lb mol/hr
- CTG EXHAUST GAS FLOW RATE, DRY, lb mol/hr

EXH. PARAMETERS @ STACK

- (5) STACK DIAMETER, ft
- MOLECULAR WEIGHT
- STACK EXHAUST GAS FLOW RATE, lb/hr
- SPECIFIC VOLUME, ft³/lb
- VOLUMETRIC FLOW, acfm
- EXIT VELOCITY, ft/sec
- ACTUAL O₂% DRY
- MOLES EXHAUST GAS per HOUR WET
- MOLES EXHAUST GAS per HOUR DRY

NOx EMISSION CALCULATION

- (1) LIMIT, ppmVd @ 15% O₂
- LIMIT, ppmVd
- CORRESPONDING MASS RATE, lb/hr as NO₂
- CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV

CO EMISSION CALCULATION

- (6) LIMIT, ppmVd @ 15% O₂
- CTG Exhaust, ppmVd
- CTG MASS RATE, lb/hr
- CTG EMISSIONS FACTOR, lb/MMBtu HHV

PARTICULATE EMISSION CALCULATION

- (2) CTG EXHAUST, lb/hr
- CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV

VOC EMISSION CALCULATION

- (3) LIMIT, ppmVd @ 15% O₂
- CTG Exhaust, ppmVw
- CTG MASS RATE, lb/hr
- CTG EMISSIONS FACTOR, lb/MMBtu HHV

Pb EMISSION CALCULATION

- Pb EMISSION FACTOR, lb/MMBtu
- STACK EMISSIONS, lb/hr

SO₂ EMISSION CALCULATION

- (4) CTG EMISSIONS, lb/hr
- CTG EMISSIONS FACTOR, lb/MMBtu HHV
- STACK EMISSIONS, ppmVd @ ACTUAL O₂
- STACK EMISSIONS, ppmVd @ 15% O₂

	1	2	3	4	5	6
(1) AMBIENT TEMPERATURE, °F	60	62	60	60	60	62
(1) RELATIVE HUMIDITY, %	65%	72%	65%	72%	65%	72%
CTG LOAD	100%	100%	70%	25%	60%	50%
SPRINT STATUS	ON	ON	OFF	OFF	OFF	OFF
CHILLER STATUS	ON	OFF	ON	OFF	OFF	OFF
(1) CTG EFFECTIVE INLET TEMPERATURE, F	50	42	75	42	60	42
(1) CTG EFFECTIVE INLET RELATIVE HUMIDITY, %	68%	72%	70%	72%	66%	72%
(1) CTG GROSS POWER OUTPUT, kW	48,097	48,044	38,153	30,890	24,027	24,822
(1) CTG FUEL CONSUMPTION, MMBtu/hr LHV	416	423	330	329	251	249
(1) CTG FUEL CONSUMPTION, lb/hr	21,919	22,282	17,347	17,316	13,195	13,111
CTG FUEL CONSUMPTION, MMBtu/hr HHV	461	469	365	364	277	276
(1) CTG EXHAUST GAS FLOW RATE, 1000 lb/hr	1,065	1,072	827	631	785	860
(1) STACK TEMPERATURE, °F	447	442	420	450	410	403
(1) ARGON + NITROGEN	28.154	73.23%	73.49%	72.65%	74.48%	73.27%
(1) OXYGEN	31.998	12.02%	12.69%	13.51%	14.22%	14.20%
(1) CARBON DIOXIDE	44.000	13.38%	13.66%	13.02%	12.87%	12.71%
(1) WATER	18.015	10.58%	10.25%	10.84%	10.43%	10.80%
TOTAL	100.10%	100.09%	100.00%	99.99%	100.00%	100.00%
CTG EXHAUST MOLECULAR WEIGHT	28.14	28.17	28.07	28.30	28.14	28.42
CTG EXHAUST GAS FLOW RATE, lb mol/hr	37,497	38,042	33,035	34,852	27,905	30,275
CTG EXHAUST GAS FLOW RATE, DRY, lb mol/hr	33,528	34,141	29,519	31,730	25,170	28,148
(5) STACK DIAMETER, ft	28.14	28.17	28.07	28.30	28.14	28.42
MOLECULAR WEIGHT	28.14	28.17	28.07	28.30	28.14	28.42
STACK EXHAUST GAS FLOW RATE, lb/hr	1,055,075	1,071,756	927,360	880,840	785,160	860,400
SPECIFIC VOLUME, ft ³ /lb	33.9	33.7	33.4	31.4	32.9	29.9
VOLUMETRIC FLOW, acfm	596,093	602,782	516,881	512,663	431,177	428,379
EXIT VELOCITY, ft/sec	126.49	127.91	109.89	108.79	91.50	80.80
ACTUAL O ₂ % DRY	14.5%	14.5%	15.1%	15.5%	15.7%	15.3%
MOLES EXHAUST GAS per HOUR WET	37,497	38,042	33,035	34,852	27,905	30,275
MOLES EXHAUST GAS per HOUR DRY	33,528	34,141	29,519	31,730	25,170	28,148
(1) LIMIT, ppmVd @ 15% O ₂	25.0	25.0	25.0	25.0	25.0	25.0
LIMIT, ppmVd	27.3	27.2	24.5	22.7	21.8	19.4
CORRESPONDING MASS RATE, lb/hr as NO ₂	42.1	42.8	33.3	33.2	25.3	25.1
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV	0.091	0.091	0.091	0.091	0.091	0.091
(6) LIMIT, ppmVd @ 15% O ₂	60	60	60	60	60	60
CTG Exhaust, ppmVd	61.2	61.0	54.9	50.8	48.9	43.4
CTG MASS RATE, lb/hr	57.5	58.3	45.4	45.3	34.5	34.2
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.125	0.125	0.124	0.124	0.124	0.124
(2) CTG EXHAUST, lb/hr	0.010	0.010	0.012	0.012	0.016	0.016
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV	0.010	0.010	0.012	0.012	0.016	0.016
(3) LIMIT, ppmVd @ 15% O ₂	10.0	10.0	10.0	10.0	10.0	10.0
CTG Exhaust, ppmVw	10.9	10.9	9.8	9.1	8.7	7.8
CTG MASS RATE, lb/hr	6.6	6.8	5.2	5.1	3.8	3.8
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.014	0.014	0.014	0.014	0.014	0.014
Pb EMISSION FACTOR, lb/MMBtu	0.0	0.0	0.0	0.0	0.0	0.0
STACK EMISSIONS, lb/hr	0.0	0.0	0.0	0.0	0.0	0.0
(4) CTG EMISSIONS, lb/hr	2.513	2.555	1.989	1.985	1.513	1.503
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.005	0.005	0.005	0.005	0.005	0.005
STACK EMISSIONS, ppmVd @ ACTUAL O ₂	1.170	1.188	1.052	0.977	0.938	0.834
STACK EMISSIONS, ppmVd @ 15% O ₂	1.071	1.072	1.073	1.074	1.074	1.075

SITE CONDITIONS

- FUEL TYPE
- FUEL LHV, Btu/lb
- FUEL LHV, Btu/SCF
- FUEL HHV, Btu/SCF
- FUEL SULFUR CONTENT [grains per 100 SCF]

Natural Gas
19000
949
1047
162

CONTROL EQUIPMENT LIMITS

- NOx PERMIT LIMIT, ppmVd @ 15% O₂

25

Notes

- 1 Based on GE LM6000-PC SPRINT data provided in e-mail from Dave Kellermyer (e-mail dated May 12, 2000).
- 2 PM10 Emission rate based on data provided in e-mail from Dave Kellermyer April 19, 2000
- 3 VOC Emission limit based on data provided in e-mail from Dave Kellermyer April 19, 2000
- 4 SO₂ emissions calculated based on fuel sulfur content of 2 grains per 100 standard cubic feet.
- 5 Stack diameter based on conversation with Dave Kellermyer June 14, 2000
- 6 CO emissions limit based on guaranteed value.

Challenger Development Company, L.L.C.
Medley Facility
GE LM 6000 SPRINT Simple Cycle Emissions
EMISSIONS COMPUTATION PER SINGLE CTG
Oil Fired CTG

Author MDK Griffin
 Revision 2

CASE NUMBER and OPERATION CONDITIONS	1	2	3	4	5	6
(1) AMBIENT TEMPERATURE, °F	60.14	61.43	61.50	61.42	61.40	61.42
(1) RELATIVE HUMIDITY, %	60%	72%	63%	72%	61%	72%
CTG LOAD	100%	100%	70%	70%	60%	60%
SPRINT STATUS	ON	ON	OFF	OFF	OFF	OFF
CHILLER STATUS	YES	NO	YES	NO	NO	NO
(1) CTG EFFECTIVE INLET TEMPERATURE, F	50.0	50.0	50.0	50.0	50.0	50.0
(1) CTG EFFECTIVE INLET RELATIVE HUMIDITY, %	66%	72%	65%	72%	61%	72%
(1) CTG NET POWER OUTPUT, KW	923	17,877	30,430	28,097	23,440	23,858
(1) CTG FUEL CONSUMPTION, MMBtu/hr LHV	112	1,110	1,300	1,177	1,031	1,031
(1) CTG FUEL CONSUMPTION, lb/hr	37,401	37,777	42,523	37,786	34,133	34,133
CTG FUEL CONSUMPTION, MMBtu/hr HHV	443	450	354	351	269	267
(1) CTG EXHAUST GAS FLOW RATE, 1000 lb/hr	1,142	71,069	1,820	1,723	1,760	1,808
(1) STACK TEMPERATURE, °F	650	600	650	650	617	620
CTG STACK EXHAUST ANALYSIS (xVOL)						
(1) ARGON	10.0%	9.96%	10.08%	9.99%	10.07%	10.09%
(1) NITROGEN + ARGON	72.86%	72.15%	72.10%	72.09%	72.23%	72.72%
(1) OXYGEN	13.17%	13.24%	13.37%	13.34%	13.31%	13.20%
(1) CARBON DIOXIDE	2.43%	4.43%	4.02%	3.80%	3.62%	3.30%
(1) WATER	18.01%	18.20%	18.25%	18.65%	18.47%	18.79%
TOTAL	100.0%	100.07%	99.89%	99.99%	99.99%	99.99%
CTG EXHAUST MOLECULAR WEIGHT	28.52	28.50	28.30	28.61	28.42	28.68
CTG EXHAUST GAS FLOW RATE, lb mol/hr	36,879	37,426	32,428	33,981	27,440	29,851
CTG EXHAUST GAS FLOW RATE, DRY, lb mol/hr	33,693	34,320	29,397	31,653	25,115	26,125
ACTUAL O2% DRY FROM CTG	14.42%	14.44%	14.97%	15.45%	15.63%	16.23%
EXH. PARAMETERS @ STACK						
(5) STACK DIAMETER, ft	40	40	40	40	40	40
MOLECULAR WEIGHT	28.52	28.50	28.30	28.61	28.42	28.68
EXHAUST GAS FLOW RATE, lb/hr	1,051,723	1,058,677	919,800	872,360	779,760	858,090
SPECIFIC VOLUME, ft ³ /lb	33.5	33.4	33.4	31.2	32.8	29.7
VOLUMETRIC FLOW, acfm	587,685	594,458	512,127	506,639	426,334	424,201
EXIT VELOCITY, ft/sec	124.71	126.15	108.68	107.30	90.47	90.02
ACTUAL O2% DRY	14.4%	14.4%	15.0%	15.5%	15.6%	16.2%
MOLES EXHAUST GAS per HOUR WET	36,879	37,426	32,428	33,981	27,440	29,851
MOLES EXHAUST GAS per HOUR DRY	33,693	34,320	29,397	31,653	25,115	26,125
NOx EMISSION CALCULATION						
(1) CTG, ppmVd @ 15% O2	46.1	46.0	42.2	38.8	37.5	33.2
CTG, ppmVd	71.5	72.8	57.1	56.5	43.3	43.0
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV	0.1615	0.1613	0.1611	0.1610	0.1608	0.1608
CO EMISSION CALCULATION						
(8) CTG, ppmVd @ 15% O2	61.5	61.3	56.3	51.7	50.0	44.3
CTG Exhaust, ppmVd	58	58	46	46	35	35
CTG MASS RATE, lb/hr	0.1311	0.1310	0.1308	0.1307	0.1307	0.1305
CTG EMISSIONS FACTOR, lb/MMBtu HHV						
PARTICULATE EMISSION CALCULATION						
(2) CTG EXHAUST, lb/hr	0.0452	0.0444	0.0365	0.0370	0.0243	0.0248
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV						
VOC EMISSION CALCULATION						
(3) VOC CTG, ppmVd @ 15% O2	11.0	11.0	10.0	9.2	8.9	7.9
VOC CTG, ppmVd	10.0	10.0	9.1	8.6	8.2	7.4
CTG Exhaust, ppmVd	5.9	6.0	4.7	4.7	3.6	3.6
CTG MASS RATE, lb/hr	0.0134	0.0134	0.0134	0.0134	0.0134	0.0133
CTG EMISSIONS FACTOR, lb/MMBtu HHV						
Pb EMISSION CALCULATION						
Pb EMISSION FACTOR - OIL, lb/MMBtu	0.000014	0.000014	0.000014	0.000014	0.000014	0.000014
STACK EMISSIONS, lb/hr	0.006	0.006	0.005	0.005	0.004	0.004
SO2 EMISSION CALCULATION						
(4) CTG EMISSIONS, lb/hr	22.378	22.754	17.905	17.736	13.606	13.509
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV	0.0505	0.0505	0.0505	0.0505	0.0505	0.0506

SITE CONDITIONS
 FUEL TYPE
 FUEL LHV, Btu/lb
 FUEL HHV, Btu/lb
 FUEL LHV, Btu/SCF
 FUEL HHV, Btu/SCF
 FUEL SULFUR CONTENT (grains per 100 SCF)
 FUEL SULFUR CONTENT (wt%)

Natural Gas	Distillate Oil
131,460 Btu/lb	18,400 Btu/lb
131,460 Btu/lb	19,700 Btu/lb
1,027 Btu/SCF	1,027 Btu/SCF
1.027	1.027
0.005	0.005

CONTROL EQUIPMENT LIMITS
 NOx PERMIT LIMIT, ppmVd @ 15% O2
 Lead Emission Factor for Oil AP-42 D400 - Section 3.1
 Emission Factor, lb/MMBtu

0.0505

1.40E-05

- Notes**
- 1 Based on GE LM6000-PC SPRINT data provided in e-mail from Dave Kellermeyer (e-mail dated May 12, 2000).
 - 2 PM10 emission rate assumed to be double the natural gas PM10 emission rate.
 - 3 VOC Emission limit based on data provided in e-mail from Dave Kellermeyer April 19, 2000
 - 4 SO2 emissions calculated based on fuel sulfur content of 0.05 wt %.
 - 5 Stack diameter based on conversation with Dave Kellermeyer June 14, 2000
 - 6 CO emissions limit based on guaranteed value.

CALCULATIONS AND COMPUTATIONS

Project: Challenger Development Company L.L.C., Medley Facility
 Project Number: 6792-123-710 Computed by: C. Godleski Date: 6/15/00
 Subject: Natural Gas Heater - Emission Calculations Checked by: B. Burgess Date: 6/28/00

Emission Source:	Natural Gas Heater
Heat Input (MMBtu/hr):	6
Number of Units:	1
Sulfur Content of Fuel (grains/scf):	0.02
Fuel Heating Value, HHV (Btu/scf):	1047
LHV (Btu/scf):	946
Operating Hours per Year:	1500
Fuel Feed Rate (scf/HR):	5731

Compound	Emission Factor (a) (Lbs/MMBtu)	Emission Rate - per Unit	
		Hourly (b) (Lbs/Hr)	Annual (c) (Tons/Year)
Nitrogen Oxides	0.102	0.612	0.459
Carbon Monoxide	0.09	0.54	0.405
Volatile Organic Carbon	0.06	0.36	0.27
Sulfur Oxides (d)	0.003	0.016	0.012
Particulate	0.01	0.06	0.045

Notes:

- (a) Emission Factors based on the information supplied by ENRON on 8/11/99.
- (b) Hourly Emission Rate (Lbs/Hr) = (Heat Input * Emission Factor)
- (c) Annual Emission Rate (Tons/Yr) = (Hourly Emission Rate, Lbs/Hr) *
(Hour of Operation Per Year, Hr/Yr) / (2,000 Lbs/Ton)
- (d) Sulfur Oxides Emission Rate (Lbs/Hr) based on the sulfur content of the fuel.

CALCULATIONS AND COMPUTATIONS

Project: Challenger Development Company, L.L.C., Medley Facility

Project Number: 6792-123-710

Computed by: M. Griffin

Date: 5/30/00

Subject: Fire-Water Pump Emission Calculations

Checked by: B. Burgess

Date: 6/28/00

Emission Source: Fire-Water Pump Engine

Source Type: Diesel Fueled Reciprocating Engine
250 Horsepower

Operating Hours per Year: 500

Compound	Emission Factor (a)		Emission Rate	
	(Lbs/hp hr)	(lb/MMBtu)	Hourly (b) (Lbs/Hr)	Annual (c) (Tons/Year)
Nitrogen Oxides	0.031		7.8	2.0
Carbon Monoxide	0.00668		1.7	0.4
Volatile Organic Carbon	0.00247		0.6	0.2
Sulfur Oxides	0.00205		0.5	0.1
Particulate	0.0022		0.6	0.2
Benzene	6.53E-06	9.33E-04	1.63E-03	4.08E-04
Toluene	2.86E-06	4.09E-04	7.16E-04	1.79E-04
Xylenes	2.00E-06	2.85E-04	4.99E-04	1.25E-04
Propylene	1.81E-05	2.58E-03	4.52E-03	1.13E-03
1,3-Butadiene	2.74E-07	3.91E-05	6.84E-05	1.71E-05
Formaldehyde	8.26E-06	1.18E-03	2.07E-03	5.16E-04
Acetaldehyde	5.37E-06	7.67E-04	1.34E-03	3.36E-04
Acrolein	6.48E-07	9.25E-05	1.62E-04	4.05E-05
PAH	1.18E-06	1.68E-04	2.94E-04	7.35E-05

Total HAPS 5.6 lb/year

Notes:

- (a) Emission Factors from AP-42, Section 3.3, Table 3.3-1
- (b) Hourly Emission Rate (Lbs/Hr) = (Emission Factor, Lbs/BHP) * (Horsepower, BHP)
- (c) Annual Emission Rate (Tons/Yr) = (Hourly Emission Rate, Lbs/Hr) *
(Hour of Operation Per Year, Hr/Yr) / (2,000 Lbs/Ton)

Annual Emissions Calculation
 Challenger Development Company, L.L.C., Medley Facility

Pollutant	CTG Natural Gas Short Term Emission Limits						CTG Distillate Oil Short Term Emission Limit			Fuel Use Calculation			Annual Emissions			
	Compliance Method			Maximum CTG Emissions for Minor Source ⁽²⁾	Natural Gas Annual Fuel Use ⁽⁴⁾	Distillate Oil Annual Fuel Use ⁽⁴⁾	Natural Gas Fired CTGs ⁽⁷⁾	Distillate Oil Fired CTGs ⁽⁷⁾	Worst Case CTG Emissions ⁽⁵⁾	Ancillary Equipment Emissions						
	ppmvd @ 15% O ₂	lb/MMBtu (HHV)	Max lb/hr ⁽¹⁾								ppmvd @ 15% O ₂	lb/MMBtu (HHV)	Max lb/hr ⁽¹⁾	(tpy)	(tpy)	(tpy)
NOx	25	0.091	47.1	42	0.162	79.9	CEMS	245.5	5,395,604	3,030,864	245.5	245.5	245.5	2.5		
CO	56	0.125	64.2	56	0.131	64.9	CEMS	247.2	3,955,200	3,774,046	247.2	198.5	247.2	0.8		
VOC	10	0.014	7.3	10	0.013	6.6	Fuel Tracking	218.6	31,228,571	33,630,769	37.8	19.7	41.58	1.4		
Pb	N/A	0	0	N/A	0.000014	0.007	Fuel Tracking	220	N/A	N/A	0	0.02	0.022	0.0		
PM10 ⁽³⁾	N/A	0.016	5	N/A	0.075	22	Fuel Tracking	219.8	27,475,000	5,861,333	43.2	113.7	125.07	0.2		
SO2	N/A	0.005	2.8	N/A	0.051	25	Fuel Tracking	219.9	87,960,000	8,623,529	13.5	77.3	85.03	0.1		
									Minimum Fuel Cap ⁽⁴⁾	3,955,200	3,030,864	Margin		10%		

Notes

- (1) Maximum hourly emission rate includes 10% margin.
- (2) CTG Emissions = Total Facility Emissions - Fire Water Pump Engine Emissions
- (3) PM10 emissions limited based on lb/hr emission rate, lb/MMBtu value calculated only for demonstration of compliance with Minor Source Status.
- (4) NOx and CO limited based on CEMS. Fuel cap calculated to estimate emissions of VOC, PM10, and SO2. Minimum Fuel Cap is used for all pollutants.
- (5) Worst Case of Natural Gas and Distillate Oil Case. VOC, PM10, and SO2 emissions include a margin of 10%.
- (6) [Annual Fuel Use (MMBtu/yr (HHV))] = [Maximum CTG Emissions (tons/year)] x [2,000 lb/ton] / [Emission Factor (lb/MMBtu (HHV))]
- (7) [CTG Annual Emissions (tons/year)] = [Minimum Fuel Cap (MMBtu/yr (HHV))] * [Emission Factor (lb/MMBtu (HHV))] / [2,000 lb/ton]

**Challenger Development Company, L.L.C., Medley Facility
NSPS NO_x Emission Standard Calculation**

Turbine General Electric Model LM 6000	
Fuel Natural Gas	
Nominal Maximum Electrical Capacity	48.0 MW
Maximum Energy Input	423 MMBtu/hr (LHV) 446,891,394 kJ/hr
Heat Rate	8,820 Btu/kWh 9.3 kJ/Wh
NSPS Subpart GG NO _x Limit	0.0116% Volume % NO _x @ 15% O ₂ 116 ppmvd @ 15% O ₂

Turbine General Electric Model LM 6000	
Fuel Distillate Oil	
Nominal Maximum Electrical Capacity	48 MW
Maximum Energy Input	419 MMBtu/hr (LHV) 442,404,310 kJ/hr
Heat Rate	8,754 Btu/kWh 9.2 kJ/Wh
NSPS Subpart GG NO _x Limit	0.0117% Volume % NO _x @ 15% O ₂ 117 ppmvd @ 15% O ₂

Calculations and Computations
HAP Emissions from Combined Cycle CTG Facility

Project: Challenger Development Company L.L.C., Medley Facility
 Project Number: 6792-123-710
 Subject: Natural Gas/Distillate Oil Fired Turbine Non-Criteria Regulated Pollutant Emissions Calculations

Computed by: M. Griffin Date: 5/12/00
 Checked by: B. Burgess Date: 6/28/00

Pollutant	Type ^(a)	Emission Factor AP-42 Section 3.1 04/00 - Combustion Turbine Natural Gas			Emission Factor AP-42 Section 3.1 04/00 - Combustion Turbine No. 2 Fuel Oil			CTG Natural Gas Combustion		Distillate Oil		CTG Natural Gas		CTG Distillate Oil		Facility		Facility Major Source (Y/N)
		AP-42 Section 3.1 04/00 - Combustion Turbine Natural Gas (lb/10 ⁶ scf)	(lb/MMBtu) ^(b)	Rating	(lb/10 ⁶ gallons)	(lb/MMBtu) ^(b)	Rating	Maximum Heat Input, per turbine (MMBtu/Hr) ^(c)	Average Heat Input, per turbine (MMBtu/Hr) ^(c)	Maximum Heat Input, per turbine (MMBtu/Hr) ^(c)	Average Heat Input, per turbine (MMBtu/Hr) ^(c)	Emission Rate, Per Turbine		Emission Rate, Per Turbine		Emission Rate All CTGs		
												Hourly ^(h) (lb/hr)	Annual ⁽ⁱ⁾ (tpy)	Hourly ^(h) (lb/hr)	Annual ⁽ⁱ⁾ (tpy)	Hourly ^(h) (lb/hr)	Annual ⁽ⁱ⁾ (tpy)	
1,3-Butadiene	HAP		4.30E-07	D		1.60E-05	D	469	469	450	450	2.01E-04	1.56E-04	7.20E-03	4.45E-03	4.32E-02	2.67E-02	No
Acetaldehyde	HAP		4.00E-05	C				469	469	450	450	1.87E-02	1.45E-02	0.00E+00	0.00E+00	1.12E-01	8.70E-02	No
Acrolein	HAP		6.40E-06	C				469	469	450	450	3.00E-03	2.32E-03	0.00E+00	0.00E+00	1.80E-02	1.39E-02	No
Benzene ^(a)	HAP	1.36E-02	1.30E-05			5.50E-05	C	469	469	450	450	6.07E-03	4.70E-03	2.48E-02	1.53E-02	1.49E-01	9.17E-02	No
Ethylbenzene	HAP		3.20E-05	C				469	469	450	450	1.50E-02	1.16E-02	0.00E+00	0.00E+00	9.00E-02	6.96E-02	No
Formaldehyde ^(a)	HAP	1.32E-01	1.27E-04			2.80E-04	B	469	469	450	450	5.93E-02	4.59E-02	1.26E-01	7.78E-02	7.56E-01	4.67E-01	No
Naphthalene	HAP		1.30E-06	C		3.50E-05	C	469	469	450	450	6.09E-04	4.71E-04	1.58E-02	9.72E-03	9.45E-02	5.83E-02	No
PAHs	HAP		2.20E-06	C		4.00E-05	C	469	469	450	450	1.03E-03	7.98E-04	1.80E-02	1.11E-02	1.08E-01	6.67E-02	No
Propylene Oxide	HAP		2.90E-05	D				469	469	450	450	1.36E-02	1.05E-02	0.00E+00	0.00E+00	8.15E-02	6.31E-02	No
Toluene ^(a)	HAP	7.10E-02	6.79E-05					469	469	450	450	3.18E-02	2.46E-02	0.00E+00	0.00E+00	1.91E-01	1.48E-01	No
Xylene	HAP		6.40E-05	C				469	469	450	450	3.00E-02	2.32E-02	0.00E+00	0.00E+00	1.80E-01	1.39E-01	No
Arsenic	HAP			E		1.10E-05	D	469	469	450	450	0.00E+00	0.00E+00	4.95E-03	3.06E-03	2.97E-02	1.83E-02	No
Beryllium	HAP			E		3.10E-07	D	469	469	450	450	0.00E+00	0.00E+00	1.40E-04	8.61E-05	8.37E-04	5.17E-04	No
Cadmium	HAP			E		4.80E-06	D	469	469	450	450	0.00E+00	0.00E+00	2.16E-03	1.33E-03	1.30E-02	8.00E-03	No
Chromium	HAP			E		1.10E-05	D	469	469	450	450	0.00E+00	0.00E+00	4.95E-03	3.06E-03	2.97E-02	1.83E-02	No
Lead	HAP			E		1.40E-05	D	469	469	450	450	0.00E+00	0.00E+00	6.30E-03	3.89E-03	3.78E-02	2.33E-02	No
Manganese	HAP			E		7.90E-04	D	469	469	450	450	0.00E+00	0.00E+00	3.56E-01	2.19E-01	2.13E+00	1.32E+00	No
Mercury	HAP			E		1.20E-06	D	469	469	450	450	0.00E+00	0.00E+00	5.40E-04	3.33E-04	3.24E-03	2.00E-03	No
Nickel	HAP			E		4.60E-06	D	469	469	450	450	0.00E+00	0.00E+00	2.07E-03	1.28E-03	1.24E-02	7.67E-03	No
Selenium	HAP			E		2.50E-05	D	469	469	450	450	0.00E+00	0.00E+00	1.13E-02	6.95E-03	6.75E-02	4.17E-02	No

Annual Fuel Use (MMBtu/yr)		Facility Total HAPs		2.7	No
CTG Natural Gas Maximum ^(j)	4,350,720	Maximum Individual HAP	1.3	No	
CTG Distillate Oil Maximum ^(j)	3,333,951				
Number of CTGs per Facility	6				
Natural Gas Heating Value	1047 Btu/SCF (HHV)				

Notes:
 (a) Type = NC for Non-Criteria Pollutants, HAP/POM for compounds included as polycyclic organic matter or HAP for Hazardous Air Pollutant.
 (b) Maximum heat input rate for turbine is based on HHV data at an ambient temperature of 42°F and base load operating conditions.
 (c) Average heat input rate is based on data at an average ambient temperature of 42°F and base load operating conditions.
 (d) Emission Factor (lb/MMBtu) = (Emission Factor, lb/10⁶ scf) / (Heat Value Btu/scf)
 (e) Hourly Emission Rate (lb/hr) = [Heat Input (MMBtu/Hr) * Emission Factor (lb/MMBtu)]
 (f) Annual Emission Rate (tons/year) = [Annual Heat Input (MMBtu/Yr) * Emission Factor (lb/MMBtu)] / (2,000 lb/ton)
 (g) Emission Factors from CARB CATEF emission factor database for natural gas fired combustion turbines.
 (h) Modified from AP-42 Section 3.1 emissions database for aero derivative turbines.
 (i) Annual Fuel Use increased by 10% margin.

**Table
AP-42 Emission Factor for Formaldehyde Emissions from Natural Gas Fired Combustion Turbine**

ID Number	Facility	Turbine	Turbine Rating	Turbine Load	AP-42 Expected			GE LM2500	
					AP-42 Final Value	AP-42, Less Outliers	GE LM2500 Turbines	GE LM2500 Turbines - Less Outliers	
					(lb/Mmcuft)	(lb/Mmcuft)	(lb/Mmcuft)	(lb/Mmcuft)	(lb/Mmcuft)
11	Gilroy Energy Co./Gilroy, CA	General Electric Frame 7	87 MW	NR	0.72	0.72	0.72		
12.1	Sithe Energies, 32nd St. Naval S/San Diego, CA	General Electric MS6000	44 MW	100	0.11	0.11	0.11		
13.1	SD Gas & Electric Co./San Diego, CA	General Electric S221	17 MW	95	0.48	0.48	0.48		
15.1	Modesto Irrigation District/Mclure/Modesto, CA	General Electric Frame 7B	50 MW	100	0.14	0.14	0.14		
16	Willamette Industries, Inc./Oxnard, CA	General Electric LM2500-PE	67.4 MW	33	0.04	0.04	0.04	0.04	0.04
18	Sycamore Cogen. Co./Bakersfield, CA	General Electric Frame 7	75 MW	100	0.09	0.09	0.09		
2	Calpine / Agnews Cogen./San Jose, CA	General Electric LM5000	23.33 MW	100	0.06	0.06	0.06	0.06	0.06
21	Dexzel Inc./Bakersfield, CA	General Electric LM2500	29.1 MW	77	0.03	0.03	0.03	0.03	0.03
22	Procter & Gamble Manufacturing/Sacramento, CA	General Electric LM2500	20.5 MW	95	0.09	0.09	0.09	0.09	0.09
23	Chevron Inc./Gaviota, CA	Allison K501	2.5 MW	NR	3.57	3.57	3.57		
25 ²	EII / Stewart & Stevenson/Berkeley, CA	General Electric LM2500	25 MW	NR	0.48	0.48	0.48	0.48	
26	Calpine Corp./Sumas, WA	General Electric MS7001EA	87.83 MW	100	0.01	0.01	0.01		
27	Sargent Canyon Cogen/Bakersfield, CA	General Electric Frame 6	42.5 MW	50	0.06	0.06	0.06		
28	Watsonville Cogen, Partnership/Watsonville, CA	General Electric LM 2500	24 MW	100	0.09	0.09	0.09	0.09	0.09
3.1	Southern Cal. Edison Co./Long Beach, CA	Brown-Boveri-Sulzer 11-D	61.75 MW	107	1.33	1.33	1.33		
313.1.1	NR/NR	General Electric Frame 3	7.7 MW	100	0.27	0.27	0.27		
313.1.2	NR/NR	General Electric Frame 3	7.7 MW	25	0.43	0.43	0.43		
313.2.1	NR/NR	Solar T12000	9.4 MW	100	0.02	0.02	0.02		
313.2.2	NR/NR	Solar T12000	9.4 MW	25	9.62	9.62	9.62		
315.1	NR/NR	General Electric LM1500	10.6 MW	100	4.27	4.27	4.27		
315.2	NR/NR	General Electric LM1500	10.6 MW	25	25.91	25.91			
4.1.2x ¹	Southern Cal. Edison Co./Coolwater, CA	Westinghouse PACE520	63 MW	100	38.96				
4.2	Southern Cal. Edison Co./Coolwater, CA	Westinghouse PACE520	63 MW	100	0.35	0.35	0.35		
6.2	Imperial Irrigation D / Choachella/Imperial, CA	General Electric NS5000P	46.3 MW	100	0.31	0.31	0.31		
7	Bonneville Pacific Corp./Somis, CA	Solar Mars	9 MW	100	0.74	0.74	0.74		
9	WSPA/SWEPI GT/Bakersfield, CA	Allison 501 KB5	4 MW	85	0.01	0.01	0.01		
Mean (lb/Mmcuft)					3.39	1.97	0.97	0.13	0.06
Std Dev					8.98	5.41	2.13	0.17	0.03

Notes:

¹ Formaldehyde data point was an outlier. Retest of the same turbine (ID Number 4.2) generated formaldehyde data more consistent with other formaldehyde data in the database.

² The data point for the EII/Stewart & Stevenson facility was calculated from three "non-detects"; the Test Method employed an unusually high detection limit.

TANKS 4.0
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: Medley Fuel Oil Day Tank
City: Dade County
State: FL
Company: Challenger Development Company, LLC
Type of Tank: Vertical Fixed Roof Tank
Description: Distillate Oil Day Storage Tank

Tank Dimensions

Shell Height (ft): 24.00
Diameter (ft): 50.00
Liquid Height (ft): 21.00
Avg. Liquid Height (ft): 21.00
Volume (gallons): 285,000.00
Turnovers: 85.26
Net Throughput (gal/yr): 24,300,000.00
Is Tank Heated (y/n): N

Paint Characteristics

Shell Color/Shade: White/White
Shell Condition: Good
Roof Color/Shade: White/White
Roof Condition: Good

Roof Characteristics

Type: Cone
Height (ft): 32.00
Slope (ft/ft) (Cone Roof): 1.28

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Miami, Florida (Avg Atmospheric Pressure = 14.75 psia)

TANKS 4.0 Emissions Report - Detail Format Liquid Contents of Storage Tank

Mixture/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)	Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	Jan	73.59	69.37	77.80	75.91	0.0100	0.0088	0.0114	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Feb	74.43	69.94	78.93	75.91	0.0103	0.0089	0.0118	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Mar	76.23	71.60	80.86	75.91	0.0109	0.0094	0.0126	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Apr	78.12	73.22	83.02	75.91	0.0115	0.0099	0.0134	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	May	79.68	75.05	84.31	75.91	0.0121	0.0105	0.0139	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Jun	80.68	76.33	85.04	75.91	0.0125	0.0109	0.0143	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Jul	81.34	76.83	85.86	75.91	0.0127	0.0111	0.0146	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Aug	81.35	77.02	85.68	75.91	0.0127	0.0112	0.0145	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Sep	80.61	76.62	84.60	75.91	0.0125	0.0110	0.0141	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Oct	78.82	74.94	82.69	75.91	0.0118	0.0105	0.0133	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Nov	76.43	72.58	80.28	75.91	0.0110	0.0097	0.0123	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Dec	74.32	70.34	78.31	75.91	0.0103	0.0091	0.0116	130.0000			188.00	Option 5: A=12.101, B=8907

TANKS 4.0 Emissions Report - Detail Format Detail Calculations (AP-42)

Month:	January	February	March	April	May	June	July	August	September	October	November	December
Standing Losses (lb):	5.2186	5.1942	6.2340	6.7753	6.8421	6.3479	6.9433	6.6231	5.7208	5.4536	4.9112	4.9883
Vapor Space Volume (cu ft):	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372
Vapor Density (lb/cu ft):	0.0002	0.0002	0.0002	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0002	0.0002
Vapor Space Expansion Factor:	0.0277	0.0298	0.0307	0.0326	0.0305	0.0284	0.0295	0.0281	0.0257	0.0249	0.0248	0.0259
Vented Vapor Saturation Factor:	0.9928	0.9926	0.9922	0.9917	0.9913	0.9910	0.9909	0.9909	0.9911	0.9915	0.9921	0.9926
Tank Vapor Space Volume												
Vapor Space Volume (cu ft):	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372	26,834.4372
Tank Diameter (ft):	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000
Vapor Space Outage (ft):	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667
Tank Shell Height (ft):	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000	24.0000
Average Liquid Height (ft):	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000
Roof Outage (ft):	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667
Roof Outage (Cone Roof)												
Roof Outage (ft):	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667	10.6667
Roof Height (ft):	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000
Roof Slope (R/rf):	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800	1.2800
Shell Radius (ft):	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000	25.0000
Vapor Density												
Vapor Density (lb/cu ft):	0.0002	0.0002	0.0002	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0002	0.0002
Vapor Molecular Weight (lb/lb-mole):	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Daily Avg. Liquid Surface Temp. (deg. R):	533.2556	534.1039	535.9009	537.7905	539.3510	540.3530	541.0146	541.0194	540.2777	538.4877	536.1033	533.9923
Daily Average Ambient Temp. (deg. F):	67.2000	68.4500	71.6500	75.1000	78.7000	81.3500	82.6000	82.8500	81.8500	78.3000	73.5500	69.1000
Ideal Gas Constant R (psia cuft / (lb-mol-deg R)):	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731
Liquid Bulk Temperature (deg. R):	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817
Tank Paint Solar Absorptance (Shell):	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700
Tank Paint Solar Absorptance (Roof):	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700
Daily Total Solar Insulation Factor (Btu/sqft day):	1,122.1840	1,344.2730	1,633.9405	1,910.5999	1,893.1501	1,771.0011	1,854.1259	1,775.7602	1,551.1330	1,381.3936	1,162.1600	1,048.2601
Vapor Space Expansion Factor												
Vapor Space Expansion Factor:	0.0277	0.0298	0.0307	0.0326	0.0305	0.0284	0.0295	0.0281	0.0257	0.0249	0.0248	0.0259
Daily Vapor Temperature Range (deg. R):	16.8616	17.9907	18.5056	19.6065	18.5154	17.4300	18.0416	17.3086	15.9514	15.5034	15.3959	15.9337
Daily Vapor Pressure Range (psia):	0.0027	0.0029	0.0031	0.0035	0.0034	0.0033	0.0035	0.0034	0.0030	0.0028	0.0026	0.0026
Breather Vent Press. Setting Range (psia):	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.0088	0.0089	0.0094	0.0099	0.0105	0.0109	0.0111	0.0112	0.0110	0.0105	0.0097	0.0091
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	0.0114	0.0118	0.0126	0.0134	0.0139	0.0143	0.0146	0.0145	0.0141	0.0133	0.0123	0.0116
Daily Avg. Liquid Surface Temp. (deg R):	533.2556	534.1039	535.9009	537.7905	539.3510	540.3530	541.0146	541.0194	540.2777	538.4877	536.1033	533.9923
Daily Min. Liquid Surface Temp. (deg R):	529.0402	529.6062	531.2745	532.8889	534.7222	535.9955	536.5042	536.6922	536.2899	534.6119	532.2543	530.0089
Daily Max. Liquid Surface Temp. (deg R):	537.4710	538.6016	540.5273	542.6921	543.9799	544.7105	545.5250	545.3465	544.2656	542.3636	539.9523	537.9758
Daily Ambient Temp. Range (deg. R):	16.0000	16.1000	14.9000	14.6000	13.2000	12.5000	12.8000	12.3000	11.9000	12.4000	13.7000	15.2000
Vented Vapor Saturation Factor												
Vented Vapor Saturation Factor:	0.9928	0.9926	0.9922	0.9917	0.9913	0.9910	0.9909	0.9909	0.9911	0.9915	0.9921	0.9926
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Vapor Space Outage (ft):	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667	13.6667

TANKS 4.0
Emissions Report - Detail Format
Detail Calculations (AP-42)- (Continued)

Working Losses (lb):	32.6013	33.4777	35.4031	37.5321	39.3745	40.5989	41.4256	41.4316	40.5058	38.3458	35.6260	33.3613
Vapor Molecular Weight (lb/lb-mole):	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Net Throughput (gal/mo.):	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000
Annual Turnovers:	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632	85.2632
Turnover Factor:	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185	0.5185
Maximum Liquid Volume (gal):	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000	285,000.0000
Maximum Liquid Height (ft):	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000	21.0000
Tank Diameter (ft):	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000	50.0000
Working Loss Product Factor:	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
Total Losses (lb):	37.8199	38.6719	41.6371	44.3074	46.2166	46.9468	48.3689	48.0547	46.2266	43.7994	40.5372	38.3495

TANKS 4.0
Emissions Report - Detail Format
Individual Tank Emission Totals

Emissions Report for: January , February , March , April , May , June , July , August , September , October , November , December

Components	Losses(lbs)		Total Emissions
	Working Loss	Breathing Loss	
Distillate fuel oil no. 2	449.68	71.25	520.94

TANKS 4.0
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: Medley Main Storage Tank
City: Dade County
State: FL
Company: Challenger Development Company, LLC
Type of Tank: Vertical Fixed Roof Tank
Description: Distillate Oil Storage Tank

Tank Dimensions

Shell Height (ft): 40.00
Diameter (ft): 85.00
Liquid Height (ft): 36.00
Avg. Liquid Height (ft): 32.00
Volume (gallons): 1,425,000.00
Turnovers: 17.05
Net Throughput (gal/yr): 24,300,000.00
Is Tank Heated (y/n): N

Paint Characteristics

Shell Color/Shade: White/White
Shell Condition: Good
Roof Color/Shade: White/White
Roof Condition: Good

Roof Characteristics

Type: Cone
Height (ft): 54.00
Slope (ft/ft) (Cone Roof): 1.27

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Miami, Florida (Avg Atmospheric Pressure = 14.75 psia)

TANKS 4.0 Emissions Report - Detail Format Liquid Contents of Storage Tank

Mixture/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)	Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	Jan	73.59	69.37	77.80	75.91	0.0100	0.0088	0.0114	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Feb	74.43	69.94	78.93	75.91	0.0103	0.0089	0.0118	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Mar	76.23	71.60	80.86	75.91	0.0109	0.0094	0.0126	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Apr	78.12	73.22	83.02	75.91	0.0115	0.0099	0.0134	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	May	79.68	75.05	84.31	75.91	0.0121	0.0105	0.0139	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Jun	80.68	76.33	85.04	75.91	0.0125	0.0109	0.0143	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Jul	81.34	76.83	85.86	75.91	0.0127	0.0111	0.0146	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Aug	81.35	77.02	85.68	75.91	0.0127	0.0112	0.0145	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Sep	80.61	76.62	84.60	75.91	0.0125	0.0110	0.0141	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Oct	78.82	74.94	82.69	75.91	0.0118	0.0105	0.0133	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Nov	76.43	72.58	80.28	75.91	0.0110	0.0097	0.0123	130.0000			188.00	Option 5: A=12.101, B=8907
Distillate fuel oil no. 2	Dec	74.32	70.34	78.31	75.91	0.0103	0.0091	0.0116	130.0000			188.00	Option 5: A=12.101, B=8907

TANKS 4.0

Emissions Report - Detail Format

Detail Calculations (AP-42)

Month:	January	February	March	April	May	June	July	August	September	October	November	December
Standing Losses (lb):	28.5068	28.3685	34.0344	36.9739	37.3251	34.6212	37.8618	36.1157	31.2016	29.7569	26.8116	27.2443
Vapor Space Volume (cu ft):	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448
Vapor Density (lb/cu ft):	0.0002	0.0002	0.0002	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0002	0.0002
Vapor Space Expansion Factor:	0.0277	0.0298	0.0307	0.0326	0.0305	0.0284	0.0295	0.0281	0.0257	0.0249	0.0248	0.0259
Vented Vapor Saturation Factor:	0.9864	0.9860	0.9852	0.9843	0.9836	0.9831	0.9827	0.9827	0.9831	0.9840	0.9851	0.9861
Tank Vapor Space Volume												
Vapor Space Volume (cu ft):	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448	147,537.0448
Tank Diameter (ft):	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000
Vapor Space Outage (ft):	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000
Tank Shell Height (ft):	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000	40.0000
Average Liquid Height (ft):	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000	32.0000
Roof Outage (ft):	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000
Roof Outage (Cone Roof)												
Roof Outage (ft):	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000	18.0000
Roof Height (ft):	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000	54.0000
Roof Slope (ft/ft):	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700	1.2700
Shell Radius (ft):	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000	42.5000
Vapor Density												
Vapor Density (lb/cu ft):	0.0002	0.0002	0.0002	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0002	0.0002
Vapor Molecular Weight (lb/lb-mole):	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Daily Avg. Liquid Surface Temp. (deg. R):	533.2556	534.1039	535.9009	537.7905	539.3510	540.3530	541.0146	541.0194	540.2777	538.4877	536.1033	533.9923
Daily Average Ambient Temp. (deg. F):	67.2000	68.4500	71.6500	75.1000	78.7000	81.3500	82.6000	82.8500	81.8500	78.3000	73.5500	69.1000
Ideal Gas Constant R (psia cu ft / (lb-mol-deg R)):	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731	10.731
Liquid Bulk Temperature (deg. R):	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817	535.5817
Tank Paint Solar Absorptance (Shell):	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700
Tank Paint Solar Absorptance (Roof):	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700	0.1700
Daily Total Solar Insulation Factor (Btu/sqft day):	1,122.1840	1,344.2730	1,633.9405	1,910.5999	1,893.1501	1,771.0011	1,854.1259	1,775.7602	1,551.1330	1,381.3936	1,162.1600	1,048.2601
Vapor Space Expansion Factor												
Vapor Space Expansion Factor:	0.0277	0.0298	0.0307	0.0326	0.0305	0.0284	0.0295	0.0281	0.0257	0.0249	0.0248	0.0259
Daily Vapor Temperature Range (deg. R):	16.8616	17.9907	18.5056	19.6065	18.5154	17.4300	18.0416	17.3086	15.9514	15.5034	15.3959	15.9337
Daily Vapor Pressure Range (psia):	0.0027	0.0029	0.0031	0.0035	0.0034	0.0033	0.0035	0.0034	0.0030	0.0028	0.0026	0.0026
Breather Vent Press. Setting Range (psia):	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600	0.0600
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.0088	0.0089	0.0094	0.0099	0.0105	0.0109	0.0111	0.0112	0.0110	0.0105	0.0097	0.0091
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	0.0114	0.0118	0.0126	0.0134	0.0139	0.0143	0.0146	0.0145	0.0141	0.0133	0.0123	0.0116
Daily Avg. Liquid Surface Temp. (deg R):	533.2556	534.1039	535.9009	537.7905	539.3510	540.3530	541.0146	541.0194	540.2777	538.4877	536.1033	533.9923
Daily Min. Liquid Surface Temp. (deg R):	529.0402	529.6062	531.2745	532.8889	534.7222	535.9955	536.5042	536.6922	536.2899	534.6119	532.2543	530.0089
Daily Max. Liquid Surface Temp. (deg R):	537.4710	538.6016	540.5273	542.6921	543.9799	544.7105	545.5250	545.3465	544.2656	542.3636	539.9523	537.9758
Daily Ambient Temp. Range (deg. R):	16.0000	16.1000	14.9000	14.6000	13.2000	12.5000	12.8000	12.3000	11.9000	12.4000	13.7000	15.2000
Vented Vapor Saturation Factor												
Vented Vapor Saturation Factor:	0.9864	0.9860	0.9852	0.9843	0.9836	0.9831	0.9827	0.9827	0.9831	0.9840	0.9851	0.9861
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Vapor Space Outage (ft):	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000	26.0000

TANKS 4.0
Emissions Report - Detail Format
Detail Calculations (AP-42)- (Continued)

Working Losses (lb):	62.8739	64.5641	68.2775	72.3834	75.9366	78.2979	79.8923	79.9038	78.1182	73.9525	68.7073	64.3396
Vapor Molecular Weight (lb/lb-mole):	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0100	0.0103	0.0109	0.0115	0.0121	0.0125	0.0127	0.0127	0.0125	0.0118	0.0110	0.0103
Net Throughput (gal/mo.):	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000	2,025,000.000
Annual Turnovers:	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526	17.0526
Turnover Factor:	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
Maximum Liquid Volume (gal):	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000	1,425,000.000
Maximum Liquid Height (ft):	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000	36.0000
Tank Diameter (ft):	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000	85.0000
Working Loss Product Factor:	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
Total Losses (lb):	91.3807	92.9326	102.3119	109.3573	113.2616	112.9190	117.7541	116.0195	109.3198	103.7094	95.5189	91.5839

TANKS 4.0
Emissions Report - Detail Format
Individual Tank Emission Totals

Emissions Report for: January , February , March , April , May , June , July , August , September , October , November , December

Components	Losses(lbs)		Total Emissions
	Working Loss	Breathing Loss	
Distillate fuel oil no. 2	867.25	388.82	1,256.07



AL, Florence
(256) 767-1210
AK, Anchorage
(907) 561-5700
AK, Fairbanks
(907) 452-5700
CA, Alameda
(510) 748-6700
CA, Camarillo
(805) 388-3775
CA, Glendale
(818) 546-2090
CA, Irvine
(949) 752-0403
CA, Sacramento
(916) 362-7100
CO, Ft. Collins
(970) 493-8878
Ft. Collins Tox Lab
(970) 416-0916
CT, Stamford
(203) 323-6620
FL, St. Petersburg
(727) 898-9591
FL, Tallahassee
(850) 385-5006
GA, Norcross
(770) 209-7167
GA, Savannah
(912) 898-0015
IL, Chicago
(630) 836-1700
LA, Lafayette
(337) 896-2430
ME, Portland
(207) 773-9501
MD, Columbia
(410) 884-9280
MA, Acton
(978) 635-9500

MA, Buzzards Bay
(508) 888-3900
MA, Northborough
(508) 393-8558
MA, Woods Hole
(508) 457-7900
MN, Minneapolis
(952) 924-0117
NJ, Piscataway
(732) 457-0500
NY, Albany
(518) 453-6444
NY, Metro Area
(914) 347-4990
NY, Rochester
(716) 381-2210
NY, Syracuse
(315) 432-0506
NC, Raleigh
(919) 571-0669
OH, Cincinnati
(513) 985-9186
OR, Portland
(503) 224-7338
PA, Langhorne
(215) 757-4900
PA, Pittsburgh
(412) 261-2910
SC, Columbia
(803) 216-0003
TX, Austin
(512) 336-2425
TX, Dallas
(972) 509-2250
TX, Houston
(713) 520-9900
TX, San Antonio
(210) 590-8393
WA, Redmond
(425) 881-7700

ENSR International
U.S.A., MA, Acton
(978) 266-4232

Bolivia
Brazil
Bulgaria
Canada
China, Hong Kong
Czech Republic
Ecuador
France
Germany
Greece
Italy
Malaysia
Mexico
Spain
Turkey
United Kingdom
Venezuela

Internet
www.ensr.com