



Enron North America Corp.

P.O. Box 1188

Houston, TX 77251-1188

RECEIVED

APR 23 2001

BUREAU OF AIR REGULATION

April 20, 2001

Mr. Al Linero, P.E.  
Administrator, New Source Review Section  
Florida Department of Environmental Protection  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

RE: Dade Development Company, LLC  
Permit Application for South Dade Energy Center

Dear Mr. Linero:

On behalf of, Dade Development Company, LLC, enclosed are four (4) copies of an air permit application for the South Dade Energy Center in Dade County, Florida. This application is for a non-PSD permit for a simple cycle combustion turbine power plant consisting of 2 Mitsubishi Heavy Industries (MHI) 501F dual-fuel units. Although not required for a non-PSD review, we have conducted an air quality impact assessment, which is contained in Attachment C of this document. In addition, enclosed is a CD-ROM containing the modeling archive. Separate copies of this application are being sent to the Southeast District of the Florida DEP as well as to Miami-Dade County Department of Environmental Resources Management (DERM). An application fee of \$7,500 has been enclosed.

If you have any questions, please don't hesitate to call me at (713) 853-3161.

Sincerely,  
Enron North America

A handwritten signature in black ink that reads "David A. Kellermeyer". The signature is written in a cursive style and is followed by a long horizontal line.

David A. Kellermeyer  
Director

Enclosures

cc: Mr. Lennon Anderson, DEP Southeast District  
Mr. Patrick Wong, DERM

*S. Meron*  
*C. Halladay*

**RECEIVED**

APR 23 2001

BUREAU OF AIR REGULATION

**Dade Development Company,  
L.L.C.  
Houston, TX**

**Air Permit Application for the  
South Dade Energy Center**

**ENSR Corporation  
April 2001  
Document Number 6792-140-410**

## CONTENTS

<b>1.0 INTRODUCTION .....</b>	<b>1-1</b>
<b>2.0 PROJECT DESCRIPTION .....</b>	<b>2-1</b>
<b>3.0 EMISSIONS SUMMARY .....</b>	<b>3-1</b>
3.1 Criteria Pollutant Emissions .....	3-1
3.2 Hazardous Air Pollutant Emissions.....	3-3
<b>4.0 REFERENCES AND BIBLIOGRAPHY .....</b>	<b>4-1</b>

### APPENDICES

- A APPLICATION FOR AIR PERMIT – TITLE V SOURCE DEP FORM NO. 62-210.900(1)**
- B EMISSION CALCULATIONS**
- C AIR QUALITY IMPACT ANALYSIS**

## LIST OF TABLES

Table 3-1	Combustion Turbine Maximum Hourly Emission Rate Summary .....	3-2
Table 3-2	Annual Criteria Pollutant Emissions.....	3-3
Table 3-3	HAP Emission Summary, Dade Development Company Electric Generating Facility...	3-4
Table 3-4	Summary of Proposed Permit Limits Natural Gas Operation .....	3-5
Table 3-5	Summary of Proposed Permit Limits Distillate Oil Operation .....	3-6

---

## LIST OF FIGURES

Figure 1-1	Site Location Map .....	1-3
Figure 2-1	Equipment Arrangement Plan .....	2-3
Figure 2-2	Process Flow Diagram .....	2-4
Figure 2-3	CTG Relative Criteria Pollutant Emission Rates .....	2-5

## 1.0 INTRODUCTION

Dade Development Company, L.L.C. is proposing to construct and operate a simple cycle combustion turbine peaking electric generating facility in Dade County, Florida. The South Dade Energy Center (SDEC) will be a non-utility power generating facility (merchant plant) designed to produce electric energy for sale to the wholesale power market.

The SDEC will be sited on approximately 31 acres located in Dade County, Florida (see Figure 1-1). The facility will consist of two Mitsubishi Heavy Industry (MHI) 501F simple cycle combustion turbines with a nominal generating capacity of approximately 370 megawatts (MW). The plant will fire natural gas and low sulfur distillate fuel oil. Natural gas will be the primary fuel. Distillate fuel will be used as a back-up fuel, in the event that natural gas is unavailable to the facility. The turbines will use dry low-NO<sub>x</sub> combustors during natural gas firing, and water injection during distillate oil firing to minimize NO<sub>x</sub> formation. Good combustion practices will be used to control emissions of CO and VOC. The turbines will be equipped with inlet air chilling for power augmentation. The SDEC is scheduled to begin producing power as early as May 1, 2002. Construction will take approximately 6 months with a planned start date of November 1, 2001 (upon receipt of all necessary local and environmental approvals).

As a peaking facility, the project will operate on an intermittent basis, primarily during periods when short-term electrical demand exceeds base load supply. Hence, the SDEC will run primarily during the peak demand hours of the summer months and to a limited extent on the coldest winter days. In order to be permitted as a minor source of air emissions, the SDEC will limit emissions of all criteria pollutants to less than 250 tons per year (TPY) by accepting an enforceable limitation on tons per year of all criteria pollutants emitted. NO<sub>x</sub> and CO have been determined to be the limiting pollutants for major source status. As such, it is proposed that NO<sub>x</sub> and CO emissions be limited to no more than 248 TPY, as measured by NO<sub>x</sub> and CO continuous emission monitoring systems.


As part of its application, Dade Development Company, L.L.C. is requesting the ability to burn fuel oil. While the intention is to burn natural gas at every opportunity, near term constraints on the Florida Gas Transmission ("FGT") pipeline may impede the ability to burn natural gas during some periods of peak demand during the summer season. In general, the FGT natural gas transmission line flows near its maximum pipeline capacity of 1.5 Bcf/day during the summer season. In order to accommodate the demand for incremental generation within the state of Florida, FGT plans to expand its pipeline capacity by approximately 600,000 MMBtu/day before the summer of 2002. Additionally, FGT is in active discussions with potential shippers to perform another expansion of its pipeline in 2003. The addition of this capacity should reduce periods of pipeline constraint and will result in an increased availability of natural gas to the proposed site. The request for oil burning flexibility is necessitated by near term FGT capacity constraints and is not due to deficient gas supplies received by FGT. Moreover, operational guidelines dictate that natural gas be the primary fuel source and that oil will be

used as a backup fuel to the extent that transmission capacity constraints on FGT pipeline preclude the delivery of natural gas to the site.

Section 2 of this application provides a more detailed project description. Section 3 presents a summary of the project emissions and the basis and methods used to calculate emissions. The required Florida Department of Environmental Protection (FDEP) application forms are presented in Appendix A, with supporting calculations for emissions included in Appendix B. Although not formally required as part of the construction permitting process for minor sources, air dispersion modeling was conducted to assess the impact of the SDEC on local air quality, including the Everglades and Biscayne National Parks. The air quality impact assessment is presented in Appendix C.

As "new affected units" under Phase II of the Acid Rain Program, the SDEC is required to obtain SO<sub>2</sub> allowances. The application for the Phase II Acid Rain permit will be submitted shortly after this application is filed.

Figure 1-1 Site Location Map





## 2.0 PROJECT DESCRIPTION

The proposed SDEC will utilize two MHI 501F combustion turbines (CTs), providing a total nominal generating capacity of approximately 370 MW. Emissions from each turbine will be vented through stacks that are 80 feet tall and with an effective diameter of 27.68 feet. Figure 2-1 is a conceptual drawing depicting the layout of the proposed turbine configuration, Figure 2-2 is a process flow diagram for the proposed combustion turbines.

The turbines will be equipped to fire both natural gas and fuel oil utilizing natural gas as the primary fuel. The project will not use any other fuel source for startup, shutdown, or backup. The SDEC will have the ability to utilize power from the grid for startup. Electrical power produced by the project will be interconnected to the electric grid by a transmission line to FPL's transmission line in the vicinity of the property.

The SDEC will use simple cycle power generation for peaking electrical generation for periods when short-term electrical demand exceeds base load supply. Peaking units have the ability to be brought on-and off-line quickly in response to fluctuations in electrical demand. Typical startup to 100% load and shutdown from 100% load can be achieved in approximately 20 minutes .


The SDEC will be permitted and operated as a synthetic minor source under the Clean Air Act by accepting a permit limitation on tons per year of criteria pollutants emitted. Figure 2-3 illustrates the relative emissions rates of criteria pollutants from the proposed turbines. Based on the proposed permit limits, the most limiting pollutant is NO<sub>x</sub> during natural gas and distillate oil operation. Dade Development Company, L.L.C. proposes to limit potential emissions from the SDEC through the use of a Continuous Emission Monitoring System (CEMS) for NO<sub>x</sub> and CO. By limiting emissions of NO<sub>x</sub> and CO to less than the major source threshold of 248 tons per year, it can be seen that none of the remaining criteria pollutants will exceed the 250 ton per year threshold. Although performance data has been included for operating conditions at 75% and 100% load, each CT will typically be operated at full (100%) load. Depending upon demand, all units may not be in operation.

The SDEC will also incorporate tanks used to store distillate oil for the combustion turbines a fire-water pump engine, a natural gas fuel heater, and a chiller system with four small mechanical draft cooling towers for cooling the inlet air to the turbines during high ambient temperature conditions. The on site oil storage requirements have been estimated to be a maximum of 1,852,200 gallons, with a maximum day storage tank requirement of 463,000 gallons. The working and breathing losses from the two tanks has been estimated using EPA's Tanks 4.0 program to be less than 0.85 tons per year.

For emergency purposes the SDEC will incorporate a fire water pump powered by a 250 hp diesel engine. The emissions from this engine have been estimated using AP-42 emission factors, assuming a maximum operation of 500 hours per year. Based on this operational limitation the fire water pump engine satisfies the applicable criteria of Rule 62-210.300(b)1 for exemption from permitting and thus


has not been addressed in the Section III of the FDEP application forms. In addition, a 6 MMBtu/hr fuel gas heater will be included for use as a means to prevent condensation of moisture and hydrates in natural gas used in the gas turbines. This emissions unit also meets the criteria for the generic emissions unit exemption under Rule 62.210.300(b)1 and has not been included in Section III of the application forms.

NURSERY  
(S.W. 256th STREET) TUESBERG DRIVE




SCHEDULE OF COMPONENTS	
1	GAS RECEIVING/STORAGE
2	GAS PURGING/VENTING
3	WIND STOP-UP TRANSFORMER
4	SUBSTATION
5	SUBSTATION CONTROL ROOM BUILDING
6	EMERGENCY SPACE
7	PLANT SWITCHGEAR AREA
8	ELECTRICAL ROOM BUILDING
9	CONTROL ROOM/INSTRUMENTATION CONTROL BLDG.
10	ADMINISTRATION BUILDING (2 STORIES)
11	FIRE WATER TOWER & FIRE WATER TANK
12	STORAGE BLDG.
13	FIRE WATER PUMP HOUSE
14	NOT USED
15	NOT USED
16	NOT USED
17	NOT USED
18	NOT USED
19	NOT USED
20	REGENERATED WATER WATER STORAGE BLDG.
21	LABORATORY
22	CHEMICAL STORAGE
23	CHILLED/COOLING WATER PACKAGE
24	WATER TREATMENT BUILDING (2 STORIES)
25	NOT USED
26	GUARD HOUSE
27	ONLY WATER TANK
28	EMERGENCY PUMP STATION (PUMP)
29	NOT USED
30	FUEL GAS COMPRESSOR ENCLOSURE
31	FUEL WRECKER/FORMING EQUIPMENT
32	FUEL OIL DRY WARE (14,000 BBL)
33	NOT USED
34	FUEL OIL STORAGE (16,000 BBL)
35	NOT USED
36	CHILLED WATER TANK (272,000 BBL)
37	FORMERLY BY REVISION AREA

NOTES:  
1- MECHANICAL EQUIPMENT SHOWN FOR ILLUSTRATION PURPOSES ONLY. FINAL LOCATION OF EQUIPMENT TO BE DETERMINED AT TIME OF CONSTRUCTION PLANS DESIGN FOR PERMITTING.  
2- FOR SETBACKS TO BUILDINGS, TANKS AND OTHER EQUIPMENT; PLEASE REFER TO SITE LAYOUT PLAN SHEET C-2



EASEMENT FOR EXISTING F.P.L. POWER LINES  
OVERHEAD/WIRES  
N 433728.9556  
E 713726.5169




DWG. NO.	REFERENCE DRAWING TITLE	NO.	REVISION - DESCRIPTION	BY	DATE	CHK'D	APP'D	CADD	PLOT DATE	FILE NAME	P.L./S.H.A. ACCT. NO.	CONSTRUCTION YR.	DESIGN	BY	DATE	DRAWN	BY	DATE	ASBUILT	FILE NO.	SCALE	1"=30'

RICHARD A. LEAR, P.E.  
DATE: \_\_\_\_\_  
I.C. No. 25182, STATE OF FLORIDA



South Dade Energy Center  
Figure 2-1  
Equipment Arrangement Plan

DATE/WORK ORDER: \_\_\_\_\_  
ASBUILT DWG. NO.: \_\_\_\_\_  
CONSTRUCTION DWG. NO.: \_\_\_\_\_  
SHEET C-3 REV. NO. E



2-4


679211A.DWG

**ENSR.**  
INTERNATIONAL

FIGURE 2-2  
PROCESS FLOW DIAGRAM  
SIMPLE CYCLE COMBUSTION TURBINE

DRAWN:	JK	DATE:	4/01
APPVD:	DD	REVISED:	X
		PROJECT NUMBER:	06792-140
		REV.	0

**Figure 2-3 CTG Relative Criteria Pollutant Emission Rates**



### 3.0 EMISSIONS SUMMARY

This section discusses the basis and methods used to estimate potential emissions for the SDEC.

The data used during the development of this application rely on process information developed by MHI for Dade Development Company, L.L.C. The summary presented in Table 3-1 has been prepared for the two MHI 501F combustion turbines. Detailed emission calculations for these turbines are presented at 100% and 75% load cases in Appendix B along with operating specifications at the following ambient conditions:

- 32, 59, 74, 95°F dry bulb at 65% relative humidity, and
- 59, 74, 95°F dry bulb at 65% relative humidity chilled to 45°F and 65% relative humidity.

#### 3.1 Criteria Pollutant Emissions

The primary emission sources at the SDEC will be the two CTs. Each CT, when used, will typically operate at 100% load, but may, at times, be operated down to 75% load. The turbines will fire natural gas, supplied directly to the site by pipeline and fuel oil, provided by onsite storage. Hourly emissions from these units were calculated from manufacturers operating parameters and guaranteed in-stack concentrations for CO, NO<sub>x</sub>, and VOC. As PM<sub>10</sub> emissions are based on manufacturers guaranteed hourly emission rates, a worst case lb/MMBtu emission factor has been calculated from the lb/hr guarantee emission rate for purposes of calculating annual PM<sub>10</sub> emissions. SO<sub>2</sub> emissions were calculated using the manufacturers' supplied fuel consumption data and an expected maximum fuel gas sulfur content of 2.0 grains per 100 standard cubic feet for natural gas and 0.05 wt % for distillate oil. Particulate emissions are estimated to be 40 lb/hour while firing fuel oil and 20 lb/hour while firing natural gas.

Maximum hourly emission rates for each pollutant were established after reviewing the calculations for the four ambient temperatures at two turbine load conditions (75%, and 100%) that represent the range of expected operating conditions. The annual facility emissions of NO<sub>x</sub> and CO will be limited through the use of CEMS, to a maximum of 248 tons per year. Although annual operation is restricted through the use of NO<sub>x</sub> and CO CEMS rather than a fuel cap, an estimate of the maximum annual fuel consumption is used to calculate the maximum annual emissions of VOC, SO<sub>2</sub>, Pb, and PM<sub>10</sub>.

**Table 3-1 Combustion Turbine Maximum Hourly Emission Rate Summary**

Compound	Load (%)	Ambient Temperature (deg F)							
		32	59 <sup>1</sup>	74 <sup>1</sup>	95 <sup>1</sup>	32	59 <sup>1</sup>	74 <sup>1</sup>	95 <sup>1</sup>
<b>Emissions for one MHI 501F Turbine (lb/hr)</b>									
		Natural Gas				Distillate Oil			
NOx	100	173	173	173	173	281	272	272	272
	75	148	132	128	122	226	212	205	196
CO	100	47	42	42	42	204	197	197	197
	75	54	49	47	45	164	154	149	142
VOC	100	3.0	3.0	3.0	3.0	35	34	34	34
	75	4.0	2.0	2.0	2.0	28	27	26	25
SO2	100	11.3	11.3	11.3	11.3	78	76	76	76
	75	9.0	8.7	8.4	8.0	63	59	57	55
H2SO4	100	1.8	1.8	1.8	1.8	12.0	11.7	11.7	11.7
	75	1.4	1.4	1.3	1.3	9.7	9.1	8.8	8.5
Pb	100	ND	ND	ND	ND	0.02	0.02	0.02	0.02
	75	ND	ND	ND	ND	0.02	0.02	0.02	0.02
PM10	100	20	20	20	20	40	40	40	40
	75	20	20	20	20	40	40	40	40

Notes

<sup>1</sup>At baseload, turbine air inlet temperature is cooled to 45°F.

Based on the guaranteed emission concentrations, during both natural gas and distillate oil operation NO<sub>x</sub> is the limiting pollutant. Annual emissions of VOC, SO<sub>2</sub>, Pb, and PM<sub>10</sub> have been estimated using NO<sub>x</sub> as the limiting pollutant for both natural gas and distillate oil operation. The data used in this analysis is presented in Appendix B. Table 3-2 presents a summary of annual emissions for the two combustion turbines, the distillate oil storage tank, the fire-water pump engine, natural gas fuel heater, and cooling towers. Tables 3-4 and 3-5 provide a summary of proposed permit limits for the combustion turbines.

**Table 3-2 Annual Criteria Pollutant Emissions**

Source Name	NO <sub>x</sub> <sup>(1)</sup>	CO <sup>(1)</sup>	VOC <sup>(2)</sup>	SO <sub>2</sub> <sup>(2)</sup>	H <sub>2</sub> SO <sub>4</sub> <sup>(2)</sup>	Pb <sup>(2)</sup>	PM <sup>(2)</sup>	PM <sub>10</sub> <sup>(2)</sup>
<b>Annual Emission Rates (tons/year)</b>								
501F Combustion Turbines.	245.5	247.2	34.7	75.8	6.9	0.02	50.2	50.2
Distillate Oil Storage Tanks	N/A	N/A	0.8	N/A	N/A	N/A	N/A	N/A
Cooling Towers	N/A	N/A	N/A	N/A	N/A	N/A	0.73	0.73
Fire-Water Pump Engine	2.00	0.40	0.20	0.10	-	-	0.20	0.20
Natural Gas Fuel Heater	0.46	0.41	0.27	0.01	-	-	0.05	0.05
<b>Total</b>	<b>248.0</b>	<b>248.0</b>	<b>36.0</b>	<b>75.9</b>	<b>6.9</b>	<b>0.02</b>	<b>52.0</b>	<b>52.0</b>
Notes:								
(1) Limited by CEMS on NO <sub>x</sub> and CO.								
(2) Estimated from CEMS limitation on NO <sub>x</sub> and CO. Annual emissions of VOC, SO <sub>2</sub> , H <sub>2</sub> SO <sub>4</sub> , Pb, and PM/PM <sub>10</sub> increased by a 10% margin.								

### 3.2 Hazardous Air Pollutant Emissions

Emissions of hazardous air pollutants (HAPs) were calculated to confirm that the SDEC will not be a new major HAP source subject to preconstruction permitting under 40 CFR 63 Subpart B. HAP emissions (with the exception of formaldehyde) were derived from the April 2000 version of AP-42 Section 3.1 which provides emission factors for stationary combustion turbines. An emission factor for formaldehyde was developed from a subset of the database used by EPA to develop the AP-42 emission factors (see Appendix B for details).

Annual HAP emissions are presented in Table 3-3. Total facility-wide emissions for all HAPs combined is 3.0 TPY with the largest single HAP being less than 1.3 TPY. Both of these values are well below the 25/10 tpy major source thresholds for HAPs.



**Table 3-3 HAP Emission Summary, Dade Development Company Electric Generating Facility**

Pollutant	CTG Natural Gas		CTG Distillate Oil		SDEC	
	Emission Rate, Per Turbine		Emission Rate, Per Turbine		Emission Rate All CTGs	
	Max Hourly (lb/hr)	Annual (tpy)	Max Hourly (lb/hr)	Annual (tpy)	Max Hourly (lb/hr)	Annual (tpy)
1,3-Butadiene	8.20E-04	5.92E-04	2.66E-02	1.32E-02	5.33E-02	2.63E-02
Acetaldehyde	7.63E-02	5.51E-02	0.00E+00	0.00E+00	1.53E-01	1.10E-01
Acrolein	1.22E-02	8.82E-03	0.00E+00	0.00E+00	2.44E-02	1.76E-02
Benzene	2.29E-02	1.65E-02	9.16E-02	4.53E-02	1.83E-01	9.06E-02
Ethylbenzene	6.10E-02	4.41E-02	0.00E+00	0.00E+00	1.22E-01	8.82E-02
Formaldehyde	2.62E-01	1.89E-01	4.66E-01	2.31E-01	9.33E-01	4.61E-01
Naphthalene	2.48E-03	1.79E-03	5.83E-02	2.88E-02	1.17E-01	5.76E-02
PAHs	4.20E-03	3.03E-03	6.66E-02	3.29E-02	1.33E-01	6.59E-02
Propylene Oxide	5.53E-02	4.00E-02	0.00E+00	0.00E+00	1.11E-01	7.99E-02
Toluene	2.48E-01	1.79E-01	0.00E+00	0.00E+00	4.96E-01	3.58E-01
Xylene	1.22E-01	1.22E-01	0.00E+00	0.00E+00	2.44E-01	2.44E-01
Arsenic	0.00E+00	0.00E+00	1.83E-02	9.06E-03	3.66E-02	1.81E-02
Beryllium	0.00E+00	0.00E+00	5.16E-04	2.55E-04	1.03E-03	5.10E-04
Cadmium	0.00E+00	0.00E+00	7.99E-03	3.95E-03	1.60E-02	7.90E-03
Chromium	0.00E+00	0.00E+00	1.83E-02	9.06E-03	3.66E-02	1.81E-02
Lead	0.00E+00	0.00E+00	2.33E-02	1.15E-02	4.66E-02	2.31E-02
Manganese	0.00E+00	0.00E+00	1.32E+00	6.50E-01	2.63E+00	1.30E+00
Mercury	0.00E+00	0.00E+00	2.00E-03	9.88E-04	4.00E-03	1.98E-03
Nickel	0.00E+00	0.00E+00	7.66E-03	3.79E-03	1.53E-02	7.57E-03
Selenium	0.00E+00	0.00E+00	4.16E-02	2.06E-02	8.33E-02	4.12E-02
<b>Facility Total HAPs</b>						<b>3.0</b>
<b>Maximum Individual HAP</b>						<b>1.3</b>

Proposed emission limits for the combustion turbines during natural gas and distillate oil operation are presented in Tables 3-4 and 3-5, respectively. Annual limits for VOCs, SO<sub>2</sub>, PM<sub>10</sub>, and Pb are not proposed to be included in the permit. This is because compliance with a 248 ton/year limit for NO<sub>x</sub> and CO will insure that these other pollutants are emitted in quantities considerably lower than the 250 ton/year major source threshold.

**Table 3-4 Summary of Proposed Permit Limits Natural Gas Operation**

	ppmvd @ 15% O <sub>2</sub>	Lb/hr <sup>1</sup> Each Turbine	CTG Annual Tons/Yr	Control Technology	Test Method
NO <sub>x</sub>	25	173	245.5	Dry Low NO <sub>x</sub> Combustors	Stack Test Ref. Method 19 & 20
CO	16	54	247.2	Good Combustion Practices	Stack Test Ref. Method 10 & 19
VOC	2.0	4.0		Good Combustion Practices	Stack Test Ref. Method 25a less Methane via bag sample & Method 18
SO <sub>2</sub>	N/A	11.3		Low Sulfur Fuel (less than 2.0 grain S/100 SCF gas)	Fuel Monitoring
PM <sub>10</sub>	N/A	20		Low Sulfur Fuel (less than 2.0 grain S/100 SCF gas)	Stack Test Ref. Method 5 & 202
<sup>1</sup> lb/hr for each turbine is based on worst case emission rates over all operating loads and temperatures.					

**Table 3-5 Summary of Proposed Permit Limits Distillate Oil Operation**

	Ppmvd @ 15% O <sub>2</sub>	Lb/hr Each Turbine	CTG Annual Tons/Yr	Control Technology	Test Method
NO <sub>x</sub>	42	281	245.5	Water Injection	Stack Test Ref. Method 19 & 20
CO	50	204	247.2	Good Combustion Practices	Stack Test Ref. Method 10 & 19
VOC	15	35		Good Combustion Practices	Stack Test Ref. Method 25a less Methane via bag sample & Method 18
SO <sub>2</sub>	N/A	78		Low Sulfur Fuel	Fuel Monitoring
Pb	N/A	.02		Low Ash Fuel	N/A
PM <sub>10</sub>	N/A	40		Low Sulfur Fuel	Stack Test Ref. Method 5 & 202

<sup>1</sup>lb/hr for each turbine is based on worst case emission rates over all operating loads and temperatures.

---

## 4.0 REFERENCES AND BIBLIOGRAPHY

Pequot Publishing, 1997. Gas Turbine World 1997 Handbook.

Rasnic, John B., August 1987. Letter to Air Compliance Branch Chiefs, Regions I-IX, RC: NSPS Custom Fuel Monitoring.


U.S. EPA. September 1977. Standards Support and Environmental Impact Statement - Volume I: Proposed Standards of Performance for Stationary gas Turbines. EPA 450/2-77-017a.

U.S. EPA. October 1990. New Source Review Workshop manual. Draft.

U.S. EPA. October 1996. AP-42.

**APPENDIX A**

**APPLICATION FOR AIR PERMIT – TITLE V SOURCE  
DEP FORM NO. 62-210.900(1)**



# Department of Environmental Protection

## Division of Air Resources Management

### APPLICATION FOR AIR PERMIT - TITLE V SOURCE

See Instructions for Form No. 62-210.900(1)

#### I. APPLICATION INFORMATION

##### Identification of Facility

1. Facility Owner/Company Name: <b>Dade Development Company, L.L.C.</b>	
2. Site Name: <b>South Dade Energy Center</b>	
3. Facility Identification Number: <span style="float: right;"><input checked="" type="checkbox"/> Unknown</span>	
4. Facility Location: Street Address or Other Locator: <b>SW Corner of 256<sup>th</sup> Street and SW 97<sup>th</sup> Avenue</b> City: <b>Unincorporated</b> County: <b>Dade</b> Zip Code: <b>33032</b>	
5. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Existing Permitted Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

##### Application Contact

1. Name and Title of Application Contact: <b>Dave Kellermeyer, Director</b>		
2. Application Contact Mailing Address: Organization/Firm: <b>Dade Development Company, L.L.C.</b> Street Address: <b>1400 Smith Street</b> City: <b>Houston</b> State: <b>TX</b> Zip Code: <b>77002-7631</b>		
3. Application Contact Telephone Numbers: Telephone: <b>(713) 853-3161</b> Fax: <b>(713) 646-3037</b>		

##### Application Processing Information (DEP Use)

1. Date of Receipt of Application:	<i>4-23-01</i>
2. Permit Number:	<i>025 1099-001-AC</i>
3. PSD Number (if applicable):	
4. Siting Number (if applicable):	

**Purpose of Application**

**Air Operation Permit Application**

This Application for Air Permit is submitted to obtain: (Check one)

- Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: \_\_\_\_\_

- Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: \_\_\_\_\_

Operation permit number to be revised: \_\_\_\_\_

- Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)

Operation permit number to be revised/corrected: \_\_\_\_\_

- Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit number to be revised: \_\_\_\_\_


Reason for revision: \_\_\_\_\_

**Air Construction Permit Application**

This Application for Air Permit is submitted to obtain: (Check one)

- Air construction permit to construct or modify one or more emissions units.
- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- Air construction permit for one or more existing, but unpermitted, emissions units.

**Owner/Authorized Representative or Responsible Official**

1. Name and Title of Owner/Authorized Representative or Responsible Official: <b>Ben Jacoby – Attorney-In-Fact</b>
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: <b>Dade Development Company, L.L.C.</b> Street Address: <b>1400 Smith Street</b> City: <b>Houston</b> State: <b>TX</b> Zip Code: <b>77002-7631</b>
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: <b>(713) 853-6173</b> Fax: <b>(713) 646-3037</b>
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative*(check here [ ], if so) or the responsible official (check here [✓], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i>  DAE  _____ 4-18-01 _____ Signature Date

\* Attach letter of authorization if not currently on file.

**Professional Engineer Certification**

1. Professional Engineer Name: <b>Blair Burgess</b> Registration Number: <b>45460</b>
2. Professional Engineer Mailing Address: Organization/Firm: <b>ENSR</b> Street Address: <b>2809 West Mall Drive</b> City: <b>Florence</b> State: <b>AL</b> Zip Code: <b>35630</b>
3. Professional Engineer Telephone Numbers: Telephone: <b>(256) 767-1210</b> Fax: <b>(256) 767-1211</b>



4. Professional Engineer Statement:

*I, the undersigned, hereby certify, except as particularly noted herein\*, that:*


*(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*

*(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.*

*If the purpose of this application is to obtain a Title V source air operation permit (check here [  ], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.*

*If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [  ], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.*

*If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [  ], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.*

*4/18/01*  
  
Signature

EMBOSSED METALLIC

(seal)

*4/18/01*  
Date

\* Attach any exception to certification statement.

**Scope of Application**

<b>Emissions Unit ID</b>	<b>Description of Emissions Unit</b>	<b>Permit Type</b>	<b>Processing Fee</b>
<b>CT001 – CT002</b>	<b>MHI 501F Single Cycle Combustion Turbines (Two identical combustion turbines)</b>	<b>AC1B</b>	<b>\$5,000</b> Similar emissions unit fee per Rule 62-4.050(4)(a)(4)
<b>T001 – T002</b>	<b>Distillate Fuel Oil Storage Tanks</b>	<b>AC1F</b>	<b>\$250</b>
<b>FWP</b>	<b>Firewater Pump Diesel Engine</b>	<b>AC1F</b>	<b>\$250</b>
<b>NGH</b>	<b>Natural Gas Fuel Heater</b>	<b>AC1F</b>	<b>\$250</b>

**Application Processing Fee**

Check one: [  ] Attached - Amount: **\$5,750**      [  ] Not Applicable

**Construction/Modification Information**

1. Description of Proposed Project or Alterations

**Dade Development Company, L.L.C. proposes to construct and operate a peaking electrical power generating facility at a greenfield site in Dade County, Florida. The facility will consist of up to two MHI 501F combustion turbines operating in simple cycle mode; each turbine has a nominal generating capacity of 184 MW. The combustion turbines will be fired primarily with natural gas with low sulfur distillate oil as a backup fuel. NO<sub>x</sub> emissions will be controlled with dry low NO<sub>x</sub> combustors when firing natural gas and water injection when firing distillate oil. Permit conditions will limit total facility annual emissions to less than 248 tons per year of any regulated air pollutant in order to be permitted as a synthetic minor source with respect to Rule 62-212.400, Prevention of Significant Deterioration. Ancillary equipment includes one 1.9 million gallon distillate oil storage tank, one 463,000 gallon distillate oil storage tank, one natural gas fuel heater and one emergency diesel fired IC engine driving a firewater pump.**

2. Projected or Actual Date of Commencement of Construction:

**November 1, 2001**

3. Projected Date of Completion of Construction:

**May 1, 2002**

**Application Comment**

[Empty box for Application Comment]

## II. FACILITY INFORMATION

### A. GENERAL FACILITY INFORMATION

#### Facility Location and Type

1. Facility UTM Coordinates: Zone: <b>17</b> East (km): <b>565.1</b> North (km): <b>2823.4</b>			
2. Facility Latitude/Longitude: Latitude (DD/MM/SS):    Longitude (DD/MM/SS):			
3. Governmental Facility Code: <b>0</b>	4. Facility Status Code: <b>C</b>	5. Facility Major Group SIC Code: <b>49</b>	6. Facility SIC(s):  <b>4911</b>
7. Facility Comment (limit to 500 characters):			

#### Facility Contact

1. Name and Title of Facility Contact: <b>Dave Kellermeyer, Director</b>		
2. Facility Contact Mailing Address: Organization/Firm: <b>Dade Development Company, L.L.C.</b> Street Address: <b>1400 Smith Street</b> City: <b>Houston</b> State: <b>TX</b> Zip Code: <b>77002-7631</b>		
3. Facility Contact Telephone Numbers: Telephone: <b>(713) 853-3161</b> Fax: <b>(713) 646-3037</b>		

**Facility Regulatory Classifications**

**Check all that apply:**

1. [ ] Small Business Stationary Source?	[ ] Unknown
2. [✓] Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?	
3. [✓] Synthetic Minor Source of Pollutants Other than HAPs?	
4. [ ] Major Source of Hazardous Air Pollutants (HAPs)?	
5. [ ] Synthetic Minor Source of HAPs?	
6. [✓] One or More Emissions Units Subject to NSPS?	
7. [ ] One or More Emission Units Subject to NESHAP?	
8. [✓] Title V Source by EPA Designation?	
9. Facility Regulatory Classifications Comment (limit to 200 characters):	

**List of Applicable Regulations (Facility-wide)**

Chapter 62-4	Permits
Rule 62-204.220	Ambient Air Quality Protection
Rule 62-204.240	Ambient Air Quality Standards
Rule 62-204.800	Federal Regulations Adopted by Reference
Rule 62-210.300	Permits Required
Rule 62-210.350	Public Notice and Comments
Rule 62-210.370	Reports
Rule 62-210.550	Stack Height Policy
Rule 62-210.650	Circumvention
Rule 62-210.700	Excess Emissions
Rule 62-210.900	Forms and Instructions
Rule 62-212.300	General Preconstruction Review Requirements
Rule 62-213	Operation Permits for Major Sources of Air Pollution
Rule 62-214	Requirements for Sources Subject to the Federal Acid Rain Program

Rule 62-296.	General Pollutant Emission Limiting Standards
Rule 62-297.310	General Test Requirements
Rule 62-297.401	Compliance Test Methods
Rule 62-297.520	EPA Continuous Monitor Performance Specifications
40 CFR 60	Applicable sections of Subpart A, General Requirements, NSPS Subparts GG and Kb
40 CFR 72	Acid Rain Permits
40 CFR 75	Monitoring
40 CFR 77	Acid Rain Program – Excess Emissions

## B. FACILITY POLLUTANTS

### List of Pollutants Emitted

1. Pollutant Emitted	2. Pollutant Classif.	3. Requested Emissions Cap		4. Basis for Emissions Cap	5. Pollutant Comment
		lb/hour	tons/year		
NOX	A, SM (PSD/248 tpy)		248	ESCPSD	Units CT001-CT002, FWP + NGH included under NO <sub>x</sub> cap.
CO	A, SM (PSD/248 tpy)		248	ESCPSD	Units CT001-CT002, FWP + NGH included under CO cap.
SO2	B				CT SO <sub>2</sub> emissions and fuel sulfur content regulated under 40 CFR 60, Subpart GG
VOC	B				Units T001-T002 subject to record keeping requirements of 40 CFR 60, Subpart Kb

### C. FACILITY SUPPLEMENTAL INFORMATION

#### Supplemental Requirements

1. Area Map Showing Facility Location: [ <input checked="" type="checkbox"/> ] Attached, Document ID: <b>Fig. 1-1</b> [ <input type="checkbox"/> ] Not Applicable [ <input type="checkbox"/> ] Waiver Requested
2. Facility Plot Plan: [ <input checked="" type="checkbox"/> ] Attached, Document ID: <b>Fig. 2-1</b> [ <input type="checkbox"/> ] Not Applicable [ <input type="checkbox"/> ] Waiver Requested
3. Process Flow Diagram(s): [ <input type="checkbox"/> ] Attached, Document ID: <b>Fig. 2-2</b> [ <input type="checkbox"/> ] Not Applicable [ <input type="checkbox"/> ] Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: [ <input type="checkbox"/> ] Attached, Document ID: _____ [ <input checked="" type="checkbox"/> ] Not Applicable [ <input type="checkbox"/> ] Waiver Requested
5. Fugitive Emissions Identification: [ <input type="checkbox"/> ] Attached, Document ID: _____ [ <input checked="" type="checkbox"/> ] Not Applicable [ <input type="checkbox"/> ] Waiver Requested
6. Supplemental Information for Construction Permit Application: [ <input checked="" type="checkbox"/> ] Attached, Document ID: <b>ENSR Document No. 6792-123-410</b> [ <input type="checkbox"/> ] Not Applicable
7. Supplemental Requirements Comment:



**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

8. List of Proposed Insignificant Activities: <input checked="" type="checkbox"/> Attached, Document ID: <b>Section 2</b> <input type="checkbox"/> Not Applicable
9. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input checked="" type="checkbox"/> Not Applicable
10. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Risk Management Plan Verification: <input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID: _____) or previously submitted to DEP (Date and DEP Office: _____) <input type="checkbox"/> Plan to be submitted to CEPPO (Date required: _____) <input checked="" type="checkbox"/> Not Applicable
14. Compliance Report and Plan: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Compliance Certification (Hard-copy Required): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**III. EMISSIONS UNIT INFORMATION**

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION  
(All Emissions Units)**

**Emissions Unit Description and Status**

<p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p>			
<p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>			
<p>3. Description of Emissions Unit Addressed in This Section (limit to 60 characters):  <b>CT001 through CT002 are identical MHI 501F simple cycle combustion turbines (CT) each having a nominal rating 184 megawatts (MW). Each CT will be fired primarily with natural gas with low sulfur distillate oil as a back up fuel.</b></p>			
<p>4. Emissions Unit Identification Number:                  ID: CT001 – CT002                  Unknown</p>		<p><input checked="" type="checkbox"/> No ID  <input type="checkbox"/> ID</p>	
<p>5. Emissions Unit Status Code:                  C</p>	<p>6. Initial Startup Date:                  May 2002</p>	<p>7. Emissions Unit Major Group SIC Code:                  49</p>	<p>8. Acid Rain Unit?  <input checked="" type="checkbox"/></p>
<p>9. Emissions Unit Comment: (Limit to 500 Characters)  <b>Each combustion turbine (CT001 to CT002) should be considered separate emissions units. The grouping of all turbines into one Emissions Unit Information Section has been done for administrative convenience since the information required in Subsections A through J is identical for each combustion turbine.</b></p>			

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

**NOx is limited through use of dry low NOx combustors for natural gas firing and water injection for distillate oil firing.**

2. Control Device or Method Code(s): **028**

**Emissions Unit Details**

1. Package Unit:	
Manufacturer: <b>Mitsubishi Heavy Industries</b>	Model Number: <b>501F</b>
2. Generator Nameplate Rating: <b>184MW (nominal)</b>	
3. Incinerator Information: <b>N/A</b>	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

**B. EMISSIONS UNIT CAPACITY INFORMATION  
(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	<b>1907 mmBtu/hr HHV (base load on natural gas @ 59°F)</b>	
2. Maximum Incineration Rate:	<b>N/A lb/hr</b>	<b>N/A tons/day</b>
3. Maximum Process or Throughput Rate:	<b>N/A</b>	
4. Maximum Production Rate:	<b>N/A</b>	
5. Requested Maximum Operating Schedule:		
	<b>24 hours/day</b>	<b>7 days/week</b>
	<b>52 weeks/year</b>	<b>8760<sup>1</sup> hours/year</b>
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
	<b>1 - Annual operations will be limited through the use of a Continuous Emissions Monitoring System for NO<sub>x</sub> and CO.</b>	

**C. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**List of Applicable Regulations**

<b>40 CFR 60, Subpart A (General Provisions for New Source Performance Standards)</b>	
<b>40 CFR 60.332(a)(1) – NO<sub>x</sub> standards for Stationary Gas Turbines</b>	
<b>40 CFR 60.333 – SO<sub>2</sub> standards for Stationary Gas Turbines</b>	
<b>40 CFR 60.334 – Monitoring Provisions for Stationary Gas Turbines</b>	
<b>40 CFR Part 72 – Acid Rain Program Requirements Regulations</b>	
<b>40 CFR Part 73 – Acid Rain Program SO<sub>2</sub> Allowances System</b>	
<b>40 CFR Part 75 – Acid Rain Program Continuous Emissions Monitoring</b>	
<b>Rule 62-296(4)(b)1 – Visible emissions</b>	

**D. EMISSION POINT (STACK/VENT) INFORMATION**  
**(Regulated Emissions Units Only)**

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? <b>CT1 and CT2</b>		2. Emission Point Type Code: <b>1</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): <b>Exhaust stacks for combustion turbines; one stack per turbine unit.</b>			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: <b>N/A</b>			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>80 feet</b>	7. Exit Diameter: <b>27.68 feet</b> <b>(Effective diameter)</b>	
8. Exit Temperature: <b>1124°F (NG)</b> <b>1006°F (Oil)</b>	9. Actual Volumetric Flow Rate: <b>532,310 acfm (NG)</b> <b>2,395,169 acfm (Oil)</b>	10. Water Vapor: <b>8.45 % (NG)</b> <b>6.51 % (Oil)</b>	
11. Maximum Dry Standard Flow Rate: <b>844,444 dscfm (NG)</b> <b>861,779 dscfm (Oil)</b>		12. Nonstack Emission Point Height: <b>N/A</b> feet	
13. Emission Point UTM Coordinates: Zone: <b>17</b> East (km): <b>565.065</b> North (km): <b>2823.350</b>			
14. Emission Point Comment (limit to 200 characters):  <b>Exhaust temperatures and flow rates (Items 8,9,10,11) are at 100% load and 59° F operating conditions. Stack temperatures and flow rates will vary with load and ambient temperature.</b>			

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment  1  of  2

1. Segment Description (Process/Fuel Type ) (limit to 500 characters): <b>Natural gas</b>		
1. Source Classification Code (SCC): <b>2-01-002-01</b>	3. SCC Units: <b>Million Cubic Feet Burned</b>	
6. Maximum Hourly Rate: <b>1.821</b>	7. Maximum Annual Rate: <b>5264</b>	6. Estimated Annual Activity Factor: <b>N/A</b>
7. Maximum % Sulfur: <b>2 grains/100 SCF</b>	8. Maximum % Ash: <b>N/A</b>	9. Million Btu per SCC Unit: <b>1047</b>
10. Segment Comment (limit to 200 characters): <b>Annual operation will be restricted through the use of NOx and CO CEMS. Maximum Annual Rate is an estimate only.</b>		

**Segment Description and Rate:** Segment  2  of  2

2. Segment Description (Process/Fuel Type) (limit to 500 characters): <b>No. 2 Distillate Fuel Oil</b>		
3. Source Classification Code (SCC): <b>2-01-001-0</b>	3. SCC Units: <b>Thousand Gallons Burned</b>	
4. Maximum Hourly Rate: <b>12.38</b>	5. Maximum Annual Rate: <b>23,692</b>	6. Estimated Annual Activity Factor: <b>N/A</b>
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash: <b>Trace</b>	9. Million Btu per SCC Unit: <b>144.5</b>
10. Segment Comment (limit to 200 characters): <b>Annual operation will be restricted through the use of NOx and CO CEMS. Maximum Annual Rate is an estimate only.</b>		

**F. EMISSIONS UNIT POLLUTANTS  
(All Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
<b>NOX</b>	<b>028</b>		<b>EL</b>
<b>CO</b>			<b>EL</b>
<b>PM</b>			<b>NS</b>
<b>PM10</b>			<b>NS</b>
<b>SO2</b>			<b>NS</b>
<b>VOC</b>			<b>NS</b>
<b>PB</b>			<b>NS</b>



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NOX</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>281 lb/hour (per turbine) 245.5 tons/year (total two turbines)</b>	4. Synthetically Limited? [ <input checked="" type="checkbox"/> ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: <b>0.164 lb/MMBtu (HHV)</b> Reference: <b>See Appendix B for emissions calculations</b>	7. Emissions Method Code: <b>2</b>
8. Calculation of Emissions (limit to 600 characters):  <b>Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil. Annual NOx emissions will be restricted through the use of CEMS.</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>ESCPSD</b>	2. Future Effective Date of Allowable Emissions: <b>N/A</b>
3. Requested Allowable Emissions and Units: <b>245.5 tons/yr (CT1 -CT2)</b>	4. Equivalent Allowable Emissions: <b>N/A lb/hour N/A tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Direct emissions monitoring of stack emissions using Part 75-certified CEMs</b>	
6. Allowable Emissions Comment (Desc. Of Operating Method) (limit to 200 characters):	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>CO</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>204 lb/hour (per turbine)      247.2 tons/year (total two turbines)</b>		4. Synthetically Limited? <input checked="" type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year			
6. Emission Factor: <b>0.119 lb/MMBtu (HHV)</b>  Reference: <b>See Appendix B for emission calculations</b>		7. Emissions Method Code: <b>2</b>	
8. Calculation of Emissions (limit to 600 characters):  <b>Hourly emission rate is based on worst case emissions for both natural gas and distillate oil. Annual CO emissions will be restricted through the use of CEMS.</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions   2   of   2  

1. Basis for Allowable Emissions Code: <b>ESCPSD</b>		2. Future Effective Date of Allowable Emissions: <b>N/A</b>	
3. Requested Allowable Emissions and Units: <b>247.2 tons/yr (CT1 - CT2)</b>		4. Equivalent Allowable Emissions: <b>N/A lb/hour      N/A tons/year</b>	
5. Method of Compliance (limit to 60 characters): <b>Direct emissions monitoring of stack emissions using certified continuous emissions monitors on each turbine stack</b>			
6. Allowable Emissions Comment (Desc. Of Operating Method) (limit to 200 characters):			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM/PM10</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>40 lb/hour (per turbine) 51.04 tons/year (total two turbines)</b>		4. Synthetically Limited? <input checked="" type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b>0.031 lb/MMBtu (HHV)</b> Reference: See Appendix B for emissions calculations		7. Emissions Method Code: <b>2</b>	
8. Calculation of Emissions (limit to 600 characters):  <b>Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil.</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_ N/A

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour                  tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. Of Operating Method) (limit to 200 characters):			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SO2</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>78 lb/hour (per turbine) 75.79 tons/year (total two turbines)</b>		4. Synthetically Limited? <input checked="" type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b>0.046 lb/MMBtu (HHV)</b> Reference: <b>See Appendix B for emissions calculations</b>		7. Emissions Method Code: <b>2</b>	
8. Calculation of Emissions (limit to 600 characters):  <b>Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil.</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_ N/A

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour                  tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>35 lb/hour (per turbine) 34.54 tons/year (total six turbines)</b>	4. Synthetically Limited? <input checked="" type="checkbox"/>
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: <b>0.021 lb/MMBtu (HHV)</b> Reference: <b>See Appendix B for emissions calculations</b>	7. Emissions Method Code: <b>2</b>
8. Calculation of Emissions (limit to 600 characters):  <b>Hourly emission rate is based on worst case emission rate for both natural gas and distillate oil.</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_ **N/A**

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour                  tons/year
5. Method of Compliance (limit to 60 characters):	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	



**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

**Supplemental Requirements**

1. Process Flow Diagram <input checked="" type="checkbox"/> Attached, Document ID: <b>Fig. 2-2</b> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input checked="" type="checkbox"/> Attached, Document ID: <b>App. B</b> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Previously submitted, Date:_____ <input checked="" type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input checked="" type="checkbox"/> Attached, Document ID: <b>ENSR Doc. No. 6792-123-410</b>
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:

**Emissions Unit Information Section 1 of 2**

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

11. Alternative Methods of Operation [ ] Attached, Document ID: _____ [✓] Not Applicable
12. Alternative Modes of Operation (Emissions Trading) [ ] Attached, Document ID: _____ [✓] Not Applicable
13. Identification of Additional Applicable Requirements [ ] Attached, Document ID: _____ [✓] Not Applicable
14. Compliance Assurance Monitoring Plan [ ] Attached, Document ID: _____ [✓] Not Applicable
15. Acid Rain Part Application (Hard-copy Required) [ ] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ [ ] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ [ ] New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ [ ] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ [ ] Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ [ ] Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ [ ] Not Applicable



**III. TANK EMISSIONS UNIT INFORMATION**

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION  
(All Emissions Units)**

**Emissions Unit Description and Status**

<p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p>			
<p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>			
<p>3. Description of Emissions Unit Addressed in This Section (limit to 60 characters):</p> <p><b>Distillate fuel oil storage tanks</b></p>			
<p>4. Emissions Unit Identification Number:</p> <p><b>ID: T001, T002</b></p>		<p><input checked="" type="checkbox"/> No ID</p> <p><input type="checkbox"/> ID Unknown</p>	
<p>5. Emissions Unit Status Code:</p> <p><b>C</b></p>	<p>6. Initial Startup Date:</p> <p><b>May 2002</b></p>	<p>7. Emissions Unit Major Group SIC Code:</p> <p><b>49</b></p>	<p>8. Acid Rain Unit?</p> <p><input type="checkbox"/></p>
<p>9. Emissions Unit Comment: (Limit to 500 Characters)</p> <p><b>T001 - main storage tank</b></p> <p><b>T002 - day storage tank.</b></p>			

**Emissions Unit Information Section 2 of 2**

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

**None**

2. Control Device or Method Code(s):

**Emissions Unit Details**

1. Package Unit:

Manufacturer:

Model Number:

2. Generator Nameplate Rating:

MW

3. Incinerator Information:

Dwell Temperature:

°F

Dwell Time:

seconds

Incinerator Afterburner Temperature:

°F

**B. EMISSIONS UNIT CAPACITY INFORMATION  
(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate: N/A mmBtu/hr
2. Maximum Incineration Rate: N/A lb/hr N/A tons/day
3. Maximum Process or Throughput Rate: <b>22,660,000 gal/year</b>
4. Maximum Production Rate: N/A
5. Requested Maximum Operating Schedule: <div style="text-align: center;"> <p><b>24 hours/day</b> <span style="float: right;"><b>7 days/week</b></span></p> <p><b>52 weeks/year</b> <span style="float: right;"><b>8760 hours/year</b></span></p> </div>
6. Operating Capacity/Schedule Comment (limit to 200 characters):



Emissions Unit Information Section 2 of 2

**D. EMISSION POINT (STACK/VENT) INFORMATION**  
**(Regulated Emissions Units Only)**

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? <b>T001 + T002</b>		2. Emission Point Type Code: <b>4</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): <b>N/A</b>			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: <b>N/A</b>			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>N/A feet</b>	7. Exit Diameter: <b>N/A feet</b>	
8. Exit Temperature: <b>N/A</b>	9. Actual Volumetric Flow Rate: <b>N/A</b>	10. Water Vapor: <b>N/A</b>	
11. Maximum Dry Standard Flow Rate: <b>N/A dscfm</b>		12. Nonstack Emission Point Height: <b>N/A feet</b>	
13. Emission Point UTM Coordinates: Zone: <b>17</b> East (km): <b>565.048 (Main Tank); 565.116 (Day Tank)</b> North (km): <b>2823.498 (Main Tank); 2823.498 (Day Tank)</b>			
14. Emission Point Comment (limit to 200 characters):			

**E. SEGMENT (PROCESS/FUEL) INFORMATION  
(All Emissions Units)**

**Segment Description and Rate:** Segment 1 of 1

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Distillate fuel oil storage tanks</b>		
2. Source Classification Code (SCC): <b>40301021</b>		3. SCC Units: <b>Thousand Gallons Throughput</b>
4. Maximum Hourly Rate: <b>N/A</b>	5. Maximum Annual Rate: <b>22,600</b>	6. Estimated Annual Activity Factor: <b>N/A</b>
7. Maximum % Sulfur: <b>N/A</b>	8. Maximum % Ash: <b>N/A</b>	9. Million Btu per SCC Unit: <b>N/A</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment \_\_\_ of \_\_\_\_

1. Segment Description (Process/Fuel Type ) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

**F. EMISSIONS UNIT POLLUTANTS**  
**(All Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour                  tons/year		4. Synthetically Limited? <input type="checkbox"/> <input type="checkbox"/>	
5. Range of Estimated Fugitive Emissions: [ ] 1                  [ ] 2                  [ ] 3                  _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <p align="center"><b>Potential VOC emissions from distillate fuel oil storage tanks are less than 5 tons per year (less than the threshold amount for reporting in this subsection). See Appendix B for emission calculations.</b></p>			

**Allowable Emissions** Allowable Emissions 1 of 1 N/A

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour                  tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			







**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

**Supplemental Requirements N/A**

1. Process Flow Diagram <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input type="checkbox"/> Attached, Document ID: _____
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:          

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

**Emissions Unit Information Section 2 of 2**

**APPENDIX B**  
**EMISSION CALCULATIONS**

**ENSR**  
**Dade Development Co. LLC**  
**South Dade Energy Center**  
**MHI 501F Simple Cycle Natural Gas Emissions**  
**EMISSIONS COMPUTATION PER CTG**  
**GAS Fired CTG**

Date 3/21/2001  
 Author J. Lubetsky  
 Checked By M. Griffin  
 Revision 1

	1	2	3	4	5	6	7	8
<b>CASE NUMBER and OPERATION CONDITIONS</b>								
(1) AMBIENT TEMPERATURE, °F	32	50	74	95	32	50	74	95
(1) RELATIVE HUMIDITY, %	65%	65%	65%	65%	65%	65%	65%	65%
CTG LOAD	100%	100%	100%	100%	75%	75%	75%	75%
CHILLER STATUS	OFF	ON	ON	ON	OFF	OFF	OFF	OFF
(1) CTG EFFECTIVE INLET TEMPERATURE, F	32	45	45	45	32	50	74	95
(1) CTG EFFECTIVE INLET RELATIVE HUMIDITY, %	65%	100%	100%	100%	65%	65%	65%	65%
(1) CTG NET POWER OUTPUT, kW	185,130	183,900	183,900	183,900	138,820	131,840	124,940	115,660
(1) CTG FUEL CONSUMPTION, MMBtu/hr LHV	1,717	1,718	1,718	1,718	1,268	1,214	1,211	1,211
(1) CTG FUEL CONSUMPTION, lb/hr	82,212	82,260	82,260	82,260	65,408	62,918	60,761	57,984
CTG FUEL CONSUMPTION, MMBtu/hr HHV	1,806	1,907	1,907	1,907	1,516	1,459	1,409	1,344
(1) CTG EXHAUST GAS FLOW RATE, 1000 lb/hr	3,743	3,730	3,730	3,730	2,663	2,945	2,893	2,618
(1) STACK TEMPERATURE, °F	112	124	124	124	146	148	148	148
<b>CTG STACK EXHAUST ANALYSIS (%VOL)</b>								
(1) ARGON + NITROGEN	75.74%	75.28%	75.28%	75.28%	75.75%	75.30%	74.78%	73.49%
(1) OXYGEN	12.53%	12.40%	12.40%	12.40%	12.55%	12.54%	12.65%	12.50%
(1) CARBON DIOXIDE	3.67%	3.86%	3.86%	3.86%	3.66%	3.79%	3.86%	3.89%
(1) WATER	7.95%	8.46%	8.46%	8.46%	7.84%	8.31%	8.86%	10.42%
TOTAL	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
CTG EXHAUST MOLECULAR WEIGHT	28.45	28.39	28.39	28.39	28.45	28.39	28.39	28.15
CTG EXHAUST GAS FLOW RATE, lb mol/hr	131,548	131,390	131,390	131,390	104,835	103,723	102,142	100,122
CTG EXHAUST GAS FLOW RATE, DRY, lb mol/hr	121,218	120,290	120,290	120,290	96,821	95,106	93,067	89,886
<b>EXH. PARAMETERS @ STACK</b>								
(5) STACK DIAMETER, ft	27.68	27.68	27.68	27.68	27.68	27.68	27.68	27.68
MOLECULAR WEIGHT	28.45	28.39	28.39	28.39	28.45	28.39	28.39	28.15
STACK EXHAUST GAS FLOW RATE, lb/hr	3,743,000	3,730,000	3,730,000	3,730,000	2,963,000	2,945,000	2,893,000	2,618,000
SPECIFIC VOLUME, ft³/lb	40.3	40.7	40.7	40.7	41.3	41.3	41.4	41.7
VOLUMETRIC FLOW, acfm	2,518,114	2,532,310	2,532,310	2,532,310	2,051,142	2,029,371	1,998,442	1,958,913
DRY STANDARD FLOW RATE, dscfm	844,444	843,390	843,390	843,390	672,962	665,807	655,622	642,555
EXIT VELOCITY, ft/sec	69.7	70.1	70.1	70.1	56.8	56.2	55.4	54.3
ACTUAL O2% DRY	13.8%	13.5%	13.5%	13.5%	13.6%	13.8%	13.9%	14.0%
MOLES EXHAUST GAS per HOUR WET	131,548	131,390	131,390	131,390	104,835	103,723	102,142	100,122
MOLES EXHAUST GAS per HOUR DRY	121,218	120,290	120,290	120,290	96,821	95,106	93,067	89,886
<b>NOx EMISSION CALCULATION</b>								
(1) LIMIT, ppmVd @ 15% O2	25.0	25.0	25.0	25.0	27.0	25.0	25.0	25.0
LIMIT, ppmVd	30.9	31.2	31.2	31.2	33.0	30.2	29.7	29.4
CORRESPONDING MASS RATE, lb/hr as NO2	173	173	173	173	148	132	128	122
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV	0.091	0.091	0.091	0.091	0.088	0.091	0.091	0.091
<b>CO EMISSION CALCULATION</b>								
(6) LIMIT, ppmVd @ 15% O2	11	10	10	10	16	15	15	15
CTG Exhaust, ppmVd	13.6	12.5	12.5	12.5	19.8	18.1	17.8	17.7
CTG MASS RATE, lb/hr	47	42	42	42	54	49	47	45
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.025	0.022	0.022	0.022	0.038	0.034	0.033	0.033
<b>PARTICULATE EMISSION CALCULATION</b>								
(2) CTG EXHAUST, lb/hr	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV	0.010	0.010	0.010	0.010	0.013	0.014	0.014	0.015
<b>VOC EMISSION CALCULATION</b>								
(3) LIMIT, ppmVd @ 15% O2	1.0	1.0	1.0	1.0	2.0	1.0	1.0	1.0
CTG Exhaust, ppmVd	1.2	1.2	1.2	1.2	2.5	1.2	1.2	1.2
CTG MASS RATE, lb/hr	3.0	3.0	3.0	3.0	4.0	2.0	2.0	2.0
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.0016	0.0016	0.0016	0.0016	0.0026	0.0014	0.0014	0.0015
<b>Pb EMISSION CALCULATION</b>								
Pb EMISSION FACTOR, lb/MMBtu	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
STACK EMISSIONS, lb/hr	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>SO2 EMISSION CALCULATION</b>								
(4) CTG EMISSIONS, lb/hr	11.3	11.3	11.3	11.3	9.0	8.7	8.4	8.0
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.006	0.006	0.006	0.006	0.006	0.006	0.006	0.006
STACK EMISSIONS, ppmVd @ ACTUAL O2	1.5	1.5	1.5	1.5	1.5	1.4	1.4	1.4
STACK EMISSIONS, ppmVd @ 15% O2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
<b>H2SO4 EMISSION CALCULATION</b>								
(4) CTG EMISSIONS, lb/hr	1.8	1.8	1.8	1.8	1.4	1.4	1.3	1.3
CTG EMISSIONS FACTOR, lb/MMBtu HHV	0.0009	0.0009	0.0009	0.0009	0.0009	0.0010	0.0009	0.0010

**SITE CONDITIONS**

FUEL TYPE: Natural Gas

FUEL LHV, Btu/lb: 20685

FUEL LHV, Btu/SCF: 868.3

FUEL HHV, Btu/SCF: 964.5

FUEL SULFUR CONTENT [grams per 100 SCF]: 2

**CONTROL EQUIPMENT LIMITS**

NOx PERMIT LIMIT, ppmVd @ 15% O2: 25

**SO2 TO H2SO4 CONVERSION**

(7) % CONVERSION, SO2 TO H2SO4: 10%

- Notes**
- Based on MHI501F data provided in e-mail from Dave Kellermeyer (e-mail dated March 15, 2001)
  - PM10 Emission rate based on data provided in e-mail from Dave Kellermeyer March 15, 2001
  - VOC Emission limit based on data provided in e-mail from Dave Kellermeyer March 15, 2001
  - SO2 emissions calculated based on fuel sulfur content of 2 grams per 100 standard cubic foot
  - Stack diameter based on conversation with Chris Booth, May 23, 2000
  - CO Emission limit based on data provided in e-mail from Dave Kellermeyer March 15, 2001
  - Assume 10% of SO2 is converted to H2SO4

Dade Development Co. LLC  
 South Dade Energy Center  
 MHI 501F - Calculation of Exhaust Composition

		Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
<b>CTG STACK EXHAUST ANALYSIS (%VOL)</b>		<b>Mol Wt</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>
	ARGON	39.95	11.32%	11.31%	11.31%	11.31%	11.92%	11.31%	11.29%
	NITROGEN	28.013	73.63%	73.35%	73.35%	73.35%	73.64%	73.36%	72.23%
	OXYGEN	31.998	14.09%	13.97%	13.97%	13.97%	14.11%	14.24%	14.21%
	CARBON DIOXIDE	44.009	5.99%	6.01%	6.01%	6.01%	5.97%	5.82%	5.60%
	WATER	18.015	4.97%	5.36%	5.36%	5.36%	4.98%	5.27%	6.67%
			<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>
	ARGON		0.00033	0.00033	0.00033	0.00033	0.00033	0.00033	0.00032
	NITROGEN		0.02628	0.02618	0.02618	0.02618	0.02629	0.02619	0.02578
	OXYGEN		0.00440	0.00437	0.00437	0.00437	0.00441	0.00445	0.00444
	CARBON DIOXIDE		0.00136	0.00137	0.00137	0.00137	0.00136	0.00132	0.00127
	WATER		0.00276	0.00298	0.00298	0.00298	0.00275	0.00293	0.00370
			<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>
	ARGON		0.94%	0.93%	0.93%	0.93%	0.94%	0.93%	0.91%
	NITROGEN		74.80%	74.35%	74.35%	74.35%	74.81%	74.37%	72.58%
	NITROGEN +ARGON		75.74%	75.28%	75.28%	75.28%	75.75%	75.30%	73.49%
	OXYGEN		12.53%	12.40%	12.40%	12.40%	12.55%	12.64%	12.50%
	CARBON DIOXIDE		3.87%	3.88%	3.88%	3.88%	3.86%	3.76%	3.58%
	WATER		7.85%	8.45%	8.45%	8.45%	7.84%	8.31%	10.42%



ENSR  
 South Dade Development Co. LLC  
 South Dade Energy Center  
 MHI 501F Simple Cycle Oil Emissions  
 EMISSIONS COMPUTATION PER CTG  
 Oil Fired CTG

Date 3/21/2001  
 Author J. Lubetsky  
 Checked By M. Griffin  
 Revision 1

CASE NUMBER and OPERATION CONDITIONS		1	2	3	4	5	6	7	8
(1) AMBIENT TEMPERATURE, °F		77.711	75.221	75.221	75.221	82.389	58.807	58.807	54.108
(1) RELATIVE HUMIDITY, %		77.711	75.221	75.221	75.221	82.389	58.807	58.807	54.108
CTG LOAD		100%	100%	100%	100%	75%	75%	75%	75%
CHILLER STATUS		OFF	ON	ON	ON	OFF	OFF	OFF	OFF
(1) CTG EFFECTIVE INLET TEMPERATURE, F		82.389	80.159	80.159	80.159	82.389	80.159	80.159	80.159
(1) CTG EFFECTIVE INLET RELATIVE HUMIDITY, %		82.389	80.159	80.159	80.159	82.389	80.159	80.159	80.159
(1) CTG NET POWER OUTPUT, kW		156,020	156,140	156,140	156,140	124,200	112,480	110,250	97,790
(1) CTG FUEL CONSUMPTION, MMBtu/hr LHV		1,623	1,571	1,571	1,571	1,309	1,224	1,184	1,030
(1) CTG FUEL CONSUMPTION, MMBtu/hr HHV		1,720	1,665	1,665	1,665	1,381	1,297	1,255	1,198
(1) CTG EXHAUST GAS FLOW RATE, 1000 lb/hr		3,088	3,781	3,781	3,781	3,044	2,898	2,815	2,662
(1) STACK TEMPERATURE, °F		1,108	1,014	1,014	1,014	1,064	1,088	1,089	1,124
<b>CTG STACK EXHAUST ANALYSIS (%VOL)</b>									
(1) ARGON + NITROGEN		78.00%	75.55%	75.55%	75.55%	75.94%	75.43%	74.90%	73.57%
(1) OXYGEN		13.27%	13.20%	13.20%	13.20%	13.12%	13.10%	13.00%	12.80%
(1) CARBON DIOXIDE		4.77%	4.74%	4.74%	4.74%	4.62%	4.80%	4.70%	4.72%
(1) WATER		5.95%	6.51%	6.51%	6.51%	6.08%	6.87%	7.34%	8.01%
TOTAL		100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
CTG EXHAUST MOLECULAR WEIGHT		28.82	28.75	28.75	28.75	28.82	28.74	28.68	28.48
CTG EXHAUST GAS FLOW RATE, lb mol/hr		134,223	130,807	130,807	130,807	105,835	100,757	98,203	94,531
CTG EXHAUST GAS FLOW RATE, DRY, lb mol/hr		126,234	122,287	122,287	122,287	99,229	94,036	90,999	86,012
<b>EXH. PARAMETERS @ STACK</b>									
(5) STACK DIAMETER, ft		27.68	27.68	27.68	27.68	27.68	27.68	27.68	27.68
MOLECULAR WEIGHT		28.82	28.75	28.75	28.75	28.82	28.74	28.68	28.48
STACK EXHAUST GAS FLOW RATE, lb/hr		3,868,000	3,781,000	3,781,000	3,781,000	3,044,000	2,898,000	2,815,000	2,692,000
SPECIFIC VOLUME, ft³/lb		37.1	37.4	37.4	37.4	38.6	39.3	39.7	40.5
VOLUMETRIC FLOW, acfm		2,394,169	2,345,962	2,345,962	2,345,962	1,958,790	1,895,314	1,862,822	1,818,478
DRY STANDARD FLOW RATE, dscfm		881,779	839,797	839,797	839,797	678,225	646,888	630,435	606,781
EXIT VELOCITY, ft/sec		66.3	65.0	65.0	65.0	54.3	52.5	51.6	50.4
ACTUAL O2% DRY		14.1%	14.1%	14.1%	14.1%	14.0%	14.0%	14.0%	14.0%
MOLES EXHAUST GAS per HOUR WET		134,223	130,807	130,807	130,807	105,835	100,757	98,203	94,531
MOLES EXHAUST GAS per HOUR DRY		126,234	122,287	122,287	122,287	99,229	94,036	90,999	86,012
<b>NOx EMISSION CALCULATION</b>									
(1) LIMIT, ppmVd @ 15% O2		42	42	42	42	42	42	42	42
LIMIT, ppmVd		48.3	48.2	48.2	48.2	48.3	48.9	48.9	49.5
CORRESPONDING MASS RATE, lb/hr as NO2		281	272	272	272	226	212	205	196
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV		0.163	0.163	0.163	0.163	0.164	0.163	0.163	0.164
<b>CO EMISSION CALCULATION</b>									
(6) LIMIT, ppmVd @ 15% O2		50	50	50	50	50	50	50	50
CTG Exhaust, ppmVd		57.6	57.4	57.4	57.4	58.7	58.2	58.9	58.9
CTG MASS RATE, lb/hr		204	197	197	197	164	154	149	142
CTG EMISSIONS FACTOR, lb/MMBtu HHV		0.119	0.118	0.118	0.118	0.119	0.119	0.119	0.119
<b>PARTICULATE EMISSION CALCULATION</b>									
(2) CTG EXHAUST, lb/hr		0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40
CORRESPONDING EMISSIONS FACTOR, lb/MMBtu HHV		0.023	0.024	0.024	0.024	0.028	0.031	0.032	0.033
<b>VOC EMISSION CALCULATION</b>									
(3) LIMIT, ppmVd @ 15% O2		15	15	15	15	15	15	15	15
CTG Exhaust, ppmVd		17.3	17.2	17.2	17.2	17.6	17.5	17.5	17.7
CTG MASS RATE, lb/hr		35	34	34	34	28	27	26	25
CTG EMISSIONS FACTOR, lb/MMBtu HHV		0.020	0.020	0.020	0.020	0.020	0.021	0.021	0.021
<b>Pb EMISSION CALCULATION</b>									
PB EMISSION FACTOR, lb/MMBtu		0.000014	0.000014	0.000014	0.000014	0.000014	0.000014	0.000014	0.000014
STACK EMISSIONS, lb/hr		0.023	0.022	0.022	0.022	0.018	0.017	0.017	0.016
<b>SO2 EMISSION CALCULATION</b>									
(4) CTG EMISSIONS, lb/hr		78	76	76	76	63	59	57	55
CTG EMISSIONS FACTOR, lb/MMBtu HHV		0.045	0.046	0.046	0.046	0.046	0.045	0.045	0.046
STACK EMISSIONS, ppmVd @ ACTUAL O2		9.6	9.7	9.7	9.7	9.9	9.8	9.8	10.0
STACK EMISSIONS, ppmVd @ 15% O2		8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.5
<b>H2SO4 EMISSION CALCULATION</b>									
(4) CTG EMISSIONS, lb/hr		12.0	11.7	11.7	11.7	9.7	9.1	8.8	8.5
CTG EMISSIONS FACTOR, lb/MMBtu HHV		0.0070	0.0070	0.0070	0.0070	0.0070	0.0070	0.0070	0.0071

<b>SITE CONDITIONS</b>	
FUEL TYPE	Distillate Oil
FUEL LHV, Btu/lb	18180
FUEL SULFUR CONTENT [wt % S]	0.005
<b>CONTROL EQUIPMENT LIMITS</b>	
NOx PERMIT LIMIT, ppmVd @ 15% O2	42
<b>SO2 TO H2SO4 CONVERSION</b>	
(7) % CONVERSION, SO2 TO H2SO4	10%

- Notes**
- Based on MHI501F data provided in e-mail from Dave Kellermeyer (e-mail dated March 15, 2001)
  - PM10 Emission rate based on data provided in e-mail from Dave Kellermeyer March 15, 2001.
  - VOC Emission limit based on data provided in e-mail from Dave Kellermeyer March 15, 2001
  - SO2 emissions calculated based on fuel sulfur content.
  - Stack diameter based on conversation with Chris Booth, May 23, 2000
  - CO Emission limit based on data provided in e-mail from Dave Kellermeyer March 15, 2001
  - Assume 10% of SO2 is converted to H2SO4.

**Dade Development Co. LLC  
 South Dade Energy Center  
 MHI 501F - Calculation of Exhaust Composition**

		Case 1	Case 2	Case 3	Case 4	Case 5	Case 6	Case 7	Case 8
<b>CTG STACK EXHAUST ANALYSIS</b>	<b>Mol Wt</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>	<b>% weight</b>
	ARGON	39.95	1.31%	1.30%	1.30%	1.31%	1.30%	1.29%	1.28%
	NITROGEN	28.013	72.95%	72.68%	72.68%	72.89%	72.59%	72.28%	71.46%
	OXYGEN	31.998	14.73%	14.69%	14.69%	14.57%	14.58%	14.51%	14.26%
	CARBON DIOXIDE	44.009	7.29%	7.25%	7.25%	7.25%	7.35%	7.31%	7.30%
	WATER	18.015	3.72%	4.08%	4.08%	4.08%	4.18%	4.61%	5.70%
		<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>	<b>Mol</b>
	ARGON	0.00033	0.00033	0.00033	0.00033	0.00033	0.00033	0.00032	0.00032
	NITROGEN	0.02604	0.02594	0.02594	0.02594	0.02602	0.02591	0.02580	0.02551
	OXYGEN	0.00460	0.00459	0.00459	0.00459	0.00455	0.00456	0.00453	0.00446
	CARBON DIOXIDE	0.00166	0.00165	0.00165	0.00165	0.00169	0.00167	0.00166	0.00166
	WATER	0.00206	0.00226	0.00226	0.00226	0.00210	0.00232	0.00256	0.00316
		<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>	<b>(%Vol)</b>
	ARGON	0.95%	0.94%	0.94%	0.94%	0.95%	0.94%	0.93%	0.91%
	NITROGEN	75.06%	74.61%	74.61%	74.61%	74.99%	74.49%	73.97%	72.66%
	NITROGEN +ARGON	76.00%	75.55%	75.55%	75.55%	75.94%	75.43%	74.90%	73.57%
	OXYGEN	13.27%	13.20%	13.20%	13.20%	13.12%	13.10%	13.00%	12.69%
	CARBON DIOXIDE	4.77%	4.74%	4.74%	4.74%	4.87%	4.80%	4.76%	4.72%
	WATER	5.95%	6.51%	6.51%	6.51%	6.06%	6.67%	7.34%	9.01%

**CALCULATIONS AND COMPUTATIONS**

Project: South Dade Energy Center, Dade Development Co. LLC.

Project Number: 6792-140-410

Computed by: J. Lubetsky

Date: 3/21/2001

Subject: Fire-Water Pump Emission Calculations

Checked by: M. Griffin

Date: 4/9/2001

Emission Source: Fire-Water Pump Engine

Source Type: Diesel Fueled Reciprocating Engine  
250 Horsepower

Operating Hours per Year: 500

Compound	Emission		Emission Rate	
	Factor (a)		Hourly (b)	Annual (c)
	(Lbs/hp hr)	(lb/MMBtu)	(Lbs/Hr)	(Tons/Year)
Nitrogen Oxides	0.031		7.8	2.0
Carbon Monoxide	0.00668		1.7	0.4
Volatile Organic Carbon	0.00247		0.6	0.2
Sulfur Oxides	0.00205		0.5	0.1
Particulate	0.0022		0.6	0.2
Benzene	6.53E-06	9.33E-04	1.63E-03	4.08E-04
Toluene	2.86E-06	4.09E-04	7.16E-04	1.79E-04
Xylenes	2.00E-06	2.85E-04	4.99E-04	1.25E-04
Propylene	1.81E-05	2.58E-03	4.52E-03	1.13E-03
1,3-Butadiene	2.74E-07	3.91E-05	6.84E-05	1.71E-05
Formaldehyde	8.26E-06	1.18E-03	2.07E-03	5.16E-04
Acetaldehyde	5.37E-06	7.67E-04	1.34E-03	3.36E-04
Acrolein	6.48E-07	9.25E-05	1.62E-04	4.05E-05
PAH	1.18E-06	1.68E-04	2.94E-04	7.35E-05

Total HAPS 5.6 lb/year

Notes:

- (a) Emission Factors from AP-42, Section 3.3, Table 3.3-1
- (b) Hourly Emission Rate (Lbs/Hr) = (Emission Factor, Lbs/BHP) \* (Horsepower, BHP)
- (c) Annual Emission Rate (Tons/Yr) = (Hourly Emission Rate, Lbs/Hr) \* (Hour of Operation Per Year, Hr/Yr) / (2,000 Lbs/Ton)

### CALCULATIONS AND COMPUTATIONS

Project: South Dade Energy Center, Dade Development Co. LLC. Computed by: J. Lubetsky Date: 3/27/2001  
 Project Number: 6792-123-610 Checked by: M. Griffin Date: 4/9/2001  
 Subject: Natural Gas Heater - Emission Calculations

Emission Source:	Natural Gas Heater
Heat Input (MMBtu/hr):	6
Number of Units:	1
Sulfur Content of Fuel (grains/scf):	0.02
Fuel Heating Value, HHV (Btu/scf):	1047
LHV (Btu/scf):	946
Operating Hours per Year:	1500
Fuel Feed Rate (scf/HR):	5731

Compound	Emission Factor (a)	Emission Rate - per Unit	
	(Lbs/MMBtu)	Hourly (b) (Lbs/Hr)	Annual (c) (Tons/Year)
Criteria Pollutants			
Nitrogen Oxides	0.102	0.612	0.459
Carbon Monoxide	0.09	0.54	0.405
Volatile Organic Carbon	0.06	0.36	0.27
Sulfur Oxides (d)	0.003	0.016	0.012
Particulate	0.01	0.06	0.045

**Notes:**

- (a) Emission Factors based on the information supplied by ENRON on 8/11/99.
- (b) Hourly Emission Rate (Lbs/Hr) = (Heat Input \* Emission Factor)
- (c) Annual Emission Rate (Tons/Yr) = (Hourly Emission Rate, Lbs/Hr) \*  
(Hour of Operation Per Year, Hr/Yr) / (2,000 Lbs/Ton)
- (d) Sulfur Oxides Emission Rate (Lbs/Hr) based on the sulfur content of the fuel.

CALCULATIONS AND COMPUTATIONS

Project: South Dade Energy Center, Dade Development Co. LLC.

Project Number: 6792-123-610

Computed by: K. Field

Date: 10/2/2000

Subject: Cooling Tower Emissions

Checked by: M. Griffin

Date: 4/9/2001

Water Circulation Rate (a), per cell	(GPM)	4,000
Number of Cells		4
Total Water Circulation Rate (a), all cells	(GPM)	16,000
Annual Operation	(hrs/year)	8,760
Total Liquid Drift (b)	(%)	0.001
Expected TDS/TSS of Circulated Water (c)	(ppmw)	2085
Emission Rate - Total Cooling Tower		
Total Suspended Particulate (d)	(Lbs/Hr)	0.167
	(Tons/Yr)	0.732

- Notes:
- (a) Design Water Circulation Rate, Gallons/Minute (GPM)
  - (b) Design Total Liquid Drift, Percent (%)
  - (c) Process Design Data
  - (d) Based on USEPA AP-42 Section 13.4 Wet Cooling Towers, Table 13.4-1. Modified to Cooling Tower Design  

$$\text{Lbs/Hr} = (\text{Water Circulation Rate, GPM}) * 60 * (\text{Drift, \%}) / 100 * (8.3453 \text{ Lbs/Gal}) * (\text{TDS, Lbs PM}/1,000,000 \text{ Lbs Water})$$

$$\text{Tons/Yr} = (\text{Lbs/Hr}) * (8,760 \text{ Hrs/Yr}) / (2,000 \text{ Lbs/Ton})$$

South Dade Energy Center, Dade Development Co. LLC.

Pollutant	CTG Natural Gas Short Term Emission Limits			CTG Distillate Oil Short Term Emission Limit			Compliance Method <sup>(7)</sup>	Fuel Use Calculation			Annual Emissions			
								Maximum CTG Emissions for Minor Source <sup>(1)</sup>	Natural Gas No Oil Annual Fuel Use <sup>(6)</sup>	Distillate Oil Annual Fuel Use <sup>(5)</sup>	Option 1 Natural Gas Fired CTGs <sup>(6)</sup>	Option 2 Distillate Oil Fired CTGs <sup>(6)</sup>	Worst Case CTG Emissions <sup>(4)</sup>	Ancillary Equipment Emissions
	ppmvd @ 15% O <sub>2</sub>	lb/MMBtu (HHV)	Max lb/hr <sup>(1)</sup>	ppmvd @ 15% O <sub>2</sub>	lb/MMBtu (HHV)	Max lb/hr <sup>(1)</sup>		tons/year	MMBtu/yr (HHV)	MMBtu/yr (HHV)	(tpy)	(tpy)	(tpy)	(tpy)
NOx	27	0.098	173	42	0.164	281	CEMS	245.5	5,010,204	2,993,902	245.5	245.5	245.5	2.5
CO	16	0.036	54	50	0.119	204.0	CEMS	247.2	13,733,333	4,154,622	247.2	247.2	247.2	0.8
VOC	2	0.003	4	15	0.021	35	Fuel Tracking	218.7	145,800,000	20,828,571	7.5	31.4	34.54	1.3
Pb	N/A	0	0	N/A	0.000014	0.02	Fuel Tracking	220	N/A	31,428,571,429	0	0.02	0.02	0.0
PM10 <sup>(2)</sup>	N/A	0.015	20	N/A	0.031	40	Fuel Tracking	219	29,200,000	14,129,032	37.6	46.4	51.04	1.0
H2SO4	N/A	0.001	1.8	N/A	0.007	12	Fuel Tracking	220	440,000,000	62,857,143	2.5	10.5	11.55	0.0
SO2	N/A	0.006	11.3	N/A	0.046	78	Fuel Tracking	219.9	73,300,000	9,560,870	15	68.9	75.79	0.1
Estimated Fuel Cap <sup>(4)</sup>									5,010,204	2,993,902	Margin		10%	
Total CTG Hours/Year									2,627	1,798				
Hours/CTG/Year									1,314	899				

Notes

- (1) CTG Emissions = Total Facility Emissions - (Fire Water Pump Engine Emissions + Natural Gas Heater + Tank Emissions)
- (2) PM10 emissions limited based on lb/hr emission rate, lb/MMBtu value calculated only for demonstration of compliance with Minor Source Status
- (3) NOx and CO limited based on CEMS. To provide the most conservative estimate of non-CEMS monitored pollutant emissions the maximum annual fuel consumption limited by the NOx fuel cap is used.
- (4) Worst Case of Natural Gas and Distillate Oil Case VOC, PM10, and SO2 emissions include a margin of 10%.
- (5) [Annual Fuel Use (MMBtu/yr (HHV))] = [Maximum CTG Emissions (tons/year)] x [2,000 lb/ton] / [Emission Factor (lb/MMBtu (HHV))]
- (6) [CTG Annual Emissions (tons/year)] = [Estimated Fuel Cap (MMBtu/yr (HHV))] \* [Emission Factor (lb/MMBtu (HHV))] / [2,000 lb/ton]
- (7) For pollutants monitored by CEMS, maximum annual allowable emissions are assumed to be 248 tpy For pollutants monitored through fuel tracking, maximum annual allowable emissions are assumed to be 220 tpy.

**South Dade Energy Center, Dade Development Co. LLC.  
NSPS NO<sub>x</sub> Emission Standard Calculation**

<b>Turbine MHI 501F</b>	
<b>Fuel Natural Gas</b>	
Maximum Electrical Capacity	183.9 MW
Maximum Energy Input	1,718 MMBtu/hr (LHV) 1,813,520,800 kJ/hr
Heat Rate	9,342 Btu/kWh 9.9 kJ/Wh
NSPS Subpart GG NO <sub>x</sub> Limit	0.0110% Volume % NO <sub>x</sub> @ 15% O <sub>2</sub> 110 ppmvd @ 15% O <sub>2</sub>

<b>Turbine MHI 501F</b>	
<b>Fuel Distillate Oil</b>	
Maximum Electrical Capacity	159.1 MW
Maximum Energy Input	1,571 MMBtu/hr (LHV) 1,658,347,600 kJ/hr
Heat Rate	9,872 Btu/kWh 10.4 kJ/Wh
NSPS Subpart GG NO <sub>x</sub> Limit	0.0104% Volume % NO <sub>x</sub> @ 15% O <sub>2</sub> 104 ppmvd @ 15% O <sub>2</sub>

**Calculations and Computations**

**HAP Emissions from Combined Cycle CTG Facility**

Project: South Dade Energy Center, Dade Development Co. LLC.  
 Project Number: 8792-140-410  
 Subject: Natural Gas/Distillate Oil Fired Turbine Non-Criteria Regulated Pollutant Emissions Calculations

Computed by: J. Lubetaky Date: 3/27/2001  
 Checked by: M. Griffin Date: 4/9/2001

Pollutant	Type <sup>(a)</sup>	Emission Factor		Rating	Emission Factor		CTG Natural Gas Combustion		Distillate Oil		CTG Natural Gas		CTG Distillate Oil		Facility		Facility Major Source
		AP-42 Section 3.1 04/00 - Combustion Turbine Natural Gas			AP-42 Section 3.1 04/00 - Combustion Turbine No. 2 Fuel Oil		Maximum Heat Input	Average Heat Input	Maximum Heat Input	Average Heat Input	Emission Rate, Per Turbine		Emission Rate, Per Turbine		Emission Rate All CTGs		
		(lb/10 <sup>6</sup> scf)	(lb/MMBtu) <sup>(f)</sup>		(lb/10 <sup>3</sup> gallons)	(lb/MMBtu) <sup>(f)</sup>	per turbine (MMBtu/Hr) <sup>(g)</sup>	per turbine (MMBtu/Hr) <sup>(g)</sup>	per turbine (MMBtu/Hr) <sup>(g)</sup>	per turbine (MMBtu/Hr) <sup>(g)</sup>	Hourly <sup>(h)</sup> (lb/hr)	Annual <sup>(i)</sup> (tpy)	Hourly <sup>(h)</sup> (lb/hr)	Annual <sup>(i)</sup> (tpy)	Hourly <sup>(h)</sup> (lb/hr)	Annual <sup>(i)</sup> (tpy)	
1,3-Butadiene	HAP		4.30E-07	D	1.60E-05	D	1,907	1,907	1,665	1,665	8.20E-04	5.92E-04	2.66E-02	1.32E-02	5.33E-02	2.63E-02	No
Acetaldehyde	HAP		4.00E-05	C			1,907	1,907	1,665	1,665	7.63E-02	5.51E-02	0.00E+00	0.00E+00	1.53E-01	1.10E-01	No
Acrolein	HAP		6.40E-06	C			1,907	1,907	1,665	1,665	1.22E-02	8.82E-03	0.00E+00	0.00E+00	2.44E-02	1.76E-02	No
Benzene	HAP		1.20E-05	C	5.50E-05	C	1,907	1,907	1,665	1,665	2.29E-02	1.65E-02	9.16E-02	4.53E-02	1.83E-01	9.06E-02	No
Ethylbenzene	HAP		3.20E-05	C			1,907	1,907	1,665	1,665	6.10E-02	4.41E-02	0.00E+00	0.00E+00	1.22E-01	8.82E-02	No
Formaldehyde <sup>(b)</sup>	HAP	1.32E-01	1.37E-04		2.80E-04	B	1,907	1,907	1,665	1,665	2.62E-01	1.89E-01	4.66E-01	2.31E-01	9.33E-01	4.61E-01	No
Naphthalene	HAP		1.30E-06	C	3.50E-05	C	1,907	1,907	1,665	1,665	2.48E-03	1.79E-03	5.83E-02	2.88E-02	1.17E-01	5.76E-02	No
PAHs	HAP		2.20E-06	C	4.00E-05	C	1,907	1,907	1,665	1,665	4.20E-03	3.03E-03	6.66E-02	3.29E-02	1.33E-01	6.59E-02	No
Propylene Oxide	HAP		2.90E-05	D			1,907	1,907	1,665	1,665	5.53E-02	4.00E-02	0.00E+00	0.00E+00	1.11E-01	7.99E-02	No
Toluene	HAP		1.30E-04				1,907	1,907	1,665	1,665	2.48E-01	1.79E-01	0.00E+00	0.00E+00	4.96E-01	3.68E-01	No
Xylene	HAP		6.40E-05	C			1,907	1,907	1,665	1,665	1.22E-01	8.82E-02	0.00E+00	0.00E+00	2.44E-01	1.76E-01	No
Arsenic	HAP			E	1.10E-05	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	1.83E-02	9.06E-03	3.66E-02	1.81E-02	No
Beryllium	HAP				3.10E-07	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	5.16E-04	2.55E-04	1.03E-03	5.10E-04	No
Cadmium	HAP			E	4.80E-06	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	7.99E-03	3.95E-03	1.60E-02	7.90E-03	No
Chromium	HAP				1.10E-05	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	1.83E-02	9.06E-03	3.66E-02	1.81E-02	No
Lead	HAP			E	1.40E-05	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	2.33E-02	1.15E-02	4.66E-02	2.31E-02	No
Manganese	HAP			E	7.90E-04	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	1.32E+00	6.50E-01	2.63E+00	1.30E+00	No
Mercury	HAP			E	1.20E-06	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	2.00E-03	9.88E-04	4.00E-03	1.98E-03	No
Nickel	HAP				4.60E-06	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	7.66E-03	3.79E-03	1.53E-02	7.57E-03	No
Selenium	HAP				2.50E-05	D	1,907	1,907	1,665	1,665	0.00E+00	0.00E+00	4.16E-02	2.06E-02	8.33E-02	4.12E-02	No
<p align="center">Annual Fuel Use (MMBtu/yr)</p> <p>CTG Natural Gas Maximum<sup>(j)</sup> 5,511,224</p> <p>CTG Distillate Oil Maximum<sup>(j)</sup> 3,293,293</p> <p>Number of CTGs per Facility 2</p> <p align="right">Facility Total HAPs 3.0</p> <p align="right">Maximum Individual HAP 1.3</p> <p>Natural Gas Heating Value 964.5 Btu/SCF (HHV)</p>																	
<p>Notes:</p> <p>(a) Type = NC for Non-Criteria Pollutants, HAP/POM for compounds included as polycyclic organic matter or HAP for Hazardous Air Pollutant.</p> <p>(b) Maximum heat input rate for turbine is based on HHV data at an ambient temperature of 59 °F and base load operating conditions.</p> <p>(c) Average heat input rate is based on data at an average ambient temperature of 59 °F and base load operating conditions.</p> <p>(d) Emission Factor (lb/MMBtu) = (Emission Factor, lb/10<sup>6</sup>scf) / (Heat Value Btu/scf)</p> <p>(e) Hourly Emission Rate (lb/hr) = [Heat Input (MMBtu/Hr) * Emission Factor (lb/MMBtu)]</p> <p>(f) Annual Emission Rate (tons/year) = [Annual Heat Input (MMBtu/yr) * Emission Factor (lb/MMBtu) / (2,000 lb/ton)]</p> <p>(h) Modified from AP-42 Section 3.1 emissions database for aero derivative turbines.</p> <p>(i) Annual Fuel Use increased by 10% margin</p>																	



**AP-42 Emission Factor for Formaldehyde Emissions from Natural Gas Fired Combustion Turbine**

ID Number	Facility	Turbine	Turbine Rating (MW)	Turbine Model	AP-42 Emission Factor (lb/Mmcuft)			AP-42 Emission Factor (lb/Mmcuft)	
					AP-42 Emission Factor (lb/Mmcuft)	AP-42 Emission Factor (lb/Mmcuft)	AP-42 Emission Factor (lb/Mmcuft)	AP-42 Emission Factor (lb/Mmcuft)	AP-42 Emission Factor (lb/Mmcuft)
11	Gilroy Energy Co./Gilroy, CA	General Electric Fram	87 MW	NR	0.72	0.72	0.72		
12.1	Sithe Energies, 32nd St. Naval S/San I	General Electric MS60	44 MW	100	0.11	0.11	0.11		
13.1	SD Gas & Electric Co./San Diego, CA	General Electric 5221	17 MW	95	0.48	0.48	0.48		
15.1	Modesto Irrigation District/Mclure/Mod	General Electric Fram	50 MW	100	0.14	0.14	0.14		
16	Willamette Industries, Inc./Oxnard, CA	General Electric LM25	67.4 MW	33	0.04	0.04	0.04	0.04	0.04
18	Sycamore Cogen. Co./Bakersfield, CA	General Electric Fram	75 MW	100	0.09	0.09	0.09		
2	Calpine / Agnews Cogen./San Jose, C.	General Electric LM50	23.33 MW	100	0.06	0.06	0.06	0.06	0.06
21	Dexzel Inc./Bakersfield, CA	General Electric LM25	29.1 MW	77	0.03	0.03	0.03	0.03	0.03
22	Procter & Gamble Manufacturing/Sacr	General Electric LM25	20.5 MW	95	0.09	0.09	0.09	0.09	0.09
23	Chevron Inc./Gaviota, CA	Allison K501	2.5 MW	NR	3.57	3.57	3.57		
25 <sup>2</sup>	Eil / Stewart & Stevenson/Berkeley, C/	General Electric LM25	25 MW	NR	0.48	0.48	0.48	0.48	
26	Calpine Corp./Sumas, WA	General Electric MS70	87.83 MW	100	0.01	0.01	0.01		
27	Sargent Canyon Cogen/Bakersfield, C.	General Electric Fram	42.5 MW	50	0.06	0.06	0.06		
28	Watsonville Cogen, Partnership/Watso	General Electric LM 2	24 MW	100	0.09	0.09	0.09	0.09	0.09
3.1	Southern Cal. Edison Co./Long Beach,	Brown-Boveri-Sulzer	61.75 MW	107	1.33	1.33	1.33		
313.1.1	NR/NR	General Electric Fram	7.7 MW	100	0.27	0.27	0.27		
313.1.2	NR/NR	General Electric Fram	7.7 MW	25	0.43	0.43	0.43		
313.2.1	NR/NR	Solar T12000	9.4 MW	100	0.02	0.02	0.02		
313.2.2	NR/NR	Solar T12000	9.4 MW	25	9.62	9.62	9.62		
315.1	NR/NR	General Electric LM15	10.6 MW	100	4.27	4.27	4.27		
315.2	NR/NR	General Electric LM15	10.6 MW	25	25.91	25.91			
4.1.2x <sup>1</sup>	Southern Cal. Edison Co./Coolwater, C	Westinghouse PACE5	63 MW	100	38.96				
4.2	Southern Cal. Edison Co./Coolwater, C	Westinghouse PACE5	63 MW	100	0.35	0.35	0.35		
6.2	Imperial Irrigation D / Choachella/Impe	General Electric NS50	46.3 MW	100	0.31	0.31	0.31		
7	Bonneville Pacific Corp./Somis, CA	Solar Mars	9 MW	100	0.74	0.74	0.74		
9	WSPA/SWEPI GT/Bakersfield, CA	Allison 501 KB5	4 MW	85	0.01	0.01	0.01		
Mean (lb/Mmcuft)					3.39	1.97	0.97	0.13	0.06
Std Dev					8.98	5.41	2.13	0.17	0.03

Notes:

<sup>1</sup> Formaldehyde data point was an outlier. Retest of the same turbine (ID Number 4.2) generated formaldehyde data more consistent with other formaldehyde data

<sup>2</sup> The data point for the Eil/Stewart & Stevenson facility was calculated from three "non-detects"; the Test Method employed an unusually high detection limit

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Tank Identification and Physical Characteristics**

**Identification**

User Identification: T001  
City: Dade County  
State: Florida  
Company: South Dade Energy Center  
Type of Tank: Vertical Fixed Roof Tank  
Description: Main Tank

**Tank Dimensions**

Shell Height (ft): 48.00  
Diameter (ft): 103.00  
Liquid Height (ft): 30.00  
Avg. Liquid Height (ft): 15.00  
Volume (gallons): 1,852,000.00  
Turnovers: 12.24  
Net Throughput (gal/yr): 22,660,000.00  
Is Tank Heated (y/n): N

**Paint Characteristics**

Shell Color/Shade: White/White  
Shell Condition: Good  
Roof Color/Shade: White/White  
Roof Condition: Good

**Roof Characteristics**

Type: Dome  
Height (ft): 0.00  
Radius (ft) (Dome Roof): 103.00

**Breather Vent Settings**

Vacuum Settings (psig): -0.03  
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Miami, Florida (Avg Atmospheric Pressure = 14.75 psia)

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Liquid Contents of Storage Tank**

Mixture/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)	Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	Jul	81.34	76.83	85.86	75.91	0.0127	0.0111	0.0146	130.0000			188.00	Option 5: A=12.101, B=8907

## TANKS 4.0 Emissions Report - Detail Format Detail Calculations (AP-42)

Month	January	February	March	April	May	June	July	August	September	October	November	December
Standing Losses (lb)							84.8772					
Vapor Space Volume (cu ft):							333,831.6374					
Vapor Density (lb/cu ft):							0.0003					
Vapor Space Expansion Factor:							0.0295					
Vented Vapor Saturation Factor:							0.9736					
Tank Vapor Space Volume												
Vapor Space Volume (cu ft):							333,831.6374					
Tank Diameter (ft):							103.0000					
Vapor Space Outage (ft):							40.0648					
Tank Shell Height (ft):							48.0000					
Average Liquid Height (ft):							15.0000					
Roof Outage (ft):							7.0648					
Roof Outage (Dome Roof)												
Roof Outage (ft):							7.0648					
Dome Radius (ft):							103.0000					
Shell Radius (ft):							51.5000					
Vapor Density												
Vapor Density (lb/cu ft)							0.0003					
Vapor Molecular Weight (lb/lb-mole):							130.0000					
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):							0.0127					
Daily Avg. Liquid Surface Temp. (deg. R):							541.0146					
Daily Average Ambient Temp. (deg. F):							82.6000					
Ideal Gas Constant R (psia cu ft / (lb-mol-deg R)):							10.731					
Liquid Bulk Temperature (deg. R):							535.5817					
Tank Paint Solar Absorptance (Shell):							0.1700					
Tank Paint Solar Absorptance (Roof):							0.1700					
Daily Total Solar Insulation Factor (Btu/sqft day):							1,854.1259					
Vapor Space Expansion Factor												
Vapor Space Expansion Factor:							0.0295					
Daily Vapor Temperature Range (deg. R):							18.0416					
Daily Vapor Pressure Range (psia):							0.0035					
Breather Vent Press. Setting Range (psia):							0.0600					
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):							0.0127					
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):							0.0111					
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):							0.0146					
Daily Avg. Liquid Surface Temp. (deg. R):							541.0146					
Daily Min. Liquid Surface Temp. (deg. R):							536.5042					
Daily Max. Liquid Surface Temp. (deg. R):							545.5250					
Daily Ambient Temp. Range (deg. R):							12.8000					
Vented Vapor Saturation Factor												
Vented Vapor Saturation Factor:							0.9736					
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):							0.0127					
Vapor Space Outage (ft):							40.0648					
Working Losses (lb):							694.0045					

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Detail Calculations (AP-42)- (Continued)**

Vapor Molecular Weight (lb/lb-mole):	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0127
Net Throughput (gal/mo.):	22,660,000.00
Annual Turnovers:	00
Turnover Factor:	12.2354
Maximum Liquid Volume (gal):	1,852,000.000
Maximum Liquid Height (ft):	0
Tank Diameter (ft):	30.0000
Working Loss Product Factor:	103.0000
	1.0000
Total Losses (lb):	978 6817

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Individual Tank Emission Totals**

**Emissions Report for: July**

Components	Losses(lbs)		
	Working Loss	Breathing Loss	Total Emissions
Distillate fuel oil no. 2	894.00	84.88	978.88

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Tank Identification and Physical Characteristics**

**Identification**

User Identification: T002  
City: Dade County  
State: Florida  
Company: South Dade Energy Center  
Type of Tank: Vertical Fixed Roof Tank  
Description: Day Tank

**Tank Dimensions**

Shell Height (ft): 40.00  
Diameter (ft): 56.00  
Liquid Height (ft): 25.10  
Avg. Liquid Height (ft): 12.60  
Volume (gallons): 463,050.00  
Turnovers: 48.94  
Net Throughput (gal/yr): 22,661,871.00  
Is Tank Heated (y/n): N

**Paint Characteristics**

Shell Color/Shade: White/White  
Shell Condition: Good  
Roof Color/Shade: White/White  
Roof Condition: Good

**Roof Characteristics**

Type: Dome  
Height (ft): 0.00  
Radius (ft) (Dome Roof): 56.00

**Breather Vent Settings**

Vacuum Settings (psig): -0.03  
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Miami, Florida (Avg Atmospheric Pressure = 14.75 psia)

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Liquid Contents of Storage Tank**

Mixture/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)	Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	Jul	81.34	76.83	85.86	75.91	0.0127	0.0111	0.0146	130.0000			188.00	Option 5: A=12.101, B=8907



## TANKS 4.0

### Emissions Report - Detail Format

### Detail Calculations (AP-42)

Month:	January	February	March	April	May	June	July	August	September	October	November	December
Standing Losses (lb):							19.6781					
Vapor Space Volume (cu ft):							76,947.0142					
Vapor Density (lb/cu ft):							0.0003					
Vapor Space Expansion Factor:							0.0295					
Vented Vapor Saturation Factor:							0.9793					
Tank Vapor Space Volume												
Vapor Space Volume (cu ft):							76,947.0142					
Tank Diameter (ft):							56.0000					
Vapor Space Outage (ft):							31.2411					
Tank Shell Height (ft):							40.0000					
Average Liquid Height (ft):							12.6000					
Roof Outage (ft):							3.8411					
Roof Outage (Dome Roof)												
Roof Outage (ft):							3.8411					
Dome Radius (ft):							56.0000					
Shell Radius (ft):							28.0000					
Vapor Density												
Vapor Density (lb/cu ft):							0.0003					
Vapor Molecular Weight (lb/lb-mole):							130.0000					
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):							0.0127					
Daily Avg. Liquid Surface Temp. (deg. R):							541.0146					
Daily Average Ambient Temp. (deg. F):							82.6000					
Ideal Gas Constant R (psia cu ft / (lb-mol-deg R)):							10.731					
Liquid Bulk Temperature (deg. R):							535.5817					
Tank Paint Solar Absorptance (Shell):							0.1700					
Tank Paint Solar Absorptance (Roof):							0.1700					
Daily Total Solar Insulation Factor (Btu/sqft day):							1,854.1259					
Vapor Space Expansion Factor												
Vapor Space Expansion Factor:							0.0295					
Daily Vapor Temperature Range (deg. R):							18.0416					
Daily Vapor Pressure Range (psia):							0.0035					
Breather Vent Press. Setting Range (psia):							0.0600					
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):							0.0127					
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):							0.0111					
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):							0.0146					
Daily Avg. Liquid Surface Temp. (deg R):							541.0146					
Daily Min. Liquid Surface Temp. (deg R):							536.5042					
Daily Max. Liquid Surface Temp. (deg R):							545.5250					
Daily Ambient Temp. Range (deg. R):							12.8000					
Vented Vapor Saturation Factor												
Vented Vapor Saturation Factor:							0.9793					
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):							0.0127					
Vapor Space Outage (ft):							31.2411					
Working Losses (lb):							697.0741					

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Detail Calculations (AP-42)- (Continued)**

Vapor Molecular Weight (lb/lb-mole):	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0127
Net Throughput (gal/mo.):	22,661,871.00
	00
Annual Turnovers:	48.9404
Turnover Factor:	0.7797
Maximum Liquid Volume (gal):	463,050.0000
Maximum Liquid Height (ft):	25.1000
Tank Diameter (ft):	56.0000
Working Loss Product Factor:	1.0000
Total Losses (lb):	716.7522

**TANKS 4.0**  
**Emissions Report - Detail Format**  
**Individual Tank Emission Totals**

Emissions Report for: July

Components	Losses (lbs)		Total Emissions
	Working Loss	Breathing Loss	
Distillate fuel oil no. 2	697.07	19.68	716.75

**APPENDIX C**  
**AIR QUALITY IMPACT ANALYSIS**

---

## 1.0 INTRODUCTION

Dispersion modeling using U.S. EPA –approved models was conducted to determine the peak impact of emissions from the proposed South Dade Energy Center on ambient air concentrations of criteria pollutants for which there is a National Ambient Air Quality Standard (NAAQS). For the proposed facility, this includes NO<sub>x</sub>, CO, SO<sub>2</sub>, PM<sub>10</sub> and lead. In addition, maximum air impacts were identified at receptors located in Biscayne National Park (BNP), approximately 2 kilometers to the east of SDEC. Analyses were also conducted to assess the potential for adverse impact to soils and vegetation (relative to the project peak impacts and impacts at BNP), and to estimate acidic deposition at BNP. The maximum air impacts predicted with the U.S. EPA's ISCST3 model were assessed relative to U.S. EPA recommended criteria for soils and vegetation. The CALPUFF model, recommended by the National Park Service for assessing deposition, was used to compute acidic deposition, in the form of sulfur and nitrogen, relative to background deposition measurements.

Section 2 presents the modeling analysis methodology and the results of the peak predicted SDEC air impacts and maximum impacts at BNP. Section 3 presents the soils and vegetation impact analysis and deposition modeling results.

---

## 2.0 AIR QUALITY MODELING ANALYSIS

### 2.1 Overview of Analysis Methodology

The ambient concentrations of the pollutants resulting from allowable emissions from the proposed facility were predicted using an approved U.S. EPA atmospheric dispersion model in accordance with U.S. EPA's "Guideline on Air Quality Models" (U.S. EPA, 1999). The atmospheric dispersion of emissions was simulated for a record of representative sequential hourly meteorological conditions over a historical five-year period. Ground-level concentrations at various averaging periods depending on the pollutant were predicted for a grid of ground-level model "receptors" surrounding the proposed facility. The following sections detail the specific aspects of the ambient air quality impact analysis.

### 2.2 Model Selection

The selection of an appropriate dispersion model must take into consideration the physical geometry of the sources, the local dispersion environment, and terrain characteristics. These factors, which formulate the basis for choosing one or more of the models recommended in the U.S. EPA modeling guidelines for both screening and refined modeling, are discussed below.

#### 2.2.1 Physical Source Geometry

The sources of criteria pollutants from the proposed facility consist of high velocity, high temperature exhausts from stacks connected to the combustion turbines. This requires the use of a model capable of simulating the dispersion of buoyant releases from elevated point sources. The U.S. EPA modeling guidelines require the evaluation of the potential for physical structures to affect the dispersion of emissions from elevated point sources. The exhaust from stacks that are located within specified distances of buildings, and whose physical heights are below specified levels, may be subject to "aerodynamic building downwash" under certain meteorological conditions. If this is the case, a model capable of simulating this effect must be employed.

The analysis used to evaluate the potential for building downwash is referred to as a physical "Good Engineering Practice" (GEP) stack height analysis. Stacks with heights below physical GEP are considered to be subject to building downwash. In the absence of structural effects, U.S. EPA has established a "default" GEP height of 213 feet. Any portion of a stack above the maximum of the physical or default GEP height cannot be used in the dispersion modeling analysis for purposes of comparison to U.S. EPA's ambient impact criteria.

Each of the two combustion turbines at the proposed facility will have its own stack. A GEP stack height analysis was performed for the proposed project configuration in accordance with U.S. EPA's guidelines (U.S. EPA, 1985). Per the guidelines, the physical GEP height,  $H_{GEP}$ , is determined from the dimensions of all buildings which are within the region of influence using the following equation:

$$H_g = H + 1.5L$$

where:

H = height of the structure within 5L of the stack which maximizes  $H_g$ , and

L = lesser dimension (height or projected width) of the structure.


For a squat structure, i.e., height less than projected width, the formula reduces to:

$$H_g = 2.5H$$

In the absence of influencing structures, a "default" GEP stack height is credited up to 65 meters (213 feet). The locations and dimensions of the various structures at the proposed facility relative to the exhaust stacks are depicted in Figure 2-1. An analysis of the potential for building downwash is presented below.

The significant structures of the proposed facility will include the turbine enclosures, turbine air intake structures, water storage tanks, and fuel storage tanks. U.S. EPA's Building Profile Input Processor (BPIP), as implemented in Lakes-Environmental *BPIP View* software, was used to determine the GEP stack height and to develop building input data for the modeling analysis. A summary of the GEP analysis and the controlling building is provided in Table 2-1. The table lists the physical GEP stack height calculated for each influencing structure. Based on the BPIP analysis, the GEP stack height for the turbine stacks is 148.5 feet. Since the proposed height of the combustion turbine stacks is 80 feet, building downwash affects must be simulated in the dispersion modeling analysis. Also, since the stacks are less than the default GEP height of 213 feet, their full height can be considered in the modeling.

**Figure 2-1 Location of Turbine Stacks Relative to Structures Included in the GEP Analysis**





**Table 2-1 Summary of GEP Analysis (Units in Feet)**

Structure	Height	Length	Width	MPW <sup>(2)</sup>	GEP Formula Height	5L <sup>(3)</sup>	Distance to Turbine Stack <sup>(4)</sup>	Turbine Stack(s) Potentially Effected By Downwash Yes/No
Exhaust Duct <sup>(1)</sup>	24.6	33	26	42	61.5	123	0	No
Turbine Enclosure <sup>(1)</sup>	26.8	69	46	83	67	134	33	No
Generator Enclosure <sup>(1)</sup>	24	36	26	44	60	120	105	No
Turbine Air Intake <sup>(1)</sup>	72	46	23	51	148.5	255	138	Yes
Turbine End Structure <sup>(1)</sup>	36	36	20	41	90	180	167	Yes
Cooling Tower	34	36	20	41	85	170	157	Yes
Filtered Water Tank	48	58	58	58	120	240	125	Yes
De-mineralized Water Tank	48	47	47	47	118.5	235	276	No
Chiller Water Tank	48	200	200	200	120	240	341	No

(1) One associated with each turbine (see Figure 2-1).  
(2) Maximum projected width.  
(3) 5 times the lessor of the MPW or height is the maximum influence region.  
(4) Closest distance relative to both turbine stacks.

## 2.2.2 Dispersion Environment

The selection and application of the model requires characterization of the local (within 3 km) dispersion environment as either urban or rural, based on a U.S. EPA-recommended procedure that characterizes an area by prevalent land use. This land use approach classifies an area according to 12 land use types. In this scheme, areas of industrial, commercial, and compact residential land use are designated urban. According to U.S. EPA modeling guidelines, if more than 50 percent of an area within a three-kilometer radius of the proposed facility is classified as rural, then rural dispersion coefficients are to be used in the dispersion modeling analysis.

For this analysis, the 1:24,000 scale United States Geological Survey (USGS) topographic maps were obtained for: Goulds NW, Perrine NE, Homestead SW, Arsenicker. Visual observation of the land use depicted on these maps clearly indicates that the region within 3 km is predominately rural.

## 2.2.3 Terrain Considerations

The U.S. EPA modeling guidelines require that the differences in terrain elevations, between the stack base and each location (receptor) at which air quality impacts are predicted, be considered in the modeling analyses. There are three types of terrain:

- simple terrain – locations where the terrain elevation is at or below the exhaust height of the stacks to be modeled;

- intermediate terrain – locations where the terrain is between the height of the stack and the modeled exhaust “plume” centerline (this varies as a function of plume rise, which in turn, varies as a function of meteorological condition);
- complex terrain – locations where the terrain is above the plume centerline.

Based on a review of USGS topographical maps, the area throughout the modeling domain is generally flat. The dispersion model must therefore be capable of simulating impacts on simple terrain only.

Based on a review of the factors discussed above, the ISCST3-Version 00101 dispersion model was selected for use in the modeling analysis.

## **2.3 Model Application**

The ISCST3 model was used to calculate concentrations at simple terrain receptor locations. The model was applied using the ISCST3 regulatory default option, in accordance with the U.S. EPA Guidelines.

### **2.3.1 Meteorological Data**

The ISCST3 model requires a sequential hourly record of dispersion meteorology representative of the region within which the proposed source is located. In the absence of site-specific measurements, the EPA Guidelines recommend the use of data from nearby National Weather Service (NWS) stations, provided they are representative. For this analysis a five-year sequential meteorological data set was used consisting of surface observations from the NWS at Miami International airport and concurrent mixing heights data from the NWS at West Palm Beach International airport from 1986 through 1990. These data are the closest representative data available and are recommended by the DEP. The surface data and mixing height data files were processed with the U.S. EPA’s meteorological processor, PCRAMMET, for input to ISCST3.

### **2.3.2 Model Receptor Grid**

A cartesian receptor grid was generated for use in the ISCST3 modeling to assess the peak project impacts. The grid consisted of densely spaced receptors 100 meters apart starting at and extending to 3000 meters from the plant fence-line. Beyond 3000 meters, a spacing of 500 meters was used out to five kilometers from the facility. From six to ten kilometers, a spacing of 1000 meters was used. Between ten and twenty kilometers, a spacing of 2000 meters was used. Additional receptors were placed approximately every 50 meters along the property fence-line for increased resolution of impacts. Terrain elevations were not used for the receptors given that the terrain in the study area is generally flat. The extent of this grid was sufficient to capture maximum impacts.

Figure 2-2 shows the near-field receptors (out to three kilometers) including the near-field portion of the cartesian grid and fence-line receptors. The full cartesian receptor grid out to twenty kilometers is shown in Figure 2-3.

A separate set of receptors, shown in Figure 2-4, was used to assess impacts in BNP. BNP receptors were placed at 1000-meter intervals along the park boundary and in a 5000-meter spaced grid inside the park.

Figure 2-2 Near-Field Receptor Locations



Figure 2-3 Far-Field Receptors





Figure 2-4 Biscayne National Park Receptors



### 2.3.3 Physical Source and Emissions Data

The air dispersion modeling analysis was conducted with emission rates and flue gas exhaust characteristics (flow rate and temperature) that are expected to represent the worst-case parameters among the range of possible values for the proposed MHI501F turbines. Because turbine emission rates and flue gas characteristics for a given turbine load vary as a function of ambient temperature and fuel use, data were derived for four ambient temperatures for both natural gas and distillate oil at each of the two operating loads (100% and 75%). The temperatures selected were:

- 32°F, an extreme lower boundary
- 59°F, ISO conditions
- 74°F, representative annual average
- 95°F, a representative upper boundary

A summary of the exhaust data and emission rates for the modeled pollutants for each fuel at each temperature and the three operating loads is provided in Table 2-2 for the MHI 501F turbines. Detailed calculations of the emissions parameters are presented in Appendix B.

In order to conservatively calculate ground-level concentrations, a composite "worst-case" set of emissions parameters was developed for each proposed fuel for input to the modeling. For each operating load, the highest pollutant-specific emission rate, the lowest exhaust temperature and the lowest exhaust flow rate were selected. Table 2-3 summarizes the worst-case emissions parameters for the two fuels at three operating loads.

Wind-direction-specific dimensions of the structures potentially causing building downwash of the turbine stacks were derived using the U.S. EPA BPIP processor. The BPIP inputs to the ISCST3 model are provided in Appendix D.

## 2.4 Ambient Impact Criteria

The U.S. EPA has established specific ambient impact criteria against which to evaluate the impact of a proposed new source. These are listed in Table 2-4 for the pollutants considered in this analysis. A description of each of the criteria is described below.

**Table 2-2 Combustion Turbine Performance Data for Natural Gas and Distillate Fuel Oil Operation**

**100 % Load – Natural Gas**

Parameter		Values			
Ambient Temperature (°F)		95	74	59	32
Stack Height (Ft.)		80	80	80	80
Stack Diameter (Ft.) <sup>(1)</sup>		27.68	27.68	27.68	27.68
Exit Temperature (°F)		1124	1124	1124	1112
Exit Velocity (Ft./sec)		70.1	70.1	70.1	69.7
Pollutant Emissions Per Combustion Turbine (lb/hr)	NO <sub>x</sub>	173	173.0	173.0	173.0
	CO	42	42.0	42.0	47.0
	SO <sub>2</sub>	11.3	11.3	11.3	11.3
	PM <sub>10</sub>	20.0	20.0	20.0	20.0

**75 % Load – Natural Gas**

Parameter		Values			
Ambient Temperature (°F)		95	74	59	32
Stack Height (Ft.)		80	80	80	80
Stack Diameter (Ft.) <sup>(1)</sup>		27.68	27.68	27.68	27.68
Exit Temperature (°F)		1148	1148	1148	1148
Exit Velocity (Ft./sec)		54.3	55.4	56.2	56.8
Pollutant Emissions Per Combustion Turbine (lb/hr)	NO <sub>x</sub>	122.0	128.0	132.0	148.0
	CO	45.0	47.0	49.0	54.0
	SO <sub>2</sub>	8.0	8.4	8.7	9.0
	PM <sub>10</sub>	20.0	20.0	20.0	20.0

<sup>(1)</sup> Equivalent diameter for rectangular stack of dimensions 22' 7 11/16" x 26' 7".



Table 2-2 Combustion Turbine Performance Data for Natural Gas and Distillate Fuel Oil Operation (continued)

100 % Load – Distillate Oil

Parameter		Values			
Ambient Temperature (°F)		95	74	59	32
Stack Height (Ft.)		80	80	80	80
Stack Diameter (Ft.) <sup>(1)</sup>		27.68	27.68	27.68	27.68
Exit Temperature (°F)		1014	1014	1014	1006
Exit Velocity (Ft./sec)		65.0	65.0	65.0	66.3
Pollutant Emissions Per Combustion Turbine (lb/hr)	NO <sub>x</sub>	272.0	272.0	272.0	281.0
	CO	197.0	197.0	197.0	204.0
	SO <sub>2</sub>	39.0	39.0	39.0	41.0
	PM <sub>10</sub>	40.0	40.0	40.0	40.0
	Lead	0.02	0.02	0.02	0.02

75 % Load – Distillate Oil

Parameter		Values			
Ambient Temperature (°F)		95	74	59	32
Stack Height (Ft.)		80	80	80	80
Stack Diameter (Ft.) <sup>(1)</sup>		27.68	27.68	27.68	27.68
Exit Temperature (°F)		1121	1099	1086	1064
Exit Velocity (Ft./sec)		50.4	51.6	52.5	54.3
Pollutant Emissions Per Combustion Turbine (lb/hr)	NO <sub>x</sub>	196.0	205.0	212.0	226.0
	CO	142.0	149.0	154.0	164.0
	SO <sub>2</sub>	28.0	30.0	31.0	33.0
	PM <sub>10</sub>	40.0	40.0	40.0	40.0
	Lead	0.02	0.02	0.02	0.02

<sup>(1)</sup> Equivalent diameter for rectangular stack of dimensions 22' 7 11/16" x 26' 7".

**Table 2-3 Worst-Case Turbine Stack Data for Dispersion Modeling**

**Natural Gas Operation**

Parameter		Value	
Load (%)		100	75
Stack Height (Ft.)		80	80
Stack Diameter (Ft.) <sup>(1)</sup>		27.68	27.68
Exit Temperature (°F)		1112	1148
Exit Velocity (Ft./sec)		69.7	54.3
Pollutant Emissions Per Combustion Turbine (lb/hr)	NO <sub>x</sub>	173.0	281.0
	CO	47.0	204.0
	SO <sub>2</sub>	11.3	41.0
	PM <sub>10</sub>	20.0	40.0

**No. 2 Fuel Operation**

Parameter		Value	
Load (%)		100	75
Stack Height (Ft.)		80	80
Stack Diameter (Ft.) <sup>(1)</sup>		27.68	27.68
Exit Temperature (°F)		1006	1064
Exit Velocity (Ft./sec)		65.0	50.4
Pollutant Emissions Per Combustion Turbine (lb/hr)	NO <sub>x</sub>	281.0	226.0
	CO	204.0	164.0
	SO <sub>2</sub>	78.0	63.0
	PM <sub>10</sub>	40.0	40.0
	Lead	0.02	0.02

<sup>(1)</sup> Equivalent diameter for rectangular stack of dimensions 22' 7 11/16" x 26' 7".

**Table 2-4 Ambient Impact Criteria<sup>1</sup>**

Pollutant	Averaging Period	NAAQS		Significant Impact Levels
		Primary	Secondary	
NO <sub>2</sub>	Annual	100	100	1
CO	1-hour	40,000	NA	2,000
	8-hour	10,000	NA	500
PM <sub>10</sub>	24-hour	150	150	5
	Annual	50	50	1
SO <sub>2</sub>	3-hour	NA	1300	25
	24-hour	365	NA	5
	Annual	80	NA	1
Lead	Quarter	1.5	1.5	NA

<sup>1</sup> All values in µg/m<sup>3</sup>. Annual averages are the maximum over all receptors. Short-term averages are the highest of the second-highest concentration over all receptors.  
NA = Not Applicable

### National Ambient Air Quality Standards (NAAQS)

National Ambient Air Quality Standards (NAAQS) are set by U.S. EPA, based on specific health and welfare effects criteria. Hence the term "criteria" pollutants. Ambient air refers to the air to which the general public is exposed, not the air inside buildings or in workplaces. The combined impacts of all existing sources cannot exceed the NAAQS. The primary NAAQS are established to protect the health of sensitive individuals. The secondary NAAQS are established to protect the general welfare of the public-at-large from adverse impacts on air quality related values such as visibility.

### Significant Impact Levels

As can be seen from the concentrations representing these levels, the Significant Impact Levels (SILs) are small fractions of the NAAQS. The U.S. EPA guidelines require these levels to be used to determine the extent of the area surrounding a proposed source within which the source could significantly add to ambient air quality concentrations. For proposed sources whose impacts are above these levels, an analysis of the combined impacts of the proposed source with other existing sources is required. If a proposed source's impacts are below these levels it is considered to be unable to either cause or contribute to violations of the NAAQS. Therefore, a cumulative impact assessment is not required.

## 2.5 Background Air Quality Data

For comparison purposes, a summary of the most recent background air quality measurements available from the Florida Department of Environmental Protection (FDEP) monitoring network was compiled for the criteria pollutants. The values listed in Table 2-5 represent the highest concentrations from the most recent year of data (1999) measured at the closest monitors relative to the location of the SDEC.

## 2.6 Results of Ambient Air Quality Impact Analysis

The emissions from the turbine stacks (2) were modeled with ISCST3 to estimate the maximum concentrations for the criteria pollutants including NO<sub>x</sub>, PM/PM<sub>10</sub>, SO<sub>2</sub>, CO, and lead for each year of meteorological data. Note that the modeling of annual impacts reflects limited annual operation of the combustion turbines (a maximum of 900 hours/year oil firing per turbine or a maximum of 1300 hours/year gas firing per turbine in order to limit potential emission to less than 250 tons per year).

### Detailed Results for Cartesian Grid Receptors

Tables 2-6 and 2-7 provide summaries of the ISCST3 modeling results for NO<sub>x</sub>, PM/PM<sub>10</sub>, SO<sub>2</sub>, CO, and lead for the cartesian grid and fence-line receptors for natural gas and oil firing, respectively. The maximum air concentrations over the five years modeled and corresponding receptor locations are listed for each turbine load case (100% and 75%). Note that in Table 2-6 (results for natural gas), the maximum annual concentrations are based on a maximum of 1300 hours/year of natural gas firing (i.e., the results have been scaled by a factor of 1300/8760). Similarly, in Table 2-7 (results for oil), the maximum annual concentrations are based on a maximum of 900 hours/year of oil firing (i.e., the results have been scaled by a factor of 900/8760).

### Summary of SDEC Peak Air Impacts, BNP Air Impacts, and Comparison to Background

Table 2-8 lists the peak ground-level air concentrations for each pollutant and averaging period over all receptors (see Figures 2-5 and 2-6 for peak impact locations) as well as the maximum concentrations calculated at BNP (see Figure 2-7 for maximum impact locations). The maximum impacts for all pollutants and averaging periods are associated with oil firing. Note that the maximum annual impacts are associated with a worst-case operating schedule of 900 hours/year oil firing for both turbines with no natural gas firing. (This is the worst-case in terms of the dispersion modeling because oil exhaust parameters are lower than gas and therefore, higher impacts are modeled assuming an "all oil" annual operating scenario as opposed to a combination of oil and gas or gas only with the same annual emission rates.) Also listed in Table 2-8 are the measured background concentrations from the FDEP monitoring network.

The air quality impact results are illustrated in graphical form in Figures 2-8 through 2-15.

As shown in Table 2-8, all air concentrations modeled for the SDEC are very low compared to the background levels and represent an almost imperceptible increase relative to existing pollution levels. In addition, all estimated SDEC impacts are well below the SILs and the summed total of the peak SDEC impacts and background concentrations are well below the NAAQS. Based on these results it can be concluded that the proposed facility will neither cause nor contribute to a violation of the NAAQS.

**Table 2-5 Summary of Florida DEP Air Monitoring Data from Miami-Dade County for 1999**

Pollutant	Avg. Period	Site Name	Highest Measured Concentration ( $\mu\text{g}/\text{m}^3$ )
PM <sub>10</sub>	24-hour	325 NW 2nd St.	41
	Annual		21
SO <sub>2</sub>	3-hour	US 27 & SR821	24
	24-hour		8
	Annual		3
NO <sub>2</sub>	Annual	864 NW 23 <sup>rd</sup> St.	34
	1-hour		216
CO	1-hour	16000 S Dixie Highway	4580
	8-hour		3435

**Table 2-6 ISCST3 Modeling Results for Natural Gas**

**100% Load**

Pollutant	Averaging Period	Maximum Concentration ( $\mu\text{g}/\text{m}^3$ )*	Receptor Location	
			UTM East (m)	UTM North (m)
NO <sub>x</sub>	Annual	0.011	549100	2823400
PM-10	24-hour	0.121	571100	2811400
	Annual	0.001	549100	2823400
SO <sub>2</sub>	3-hour	0.291	566900	2823300
	24-hour	0.069	571100	2811400
	Annual	0.001	549100	2823400
CO	1-hour	2.500	564975	2823305
	8-hour	0.538	575100	2807400

\* Annual concentrations based on a maximum of 1300 hours/year of natural gas use.

**75% Load**

Pollutant	Averaging Period	Maximum Concentration ( $\mu\text{g}/\text{m}^3$ )*	Receptor Location	
			UTM East (m)	UTM North (m)
NO <sub>x</sub>	Annual	0.012	551100	2823400
PM-10	24-hour	0.506	564975	2823305
	Annual	0.002	551100	2823400
SO <sub>2</sub>	3-hour	0.565	564975	2823305
	24-hour	0.228	564975	2823305
	Annual	0.001	551100	2823400
CO	1-hour	8.525	564975	2823305
	8-hour	2.235	564975	2823305

\* Annual concentrations based on a maximum of 1300 hours/year of natural gas use.

**Table 2-7 ISCAST3 Modeling Results for Distillate Oil**

**100% Load**

Pollutant	Averaging Period	Maximum Concentration ( $\mu\text{g}/\text{m}^3$ )*	Receptor Location	
			UTM East (m)	UTM North (m)
NO <sub>x</sub>	Annual	0.013	551100	2823400
PM-10	24-hour	0.281	564975	2823304.5
	Annual	0.002	551100	2823400
SO <sub>2</sub>	3-hour	2.066	566800	2823300
	24-hour	0.549	564975	2823304.5
	Annual	0.004	551100	2823400
CO	1-hour	15.904	564975	2823304.5
	8-hour	3.909	564975	2823304.5
Lead	24-hour	1.41E-04	564975	2823304.5

\* Annual concentrations based on a maximum of 900 hours/year of oil use.

**75% Load**

Pollutant	Averaging Period	Maximum Concentration ( $\mu\text{g}/\text{m}^3$ )*	Receptor Location	
			UTM East (m)	UTM North (m)
NO <sub>x</sub>	Annual	0.014	553100	2823400
PM-10	24-hour	1.457	564975	2823304.5
	Annual	0.002	553100	2823400
SO <sub>2</sub>	3-hour	5.819	564975	2823304.5
	24-hour	2.295	564975	2823304.5
	Annual	0.004	553100	2823400
CO	1-hour	35.214	564975	2823304.5
	8-hour	9.577	564975	2823304.5
Lead	24-hour	7.29E-04	564975	2823304.5

\* Annual concentrations based on a maximum of 900 hours/year of oil use.




**Table 2-8 Summary of SDEC Dispersion Modeling Results**

Pollutant	Avg Period	Peak Impact of SDEC ( $\mu\text{g}/\text{m}^3$ )	SDEC Impact at Biscayne National Park ( $\mu\text{g}/\text{m}^3$ )	EPA Sign. Impact Level ( $\mu\text{g}/\text{m}^3$ )	Baseline Conc. <sup>(1)</sup> ( $\mu\text{g}/\text{m}^3$ )	Sum of Peak SDEC Impact and Baseline ( $\mu\text{g}/\text{m}^3$ )	NAAQS ( $\mu\text{g}/\text{m}^3$ )
NO <sub>2</sub>	Annual	0.014	0.011	1	34	34	100
PM <sub>10</sub>	24 hr	1.457	0.306	5	41	42	150
	Annual	0.0024	0.0020	1	21	21	50
SO <sub>2</sub>	3-hr	5.819	1.613	25	24	27	1300
	24-hr	2.295	0.497	5	8	9	365
	Annual	0.0038	0.0031	1	3	3	80
CO	1-hr	35.214	10.778	2,000	4,580	4,615	40,000
	8-hr	9.577	2.731	500	3,435	3,445	10,000

Note: Maximum short-term ( $\leq$  24-hour average) concentrations based on oil usage. Maximum annual concentrations based on the worst-case annual emissions scenario of 900 hours/yr of oil use for each turbine.

<sup>(1)</sup> Highest measured concentration in 1999 from FDEP monitoring stations closest to SDEC.

**Figure 2-5 Location of SDEC Peak Short-term Impacts**



**Figure 2-6 Location of SDEC Peak Annual Impacts**







Figure 2-7 Location of SDEC Maximum Impacts at Biscayne National Park




**Figure 2-8 Dispersion Modeling Results for South Dade Energy Center (SDEC): 24-hour Average PM<sub>10</sub> Concentrations**




**Figure 2-9 Dispersion Modeling Results for South Dade Energy Center (SDEC): Annual Average PM<sub>10</sub> Concentrations**



**Figure 2-10 Dispersion Modeling Results for South Dade Energy Center (SDEC): 3-hour Average SO<sub>2</sub> Concentrations**




**Figure 2-11 Dispersion Modeling Results for South Dade Energy Center (SDEC): 24-hour Average SO<sub>2</sub> Concentrations**







**Figure 2-12 Dispersion Modeling Results for South Dade Energy Center (SDEC): Annual Average SO<sub>2</sub> Concentrations**




**Figure 2-13 Dispersion Modeling Results for South Dade Energy Center (SDEC): Annual Average NO<sub>x</sub> Concentrations**



**Figure 2-14 Dispersion Modeling Results for South Dade Energy Center (SDEC): 1-hour Average CO Concentrations**



**Figure 2-15 Dispersion Modeling Results for South Dade Energy Center (SDEC): 8-hour Average CO Concentrations**



---

### 3.0 ADDITIONAL IMPACTS

Additional analyses were conducted to assess the potential for adverse air impact to soils and vegetation and to estimate acidic deposition at Biscayne National Park (BNP). The maximum air impacts from the ISCST3 modeling were compared to U.S. EPA recommended criteria for soils and vegetation. The CALPUFF model, recommended by the National Park Service for assessing deposition, was used to compute acidic deposition in the form of sulfur and nitrogen relative to background deposition measurements.

#### 3.1 Soils and Vegetation

The criteria for evaluating impacts on soils and vegetation is taken from U.S. EPA's A Screening Procedure for the Impacts of Air Pollution Sources on Plants, Soils and Animals (U.S. EPA 1980). Table 3-1 lists the U.S. EPA suggested criteria for the gaseous pollutants emitted directly from the proposed facility. The table lists the background concentrations (see Section 2.5), the peak SDEC impacts, the maximum SDEC impacts predicted at BNP, and the sum of the SDEC impacts plus background for comparison to the criteria concentrations. The criteria are established for sensitive vegetation and crops exposed to the effects of the gaseous pollutants through direct exposure. Adverse impacts on soil systems result more readily from the secondary effects of these pollutants' impacts on the stability of the soil system. These impacts could include increased soil temperature and moisture stress and/or increased runoff and erosion resulting from damage to vegetative cover. Thus, the Table 3-1 criteria have been applied to the proposed facility to evaluate impacts on both soils and vegetation. As shown in Table 3-1, the results clearly indicate that no adverse impacts will occur to sensitive vegetation, crops, or soil systems as a result of operation of the proposed facility.

**Table 3-1 Comparison to U.S. EPA Criteria for Gaseous Pollutant Impacts on Natural Vegetation and Crops**

Pollutant	Averaging Time	Peak SDEC Impact ( $\mu\text{g}/\text{m}^3$ ) <sup>(1)</sup>	Max Impact of SDEC at BNP ( $\mu\text{g}/\text{m}^3$ ) <sup>(1)</sup>	Background Concentration ( $\mu\text{g}/\text{m}^3$ ) <sup>(2)</sup>	Peak SDEC Impact Plus Background ( $\mu\text{g}/\text{m}^3$ )	Max Impact of SDEC at BNP Plus Background ( $\mu\text{g}/\text{m}^3$ )	Minimum Impact Level for Affects On Sensitive Plants ( $\mu\text{g}/\text{m}^3$ )
SO <sub>2</sub>	1 hour	13.53	4.14	24	37.5	28.1	917
	3 hours	5.82	1.61	24	29.8	25.6	786
	Annual	0.004	0.003	3	3.0	3.0	18
NO <sub>x</sub>	4 hours	20.87	5.81	216	236.9	221.8	3760
	8 hours	13.20	3.76	216	229.2	219.8	3760
	1 month	8.23	1.79	216	224.2	217.8	564
	Annual	0.01	0.01	34	34.0	34.0	94
CO	1 week	5.97	1.30	3,435	3,441	3,436	1,800,000

<sup>(1)</sup> 24-hour average used to conservatively represent 1-week and 1-month average impacts and 3-hour average used to conservatively represent 4-hour average impact.

<sup>(2)</sup> Not all averaging periods are available from FDEP monitoring reports. Therefore, the following substitutions were made:  
 SO<sub>2</sub> – 3-hour value substituted for 1-hour value;  
 NO<sub>x</sub> – 1-hour value substituted for 4-hour and 8-hour values; and  
 CO – 8-hour value substituted for 1-week value.

### 3.2 Acid Deposition At Biscayne National Park

Acid deposition was evaluated in the form of total sulfur and nitrogen deposition at BNP. CALPUFF modeling provided upper limit estimates of annual (wet and dry) deposition of sulfur and nitrogen compounds (kg/ha/yr) associated with emissions of SO<sub>2</sub> and NO<sub>x</sub>. The CALPUFF modeling was applied with the same meteorological data used in the ISCST3 modeling analysis and was applied in accordance with recent guidance provided by the National Park Service for deposition modeling at the Everglades National Park for another project. The maximum annual sulfur deposition for the BNP receptors was 3.58E-02 kg/ha/yr and the maximum nitrogen deposition was 8.69E-03 kg/ha/yr.

There are no published deposition significance thresholds for BNP. However, the modeled results can be compared to deposition measurements at nearby Everglades National Park (ENP), which is a reasonable representation of the existing deposition of the region including BNP area. Wet deposition measurements at ENP have been taken in 1998 and 1999. Although dry deposition values are currently being taken at ENP, measurements are not yet available. Therefore, consistent with Federal Land Managers Air Quality Related Values Workgroup (FLAG) Phase I guidance, the total existing deposition was estimated by doubling the wet deposition values. Using this convention, the estimated existing annual sulfur deposition at ENP is 8 kg/ha/yr and the existing annual nitrogen deposition is 7 kg/ha/yr. Given that the modeled SDEC deposition rates of sulfur and nitrogen are only about 0.4% and 0.1%, respectively, of existing deposition rates, the deposition impact of the SDEC emissions can

be deemed insignificant. This increase in deposition does not include potential regional emission and deposition benefits that could occur if SDEC displaces emissions from existing fossil generating units.