

Public Notice

On May 12, 1986, the Jacksonville Electric Authority requested that their Prevention of Significant Deterioration permit (PSD-FL-010) for two coal-fired steam generating units adjacent to the existing JEA Northside Generation Station near Jacksonville, Florida, be revised. This permit was based on rail delivery of coal from the St. Johns River Coal Terminal to the St. Johns River Power Park. The requested revision to the permit will replace the railcar system with a 3.2 mile overland, fully enclosed conveyor system to transfer coal to the Power Park and additional coal blending capability within the existing Power Park coal stockyard. The requested revision will result in a projected decrease of 0.10 pound per hour of particulate matter.

Any person may submit written comments regarding this proposed permit revision. All comments must be received not later than 30 days from the date of this notice in order to be considered. A public hearing may be held if sufficient justification is provided, as determined by the Administrator. Letters should be addressed to:

Mr. C. H. Fancy, P.E.
State of Florida Department of
Environmental Regulation
Bureau of Air Quality
Management
2600 Blair Stone Road
Tallahassee, Florida 32301