

HOPPING GREEN SAMS & SMITH

PROFESSIONAL ASSOCIATION

ATTORNEYS AND COUNSELORS

123 SOUTH CALHOUN STREET

POST OFFICE BOX 652

TALLAHASSEE, FLORIDA 32314

(850) 222-7500

FAX (850) 224-8551

FAX (850) 425-3415

RECEIVED

AUG 17 1999

BUREAU OF AIR REGULATION

JAMES S. ALVES
BRIAN H. BIBEAU
RICHARD S. BRIGHTMAN
KEVIN B. COVINGTON
PETER C. CUNNINGHAM
RALPH A. DeMEO
RANDOLPH M. GIDDINGS
WILLIAM H. GREEN
WADE L. HOPPING
GARY K. HUNTER, JR.
JONATHAN T. JOHNSON
ROBERT A. MANNING
FRANK E. MATTHEWS
RICHARD D. MELSON
ANGELA R. MORRISON
GABRIEL E. NIETO
ERIC T. OLSEN

GARY V. PERKO
MICHAEL P. PETROVICH
DAVID L. POWELL
WILLIAM D. PRESTON
CAROLYN S. RAEPPEL
DOUGLAS S. ROBERTS
GARY P. SAMS
TIMOTHY G. SCHOENWALDER
ROBERT P. SMITH
DAN R. STENGLE
CHERYL G. STUART
W. STEVE SYKES
T. KENT WETHERELL, II
OF COUNSEL
ELIZABETH C. BOWMAN

Writer's Direct Dial No.
(850) 425-2258

MEMORANDUM

TO: Syed Arif, DEP
FROM: Angela Morrison *AM*
DATE: August 16, 1999
SUBJECT: SJRPP Permit Modification
PSD-FL-010

As we discussed, please find enclosed for your files the 1986 document which contains the revision pertaining to the above-referenced permit.

If you should have any questions or require further information concerning the enclosed, please do not hesitate to give me a call. Thank you.

ARM/gg
Enclosure

HOPPING GREEN SAMS & SMITH

PROFESSIONAL ASSOCIATION

ATTORNEYS AND COUNSELORS

123 SOUTH CALHOUN STREET

POST OFFICE BOX 8526

TALLAHASSEE, FLORIDA 32314

(850) 222-7500

FAX (850) 224-8551

FAX (850) 425-3415

KEVIN B. COVINGTON
 RANDOLPH M. GIDDINGS
 KIMBERLY A. GRIPPA
 GARY K. HUNTER, JR.
 JONATHAN T. JOHNSON
 ROBERT A. MANNING
 W. STEVE SYKES
 T. MENT WETHERELL, II

OF COUNSEL
 W. ROBERT FOKES

JAMES S. ALVES
 BRIAN H. BIRBAU
 KATHLEEN BLIZZARD
 ELIZABETH C. BOWMAN
 RICHARD E. BRIGHTMAN
 PETER C. CUNNINGHAM
 RALPH A. DEMEO
 THOMAS M. DEROSE
 WILLIAM H. GREEN
 WADE L. HOPPING
 FRANK E. MATTHEWS
 RICHARD D. NELSON
 ANGELA R. MORRISON
 GARY V. PERKO
 MICHAEL P. PETROVICH
 DAVID L. POWELL
 WILLIAM D. PRESTON
 CAROLYN S. RAEPPEL
 DOUGLAS S. ROBERTS
 GARY P. SAMS
 ROBERT P. SMITH
 CHERYL G. STUART

FAX COVER SHEET

Please Deliver the Following Pages to:

NAME:	Syed Arif	NAME:	
FIRM:	DEP	FIRM:	
FAX NO:	922-6979	FAX NO:	
VERIFY:		VERIFY:	
NAME:		NAME:	
FIRM:		FIRM:	
FAX NO:		FAX NO:	
VERIFY:		VERIFY:	

MESSAGE:

Attached is a 1996 permit revision for SURPP, which includes revised language for the second paragraph of Condition 3.

Please call me if you should have any further questions.

Thanks.

FROM:	Angela Morrison	CLIENT NO.	JEA/201
5	page(s) transmitted (including this cover sheet). If you do not receive all of the pages, please call the FAX Desk at (904) 222-7500, ext. 419.	DATE:	8/16/99

THE INFORMATION CONTAINED IN THIS FACSIMILE MESSAGE IS ATTORNEY PRIVILEGED AND CONFIDENTIAL INFORMATION INTENDED ONLY FOR THE USE OF THE INDIVIDUAL OR ENTITY NAMED ABOVE. IF THE READER OF THIS MESSAGE IS NOT THE INTENDED RECIPIENT, YOU ARE HEREBY NOTIFIED THAT ANY DISSEMINATION, DISTRIBUTION OR COPY OF THIS COMMUNICATION IS STRICTLY PROHIBITED. IF YOU HAVE RECEIVED THIS COMMUNICATION IN ERROR, PLEASE IMMEDIATELY NOTIFY US BY TELEPHONE AND RETURN THE ORIGINAL MESSAGE TO US AT THE ABOVE ADDRESS VIA THE U.S. POSTAL SERVICE. THANK YOU.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

OCT 28 1986

REGION IV

343 COURTLAND STREET
ATLANTA, GEORGIA 30365

4AFT-AP/ch

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Richard Breitmoser, P. E.
Division Chief
Research and Environmental Affairs Division
Jacksonville Electric Authority
P. O. Box 53015
233 W. Duval Street
Jacksonville, Florida 32201

RE: St. John's River Power Park PSD-FL-010

Dear Mr. Breitmoser:

This letter is in response to your May 12, 1986, request for coal terminal and blending modifications at the above-referenced facility permitted on March 12, 1982, by EPA Region IV. The Florida Department of Regulation (FDER) published a public notice announcing the proposed coal handling modifications on July 28, 1986. No comments were received and the FDER subsequently recommended that the PSD permit be modified.

In addition to the above, we have reviewed recommendations from The Department of Health, Welfare, and Bio-Environmental Services (City of Jacksonville, Florida) dated July 1, 1986, regarding opacity and control of fugitive emissions from shiploading, and subsequent recommendations from your office dated August 27, 1986, regarding emission limits and testing of non-stack emission points. In response to these recommendations and communications with the FDER, your PSD permit (PSD-FL-010) is hereby modified as follows:

1. The second paragraph of Condition of Approval No. 3 is changed from the existing wording regarding compliance testing of particulate emission points to the following:

"Opacity tests shall be performed for emission points three (3) through nineteen (19) of revised Table 6 for compliance purposes. If the opacity limits are not met for those sources that exhaust through a stack, permit compliance shall be determined on the basis of mass emission rate tests."

2. Table 2 of the final determination is replaced by revised Table 2 (enclosed).
3. Table 6 of the final determination is replaced by revised Table 6 (enclosed).
4. All reference to Table 2 and Table 6 in Conditions of Approval numbers 2, 3, 4, and 5, as contained in the March 12, 1982 PSD permit, shall be construed to pertain to the enclosed revised Tables 2 and 6.

DER

NOV 17 1986

BAOM

-2-

Please be advised that the modification to your PSD permit herein described shall become a binding part of permit PSD-FL-010. This permit modification shall become effective upon receipt of this letter, unless you notify us of your unacceptance of the conditions contained herein within ten (10) days after receipt of this letter.

If you have any questions regarding this permit modification, please contact Mr. Wayne J. Aronson, Chief, Program Support Section, at (404) 347-4901.

Sincerely yours,

/s/ Lee A. DeHihns, III
Deputy Regional Administrator

Jack E. Ravan
Regional Administrator

Attachments: 2

cc: Mr. Clair H. Fancy
Deputy Bureau Chief
Florida Department of Environmental Regulation

Table 6. Allowable Emission Limits (Revised; From PSD Permit) (lb/hour; lb/MWtu)

Emission Unit	SO ₂	NO _x	PM	Opacity (Percent)
			(Revised Original)	
1. Steam Generating sm Boiler No. 1 (6.144 MWtu/hr maximum heat input)	4,669.0; 0.76 (30-day rolling average)	3,686; 0.6	104; 0.03	20
2. Steam Generating Boiler No. 2 (4.144 MWtu/hr maximum heat input)	4,669; 0.76 (30-day rolling average)	3,686; 0.6	104; 0.03	20
3. Auxiliary boilers (254 MWtu/hr maximum heat input total)	203; 0.8		25.0; 0.1	20
4. Ship Unloading (2 Grab Buckets)*			1.0	10
5. Feeders to Conveyor A (2 Wet Suppression points)*			0.13	10
6. Conveyor Transfers 1 & 2 (2 points)*			0.57	10
7. Conveyor Transfer 3, 4, 5 & D to D by-pass (4 points)*			2.6	10
8. Conveyor Transfers 6 & 7 (2 points)*			1.0	10
9. Traveling Stacker (3 points)*			0.8	10
10. Bucket Wheel Reclaimer (2 points)*			0.6	10
11. Ship unloading facility coal storage pile			1.6	10
12. Coal handling transfer points ship unloading facility coal pile (8 points)*			1.8	10
13. Rail car unloading (Rotary Dumper)			5	10
14. Coal handling transfer points (6 wet suppression points)			5 (each)	10
15. Coal handling transfer points (11 dry collection)			0.1 (each)	10
16. Coal storage at plant* (10 acres active)			0.5	10
17. Coal storage at plant* (2 to 13-acre inactive piles)			0.02	10
18. Limestone unloading (rail dumper)			0.1	10
19. Limestone transfer points			0.1 (each)	10
20. Cooling towers			67 (each tower)	N/A

* Revised emission unit, May 1986.

Table 2. Fugitive Emissions and Control Summary (Revised: From PSD Permit)

Source	Type	Amount	Factor	Control	Technique	Emissions Tons/Year
1 Ship Unloading*	2 Crab Buckets	2,200 Tons/hr	0.0014 lb/Ton ^a	70.0%	Suppression, Enclosure	0.13
2 Feeders to Con- veyor A*	2 Points	2,200 Tons/hr	0.00039 lb/Ton	95.0%	Suppression, Enclosure	0.02
3 Conveyor Trans- fers, 1 and 2*	2 Points	2,200 Tons/hr	0.00087 lb/Ton ^{**}	95.0%	Suppression Enclosure	0.07
4 Conveyor Trans- fers 3, 4, 5 and D to D by-pass*	4 Points	2,200 Tons/hr	0.00118 lb/Ton ^{**}	75.0%	Enclosure, Conditioned Material	0.33
5 Conveyor Trans- fers 6 and 7*	2 Points	2,000 Tons/hr	0.00106 lb/Ton ^{**}	75.0%	Enclosure, Conditioned Material	0.13
6 Traveling Stackers*	3 Points: 1 Point	2,200 Tons/hr	0.00031 lb/Ton	75.0%	Enclosure, Conditioned Material	0.02
	1 Point	2,200 Tons/hr	0.00039 lb/Ton	75.0%	Enclosure, Conditioned Material	0.03
	1 Point	2,200 Tons/hr	0.00017 lb/Ton	0.0%		0.05
7 Bucket Wheel Reclaimer*	2 Points	2,000 Tons/hr	0.00069 lb/Ton ^{**}	75.0%	Enclosure, Conditioned Material	0.09
8 Ship-Unloading Facility Coal Surge Pile	Active	10 Acres	13 lb/Acre/day ^d	(90%) ^e	Wetting Agent	0.20
9 Coal Handling Transfer Points Ship Unloading Facility Coal Pile*	6 Points	2,300 Tons/hr.	0.00041 lbs/Ton ^{**}	75.0%	Enclosure, Conditioned Material	0.23
10 Rail Car Unloading	Rotary Dumper	10,000 Tons/Day	0.4 lb/Ton ^a	(97%) ^b	Wet Suppression	0.63
11 Coal Handling Transfer Points	2 Points	10,000 Tons/Day	0.2 lb/Ton ^c	(99.9%) ^b	Dry Collection	0.03
12 Coal Handling Transfer Points	2 Points	1,300 Tons/Day	0.2 lb/Ton ^c	(99.9%) ^b	Dry Collection	0.02
13 Coal Handling Transfer Points	6 Points	1,300 Tons/Day	0.2 lb/Ton ^c	(97%) ^b	Wet Suppression	0.43
14 Coal Handling Transfer Points	7 Points	3,000 Tons/Day	0.2 lb/Ton ^c	(99.9%) ^b	Dry Collection	0.04
15 Coal Storage At Plant*	Active	10 Acres	13 lb/Acre/day ^d	(90%) ^e	Wetting Agent	0.07
16 Coal Storage At Plant*	2 Inactive Piles	13 Acres	3.5 lb/Acre/day ^d	(90%) ^e	Wetting Agent	0.002
17 Limestone Unloading	Rail Dumper	750 Tons/Day	0.4 lb/ton ^a	(97%) ^b	Wet Suppression	0.05
18 Limestone Transfer	1 Point	750 Tons/Day	0.2 lb/Ton ^a	(99.9%) ^b	Dry Collection	0.001
19 Cooling Towers	Drift	2 x 243,500 gal/min	11,450 ppm solids (maximum) (40% < 30 microns diameter)	99.999%	Drift Elim- ination	18.46
20 Solid Waste Disposal Area	Active	10 Acres	13 lb/Acre/day ^d	(90%) ^e	Wetting Agent	0.07

* Revised process or emissions, May 1986.

. Weighted average based on 1,500 and 700 TPH ship unloaders.

** Average of emission factors for individual sources.

a. Fedco, 1977.

b. Staughton, 1980.

c. EPA, 1977.