From:	Koerner, Jeff
To:	Scearce, Lynn
Subject:	RE: 0310045-035-AC exemption for fabric filter replacement Feb 9 2012.docx
Date:	Friday, February 10, 2012 2:42:25 PM
Attachments:	0310045-035-AC - Exemption, LS Silo FF Replacement.docx 0310045-035-AC - Exemption, LS Silo FF Replacement - Signed.pdf

---

Lynn,

I e-signed this exemption letter.

Please clerk and send out.

Thanks!

Jeff

From: Costello, Martin
Sent: Thursday, February 09, 2012 4:15 PM
To: Koerner, Jeff
Cc: Holtom, Jonathan; Scearce, Lynn
Subject: 0310045-035-AC exemption for fabric filter replacement Feb 9 2012.docx

Jeff,

Attached is a Permit Exemption for JEA to replace two fan powered fabric filters on limestone silos. These serve coal fired units at the St. Johns River Power Park.

Originally they requested removal of the fabric filters since they had been unserviceable for some time, and the silos apparently could be filled without these controls in operation—and still meet the 5% opacity limit. The limestone is apparently moist enough at the current time and the controls are unnecessary.

JEA revised their request today and they are now going to replace the fabric filters with static filters that are pleated. They will continue to meet the opacity limit after this change. This action does not require an AC and can be accomplished through the attached permit exemption. I recommend your approval of this permit exemption.