

From: [Linero, Alvaro](#)
To: [Friday, Barbara](#)
Subject: Permit No. 0310045-038-AV, JEA Northside Generating Station and St. Johns River Power Park
Date: Monday, December 03, 2012 7:54:48 AM
Attachments: [0310045-038-AV Signed Final Notice.pdf](#)
[0310045-038-AV Signed Final Permit.pdf](#)
[0310045-038-AV Final Notice.docx](#)
[0310045-038-AV Final Determination.docx](#)
[0310045-038-AV Revision SOB.doc](#)
[0310045-038-AV Final Permit.doc](#)
[0310045-038-AV Table H.doc](#)
[0310045-038-AV Appendices.doc](#)

Barbara: This is one ready to go.

I signed on behalf of Syed and Jeff.

Al Linero

Note to project file:

On November 12, 2012 we issued Permit No. 0310045-022-AC (PSD-FL-265E) to: remove the conditions regarding the mercury Continuous Emission Monitoring System requirements; allow the firing of up to 240 tons per day of biomass for each of the Northside Generating Station Boiler Nos. 1 and 2; and revise the description of St. Johns River Power Park Units 1 and 2 in Permit 0310045-030-AV to allow the operation of one scrubber tower during low load operations.

This Title V permitting action will roll over the changes described above into a revised Title V Air Permit.

We received this application on September 5, 2012.

Draft/Proposed Title V Air Operation Permit Renewal was distributed on October 8, 2012.

The time-to-process was 33 days.

Public Notice published on October 12, 2012.

The time-in-house was 89 days, most of which was consumed by the concurrent public comment and EPA review period of 45 days.

AAL 12/03/2012

TO: Jeff Koerner, Administrator
THROUGH: Syed Arif, P.E., Mineral and Metals Section
FROM: Edward J. Svec
DATE: November 29, 2012
SUBJECT: Title V Air Operation Permit No. 0310045-038-AV

JEA
NGS/SJRPP/ST Facility

Final Title V Air Operation Permit Revision

The final permit for this project is attached for your approval and signature.

The attached Final Determination identifies issuance of the draft/proposed Title V air operation permit and summarizes the publication process. There were no comments received from EPA or from the applicant or public in response to the draft/proposed permit.

I recommend your approval of the attached final permit for this project.