

Mitchell, Bruce

From: Boutwell, Barbara
Sent: Monday, May 14, 2001 9:40 AM
To: Elizabeth Bartlett; Fillingim, Mary; Gracy Danois; Gregg Worley; Joel Huey; Walker, Elizabeth (AIR)
Cc: Mitchell, Bruce
Subject: New Posting #0310047

There is a new posting on Florida's website.

0310047006AV
JEA - KENNEDY

Final Permit Revision

If you have any questions, feel free to contact me.

Thanks,
Barbara

Mitchell, Bruce

To: Boutwell, Barbara
Cc: Fancy, Clair; Sheplak, Scott
Subject: Posting of FINAL Title V Permit package: JEA - Kennedy Generating Station: 0310047-006-AV.

5/10/2001

Dear Barbara,

Please post the above reference T-5 package:

o:\Bar\Title V\Bruce\Permits.0310047.006
0310047F.006
0310047H.006
0310047.006.SOB
0310047U.006
0310047G.006
0310047.006FD

Many thanks.

Bruce

Mitchell, Bruce

From: Boutwell, Barbara
Sent: Monday, February 05, 2001 2:15 PM
To: Elizabeth Bartlett; Fillingim, Mary; Gracy Danois; Gregg Worley; Joel Huey; Walker, Elizabeth
Cc: Mitchell, Bruce
Subject: New Posting #0310047

There is a new posting on Florida's website.

0310047006AV
JEA - KENNEDY

Proposed

The notification letter is encoded and attached. If you have any questions, feel free to contact me.

Thanks,
Barbara

FEDNOT_P.UUE

Mitchell, Bruce

From: Mitchell, Bruce
Sent: Friday, February 02, 2001 10:30 AM
To: Boutwell, Barbara
Cc: Sheplak, Scott; Fancy, Clair
Subject: Posting of PROPOSED T-5 Permit Revision package: JEA - Kennedy Power Station: 0310047-006-AV.

2/2/01

Dear Barbara,

The above permit package is ready for posting for EPA review. It can be found at:
o:Bar/Title V/Bruce/Permits/0310047.006

Many thanks.

0310047P.006.FEDNO

B T.doc ruce

Boutwell, Barbara

To: epa
Cc: mitchell_b
Subject: New Posting #0310047

There is a new posting on Florida's website.

0310047006AV
JEA - KENNEDY

Draft Permit Revision

The notification letter is encoded and attached. If you have any questions, feel free to contact me.

Thanks,
Barbara



FEDNOTD.UUE

Mitchell, Bruce

From: Boutwell, Barbara
Sent: Thursday, December 07, 2000 10:00 AM
To: Elizabeth Bartlett; Fillingim, Mary; Gracy Danois; Gregg Worley; Joel Huey; Walker, Elizabeth
Cc: Mitchell, Bruce
Subject: New Posting #0310047

ATT13.FGN

ATT14.TXT

There is a new posting on Florida's website.

0310047006AV
JEA - KENNEDY

Draft Permit Revision

The notification letter is encoded and attached. If you have any questions, feel free to contact me.

Thanks,
Barbara
<<FEDNOTD.UUE>>

INTEROFFICE MEMORANDUM

Sensitivity: COMPANY CONFIDENTIAL

Date: 05-Dec-2000 03:16pm
From: Bruce Mitchell TAL
MITCHELL_B
Dept: Air Resources Management
Tel No: 850/488-1344

To: Barbara Boutwell TAL (BOUTWELL_B)
CC: Scott Sheplak TAL (SHEPLAK_S)
CC: Clair Fancy TAL (FANCY_C)

Subject: JEA: Kennedy Power Station: Permit Summary Page completed.

12/5/2000

Dear Barbara,

I have completed the Permit Summary Pages and the project, 0310047-006-AV, for the DRAFT Title V Permit Revision package. Thanks for catching the omissions and posting.

Bruce

Mitchell, Bruce

From: Gianazza, N. Bert [GianNB@jea.com]
Sent: Wednesday, December 20, 2000 1:58 PM
To: Mitchell, Bruce
Subject: Comments regarding Kennedy draft permit

Hi Bruce,

I wanted to get these comments to you. I'm still checking on what changes we might want to make to the the list of insignificant emissions units.

The only comments we have are:

- > 1. On page 36, under D.28., "Subject to EPA approval" should probably be removed. Using NOx CEMS for reporting excess emissions is already listed in CFR. Therefore, it is understood that this has already been approved by EPA.
- > 2. On page 41, under A.2., the EPA ID now labeled as 15 has been changed to 7 to better reflect the CT 7 name. The E.U. ID No. will still remain 015.

Let me know if you have any questions with regard to this.

Thanks, Bert (904) 665-6247 (pgr. 904-442-6225)

Bruce's copies

*3 x Responses/comments
received from JEA
regarding the DRAFT permit
after PN.*

Mitchell, Bruce

From: Gianazza, N. Bert [GianNB@jea.com]
Sent: Friday, December 22, 2000 10:03 AM
To: Mitchell, Bruce
Subject: Kennedy insignificant list

Bruce, since the plans for the empty tanks are unclear at this time, I think we'll just leave the list alone for now. Let me know if you have any questions.

Happy Holidays!

Bert

To: Bruce Mitchell
 From: Bert Gianazza

STATE OF FLORIDA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION

NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V OPERATION PERMIT

In the Matter of a Request for Administrative Correction:

Mr. Walter P. Bussells
 Managing Director
 Jacksonville Electric Authority
 21 West Church Street
 Jacksonville, Florida 32202

FINAL Permit No.: 0310047-001-AV
 Kennedy Generating Station

Enclosed is an ADMINISTRATIVELY CORRECTED page to the initial Title V operation permit 0310047-001-AV, for the operation of the JEA's Kennedy Generating Station located at 4215 Taileyrand Avenue, Jacksonville, Duval County. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code, and Chapter 403, Florida Statutes (F.S.). This change is made at the applicant's request received 06/11/99, to add a permitting note to Specific Condition C.13 to incorporate the heat input curves previously submitted during the initial Title V permitting action and referenced in Section I. Subsection C. Relevant Documents of the permit and listed as "Letter received October 22, 1997, from Mr. Bert Gianazza.". This corrective action does not alter the effective dates of the existing permit.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

C. H. Fancy
 for C. H. Fancy, P.E.
 Chief
 Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT (including the corrected page(s)) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on July 28, 1999 to the person(s) listed or as otherwise noted:

Mr. Walter P. Bussells*, Managing Director/Responsible Official, JEA
 Mr. Jon P. Eckenbach*, Executive Vice President/Designated Representative, JEA
 Mr. Richard Breitmoser, P.E., JEA
 Mr. Bert Gianazza, JEA, Application Contact
 Mr. Richard Robinson, AWQD
 Mr. Gregg Worley, USEPA, Region 4 (INTERNET E-mail Memorandum)
 Ms. Gracy R. Danois, USEPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Sandra G. Knight 07-28-99
 (Clerk) (Date)

ADMINISTRATIVE PERMIT CORRECTION

FINAL Permit No.: 0310047-001-AV

JEA: Kennedy Generating Station

Page 1 of 1

Specific Condition C.13. is hereby changed FROM:

C.13. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity (i.e., at less than 90 percent of the maximum operation rate allowed by the permit); in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted, provided however, operations do not exceed 100 percent of the maximum operation rate allowed by the permit. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rule 62-297.310(2), F.A.C.]

TO:

C.13. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity (i.e., at less than 90 percent of the maximum operation rate allowed by the permit); in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted, provided however, operations do not exceed 100 percent of the maximum operation rate allowed by the permit. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

{Permitting note: Attached (see "Attachment KGS: CT Heat Input Nominal Values") is a chart of the "Base Load MW" vs "Temperature" to aid in defining "full load" for visible emissions testing purposes, since the manufacturer's curves are not available. The heat input numbers are only nominal values.}

[Rule 62-297.310(2), F.A.C.]

Suggested language for CT 7:

{ Permitting Note: These heat input curves are nominal values to be used to aid in defining "full load" for stack testing purposes and do not constitute a limit on heat input. }